

December 23, 1999

Mr. Robert P. Powers, Senior Vice President  
Indiana Michigan Power Company  
Nuclear Generation Group  
500 Circle Drive  
Buchanan, MI 49107

SUBJECT: DONALD C. COOK NUCLEAR PLANT, UNITS 1 AND 2 - ISSUANCE OF  
AMENDMENTS RE: EMERGENCY CORE COOLING SYSTEM  
ACCUMULATORS (TAC NOS. MA7049 AND MA7050)

Dear Mr. Powers:

The U.S. Nuclear Regulatory Commission (NRC) has issued the enclosed Amendment No. 237 to Facility Operating License No. DPR-58 and Amendment No. 219 to Facility Operating License No. DPR-74 for the Donald C. Cook Nuclear Plant, Units 1 and 2. The amendment consists of changes to Appendix A, Technical Specifications (TSs), in response to your application dated November 5, 1999.

The proposed amendment would revise Unit 1 and 2 TS 3.5.1, Action "a" and "b," to reflect the monitoring pressure data from the Reactor Coolant System instead of the pressurizer. The amendment would also revise Unit 1 and 2 TS Surveillance Requirement (SR) 4.5.1.c to require verification that power is removed from each emergency core cooling system accumulator isolation valve operator instead of verification that each accumulator isolation valve breaker is removed from the circuit. Furthermore, the licensee proposes to make administrative changes to Unit 1 and 2 TS Bases 3/4.5.1.

A copy of our related Safety Evaluation Report is also enclosed. Notice of Issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,

ORIGINAL SIGNED BY:  
John F. Stang, Senior Project Manager, Section 1  
Project Directorate III  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-315 and 50-316

- Enclosures: 1. Amendment No. 237 to DPR-58
- 2. Amendment No. 219 to DPR-74
- 3. Safety Evaluation

cc w/encls: See next page

FILE CENTER

DFOI

DOCUMENT NAME: G:\PD31\DCCOOK12VAMDA7049

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy \*See previous concurrence

OFC	RGEB	E	PM:PD31	E	LA:PD31	E	SRXB	EEIB	OGC <i>RD</i>	SC:PD31	C
NAME	KLeigh*		JStang <i>JStang</i>		THarris <i>JH</i>		*JWermiel	*JCalvo	R Bachmann	CCraig <i>CC</i>	
DATE	12/6/99		12/10/99		12/10/99		12/13/99	12/17/99	12/17/99	12/22/99	

OFFICIAL RECORD COPY

PDR ADOCK

Mr. Robert P. Powers, Senior Vice President  
 Indiana Michigan Power Company  
 Nuclear Generation Group  
 500 Circle Drive  
 Buchanan, MI 49107

SUBJECT: DONALD C. COOK NUCLEAR PLANT, UNITS 1 AND 2 - ISSUANCE OF  
 AMENDMENTS RE: EMERGENCY CORE COOLING SYSTEM  
 ACCUMULATORS (TAC NOS. MA7049 AND MA7050)

Dear Mr. Powers:

The U.S. Nuclear Regulatory Commission (NRC) has issued the enclosed Amendment No. to Facility Operating License No. DPR-58 and Amendment No. to Facility Operating License No. DPR-74 for the Donald C. Cook Nuclear Plant, Units 1 and 2. The amendment consists of changes to Appendix A, Technical Specifications (TS), in response to your application dated November 5, 1999.

The proposed amendment would revise Unit 1 and 2 TS 3.5.1, Action "a" and "b," to reflect the monitoring pressure data from the Reactor Coolant System instead of the pressurizer. The amendment would also revise Unit 1 and 2 TS Surveillance Requirement (SR) 4.5.1.c to require verification that power is removed from each emergency core cooling system accumulator isolation valve operator instead of verification that each accumulator isolation valve breaker is removed from the circuit. Furthermore, the licensee proposes to make administrative changes to Unit 1 and 2 TS Bases 3/4.5.1.

A copy of our related Safety Evaluation Report is also enclosed. Notice of Issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,

John F. Stang, Project Manager  
 Project Directorate III  
 Division of Licensing Project Management  
 Office of Nuclear Reactor Regulation

Docket Nos. 50-315 and 50-316

- Enclosures: 1. Amendment No. to DPR-58  
 2. Amendment No. to DPR-74  
 3. Safety Evaluation Report

cc w/encls: See next page

DOCUMENT NAME: G:\PD31\DCCOOK12\AMDA .wpd

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	RGEB	E	PM:LPD31	E	LA:LPD31	E	OGC		SC:LPD31	
NAME	KLeigh	<i>JS</i>	JStang		THarris				CCraig	
DATE	<i>2/6</i> /99		/ /99		/ /99		/ /99		/ /99	

OFFICIAL RECORD COPY

Mr. Robert P. Powers, Senior Vice President  
 Indiana Michigan Power Company  
 Nuclear Generation Group  
 500 Circle Drive  
 Buchanan, MI 49107

SUBJECT: DONALD C. COOK NUCLEAR PLANT, UNITS 1 AND 2 - ISSUANCE OF  
 AMENDMENTS RE: EMERGENCY CORE COOLING SYSTEM  
 ACCUMULATORS (TAC NOS. MA7049 AND MA7050)

Dear Mr. Powers:

The U.S. Nuclear Regulatory Commission (NRC) has issued the enclosed Amendment No. to Facility Operating License No. DPR-58 and Amendment No. to Facility Operating License No. DPR-74 for the Donald C. Cook Nuclear Plant, Units 1 and 2. The amendment consists of changes to Appendix A, Technical Specifications (TSs), in response to your application dated November 5, 1999.

The proposed amendment would revise Unit 1 and 2 TS 3.5.1, Action "a" and "b," to reflect the monitoring pressure data from the Reactor Coolant System instead of the pressurizer. The amendment would also revise Unit 1 and 2 TS Surveillance Requirement (SR) 4.5.1.c to require verification that power is removed from each emergency core cooling system accumulator isolation valve operator instead of verification that each accumulator isolation valve breaker is removed from the circuit. Furthermore, the licensee proposes to make administrative changes to Unit 1 and 2 TS Bases 3/4.5.1.

A copy of our related Safety Evaluation Report is also enclosed. Notice of Issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,

John F. Stang, Senior Project Manager, Section 1  
 Project Directorate III  
 Division of Licensing Project Management  
 Office of Nuclear Reactor Regulation

Docket Nos. 50-315 and 50-316

- Enclosures: 1. Amendment No. to DPR-58  
 2. Amendment No. to DPR-74  
 3. Safety Evaluation

cc w/encls: See next page

DOCUMENT NAME: G:\PD31\DCCOOK12\AMDA7049

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy \*See previous concurrence

OFC	RGEB	E	PM:PD31	E	LA:PD31	E	SRXB	E	EEIB	OGC	SC:PD31
NAME	KLeigh*		JStang		THarris		JWermiel		JCalvo		CCraig
DATE	12/6/99		12/10/99		12/10/99		12/13/99		1/1999		1/1999

OFFICIAL RECORD COPY

Mr. Robert P. Powers, Senior Vice President  
 Indiana Michigan Power Company  
 Nuclear Generation Group  
 500 Circle Drive  
 Buchanan, MI 49107

SUBJECT: DONALD C. COOK NUCLEAR PLANT, UNITS 1 AND 2 - ISSUANCE OF  
 AMENDMENTS RE: EMERGENCY CORE COOLING SYSTEM  
 ACCUMULATORS (TAC NOS. MA7049 AND MA7050)

Dear Mr. Powers:

The U.S. Nuclear Regulatory Commission (NRC) has issued the enclosed Amendment No. to Facility Operating License No. DPR-58 and Amendment No. to Facility Operating License No. DPR-74 for the Donald C. Cook Nuclear Plant, Units 1 and 2. The amendment consists of changes to Appendix A, Technical Specifications (TSs), in response to your application dated November 5, 1999.

The proposed amendment would revise Unit 1 and 2 TS 3.5.1, Action "a" and "b," to reflect the monitoring pressure data from the Reactor Coolant System instead of the pressurizer. The amendment would also revise Unit 1 and 2 TS Surveillance Requirement (SR) 4.5.1.c to require verification that power is removed from each emergency core cooling system accumulator isolation valve operator instead of verification that each accumulator isolation valve breaker is removed from the circuit. Furthermore, the licensee proposes to make administrative changes to Unit 1 and 2 TS Bases 3/4.5.1.

A copy of our related Safety Evaluation Report is also enclosed. Notice of Issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,

John F. Stang, Senior Project Manager, Section 1  
 Project Directorate III  
 Division of Licensing Project Management  
 Office of Nuclear Reactor Regulation

Docket Nos. 50-315 and 50-316

- Enclosures: 1. Amendment No. to DPR-58  
 2. Amendment No. to DPR-74  
 3. Safety Evaluation

cc w/encls: See next page

DOCUMENT NAME: G:\PD31\DCCOOK12\AMDA7049

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy \*See previous concurrence

OFC	RGEB	E	PM:PD31	E	LA:PD31	E	SRXB	EEIB	OGC	SC:PD31
NAME	KLeigh*		JStang		THarris		JWermiel	JCalvo		CCraig
DATE	12/6/99		12/10/99		12/10/99		1/199	12/17/99	1/199	1/199

OFFICIAL RECORD COPY

12/13  
 #1  
 NPK

December 23, 1999

Mr. Robert P. Powers, Senior Vice President  
Indiana Michigan Power Company  
Nuclear Generation Group  
500 Circle Drive  
Buchanan, MI 49107

SUBJECT: DONALD C. COOK NUCLEAR PLANT, UNITS 1 AND 2 - ISSUANCE OF  
AMENDMENTS RE: EMERGENCY CORE COOLING SYSTEM  
ACCUMULATORS (TAC NOS. MA7049 AND MA7050)

Dear Mr. Powers:

The U.S. Nuclear Regulatory Commission (NRC) has issued the enclosed Amendment No. 237 to Facility Operating License No. DPR-58 and Amendment No. 219 to Facility Operating License No. DPR-74 for the Donald C. Cook Nuclear Plant, Units 1 and 2. The amendment consists of changes to Appendix A, Technical Specifications (TSs), in response to your application dated November 5, 1999.

The proposed amendment would revise Unit 1 and 2 TS 3.5.1, Action "a" and "b," to reflect the monitoring pressure data from the Reactor Coolant System instead of the pressurizer. The amendment would also revise Unit 1 and 2 TS Surveillance Requirement (SR) 4.5.1.c to require verification that power is removed from each emergency core cooling system accumulator isolation valve operator instead of verification that each accumulator isolation valve breaker is removed from the circuit. Furthermore, the licensee proposes to make administrative changes to Unit 1 and 2 TS Bases 3/4.5.1.

A copy of our related Safety Evaluation Report is also enclosed. Notice of Issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,

ORIGINAL SIGNED BY:  
John F. Stang, Senior Project Manager, Section 1  
Project Directorate III  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-315 and 50-316

- Enclosures: 1. Amendment No. 237 to DPR-58  
2. Amendment No. 219 to DPR-74  
3. Safety Evaluation

cc w/encls: See next page

DOCUMENT NAME: G:\PD31\DCCOOK12\AMDA7049

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy \*See previous concurrence

OFC	RGEB	E	PM:PD31	E	LA:PD31	E	SRXB	EEIB	OGC <i>GD</i>	SC:PD31	<i>C</i>
NAME	KLeigh*		JStang <i>JStang</i>		THarris <i>JH</i>		*JWermiel	*JCalvo	<i>R Bachmann</i>	CCraig <i>CC</i>	
DATE	12/6/99		12/10/99		12/10/99		12/13/99	12/17/99	12/17/99	12/22/99	

OFFICIAL RECORD COPY



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

December 23, 1999

Mr. Robert P. Powers, Senior Vice President  
Indiana Michigan Power Company  
Nuclear Generation Group  
500 Circle Drive  
Buchanan, MI 49107

SUBJECT: DONALD C. COOK NUCLEAR PLANT, UNITS 1 AND 2 - ISSUANCE OF  
AMENDMENTS RE: EMERGENCY CORE COOLING SYSTEM  
ACCUMULATORS (TAC NOS. MA7049 AND MA7050)

Dear Mr. Powers:

The U.S. Nuclear Regulatory Commission (NRC) has issued the enclosed Amendment No. 237 to Facility Operating License No. DPR-58 and Amendment No. 219 to Facility Operating License No. DPR-74 for the Donald C. Cook Nuclear Plant, Units 1 and 2. The amendment consists of changes to Appendix A, Technical Specifications (TSs), in response to your application dated November 5, 1999.

The proposed amendment would revise Unit 1 and 2 TS 3.5.1, Action "a" and "b," to reflect the monitoring pressure data from the Reactor Coolant System instead of the pressurizer. The amendment would also revise Unit 1 and 2 TS Surveillance Requirement (SR) 4.5.1.c to require verification that power is removed from each emergency core cooling system accumulator isolation valve operator instead of verification that each accumulator isolation valve breaker is removed from the circuit. Furthermore, the licensee proposes to make administrative changes to Unit 1 and 2 TS Bases 3/4.5.1.

A copy of our related Safety Evaluation Report is also enclosed. Notice of Issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,

A handwritten signature in black ink, appearing to read "John F. Stang".

John F. Stang, Senior Project Manager, Section 1  
Project Directorate III  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-315 and 50-316

Enclosures: 1. Amendment No. 237 to DPR-58  
2. Amendment No. 219 to DPR-74  
3. Safety Evaluation

cc w/encls: See next page

Donald C. Cook Nuclear Plant, Units 1 and 2

cc:

Regional Administrator, Region III  
U.S. Nuclear Regulatory Commission  
801 Warrenville Road  
Lisle, IL 60532-4351

Attorney General  
Department of Attorney General  
525 West Ottawa Street  
Lansing, MI 48913

Township Supervisor  
Lake Township Hall  
P.O. Box 818  
Bridgman, MI 49106

U.S. Nuclear Regulatory Commission  
Resident Inspector's Office  
7700 Red Arrow Highway  
Stevensville, MI 49127

David W. Jenkins, Esquire  
Indiana Michigan Power Company  
Nuclear Generation Group  
One Cook Place  
Bridgman, MI 49106

Mayor, City of Bridgman  
P.O. Box 366  
Bridgman, MI 49106

Special Assistant to the Governor  
Room 1 - State Capitol  
Lansing, MI 48909

Drinking Water and Radiological  
Protection Division  
Michigan Department of  
Environmental Quality  
3423 N. Martin Luther King Jr Blvd  
P.O. Box 30630, CPH Mailroom  
Lansing, MI 48909-8130

Robert C. Godley  
Director, Regulatory Affairs  
Indiana Michigan Power Company  
Nuclear Generation Group  
One Cook Place  
Bridgman, MI 49106

David A. Lochbaum  
Union of Concerned Scientists  
1616 P Street NW, Suite 310  
Washington, DC 20036-1495

A. Christopher Bakken, Site Vice President  
Indiana Michigan Power Company  
Nuclear Generation Group  
One Cook Place  
Bridgman, MI 49106

Michael W. Rencheck  
Vice President, Nuclear Engineering  
Indiana Michigan Power Company  
Nuclear Generation Group  
500 Circle Drive  
Buchanan, MI 49107