

From: Joseph B. Brady
To: Brian Bonser, Bruce Mallett, Carolyn Evans, Cha...
Date: Mon, May 17, 1999 1:52 PM
Subject: Re: Fwd: [NRC_CONCERNS] UCS Allegations re: Spent Fuel Storage at Harris Nuclear Pla

CP&L came to me this morning with a copy of the allegation. They were sent a copy via E-mail by Mr. Lochbaum on May 14. The numbers that he is concerned about (5400 gpm) for the existing A&B pools were used as worst case assumptions for the C&D pool calcs. The calc assumed that A&B would get max flow. The FSAR (section 9.1.3.3) states that the required flow for A&B pool SFP heat exchangers is 1789 gpm. I have faxed a copy of the appropriate pages of the calc to George MacDonald and Brian Bonser.

[REDACTED]

F45

[REDACTED]

F45

Joe

>>> Kenneth Clark 05/14 1:01 PM >>>

Here's a letter from UCS containing what it says are Harris spent fuel pool allegations. It's signed by D. L'baum of UOCS. it was apparently sent out by UCS as an email today. Diane Scrtenci, our RI senior PAO, is on the subscription list and forwarded it to me.

*When I try to right-click to open it, I get gobbledygook. When I left click, it opens.

CC: Anne Boland

H/1