

**CALCULATION TITLE PAGE**CALCULATION NO: **QDC 9400-M-0550 REV. 0**

STATION/UNIT: Quad Cities 1/2

TITLE: Control Room and Site Boundary Radiation Doses Following a CRDA

DESCRIPTION CODE: **R01** SYSTEM CODE: **VC**DISCIPLINE CODE: **M** ELEVATION CODE: **N/A** Safety Related       Augmented Quality Related       Non-Safety Related**REFERENCE NUMBERS:****Type****Number**

--	--

**COMPONENT EPN:****EPN****Comp Type**

--	--

**DOCUMENT NUMBERS:****Doc Type/ SubType****Document Number**

--	--	--

**REVISION SUMMARY:** initial issue



## Electronic Calculation Data Files:

(Program Name, Version, File name ext/size/date/hour/:min)

Type of Review:  Detailed       Alternate       Test       Repetitive Calc ReviewDO ANY ASSUMPTIONS IN THIS CALCULATION REQUIRE LATER VERIFICATION?  YES  NO

Tracked by: (NTS#, AT#, EWCS #, etc.)

Approvals required when initiating Calc Revision in accordance with Section C.5.4

Prepared by: Harry A. Wagage  SCI 11/30/1999  
Print/Sign/Initial Org. DateReviewed by: David A. Study  SCI 12/1/99  
Print/Sign/Initial Org. DateApproved by Joseph A. Signorelli, FOR M. Dowdman  SCI 12/1/99  
Print/Sign/Initial Org. DateSupplemental Review Required  Yes (NEP-12-05 documentation attached)  No  
Supervisor  (ComEd USE ONLY)

CALCULATION NO.: QDC 9400-M-0550 Rev. 0

**Table of Contents**

SECTION	PAGE NO.
TITLE PAGE	1
REVISION SUMMARY	1
TABLE OF CONTENTS	2
PURPOSE/OBJECTIVE	4
METHODOLOGY AND ACCEPTANCE CRITERIA	4
ASSUMPTIONS/ENGINEERING JUDGEMENTS	7
DESIGN INPUT	9
REFERENCES	12
CALCULATIONS	13
SUMMARY AND CONCLUSIONS	17
APPENDIX A (Page A1)	
<b>ATTACHMENTS:</b>	
A. QDC CRDA, TID-14844 Source Term (Page A1)	
B. QDC CRDA, TID-14844, LPZ & CR, MVP Release, Using ICRP-2 DCF's for Thyroid Dose (Pages B1 – B3)	
C. QDC CRDA, TID-14844, LPZ & CR, AOG Release, Using ICRP-2 DCF's for Thyroid Dose (Pages C1 – C6)	
D. QDC CRDA, TID-14844, LPZ & CR, Gland Release, Using ICRP-2 DCF's for Thyroid Dose (Pages D1 – D6)	
E. QDC CRDA, TID-14844, EAB, MVP Release, Using ICRP-2 DCF's for Thyroid Dose (Pages E1 – E3)	
F. QDC CRDA, TID-14844, EAB, AOG Release, Using ICRP-2 DCF's for Thyroid Dose (Pages F1 – F4)	
G. QDC CRDA, TID-14844, EAB, Gland Release, Using ICRP-2 DCF's for Thyroid Dose (Pages G1 – G4)	
H. QDC CRDA, Siemens 20 GWd/MTU, LPZ & CR, MVP Release, Using ICRP-2 DCF's for Thyroid Dose (Pages H1 – H3)	
I. QDC CRDA, Siemens 20 GWd/MTU, LPZ & CR, AOG Release, Using ICRP-2 DCF's for Thyroid Dose (Pages I1 – I6)	
J. QDC CRDA, Siemens 20 GWd/MTU, LPZ & CR, Gland Release, Using ICRP-2 DCF's for Thyroid Dose (Pages J1 – J6)	
K. QDC CRDA, Siemens 20 GWd/MTU, EAB, MVP Release, Using ICRP-2 DCF's for Thyroid Dose (Pages K1 – K3)	

CALCULATION NO.: QDC 9400-M-0550 Rev. 0

SECTION	PAGE NO.
L. QDC CRDA, Siemens 20 GWd/MTU, EAB, AOG Release, Using ICRP-2 DCF's for Thyroid Dose (Pages L1 – L4)	
M. QDC CRDA, Siemens 20 GWd/MTU, EAB, Gland Release, Using ICRP-2 DCF's for Thyroid Dose (Pages M1 – M4)	
N. QDC CRDA, Siemens 60 GWd/MTU, LPZ & CR, MVP Release, Using ICRP-2 DCF's for Thyroid Dose (Pages N1 – N3)	
O. QDC CRDA, Siemens 60 GWd/MTU, LPZ & CR, AOG Release, Using ICRP-2 DCF's for Thyroid Dose (Pages O1 – O6)	
P. QDC CRDA, Siemens 60 GWd/MTU, LPZ & CR, Gland Release, Using ICRP-2 DCF's for Thyroid Dose (Pages P1 – P6)	
Q. QDC CRDA, Siemens 60 GWd/MTU, EAB, MVP Release, Using ICRP-2 DCF's for Thyroid Dose (Pages Q1 – Q3)	
R. QDC CRDA, Siemens 60 GWd/MTU, EAB, AOG Release, Using ICRP-2 DCF's for Thyroid Dose (Pages R1 – R4)	
S. QDC CRDA, Siemens 60 GWd/MTU, EAB, Gland Release, Using ICRP-2 DCF's for Thyroid Dose (Pages S1 – S4)	

CALCULATION NO.: QDC 9400-M-0550 Rev. 0

## 1. PURPOSE/OBJECTIVE

The purpose of this calculation is to determine the control room and offsite doses due to a control rod drop accident (CRDA) assuming that the main steam line radiation monitors (MSLRM) no longer provide a signal for automatic closure of the main steam line isolation valves (MSIVs). This calculation is to support Technical Specifications changes and updated final safety analysis report (UFSAR) revisions on the elimination of the need for automatic closure of MSIVs on high MSLRM signals. [5.1, 5.2]

## 2. METHODOLOGY AND ACCEPTANCE CRITERIA

### 2.1. METHODOLOGY

#### 2.1.1. General Information

This calculation was based on the methods established in §15.4.9 of the Standard Review Plan (SRP). [5.3] The methodology used is consistent with that used by Bechtel Power Corporation on performing similar analysis for the Dresden Nuclear Plant, which is similar in design to Quad Cities. [5.4] The radiological consequences of a CRDA to the control room operators and the offsite population were assessed with the SCIENTECH-NUS "AXIDENT" computer code which is a transient control room and site boundary dose analysis code. [5.5] The AXIDENT program was executed on a Dell Inspiron 3000 computer running a Windows NT Version 4.0 operating system as currently assigned to Harry Wagage (owned by Matrix Leasing, no. 210158). Satisfactory operation of the AXIDENT code on this computer has been confirmed by revalidation. [5.6] There have been no hardware or software changes since this revalidation and therefore the verification/baseline is still valid.

In the 1991 time frame, the BWR Owner's Group requested permission from the NRC to eliminate MSIV automatic closure function and scram function of the MSLRM. The MSLRM provided protection from a CRDA by isolating the MSIVs and thus limiting the quantity of activity released.

General Electric documented the generic safety evaluation of eliminating the MSIV action on high radiation alarm in NEDO 31400A which has been accepted by the NRC for reference in licensing applications. [5.7]

#### 2.1.2. Source Term

A source term for activity to be released was developed based on the guidelines of NEDO 31400A, which is for a generic plant, SRP 15.4.9, and plant specific data for Quad Cities. [5.7,

PEPP-E FORM

## CALCULATION NO.: QDC 9400-M-0550 Rev. 0

5.3] A model to evaluate the CRDA was developed to include source term contributions from the main steam line and the gland steam line, their leakage paths and release points. The total radioactive inventory of the core was calculated based on TID 14844 methodology and Siemens 20 and 60 GWd/MTU fuels. [5.8, 5.9]

The source term derived from TID-14844, which was published in 1962, is referred in this report as the TID source term. [5.8] The TID source term is expressed as curies per MWt and reflects fission product yields of U-235 for low burnup fuels as was the case in the 1960s. With the advent of higher burnup fuel (i.e. greater than 35,000 MW days per ton), plutonium fission becomes important. The fission product yields of Pu-239 are different from the U-235 yields. As the contribution of Pu-239 increases, the core fission product inventories change from that initially dominated by U-235 fission. This change is evident in the Siemens fission product inventories included in reference 5.9 for burnup of 20,000, 40,000 and 60,000 MW days per ton. [5.9]

The source term that is used in the AXIDENT code was calculated using equation 1, which accounts for various source term reduction/enhance mechanisms and compensates for the automatic reduction of iodine isotopes in the code.

$$Q_{in} = f_n Q_{cn} \quad (1)$$

where

$$f_n = f_{ff} f_g f_p f_{cn} f_m f_{an} \quad (2)$$

where

$Q_{in}$	Activity of isotope n, which is input to the code
$f_{ff}$	Fuel-specific fraction of failed fuel in the core following the CRDA
$F_g$	Fraction of activity of the fuel that is available for release from the gap
$F_p$	Power peaking factor of the core
$f_{cn}$	Fraction of activity of isotope n in the coolant which is transported to the condenser
$f_{rn}$	Fraction of activity of isotope n in the condenser which is available for release
$f_{an}$	Factor for isotope n to compensate for automatic reduction in the AXIDENT code
$Q_{cn}$	Activity of isotope n that is available in the core

### 2.1.3. Dose Conversion Factors for Thyroid from Inhalation of Iodine

The existing licensing basis accident analysis is based on the dose conversion factors (DCF's), which were referenced in Regulatory Guide 1.3 and TID-14844. [5.14, 5.8] The basis was ICRP Publication 2, which was published, in the early 1960's. [5.16] Since the publishing of ICRP-2, work has been and continues to be performed in both the U.S. and overseas on developing new

CALCULATION NO.: QDC 9400-M-0550 Rev. 0

DCF's. Regulatory Guide 1.109 recommends DCF's that are significantly lower than those recommended do in Regulatory Guide 1.3 or TID-14844. [5.15, 5.14, 5.8] ICRP Publication 30 issued in 1979 provides even lower DCF's. [5.13] The DCF's based on ICRP-30 have been collected and "processed" and are conveniently published in Federal Guidance Report-11. [5.17] Although ICRP-30 DCF's have not been included in a regulatory guide for use in accident analyses, they have been submitted and approved by NRC in a number of Post-TMI Control Room Habitability analyses. Table 1 compares DCF's for iodine isotopes from different sources.

This analysis used the ICRP 2 DCF's to calculate thyroid doses. The thyroid doses, which were calculated using ICRP 30 DCF's are given for information.

**Table 1. Thyroid Dose Conversion Factors for Inhalation of Iodine, rem per curie inhaled**

Isotope	Dose Conversion Factor (rem/Ci)		
	ICRP 2 [5.16, 5.8]	RG 1.109 [5.15]	ICRP 30 [5.13, 5.17]
I-131	1.48E+6	1.49E+6	1.10E+6
I-132	5.35E+4	1.43E+4	6.30E+3
I-133	4.00E+5	2.69E+5	1.80E+5
I-134	2.50E+4	3.73E+3	1.10E+3
I-135	1.24E+5	5.60E+4	3.10E+4

#### 2.1.4. CRDA Model

The plant has been configured so that the main steam isolation valves do not close on high radiation in the main steam line. Two release paths, 1) main steam to the turbine/condenser and 2) gland seal steam to the gland steam condenser were considered. The mechanical vacuum pumps (MVP's) are assumed to operate until they are isolated on a high radiation signal from the MSLRM.<sup>1</sup>. All the release from the main steam condenser was assumed to pass through MVP's without being filtered. After isolation of the MVP's, all the release from the main steam condenser was assumed to pass through filters of the augmented offgas system.

<sup>1</sup> The MSLRM trip function for the mechanical vacuum pump is not impacted by the proposed change.

CALCULATION NO.: QDC 9400-M-0550 Rev. 0




Figure 1. Schematic diagram of radioactivity release flow paths

## 2.2. ACCEPTANCE CRITERIA

This analysis is intended to confirm that the calculated doses resulting from a design basis CRDA for the control room operator, a person at the EAB, and a person at the LPZ are less than the regulatory dose limits as given in table 2.

Table 2. Regulatory Dose Limits

Dose Type	Control Room (rem)	EAB and LPZ (rem)
Thyroid Dose	30 <sup>a</sup>	75 <sup>b</sup>
Whole Body Dose	5 <sup>a</sup>	6 <sup>b</sup>
Beta Skin Dose	30 <sup>a</sup>	-

Notes: <sup>a</sup> SRP, Section 6.4, Acceptance Criteria-6 [5.3]

<sup>b</sup> SRP 15.4.9 [5.3]

## 3. ASSUMPTIONS/ENGINEERING JUDGEMENTS

- 3.1 The steam jet air ejectors are in operation and all leakage from the main condenser passes through to the augmented off gas system for ultimate release from the plant stack. (NEDO 31400A, § 6.1) [5.7]
- 3.2 The augmented off gas system removes all Iodides from the flow passing through the system from the condenser. (Basis: The augmented off gas system has deep bed charcoal filters which are very efficient at iodine removal.)

## CALCULATION NO.: QDC 9400-M-0550 Rev. 0

- 3.3 Coincident Loss of power occurs at time of accident. (SRP 15.4.9 Appendix A, III-1) [5.3]
- 3.4 No fuel melting would occur at Quad Cities during a CRDA. (Quad Cities UFSAR 15.4.10.5 [5.2])
- 3.5 Since no fuel melting would occur the only release from the fuel rods is a gap release. 10% of the noble gas inventory and 10% of the radioiodine inventory will be released from the fuel to the reactor coolant during the gap release. (Regulatory Guide 1.77; SRP 15.4.9 Appendix A, III-5) [5.10, 5.3]
- 3.6 As in NEDO-31400A, the CRDA is assumed to result in the failure of 850 fuel rods. [5.7] The peaking factor is 1.5. [5.3]
- 3.7 Core 102% power was used to account for uncertainty in the core power level.
- 3.8 Gap activity from failed fuel is assumed to mix instantaneously with the reactor coolant. (SRP 15.4.9 Appendix A, III-8) [5.3]
- 3.9 Ten per cent of all iodides and 100% of all noble gases are transported to the turbine/condenser. (SRP 15.4.9 Appendix A, III-9) [5.3]
- 3.10 100% of all noble gases are available for release from the turbine condenser. (SRP 15.4.9 Appendix A, III-10) [5.3]
- 3.11 90% of all iodine isotopes plate out leaving only 10% in the gaseous form available for release from the turbine condenser. (SRP 15.4.9 Appendix A, III-11) [5.3] Note: This assumption not used for release to the AOG system since all iodine isotopes would be trapped in the deep bed charcoal filters.
- 3.12 The main steam turbine condenser leaks to the atmosphere for 24 hours. (SRP 15.4.9 Appendix A, III-10) [5.3]
- 3.13 No credit had been taken for decay due to hold up in the gland steam condenser. (SRP 15.4.9 Appendix A, III-13) [5.3]
- 3.14 Atmospheric dispersion factors, breathing rates and dose conversion factors are the same as those use in the dose calculation for loss of coolant accident. (SRP 15.4.9 Appendix A, III-14) [5.3] Note: These parameters are given in references 5.11 and 5.12.
- 3.15 The reactor scrams in six seconds with reduction of steam flow. MVPs also will be isolated at the same time.
- 3.16 Steam flow rate after initiation of CRDA is 5% of its full power value.
- 3.17 Before the MVPs are isolated all exhaust from the main steam condenser was assumed to release bypassing the AOG.
- 3.18 After the MVPs are isolated all exhaust from the main steam condenser was assumed to release through the AOG.
- 3.19 The exhaust rate from the main steam condenser was assumed to be 100% per day. This is conservative because this would amount to about 64 scfm, which is higher than expected following the scram. Plus we would still have an active SJAE isolation.

CALCULATION NO.: QDC 9400-M-0550 Rev. 0

## 4. DESIGN INPUT

### 4.1. Source Term Data

#### 4.1.1. TID Source Term

▪ Total number fuel assemblies in the core	724
▪ Number of fuel rods per fuel assembly (8x8 fuel assembly) <sup>2</sup>	63
• Iodine Fractions (Reg. Guide 1.3) [5.14]	
Organic	0.04
Elemental	0.91
Particulate	0.05

#### 4.1.2. Siemens Fuel Source Term [5.9]

▪ Number of fuel assemblies in the core	724
▪ Number of fuel rods per fuel assembly	72
▪ MW/MTU	22.0
▪ MTU/core	121.632
▪ Burnup (GWd/MTU)	20                  60
▪ Core Residence Times (days)	909                  2727
▪ Core isotope inventory for Siemens 20 GWd /MTU fuel (2676 MWt core)	Table 3
▪ Core isotope inventory for Siemens 60 GWd/MTU fuel (2676 MWt core)	Table 3

<sup>2</sup> 850 failed rods bounds the 8X8 and 9X9 fuel per the UFSAR 15.4.10.4.

CALCULATION NO.: QDC 9400-M-0550 Rev. 0

#### 4.2. Plant Data

Some of the input data were obtained from the Dresden Nuclear Power Plant because they were readily available in reference 5.4. Due to similarities of the plants, it is acceptable to use the Dresden inputs and references.

▪ Flow rate of main steam [5.4]	9.7006E6 lb/hr <i>(Note that the above value of main steam flow, which was obtained from Dresden, is 0.6% lower than that at Quad Cities (9.759E6 lb/hr). The impact of this difference on results is negligible and is well compensated by the other conservatisms used in the calculation.)</i>
▪ Flow rate of gland steam [5.4]	1.50E4 lb/hr
▪ Specific volume of steam [5.4]	0.445 ft <sup>3</sup> /lb
▪ Volume of primary system (MSL and dome) (Conservatively reduced from 8,431 ft <sup>3</sup> ) [5.4]	5,000 ft <sup>3</sup>
▪ Design flow rate of MVP (UFSAR 15.4.10.5) [5.2]	5,000 ft <sup>3</sup> /min
▪ Time of isolation of MVP	6 s
▪ Free volume of the condenser (UFSAR 15.4.10.5) [5.2]	92,000 ft <sup>3</sup>
▪ Volume of water in the condenser (UFSAR 15.4.10.5) [5.2]	11,000 ft <sup>3</sup>
▪ Delay to reactor scram (UFSAR 15.4.10.3) [5.2]	6 s
▪ Power Level, MWt (UFSAR 15.4.10.5, SRP 15.5.4 [5.2, 5.3] - (2511 x 1.02))	2561

CALCULATION NO.: QDC 9400-M-0550 Rev. 0

**Table 3. Core Isotope Inventory for Siemens 20 and 60 GWd/MTU Fuels [5.9]**

Isotope	Activity (Ci/Core)	
	20 GWd/MTU	60 GWd/MTU
I-131	7.22E7	7.94E7
I-132	1.04E8	1.11E8
I-133	1.45E8	1.41E8
I-134	1.68E8	1.58E8
I-135	1.30E8	1.24E8
Xe-131m	5.16E5	6.70E5
Xe-133m	3.49E6	3.47E6
Xe-133	1.45E8	1.42E8
Xe-135m	3.93E7	3.79E7
Xe-135	4.78E7	3.52E7
Xe-137	1.37E8	1.40E8
Xe-138	1.31E8	1.35E8
Kr-83m	7.78E6	3.58E6
Kr-85m	2.13E7	1.37E7
Kr-85	9.73E5	1.95E6
Kr-87	4.18E7	2.57E7
Kr-88	6.05E7	3.81E7
Kr-89	7.67E7	4.65E7

#### **4.3. Atmospheric Dispersion Factors**

Table 4 gives the atmospheric dispersion factors, which were used in the calculation.

**Table 4. Atmospheric Dispersion Factors for Stack Release**

Location	Duration	$\frac{\chi}{Q}$ (s/m <sup>3</sup> )	Reference
EAB	0 - ½ hr	2.9E-4	Calc. QDC-7500-M-0387 [5.11]
	½ - 2 hr	2.3E-5	
LPZ	0 - ½ hr	3.2E-5	Calc. QDC-7500-M-0387 [5.11]
	½ - 8 hr	9.0E-6	
	8 - 24 hr	3.0E-6	
Control Room	0 - 2 hr	7.00E-4	Calc. QDC-9400-M-0363 [5.12]
	2 - 8 hr	6.45E-6	
	8 - 24 hr	3.81E-6	

CALCULATION NO.: QDC 9400-M-0550 Rev. 0

## 5. REFERENCES

- 5.1 Quad Cities Technical Specifications:
  - Basis Section 2.2.A. Reactor Protection System Instruments Set Points
  - Table 2.2.A-1. Reactor Protection System Instruments Set Points
  - Table 3.1.A-1. Reactor Protection System Instruments
  - Table 3.2.A-1. Isolation Actuation Instrumentation
  - Table 4.1.A-1. Reactor Protecting System Instruments Surveillance Requirements
  - Table 4.2.A-1. Isolation Actuation Instrumentation Surveillance Requirements
- 5.2 Quad Cities UFSAR.
- 5.3 NUREG-0800, Standard Review Plan, Rev. 2, July 1981:
  - Section 6.4, "Control Room Habitability Systems,"
  - Section 15.4.9, Radiological Consequences of Control Rod Drop Accident (BWR), Appendix A
- 5.4 Bechtel Power Corporation, "Control Rod Drop Accident/ MSLRM Removal," DR-357-M-004, Revision 0, 3/1/96.
- 5.5 HALLIBURTON NUS "AXIDENT, A Digital Computer Dose Calculation Model," Version 2, Mod 4, dated 2/18/92.
- 5.6 Software Verification Memo from H. Wagage to T. Bladen dated 7/8/98.
- 5.7 General Electric Company, "Safety Evaluation for Eliminating the boiling Water Reactor Main Steam Isolation Valve Closure Function and Scram Function of the Main Steam Line Radiation Monitor," NEDO 31400A, October 1992.
- 5.8 TID-14844, Calculation of Distance Factors for Power and Test Reactor Sites, U.S. Atomic Energy Commission Technical Information Document, March 23, 1962
- 5.9 Siemens Letter, JHR:96:188, from J. H. Riddle (Siemens) to Ronald J. Chin (Commonwealth Edison) on "Radioactive Release Analysis Source Term Values," May 20, 1996.
- 5.10 U.S. NRC Regulatory Guide 1.77, "Assumptions Used for Evaluating a Control Rod Ejection Accident for Pressurized Water Reactors," 5/1/74
- 5.11 QDC-9400-M-0363, "Quad Cities Control Room Habitability with Revised Dose Analysis Methodology," Revision 1, August 1998.
- 5.12 Calculation QDC 7500-M-0387, "Quad Cities EAB and LPZ LOCA Doses with Revised Dose Analysis Methodology," Revision 1, August 1998.
- 5.13 ICRP Publication 30, "Limits for Intakes of Radionuclides by Workers," 1979.
- 5.14 Regulatory Guide 1.3, Assumptions Used For Evaluating The Potential Radiological Consequences of a Loss of Coolant Accident for Boiling Water Reactors, Revision 2, June 1974.
- 5.15 Regulatory Guide 1.109, "Calculation of Annual Doses to Man from Radioactive Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10 CFR 50 Appendix I," Revision 1, 1977.

CALCULATION NO.: QDC 9400-M-0550 Rev. 0

- 5.16 ICRP Publication 2, "Report of Committee II, Permissible Dose for Internal Radiation," 1959.
- 5.17 Federal Guidance Report No. 11, Sept 1988.

## 6. CALCULATION

### 6.1. *Source Term*

The radioactive inventory in the core for the TID source term was calculated by running the accident code as given in attachment 1. The calculated inventories are listed in table 5. The fractional release for iodine and noble gas groups were calculated using equation 2 and listed in table 6. Table 6 also lists the factors used for the calculation. The fraction of failed fuel in the core following the CRDA for TID source term as given in table 6 was calculated as follows:

$$f_{ff\ TID} = \frac{(850 \text{ rods failed})}{(724 \text{ fuel assemblies per core})(63 \text{ rods per fuel assembly})} \\ = 0.0186$$

$$f_{ff\ Siemens} = \frac{(850 \text{ rods failed})}{(724 \text{ fuel assemblies per core})(72 \text{ rods per fuel assembly})} \\ = 0.0163$$

CALCULATION NO.: QDC 9400-M-0550 Rev. 0

**Table 5. Core Inventory and Source Terms Used for the AXIDENT Code Input for TID-14844 Source Term and Siemens Fuels [5.8, 5.9]**

Isotope	TID-14844 fission products		Siemens Fuel					
	Core Inventory (Ci)	AXIDENT Input (Ci)	20 GWd/MTU			60 GWd/MTU		
			Core Inventory (Ci)	AXIDENT Input (Ci)	2676 MWt [5.9]	2561 MWt	Core Inventory (Ci)	AXIDENT Input (Ci)
I-131	6.446E+7	7.16E+3	7.22E+7	6.91E+7	6.76E+3	7.94E7	7.60E+7	7.43E+3
I-132	9.592E+7	1.06E+4	1.04E+8	9.95E+7	9.73E+3	1.11E8	1.06E+8	1.04E+4
I-133	1.482E+8	1.65E+4	1.45E+8	1.39E+8	1.36E+4	1.41E8	1.35E+8	1.32E+4
I-134	1.728E+8	1.92E+4	1.68E+8	1.61E+8	1.57E+4	1.58E8	1.51E+8	1.48E+4
I-135	1.373E+8	1.52E+4	1.30E+8	1.24E+8	1.22E+4	1.24E8	1.19E+8	1.16E+4
XE-131M	4.874E+5	1.36E+3	5.16E+5	4.94E+5	1.21E+3	6.70E5	6.41E+5	1.57E+3
XE-133M	3.766E+6	1.05E+4	3.49E+6	3.34E+6	8.18E+3	3.47E6	3.32E+6	8.14E+3
XE-133	1.482E+8	4.13E+5	1.45E+8	1.39E+8	3.40E+5	1.42E8	1.36E+8	3.33E+5
XE-135M	3.987E+7	1.11E+5	3.93E+7	3.76E+7	9.21E+4	3.79E7	3.63E+7	8.89E+4
XE-135	1.396E+8	3.89E+5	4.78E+7	4.57E+7	1.12E+5	3.52E7	3.37E+7	8.25E+4
XE-138	1.307E+8	3.65E+5	1.31E+8	1.25E+8	3.07E+5	1.35E8	1.29E+8	3.17E+5
KR-83M	1.152E+7	3.21E+4	7.78E+6	7.45E+6	1.82E+4	3.58E6	3.43E+6	8.39E+3
KR-85M	2.880E+7	8.04E+4	2.13E+7	2.04E+7	4.99E+4	1.37E7	1.31E+7	3.21E+4
KR-85	9.665E+5	2.70E+3	9.73E+5	9.31E+5	2.28E+3	1.95E6	1.87E+6	4.57E+3
KR-87	5.538E+7	1.55E+5	4.18E+7	4.00E+7	9.80E+4	2.57E7	2.46E+7	6.03E+4
KR-88	7.886E+7	2.20E+5	6.05E7	5.79E+7	1.42E+5	3.81E7	3.65E+7	8.93E+4

\* Note: Core inventory was calculated by AXIDENT code using TID-14844 methodology. [5.5, 5.8]

**Table 6. Factors Used to Calculate Fractional Release for Iodine and Noble Gas Groups**

Factor		Iodine	Noble Gas
Fuel-specific fraction of failed fuel in the core following the CRDA	$f_f$ TID-14844 fission products Siemens Fuel	0.0186	
Fraction of activity of the fuel that is available for release from the gap	$f_g$	0.1	
Power peaking factor of the core	$f_p$	1.5	
Fraction of activity of isotope n in the coolant which is transported to the condenser	$f_{cn}$	0.1	1
Fraction of activity of isotope n in the condenser which is available for release	$f_{rn}$	0.1	1
Factor for isotope n to compensate for automatic reduction in the AXIDENT code	$f_{an}$	4	1
Resultant Factor	$f_n$ TID-14844 fission products Siemens Fuel	1.11E-4	2.79E-3
		9.78E-5	2.45E-3

CALCULATION NO.: QDC 9400-M-0550 Rev. 0

## 6.2. Source Term Release Data

### 6.2.1. Primary Leakage

The primary leakage rate for main steam at full power is calculated as follows:

$$\begin{aligned} \text{primary leakage main steam} &= \frac{\text{steam volume flow}}{\text{steam volume}} \\ &= \frac{\left( 9.7006E6 \frac{\text{lb}}{\text{h}} \right) \left( 0.445 \frac{\text{ft}^3}{\text{lb}} \right) \left( \frac{1}{3600} \frac{\text{s}}{\text{h}} \right)}{5000 \text{ ft}^3} \\ &= 0.2398 \text{ s}^{-1} \end{aligned}$$

The primary leakage rate for gland steam at full power is calculated as follows:

$$\begin{aligned} \text{primary leakage gland steam} &= \frac{\text{steam volume flow}}{\text{steam volume}} \\ &= \frac{\left( 1.500E4 \frac{\text{lb}}{\text{h}} \right) \left( 0.445 \frac{\text{ft}^3}{\text{lb}} \right) \left( \frac{1}{3600} \frac{\text{s}}{\text{h}} \right)}{5000 \text{ ft}^3} \\ &= 3.708E-4 \text{ s}^{-1} \end{aligned}$$

$$\begin{aligned} \text{Total primary leakage at full power} &= (0.2398 + 3.708E-4) \text{ s}^{-1} \\ &= 0.24017 \text{ s}^{-1} \end{aligned}$$

$$\begin{aligned} \text{The fraction of primary leakage through the main steam line} &= (0.2398 \text{ s}^{-1}) / (0.24017 \text{ s}^{-1}) \\ &= 0.99846 \end{aligned}$$

$$\begin{aligned} \text{The fraction of primary leakage through the gland line} &= (3.708E-4 \text{ s}^{-1}) / (0.24017 \text{ s}^{-1}) \\ &= 1.544E-3 \end{aligned}$$

After reactor scram at 6 seconds the steam flow is reduced to 5% of its full power value. The primary leakage rate for main steam after reactor scram is calculated as follows:

$$\text{primary leakage} = 0.05 * 0.2398 \text{ sec}^{-1} = 1.199E-2 \text{ s}^{-1}$$

CALCULATION NO.: QDC 9400-M-0550 Rev. 0

The primary leakage rate for gland steam after reactor scram is calculated as follows:

$$\text{primary leakage} = 0.05 * 3.708E - 4 \text{ s}^{-1} = 1.854E - 5 \text{ s}^{-1}$$

$$\text{Total primary leakage rate after reactor scram} = (1.199E-2 + 1.854E-5) \text{ s}^{-1} = 1.201E-2 \text{ s}^{-1}$$

The primary leak rate terminates at 24 hours after the event.

### **6.2.2. Secondary Leakage**

The secondary leakage is the rate at which activity is transported from the condenser to the release point expressed in volumes per second. The release point for the main condenser is the chimney by way of the augmented offgas system (AOG).

#### **6.2.2.1. SJAЕ-AOG Pathway**

The SRP assumes the CRD radioactivity release is transported to the condenser, the MSIVs close and the SJAЕs do not exhaust radioactivity from the condenser. The radioactivity in the condenser leaks to the environment at the rate of 1 volume per day.

The present plant configuration has removed the MSLRM trip function. The above SRP scenario is therefore not applicable. Thus, in a CRDA the MSIVs remain open allowing the SJAЕ to remain in operation. Radioactivity from the CRDA is exhausted through the SJAЕ and the AOG and discharged through the condenser to the station chimney. The exhaust rate from the condenser to the AOG is conservatively assumed to be 100% per day (§ 3.17).

Leakage rate of the main condenser is calculated as follows:

$$\begin{aligned}\text{secondary leakage} &= \left( 1 \frac{\text{volume}}{\text{day}} \right) \left( \frac{1}{86,400} \frac{\text{day}}{\text{s}} \right) \\ &= 1.157E - 5 \text{ s}^{-1}\end{aligned}$$

#### **6.2.2.2. Gland Steam Discharge Pathway**

Instantaneous leakage to the environment is assumed for the gland steam condenser. No credit is taken for iodide removal through absorption in water or plate out. Thus, this assumption is conservative. The secondary leakage is set at 1 volume per second.

### **6.3. Secondary Activity Reductions and Cleanup**

For the release to the AOG system and the plant stack, the iodine species will be effectively and efficiently trapped in the deep bed charcoal filters. As such the non-removal factor for the secondary is set to zero for particulate, gaseous, and organic iodides. The noble gases will be

## CALCULATION NO.: QDC 9400-M-0550 Rev. 0

retained in the AOG for a hold up period allowing some reduction in activity. For this calculation, no credit is taken for noble gas holdup in the AOG.

#### **6.4. AXIDENT Evaluation**

The AXIDENT code was used to calculate the release on the basis of the total flow going to each of the two release paths. The detailed computer outputs are given in attachments 2 through 13. The releases were weighted by the ratio of the flow going to a specific path to the total flow and summed to obtain the dose at the control room, the low population zone, and the exclusion area boundary. As calculated in §6.2.1, 99.83% of release contribution results from the leakage from the main steam condenser, which passes through SJAE-AOG, and released to the environment as an elevated release. The balance of 0.153% of release contribution results from the leakage from gland steam. Table 7 shows contribution from each path, which was calculated from AXIDENT-calculated dose values and the above weighting factors and the total dose. Table 7 shows that the doses from TID-14844 source term are more limiting than that from the two Siemens source terms. Table 8 compares the limiting dose results, i.e., for the TID-14844 source term, with the SRP limits. Table 8 shows that the calculated limiting doses are well below the SRP limits.

Appendix A gives the AXIDENT code runs made with ICRP-30 DCF's for the MVP and gland seal release pathways to determine the effect of lower DCF's than ICRP-2 DCF's, which were used for the base case calculations. Table 9 compares the thyroid doses calculated using ICRP-2 and ICRP-30 DCF's. The thyroid doses calculated with ICRP 30 DCF's give between 40 – 43 % reduction of doses than that calculated with ICRP-2 DCF's.

## **7. SUMMARY AND CONCLUSIONS**

This calculation is to support Technical Specifications changes and updated final safety analysis report (UFSAR) revisions on the elimination of the need for automatic closure of MSIVs on high MSLRM signals. [5.1, 5.2] The calculated doses at control room, LPZ, and EAB following a design basis CRDA are listed in table 7. These doses are within the established regulatory guidelines as show in table 2. As such, the CRDA without actuation of the MSIV's is a minimal risk to plant operators and the general public.

STATION/UNIT: Quad Cities 1/2

NEP-12-02.01

Effective Date: 11/4/99

Page 18 of 19

CALCULATION NO.: QDC 9400-M-0550 Rev. 0

**Table 7. Summary of Doses Calculated at LPZ, Control Room, and EAB for TID and Siemens Source Terms Using ICRP-2 DCF's\***

Fuel Type	Path	LPZ			Control Room			EAB			Att.	
		Dose (Rem)			Att.	Dose (Rem)			Att.	Dose (Rem)		
		Thyroid	Whole Body	Beta		Thyroid	Whole Body	Beta		Thyroid	Whole Body	
TID-14844	MVP	0.143	3.73E-2	1.42E-2	B	2.98	8.78E-3	0.176	B	1.29	0.338	0.128 E
	AOG	0	0.412	0.241	C	0	0.195	3.94	C	0	2.11	0.912 F
	Gland	8.63E-2	2.25E-2	8.52E-3	D	1.81	5.31E-3	0.106	D	0.781	0.204	7.72E-2 G
	Total	0.229	0.472	0.263	-	4.78	0.209	4.23	-	2.07	2.65	1.12 -
Siemens 20 GWd/MTU	MVP	0.127	2.79E-2	9.58E-3	H	2.65	5.56E-3	0.107	H	1.15	0.253	8.68E-2 K
	AOG	0	0.267	0.142	I	0	0.116	2.22	I	0	1.49	0.579 L
	Gland	7.66E-2	1.67E-2	5.76E-3	J	1.61	3.37E-3	6.44E-2	J	0.693	0.152	5.22E-2 M
	Total	0.203	0.311	0.157	-	4.25	0.125	2.39	-	1.84	1.89	0.718 -
Siemens 60 GWd/MTU	MVP	0.132	2.53E-2	8.37E-3	N	2.77	4.22E-3	0.087	N	1.20	0.229	7.58E-2 Q
	AOG	0	0.212	0.118	O	0	8.24E-2	1.75	O	0	1.27	0.482 R
	Gland	7.98E-2	1.52E-2	5.03E-3	P	1.68	2.55E-3	0.052	P	0.724	0.137	4.55E-2 S
	Total	0.212	0.252	0.131	-	4.45	0.089	1.89	-	1.92	1.63	0.604 -

\* Note: AXIDENT computer runs were made assuming all the release passing through one release path at a time. The results presented in the table were weighted with the actual release fraction through each path.

PEPP-E FORM

CALCULATION NO.: QDC 9400-M-0550 Rev. 0

**Table 8. Comparison of the Limiting Dose Results (for TID-14844 Source Term), Calculated Using ICRP-2 DCF's, with the SRP limits**

Location	Dose	Thyroid (Rem)	Whole Body (Rem)	Beta Dose (Rem)
LPZ Dose	AXIDENT Prediction	0.229	0.472	0.263
	SRP 15.4.9 Limit	75	6	-
Control Room	AXIDENT Prediction	4.78	0.209	4.23
	SRP 6.4 Limits	30	5	30
EAB Dose	AXIDENT Prediction	2.07	2.65	1.12
	SRP 15.4.9 Limit	75	6	-

**Table 9. Comparison of Thyroid Doses calculated Using ICRP-2 and ICRP-30 DCF's**

Fuel Type	Location	Dose (rem) W/ ICRP 2 DCF's (Table 7)	Dose (rem) W/ ICRP 30 DCF's (Table A-1)	Dose Reduction w/ ICRP-30 DCF's Compared to ICRP-2 DCF's
TID-14844	LPZ	0.229	0.130	43%
	CR	4.78	2.77	42%
	EAB	2.07	1.17	43%
Siemens 20 GWd/MTU	LPZ	0.203	0.117	42%
	CR	4.25	2.52	41%
	EAB	1.84	1.06	42%
Siemens 60 GWd/MTU	LPZ	0.212	0.125	41%
	CR	4.45	2.68	40%
	EAB	1.92	1.13	41%

### Appendix A: Calculation of the Effect of ICRP 30 DCF's on Thyroid Doses

Appendix A gives the AXIDENT code runs made with ICRP-30 DCF's for the gland seal steam pathway cases to determine the effect of lower DCF's than ICRP-2 DCF's, which were used for the base case calculations. The AXIDENT code output is given in attachments A-A through A-L. Table A-1 shows a summary of results.

**Table A-1. Summary of Thyroid Doses Calculated at LPZ, Control Room, and EAB for TID and Siemens Source Terms Using ICRP-30 DCF's\***

Fuel Type	Path	LPZ		Control Room		EAB	
		Thyroid Dose (Rem)	Att.	Thyroid Dose (Rem)	Att.	Thyroid Dose (Rem)	Att.
TID-14844	MVP	8.07E-2	A-A	1.73	A-A	0.73	A-C
	Gland	4.89E-2	A-B	1.05	A-B	0.443	A-D
	Total	0.130	-	2.77	-	1.17	-
Siemens 20 GWd/MTU	MVP	7.31E-2	A-E	1.57	A-E	0.66	A-G
	Gland	4.43E-2	A-F	0.95	A-F	0.401	A-H
	Total	0.117	-	2.52	-	1.06	-
Siemens 60 GWd/MTU	MVP	7.77E-2	A-I	1.67	A-I	0.704	A-K
	Gland	4.71E-2	A-J	1.01	A-J	0.426	A-L
	Total	0.125	-	2.68	-	1.13	-

\* Note: AXIDENT computer runs were made assuming all the release passing through one release path at a time. The results presented in the table were weighted with the actual release fraction through each path.

### ATTACHMENTS TO APPENDIX A

Att. No.	Description
A-A	QDC CRDA, TID-14844, LPZ & CR, MVP Release, Using ICRP-30 DCF's for Thyroid Dose (Pages A-A1 – A-A3)
A-B	QDC CRDA, TID-14844, LPZ & CR, Gland Release, Using ICRP-30 DCF's for Thyroid Dose (Pages A-B1 – A-B6)
A-C	QDC CRDA, TID-14844, EAB, MVP Release, Using ICRP-30 DCF's for Thyroid Dose (Pages A-C1 – A-C3)
A-D	QDC CRDA, TID-14844, EAB, Gland Release, Using ICRP-30 DCF's for Thyroid Dose (Pages A-D1 – A-D4)
A-E	QDC CRDA, Siemens 20 GWd/MTU, LPZ & CR, MVP Release, Using ICRP-30 DCF's for Thyroid Dose (Pages A-E1 – A-E3)
A-F	QDC CRDA, Siemens 20 GWd/MTU, LPZ & CR, Gland Release, Using ICRP-30 DCF's for Thyroid Dose (Pages A-F1 – A-F6)
A-G	QDC CRDA, Siemens 20 GWd/MTU, EAB, MVP Release, Using ICRP-30 DCF's for Thyroid Dose (Pages A-G1 – A-G3)
A-H	QDC CRDA, Siemens 20 GWd/MTU, EAB, Gland Release, Using ICRP-30 DCF's for Thyroid Dose (Pages A-H1 – A-H4)
A-I	QDC CRDA, Siemens 60 GWd/MTU, LPZ & CR, MVP Release, Using ICRP-30 DCF's for Thyroid Dose (Pages A-II – A-I3)
A-J	QDC CRDA, Siemens 60 GWd/MTU, LPZ & CR, Gland Release, Using ICRP-30 DCF's for Thyroid Dose (Pages A-J1 – A-J6)
A-K	QDC CRDA, Siemens 60 GWd/MTU, EAB, MVP Release, Using ICRP-30 DCF's for Thyroid Dose (Pages A-K1 – A-K3)
A-L	QDC CRDA, Siemens 60 GWd/MTU, EAB, Gland Release, Using ICRP-30 DCF's for Thyroid Dose (Pages A-L1 – A-L4)



AXIDENT VER 2 MOD 4  
 PRODUCTION DATE 02/18/92  
 BEGIN EXECUTION DATE: 11/18/1999  
 BEGIN EXECUTION TIME: 10:20:20.48

```

1 QDC CRDA, CR & LPZ, ALL REL MVP: TID-14844: 0 - 6 s
2 2 2 1. 1.
3 -2561 2.60+6 1.845+5 5.83+4
4 0. 0. 0. 1. 1. 2.78+5 0.
5 6 2.592E6
6 0.2402 0.
7 9.058E-4 0.
8 2*1.
9 2*2460
10 3.2E-5 0.
11 7.00E-4 0.
12 2*0.
13 2*0.
14 2*0.
15 2*0.
16 2*0.
17 2*0.
18 2*0.
19 2*0.
20 2*0.
21 6*1.
22 3*1.
23 7.16E+3      1.06E+4   1.65E+4   1.92E+4   1.52E+4   1.36E+3   1.05E+4   4.13E+5
24 1.11E+5      3.89E+5   3.65E+5   3.21E+4   8.04E+4   2.70E+3   1.55E+5   2.20E+5

```

1

QDC CRDA, CR &amp; LPZ, ALL REL MVP: TID-14844: 0 - 6 s

## INITIAL CONTAINMENT INVENTORY

## ISOTOPE ACTIVITY (CURIES)

I-131	7.160E+03
I-132	1.060E+04
I-133	1.650E+04
I-134	1.920E+04
I-135	1.520E+04
XE-131M	1.360E+03
XE-133M	1.050E+04
XE-133	4.130E+05
XE-135M	1.110E+05
XE-135	3.890E+05
XE-138	3.650E+05
KR-83M	3.210E+04
KR-85M	8.040E+04
KR-85	2.700E+03
KR-87	1.550E+05
KR-88	2.200E+05

1

QDC CRDA, CR &amp; LPZ, ALL REL MVP: TID-14844: 0 - 6 s

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

SPRAYED VOL	1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL,	1. CFM MIXING, 00.00 PCT REL TO
-------------	--	---------------------------------

AT .002 HOURS: X/Q(SITE)= .32E-04 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM
INTAKE=2460.0 CFM		

00.00	X/Q CONT ROOM= .70E-03 SEC/M3	SEC RELEASE RATE= .78E+02 VOL/DAY	PCT PRI LKG TO ATM =
-------	-------------------------------	-----------------------------------	----------------------

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM		SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA
ELEMENTAL											
I-131	3.85E+02	1.24E+03	4.16E+00	3.38E-03	6.46E-07	5.08E-02	1.23E-05	6.02E-06	5.47E-04	4.74E-09	6.49E-08
I-132	5.70E+02	1.83E+03	6.15E+00	4.99E-03	9.56E-07	4.30E-04	1.18E-04	2.03E-05	4.63E-06	3.93E-08	2.18E-07
I-133	8.88E+02	2.86E+03	9.58E+00	7.78E-03	1.49E-06	1.91E-02	3.65E-05	2.98E-05	2.06E-04	1.76E-08	3.21E-07
I-134	1.03E+03	3.32E+03	1.11E+01	9.04E-03	1.73E-06	1.36E-04	1.73E-04	3.73E-05	1.46E-06	7.64E-08	4.02E-07

I-135	8.18E+02	2.63E+03	8.82E+00	7.16E-03	1.37E-06	3.04E-03	1.26E-04	2.00E-05	3.27E-05	3.29E-08	2.15E-07
<b>PARTICULATE</b>											
I-131	2.12E+01	6.81E+01	2.28E-01	1.85E-04	3.55E-08	2.79E-03	6.78E-07	3.31E-07	3.00E-05	2.61E-10	3.57E-09
I-132	3.13E+01	1.01E+02	3.38E-01	2.74E-04	5.25E-08	2.36E-05	6.49E-06	1.11E-06	2.55E-07	2.16E-09	1.20E-08
I-133	4.88E+01	1.57E+02	5.26E-01	4.27E-04	8.18E-08	1.05E-03	2.01E-06	1.64E-06	1.13E-05	9.68E-10	1.76E-08
I-134	5.67E+01	1.82E+02	6.12E-01	4.97E-04	9.51E-08	7.47E-06	9.49E-06	2.05E-06	8.05E-08	4.20E-09	2.21E-08
I-135	4.50E+01	1.45E+02	3.94E-01	7.53E-08	1.67E-04	6.90E-06	1.10E-06	1.80E-06	1.81E-09	1.18E-08	
<b>ORGANIC</b>											
I-131	1.69E+01	5.45E+01	1.83E-01	1.48E-04	2.84E-08	2.23E-03	5.42E-07	2.65E-07	2.40E-05	2.08E-10	2.85E-09
I-132	2.51E+01	8.06E+01	2.70E-01	2.20E-04	4.20E-08	1.89E-05	5.19E-06	8.91E-07	2.04E-07	1.73E-09	9.60E-09
I-133	3.90E+01	1.26E+02	4.21E-01	3.42E-04	6.54E-08	8.41E-04	1.61E-06	1.31E-06	9.06E-06	7.74E-10	1.41E-08
I-134	4.54E+01	1.46E+02	4.89E-01	3.97E-04	7.61E-08	5.98E-06	7.59E-06	1.64E-06	6.44E-08	3.36E-09	1.76E-08
I-135	3.60E+01	1.16E+02	3.88E-01	3.15E-04	6.03E-08	1.33E-04	5.52E-06	8.79E-07	1.44E-06	1.45E-09	9.47E-09
<b>NOBLE GASES</b>											
XE-131M	3.22E+02	1.03E+03	3.47E+00	2.82E-03	5.39E-07	0.00E+00	6.11E-07	3.45E-06	0.00E+00	1.03E-09	3.71E-08
XE-133M	2.48E+03	7.99E+03	2.68E+01	2.18E-02	4.16E-06	0.00E+00	7.07E-06	3.06E-05	0.00E+00	3.50E-09	3.29E-07
XE-133	9.77E+04	3.14E+05	1.05E+03	8.56E-01	1.64E-04	0.00E+00	2.53E-04	1.13E-03	0.00E+00	3.08E-07	1.22E-05
XE-135M	2.62E+04	8.41E+04	2.82E+02	2.29E-01	4.38E-05	0.00E+00	9.53E-04	2.02E-04	0.00E+00	3.77E-07	2.17E-06
XE-135	9.20E+04	2.96E+05	9.92E+02	8.06E-01	1.54E-04	0.00E+00	1.95E-03	2.35E-03	0.00E+00	7.51E-07	2.53E-05
XE-138	8.60E+04	2.77E+05	9.29E+02	7.53E-01	1.44E-04	0.00E+00	2.13E-02	5.47E-03	0.00E+00	2.18E-06	5.89E-05
KR-83M	7.59E+03	2.44E+04	8.19E+01	6.65E-02	1.27E-05	0.00E+00	3.27E-06	2.05E-05	0.00E+00	1.93E-08	2.21E-07
KR-85M	1.90E+04	6.12E+04	2.05E+02	1.67E-01	3.19E-05	0.00E+00	2.56E-04	3.52E-04	0.00E+00	1.06E-07	3.79E-06
KR-85	6.39E+02	2.05E+03	6.89E+00	5.59E-03	1.07E-06	0.00E+00	1.16E-07	1.13E-05	0.00E+00	4.55E-11	1.22E-07
KR-87	3.66E+04	1.18E+05	3.95E+02	3.21E-01	6.14E-05	0.00E+00	4.35E-03	3.05E-03	0.00E+00	8.34E-07	3.29E-05
KR-88	5.20E+04	1.67E+05	5.61E+02	4.56E-01	8.72E-05	0.00E+00	7.82E-03	1.41E-03	0.00E+00	2.58E-06	1.52E-05
						8.08E-02	3.74E-02	1.42E-02	8.70E-04	7.34E-06	1.52E-04

1 QDC CRDA, CR & LPZ, ALL REL MVP: TID-14844: 0 - 6 s

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
SPRAYED VOL. 1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO

AT 720.000 HOURS: X/Q(SITE)= .00E+00 SEC/M3 PRIMARY LEAK RATE= .000 PERCENT/DAY CONTROL ROOM  
INTAKE=2460.0 CFM

X/Q CONT ROOM= .00E+00 SEC/M3 SEC RELEASE RATE= .00E+00 VOL/DAY PCT PRI LKG TO ATM =  
00.00

CLEANUP RATES (HR-1)							FILTER NON-REMOVAL FACTORS				
	SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER					
ELEMENTAL .	.000	.000	.000	.000	1.000	1.000					
PARTICULATE .	.000	.000	.000	.000	1.000	1.000					
ORGANIC .	.000	.000	.000	.000	1.000	1.000					
ACTIVITY (CURIES)				CONTROL ROOM		SITE BOUNDARY DOSES (REM)		CONTROL ROOM DOSES (REM)			
ISOTOPE	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA
ELEMENTAL											
I-131	2.91E+01	9.35E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.10E+00	9.58E-06	1.31E-04
I-132	3.44E-92	1.10E-91	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.83E-03	5.79E-05	3.22E-04
I-133	4.23E-08	1.36E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.02E-01	3.43E-05	6.26E-04
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.49E-03	7.75E-05	4.08E-04
I-135	4.03E-30	1.30E-29	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.88E-02	5.91E-05	3.87E-04
PARTICULATE											
I-131	1.60E+00	5.14E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.07E-02	5.26E-07	7.21E-06
I-132	1.89E-93	6.07E-93	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.75E-04	3.18E-06	1.77E-05
I-133	2.32E-09	7.47E-09	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.21E-02	1.89E-06	3.44E-05
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.17E-05	4.26E-06	2.24E-05
I-135	2.22E-31	7.12E-31	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.23E-03	3.25E-06	2.13E-05
ORGANIC											
I-131	1.28E+00	4.11E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.86E-02	4.21E-07	5.76E-06
I-132	1.51E-93	4.86E-93	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.00E-04	2.55E-06	1.42E-05
I-133	1.86E-09	5.97E-09	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.77E-02	1.51E-06	2.75E-05
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.53E-05	3.41E-06	1.79E-05
I-135	1.77E-31	5.70E-31	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.58E-03	2.60E-06	1.70E-05
NOBLE GASES											
XE-131M	5.54E+01	1.78E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.08E-06	7.51E-05
XE-132M	2.51E+01	8.05E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.00E-06	6.58E-04
XE-133	1.90E+03	6.11E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.22E-04	2.46E-02
XE-135M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.76E-04	1.02E-03
XE-135	1.63E-19	5.24E-19	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.39E-03	4.70E-02
XE-138	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.11E-03	3.01E-02
KR-83M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.67E-05	3.06E-04
KR-85M	9.42E-46	3.03E-45	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.80E-04	6.42E-03
KR-85	6.36E+02	2.04E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.25E-08	2.47E-04
KR-87	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.01E-03	3.96E-02
KR-88	1.86E-73	5.97E-73	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.00E-03	2.35E-02

TOTAL DOSES 0-30 DAYS	8.08E-02	3.74E-02	1.42E-02	1.73E+00	8.79E-03	1.76E-01
-----------------------	----------	----------	----------	----------	----------	----------

1

QDC CRDA, CR &amp; LPZ, ALL REL MVP: TID-14844: 0 - 6 s

ISOTOPE	0. HRS	720. HRS	ACTIVITY RELEASED (CURIES)
ELEMENTAL			
I-131	4.16E+00	0.00E+00	4.16E+00
I-132	6.15E+00	0.00E+00	6.15E+00
I-133	9.58E+00	0.00E+00	9.58E+00
I-134	1.11E+01	0.00E+00	1.11E+01
I-135	8.82E+00	0.00E+00	8.82E+00
PARTICULATE			
I-131	2.28E-01	0.00E+00	2.28E-01
I-132	3.38E-01	0.00E+00	3.38E-01
I-133	5.26E-01	0.00E+00	5.26E-01
I-134	6.12E-01	0.00E+00	6.12E-01
I-135	4.85E-01	0.00E+00	4.85E-01
ORGANIC			
I-131	1.83E-01	0.00E+00	1.83E-01
I-132	2.70E-01	0.00E+00	2.70E-01
I-133	4.21E-01	0.00E+00	4.21E-01
I-134	4.89E-01	0.00E+00	4.89E-01
I-135	3.88E-01	0.00E+00	3.88E-01
NOBLE GASES			
XE-131M	3.47E+00	0.00E+00	3.47E+00
XE-133M	2.68E+01	0.00E+00	2.68E+01
XE-133	1.05E+03	0.00E+00	1.05E+03
XE-135M	2.82E+02	0.00E+00	2.82E+02
XE-135	9.92E+02	0.00E+00	9.92E+02
XE-138	9.29E+02	0.00E+00	9.29E+02
KR-83M	8.19E+01	0.00E+00	8.19E+01
KR-85M	2.05E+02	0.00E+00	2.05E+02
KR-85	6.89E+00	0.00E+00	6.89E+00
KR-87	3.95E+02	0.00E+00	3.95E+02
KR-88	5.61E+02	0.00E+00	5.61E+02

END EXECUTION DATE: 11/18/1999

END EXECUTION TIME: 10:20:20.59

AXIDENT VER 2 MOD 4  
 PRODUCTION DATE 02/18/92  
 BEGIN EXECUTION DATE: 11/18/1999  
 BEGIN EXECUTION TIME: 08:57:52.35

1 QDC CRDA, CR & LPZ, ALL REL GLAND: TID-14844: 0 - 30 d  
 2 6 2 1. 1.  
 3 -2561 2.60+6 1.845+5 5.83+4  
 4 0. 0. 0. 1. 1. 2.78+5 0.  
 5 6 1800 7200 2.88+4 8.64+4 2.592E6  
 6 0.2402 4\*1.201E-2 0.  
 7 5\*1. 0.  
 8 6\*1.  
 9 6\*2460  
 10 2\*3.2E-5 2\*9.0E-6 3.0E-6 0.  
 11 3\*7.00E-4 6.45E-6 3.81E-6 0.  
 12 6\*0.  
 13 6\*0.  
 14 6\*0.  
 15 6\*0.  
 16 6\*0.  
 17 6\*0.  
 18 6\*0.  
 19 6\*0.  
 20 6\*0.  
 21 6\*1.  
 22 3\*1.  
 23 7.16E+3        1.06E+4 1.65E+4 1.92E+4 1.52E+4 1.36E+3 1.05E+4 4.13E+5  
 24 1.11E+5        3.89E+5 3.65E+5 3.21E+4 8.04E+4 2.70E+3 1.55E+5 2.20E+5

1

QDC CRDA, CR &amp; LPZ, ALL REL GLAND: TID-14844: 0 - 30 d

## INITIAL CONTAINMENT INVENTORY

## ISOTOPE ACTIVITY (CURIES)

I-131	7.160E+03
I-132	1.060E+04
I-133	1.650E+04
I-134	1.920E+04
I-135	1.520E+04
XE-131M	1.360E+03
XE-133M	1.050E+04
XE-133	4.130E+05
XE-135M	1.110E+05
XE-135	3.890E+05
XE-138	3.650E+05
KR-83M	3.210E+04
KR-85M	8.040E+04
KR-85	2.700E+03
KR-87	1.550E+05
KR-88	2.200E+05

1 QDC CRDA, CR &amp; LPZ, ALL REL GLAND: TID-14844: 0 - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

SPRAYED VOL	1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL,	1. CFM MIXING, 00.00 PCT REL TO
-------------	--	---------------------------------

AT .002 HOURS: X/Q(SITE)= .32E-04 SEC/M3 PRIMARY LEAK RATE=***** PERCENT/DAY CONTROL ROOM
INTAKE=2460.0 CFM
X/Q CONT ROOM= .70E-03 SEC/M3 SEC RELEASE RATE= .86E+05 VOL/DAY PCT PRI LKG TO ATM =
00.00

SPRAY	CLEANUP RATES (HR-1)			FILTER NON-REMOVAL FACTORS	
	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM		SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA
<b>ELEMENTAL</b>											
I-131	3.85E+02	1.21E+02	1.12E+03	9.12E-01	1.75E-04	1.37E+01	3.33E-03	1.63E-03	2.06E-01	1.79E-06	2.45E-05
I-132	5.70E+02	1.78E+02	1.66E+03	1.35E+00	2.58E-04	1.16E-01	3.19E-02	5.48E-03	1.75E-03	1.48E-05	8.24E-05
I-133	8.88E+02	2.78E+02	2.59E+03	2.10E+00	4.02E-04	5.17E+00	9.87E-03	8.06E-03	7.77E-02	6.64E-06	1.21E-04
I-134	1.03E+03	3.23E+02	3.01E+03	2.44E+00	4.67E-04	3.68E-02	4.67E-02	1.01E-02	5.52E-04	2.88E-05	1.51E-04

1 QDC CRDA, CR & LPZ, ALL REL GLAND: TID-14844: 0 - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL. 278000. FT3 UNSPRAYED VOL. 1. CFM MIXING, 00.00 PCT REL TO

SPRAYED VOL

AT .500 HOURS: X/Q(SITE)= .32E-04 SEC/M3 PRIMARY LEAK RATE=\*\*\*\*\* PERCENT/DAY CONTROL ROOM  
INTAKE=2460.0 CFM

X/Q CONT ROOM= .70E-03 SEC/M3 SEC RELEASE RATE= .86E+05 VOL/DAY PCT PRI LKG TO ATM =  
00.00

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS		
	SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	.000	1.000	1.000

ACTIVITY (CURIES)			CONTROL ROOM		SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)			
ISOTOPE	PRIMARY	SECONDARY RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA	
<b>ELEMENTAL</b>											
I-131	1.69E-07	2.05E-09	5.06E+02	8.91E-01	1.70E-04	6.18E+00	1.50E-03	7.34E-04	1.42E+02	1.23E-03	1.68E-02
I-132	2.16E-07	2.62E-09	7.45E+02	1.14E+00	2.17E-04	5.21E-02	1.43E-02	2.46E-03	1.12E+00	9.49E-03	5.28E-02
I-133	3.84E-07	4.67E-09	1.17E+03	2.02E+00	3.87E-04	2.33E+00	4.45E-03	3.63E-03	5.30E+01	4.53E-03	8.26E-02
I-134	3.04E-07	3.70E-09	1.34E+03	1.60E+00	3.07E-04	1.63E-02	2.07E-02	4.47E-03	3.16E-01	1.65E-02	8.67E-02
I-135	3.41E-07	4.15E-09	1.07E+03	1.80E+00	3.44E-04	3.69E-01	1.53E-02	2.43E-03	8.27E+00	8.32E-03	5.45E-02
<b>PARTICULATE</b>											
I-131	9.29E-09	1.13E-10	2.78E+01	4.89E-02	9.37E-06	3.40E-01	8.25E-05	4.03E-05	7.78E+00	6.75E-05	9.23E-04
I-132	1.18E-08	1.44E-10	4.09E+01	6.24E-02	1.19E-05	2.86E-03	7.86E-04	1.35E-04	6.15E-02	5.22E-04	2.90E-03
I-133	2.11E-08	2.56E-10	6.40E+01	1.11E-01	2.13E-05	1.28E-01	2.44E-04	1.99E-04	2.91E+00	2.49E-04	4.54E-03
I-134	1.67E-08	2.03E-10	7.34E+01	8.81E-02	1.69E-05	8.97E-04	1.14E-03	2.46E-04	1.74E-02	9.06E-04	4.77E-03
I-135	1.88E-08	2.28E-10	5.89E+01	9.88E-02	1.89E-05	2.03E-02	8.38E-04	1.34E-04	4.55E-01	4.57E-04	2.99E-03
<b>ORGANIC</b>											
I-131	7.43E-09	9.03E-11	2.22E+01	3.91E-02	7.49E-06	2.72E-01	6.60E-05	3.22E-05	6.22E+00	5.40E-05	7.39E-04
I-132	9.48E-09	1.15E-10	3.27E+01	4.99E-02	9.56E-06	2.29E-03	6.29E-04	1.08E-04	4.92E-02	4.17E-04	2.32E-03
I-133	1.69E-08	2.05E-10	5.12E+01	8.89E-02	1.70E-05	1.02E-01	1.95E-04	1.59E-04	2.33E+00	1.99E-04	3.63E-03
I-134	1.34E-08	1.63E-10	5.87E+01	7.05E-02	1.35E-05	7.17E-04	9.11E-04	1.97E-04	1.39E-02	7.25E-04	3.81E-03
I-135	1.50E-08	1.82E-10	4.71E+01	7.91E-02	1.51E-05	1.62E-02	6.71E-04	1.07E-04	3.64E-01	3.66E-04	2.39E-03
<b>NOBLE GASES</b>											
XE-131M	1.41E-07	1.72E-09	4.22E+02	7.44E-01	1.42E-04	0.00E+00	7.44E-05	4.20E-04	0.00E+00	2.67E-04	9.62E-03
XE-133M	1.08E-06	1.32E-08	3.26E+03	5.71E+00	1.09E-03	0.00E+00	8.61E-04	3.72E-03	0.00E+00	9.06E-04	8.51E-02
XE-133	4.28E-05	5.20E-07	1.28E+05	2.26E+02	4.32E-02	0.00E+00	3.08E-02	1.38E-01	0.00E+00	7.99E-02	3.16E-00
XE-135M	3.05E-06	3.70E-08	3.28E+04	1.60E+01	3.07E-03	0.00E+00	1.11E-01	2.34E-02	0.00E+00	5.58E-02	3.22E-01
XE-135	3.89E-05	4.73E-07	1.21E+05	2.05E+02	3.93E-02	0.00E+00	2.37E-01	2.86E-01	0.00E+00	1.91E-01	6.45E+00
XE-138	1.16E-05	1.41E-07	1.08E+05	6.09E+01	1.17E-02	0.00E+00	2.49E+00	6.38E-01	0.00E+00	3.40E-01	9.21E+00
KR-83M	2.77E-06	3.37E-08	9.90E+03	1.46E+01	2.80E-03	0.00E+00	3.96E-04	2.48E-03	0.00E+00	4.59E-03	5.25E-02
KR-85M	7.72E-06	9.39E-08	2.49E+04	4.07E+01	7.79E-03	0.00E+00	3.11E-02	4.27E-02	0.00E+00	2.65E-02	9.46E-01
KR-85	2.81E-07	3.41E-09	8.39E+02	1.48E+00	2.83E-04	0.00E+00	1.41E-05	1.38E-03	0.00E+00	1.18E-05	3.16E-02
KR-87	1.23E-05	1.49E-07	4.76E+04	6.46E+01	1.24E-02	0.00E+00	5.24E-01	3.68E-01	0.00E+00	1.91E-01	7.52E+00
KR-88	2.02E-05	2.46E-07	6.80E+04	1.06E+02	2.04E-02	0.00E+00	9.48E-01	1.71E-01	0.00E+00	6.31E-01	3.71E+00

QDC CRDA, CR & LPZ, ALL REL GLAND: TID-14844: 0 - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO  
SPRAYED VOL

AT 2.000 HOURS: X/Q(SITE)= .90E-05 SEC/M3 PRIMARY LEAK RATE=\*\*\*\*\* PERCENT/DAY CONTROL ROOM  
 INTAKE=2460.0 CFM

X/Q CONT ROOM= .70E-03 SEC/M3 SEC RELEASE RATE= .86E+05 VOL/DAY PCT PRI LKG TO ATM =  
 00.00

CLEANUP RATES (HR-1)				FILTER NON-REMPTION FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
.000	.000	.000	.000	1.000	1.000
.000	.000	.000	.000	1.000	1.000
.000	.000	.000	.000	.000	.000

ACTIVITY (CURIES)				CONTROL ROOM		SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
ISOTOPE	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA
<b>ELEMENTAL</b>											
I-131	1.15E-35	1.40E-37	1.71E-07	2.67E-01	5.11E-05	5.88E-10	1.43E-13	6.98E-14	2.04E+02	1.77E-03	2.42E-02
I-132	9.37E-36	1.14E-37	2.17E-07	2.18E-01	4.17E-05	4.26E-12	1.17E-12	2.01E-13	1.26E+00	1.06E-02	5.92E-02
I-133	2.49E-35	3.03E-37	3.88E-07	5.80E-01	1.11E-04	2.18E-10	4.17E-13	3.40E-13	7.45E+01	6.37E-03	1.16E-01
I-134	6.27E-36	7.62E-38	3.03E-07	1.46E-01	2.79E-05	1.04E-12	1.32E-12	2.85E-13	2.40E+01	1.25E-02	6.58E-02
I-135	2.00E-35	2.43E-37	3.45E-07	4.64E-01	8.88E-05	3.34E-11	1.38E-12	2.20E-13	1.10E+01	1.10E-02	7.21E-02
<b>PARTICULATE</b>											
I-131	6.31E-37	7.67E-39	9.40E-09	1.47E-02	2.81E-06	3.23E-11	7.85E-15	3.83E-15	1.12E+01	9.73E-05	1.33E-03
I-132	5.15E-37	6.26E-39	1.19E-08	1.20E-02	2.29E-06	2.34E-13	6.43E-14	1.10E-14	6.90E-02	5.85E-04	3.25E-03
I-133	1.37E-36	1.67E-38	2.13E-08	3.19E-02	6.10E-06	1.20E-11	2.29E-14	1.87E-14	4.10E+00	3.50E-04	6.38E-03
I-134	3.44E-37	4.19E-39	1.66E-08	8.01E-03	1.53E-06	5.71E-14	7.25E-14	1.57E-14	1.32E-02	6.87E-04	3.61E-03
I-135	1.10E-36	1.33E-38	1.89E-08	2.55E-02	4.88E-06	1.83E-12	7.58E-14	1.21E-14	6.02E-01	6.05E-04	3.96E-03
<b>ORGANIC</b>											
I-131	5.05E-37	6.13E-39	7.52E-09	1.17E-02	2.24E-06	2.58E-11	6.28E-15	3.07E-15	8.97E+00	7.78E-05	1.07E-03
I-132	4.12E-37	5.01E-39	9.53E-09	9.57E-03	1.83E-06	1.87E-13	5.14E-14	8.83E-15	5.52E-02	4.68E-04	2.60E-03
I-133	1.10E-36	1.33E-38	1.71E-08	2.55E-02	4.88E-06	9.59E-12	1.83E-14	1.49E-14	3.28E+00	2.80E-04	5.10E-03
I-134	2.76E-37	3.35E-39	1.33E-08	6.41E-03	1.23E-06	4.57E-14	5.80E-14	1.25E-14	1.05E-02	5.50E-04	2.89E-03
I-135	8.77E-37	1.07E-38	1.52E-08	2.04E-02	3.90E-06	1.47E-12	6.06E-14	9.66E-15	4.81E-01	4.84E-04	3.17E-03
<b>NOBLE GASES</b>											
XE-131M	9.60E-36	1.17E-37	1.43E-07	2.23E-01	4.27E-05	0.00E+00	7.07E-15	3.99E-14	0.00E+00	3.85E-04	1.39E-02
XE-133M	7.26E-35	8.83E-37	1.10E-06	1.69E+00	3.23E-04	0.00E+00	8.15E-14	3.52E-13	0.00E+00	1.30E-03	1.22E-01
XE-133	2.90E-33	3.52E-35	4.33E-05	6.74E+01	1.29E-02	0.00E+00	2.92E-12	1.31E-11	0.00E+00	1.15E-01	4.54E+00
XE-135M	3.82E-36	4.65E-38	2.90E-06	8.89E-02	1.70E-05	0.00E+00	2.76E-12	5.83E-13	0.00E+00	1.23E-02	7.08E-02
XE-135	2.37E-33	2.88E-35	3.93E-05	5.51E+01	1.06E-02	0.00E+00	2.18E-11	2.62E-11	0.00E+00	2.59E-01	8.74E+00
XE-138	2.24E-35	2.72E-37	1.11E-05	5.20E-01	9.95E-05	0.00E+00	7.17E-11	1.84E-11	0.00E+00	8.91E-02	2.41E+00
KR-83M	1.09E-34	1.32E-36	2.78E-06	2.52E+00	4.83E-04	0.00E+00	3.13E-14	1.96E-13	0.00E+00	4.86E-03	5.56E-02
KR-85M	4.16E-34	5.06E-36	7.79E-06	9.68E+00	1.85E-03	0.00E+00	2.73E-12	3.76E-12	0.00E+00	3.34E-02	1.20E+00
KR-85	1.92E-35	2.33E-37	2.84E-07	4.45E-01	8.53E-05	0.00E+00	1.34E-15	1.31E-13	0.00E+00	1.71E-05	4.57E-02
KR-87	3.68E-34	4.48E-36	1.22E-05	8.56E+00	1.64E-03	0.00E+00	3.79E-11	2.66E-11	0.00E+00	1.75E-01	6.92E+00
KR-88	9.51E-34	1.16E-35	2.03E-05	2.21E+01	4.23E-03	0.00E+00	9.79E-11	1.44E-11	0.00E+00	7.40E-01	4.35E+00
						9.28E-10	2.24E-10	1.05E-10	3.20E+02	1.48E+00	2.88E+01

1 ODC CRDA: CR & LPZ: ALL REL GLAND: TID-14844: 0 - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
SPRAYED VOL 1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO

AT 8.000 HOURS: X/Q(SITE)= .90E-05 SEC/M3 PRIMARY LEAK RATE=\*\*\*\*\* PERCENT/DAY CONTROL ROOM  
 INTAKE=2460.0 CFM

X/Q CONT ROOM= .65E-05 SEC/M3 SEC RELEASE RATE= .86E+05 VOL/DAY PCT PRI LKG TO ATM =  
 00.00

CLEANUP RATES (HR-1)				FILTER NON-REMPTION FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
.000	.000	.000	.000	1.000	1.000
.000	.000	.000	.000	1.000	1.000
.000	.000	.000	.000		

ACTIVITY (CURIES)			CONTROL ROOM			SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
ISOTOPE	PRIMARY	SECONDARY RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA	

ELEMENTAL													
I-131	0.00E+00	0.00E+00	1.16E-35	2.15E-03	4.11E-07	3.99E-38	9.70E-42	4.74E-42	8.66E+01	7.51E-04	1.03E-02		
I-132	0.00E+00	0.00E+00	9.42E-36	2.94E-04	5.63E-08	1.85E-40	5.08E-41	8.73E-42	2.97E-01	2.52E-03	1.40E-02		
I-133	0.00E+00	0.00E+00	2.52E-35	3.91E-03	7.49E-07	1.42E-38	2.71E-41	2.21E-41	2.97E+01	2.54E-03	4.63E-02		
I-134	0.00E+00	0.00E+00	6.23E-36	9.92E-06	1.90E-09	2.14E-41	2.72E-41	5.87E-42	2.40E-02	1.25E-03	6.57E-03		
I-135	0.00E+00	0.00E+00	2.02E-35	2.05E-03	3.93E-07	1.95E-39	8.07E-41	1.28E-41	3.79E+00	3.81E-03	2.50E-02		
PARTICULATE													
I-131	0.00E+00	0.00E+00	6.38E-37	1.18E-04	2.26E-08	2.19E-39	5.33E-43	2.60E-43	4.76E+00	4.13E-05	5.65E-04		
I-132	0.00E+00	0.00E+00	5.17E-37	1.61E-05	3.09E-09	1.02E-41	2.79E-42	4.80E-43	1.63E-02	1.39E-04	7.70E-04		
I-133	0.00E+00	0.00E+00	1.39E-36	2.15E-04	4.12E-08	7.79E-40	1.49E-42	1.21E-42	1.63E+00	1.40E-04	2.55E-03		
I-134	0.00E+00	0.00E+00	3.42E-37	5.45E-07	1.04E-10	1.18E-42	1.49E-42	3.22E-43	1.32E-03	6.87E-05	3.61E-04		
I-135	0.00E+00	0.00E+00	1.11E-36	1.13E-04	2.16E-08	1.07E-40	4.43E-42	7.06E-43	2.08E-01	2.09E-04	1.37E-03		
ORGANIC													
I-131	0.00E+00	0.00E+00	5.11E-37	9.45E-05	1.81E-08	1.75E-39	4.26E-43	2.08E-43	3.81E+00	3.30E-05	4.52E-04		
I-132	0.00E+00	0.00E+00	4.14E-37	1.29E-05	2.47E-09	8.14E-42	2.24E-42	3.84E-43	1.31E-02	1.11E-04	6.16E-04		
I-133	0.00E+00	0.00E+00	1.11E-36	1.72E-04	3.29E-08	6.23E-40	1.19E-42	9.71E-43	1.31E+00	1.12E-04	2.04E-03		
I-134	0.00E+00	0.00E+00	2.74E-37	4.36E-07	8.34E-11	9.41E-43	1.19E-42	2.58E-43	1.05E-03	5.49E-05	2.89E-04		
I-135	0.00E+00	0.00E+00	8.86E-37	9.03E-05	1.73E-08	8.58E-41	3.55E-42	5.65E-43	1.67E-01	1.68E-04	1.10E-03		
NOBLE GASES													
XE-131M	0.00E+00	0.00E+00	9.72E-36	1.81E-03	3.47E-07	0.00E+00	4.81E-43	2.72E-42	0.00E+00	1.64E-04	5.90E-03		
XE-133M	0.00E+00	0.00E+00	7.35E-35	1.29E-02	2.46E-06	0.00E+00	5.46E-42	2.36E-41	0.00E+00	5.39E-04	5.06E-02		
XE-133	0.00E+00	0.00E+00	2.93E-33	5.37E-01	1.03E-04	0.00E+00	1.98E-40	8.87E-40	0.00E+00	4.86E-02	1.92E+00		
XE-135M	0.00E+00	0.00E+00	3.65E-36	8.36E-11	1.60E-14	0.00E+00	3.46E-42	7.32E-43	0.00E+00	6.84E-05	3.94E-04		
XE-135	0.00E+00	0.00E+00	2.40E-33	2.88E-01	5.51E-05	0.00E+00	1.33E-39	1.60E-39	0.00E+00	9.47E-02	3.19E+00		
XE-138	0.00E+00	0.00E+00	2.15E-35	2.75E-09	5.27E-13	0.00E+00	1.39E-40	3.55E-41	0.00E+00	7.67E-04	2.08E-02		
KR-83M	0.00E+00	0.00E+00	1.09E-34	2.24E-03	4.29E-07	0.00E+00	1.23E-42	7.66E-42	0.00E+00	1.01E-03	1.16E-02		
KR-85M	0.00E+00	0.00E+00	4.20E-34	3.09E-02	5.92E-06	0.00E+00	1.47E-40	2.02E-40	0.00E+00	1.04E-02	3.72E-01		
KR-85	0.00E+00	0.00E+00	1.94E-35	3.67E-03	7.02E-07	0.00E+00	9.16E-44	8.95E-42	0.00E+00	7.30E-06	1.95E-02		
KR-87	0.00E+00	0.00E+00	3.68E-34	2.64E-03	5.06E-07	0.00E+00	1.14E-39	8.00E-40	0.00E+00	2.68E-02	1.06E+00		
KR-88	0.00E+00	0.00E+00	9.57E-34	4.12E-02	7.88E-06	0.00E+00	3.76E-39	6.76E-40	0.00E+00	1.94E-01	1.14E+00		
						6.18E-38	6.93E-39	4.30E-39	1.32E+02	3.89E-01	7.90E+00		

1 QDC CRDA, CR &amp; LPZ, ALL REL GLAND: TID-14844: 0 - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO SPRAYED VOL

AT 24.000 HOURS: X/Q(SITE)= .30E-05 SEC/M3 PRIMARY LEAK RATE=***** PERCENT/DAY	INTAKE=2460.0 CFM	CONTROL ROOM
X/Q CONT ROOM= .38E-05 SEC/M3 SEC RELEASE RATE= .86E+05 VOL/DAY	PCT PRI LKG TO ATM =	00.00

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL .000	.000	.000	.000	1.000	1.000
PARTICULATE .000	.000	.000	.000	1.000	1.000
ORGANIC .000	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)	CONTROL ROOM (CURIES)	SITE BOUNDARY DOSES (REM)	THYROID WH BODY BETA	CONTROL ROOM DOSES (REM)
	PRIMARY SECONDARY RELEASE	(UCI/CM3)	THYROID WH BODY	BETA	THYROID WH BODY BETA
ELEMENTAL					
I-131	0.00E+00 0.00E+00 0.00E+00	5.60E-09	1.07E-12	0.00E+00 0.00E+00 0.00E+00	7.03E-01 6.10E-06 8.35E-05
I-132	0.00E+00 0.00E+00 0.00E+00	6.54E-12	1.25E-15	0.00E+00 0.00E+00 0.00E+00	4.02E-04 3.41E-06 1.89E-05
I-133	0.00E+00 0.00E+00 0.00E+00	6.37E-09	1.22E-12	0.00E+00 0.00E+00 0.00E+00	2.02E-01 1.73E-05 3.15E-04
I-134	0.00E+00 0.00E+00 0.00E+00	7.66E-17	1.47E-20	0.00E+00 0.00E+00 0.00E+00	0.00E+00 1.63E-06 8.50E-08 4.47E-07
I-135	0.00E+00 0.00E+00 0.00E+00	1.09E-09	2.08E-13	0.00E+00 0.00E+00 0.00E+00	0.00E+00 1.69E-02 1.70E-05 1.11E-04
PARTICULATE					
I-131	0.00E+00 0.00E+00 0.00E+00	3.08E-10	5.89E-14	0.00E+00 0.00E+00 0.00E+00	3.86E-02 3.35E-07 4.59E-06
I-132	0.00E+00 0.00E+00 0.00E+00	3.59E-13	6.88E-17	0.00E+00 0.00E+00 0.00E+00	2.21E-05 1.87E-07 1.04E-06
I-133	0.00E+00 0.00E+00 0.00E+00	3.50E-10	6.70E-14	0.00E+00 0.00E+00 0.00E+00	1.11E-02 9.49E-07 1.73E-05
I-134	0.00E+00 0.00E+00 0.00E+00	4.21E-18	8.05E-22	0.00E+00 0.00E+00 0.00E+00	0.00E+00 8.96E-08 4.67E-09 2.46E-08
I-135	0.00E+00 0.00E+00 0.00E+00	5.97E-11	1.14E-14	0.00E+00 0.00E+00 0.00E+00	0.00E+00 9.26E-04 9.32E-07 6.10E-06
ORGANIC					
I-131	0.00E+00 0.00E+00 0.00E+00	2.46E-10	4.71E-14	0.00E+00 0.00E+00 0.00E+00	3.09E-02 2.68E-07 3.67E-06
I-132	0.00E+00 0.00E+00 0.00E+00	2.87E-13	5.50E-17	0.00E+00 0.00E+00 0.00E+00	1.77E-05 1.50E-07 8.33E-07
I-133	0.00E+00 0.00E+00 0.00E+00	2.80E-10	5.36E-14	0.00E+00 0.00E+00 0.00E+00	8.89E-03 7.59E-07 1.38E-05
I-134	0.00E+00 0.00E+00 0.00E+00	3.37E-18	6.44E-22	0.00E+00 0.00E+00 0.00E+00	7.17E-08 3.74E-09 1.97E-08
I-135	0.00E+00 0.00E+00 0.00E+00	4.77E-11	9.13E-15	0.00E+00 0.00E+00 0.00E+00	7.41E-04 7.45E-07 4.88E-06
NOBLE GASES					
XE-131M	0.00E+00 0.00E+00 0.00E+00	4.81E-09	9.20E-13	0.00E+00 0.00E+00 0.00E+00	0.00E+00 1.34E-06 4.83E-05
XE-133M	0.00E+00 0.00E+00 0.00E+00	2.90E-08	5.54E-12	0.00E+00 0.00E+00 0.00E+00	0.00E+00 4.14E-06 3.89E-04
XE-133	0.00E+00 0.00E+00 0.00E+00	1.36E-06	2.60E-10	0.00E+00 0.00E+00 0.00E+00	0.00E+00 3.90E-04 1.54E-02
XE-135M	0.00E+00 0.00E+00 0.00E+00	7.11E-35	1.36E-38	0.00E+00 0.00E+00 0.00E+00	0.00E+00 6.44E-14 3.71E-13
XE-135	0.00E+00 0.00E+00 0.00E+00	2.36E-07	4.51E-11	0.00E+00 0.00E+00 0.00E+00	0.00E+00 4.97E-04 1.68E-02
XE-138	0.00E+00 0.00E+00 0.00E+00	2.35E-31	4.50E-35	0.00E+00 0.00E+00 0.00E+00	0.00E+00 0.00E+00 4.06E-12 1.10E-10
KR-83M	0.00E+00 0.00E+00 0.00E+00	1.64E-11	3.14E-15	0.00E+00 0.00E+00 0.00E+00	0.00E+00 9.03E-07 1.03E-05
KR-85M	0.00E+00 0.00E+00 0.00E+00	6.85E-09	1.31E-12	0.00E+00 0.00E+00 0.00E+00	0.00E+00 3.33E-05 1.19E-03
KR-85	0.00E+00 0.00E+00 0.00E+00	1.01E-08	1.94E-12	0.00E+00 0.00E+00 0.00E+00	0.00E+00 6.06E-08 1.62E-04

KR-87	0.00E+00	0.00E+00	0.00E+00	1.15E-12	2.20E-16	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.28E-06	3.26E-04
KR-88	0.00E+00	0.00E+00	0.00E+00	2.16E-09	4.14E-13	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.61E-04	2.12E-03
						0.00E+00	0.00E+00	0.00E+00	1.01E+00	1.34E-03	3.70E-02

1 QDC CRDA, CR & LPZ, ALL REL GLAND: TID-14844: 0 - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO SPRAYED VOL

AT 720.000 HOURS: X/Q(SITE)= .00E+00 SEC/M3 PRIMARY LEAK RATE= .000 PERCENT/DAY CONTROL ROOM  
INTAKE=2460.0 CFM

X/Q CONT ROOM= .00E+00 SEC/M3 SEC RELEASE RATE= .00E+00 VOL/DAY PCT PRI LKG TO ATM =  
00.00

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS		
	SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)	CONTROL ROOM (CURIES)	SITE BOUNDARY DOSES (REM)	CONTROL ROOM DOSES (REM)	
	PRIMARY	SECONDARY	THYROID WH BODY BETA	THYROID WH BODY BETA	
<b>ELEMENTAL</b>					
I-131	0.00E+00	0.00E+00	0.00E+00	0.00E+00 1.83E-06 1.59E-11 2.18E-10	
I-132	0.00E+00	0.00E+00	0.00E+00	0.00E+00 8.94E-12 7.58E-14 4.21E-13	
I-133	0.00E+00	0.00E+00	0.00E+00	0.00E+00 3.29E-07 2.81E-11 5.13E-10	
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00 0.00E+00 1.26E-17 6.56E-19 3.45E-18	
I-135	0.00E+00	0.00E+00	0.00E+00	0.00E+00 0.00E+00 8.91E-09 8.96E-12 5.87E-11	
<b>PARTICULATE</b>					
I-131	0.00E+00	0.00E+00	0.00E+00	0.00E+00 0.00E+00 1.01E-07 8.74E-13 1.20E-11	
I-132	0.00E+00	0.00E+00	0.00E+00	0.00E+00 0.00E+00 4.91E-13 4.17E-15 2.32E-14	
I-133	0.00E+00	0.00E+00	0.00E+00	0.00E+00 0.00E+00 1.81E-08 1.55E-12 2.82E-11	
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00 0.00E+00 6.92E-19 3.61E-20 1.90E-19	
I-135	0.00E+00	0.00E+00	0.00E+00	0.00E+00 0.00E+00 4.90E-10 4.92E-13 3.22E-12	
<b>ORGANIC</b>					
I-131	0.00E+00	0.00E+00	0.00E+00	0.00E+00 0.00E+00 8.06E-08 6.99E-13 9.57E-12	
I-132	0.00E+00	0.00E+00	0.00E+00	0.00E+00 0.00E+00 3.93E-13 3.33E-15 1.85E-14	
I-133	0.00E+00	0.00E+00	0.00E+00	0.00E+00 0.00E+00 1.45E-08 1.24E-12 2.25E-11	
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00 0.00E+00 5.53E-19 2.89E-20 1.52E-19	
I-135	0.00E+00	0.00E+00	0.00E+00	0.00E+00 0.00E+00 3.92E-10 3.94E-13 2.58E-12	
<b>NOBLE GASES</b>					
XE-131M	0.00E+00	0.00E+00	0.00E+00	0.00E+00 0.00E+00 0.00E+00 0.00E+00 3.55E-12 1.28E-10	
XE-133M	0.00E+00	0.00E+00	0.00E+00	0.00E+00 0.00E+00 0.00E+00 0.00E+00 9.32E-12 8.75E-10	
XE-133	0.00E+00	0.00E+00	0.00E+00	0.00E+00 0.00E+00 0.00E+00 0.00E+00 9.86E-10 3.90E-08	
XE-135M	0.00E+00	0.00E+00	0.00E+00	0.00E+00 0.00E+00 0.00E+00 0.00E+00 5.48E-38 3.16E-37	
XE-135	0.00E+00	0.00E+00	0.00E+00	0.00E+00 0.00E+00 0.00E+00 0.00E+00 4.07E-10 1.37E-08	
XE-138	0.00E+00	0.00E+00	0.00E+00	0.00E+00 0.00E+00 0.00E+00 0.00E+00 3.46E-34 9.38E-33	
KR-83M	0.00E+00	0.00E+00	0.00E+00	0.00E+00 0.00E+00 0.00E+00 0.00E+00 6.61E-15 7.56E-14	
KR-85M	0.00E+00	0.00E+00	0.00E+00	0.00E+00 0.00E+00 0.00E+00 0.00E+00 7.38E-12 2.64E-10	
KR-85	0.00E+00	0.00E+00	0.00E+00	0.00E+00 0.00E+00 0.00E+00 0.00E+00 1.67E-13 4.47E-10	
KR-87	0.00E+00	0.00E+00	0.00E+00	0.00E+00 0.00E+00 0.00E+00 0.00E+00 3.60E-15 1.42E-13	
KR-88	0.00E+00	0.00E+00	0.00E+00	0.00E+00 0.00E+00 0.00E+00 0.00E+00 1.90E-11 1.11E-10	
					0.00E+00 0.00E+00 0.00E+00 2.39E-06 1.49E-09 5.54E-08

TOTAL DOSES 0-30 DAYS 3.17E+01 1.46E+01 5.52E+00 6.78E+02 3.44E+00 6.86E+01

1

QDC CRDA, CR & LPZ, ALL REL GLAND: TID-14844: 0 - 30 d

ISOTOPE	ACTIVITY RELEASED (CURIES)			
	2. HRS	8. HRS	24. HRS	720. HRS
<b>ELEMENTAL</b>				
I-131	1.63E+03	1.16E-35	0.00E+00	0.00E+00 1.63E+03
I-132	2.41E+03	9.42E-36	0.00E+00	0.00E+00 2.41E+03
I-133	3.75E+03	2.52E-35	0.00E+00	0.00E+00 3.75E+03
I-134	4.35E+03	6.23E-36	0.00E+00	0.00E+00 4.35E+03
I-135	3.46E+03	2.02E-35	0.00E+00	0.00E+00 3.46E+03
<b>PARTICULATE</b>				
I-131	8.95E+01	6.38E-37	0.00E+00	0.00E+00 8.95E+01
I-132	1.32E+02	5.17E-37	0.00E+00	0.00E+00 1.32E+02
I-133	2.06E+02	1.39E-36	0.00E+00	0.00E+00 2.06E+02
I-134	2.39E+02	3.42E-37	0.00E+00	0.00E+00 2.39E+02
I-135	1.90E+02	1.11E-36	0.00E+00	0.00E+00 1.90E+02
<b>ORGANIC</b>				
I-131	7.16E+01	5.11E-37	0.00E+00	0.00E+00 7.16E+01
I-132	1.06E+02	4.14E-37	0.00E+00	0.00E+00 1.06E+02

I-133	1.65E+02	1.11E-36	0.00E+00	0.00E+00	1.65E+02
I-134	1.91E+02	2.74E-37	0.00E+00	0.00E+00	1.91E+02
I-135	1.52E+02	8.86E-37	0.00E+00	0.00E+00	1.52E+02
NOBLE GASES					
XE-131M	1.36E+03	9.72E-36	0.00E+00	0.00E+00	1.36E+03
XE-133M	1.05E+04	7.35E-35	0.00E+00	0.00E+00	1.05E+04
XE-133	4.13E+05	2.93E-33	0.00E+00	0.00E+00	4.13E+05
XE-135M	1.09E+05	3.65E-36	0.00E+00	0.00E+00	1.09E+05
XE-135	3.89E+05	2.40E-33	0.00E+00	0.00E+00	3.89E+05
XE-138	3.60E+05	2.15E-35	0.00E+00	0.00E+00	3.60E+05
KR-83M	3.20E+04	1.09E-34	0.00E+00	0.00E+00	3.20E+04
KR-85M	8.03E+04	4.20E-34	0.00E+00	0.00E+00	8.03E+04
KR-85	2.70E+03	1.94E-35	0.00E+00	0.00E+00	2.70E+03
KR-87	1.54E+05	3.68E-34	0.00E+00	0.00E+00	1.54E+05
KR-88	2.20E+05	9.57E-34	0.00E+00	0.00E+00	2.20E+05

END EXECUTION DATE: 11/18/1999

END EXECUTION TIME: 08:57:52.51

QDC 9400-M-0550 Rev. 0 Attachment A-B Page A-B6

AXIDENT VER 2 MOD 4  
 PRODUCTION DATE 02/18/92  
 BEGIN EXECUTION DATE: 11/18/1999  
 BEGIN EXECUTION TIME: 10:20:37.01

1 QDC CRDA, EAB, ALL REL MVP: TID-14844: 0 - 6 s  
 2 2 1 1. 1.  
 3 -2561 2.60+6 1.845+5 5.83+4  
 4 0. 0. 0. 1. 1. 2.78+5 0.  
 5 6 7200  
 6 0.2402 0.  
 7 9.058E-4 0.  
 8 2\*1.  
 9 2\*0.  
 10 2.9E-4 0.  
 11 2\*0.  
 12 2\*0.  
 13 2\*0.  
 14 2\*0.  
 15 2\*0.  
 16 2\*0.  
 17 2\*0.  
 18 2\*0.  
 19 2\*0.  
 20 2\*0.  
 21 6\*1.  
 22 3\*1.  
 23 7.16E+3 1.06E+4 1.65E+4 1.92E+4 1.52E+4 1.36E+3 1.05E+4 4.13E+5  
 24 1.11E+5 3.89E+5 3.65E+5 3.21E+4 8.04E+4 2.70E+3 1.55E+5 2.20E+5

1

QDC CRDA, EAB, ALL REL MVP: TID-14844: 0 - 6 s

## INITIAL CONTAINMENT INVENTORY

## ISOTOPE ACTIVITY (CURIES)

I-131	7.160E+03
I-132	1.060E+04
I-133	1.650E+04
I-134	1.920E+04
I-135	1.520E+04
XE-131M	1.360E+03
XE-133M	1.050E+04
XE-133	4.130E+05
XE-135M	1.110E+05
XE-135	3.890E+05
XE-138	3.650E+05
KR-83M	3.210E+04
KR-85M	8.040E+04
KR-85	2.700E+03
KR-87	1.550E+05
KR-88	2.200E+05

1 QDC CRDA, EAB, ALL REL MVP: TID-14844: 0 - 6 s

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
 SPRAYED VOL 1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO

AT .002 HOURS: X/Q(SITE)= .29E-03 SEC/M3 PRIMARY LEAK RATE=\*\*\*\*\* PERCENT/DAY CONTROL ROOM INTAKE=  
 .0 CFM  
 X/Q CONT ROOM= .00E+00 SEC/M3 SEC RELEASE RATE= .78E+02 VOL/DAY PCT PRI LKG TO ATM =  
 00.00

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM		SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA
<b>ELEMENTAL</b>											
I-131	3.85E+02	1.24E+03	4.16E+00	0.00E+00	0.00E+00	4.60E-01	1.12E-04	5.46E-05	0.00E+00	0.00E+00	0.00E+00
I-132	5.70E+02	1.83E+03	6.15E+00	0.00E+00	0.00E+00	3.90E-03	1.07E-03	1.84E-04	0.00E+00	0.00E+00	0.00E+00
I-133	8.88E+02	2.86E+03	9.58E+00	0.00E+00	0.00E+00	1.73E-01	3.31E-04	2.70E-04	0.00E+00	0.00E+00	0.00E+00
I-134	1.03E+03	3.32E+03	1.11E+01	0.00E+00	0.00E+00	1.23E-03	1.57E-03	3.38E-04	0.00E+00	0.00E+00	0.00E+00

1 QDC CRDA, EAB, ALL REL MVP: TID-14844: 0 - 6 s

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
SPRAYED VOL 1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO

AT .0 CFM	2.000 HOURS: X/Q(SITE)= .00E+00 SEC/M3	PRIMARY LEAK RATE= .000 PERCENT/DAY	CONTROL ROOM INTAKE=
	X/Q CONT ROOM= .00E+00 SEC/M3	SEC RELEASE RATE= .00E+00 VOL/DAY	PCT PRI LKG TO ATM =
	00.00		

CLEANUP RATES (HR-1)				FILTER NON-REMPTION FACTORS		
	SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	.000	1.000	1.000

1

	TOTAL DOSES 0-30 DAYS	7.32E-01	3.39E-01	1.28E-01	0.00E+00	0.00E+00	0.00E+00
--	-----------------------	----------	----------	----------	----------	----------	----------

QDC CRDA, EAB, ALL REL MVP: TID-14844: 0 - 6 s

ISOTOPE	ACTIVITY RELEASED (CURIES)	
	2. HRS	
<b>ELEMENTAL</b>		
I-131	4.16E+00	4.16E+00
I-132	6.15E+00	6.15E+00
I-133	9.58E+00	9.58E+00
I-134	1.11E+01	1.11E+01
I-135	8.82E+00	8.82E+00
<b>PARTICULATE</b>		
I-131	2.28E-01	2.28E-01
I-132	3.38E-01	3.38E-01
I-133	5.26E-01	5.26E-01
I-134	6.12E-01	6.12E-01
I-135	4.85E-01	4.85E-01
<b>ORGANIC</b>		
I-131	1.83E-01	1.83E-01
I-132	2.70E-01	2.70E-01
I-133	4.21E-01	4.21E-01
I-134	4.89E-01	4.89E-01
I-135	3.88E-01	3.88E-01
<b>NOBLE GASES</b>		
XE-131M	3.47E+00	3.47E+00
XE-133M	2.68E+01	2.68E+01
XE-133	1.05E+03	1.05E+03
XE-135M	2.82E+02	2.82E+02
XE-135	9.92E+02	9.92E+02
XE-138	9.29E+02	9.29E+02
KR-83M	8.19E+01	8.19E+01
KR-85M	2.05E+02	2.05E+02
KR-85	6.89E+00	6.89E+00
KR-87	3.95E+02	3.95E+02
KR-88	5.61E+02	5.61E+02

END EXECUTION DATE: 11/18/1999  
 END EXECUTION TIME: 10:20:37.01

AXIDENT VER 2 MOD 4  
 PRODUCTION DATE 02/18/92  
 BEGIN EXECUTION DATE: 11/18/1999  
 BEGIN EXECUTION TIME: 10:20:37.01

```

1 QDC CRDA, EAB, ALL REL MVP: TID-14844: 0 - 6 s
2 2 1 1. 1.
3 -2561 2.60+6 1.845+5 5.83+4
4 0. 0. 0. 1. 1. 2.78+5 0.
5 6 7200
6 0.2402 0.
7 9.058E-4 0.
8 2*1.
9 2*0.
10 2.9E-4 0.
11 2*0.
12 2*0.
13 2*0.
14 2*0.
15 2*0.
16 2*0.
17 2*0.
18 2*0.
19 2*0.
20 2*0.
21 6*1.
22 3*1.
23 7.16E+3      1.05E+4   1.65E+4   1.92E+4   1.52E+4   1.36E+3   1.05E+4   4.13E+5
24 1.11E+5      3.89E+5   3.65E+5   3.21E+4   8.04E+4   2.70E+3   1.55E+5   2.20E+5

```

1

QDC CRDA, EAB, ALL REL MVP: TID-14844: 0 - 6 s

## INITIAL CONTAINMENT INVENTORY

## ISOTOPE ACTIVITY (CURIES)

I-131	7.160E+03
I-132	1.060E+04
I-133	1.650E+04
I-134	1.920E+04
I-135	1.520E+04
XE-131M	1.360E+03
XE-133M	1.050E+04
XE-133	4.130E+05
XE-135M	1.110E+05
XE-135	3.890E+05
XE-138	3.650E+05
KR-83M	3.210E+04
KR-85M	8.040E+04
KR-85	2.700E+03
KR-87	1.550E+05
KR-88	2.200E+05

1

QDC CRDA, EAB, ALL REL MVP: TID-14844: 0 - 6 s

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
 SPRAYED VOL

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL,	1. CFM MIXING, 00.00 PCT REL TO
--	---------------------------------

AT .002 HOURS:	X/Q(SITE)= .29E-03 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM INTAKE=
.0 CFM			
00.00	X/Q CONT ROOM= .00E+00 SEC/M3	SEC RELEASE RATE= .78E+02 VOL/DAY	PCT PRI LKG TO ATM =

SPRAY	CLEANUP RATES (HR-1)			FILTER NON-REMOVAL FACTORS	
	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM		SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA
ELEMENTAL											
I-131	3.85E+02	1.24E+03	4.16E+00	0.00E+00	0.00E+00	4.60E-01	1.12E-04	5.46E-05	0.00E+00	0.00E+00	0.00E+00
I-132	5.70E+02	1.83E+03	6.15E+00	0.00E+00	0.00E+00	3.90E-03	1.07E-03	1.84E-04	0.00E+00	0.00E+00	0.00E+00
I-133	8.88E+02	2.86E+03	9.58E+00	0.00E+00	0.00E+00	1.73E-01	3.31E-04	2.70E-04	0.00E+00	0.00E+00	0.00E+00
I-134	1.03E+03	3.32E+03	1.11E+01	0.00E+00	0.00E+00	1.23E-03	1.57E-03	3.38E-04	0.00E+00	0.00E+00	0.00E+00

I-135	8.18E+02	2.63E+03	8.82E+00	0.00E+00	0.00E+00	2.75E-02	1.14E-03	1.81E-04	0.00E+00	0.00E+00	0.00E+00
<b>PARTICULATE</b>											
I-131	2.12E+01	6.81E+01	2.28E-01	0.00E+00	0.00E+00	2.53E-02	6.14E-06	3.00E-06	0.00E+00	0.00E+00	0.00E+00
I-132	3.13E+01	1.01E+02	3.38E-01	0.00E+00	0.00E+00	2.14E-04	5.88E-05	1.01E-05	0.00E+00	0.00E+00	0.00E+00
I-133	4.88E+01	1.57E+02	5.26E-01	0.00E+00	0.00E+00	9.53E-03	1.82E-05	1.48E-05	0.00E+00	0.00E+00	0.00E+00
I-134	5.67E+01	1.82E+02	6.12E-01	0.00E+00	0.00E+00	6.77E-05	8.60E-05	1.86E-05	0.00E+00	0.00E+00	0.00E+00
I-135	4.50E+01	1.45E+02	4.85E-01	0.00E+00	0.00E+00	1.51E-03	6.25E-05	9.96E-06	0.00E+00	0.00E+00	0.00E+00
<b>ORGANIC</b>											
I-131	1.69E+01	5.45E+01	1.83E-01	0.00E+00	0.00E+00	2.02E-02	4.91E-06	2.40E-06	0.00E+00	0.00E+00	0.00E+00
I-132	2.51E+01	8.06E+01	2.70E-01	0.00E+00	0.00E+00	1.71E-04	4.70E-05	8.08E-06	0.00E+00	0.00E+00	0.00E+00
I-133	3.90E+01	1.26E+02	4.21E-01	0.00E+00	0.00E+00	7.62E-03	1.46E-05	1.19E-05	0.00E+00	0.00E+00	0.00E+00
I-134	4.54E+01	1.46E+02	4.89E-01	0.00E+00	0.00E+00	5.42E-05	6.88E-05	1.49E-05	0.00E+00	0.00E+00	0.00E+00
I-135	3.60E+01	1.16E+02	3.88E-01	0.00E+00	0.00E+00	1.21E-03	5.00E-05	7.97E-06	0.00E+00	0.00E+00	0.00E+00
<b>NOBLE GASES</b>											
XE-131M	3.22E+02	1.03E+03	3.47E+00	0.00E+00	0.00E+00	0.00E+00	5.53E-06	3.12E-05	0.00E+00	0.00E+00	0.00E+00
XE-133M	2.48E+03	7.99E+03	2.68E+01	0.00E+00	0.00E+00	0.00E+00	6.41E-05	2.77E-04	0.00E+00	0.00E+00	0.00E+00
XE-133	9.77E+04	3.14E+05	1.05E+03	0.00E+00	0.00E+00	0.00E+00	2.29E-03	1.03E-02	0.00E+00	0.00E+00	0.00E+00
XE-135M	2.62E+04	8.41E+04	2.82E+02	0.00E+00	0.00E+00	0.00E+00	8.64E-03	1.83E-03	0.00E+00	0.00E+00	0.00E+00
XE-135	9.20E+04	2.96E+05	9.92E+02	0.00E+00	0.00E+00	0.00E+00	1.77E-02	2.13E-02	0.00E+00	0.00E+00	0.00E+00
XE-138	8.60E+04	2.77E+05	9.29E+02	0.00E+00	0.00E+00	0.00E+00	1.93E-01	4.96E-02	0.00E+00	0.00E+00	0.00E+00
KR-83M	7.59E+03	2.44E+04	8.19E+01	0.00E+00	0.00E+00	0.00E+00	2.97E-05	1.86E-04	0.00E+00	0.00E+00	0.00E+00
KR-85M	1.90E+04	6.12E+04	2.05E+02	0.00E+00	0.00E+00	0.00E+00	2.32E-03	3.19E-03	0.00E+00	0.00E+00	0.00E+00
KR-85	6.39E+02	2.05E+03	6.89E+00	0.00E+00	0.00E+00	0.00E+00	1.05E-06	1.02E-04	0.00E+00	0.00E+00	0.00E+00
KR-87	3.66E+04	1.18E+05	3.95E+02	0.00E+00	0.00E+00	0.00E+00	3.94E-02	2.77E-02	0.00E+00	0.00E+00	0.00E+00
KR-88	5.20E+04	1.67E+05	5.61E+02	0.00E+00	0.00E+00	0.00E+00	7.09E-02	1.28E-02	0.00E+00	0.00E+00	0.00E+00
-----											
						7.32E-01	3.39E-01	1.28E-01	0.00E+00	0.00E+00	0.00E+00

1 QDC CRDA, EAB, ALL REL MVP: TID-14844: 0 - 6 s

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

SPRAYED VOL 1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO

AT 2.000 HOURS: X/Q(SITE)= .00E+00 SEC/M3 PRIMARY LEAK RATE= .000 PERCENT/DAY CONTROL ROOM INTAKE=.  
 .0 CFM  
 X/Q CONT ROOM= .00E+00 SEC/M3 SEC RELEASE RATE= .00E+00 VOL/DAY PCT PRI LKG TO ATM =  
 00.00

CLEANUP RATES (HR-1)				FILTER NON-REMPTION FACTORS		
	SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	.000	1.000	1.000

1

QDC CRDA, EAB, ALL REL MVP: TID-14844: 0 - 6 s

ISOTOPE	2. HRS	ACTIVITY RELEASED (CURIES)
<b>ELEMENTAL</b>		
I-131	4.16E+00	4.16E+00
I-132	6.15E+00	6.15E+00
I-133	9.58E+00	9.58E+00
I-134	1.11E+01	1.11E+01
I-135	8.82E+00	8.82E+00
<b>PARTICULATE</b>		
I-131	2.28E-01	2.28E-01
I-132	3.38E-01	3.38E-01
I-133	5.26E-01	5.26E-01
I-134	6.12E-01	6.12E-01
I-135	4.85E-01	4.85E-01
<b>ORGANIC</b>		
I-131	1.83E-01	1.83E-01
I-132	2.70E-01	2.70E-01
I-133	4.21E-01	4.21E-01
I-134	4.89E-01	4.89E-01
I-135	3.88E-01	3.88E-01
<b>NOBLE GASES</b>		
XE-131M	3.47E+00	3.47E+00
XE-133M	2.68E+01	2.68E+01
XE-133	1.05E+03	1.05E+03
XE-135M	2.82E+02	2.82E+02
XE-135	9.92E+02	9.92E+02
XE-138	9.29E+02	9.29E+02
KR-83M	8.19E+01	8.19E+01
KR-85M	2.05E+02	2.05E+02
KR-85	6.89E+00	6.89E+00
KR-87	3.95E+02	3.95E+02
KR-88	5.61E+02	5.61E+02

END EXECUTION DATE: 11/18/1999  
 END EXECUTION TIME: 10:20:37.01

AXIDENT VER 2 MOD 4  
 PRODUCTION DATE 02/18/92  
 BEGIN EXECUTION DATE: 11/18/1999  
 BEGIN EXECUTION TIME: 10:20:49.97

```

1 QDC CRDA, EAB, ALL REL GLAND: TID-14844: 0 - 2 h
2 3 2 1. 1.
3 -2561 2.60+6 1.845+5 5.83+4
4 0. 0. 1. 1. 2.78+5 0.
5 6 1800 7200
6 0.2402 2*1.201E-2
7 3*1.
8 3*1.
9 3*0.
10 2*2.9e-4 2.3E-5
11 3*0.
12 3*0.
13 3*0.
14 3*0.
15 3*0.
16 3*0.
17 3*0.
18 3*0.
19 3*0.
20 3*0.
21 6*1.
22 3*1.
23 7.16E+3      1.06E+4   1.65E+4   1.92E+4   1.52E+4   1.36E+3   1.05E+4   4.13E+5
24 1.11E+5      3.89E+5   3.65E+5   3.21E+4   8.04E+4   2.70E+3   1.55E+5   2.20E+5

```

1

QDC CRDA, EAB, ALL REL GLAND: TID-14844: 0 - 2 h

## INITIAL CONTAINMENT INVENTORY

## ISOTOPE ACTIVITY (CURIES)

I-131	7.160E+03
I-132	1.060E+04
I-133	1.650E+04
I-134	1.920E+04
I-135	1.520E+04
XE-131M	1.360E+03
XE-133M	1.050E+04
XE-133	4.130E+05
XE-135M	1.110E+05
XE-135	3.890E+05
XE-138	3.650E+05
KR-83M	3.210E+04
KR-85M	8.040E+04
KR-85	2.700E+03
KR-87	1.550E+05
KR-88	2.200E+05

1 QDC CRDA, EAB, ALL REL GLAND: TID-14844: 0 - 2 h

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
 SPRAYED VOL 1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO

AT .002 HOURS: X/Q(SITE)= .29E-03 SEC/M3 PRIMARY LEAK RATE=\*\*\*\*\* PERCENT/DAY CONTROL ROOM INTAKE=  
 .0 CFM  
 X/Q CONT ROOM= .00E+00 SEC/M3 SEC RELEASE RATE= .86E+05 VOL/DAY PCT PRI LKG TO ATM =  
 00.00

SPRAY	CLEANUP RATES (HR-1)			FILTER NON-REMOVAL FACTORS	
	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM		SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA
ELEMENTAL											
I-131	3.85E+02	1.21E+02	1.12E+03	0.00E+00	0.00E+00	1.24E+02	3.02E-02	1.48E-02	0.00E+00	0.00E+00	0.00E+00
I-132	5.70E+02	1.78E+02	1.66E+03	0.00E+00	0.00E+00	1.05E+00	2.89E-01	4.97E-02	0.00E+00	0.00E+00	0.00E+00
I-133	8.88E+02	2.78E+02	2.59E+03	0.00E+00	0.00E+00	4.69E+01	8.95E-02	7.30E-02	0.00E+00	0.00E+00	0.00E+00
I-134	1.03E+03	3.23E+02	3.01E+03	0.00E+00	0.00E+00	3.33E-01	4.23E-01	9.13E-02	0.00E+00	0.00E+00	0.00E+00

I-135	8.18E+02	2.56E+02	2.38E+03	0.00E+00	0.00E+00	7.44E+00	3.07E-01	4.90E-02	0.00E+00	0.00E+00	0.00E+00
<b>PARTICULATE</b>											
I-131	2.12E+01	6.63E+00	6.17E+01	0.00E+00	0.00E+00	6.83E+00	1.66E-03	8.11E-04	0.00E+00	0.00E+00	0.00E+00
I-132	3.13E+01	9.80E+00	9.13E+01	0.00E+00	0.00E+00	5.79E-02	1.59E-02	2.73E-03	0.00E+00	0.00E+00	0.00E+00
I-133	4.88E+01	1.53E+01	1.42E+02	0.00E+00	0.00E+00	2.58E+00	4.92E-03	4.01E-03	0.00E+00	0.00E+00	0.00E+00
I-134	5.67E+01	1.77E+01	1.65E+02	0.00E+00	0.00E+00	1.83E-02	2.32E-02	5.02E-03	0.00E+00	0.00E+00	0.00E+00
I-135	4.50E+01	1.41E+01	1.31E+02	0.00E+00	0.00E+00	4.09E-01	1.69E-02	2.69E-03	0.00E+00	0.00E+00	0.00E+00
<b>ORGANIC</b>											
I-131	1.69E+01	5.30E+00	4.94E+01	0.00E+00	0.00E+00	5.46E+00	1.33E-03	6.49E-04	0.00E+00	0.00E+00	0.00E+00
I-132	2.51E+01	7.84E+00	7.31E+01	0.00E+00	0.00E+00	4.63E-02	1.27E-02	2.18E-03	0.00E+00	0.00E+00	0.00E+00
I-133	3.90E+01	1.22E+01	1.14E+02	0.00E+00	0.00E+00	2.06E+00	3.93E-03	3.21E-03	0.00E+00	0.00E+00	0.00E+00
I-134	4.54E+01	1.42E+01	1.32E+02	0.00E+00	0.00E+00	1.46E-02	1.86E-02	4.01E-03	0.00E+00	0.00E+00	0.00E+00
I-135	3.60E+01	1.13E+01	1.05E+02	0.00E+00	0.00E+00	3.27E-01	1.35E-02	2.15E-03	0.00E+00	0.00E+00	0.00E+00
<b>NOBLE GASES</b>											
XE-131M	3.22E+02	1.01E+02	9.37E+02	0.00E+00	0.00E+00	0.00E+00	1.50E-03	8.44E-03	0.00E+00	0.00E+00	0.00E+00
XE-133M	2.48E+03	7.77E+02	7.24E+03	0.00E+00	0.00E+00	0.00E+00	1.73E-02	7.48E-02	0.00E+00	0.00E+00	0.00E+00
XE-133	9.77E+04	3.06E+04	2.85E+05	0.00E+00	0.00E+00	0.00E+00	6.19E-01	2.77E+00	0.00E+00	0.00E+00	0.00E+00
XE-135M	2.62E+04	8.18E+03	7.64E+04	0.00E+00	0.00E+00	0.00E+00	2.34E+00	4.94E-01	0.00E+00	0.00E+00	0.00E+00
XE-135	9.20E+04	2.88E+04	2.68E+05	0.00E+00	0.00E+00	0.00E+00	4.78E+00	5.76E+00	0.00E+00	0.00E+00	0.00E+00
XE-138	8.60E+04	2.69E+04	2.51E+05	0.00E+00	0.00E+00	0.00E+00	5.23E+01	1.34E+01	0.00E+00	0.00E+00	0.00E+00
KR-83M	7.59E+03	2.37E+03	2.21E+04	0.00E+00	0.00E+00	0.00E+00	8.02E-03	5.02E-02	0.00E+00	0.00E+00	0.00E+00
KR-85M	1.90E+04	5.95E+03	5.54E+04	0.00E+00	0.00E+00	0.00E+00	6.27E-01	8.61E-01	0.00E+00	0.00E+00	0.00E+00
KR-85	6.39E+02	2.00E+02	1.86E+03	0.00E+00	0.00E+00	0.00E+00	2.83E-04	2.77E-02	0.00E+00	0.00E+00	0.00E+00
KR-87	3.66E+04	1.15E+04	1.07E+05	0.00E+00	0.00E+00	0.00E+00	1.06E+01	7.48E+00	0.00E+00	0.00E+00	0.00E+00
KR-88	5.20E+04	1.63E+04	1.52E+05	0.00E+00	0.00E+00	0.00E+00	1.92E+01	3.45E+00	0.00E+00	0.00E+00	0.00E+00
							-----	-----			
							1.98E+02	9.17E+01	3.47E+01	0.00E+00	0.00E+00

1 QDC CRDA, EAB, ALL REL GLAND: TID-14844: 0 - 2 h

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
 1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO  
 SPRAYED VOL

AT .500 HOURS:	X/Q(SITE)= .29E-03 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM INTAKE=
.0 CFM			
	X/Q CONT ROOM= .00E+00 SEC/M3	SEC RELEASE RATE= .86E+05 VOL/DAY	PCT PRI LKG TO ATM =
00.00			

	CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS			
	SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER		
ELEMENTAL	.000	.000	.000	.000	1.000	1.000		
PARTICULATE	.000	.000	.000	.000	1.000	1.000		
ORGANIC	.000	.000	.000	.000	1.000	1.000		
ISOTOPE	ACTIVITY (CURIES)	CONTROL ROOM (CURIES)	SITE BOUNDARY DOSES (REM)		CONTROL ROOM DOSES (REM)			
	PRIMARY	SECONDARY	RELEASE	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID
ELEMENTAL	1.69E-07	2.05E-09	5.06E+02	0.00E+00	0.00E+00	5.60E+01	1.36E-02	6.65E-03
I-131	2.16E-07	2.62E-09	7.45E+02	0.00E+00	0.00E+00	4.72E-01	1.30E-01	2.23E-02
I-132	3.84E-07	4.67E-09	1.17E+03	0.00E+00	0.00E+00	2.11E+01	4.03E-02	3.29E-02
I-133	3.04E-07	3.70E-09	1.34E+03	0.00E+00	0.00E+00	1.48E-01	1.88E-01	4.06E-02
I-134	3.41E-07	4.15E-09	1.07E+03	0.00E+00	0.00E+00	3.34E+00	1.38E-01	2.20E-02
PARTICULATE	9.29E-09	1.13E-10	2.78E+01	0.00E+00	0.00E+00	3.08E+00	7.48E-04	3.65E-04
I-131	1.18E-08	1.44E-10	4.09E+01	0.00E+00	0.00E+00	2.59E-02	7.12E-03	1.22E-03
I-132	2.11E-08	2.56E-10	6.40E+01	0.00E+00	0.00E+00	1.16E+00	2.21E-03	1.81E-03
I-133	1.67E-08	2.03E-10	7.34E+01	0.00E+00	0.00E+00	8.13E-03	1.03E-02	2.23E-03
I-134	1.88E-08	2.28E-10	5.89E+01	0.00E+00	0.00E+00	1.84E-01	7.60E-03	1.21E-03
ORGANIC	7.43E-09	9.03E-11	2.22E+01	0.00E+00	0.00E+00	2.46E+00	5.98E-04	2.92E-04
I-131	9.48E-09	1.15E-10	3.27E+01	0.00E+00	0.00E+00	2.08E-02	5.70E-03	9.78E-04
I-132	1.69E-08	2.05E-10	5.12E+01	0.00E+00	0.00E+00	9.28E-01	1.77E-03	1.45E-03
I-133	1.34E-08	1.63E-10	5.87E+01	0.00E+00	0.00E+00	6.50E-03	8.26E-03	1.78E-03
I-134	1.50E-08	1.82E-10	4.71E+01	0.00E+00	0.00E+00	1.47E-01	6.08E-03	9.68E-04
NOBLE GASES	1.41E-07	1.72E-09	4.22E+02	0.00E+00	0.00E+00	0.00E+00	6.74E-04	3.80E-03
XE-131M	1.08E-06	1.32E-08	3.26E+03	0.00E+00	0.00E+00	0.00E+00	7.80E-03	3.37E-02
XE-133	4.28E-05	5.20E-07	1.28E+05	0.00E+00	0.00E+00	0.00E+00	2.79E-01	1.25E+00
XE-135M	3.05E-06	3.70E-08	3.28E+04	0.00E+00	0.00E+00	0.00E+00	1.00E+00	2.12E-01
XE-135	3.89E-05	4.73E-07	1.21E+05	0.00E+00	0.00E+00	0.00E+00	2.15E+00	2.59E+00
XE-138	1.16E-05	1.41E-07	1.08E+05	0.00E+00	0.00E+00	0.00E+00	2.26E+01	5.78E+00
KR-83M	2.77E-06	3.37E-08	9.90E+03	0.00E+00	0.00E+00	0.00E+00	3.59E-03	2.25E-02
KR-85M	7.72E-06	9.39E-08	2.49E+04	0.00E+00	0.00E+00	0.00E+00	2.82E-01	3.87E-01
KR-85	2.81E-07	3.41E-09	8.39E+02	0.00E+00	0.00E+00	0.00E+00	1.28E-04	1.25E-02
KR-87	1.23E-05	1.49E-07	4.76E+04	0.00E+00	0.00E+00	0.00E+00	4.75E+00	3.34E+00
KR-88	2.02E-05	2.46E-07	6.80E+04	0.00E+00	0.00E+00	0.00E+00	8.60E+00	1.55E+00
					8.91E+01	4.02E+01	1.53E+01	0.00E+00

1 QDC CRDA, EAB, ALL REL GLAND: TID-14844: 0 - 2 h

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO  
SPRAYED VOL

AT .0 CFM	2.000 HOURS:	X/Q(SITE) = .23E-04 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM INTAKE=
		X/Q CONT ROOM= .00E+00 SEC/M3	SEC RELEASE RATE= .86E+05 VOL/DAY	PCT PRI LKG TO ATM =
	00.00			

CLEANUP RATES (HR-1)						FILTER NON-REMOVAL FACTORS					
	SPRAY	PRIMARY	SECONDARY	CONT CENTER		RELEASE	CONT CENTER				
ELEMENTAL	.000	.000	.000	.000		1.000	1.000				
PARTICULATE	.000	.000	.000	.000		1.000	1.000				
ORGANIC	.000	.000	.000	.000		1.000	1.000				
ISOTOPE	ACTIVITY (CURIES)	CONTROL ROOM (CURIES)	SITE BOUNDARY DOSES (REM)	THYROID WH BODY BETA	THYROID WH BODY BETA	CONTROL ROOM DOSES (REM)	THYROID WH BODY BETA				
	PRIMARY SECONDARY RELEASE	(UCI/CM3)	THYROID WH BODY	BETA	THYROID WH BODY	BETA	THYROID WH BODY	BETA			
ELEMENTAL											
I-131	1.15E-35	1.40E-37	1.71E-07	0.00E+00 0.00E+00	1.50E-09 3.65E-13	1.78E-13	0.00E+00 0.00E+00	0.00E+00 0.00E+00			
I-132	9.37E-36	1.14E-37	2.17E-07	0.00E+00 0.00E+00	1.09E-11 2.99E-12	5.14E-13	0.00E+00 0.00E+00	0.00E+00 0.00E+00			
I-133	2.49E-35	3.03E-37	3.88E-07	0.00E+00 0.00E+00	5.58E-10 1.06E-12	8.69E-13	0.00E+00 0.00E+00	0.00E+00 0.00E+00			
I-134	6.27E-36	7.62E-38	3.03E-07	0.00E+00 0.00E+00	2.66E-12 3.37E-12	7.28E-13	0.00E+00 0.00E+00	0.00E+00 0.00E+00			
I-135	2.00E-35	2.43E-37	3.45E-07	0.00E+00 0.00E+00	8.53E-11 3.53E-12	5.62E-13	0.00E+00 0.00E+00	0.00E+00 0.00E+00			
PARTICULATE											
I-131	6.31E-37	7.67E-39	9.40E-09	0.00E+00 0.00E+00	8.25E-11 2.00E-14	9.79E-15	0.00E+00 0.00E+00	0.00E+00 0.00E+00			
I-132	5.15E-37	6.26E-39	1.19E-08	0.00E+00 0.00E+00	5.99E-13 1.64E-13	2.82E-14	0.00E+00 0.00E+00	0.00E+00 0.00E+00			
I-133	1.37E-36	1.67E-38	2.13E-08	0.00E+00 0.00E+00	3.06E-11 5.85E-14	4.77E-14	0.00E+00 0.00E+00	0.00E+00 0.00E+00			
I-134	3.44E-37	4.19E-39	1.66E-08	0.00E+00 0.00E+00	1.46E-13 1.85E-13	4.00E-14	0.00E+00 0.00E+00	0.00E+00 0.00E+00			
I-135	1.10E-36	1.33E-38	1.89E-08	0.00E+00 0.00E+00	4.69E-12 1.94E-13	3.09E-14	0.00E+00 0.00E+00	0.00E+00 0.00E+00			
ORGANIC											
I-131	5.05E-37	6.13E-39	7.52E-09	0.00E+00 0.00E+00	6.60E-11 1.60E-14	7.84E-15	0.00E+00 0.00E+00	0.00E+00 0.00E+00			
I-132	4.12E-37	5.01E-39	9.53E-09	0.00E+00 0.00E+00	4.79E-13 1.31E-13	2.26E-14	0.00E+00 0.00E+00	0.00E+00 0.00E+00			
I-133	1.10E-36	1.33E-38	1.71E-08	0.00E+00 0.00E+00	2.45E-11 4.68E-14	3.82E-14	0.00E+00 0.00E+00	0.00E+00 0.00E+00			
I-134	2.76E-37	3.35E-39	1.33E-08	0.00E+00 0.00E+00	1.17E-13 1.48E-13	3.20E-14	0.00E+00 0.00E+00	0.00E+00 0.00E+00			
I-135	8.77E-37	1.07E-38	1.52E-08	0.00E+00 0.00E+00	3.75E-12 1.55E-13	2.47E-14	0.00E+00 0.00E+00	0.00E+00 0.00E+00			
NOBLE GASES											
XE-131M	9.60E-36	1.17E-37	1.43E-07	0.00E+00 0.00E+00	0.00E+00 1.81E-14	1.02E-13	0.00E+00 0.00E+00	0.00E+00 0.00E+00			
XE-133M	7.26E-35	8.83E-37	1.10E-06	0.00E+00 0.00E+00	0.00E+00 2.08E-13	9.00E-13	0.00E+00 0.00E+00	0.00E+00 0.00E+00			
XE-133	2.90E-33	3.52E-35	4.33E-05	0.00E+00 0.00E+00	0.00E+00 7.47E-12	3.35E-11	0.00E+00 0.00E+00	0.00E+00 0.00E+00			
XE-135M	3.82E-36	4.65E-38	2.90E-06	0.00E+00 0.00E+00	0.00E+00 7.05E-12	1.49E-12	0.00E+00 0.00E+00	0.00E+00 0.00E+00			
XE-135	2.37E-33	2.88E-35	3.93E-05	0.00E+00 0.00E+00	0.00E+00 5.56E-11	6.70E-11	0.00E+00 0.00E+00	0.00E+00 0.00E+00			
XE-138	2.24E-35	2.72E-37	1.11E-05	0.00E+00 0.00E+00	0.00E+00 1.83E-10	4.70E-11	0.00E+00 0.00E+00	0.00E+00 0.00E+00			
KR-83M	1.09E-34	1.32E-36	2.78E-06	0.00E+00 0.00E+00	0.00E+00 8.00E-14	5.00E-13	0.00E+00 0.00E+00	0.00E+00 0.00E+00			
KR-85M	4.16E-34	5.06E-36	7.79E-06	0.00E+00 0.00E+00	0.00E+00 6.99E-12	9.60E-12	0.00E+00 0.00E+00	0.00E+00 0.00E+00			
KR-85	1.92E-35	2.33E-37	2.84E-07	0.00E+00 0.00E+00	0.00E+00 3.43E-15	3.35E-13	0.00E+00 0.00E+00	0.00E+00 0.00E+00			
KR-87	3.68E-34	4.48E-36	1.22E-05	0.00E+00 0.00E+00	0.00E+00 9.68E-11	6.80E-11	0.00E+00 0.00E+00	0.00E+00 0.00E+00			
KR-88	9.51E-34	1.16E-35	2.03E-05	0.00E+00 0.00E+00	0.00E+00 2.04E-10	3.67E-11	0.00E+00 0.00E+00	0.00E+00 0.00E+00			
					2.37E-09	5.74E-10	2.68E-10	0.00E+00	0.00E+00	0.00E+00	
TOTAL DOSES 0-30 DAYS					2.87E+02	1.32E+02	5.00E+01	0.00E+00	0.00E+00	0.00E+00	

1

QDC CRDA, EAB, ALL REL GLAND: TID-14844: 0 - 2 h

ISOTOPE	ACTIVITY RELEASED (CURIES)
	2. HRS
ELEMENTAL	
I-131	1.63E+03 1.63E+03
I-132	2.41E+03 2.41E+03
I-133	3.75E+03 3.75E+03
I-134	4.35E+03 4.35E+03
I-135	3.46E+03 3.46E+03
PARTICULATE	
I-131	8.95E+01 8.95E+01
I-132	1.32E+02 1.32E+02
I-133	2.06E+02 2.06E+02
I-134	2.39E+02 2.39E+02
I-135	1.90E+02 1.90E+02
ORGANIC	
I-131	7.16E+01 7.16E+01
I-132	1.06E+02 1.06E+02
I-133	1.65E+02 1.65E+02
I-134	1.91E+02 1.91E+02
I-135	1.52E+02 1.52E+02
NOBLE GASES	
XE-131M	1.36E+03 1.36E+03

XE-133M	1.05E+04	1.05E+04
XE-133	4.13E+05	4.13E+05
XE-135M	1.09E+05	1.09E+05
XE-135	3.89E+05	3.89E+05
XE-138	3.60E+05	3.60E+05
KR-83M	3.20E+04	3.20E+04
KR-85M	8.03E+04	8.03E+04
KR-85	2.70E+03	2.70E+03
KR-87	1.54E+05	1.54E+05
KR-88	2.20E+05	2.20E+05

END EXECUTION DATE: 11/18/1999  
END EXECUTION TIME: 10:20:50.08

AXIDENT VER 2 MOD 4  
 PRODUCTION DATE 02/18/92  
 BEGIN EXECUTION DATE: 11/18/1999  
 BEGIN EXECUTION TIME: 19:17:14.99

```

1 QDC CRDA, CR & LPZ, ALL REL MVP: SIEMENS 20 GWD/MTU: 0 - 6 s
2 2 2 1. 1.
3 -2561 2.60+6 1.845+5 5.83+4
4 0. 0. 1. 1. 2.78+5 0.
5 6 2.592E6
6 0.2402 0.
7 9.058E-4 0.
8 2*1.
9 2*2460
10 3.2E-5 0.
11 7.00E-4 0.
12 2*0.
13 2*0.
14 2*0.
15 2*0.
16 2*0.
17 2*0.
18 2*0.
19 2*0.
20 2*0.
21 6*1.
22 3*1.
23 6.76E+3      9.73E+3   1.36E+4   1.57E+4   1.22E+4   1.21E+3   8.18E+3   3.40E+5
24 9.21E+4      1.12E+5   3.07E+5   1.82E+4   4.99E+4   2.28E+3   9.80E+4   1.42E+5

```

1

QDC CRDA, CR &amp; LPZ, ALL REL MVP: SIEMENS 20 GWD/MTU: 0 - 6 s

## INITIAL CONTAINMENT INVENTORY

## ISOTOPE ACTIVITY (CURIES)

I-131	6.760E+03
I-132	9.730E+03
I-133	1.360E+04
I-134	1.570E+04
I-135	1.220E+04
XE-131M	1.210E+03
XE-133M	8.180E+03
XE-133	3.400E+05
XE-135M	9.210E+04
XE-135	1.120E+05
XE-138	3.070E+05
KR-83M	1.820E+04
KR-85M	4.990E+04
KR-85	2.280E+03
KR-87	9.800E+04
KR-88	1.420E+05

1

QDC CRDA, CR &amp; LPZ, ALL REL MVP: SIEMENS 20 GWD/MTU: 0 - 6 s

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL,	1. CFM MIXING, 00.00 PCT REL TO
SPRAYED VOL	

AT .002 HOURS: X/Q(SITE)= .32E-04 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM
INTAKE=2460.0 CFM		
X/Q CONT ROOM= .70E-03 SEC/M3	SEC RELEASE RATE= .78E+02 VOL/DAY	PCT PRI LKG TO ATM =
00.00		

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM		SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA
ELEMENTAL											
I-131	3.64E+02	1.17E+03	3.92E+00	3.19E-03	6.10E-07	4.79E-02	1.16E-05	5.69E-06	5.16E-04	4.48E-09	6.13E-08
I-132	5.24E+02	1.68E+03	5.65E+00	4.58E-03	8.78E-07	3.95E-04	1.08E-04	1.86E-05	4.25E-06	3.61E-08	2.00E-07
I-133	7.32E+02	2.35E+03	7.89E+00	6.41E-03	1.23E-06	1.58E-02	3.01E-05	2.46E-05	1.70E-04	1.45E-08	2.265E-07
I-134	8.44E+02	2.71E+03	9.10E+00	7.39E-03	1.41E-06	1.11E-04	1.41E-04	3.05E-05	1.20E-06	6.24E-08	3.28E-07

I-135	6.57E+02	2.11E+03	7.08E+00	5.75E-03	1.10E-06	2.44E-03	1.01E-04	1.60E-05	2.62E-05	2.64E-08	1.73E-07
<b>PARTICULATE</b>											
I-131	2.00E+01	6.43E+01	2.16E-01	1.75E-04	3.35E-08	2.63E-03	6.40E-07	3.13E-07	2.84E-05	2.46E-10	3.37E-09
I-132	2.88E+01	9.25E+01	3.10E-01	2.52E-04	4.82E-08	2.17E-05	5.96E-06	1.02E-06	2.34E-07	1.98E-09	1.10E-08
I-133	4.02E+01	1.29E+02	4.34E-01	3.52E-04	6.74E-08	8.67E-04	1.65E-06	1.35E-06	9.34E-06	7.98E-10	1.45E-08
I-134	4.64E+01	1.49E+02	5.00E-01	4.06E-04	7.77E-08	6.11E-06	7.76E-06	1.68E-06	6.58E-08	3.43E-09	1.80E-08
I-135	3.61E+01	1.16E+02	3.89E-01	3.16E-04	6.05E-08	1.34E-04	5.54E-06	8.82E-07	1.44E-06	1.45E-09	9.50E-09
<b>ORGANIC</b>											
I-131	1.60E+01	5.14E+01	1.72E-01	1.40E-04	2.68E-08	2.11E-03	5.12E-07	2.50E-07	2.27E-05	1.97E-10	2.69E-09
I-132	2.30E+01	7.40E+01	2.48E-01	2.02E-04	3.86E-08	1.74E-05	4.76E-06	8.18E-07	1.87E-07	1.58E-09	8.81E-09
I-133	3.22E+01	1.03E+02	3.47E-01	2.82E-04	5.39E-08	6.93E-04	1.32E-06	1.08E-06	7.47E-06	6.38E-10	1.16E-08
I-134	3.71E+01	1.19E+02	4.00E-01	3.25E-04	6.22E-08	4.89E-06	6.21E-06	1.34E-06	5.26E-08	2.74E-09	1.44E-08
I-135	2.89E+01	9.28E+01	3.11E-01	2.53E-04	4.84E-08	1.07E-04	4.43E-06	7.05E-07	1.15E-06	1.16E-09	7.60E-09
<b>NOBLE GASES</b>											
XE-131M	2.86E+02	9.21E+02	3.09E+00	2.51E-03	4.80E-07	0.00E+00	5.43E-07	3.07E-06	0.00E+00	9.15E-10	3.30E-08
XE-133M	1.94E+03	6.22E+03	2.09E+01	1.70E-02	3.24E-06	0.00E+00	5.51E-06	2.38E-05	0.00E+00	2.73E-09	2.56E-07
XE-133	8.05E+04	2.59E+05	8.67E+02	7.05E-01	1.35E-04	0.00E+00	2.08E-04	9.32E-04	0.00E+00	2.54E-07	1.00E-05
XE-135M	2.17E+04	6.98E+04	2.34E+02	1.90E-01	3.64E-05	0.00E+00	7.91E-06	1.67E-04	0.00E+00	3.12E-07	1.80E-06
XE-135	2.65E+04	8.52E+04	2.86E+02	2.32E-01	4.44E-05	0.00E+00	5.62E-04	6.77E-04	0.00E+00	2.16E-07	7.29E-06
XE-138	7.24E+04	2.33E+05	7.81E+02	6.34E-01	1.21E-04	0.00E+00	1.79E-02	4.60E-03	0.00E+00	1.83E-06	4.95E-05
KR-83M	4.30E+03	1.38E+04	4.64E+01	3.77E-02	7.21E-06	0.00E+00	1.86E-06	1.16E-05	0.00E+00	1.09E-08	1.25E-07
KR-85M	1.18E+04	3.80E+04	1.27E+02	1.03E-01	1.98E-05	0.00E+00	1.59E-04	2.18E-04	0.00E+00	6.57E-08	2.35E-06
KR-85	5.40E+02	1.73E+03	5.82E+00	4.72E-03	9.04E-07	0.00E+00	9.77E-08	9.55E-06	0.00E+00	3.85E-11	1.03E-07
KR-87	2.32E+04	7.45E+04	2.50E+02	2.03E-01	3.88E-05	0.00E+00	2.75E-03	1.93E-03	0.00E+00	5.27E-07	2.08E-05
KR-88	3.36E+04	1.08E+05	3.62E+02	2.94E-01	5.63E-05	0.00E+00	5.05E-03	9.09E-04	0.00E+00	1.67E-06	9.79E-06
<hr/>											
							7.32E-02	2.79E-02	9.59E-03	7.89E-04	5.04E-06
											1.03E-04

1 QDC CRDA, CR &amp; LPZ, ALL REL MVP: SIEMENS 20 GWD/MTU: 0 - 6 s

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO  
SPRAYED VOLAT 720.000 HOURS: X/Q(SITE)= .00E+00 SEC/M3 PRIMARY LEAK RATE= .000 PERCENT/DAY CONTROL ROOM  
INTAKE=2460.0 CFMX/Q CONT ROOM= .00E+00 SEC/M3 SEC RELEASE RATE= .00E+00 VOL/DAY PCT PRI LKG TO ATM =  
00.00

SPRAY	CLEANUP RATES (HR-1)			FILTER NON-REMOVAL FACTORS	
	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	1.000	1.000

ACTIVITY (CURIES)		CONTROL ROOM (CURIES)		SITE BOUNDARY DOSES (REM)
	PRIMARY	SECONDARY	THYROID WH BODY BETA	THYROID WH BODY BETA
<b>ELEMENTAL</b>				
I-131	2.75E+01	8.83E+01	0.00E+00	0.00E+00 0.00E+00 1.04E+00 9.05E-06 1.24E-04
I-132	3.15E-92	1.01E-91	0.00E+00	0.00E+00 0.00E+00 6.27E-03 5.32E-05 2.96E-04
I-133	3.48E-08	1.12E-07	0.00E+00	0.00E+00 0.00E+00 3.31E-01 2.83E-05 5.16E-04
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00 0.00E+00 1.22E-03 6.34E-05 3.33E-04
I-135	3.24E-30	1.04E-29	0.00E+00	0.00E+00 0.00E+00 4.72E-02 4.75E-05 3.11E-04
<b>PARTICULATE</b>				
I-131	1.51E+00	4.85E+00	0.00E+00	0.00E+00 0.00E+00 5.73E-02 4.97E-07 6.80E-06
I-132	1.73E-93	5.57E-93	0.00E+00	0.00E+00 0.00E+00 3.45E-04 2.92E-06 1.62E-05
I-133	1.91E-09	6.15E-09	0.00E+00	0.00E+00 0.00E+00 1.82E-02 1.56E-06 2.83E-05
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00 0.00E+00 6.68E-05 3.48E-06 1.83E-05
I-135	1.78E-31	5.72E-31	0.00E+00	0.00E+00 0.00E+00 2.59E-03 2.61E-06 1.71E-05
<b>ORGANIC</b>				
I-131	1.21E+00	3.88E+00	0.00E+00	0.00E+00 0.00E+00 4.58E-02 3.98E-07 5.44E-06
I-132	1.39E-93	4.46E-93	0.00E+00	0.00E+00 0.00E+00 2.76E-04 2.34E-06 1.30E-05
I-133	1.53E-09	4.92E-09	0.00E+00	0.00E+00 0.00E+00 1.46E-02 1.24E-06 2.27E-05
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00 0.00E+00 5.34E-05 2.79E-06 1.47E-05
I-135	1.42E-31	4.57E-31	0.00E+00	0.00E+00 0.00E+00 2.07E-03 2.09E-06 1.37E-05
<b>NOBLE GASES</b>				
XE-131M	4.93E+01	1.58E+02	0.00E+00	0.00E+00 0.00E+00 0.00E+00 1.85E-06 6.69E-05
XE-133M	1.95E-01	6.28E-01	0.00E+00	0.00E+00 0.00E+00 0.00E+00 5.45E-06 5.12E-04
XE-133	1.57E+03	5.03E+03	0.00E+00	0.00E+00 0.00E+00 0.00E+00 5.12E-04 2.02E-02
XE-135M	0.00E+00	0.00E+00	0.00E+00	0.00E+00 0.00E+00 0.00E+00 1.46E-04 8.43E-04
XE-135	4.69E-20	1.51E-19	0.00E+00	0.00E+00 0.00E+00 0.00E+00 4.01E-04 1.35E-02
XE-138	0.00E+00	0.00E+00	0.00E+00	0.00E+00 0.00E+00 0.00E+00 9.34E-04 2.53E-02
KR-83M	0.00E+00	0.00E+00	0.00E+00	0.00E+00 0.00E+00 0.00E+00 1.52E-05 1.73E-04
KR-85M	5.85E-46	1.88E-45	0.00E+00	0.00E+00 0.00E+00 0.00E+00 1.11E-04 3.99E-03
KR-85	5.37E+02	1.73E+03	0.00E+00	0.00E+00 0.00E+00 0.00E+00 7.81E-08 2.09E-04
KR-87	0.00E+00	0.00E+00	0.00E+00	0.00E+00 0.00E+00 0.00E+00 6.36E-04 2.51E-02
KR-88	1.20E-73	3.85E-73	0.00E+00	0.00E+00 0.00E+00 0.00E+00 2.58E-03 1.52E-02
			0.00E+00 0.00E+00	0.00E+00 1.57E+00 5.57E-03 1.07E-01

1

QDC CRDA, CR &amp; LPZ, ALL REL MVP: SIEMENS 20 GWD/MTU: 0 - 6 s

ISOTOPE	0. HRS	720. HRS	ACTIVITY RELEASED (CURIES)
<b>ELEMENTAL</b>			
I-131	3.92E+00	0.00E+00	3.92E+00
I-132	5.65E+00	0.00E+00	5.65E+00
I-133	7.89E+00	0.00E+00	7.89E+00
I-134	9.10E+00	0.00E+00	9.10E+00
I-135	7.08E+00	0.00E+00	7.08E+00
<b>PARTICULATE</b>			
I-131	2.16E-01	0.00E+00	2.16E-01
I-132	3.10E-01	0.00E+00	3.10E-01
I-133	4.34E-01	0.00E+00	4.34E-01
I-134	5.00E-01	0.00E+00	5.00E-01
I-135	3.89E-01	0.00E+00	3.89E-01
<b>ORGANIC</b>			
I-131	1.72E-01	0.00E+00	1.72E-01
I-132	2.48E-01	0.00E+00	2.48E-01
I-133	3.47E-01	0.00E+00	3.47E-01
I-134	4.00E-01	0.00E+00	4.00E-01
I-135	3.11E-01	0.00E+00	3.11E-01
<b>NOBLE GASES</b>			
XE-131M	3.09E+00	0.00E+00	3.09E+00
XE-133M	2.09E+01	0.00E+00	2.09E+01
XE-133	8.67E+02	0.00E+00	8.67E+02
XE-135M	2.34E+02	0.00E+00	2.34E+02
XE-135	2.86E+02	0.00E+00	2.86E+02
XE-138	7.81E+02	0.00E+00	7.81E+02
KR-83M	4.64E+01	0.00E+00	4.64E+01
KR-85M	1.27E+02	0.00E+00	1.27E+02
KR-85	5.82E+00	0.00E+00	5.82E+00
KR-87	2.50E+02	0.00E+00	2.50E+02
KR-88	3.62E+02	0.00E+00	3.62E+02

END EXECUTION DATE: 11/18/1999

END EXECUTION TIME: 19:17:15.05

AXIDENT VER 2 MOD 4  
 PRODUCTION DATE 02/18/92  
 BEGIN EXECUTION DATE: 11/18/1999  
 BEGIN EXECUTION TIME: 19:17:22.90

1 QDC CRDA, CR & LPZ, ALL REL GLAND: SIEMENS 20 GWD/MTU: 0 - 30 d  
 2 6 2 1. 1.  
 3 -2561 2.60+6 1.845+5 5.83+4  
 4 0. 0. 0. 1. 1. 2.78+5 0.  
 5 6 1800 7200 2.88+4 8.64+4 2.592E6  
 6 0.2402 4\*1.201E-2 0.  
 7 5\*1. 0.  
 8 6\*1.  
 9 6\*2460  
 10 2\*3.2E-5 2\*9.0E-6 3.0E-6 0.  
 11 3\*7.00E-4 6.45E-6 3.81E-6 0.  
 12 6\*0.  
 13 6\*0.  
 14 6\*0.  
 15 6\*0.  
 16 6\*0.  
 17 6\*0.  
 18 6\*0.  
 19 6\*0.  
 20 6\*0.  
 21 6\*1.  
 22 3\*1.  
 23 6.76E+3 9.73E+3 1.36E+4 1.57E+4 1.22E+4 1.21E+3 8.18E+3 3.40E+5  
 24 9.21E+4 1.12E+5 3.07E+5 1.82E+4 4.99E+4 2.28E+3 9.80E+4 1.42E+5

1

QDC CRDA, CR &amp; LPZ, ALL REL GLAND: SIEMENS 20 GWD/MTU: 0 - 30 d

## INITIAL CONTAINMENT INVENTORY

## ISOTOPE ACTIVITY (CURIES)

I-131	6.760E+03
I-132	9.730E+03
I-133	1.360E+04
I-134	1.570E+04
I-135	1.220E+04
XE-131M	1.210E+03
XE-133M	8.180E+03
XE-133	3.400E+05
XE-135M	9.210E+04
XE-135	1.120E+05
XE-138	3.070E+05
KR-83M	1.820E+04
KR-85M	4.990E+04
KR-85	2.280E+03
KR-87	9.800E+04
KR-88	1.420E+05

1

QDC CRDA, CR &amp; LPZ, ALL REL GLAND: SIEMENS 20 GWD/MTU: 0 - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL,	1. CFM MIXING, 00.00 PCT REL TO SPRAYED VOL
--	---

AT .002 HOURS: X/Q(SITE)= .32E-04 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM
INTAKE=2460.0 CFM		

X/Q CONT ROOM= .70E-03 SEC/M3	SEC RELEASE RATE= .86E+05 VOL/DAY	PCT PRI LKG TO ATM = 00.00
-------------------------------	-----------------------------------	----------------------------

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM		SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA
ELEMENTAL											
I-131	3.64E+02	1.14E+02	1.06E+03	8.61E-01	1.65E-04	1.29E+01	3.15E-03	1.54E-03	1.95E-01	1.69E-06	2.31E-05
I-132	5.24E+02	1.64E+02	1.53E+03	1.24E+00	2.37E-04	1.07E-01	2.93E-02	5.03E-03	1.60E-03	1.36E-05	7.56E-05
I-133	7.32E+02	2.29E+02	2.13E+03	1.73E+00	3.32E-04	4.26E+00	8.14E-03	6.64E-03	6.41E-02	5.48E-06	9.98E-05
I-134	8.44E+02	2.64E+02	2.46E+03	2.00E+00	3.82E-04	3.01E-02	3.82E-02	8.24E-03	4.52E-04	2.36E-05	1.24E-04

I-135	6.57E+02	2.05E+02	1.91E+03	1.55E+00	2.97E-04	6.59E-01	2.72E-02	4.34E-03	9.90E-03	9.96E-06	6.52E-05
<b>PARTICULATE</b>											
I-131	2.00E+01	6.26E+00	5.82E+01	4.73E-02	9.05E-06	7.11E-01	1.73E-04	8.45E-05	1.07E-02	9.28E-08	1.27E-06
I-132	2.88E+01	9.00E+00	8.38E+01	6.81E-02	1.30E-05	5.86E-03	1.61E-03	2.76E-04	8.81E-05	7.47E-07	4.15E-06
I-133	4.02E+01	1.26E+01	1.17E+02	9.52E-02	1.82E-05	2.34E-01	4.47E-04	3.65E-04	3.52E-03	3.01E-07	5.48E-06
I-134	4.64E+01	1.45E+01	1.35E+02	1.10E-01	2.10E-05	1.65E-03	2.10E-03	4.53E-04	2.48E-05	1.29E-06	6.80E-06
I-135	3.61E+01	1.13E+01	1.05E+02	8.54E-02	1.63E-05	3.62E-02	1.50E-03	2.38E-04	5.44E-04	5.47E-07	3.58E-06
<b>ORGANIC</b>											
I-131	1.60E+01	5.00E+00	4.66E+01	3.78E-02	7.24E-06	5.69E-01	1.38E-04	6.76E-05	8.56E-03	7.42E-08	1.02E-06
I-132	2.30E+01	7.20E+00	6.71E+01	5.46E-02	1.04E-05	4.69E-03	1.29E-03	2.21E-04	7.05E-05	5.98E-07	3.32E-06
I-133	3.22E+01	1.01E+01	9.37E+01	7.61E-02	1.46E-05	1.87E-01	3.58E-04	2.92E-04	2.82E-03	2.41E-07	4.39E-06
I-134	3.71E+01	1.16E+01	1.08E+02	8.78E-02	1.68E-05	1.32E-03	1.68E-03	3.62E-04	1.99E-05	1.04E-06	5.44E-06
I-135	2.89E+01	9.03E+00	8.41E+01	6.83E-02	1.31E-05	2.89E-02	1.20E-03	1.91E-04	4.35E-04	4.38E-07	2.87E-06
<b>NOBLE GASES</b>											
XE-131M	2.86E+02	8.96E+01	8.34E+02	6.77E-01	1.30E-04	0.00E+00	1.47E-04	8.29E-04	0.00E+00	3.45E-07	1.25E-05
XE-133M	1.94E+03	6.06E+02	5.64E+03	4.58E+00	8.77E-04	0.00E+00	1.49E-03	6.43E-03	0.00E+00	1.03E-06	9.67E-05
XE-133	8.05E+02	5.52E+04	3.24E+05	1.90E+02	3.64E-02	0.00E+00	5.62E-02	2.52E-01	0.00E+00	9.58E-05	3.79E-03
XE-135M	2.17E+04	6.79E+03	6.34E+04	5.13E+01	9.83E-03	0.00E+00	2.14E-01	4.52E-02	0.00E+00	1.18E-04	6.79E-04
XE-135	2.65E+04	8.29E+03	7.72E+04	6.27E+01	1.20E-02	0.00E+00	1.52E-01	1.83E-01	0.00E+00	8.15E-05	2.75E-03
XE-138	7.24E+04	2.26E+04	2.11E+05	1.71E+02	3.28E-02	0.00E+00	4.85E+00	1.24E+00	0.00E+00	6.90E-04	1.87E-02
KR-83M	4.30E+03	1.35E+03	1.25E+04	1.02E+01	1.95E-03	0.00E+00	5.02E-04	3.14E-03	0.00E+00	4.12E-06	4.72E-05
KR-85M	1.18E+04	3.69E+03	3.44E+04	2.79E+01	5.35E-03	0.00E+00	4.29E-02	5.90E-02	0.00E+00	2.48E-05	8.87E-04
KR-85	5.40E+02	1.69E+02	1.57E+03	1.28E+00	2.44E-04	0.00E+00	2.64E-05	2.58E-03	0.00E+00	1.45E-08	3.88E-05
KR-87	2.32E+04	7.25E+03	6.75E+04	5.48E+01	1.05E-02	0.00E+00	7.43E-01	5.22E-01	0.00E+00	1.99E-04	7.84E-03
KR-88	3.36E+04	1.05E+04	9.79E+04	7.95E+01	1.52E-02	0.00E+00	1.36E+00	2.46E-01	0.00E+00	6.28E-04	3.69E-03
										1.98E+01	7.54E+00
										2.59E+00	2.97E-01
										1.90E-03	3.89E-02

1 QDC CRDA, CR &amp; LPZ, ALL REL GLAND: SIEMENS 20 GWD/MTU: 0 - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO SPRAYED VOL

AT .500 HOURS: X/Q(SITE)= .32E-04 SEC/M3 PRIMARY LEAK RATE=\*\*\*\*\* PERCENT/DAY CONTROL ROOM  
INTAKE=2460.0 CFMX/Q CONT ROOM= .70E-03 SEC/M3 SEC RELEASE RATE= .86E+05 VOL/DAY PCT PRI LKG TO ATM =  
00.00

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	1.000	1.000

ACTIVITY (CURIES)		CONTROL ROOM (CURIES)		SITE BOUNDARY DOSES (REM)
ISOTOPE	PRIMARY	SECONDARY	THYROID WH BODY BETA	CONTROL ROOM DOSES (REM)
	(UCI/CM3)			THYROID WH BODY BETA
<b>ELEMENTAL</b>				
I-131	1.60E-07	1.94E-09	4.78E+02	8.41E-01 1.61E-04 5.84E+00 1.42E-03 6.93E-04 1.34E+02 1.16E-03 1.59E-02
I-132	1.98E-07	2.41E-09	6.84E+02	1.04E+00 2.00E-04 4.78E-02 1.31E-02 2.25E-03 1.03E+00 8.71E-03 4.84E-02
I-133	3.16E-07	3.85E-09	9.61E+02	1.67E+00 3.19E-00 4.92E+00 3.67E-03 2.99E-03 4.37E+01 3.73E-03 6.81E-02
I-134	2.49E-07	3.03E-09	1.09E+03	1.31E+00 2.51E-04 1.33E-02 1.69E-02 3.66E-03 2.59E-01 1.35E-02 7.09E-02
I-135	2.74E-07	3.33E-09	8.61E+02	1.44E+00 2.76E-04 2.96E-01 1.22E-02 1.95E-03 6.64E+00 6.68E-03 4.37E-02
<b>PARTICULATE</b>				
I-131	8.77E-09	1.07E-10	2.62E+01	4.62E-02 8.84E-06 3.21E-01 7.79E-05 3.81E-05 7.34E+00 6.37E-05 8.72E-04
I-132	1.09E-08	1.32E-10	3.76E+01	5.73E-02 1.10E-05 2.63E-03 7.21E-04 1.24E-04 5.65E-02 4.79E-04 2.66E-03
I-133	1.74E-08	2.11E-10	5.28E+01	9.16E-02 1.75E-05 1.05E-01 2.01E-04 1.64E-04 2.40E+00 2.05E-04 3.74E-03
I-134	1.37E-08	1.66E-10	6.00E+01	7.21E-02 1.38E-05 7.33E-04 9.31E-04 2.01E-04 1.42E-02 7.41E-04 3.90E-03
I-135	1.51E-08	1.83E-10	4.73E+01	7.93E-02 1.52E-05 1.63E-02 6.73E-04 1.07E-04 3.65E-01 3.67E-04 2.40E-03
<b>ORGANIC</b>				
I-131	7.01E-09	8.53E-11	2.10E+01	3.70E-02 7.07E-06 2.57E-01 6.23E-05 3.04E-05 5.88E+00 5.10E-05 6.97E-04
I-132	8.70E-09	1.06E-10	3.01E+01	4.58E-02 8.77E-06 2.10E-03 5.77E-04 9.91E-05 4.52E-02 3.83E-04 2.13E-03
I-133	1.39E-08	1.69E-09	4.22E+01	7.33E-02 1.40E-05 8.44E-02 1.61E-04 1.31E-04 1.92E+00 1.64E-04 2.99E-03
I-134	1.09E-08	1.33E-10	4.80E+01	5.77E-02 1.10E-05 5.87E-04 7.45E-04 1.61E-04 1.14E-02 5.93E-04 3.12E-03
I-135	1.20E-08	1.46E-10	3.78E+01	6.35E-02 1.21E-05 1.30E-02 5.38E-04 8.57E-05 2.92E-01 2.94E-04 1.92E-03
<b>NOBLE GASES</b>				
XE-131M	1.26E-07	1.53E-09	3.76E+02	6.62E-01 1.27E-04 0.00E+00 6.62E-05 3.73E-04 0.00E+00 2.37E-04 8.56E-03
XE-133M	8.45E-07	1.03E-08	2.54E+03	4.45E+00 8.52E-04 0.00E+00 6.71E-04 2.90E-03 0.00E+00 7.05E-04 6.63E-02
XE-133	3.52E-05	4.28E-07	1.06E+05	1.86E+02 3.55E-02 0.00E+00 2.53E-02 1.13E-01 0.00E+00 6.57E-02 2.60E+00
XE-135M	2.53E-06	3.07E-08	2.72E+04	1.33E+01 2.55E-03 0.00E+00 9.18E-02 1.94E-02 0.00E+00 4.63E-02 2.67E-01
XE-135	1.12E-05	1.36E-07	3.47E+04	5.91E+01 1.13E-02 0.00E+00 6.84E-02 8.23E-02 0.00E+00 5.50E-02 1.86E+00
XE-138	9.73E-06	1.18E-07	9.12E+04	5.13E+01 9.81E-03 0.00E+00 2.09E+00 5.37E-01 0.00E+00 2.86E-01 7.75E+00
KR-83M	1.57E-06	1.91E-08	5.61E+03	8.28E+00 1.59E-03 0.00E+00 2.25E-04 1.40E-03 0.00E+00 2.60E-03 2.97E-02
KR-85M	4.79E-06	5.83E-08	1.55E+04	2.53E+01 4.83E-03 0.00E+00 1.93E-02 2.65E-02 0.00E+00 1.64E-02 5.87E-01
KR-85	2.37E-07	2.88E-09	7.08E+02	1.25E+00 2.39E-04 0.00E+00 1.19E-05 1.16E-03 0.00E+00 9.97E-06 2.67E-02
KR-87	7.75E-06	9.42E-08	3.01E+04	4.08E+01 7.81E-03 0.00E+00 3.31E-01 2.33E-01 0.00E+00 1.21E-01 4.75E+00
KR-88	1.30E-05	1.59E-07	4.39E+04	6.87E+01 1.32E-02 0.00E+00 6.12E-01 1.10E-01 0.00E+00 4.08E-01 2.39E+00
				8.92E+00 3.29E+00 1.14E+00 2.04E+02 1.04E+00 2.06E+01

1 QDC CRDA, CR & LPZ, ALL REL GLAND: SIEMENS 20 GWD/MTU: 0 - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO

SPRAYED VOL

AT 2.000 HOURS:	X/Q(SITE)= .90E-05 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM
INTAKE=2460.0 CFM			
	X/Q CONT ROOM= .70E-03 SEC/M3	SEC RELEASE RATE= .86E+05 VOL/DAY	PCT PRI LKG TO ATM =
00.00			

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM	SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)			
	PRIMARY	SECONDARY	RELEASE	(CURIES) (UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA	
<b>ELEMENTAL</b>											
I-131	1.08E-35	1.32E-37	1.61E-07	2.52E-01	4.82E-05	5.55E-10	1.35E-13	6.59E-14	1.93E+02	1.67E-03	2.29E-02
I-132	8.60E-36	1.05E-37	1.99E-07	2.00E-01	3.83E-05	3.91E-12	1.07E-12	1.84E-13	1.15E+00	9.77E-03	5.43E-02
I-133	2.06E-35	2.50E-37	3.20E-07	4.78E-01	9.15E-05	1.80E-10	3.43E-13	2.80E-13	6.14E+01	5.25E-03	9.57E-02
I-134	5.13E-36	6.23E-38	2.47E-07	1.19E-01	2.28E-05	8.50E-13	1.08E-12	2.33E-13	1.96E-01	1.02E-02	5.38E-02
I-135	1.60E-35	1.95E-37	2.77E-07	3.72E-01	7.13E-05	2.68E-11	1.11E-12	1.76E-13	8.79E+00	8.84E-03	5.79E-02
<b>PARTICULATE</b>											
I-131	5.95E-37	7.24E-39	8.87E-09	1.38E-02	2.65E-06	3.05E-11	7.41E-15	3.62E-15	1.06E+01	9.19E-05	1.26E-03
I-132	4.72E-37	5.74E-39	1.09E-08	1.10E-02	2.10E-06	2.15E-13	5.90E-14	1.01E-14	6.33E-02	5.37E-04	2.99E-03
I-133	1.13E-36	1.37E-38	1.76E-08	2.63E-02	5.02E-06	9.88E-12	1.89E-14	1.54E-14	3.38E+00	2.88E-04	5.26E-03
I-134	2.82E-37	3.42E-39	1.36E-08	6.55E-03	1.25E-06	4.67E-14	5.93E-14	1.28E-14	1.08E-02	5.62E-04	2.95E-03
I-135	8.80E-37	1.07E-38	1.52E-08	2.05E-02	3.92E-06	1.47E-12	6.08E-14	9.69E-15	4.83E-01	4.86E-04	3.18E-03
<b>ORGANIC</b>											
I-131	4.76E-37	5.79E-39	7.10E-09	1.11E-02	2.12E-06	2.44E-11	5.93E-15	2.89E-15	8.47E+00	7.35E-05	1.01E-03
I-132	3.78E-37	4.59E-39	8.74E-09	8.79E-03	1.68E-06	1.72E-13	4.72E-14	8.11E-15	5.07E-02	4.30E-04	2.39E-03
I-133	9.04E-37	1.10E-38	1.41E-08	2.10E-02	4.02E-06	7.91E-12	1.51E-14	1.23E-14	2.70E+00	2.31E-04	4.21E-03
I-134	2.25E-37	2.74E-39	1.09E-08	5.24E-03	1.00E-06	3.74E-14	4.74E-14	1.02E-14	8.62E-03	4.50E-04	2.36E-03
I-135	7.04E-37	8.56E-39	1.22E-08	1.64E-02	3.13E-06	1.18E-12	4.87E-14	7.75E-15	3.86E-01	3.89E-04	2.54E-03
<b>NOBLE GASES</b>											
XE-131M	8.55E-36	1.04E-37	1.27E-07	1.99E-01	3.80E-05	0.00E+00	6.29E-15	3.55E-14	0.00E+00	3.42E-04	1.24E-02
XE-133M	5.66E-35	6.88E-37	8.55E-07	1.32E+00	2.52E-04	0.00E+00	6.35E-14	2.74E-13	0.00E+00	1.01E-03	9.48E-02
XE-133	2.39E-33	2.90E-35	3.57E-05	5.55E+01	1.06E-02	0.00E+00	2.41E-12	1.08E-11	0.00E+00	9.46E-02	3.74E+00
XE-135M	3.17E-36	3.86E-38	2.41E-06	7.37E-02	4.14E-05	0.00E+00	2.29E-12	4.84E-13	0.00E+00	1.02E-02	5.88E-02
XE-135	6.83E-34	8.30E-36	1.13E-05	1.59E+01	3.04E-03	0.00E+00	6.27E-12	7.55E-12	0.00E+00	7.46E-02	2.52E+00
XE-138	1.88E-35	2.29E-37	9.33E-06	4.37E-01	8.37E-05	0.00E+00	6.03E-11	1.55E-11	0.00E+00	7.49E-02	2.03E+00
KR-83M	6.15E-35	7.48E-37	1.58E-06	1.43E+00	2.74E-04	0.00E+00	1.77E-14	1.11E-13	0.00E+00	2.76E-03	3.15E-02
KR-85M	2.58E-34	3.14E-36	4.83E-06	6.01E+00	1.15E-03	0.00E+00	1.70E-12	2.33E-12	0.00E+00	2.08E-02	7.42E-01
KR-85	1.62E-35	1.97E-37	2.40E-07	3.76E-01	7.20E-05	0.00E+00	1.13E-15	1.11E-13	0.00E+00	1.44E-05	3.86E-02
KR-87	2.33E-34	2.83E-36	7.74E-06	5.41E+00	1.04E-03	0.00E+00	2.40E-11	1.68E-11	0.00E+00	1.11E-01	4.37E+00
KR-88	6.14E-34	7.46E-36	1.31E-05	1.43E+01	2.73E-03	0.00E+00	5.15E-11	9.26E-12	0.00E+00	4.78E-01	2.81E+00

1 QDC CRDA, CR & LPZ, ALL REL GLAND: SIEMENS 20 GWD/MTU: 0 - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO  
SPRAYED VOL

AT 8.000 HOURS:	X/Q(SITE)= .90E-05 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM
INTAKE=2460.0 CFM			
	X/Q CONT ROOM= .65E-05 SEC/M3	SEC RELEASE RATE= .86E+05 VOL/DAY	PCT PRI LKG TO ATM =
00.00			

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM	SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE	(CURIES) (UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA

ELEMENTAL													
I-131	0.00E+00	0.00E+00	1.10E-35	2.03E-03	3.88E-07	3.77E-38	9.15E-42	4.47E-42	8.18E+01	7.09E-04	9.71E-03		
I-132	0.00E+00	0.00E+00	8.64E-36	2.70E-04	5.16E-08	1.70E-40	4.67E-41	8.02E-42	2.73E-01	2.31E-03	1.29E-02		
I-133	0.00E+00	0.00E+00	2.08E-35	3.23E-03	6.17E-07	1.17E-38	2.23E-41	1.82E-41	2.45E+01	2.09E-03	3.82E-02		
I-134	0.00E+00	0.00E+00	5.09E-36	8.11E-06	1.55E-09	1.75E-41	2.22E-41	4.80E-42	1.96E-02	1.02E-03	5.37E-03		
I-135	0.00E+00	0.00E+00	1.62E-35	1.65E-03	3.16E-07	1.57E-39	6.48E-41	1.03E-41	3.04E+00	3.06E-03	2.00E-02		
PARTICULATE													
I-131	0.00E+00	0.00E+00	6.03E-37	1.11E-04	2.13E-08	2.07E-39	5.03E-43	2.46E-43	4.49E+00	3.90E-05	5.33E-04		
I-132	0.00E+00	0.00E+00	4.75E-37	1.48E-05	2.84E-09	9.34E-42	2.56E-42	4.40E-43	1.50E-02	1.27E-04	7.07E-04		
I-133	0.00E+00	0.00E+00	1.14E-36	1.77E-04	3.39E-08	6.42E-40	1.23E-42	1.00E-42	1.35E+00	1.15E-04	2.10E-03		
I-134	0.00E+00	0.00E+00	2.80E-37	4.46E-07	8.53E-11	9.62E-43	1.22E-42	2.64E-43	1.08E-03	5.61E-05	2.95E-04		
I-135	0.00E+00	0.00E+00	8.89E-37	9.06E-05	1.73E-08	8.60E-41	3.56E-42	5.67E-43	1.67E-01	1.68E-04	1.10E-03		
ORGANIC													
I-131	0.00E+00	0.00E+00	4.82E-37	8.92E-05	1.71E-08	1.66E-39	4.02E-43	1.97E-43	3.59E+00	3.12E-05	4.27E-04		
I-132	0.00E+00	0.00E+00	3.80E-37	1.19E-05	2.27E-09	7.47E-42	2.05E-42	3.52E-43	1.20E-02	1.02E-04	5.66E-04		
I-133	0.00E+00	0.00E+00	9.14E-37	1.42E-04	2.71E-08	5.14E-40	9.81E-43	8.00E-43	1.08E+00	9.21E-05	1.68E-03		
I-134	0.00E+00	0.00E+00	2.24E-37	3.56E-07	6.82E-11	7.69E-43	9.77E-43	2.11E-43	8.61E-04	4.49E-05	2.36E-04		
I-135	0.00E+00	0.00E+00	7.11E-37	7.25E-05	1.39E-08	6.88E-41	2.85E-42	4.53E-43	1.34E-01	1.35E-04	8.81E-04		
NOBLE GASES													
XE-131M	0.00E+00	0.00E+00	8.65E-36	1.61E-03	3.08E-07	0.00E+00	4.28E-43	2.42E-42	0.00E+00	1.46E-04	5.25E-03		
XE-133M	0.00E+00	0.00E+00	5.73E-35	1.00E-02	1.92E-06	0.00E+00	4.25E-42	1.84E-41	0.00E+00	4.20E-04	3.95E-02		
XE-133	0.00E+00	0.00E+00	2.42E-33	4.42E-01	8.46E-05	0.00E+00	1.63E-40	7.30E-40	0.00E+00	4.00E-02	1.56E+00		
XE-135M	0.00E+00	0.00E+00	3.02E-36	6.94E-11	1.33E-14	0.00E+00	2.87E-42	6.07E-43	0.00E+00	5.68E-05	3.27E-04		
XE-135	0.00E+00	0.00E+00	6.90E-34	8.28E-02	1.59E-05	0.00E+00	3.82E-40	4.60E-40	0.00E+00	2.73E-02	9.20E-01		
XE-138	0.00E+00	0.00E+00	1.80E-35	2.32E-09	4.43E-13	0.00E+00	1.17E-40	2.99E-41	0.00E+00	6.45E-04	1.75E-02		
KR-83M	0.00E+00	0.00E+00	6.17E-35	1.27E-03	2.44E-07	0.00E+00	6.95E-43	4.35E-42	0.00E+00	5.75E-04	6.58E-03		
KR-85M	0.00E+00	0.00E+00	2.61E-34	1.92E-02	3.67E-06	0.00E+00	9.15E-41	1.26E-40	0.00E+00	6.45E-03	2.31E-01		
KR-85	0.00E+00	0.00E+00	1.64E-35	3.10E-03	5.92E-07	0.00E+00	7.74E-44	7.56E-42	0.00E+00	6.16E-06	1.65E-02		
KR-87	0.00E+00	0.00E+00	2.33E-34	1.67E-03	3.20E-07	0.00E+00	7.20E-40	5.06E-40	0.00E+00	1.69E-02	6.68E-01		
KR-88	0.00E+00	0.00E+00	6.18E-34	2.66E-02	5.09E-06	0.00E+00	2.42E-39	4.36E-40	0.00E+00	1.25E-01	7.35E-01		
						5.62E-38	4.09E-39	2.37E-39	1.20E+02	2.28E-01	4.32E+00		

1 QDC CRDA, CR &amp; LPZ, ALL REL GLAND: SIEMENS 20 GWD/MTU: 0 - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO SPRAYED VOL

AT 24.000 HOURS: X/Q(SITE)= .30E-05 SEC/M3 PRIMARY LEAK RATE=\*\*\*\*\* PERCENT/DAY CONTROL ROOM INTAKE=2460.0 CFM

X/Q CONT ROOM=.38E-05 SEC/M3 SEC RELEASE RATE=.86E+05 VOL/DAY PCT PRI LKG TO ATM = 00.00

CLEANUP RATES (HR-1)						FILTER NON-REMOVAL FACTORS		
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER			
ELEMENTAL	.000	.000	.000	1.000	1.000			
PARTICULATE	.000	.000	.000	1.000	1.000			
ORGANIC	.000	.000	.000	1.000	1.000			
ACTIVITY (CURIES) CONTROL ROOM SITE BOUNDARY DOSES (REM) CONTROL ROOM DOSES (REM)								
ISOTOPE	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID WH BODY BETA	THYROID WH BODY BETA	
ELEMENTAL	0.00E+00	0.00E+00	0.00E+00	5.29E-09	1.01E-12	0.00E+00 0.00E+00 0.00E+00	6.64E-01 5.76E-06 7.88E-05	
I-131	0.00E+00	0.00E+00	0.00E+00	6.00E-12	1.15E-15	0.00E+00 0.00E+00 0.00E+00	3.69E-04 3.13E-06 1.74E-05	
I-132	0.00E+00	0.00E+00	0.00E+00	5.25E-09	1.01E-12	0.00E+00 0.00E+00 0.00E+00	1.67E-01 1.42E-05 2.60E-04	
I-133	0.00E+00	0.00E+00	0.00E+00	6.26E-17	1.20E-20	0.00E+00 0.00E+00 0.00E+00	1.33E-06 6.95E-08 3.66E-07	
I-134	0.00E+00	0.00E+00	0.00E+00	8.71E-10	1.67E-13	0.00E+00 0.00E+00 0.00E+00	1.35E-02 1.36E-05 8.91E-05	
PARTICULATE	0.00E+00	0.00E+00	0.00E+00	2.91E-10	5.56E-14	0.00E+00 0.00E+00 0.00E+00	3.65E-02 3.16E-07 4.33E-06	
I-131	0.00E+00	0.00E+00	0.00E+00	3.30E-13	6.31E-17	0.00E+00 0.00E+00 0.00E+00	2.03E-05 1.72E-07 9.56E-07	
I-133	0.00E+00	0.00E+00	0.00E+00	2.89E-10	5.52E-14	0.00E+00 0.00E+00 0.00E+00	9.16E-03 7.82E-07 1.43E-05	
I-134	0.00E+00	0.00E+00	0.00E+00	3.44E-18	6.58E-22	0.00E+00 0.00E+00 0.00E+00	7.33E-08 3.82E-09 2.01E-08	
I-135	0.00E+00	0.00E+00	0.00E+00	4.79E-11	9.16E-15	0.00E+00 0.00E+00 0.00E+00	7.43E-04 7.48E-07 4.90E-06	
ORGANIC	0.00E+00	0.00E+00	0.00E+00	2.32E-10	4.45E-14	0.00E+00 0.00E+00 0.00E+00	2.92E-02 2.53E-07 3.46E-06	
I-131	0.00E+00	0.00E+00	0.00E+00	2.64E-13	5.05E-17	0.00E+00 0.00E+00 0.00E+00	1.62E-05 1.37E-07 7.64E-07	
I-132	0.00E+00	0.00E+00	0.00E+00	2.31E-10	4.42E-14	0.00E+00 0.00E+00 0.00E+00	7.33E-03 6.26E-07 1.14E-05	
I-133	0.00E+00	0.00E+00	0.00E+00	2.75E-18	5.27E-22	0.00E+00 0.00E+00 0.00E+00	5.86E-08 3.06E-09 1.61E-08	
I-135	0.00E+00	0.00E+00	0.00E+00	3.83E-11	7.33E-15	0.00E+00 0.00E+00 0.00E+00	5.95E-04 5.98E-07 3.92E-06	
Noble Gases	0.00E+00	0.00E+00	0.00E+00	4.28E-09	8.19E-13	0.00E+00 0.00E+00 0.00E+00	1.19E-06 4.30E-05	
XE-131M	0.00E+00	0.00E+00	0.00E+00	2.25E-08	4.32E-12	0.00E+00 0.00E+00 0.00E+00	3.23E-06 3.03E-04	
XE-133M	0.00E+00	0.00E+00	0.00E+00	1.12E-06	2.14E-10	0.00E+00 0.00E+00 0.00E+00	0.00E+00 0.00E+00 3.21E-04	
XE-133	0.00E+00	0.00E+00	0.00E+00	5.90E-35	1.13E-38	0.00E+00 0.00E+00 0.00E+00	0.00E+00 0.00E+00 5.34E-14	
XE-135	0.00E+00	0.00E+00	0.00E+00	6.78E-08	1.30E-11	0.00E+00 0.00E+00 0.00E+00	0.00E+00 0.00E+00 1.43E-04	
XE-138	0.00E+00	0.00E+00	0.00E+00	1.98E-31	3.78E-35	0.00E+00 0.00E+00 0.00E+00	0.00E+00 0.00E+00 3.42E-12	
KR-83M	0.00E+00	0.00E+00	0.00E+00	9.31E-12	1.78E-15	0.00E+00 0.00E+00 0.00E+00	0.00E+00 0.00E+00 5.12E-07	
KR-85M	0.00E+00	0.00E+00	0.00E+00	4.25E-09	8.14E-13	0.00E+00 0.00E+00 0.00E+00	0.00E+00 0.00E+00 2.07E-05	
KR-85	0.00E+00	0.00E+00	0.00E+00	8.54E-09	1.64E-12	0.00E+00 0.00E+00 0.00E+00	0.00E+00 0.00E+00 5.12E-08	

KR-87	0.00E+00	0.00E+00	0.00E+00	7.27E-13	1.39E-16	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.23E-06	2.06E-04
KR-88	0.00E+00	0.00E+00	0.00E+00	1.39E-09	2.67E-13	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.33E-04	1.37E-03
						-----	-----	-----	-----	-----	-----
						0.00E+00	0.00E+00	0.00E+00	9.28E-01	7.69E-04	2.08E-02

1

QDC CRDA, CR &amp; LPZ, ALL REL GLAND: SIEMENS 20 GWD/MTU: 0 - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
 1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO

## SPRAYED VOL

AT 720.000 HOURS:	X/Q(SITE)= .00E+00 SEC/M3	PRIMARY LEAK RATE= .000 PERCENT/DAY	CONTROL ROOM
INTAKE=2460.0 CFM			
	X/Q CONT ROOM= .00E+00 SEC/M3	SEC RELEASE RATE= .00E+00 VOL/DAY	PCT PRI LKG TO ATM =
00.00			

ISOTOPE	ACTIVITY (CURIES)			(CURIES) (UCI/CM3)	CONTROL ROOM			SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)			
	PRIMARY	SECONDARY	RELEASE		THYROID	WH BODY	BETA	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA	
					CLEANUP RATES (HR-1)	SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER			
ELEMENTAL	.000	.000	.000		.000					1.000		1.000		
I-131	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.73E-06	1.50E-11	2.05E-10		
I-132	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.21E-12	6.96E-14	3.87E-13		
I-133	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.71E-07	2.32E-11	4.23E-10		
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.03E-17	5.37E-19	2.82E-18		
I-135	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.15E-09	7.19E-12	4.71E-11		
PARTICULATE	.000	.000	.000		.000					1.000		1.000		
I-131	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.51E-08	8.25E-13	1.13E-11		
I-132	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.51E-13	3.82E-15	2.13E-14		
I-133	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.49E-08	1.27E-12	2.32E-11		
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.66E-19	2.95E-20	1.55E-19		
I-135	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.93E-10	3.95E-13	2.59E-12		
ORGANIC	.000	.000	.000		.000					1.000		1.000		
I-131	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.61E-08	6.60E-13	9.03E-12		
I-132	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.61E-13	3.06E-15	1.70E-14		
I-133	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.19E-08	1.02E-12	1.86E-11		
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.53E-19	2.36E-20	1.24E-19		
I-135	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.14E-10	3.16E-13	2.07E-12		
NOBLE GASES	.000	.000	.000		.000					1.000		1.000		
XE-131M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.16E-12	1.14E-10			
XE-133M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.26E-12	6.82E-10			
XE-133	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.12E-10	3.21E-08			
XE-135M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.54E-38	2.62E-37			
XE-135	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.17E-10	3.95E-09			
XE-138	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.91E-34	7.89E-33			
KR-83M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.75E-15	4.29E-14			
KR-85M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.58E-12	1.64E-10			
KR-85	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.41E-13	3.77E-10			
KR-87	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.28E-15	8.98E-14			
KR-88	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.22E-11	7.19E-11			
TOTAL DOSES 0-30 DAYS					2.87E+01	1.08E+01	3.73E+00	6.16E+02	2.18E+00	4.17E+01				

1

QDC CRDA, CR &amp; LPZ, ALL REL GLAND: SIEMENS 20 GWD/MTU: 0 - 30 d

ISOTOPE	ACTIVITY RELEASED (CURIES)			
	2. HRS	8. HRS	24. HRS	720. HRS
ELEMENTAL				
I-131	1.54E+03	1.10E-35	0.00E+00	0.00E+00
I-132	2.21E+03	8.64E-36	0.00E+00	0.00E+00
I-133	3.09E+03	2.08E-35	0.00E+00	0.00E+00
I-134	3.55E+03	5.09E-36	0.00E+00	0.00E+00
I-135	2.77E+03	1.62E-35	0.00E+00	0.00E+00
PARTICULATE				
I-131	8.45E+01	6.03E-37	0.00E+00	0.00E+00
I-132	1.21E+02	4.75E-37	0.00E+00	0.00E+00
I-133	1.70E+02	1.14E-36	0.00E+00	0.00E+00
I-134	1.95E+02	2.80E-37	0.00E+00	0.00E+00
I-135	1.52E+02	8.89E-37	0.00E+00	0.00E+00
ORGANIC				
I-131	6.76E+01	4.82E-37	0.00E+00	0.00E+00
I-132	9.71E+01	3.80E-37	0.00E+00	0.00E+00

I-133	1.36E+02	9.14E-37	0.00E+00	0.00E+00	1.36E+02
I-134	1.56E+02	2.24E-37	0.00E+00	0.00E+00	1.56E+02
I-135	1.22E+02	7.11E-37	0.00E+00	0.00E+00	1.22E+02
NOBLE GASES					
XE-131M	1.21E+03	8.65E-36	0.00E+00	0.00E+00	1.21E+03
XE-133M	8.18E+03	5.73E-35	0.00E+00	0.00E+00	8.18E+03
XE-133	3.40E+05	2.42E-33	0.00E+00	0.00E+00	3.40E+05
XE-135M	9.06E+04	3.02E-36	0.00E+00	0.00E+00	9.06E+04
XE-135	1.12E+05	6.90E-34	0.00E+00	0.00E+00	1.12E+05
XE-138	3.02E+05	1.80E-35	0.00E+00	0.00E+00	3.02E+05
KR-83M	1.82E+04	6.17E-35	0.00E+00	0.00E+00	1.82E+04
KR-85M	4.98E+04	2.61E-34	0.00E+00	0.00E+00	4.98E+04
KR-85	2.28E+03	1.64E-35	0.00E+00	0.00E+00	2.28E+03
KR-87	9.76E+04	2.33E-34	0.00E+00	0.00E+00	9.76E+04
KR-88	1.42E+05	6.18E-34	0.00E+00	0.00E+00	1.42E+05

END EXECUTION DATE: 11/18/1999  
END EXECUTION TIME: 19:17:23.12

AXIDENT VER 2 MOD 4  
 PRODUCTION DATE 02/18/92  
 BEGIN EXECUTION DATE: 11/18/1999  
 BEGIN EXECUTION TIME: 19:17:30.43

1 QDC CRDA, EAB, ALL REL MVP: SIEMENS 20 GWD/MTU: 0 - 6 s  
 2 2 1 1. 1.  
 3 -2561 2.60+6 1.845+5 5.83+4  
 4 0. 0. 1. 1. 2.78+5 0.  
 5 6 7200  
 6 0.2402 0.  
 7 9.058E-4 0.  
 8 2\*1.  
 9 2\*0.  
 10 2.9E-4 0.  
 11 2\*0.  
 12 2\*0.  
 13 2\*0.  
 14 2\*0.  
 15 2\*0.  
 16 2\*0.  
 17 2\*0.  
 18 2\*0.  
 19 2\*0.  
 20 2\*0.  
 21 6\*1.  
 22 3\*1.  
 23 6.76E+3 9.73E+3 1.36E+4 1.57E+4 1.22E+4 1.21E+3 8.18E+3 3.40E+5  
 24 9.21E+4 1.12E+5 3.07E+5 1.82E+4 4.99E+4 2.28E+3 9.80E+4 1.42E+5

1

QDC CRDA, EAB, ALL REL MVP: SIEMENS 20 GWD/MTU: 0 - 6 s

## INITIAL CONTAINMENT INVENTORY

## ISOTOPE ACTIVITY (CURIES)

I-131	6.760E+03
I-132	9.730E+03
I-133	1.360E+04
I-134	1.570E+04
I-135	1.220E+04
XE-131M	1.210E+03
XE-133M	8.180E+03
XE-133	3.400E+05
XE-135M	9.210E+04
XE-135	1.120E+05
XE-138	3.070E+05
KR-83M	1.820E+04
KR-85M	4.990E+04
KR-85	2.280E+03
KR-87	9.800E+04
KR-88	1.420E+05

1 QDC CRDA, EAB, ALL REL MVP: SIEMENS 20 GWD/MTU: 0 - 6 s

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
 SPRAYED VOL 1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO

AT .002 HOURS: X/Q(SITE)= .29E-03 SEC/M3 PRIMARY LEAK RATE=\*\*\*\*\* PERCENT/DAY CONTROL ROOM INTAKE=  
 .0 CFM  
 X/Q CONT ROOM= .00E+00 SEC/M3 SEC RELEASE RATE= .78E+02 VOL/DAY PCT PRI LKG TO ATM =  
 00.00

ISOTOPE	CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS						
	SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE		CONT CENTER				
					ELEMENTAL	.000					
ELEMENTAL		.000	.000	.000		1.000	1.000				
PARTICULATE		.000	.000	.000		1.000	1.000				
ORGANIC		.000	.000	.000		1.000	1.000				
	ACTIVITY (CURIES)		CONTROL ROOM	SITE BOUNDARY DOSES (REM)	CONTROL ROOM DOSES (REM)						
	ISOTOPE	PRIMARY	SECONDARY	RELEASE (UCI/CM3)	THYROID	WH BODY	BETA				
I-131	3.64E+02	1.17E+03	3.92E+00	0.00E+00	0.00E+00	4.34E-01	1.06E-04	5.16E-05	0.00E+00	0.00E+00	0.00E+00
I-132	5.24E+02	1.68E+03	5.65E+00	0.00E+00	0.00E+00	3.58E-03	9.82E-04	1.69E-04	0.00E+00	0.00E+00	0.00E+00
I-133	7.32E+02	2.35E+03	7.89E+00	0.00E+00	0.00E+00	1.43E-01	2.73E-04	2.23E-04	0.00E+00	0.00E+00	0.00E+00
I-134	8.44E+02	2.71E+03	9.10E+00	0.00E+00	0.00E+00	1.01E-03	1.28E-03	2.76E-04	0.00E+00	0.00E+00	0.00E+00

I-135	6.57E+02	2.11E+03	7.08E+00	0.00E+00	0.00E+00	2.21E-02	9.13E-04	1.45E-04	0.00E+00	0.00E+00	0.00E+00
<b>PARTICULATE</b>											
I-131	2.00E+01	6.43E+01	2.16E-01	0.00E+00	0.00E+00	2.39E-02	5.80E-06	2.83E-06	0.00E+00	0.00E+00	0.00E+00
I-132	2.88E+01	9.25E+01	3.10E-01	0.00E+00	0.00E+00	1.97E-04	5.40E-05	9.27E-06	0.00E+00	0.00E+00	0.00E+00
I-133	4.02E+01	1.29E+02	4.34E-01	0.00E+00	0.00E+00	7.86E-03	1.50E-05	1.22E-05	0.00E+00	0.00E+00	0.00E+00
I-134	4.64E+01	1.49E+02	5.00E-01	0.00E+00	0.00E+00	5.54E-05	7.03E-05	1.52E-05	0.00E+00	0.00E+00	0.00E+00
I-135	3.61E+01	1.16E+02	3.89E-01	0.00E+00	0.00E+00	1.21E-03	5.02E-05	7.99E-06	0.00E+00	0.00E+00	0.00E+00
<b>ORGANIC</b>											
I-131	1.60E+01	5.14E+01	1.72E-01	0.00E+00	0.00E+00	1.91E-02	4.64E-06	2.27E-06	0.00E+00	0.00E+00	0.00E+00
I-132	2.30E+01	7.40E+01	2.48E-01	0.00E+00	0.00E+00	1.57E-04	4.32E-05	7.41E-06	0.00E+00	0.00E+00	0.00E+00
I-133	3.22E+01	1.03E+02	3.47E-01	0.00E+00	0.00E+00	6.28E-03	1.20E-05	9.79E-06	0.00E+00	0.00E+00	0.00E+00
I-134	3.71E+01	1.19E+02	4.00E-01	0.00E+00	0.00E+00	4.43E-05	5.63E-05	1.21E-05	0.00E+00	0.00E+00	0.00E+00
I-135	2.89E+01	9.28E+01	3.11E-01	0.00E+00	0.00E+00	9.71E-04	4.01E-05	6.39E-06	0.00E+00	0.00E+00	0.00E+00
<b>NOBLE GASES</b>											
XE-131M	2.86E+02	9.21E+02	3.09E+00	0.00E+00	0.00E+00	0.00E+00	4.92E-06	2.78E-05	0.00E+00	0.00E+00	0.00E+00
XE-133M	1.94E+03	6.22E+03	2.09E+01	0.00E+00	0.00E+00	0.00E+00	4.99E-05	2.16E-04	0.00E+00	0.00E+00	0.00E+00
XE-133	8.05E+04	2.59E+05	8.67E+02	0.00E+00	0.00E+00	0.00E+00	1.89E-03	8.45E-03	0.00E+00	0.00E+00	0.00E+00
XE-135M	2.17E+04	6.98E+04	2.34E+02	0.00E+00	0.00E+00	0.00E+00	7.17E-03	1.52E-03	0.00E+00	0.00E+00	0.00E+00
XE-135	2.65E+04	8.52E+04	2.86E+02	0.00E+00	0.00E+00	0.00E+00	5.10E-03	6.14E-03	0.00E+00	0.00E+00	0.00E+00
XE-138	7.24E+04	2.33E+05	7.81E+02	0.00E+00	0.00E+00	0.00E+00	1.63E-01	4.17E-02	0.00E+00	0.00E+00	0.00E+00
KR-83M	4.30E+03	1.38E+04	4.64E+01	0.00E+00	0.00E+00	0.00E+00	1.68E-05	1.05E-04	0.00E+00	0.00E+00	0.00E+00
KR-85M	1.18E+04	3.80E+04	1.27E+02	0.00E+00	0.00E+00	0.00E+00	1.44E-03	1.98E-03	0.00E+00	0.00E+00	0.00E+00
KR-85	5.40E+02	1.73E+03	5.82E+00	0.00E+00	0.00E+00	0.00E+00	8.86E-07	8.65E-05	0.00E+00	0.00E+00	0.00E+00
KR-87	2.32E+04	7.45E+04	2.50E+02	0.00E+00	0.00E+00	0.00E+00	2.49E-02	1.75E-02	0.00E+00	0.00E+00	0.00E+00
KR-88	3.36E+04	1.09E+05	3.62E+02	0.00E+00	0.00E+00	0.00E+00	4.58E-02	8.24E-03	0.00E+00	0.00E+00	0.00E+00
							6.64E-01	2.53E-01	8.69E-02	0.00E+00	0.00E+00

1 QDC CRDA, EAB, ALL REL MVP: SIEMENS 20 GWD/MTU: 0 - 6 s

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO SPRAYED VOL

AT	2.000 HOURS:	X/Q(SITE)= .00E+00 SEC/M3	PRIMARY LEAK RATE= .000 PERCENT/DAY	CONTROL ROOM INTAKE=.0 CFM
		X/Q CONT ROOM= .00E+00 SEC/M3	SEC RELEASE RATE= .00E+00 VOL/DAY	PCT PRI LKG TO ATM = 00.00

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM (CURIES)	SITE BOUNDARY DOSES (REM)	CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE	(UCI/CM3)	THYROID WH BODY	BETA	THYROID WH BODY	BETA
ELEMENTAL								
I-131	3.61E+02	1.16E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	2.87E+02	9.22E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	6.85E+02	2.20E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	1.71E+02	5.50E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	5.34E+02	1.72E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
PARTICULATE								
I-131	1.99E+01	6.38E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	1.58E+01	5.06E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	3.77E+01	1.21E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	9.39E+00	3.02E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	2.94E+01	9.44E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ORGANIC								
I-131	1.59E+01	5.11E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	1.26E+01	4.05E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	3.01E+01	9.69E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	7.51E+00	2.42E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	2.35E+01	7.55E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
NOBLE GASES								
XE-131M	2.85E+02	9.16E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
XE-133M	1.89E+03	6.07E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
XE-133	7.96E+04	2.56E+05	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
XE-135M	1.06E+02	3.40E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
XE-135	2.28E+04	7.32E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
XE-138	6.27E+02	2.02E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
KR-83M	2.05E+03	6.60E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
KR-85M	8.61E+03	2.77E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
KR-85	5.40E+02	1.73E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
KR-87	7.76E+03	2.50E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
KR-88	2.05E+04	6.58E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
					0.00E+00	0.00E+00	0.00E+00	0.00E+00

1

TOTAL DOSES 0-30 DAYS	6.64E-01	2.53E-01	8.69E-02	0.00E+00	0.00E+00	0.00E+00
-----------------------	----------	----------	----------	----------	----------	----------

QDC CRDA, EAB, ALL REL MVP: SIEMENS 20 GWD/MTU: 0 - 6 s

ISOTOPE	ACTIVITY RELEASED (CURIES)	
	2. HRS	
<b>ELEMENTAL</b>		
I-131	3.92E+00	3.92E+00
I-132	5.65E+00	5.65E+00
I-133	7.89E+00	7.89E+00
I-134	9.10E+00	9.10E+00
I-135	7.08E+00	7.08E+00
<b>PARTICULATE</b>		
I-131	2.16E-01	2.16E-01
I-132	3.10E-01	3.10E-01
I-133	4.34E-01	4.34E-01
I-134	5.00E-01	5.00E-01
I-135	3.89E-01	3.89E-01
<b>ORGANIC</b>		
I-131	1.72E-01	1.72E-01
I-132	2.48E-01	2.48E-01
I-133	3.47E-01	3.47E-01
I-134	4.00E-01	4.00E-01
I-135	3.11E-01	3.11E-01
<b>NOBLE GASES</b>		
XE-131M	3.09E+00	3.09E+00
XE-133M	2.09E+01	2.09E+01
XE-133	8.67E+02	8.67E+02
XE-135M	2.34E+02	2.34E+02
XE-135	2.86E+02	2.86E+02
XE-138	7.81E+02	7.81E+02
KR-83M	4.64E+01	4.64E+01
KR-85M	1.27E+02	1.27E+02
KR-85	5.82E+00	5.82E+00
KR-87	2.50E+02	2.50E+02
KR-88	3.62E+02	3.62E+02

END EXECUTION DATE: 11/18/1999

END EXECUTION TIME: 19:17:30.43

AXIDENT VER 2 MOD 4  
 PRODUCTION DATE 02/18/92  
 BEGIN EXECUTION DATE: 11/18/1999  
 BEGIN EXECUTION TIME: 19:17:43.83

1 QDC CRDA, EAB, ALL REL GLAND: SIEMENS 20 GWD/MTU: 0 - 2 h  
 2 3 2 1. 1.  
 3 -2561 2.60+6 1.845+5 5.83+4  
 4 0. 0. 0. 1. 1. 2.78+5 0.  
 5 6 1800 7200  
 6 0.2402 2\*1.201E-2  
 7 3\*1.  
 8 3\*1.  
 9 3\*0.  
 10 2\*2.9e-4 2.3E-5  
 11 3\*0.  
 12 3\*0.  
 13 3\*0.  
 14 3\*0.  
 15 3\*0.  
 16 3\*0.  
 17 3\*0.  
 18 3\*0.  
 19 3\*0.  
 20 3\*0.  
 21 6\*1.  
 22 3\*1.  
 23 6.76E+3 9.73E+3 1.36E+4 1.57E+4 1.22E+4 1.21E+3 8.18E+3 3.40E+5  
 24 9.21E+4 1.12E+5 3.07E+5 1.82E+4 4.99E+4 2.28E+3 9.80E+4 1.42E+5

1

QDC CRDA, EAB, ALL REL GLAND: SIEMENS 20 GWD/MTU: 0 - 2 h

## INITIAL CONTAINMENT INVENTORY

## ISOTOPE ACTIVITY (CURIES)

I-131	6.760E+03
I-132	9.730E+03
I-133	1.360E+04
I-134	1.570E+04
I-135	1.220E+04
XE-131M	1.210E+03
XE-133M	8.180E+03
XE-133	3.400E+05
XE-135M	9.210E+04
XE-135	1.120E+05
XE-138	3.070E+05
KR-83M	1.820E+04
KR-85M	4.990E+04
KR-85	2.280E+03
KR-87	9.800E+04
KR-88	1.420E+05

1

QDC CRDA, EAB, ALL REL GLAND: SIEMENS 20 GWD/MTU: 0 - 2 h

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL,	1. CFM MIXING, 00.00 PCT REL TO
SPRAYED VOL	

AT .002 HOURS: X/Q(SITE)= .29E-03 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM INTAKE=
.0 CFM		
X/Q CONT ROOM= .00E+00 SEC/M3	SEC RELEASE RATE= .86E+05 VOL/DAY	PCT PRI LKG TO ATM =
00.00		

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM		SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA
ELEMENTAL											
I-131	3.64E+02	1.14E+02	1.06E+03	0.00E+00	0.00E+00	1.17E+02	2.85E-02	1.39E-02	0.00E+00	0.00E+00	0.00E+00
I-132	5.24E+02	1.64E+02	1.53E+03	0.00E+00	0.00E+00	9.67E-01	2.65E-01	4.56E-02	0.00E+00	0.00E+00	0.00E+00
I-133	7.32E+02	2.29E+02	2.13E+03	0.00E+00	0.00E+00	3.86E+01	7.38E-02	6.02E-02	0.00E+00	0.00E+00	0.00E+00
I-134	8.44E+02	2.64E+02	2.46E+03	0.00E+00	0.00E+00	2.72E-01	3.46E-01	7.47E-02	0.00E+00	0.00E+00	0.00E+00

I-135	6.57E+02	2.05E+02	1.91E+03	0.00E+00	0.00E+00	5.97E+00	2.47E-01	3.93E-02	0.00E+00	0.00E+00	0.00E+00
<b>PARTICULATE</b>											
I-131	2.00E+01	6.26E+00	5.82E+01	0.00E+00	0.00E+00	6.45E+00	1.57E-03	7.65E-04	0.00E+00	0.00E+00	0.00E+00
I-132	2.88E+01	9.00E+00	8.38E+01	0.00E+00	0.00E+00	5.31E-02	1.46E-02	2.50E-03	0.00E+00	0.00E+00	0.00E+00
I-133	4.02E+01	1.26E+01	1.17E+02	0.00E+00	0.00E+00	2.12E+00	4.05E-03	3.31E-03	0.00E+00	0.00E+00	0.00E+00
I-134	4.64E+01	1.45E+01	1.35E+02	0.00E+00	0.00E+00	1.50E-02	1.90E-02	4.10E-03	0.00E+00	0.00E+00	0.00E+00
I-135	3.61E+01	1.13E+01	1.05E+02	0.00E+00	0.00E+00	3.28E-01	1.36E-02	2.16E-03	0.00E+00	0.00E+00	0.00E+00
<b>ORGANIC</b>											
I-131	1.60E+01	5.00E+00	4.66E+01	0.00E+00	0.00E+00	5.16E+00	1.25E-03	6.12E-04	0.00E+00	0.00E+00	0.00E+00
I-132	2.30E+01	7.20E+00	6.71E+01	0.00E+00	0.00E+00	4.25E-02	1.17E-02	2.00E-03	0.00E+00	0.00E+00	0.00E+00
I-133	3.22E+01	1.01E+01	9.37E+01	0.00E+00	0.00E+00	1.70E+00	3.24E-03	2.64E-03	0.00E+00	0.00E+00	0.00E+00
I-134	3.71E+01	1.16E+01	1.08E+02	0.00E+00	0.00E+00	1.20E-02	1.52E-02	3.28E-03	0.00E+00	0.00E+00	0.00E+00
I-135	2.89E+01	9.03E+00	8.41E+01	0.00E+00	0.00E+00	2.62E-01	1.08E-02	1.73E-03	0.00E+00	0.00E+00	0.00E+00
<b>NOBLE GASES</b>											
XE-131M	2.86E+02	8.96E+01	8.34E+02	0.00E+00	0.00E+00	0.00E+00	1.33E-03	7.51E-03	0.00E+00	0.00E+00	0.00E+00
XE-133M	1.94E+03	6.06E+02	5.64E+03	0.00E+00	0.00E+00	0.00E+00	1.35E-02	5.83E-02	0.00E+00	0.00E+00	0.00E+00
XE-133	8.05E+02	2.52E+04	2.34E+05	0.00E+00	0.00E+00	0.00E+00	5.10E-01	2.28E+00	0.00E+00	0.00E+00	0.00E+00
XE-135M	2.17E+04	6.79E+03	6.34E+04	0.00E+00	0.00E+00	0.00E+00	1.94E+00	4.10E-01	0.00E+00	0.00E+00	0.00E+00
XE-135	2.65E+04	8.29E+03	7.72E+04	0.00E+00	0.00E+00	0.00E+00	1.38E+00	1.66E+00	0.00E+00	0.00E+00	0.00E+00
XE-138	7.24E+04	2.26E+04	2.11E+05	0.00E+00	0.00E+00	0.00E+00	4.39E+01	1.13E+01	0.00E+00	0.00E+00	0.00E+00
KR-83M	4.30E+03	1.35E+03	1.25E+04	0.00E+00	0.00E+00	0.00E+00	4.55E-03	2.84E-02	0.00E+00	0.00E+00	0.00E+00
KR-85M	1.18E+04	3.69E+03	3.44E+04	0.00E+00	0.00E+00	0.00E+00	3.89E-01	5.35E-01	0.00E+00	0.00E+00	0.00E+00
KR-85	5.40E+02	1.69E+02	1.57E+03	0.00E+00	0.00E+00	0.00E+00	2.39E-04	2.34E-02	0.00E+00	0.00E+00	0.00E+00
KR-87	2.32E+04	7.25E+03	6.75E+04	0.00E+00	0.00E+00	0.00E+00	6.73E+00	4.73E+00	0.00E+00	0.00E+00	0.00E+00
KR-88	3.36E+04	1.05E+04	9.79E+04	0.00E+00	0.00E+00	0.00E+00	1.24E+01	2.23E+00	0.00E+00	0.00E+00	0.00E+00
							1.79E+02	6.83E+01	2.35E+01	0.00E+00	0.00E+00

1 QDC CRDA, EAB, ALL REL GLAND: SIEMENS 20 GWD/MTU: 0 - 2 h

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO SPRAYED VOL

AT .500 HOURS:	X/Q(SITE) = .29E-03 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM INTAKE=
.0 CFM			
00.00	X/Q CONT ROOM= .00E+00 SEC/M3	SEC RELEASE RATE= .86E+05 VOL/DAY	PCT PRI LKG TO ATM =

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL .000	.000	.000	.000	1.000	1.000
PARTICULATE .000	.000	.000	.000	1.000	1.000
ORGANIC .000	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)	CONTROL ROOM (CURIES)	SITE BOUNDARY (UCI/CM3)	DOSES (REM)	CONTROL ROOM DOSES (REM)						
	PRIMARY	SECONDARY	RELEASE	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA		
<b>ELEMENTAL</b>											
I-131	1.60E-07	1.94E-09	4.78E+02	0.00E+00	0.00E+00	5.29E+01	1.29E-02	6.28E-03	0.00E+00	0.00E+00	0.00E+00
I-132	1.98E-07	2.41E-09	6.84E+02	0.00E+00	0.00E+00	4.33E-01	1.19E-01	2.04E-02	0.00E+00	0.00E+00	0.00E+00
I-133	3.16E-07	3.85E-09	9.61E+02	0.00E+00	0.00E+00	1.74E+01	3.32E-02	2.71E-02	0.00E+00	0.00E+00	0.00E+00
I-134	2.49E-07	3.03E-09	1.09E+03	0.00E+00	0.00E+00	1.21E-01	1.54E-01	3.32E-02	0.00E+00	0.00E+00	0.00E+00
I-135	2.74E-07	3.33E-09	8.61E+02	0.00E+00	0.00E+00	2.68E+00	1.11E-01	1.77E-02	0.00E+00	0.00E+00	0.00E+00
<b>PARTICULATE</b>											
I-131	8.77E-09	1.07E-10	2.62E+01	0.00E+00	0.00E+00	2.91E+00	7.06E-04	3.45E-04	0.00E+00	0.00E+00	0.00E+00
I-132	1.09E-08	1.32E-10	3.76E+01	0.00E+00	0.00E+00	2.38E-02	6.54E-03	1.12E-03	0.00E+00	0.00E+00	0.00E+00
I-133	1.74E-08	2.11E-10	5.28E+01	0.00E+00	0.00E+00	9.56E-01	1.83E-03	1.49E-03	0.00E+00	0.00E+00	0.00E+00
I-134	1.37E-08	1.66E-10	6.00E+01	0.00E+00	0.00E+00	6.65E-03	8.44E-03	1.82E-03	0.00E+00	0.00E+00	0.00E+00
I-135	1.51E-08	1.83E-10	4.73E+01	0.00E+00	0.00E+00	1.47E-01	6.10E-03	9.71E-04	0.00E+00	0.00E+00	0.00E+00
<b>ORGANIC</b>											
I-131	7.01E-09	8.53E-11	2.10E+01	0.00E+00	0.00E+00	2.32E+00	5.65E-04	2.76E-04	0.00E+00	0.00E+00	0.00E+00
I-132	8.70E-09	1.06E-10	3.01E+01	0.00E+00	0.00E+00	1.91E-02	5.23E-03	8.98E-04	0.00E+00	0.00E+00	0.00E+00
I-133	1.39E-08	1.69E-10	4.22E+01	0.00E+00	0.00E+00	7.65E-01	1.46E-03	1.19E-03	0.00E+00	0.00E+00	0.00E+00
I-134	1.09E-08	1.33E-10	4.80E+01	0.00E+00	0.00E+00	5.32E-03	6.75E-03	1.46E-03	0.00E+00	0.00E+00	0.00E+00
I-135	1.20E-08	1.46E-10	3.78E+01	0.00E+00	0.00E+00	1.18E-01	4.88E-03	7.77E-04	0.00E+00	0.00E+00	0.00E+00
<b>NOBLE GASES</b>											
XE-131M	1.26E-07	1.53E-09	3.76E+02	0.00E+00	0.00E+00	0.00E+00	6.00E-04	3.38E-03	0.00E+00	0.00E+00	0.00E+00
XE-133M	8.45E-07	1.03E-08	2.54E+03	0.00E+00	0.00E+00	0.00E+00	6.08E-03	2.63E-02	0.00E+00	0.00E+00	0.00E+00
XE-133	3.52E-05	4.28E-07	1.06E+05	0.00E+00	0.00E+00	0.00E+00	2.30E-01	1.03E+00	0.00E+00	0.00E+00	0.00E+00
XE-135M	2.53E-06	3.07E-08	2.72E+04	0.00E+00	0.00E+00	0.00E+00	8.32E-01	1.76E-01	0.00E+00	0.00E+00	0.00E+00
XE-135	1.12E-05	1.36E-07	3.47E+04	0.00E+00	0.00E+00	0.00E+00	6.20E-01	7.46E-01	0.00E+00	0.00E+00	0.00E+00
XE-138	9.73E-06	1.18E-07	9.12E+04	0.00E+00	0.00E+00	0.00E+00	1.90E+01	4.86E+00	0.00E+00	0.00E+00	0.00E+00
KR-83M	1.57E-06	1.91E-08	5.61E+03	0.00E+00	0.00E+00	0.00E+00	2.03E-03	1.27E-02	0.00E+00	0.00E+00	0.00E+00
KR-85M	4.79E-06	5.83E-08	1.55E+04	0.00E+00	0.00E+00	0.00E+00	1.75E-01	2.40E-01	0.00E+00	0.00E+00	0.00E+00
KR-85	2.37E-07	2.88E-09	7.08E+02	0.00E+00	0.00E+00	0.00E+00	1.08E-04	1.05E-02	0.00E+00	0.00E+00	0.00E+00
KR-87	7.75E-06	9.42E-08	3.01E+04	0.00E+00	0.00E+00	0.00E+00	3.00E+00	2.11E+00	0.00E+00	0.00E+00	0.00E+00
KR-88	1.30E-05	1.59E-07	4.39E+04	0.00E+00	0.00E+00	0.00E+00	5.55E+00	9.99E-01	0.00E+00	0.00E+00	0.00E+00
	8.08E+01	2.99E+01	1.03E+01	0.00E+00	0.00E+00	0.00E+00					

1 QDC CRDA, EAB, ALL REL GLAND: SIEMENS 20 GWD/MTU: 0 - 2 h

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO  
SPRAYED VOL

AT	2.000 HOURS:	X/Q(SITE)= .23E-04 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM INTAKE=
.0 CFM				
		X/Q CONT ROOM= .00E+00 SEC/M3	SEC RELEASE RATE= .86E+05 VOL/DAY	PCT PRI LKG TO ATM =
		00.00		

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)	CONTROL ROOM	SITE BOUNDARY DOSES (REM)	CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE (UCI/CM3)	THYROID WH BODY BETA	THYROID WH BODY BETA	
ELEMENTAL						
I-131	1.08E-35	1.32E-37	1.61E-07	0.00E+00 0.00E+00	1.42E-09 3.45E-13 1.68E-13	0.00E+00 0.00E+00 0.00E+00
I-132	8.60E-36	1.05E-37	1.99E-07	0.00E+00 0.00E+00	1.00E-11 2.75E-12 4.71E-13	0.00E+00 0.00E+00 0.00E+00
I-133	2.06E-35	2.50E-37	3.20E-07	0.00E+00 0.00E+00	4.60E-10 8.78E-13 7.16E-13	0.00E+00 0.00E+00 0.00E+00
I-134	5.13E-36	6.23E-38	2.47E-07	0.00E+00 0.00E+00	2.17E-12 2.76E-12 5.96E-13	0.00E+00 0.00E+00 0.00E+00
I-135	1.60E-35	1.95E-37	2.77E-07	0.00E+00 0.00E+00	6.84E-11 2.83E-12 4.51E-13	0.00E+00 0.00E+00 0.00E+00
PARTICULATE						
I-131	5.95E-37	7.24E-39	8.87E-09	0.00E+00 0.00E+00	7.79E-11 1.89E-14 9.25E-15	0.00E+00 0.00E+00 0.00E+00
I-132	4.72E-37	5.74E-39	1.09E-08	0.00E+00 0.00E+00	5.50E-13 1.51E-13 2.59E-14	0.00E+00 0.00E+00 0.00E+00
I-133	1.13E-36	1.37E-38	1.76E-08	0.00E+00 0.00E+00	2.53E-11 4.82E-14 3.93E-14	0.00E+00 0.00E+00 0.00E+00
I-134	2.82E-37	3.42E-39	1.36E-08	0.00E+00 0.00E+00	1.19E-13 1.52E-13 3.27E-14	0.00E+00 0.00E+00 0.00E+00
I-135	8.80E-37	1.07E-38	1.52E-08	0.00E+00 0.00E+00	3.76E-12 1.55E-13 2.48E-14	0.00E+00 0.00E+00 0.00E+00
ORGANIC						
I-131	4.76E-37	5.79E-39	7.10E-09	0.00E+00 0.00E+00	6.23E-11 1.51E-14 7.40E-15	0.00E+00 0.00E+00 0.00E+00
I-132	3.78E-37	4.59E-39	8.74E-09	0.00E+00 0.00E+00	4.40E-13 1.21E-13 2.07E-14	0.00E+00 0.00E+00 0.00E+00
I-133	9.04E-37	1.10E-38	1.41E-08	0.00E+00 0.00E+00	2.02E-11 3.86E-14 3.15E-14	0.00E+00 0.00E+00 0.00E+00
I-134	2.25E-37	2.74E-39	1.09E-08	0.00E+00 0.00E+00	9.55E-14 1.21E-13 2.62E-14	0.00E+00 0.00E+00 0.00E+00
I-135	7.04E-37	8.56E-39	1.22E-08	0.00E+00 0.00E+00	3.01E-12 1.24E-13 1.98E-14	0.00E+00 0.00E+00 0.00E+00
NOBLE GASES						
XE-131M	8.55E-36	1.04E-37	1.27E-07	0.00E+00 0.00E+00	0.00E+00 1.61E-14 9.08E-14	0.00E+00 0.00E+00 0.00E+00
XE-133M	5.66E-35	6.88E-37	8.55E-07	0.00E+00 0.00E+00	0.00E+00 1.62E-13 7.01E-13	0.00E+00 0.00E+00 0.00E+00
XE-133	2.39E-33	2.90E-35	3.57E-05	0.00E+00 0.00E+00	0.00E+00 6.15E-12 2.75E-11	0.00E+00 0.00E+00 0.00E+00
XE-135M	3.17E-36	3.86E-38	2.41E-06	0.00E+00 0.00E+00	0.00E+00 5.85E-12 1.24E-12	0.00E+00 0.00E+00 0.00E+00
XE-135	6.83E-34	8.30E-36	1.13E-05	0.00E+00 0.00E+00	0.00E+00 1.60E-11 1.93E-11	0.00E+00 0.00E+00 0.00E+00
XE-138	1.88E-35	2.29E-37	9.33E-06	0.00E+00 0.00E+00	0.00E+00 1.54E-10 3.95E-11	0.00E+00 0.00E+00 0.00E+00
KR-83M	6.15E-35	7.48E-37	1.58E-06	0.00E+00 0.00E+00	0.00E+00 4.53E-14 2.84E-13	0.00E+00 0.00E+00 0.00E+00
KR-85M	2.58E-34	3.14E-36	4.83E-06	0.00E+00 0.00E+00	0.00E+00 4.34E-12 5.96E-12	0.00E+00 0.00E+00 0.00E+00
KR-85	1.62E-35	1.97E-37	2.40E-07	0.00E+00 0.00E+00	0.00E+00 2.90E-15 2.83E-13	0.00E+00 0.00E+00 0.00E+00
KR-87	2.33E-34	2.83E-36	7.74E-06	0.00E+00 0.00E+00	0.00E+00 6.12E-11 4.30E-11	0.00E+00 0.00E+00 0.00E+00
KR-88	6.14E-34	7.46E-36	1.31E-05	0.00E+00 0.00E+00	0.00E+00 1.32E-10 2.37E-11	0.00E+00 0.00E+00 0.00E+00
					2.15E-09 3.90E-10 1.64E-10	0.00E+00 0.00E+00 0.00E+00
TOTAL DOSES 0-30 DAYS				2.60E+02 9.82E+01 3.38E+01	0.00E+00 0.00E+00 0.00E+00	

1

QDC CRDA, EAB, ALL REL GLAND: SIEMENS 20 GWD/MTU: 0 - 2 h

ISOTOPE	ACTIVITY RELEASED (CURIES)	
	2. HRS	
ELEMENTAL		
I-131	1.54E+03	1.54E+03
I-132	2.21E+03	2.21E+03
I-133	3.09E+03	3.09E+03
I-134	3.55E+03	3.55E+03
I-135	2.77E+03	2.77E+03
PARTICULATE		
I-131	8.45E+01	8.45E+01
I-132	1.21E+02	1.21E+02
I-133	1.70E+02	1.70E+02
I-134	1.95E+02	1.95E+02
I-135	1.52E+02	1.52E+02
ORGANIC		
I-131	6.76E+01	6.76E+01
I-132	9.71E+01	9.71E+01
I-133	1.36E+02	1.36E+02
I-134	1.56E+02	1.56E+02
I-135	1.22E+02	1.22E+02
NOBLE GASES		
XE-131M	1.21E+03	1.21E+03

XE-133M	8.18E+03	8.18E+03
XE-133	3.40E+05	3.40E+05
XE-135M	9.06E+04	9.06E+04
XE-135	1.12E+05	1.12E+05
XE-138	3.02E+05	3.02E+05
KR-83M	1.82E+04	1.82E+04
KR-85M	4.98E+04	4.98E+04
KR-85	2.28E+03	2.28E+03
KR-87	9.76E+04	9.76E+04
KR-88	1.42E+05	1.42E+05

END EXECUTION DATE: 11/18/1999  
END EXECUTION TIME: 19:17:43.88

AXIDENT VER 2 MOD 4  
 PRODUCTION DATE 02/18/92  
 BEGIN EXECUTION DATE: 11/18/1999  
 BEGIN EXECUTION TIME: 19:00:38.48

1 QDC CRDA, CR & LPZ, ALL REL MVP: SIEMENS 60 GWD/MTU: 0 - 6 s  
 2 2 2 1. 1.  
 3 -2561 2.60+6 1.845+5 5.83+4  
 4 0. 0. 0. 1. 1. 2.78+5 0.  
 5 6 2.592E6  
 6 0.2402 0.  
 7 9.058E-4 0.  
 8 2\*1.  
 9 2\*2460  
 10 3.2E-5 0.  
 11 7.00E-4 0.  
 12 2\*0.  
 13 2\*0.  
 14 2\*0.  
 15 2\*0.  
 16 2\*0.  
 17 2\*0.  
 18 2\*0.  
 19 2\*0.  
 20 2\*0.  
 21 6\*1.  
 22 3\*1.  
 23 7.43E+3 1.04E+4 1.32E+4 1.48E+4 1.16E+4 1.57E+3 8.14E+3 3.33E+5  
 24 8.89E+4 8.25E+4 3.17E+5 8.39E+3 3.21E+4 4.57E+3 6.03E+4 8.93E+4

1

QDC CRDA, CR &amp; LPZ, ALL REL MVP: SIEMENS 60 GWD/MTU: 0 - 6 s

## INITIAL CONTAINMENT INVENTORY

## ISOTOPE ACTIVITY (CURIES)

I-131	7.430E+03
I-132	1.040E+04
I-133	1.320E+04
I-134	1.480E+04
I-135	1.160E+04
XE-131M	1.570E+03
XE-133M	8.140E+03
XE-133	3.330E+05
XE-135M	8.890E+04
XE-135	8.250E+04
XE-138	3.170E+05
KR-83M	8.390E+03
KR-85M	3.210E+04
KR-85	4.570E+03
KR-87	6.030E+04
KR-88	8.930E+04

1

QDC CRDA, CR &amp; LPZ, ALL REL MVP: SIEMENS 60 GWD/MTU: 0 - 6 s

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL,	1. CFM MIXING, 00.00 PCT REL TO
SPRAYED VOL	

AT .002 HOURS: X/Q(SITE)= .32E-04 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM
INTAKE=2460.0 CFM		
X/Q CONT ROOM= .70E-03 SEC/M3	SEC RELEASE RATE= .78E+02 VOL/DAY	PCT PRI LKG TO ATM =
00.00		

SPRAY	CLEANUP RATES (HR-1)			FILTER NON-REMOVAL FACTORS	
	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM			SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA	
ELEMENTAL												
I-131	4.00E+02	1.29E+03	4.31E+00	3.50E-03	6.70E-07	5.27E-02	1.28E-05	6.25E-06	5.67E-04	4.92E-09	6.73E-08	
I-132	5.60E+02	1.80E+03	6.03E+00	4.90E-03	9.38E-07	4.22E-04	1.16E-04	1.99E-05	4.55E-06	3.85E-08	2.14E-07	
I-133	7.11E+02	2.28E+03	7.66E+00	6.22E-03	1.19E-06	1.53E-02	2.92E-05	2.38E-05	1.65E-04	1.41E-08	2.57E-07	
I-134	7.96E+02	2.56E+03	8.58E+00	6.97E-03	1.33E-06	1.05E-04	1.33E-04	2.87E-05	1.13E-06	5.89E-08	3.10E-07	

I-135	6.24E+02	2.01E+03	6.73E+00	5.47E-03	1.05E-06	2.32E-03	9.58E-05	1.53E-05	2.50E-05	2.51E-08	1.64E-07
<b>PARTICULATE</b>											
I-131	2.20E+01	7.07E+01	2.37E-01	1.92E-04	3.68E-08	2.89E-03	7.03E-07	3.44E-07	3.12E-05	2.70E-10	3.70E-09
I-132	3.07E+01	9.89E+01	3.32E-01	2.69E-04	5.15E-08	2.32E-05	6.37E-06	1.09E-06	2.50E-07	2.12E-09	1.18E-08
I-133	3.90E+01	1.26E+02	4.21E-01	3.42E-04	6.54E-08	8.41E-04	1.61E-06	1.31E-06	9.06E-06	7.74E-10	1.41E-08
I-134	4.37E+01	1.41E+02	4.72E-01	3.83E-04	7.33E-08	5.76E-06	7.31E-06	1.58E-06	6.20E-08	3.23E-09	1.70E-08
I-135	3.43E+01	1.10E+02	3.70E-01	3.00E-04	5.75E-08	1.27E-04	5.26E-06	8.38E-07	1.37E-06	1.38E-09	9.03E-09
<b>ORGANIC</b>											
I-131	1.76E+01	5.65E+01	1.90E-01	1.54E-04	2.95E-08	2.32E-03	5.63E-07	2.75E-07	2.49E-05	2.16E-10	2.96E-09
I-132	2.46E+01	7.91E+01	2.65E-01	2.15E-04	4.12E-08	1.86E-05	5.09E-06	8.75E-07	2.00E-07	1.69E-09	9.42E-09
I-133	3.12E+01	1.00E+02	3.37E-01	2.74E-04	5.24E-08	6.73E-04	1.28E-06	1.05E-06	7.25E-06	6.19E-10	1.13E-08
I-134	3.50E+01	1.12E+02	3.77E-01	3.06E-04	5.86E-08	4.61E-06	5.85E-06	1.26E-06	4.96E-08	2.59E-09	1.36E-08
I-135	2.74E+01	8.82E+01	2.96E-01	2.40E-04	4.60E-08	1.02E-04	4.21E-06	6.71E-07	1.10E-06	1.10E-09	7.22E-09
<b>NOBLE GASES</b>											
XE-131M	3.72E+02	1.19E+03	4.01E+00	3.25E-03	6.23E-07	0.00E+00	7.05E-07	3.98E-06	0.00E+00	1.19E-09	4.29E-08
XE-133M	1.93E+03	6.19E+03	2.08E+01	1.69E-02	3.23E-06	0.00E+00	5.48E-06	2.37E-05	0.00E+00	2.72E-09	2.55E-07
XE-133	7.88E+02	2.53E+05	8.49E+02	6.90E-01	1.32E-04	0.00E+00	2.04E-04	9.13E-04	0.00E+00	2.49E-07	9.83E-06
XE-135M	2.09E+04	6.73E+04	2.26E+02	1.83E-01	3.51E-05	0.00E+00	7.63E-04	1.61E-04	0.00E+00	3.02E-07	1.74E-06
XE-135	1.95E+04	6.28E+04	2.10E+02	1.71E-01	3.27E-05	0.00E+00	4.14E-04	4.99E-04	0.00E+00	1.59E-07	5.37E-06
XE-138	7.47E+04	2.40E+05	8.07E+02	6.54E-01	1.25E-04	0.00E+00	1.85E-02	4.75E-03	0.00E+00	1.89E-06	5.11E-05
KR-83M	1.98E+03	6.38E+03	2.14E+01	1.74E-02	3.33E-06	0.00E+00	8.56E-07	5.35E-06	0.00E+00	5.04E-09	5.77E-08
KR-85M	7.59E+03	2.44E+04	8.19E+01	6.65E-02	1.27E-05	0.00E+00	1.02E-04	1.40E-04	0.00E+00	4.23E-08	1.51E-06
KR-85	1.08E+03	3.48E+03	1.17E+01	9.47E-03	1.81E-06	0.00E+00	1.96E-07	1.91E-05	0.00E+00	7.71E-11	2.06E-07
KR-87	1.43E+04	4.58E+04	1.54E+02	1.25E-01	2.39E-05	0.00E+00	1.69E-03	1.19E-03	0.00E+00	3.25E-07	1.28E-05
KR-88	2.11E+04	6.79E+04	2.28E+02	1.85E-01	3.54E-05	0.00E+00	3.18E-03	5.72E-04	0.00E+00	1.05E-06	6.16E-06

1

QDC CRDA, CR &amp; LPZ, ALL REL MVP: SIEMENS 60 GWD/MTU: 0 - 6 s

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO

SPRAYED VOL

AT 720.000 HOURS: X/Q(SITE)= .00E+00 SEC/M3 PRIMARY LEAK RATE= .000 PERCENT/DAY CONTROL ROOM  
INTAKE=2460.0 CFMX/Q CONT ROOM= .00E+00 SEC/M3 SEC RELEASE RATE= .00E+00 VOL/DAY PCT PRI LKG TO ATM =  
00.00

	CLEANUP RATES (HR-1)			FILTER NON-REMOVAL FACTORS		
	SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM		SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA
<b>ELEMENTAL</b>											
I-131	3.02E+01	9.70E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.15E+00	9.94E-06	1.36E-04
I-132	3.37E-92	1.08E-91	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.70E-03	5.68E-05	3.16E-04
I-133	3.38E-08	1.09E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.21E-01	2.75E-05	5.01E-04
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.15E-03	5.98E-05	3.14E-04
I-135	3.08E-30	9.89E-30	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.49E-02	4.51E-05	2.95E-04
<b>PARTICULATE</b>											
I-131	1.66E+00	5.33E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.30E-02	5.46E-07	7.48E-06
I-132	1.85E-93	5.95E-93	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.69E-04	3.12E-06	1.74E-05
I-133	1.86E-09	5.97E-09	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.77E-02	1.51E-06	2.75E-05
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.30E-05	3.28E-06	1.73E-05
I-135	1.69E-31	5.44E-31	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.47E-03	2.48E-06	1.62E-05
<b>ORGANIC</b>											
I-131	1.33E+00	4.27E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.04E-02	4.37E-07	5.98E-06
I-132	1.48E-93	4.76E-93	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.95E-04	2.50E-06	1.39E-05
I-133	1.53E+03	4.93E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.01E-04	1.98E-02	
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.04E-05	2.63E-06	1.38E-05
I-135	1.35E-31	4.35E-31	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.97E-03	1.98E-06	1.30E-05
<b>NOBLE GASES</b>											
XE-131M	6.39E+01	2.06E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.40E-06	8.67E-05
XE-133M	1.94E-01	6.25E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.43E-06	5.10E-04
XE-133	1.53E+03	4.93E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.01E-04	1.98E-02
XE-135M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.41E-04	8.14E-04
XE-135	3.46E-20	1.11E-19	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.95E-04	9.96E-03
XE-138	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.65E-04	2.61E-02
KR-83M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.99E-06	8.00E-05
KR-85M	3.76E-46	1.21E-45	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.17E-05
KR-85	1.08E+03	3.46E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.56E-07
KR-87	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.91E-04	1.54E-02
KR-88	7.54E-74	2.42E-73	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.62E-03	9.54E-03

0.00E+00 0.00E+00 0.00E+00 1.67E+00 4.22E-03 8.71E-02

TOTAL DOSES 0-30 DAYS	7.78E-02	2.53E-02	8.38E-03	1.67E+00	4.23E-03	8.71E-02
-----------------------	----------	----------	----------	----------	----------	----------

1

QDC CRDA, CR &amp; LPZ, ALL REL MVP: SIEMENS 60 GWD/MTU: 0 - 6 s

ISOTOPE	0. HRS	720. HRS	ACTIVITY RELEASED (CURIES)
ELEMENTAL			
I-131	4.31E+00	0.00E+00	4.31E+00
I-132	6.03E+00	0.00E+00	6.03E+00
I-133	7.66E+00	0.00E+00	7.66E+00
I-134	8.58E+00	0.00E+00	8.58E+00
I-135	6.73E+00	0.00E+00	6.73E+00
PARTICULATE			
I-131	2.37E-01	0.00E+00	2.37E-01
I-132	3.32E-01	0.00E+00	3.32E-01
I-133	4.21E-01	0.00E+00	4.21E-01
I-134	4.72E-01	0.00E+00	4.72E-01
I-135	3.70E-01	0.00E+00	3.70E-01
ORGANIC			
I-131	1.90E-01	0.00E+00	1.90E-01
I-132	2.65E-01	0.00E+00	2.65E-01
I-133	3.37E-01	0.00E+00	3.37E-01
I-134	3.77E-01	0.00E+00	3.77E-01
I-135	2.96E-01	0.00E+00	2.96E-01
NOBLE GASES			
XE-131M	4.01E+00	0.00E+00	4.01E+00
XE-133M	2.09E+01	0.00E+00	2.09E+01
XE-133	8.49E+02	0.00E+00	8.49E+02
XE-135M	2.26E+02	0.00E+00	2.26E+02
XE-135	2.10E+02	0.00E+00	2.10E+02
XE-138	8.07E+02	0.00E+00	8.07E+02
KR-83M	2.14E+01	0.00E+00	2.14E+01
KR-85M	8.19E+01	0.00E+00	8.19E+01
KR-85	1.17E+01	0.00E+00	1.17E+01
KR-87	1.54E+02	0.00E+00	1.54E+02
KR-88	2.28E+02	0.00E+00	2.28E+02

END EXECUTION DATE: 11/18/1999  
 END EXECUTION TIME: 19:00:38.53

AXIDENT VER 2 MOD 4  
 PRODUCTION DATE 02/18/92  
 BEGIN EXECUTION DATE: 11/18/1999  
 BEGIN EXECUTION TIME: 19:00:54.52

1 QDC CRDA, CR & LPZ, ALL REL GLAND: SIEMENS 60 GWD/MTU: 0 - 30 d  
 2 6 2 1. 1.  
 3 -2561 2.60+6 1.845+5 5.83+4  
 4 0. 0. 0. 1. 1. 2.78+5 0.  
 5 6 1800 7200 2.88+4 8.64+4 2.592E6  
 6 0.2402 4\*1.201E-2 0.  
 7 5\*1. 0.  
 8 6\*1.  
 9 6\*2460  
 10 2\*3.2E-5 2\*9.0E-6 3.0E-6 0.  
 11 3\*7.00E-4 6.45E-6 3.81E-6 0.  
 12 6\*0.  
 13 6\*0.  
 14 6\*0.  
 15 6\*0.  
 16 6\*0.  
 17 6\*0.  
 18 6\*0.  
 19 6\*0.  
 20 6\*0.  
 21 6\*1.  
 22 3\*1.  
 23 7.43E+3 1.04E+4 1.32E+4 1.48E+4 1.16E+4 1.57E+3 8.14E+3 3.33E+5  
 24 8.89E+4 8.25E+4 3.17E+5 8.39E+3 3.21E+4 4.57E+3 6.03E+4 8.93E+4

1

QDC CRDA, CR &amp; LPZ, ALL REL GLAND: SIEMENS 60 GWD/MTU: 0 - 30 d

## INITIAL CONTAINMENT INVENTORY

## ISOTOPE ACTIVITY (CURIES)

I-131	7.430E+03
I-132	1.040E+04
I-133	1.320E+04
I-134	1.480E+04
I-135	1.160E+04
XE-131M	1.570E+03
XE-133M	8.140E+03
XE-133	3.330E+05
XE-135M	8.890E+04
XE-135	8.250E+04
XE-138	3.170E+05
KR-83M	8.390E+03
KR-85M	3.210E+04
KR-85	4.570E+03
KR-87	6.030E+04
KR-88	8.930E+04

1

QDC CRDA, CR &amp; LPZ, ALL REL GLAND: SIEMENS 60 GWD/MTU: 0 - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL,	1. CFM MIXING, 00.00 PCT REL TO
SPRAYED VOL	

AT .002 HOURS: X/Q(SITE)= .32E-04 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM
INTAKE=2460.0 CFM		
X/Q CONT ROOM= .70E-03 SEC/M3	SEC RELEASE RATE= .86E+05 VOL/DAY	PCT PRI LKG TO ATM =
00.00		

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER

ELEMENTAL	.000	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM		SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA
ELEMENTAL											
I-131	4.00E+02	1.25E+02	1.17E+03	9.46E-01	1.81E-04	1.42E+01	3.46E-03	1.69E-03	2.14E-01	1.86E-06	2.54E-05
I-132	5.60E+02	1.75E+02	1.63E+03	1.32E+00	2.53E-04	1.14E-01	3.13E-02	5.38E-03	1.71E-03	1.45E-05	8.08E-05
I-133	7.11E+02	2.22E+02	2.07E+03	1.68E+00	3.22E-04	4.14E+00	7.90E-03	6.44E-03	6.22E-02	5.31E-06	9.69E-05
I-134	7.96E+02	2.49E+02	2.32E+03	1.88E+00	3.60E-04	2.83E-02	3.60E-02	7.77E-03	4.26E-04	2.22E-05	1.17E-04

1 QDC CRDA, CR & LPZ, ALL REL GLAND: SIEMENS 60 GWD/MTU: 0 - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL. 278000. FT3 UNSPRAYED VOL. 1. CFM MIXING. 00.00 PCT REL TO

**SPRAYED VOL**

AT .500 HOURS: X/Q(SITE)= .32E-04 SEC/M3 PRIMARY LEAK RATE=\*\*\*\*\* PERCENT/DAY CONTROL ROOM  
 INTAKE=2460.0 CFM

X/Q CONT ROOM= .70E-03 SEC/M3 SEC RELEASE RATE= .86E+05 VOL/DAY PCT PRI LKG TO ATM =  
 00.00

	CLEANUP RATES (HR-1)			FILTER NON-REMPTION FACTORS	
	SPRAY	PRIMARY	SECONDARY	CONT	CENTER
ELEMENTAL	.000	.000	.000	.000	1.000
PARTICULATE	.000	.000	.000	.000	1.000
ORGANIC	.000	.000	.000	.000	1.000

ACTIVITY (CURIES)				CONTROL ROOM		SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
ISOTOPE	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA
<b>ELEMENTAL</b>											
I-131	1.75E-07	2.13E-09	5.25E+02	9.24E-01	1.77E-04	6.41E+00	1.56E-03	7.61E-04	1.47E+02	1.27E-03	1.74E-02
I-132	2.12E-07	2.57E-09	7.31E+02	1.11E+00	2.13E-04	5.11E-02	1.40E-02	2.41E-03	1.10E+00	9.31E-03	5.18E-02
I-133	3.07E-07	3.73E-09	9.32E+02	1.62E+00	3.10E-04	1.86E+00	3.56E-03	2.90E-03	4.24E+01	3.62E-03	6.61E-02
I-134	2.35E-07	2.85E-09	1.03E+03	1.24E+00	2.37E-04	1.26E-02	1.60E-02	3.45E-03	2.44E+01	1.27E-02	6.69E-02
I-135	2.61E-07	3.17E-09	8.18E+02	1.37E+00	2.63E-04	2.82E-01	1.16E-02	1.85E-03	6.31E+00	6.35E-03	4.16E-02
<b>PARTICULATE</b>											
I-131	9.64E-09	1.17E-10	2.89E+01	5.08E-02	9.72E-06	3.52E-01	8.56E-05	4.18E-05	8.07E+00	7.00E-05	9.58E-04
I-132	1.16E-08	1.41E-10	4.02E+01	6.12E-02	1.17E-05	2.81E-03	7.71E-04	1.32E-04	6.04E-02	5.12E-04	2.84E-03
I-133	1.69E-08	2.05E-09	5.12E+01	8.89E-02	1.70E-05	1.02E-01	1.95E-04	1.59E-04	2.33E+00	1.99E-04	3.63E-03
I-134	1.29E-08	1.57E-10	5.66E+01	6.79E-02	1.30E-05	6.91E-04	8.78E-04	1.90E-04	1.34E-02	6.99E-04	3.67E-03
I-135	1.43E-08	1.74E-10	4.50E+01	7.54E-02	1.44E-05	1.55E-02	6.40E-04	1.02E-04	3.47E-01	3.49E-04	2.28E-03
<b>ORGANIC</b>											
I-131	7.71E-09	9.37E-11	2.31E+01	4.06E-02	7.78E-06	2.82E-01	6.85E-05	3.35E-05	6.46E+00	5.60E-05	7.67E-04
I-132	9.30E-09	1.13E-10	3.21E+01	4.90E-02	9.38E-06	2.25E-03	6.17E-04	1.06E-04	4.83E-02	4.09E-04	2.28E-03
I-133	1.35E-08	1.64E-10	4.10E+01	7.11E-02	1.36E-05	8.19E-02	1.56E-04	1.28E-04	1.86E+00	1.59E-04	2.90E-03
I-134	1.03E-08	1.25E-10	4.53E+01	5.44E-02	1.04E-05	5.53E-04	7.02E-04	1.52E-04	1.07E-02	5.59E-04	2.94E-03
I-135	1.15E-08	1.39E-10	3.60E+01	6.03E-02	1.15E-05	1.24E-02	5.12E-04	8.15E-05	2.76E-01	2.79E-04	1.83E-03
<b>NOBLE GASES</b>											
XE-131M	1.63E-07	1.98E-09	4.88E+02	8.59E-01	1.64E-04	0.00E+00	8.58E-05	4.85E-04	0.00E+00	3.08E-04	1.11E-02
XE-133M	8.41E-07	1.02E-08	2.53E+03	4.43E+00	8.48E-04	0.00E+00	6.67E-04	2.88E-03	0.00E+00	7.02E-04	6.59E-02
XE-133	3.45E-05	4.20E-07	1.03E+05	1.82E+02	3.48E-02	0.00E+00	2.48E-02	1.11E-01	0.00E+00	6.44E-02	2.55E+00
XE-135M	2.44E-06	2.96E-08	2.63E+04	1.29E+01	2.46E-03	0.00E+00	8.87E-02	1.87E-02	0.00E+00	4.47E-02	2.58E-01
XE-135	8.26E-06	1.00E-07	2.56E+04	4.35E+01	8.33E-03	0.00E+00	5.04E-02	6.07E-02	0.00E+00	4.05E-02	1.37E+00
XE-138	1.00E-05	1.22E-07	9.41E+04	5.29E+01	1.01E-02	0.00E+00	2.16E+00	5.54E-01	0.00E+00	2.95E-01	8.00E+00
KR-83M	7.25E-07	8.81E-09	2.59E+03	3.82E+00	7.31E-04	0.00E+00	1.04E-04	6.48E-04	0.00E+00	1.20E-03	1.37E-02
KR-85M	3.08E-06	3.75E-08	9.94E+03	1.62E+01	3.11E-03	0.00E+00	1.24E-02	1.70E-02	0.00E+00	1.06E-02	3.78E-01
KR-85	4.75E-07	5.77E-09	1.42E+03	2.50E+00	4.79E-04	0.00E+00	2.39E-05	2.33E-03	0.00E+00	2.00E-05	5.34E-02
KR-87	4.77E-06	5.80E-08	1.85E+04	2.51E+01	4.81E-03	0.00E+00	2.04E-01	1.43E-01	0.00E+00	7.42E-02	2.92E+00
KR-88	8.20E-06	9.97E-08	2.76E+04	4.32E+01	8.27E-03	0.00E+00	3.85E-01	6.93E-02	0.00E+00	2.56E-01	1.51E+00

1

QDC CRDA, CR &amp; LPZ, ALL REL GLAND: SIEMENS 60 GWD/MTU: 0 - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO  
SPRAYED VOL

AT 2.000 HOURS:	X/Q(SITE)= .90E-05 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM
INTAKE=2460.0 CFM			
00.00	X/Q CONT ROOM= .70E-03 SEC/M3	SEC RELEASE RATE= .86E+05 VOL/DAY	PCT PRI LKG TO ATM =

	CLEANUP RATES (HR-1)			FILTER NON-REMOVAL FACTORS		
	SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)	CONTROL ROOM	SITE BOUNDARY DOSES (REM)	CONTROL ROOM DOSES (REM)							
	PRIMARY	SECONDARY	RELEASE	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA	
<b>ELEMENTAL</b>											
I-131	1.19E-35	1.45E-37	1.78E-07	2.77E-01	5.30E-05	6.10E-10	1.48E-13	7.24E-14	2.12E+02	1.84E-03	2.51E-02
I-132	9.19E-36	1.12E-37	2.13E-07	2.14E-01	4.09E-05	4.18E-12	1.15E-12	1.97E-13	1.23E+00	1.04E-02	5.81E-02
I-133	2.00E-35	2.43E-37	3.11E-07	4.64E-01	8.88E-05	1.75E-10	3.33E-13	2.72E-13	5.96E+01	5.09E-03	9.29E-02
I-134	4.83E-36	5.87E-38	2.33E-07	1.12E-01	2.15E-05	8.01E-13	1.02E-12	2.20E-13	1.85E-01	9.64E-03	5.07E-02
I-135	1.52E-35	1.85E-37	2.63E-07	3.54E-01	6.78E-05	2.55E-11	1.05E-12	1.68E-13	8.36E+00	8.41E-03	5.50E-02
<b>PARTICULATE</b>											
I-131	6.54E-37	7.96E-39	9.75E-09	1.52E-02	2.91E-06	3.35E-11	8.14E-15	3.98E-15	1.16E+01	1.01E-04	1.38E-03
I-132	5.05E-37	6.14E-39	1.17E-08	1.17E-02	2.25E-06	2.30E-13	6.31E-14	1.08E-14	6.77E-02	5.74E-04	3.19E-03
I-133	1.10E-36	1.33E-38	1.71E-08	2.55E-02	4.88E-06	9.59E-12	1.83E-14	1.49E-14	3.28E+00	2.80E-04	5.10E-03
I-134	2.66E-37	3.23E-39	1.28E-08	6.17E-03	1.18E-06	4.40E-14	5.59E-14	1.21E-14	1.02E-02	5.30E-04	2.79E-03
I-135	8.37E-37	1.02E-38	1.45E-08	1.95E-02	3.72E-06	1.40E-12	5.79E-14	9.21E-15	4.59E-01	4.62E-04	3.02E-03
<b>ORGANIC</b>											
I-131	5.24E-37	6.36E-39	7.80E-09	1.22E-02	2.33E-06	2.68E-11	6.51E-15	3.18E-15	9.31E+00	8.08E-05	1.11E-03
I-132	4.04E-37	4.91E-39	9.35E-09	9.39E-03	1.80E-06	1.84E-13	5.05E-14	8.67E-15	5.42E-02	4.59E-04	2.55E-03
I-133	8.77E-37	1.07E-38	1.37E-08	2.04E-02	3.90E-06	7.67E-12	1.46E-14	1.20E-14	2.62E+00	2.24E-04	4.08E-03
I-134	2.12E-37	2.58E-39	1.03E-08	4.94E-03	9.45E-07	3.52E-14	4.47E-14	9.66E-15	8.13E-03	4.24E-04	2.23E-03
I-135	6.70E-37	8.14E-39	1.16E-08	1.56E-02	2.98E-06	1.12E-12	4.63E-14	7.37E-15	3.67E-01	3.70E-04	2.42E-03
<b>NOBLE GASES</b>											
XE-131M	1.11E-35	1.35E-37	1.65E-07	2.58E-01	4.93E-05	0.00E+00	8.17E-15	4.61E-14	0.00E+00	4.44E-04	1.60E-02
XE-133M	5.63E-35	6.85E-37	8.51E-07	1.31E+00	2.51E-04	0.00E+00	6.32E-14	2.73E-13	0.00E+00	1.00E-03	9.43E-02
XE-133	2.34E-33	2.84E-35	3.49E-05	5.43E+01	1.04E-02	0.00E+00	2.36E-12	1.06E-11	0.00E+00	9.27E-02	3.66E+00
XE-135M	3.06E-36	3.72E-38	2.33E-06	7.12E-02	1.36E-05	0.00E+00	2.21E-12	4.67E-13	0.00E+00	9.84E-03	5.67E-02
XE-135	5.03E-34	6.11E-36	8.34E-06	1.17E+01	2.24E-03	0.00E+00	4.62E-12	5.56E-12	0.00E+00	5.49E-02	1.85E+00
XE-138	1.94E-35	2.36E-37	9.64E-06	4.52E-01	8.64E-05	0.00E+00	6.22E-11	1.60E-11	0.00E+00	7.74E-02	2.09E+00
KR-83M	2.84E-35	3.45E-37	7.27E-07	6.59E-01	1.26E-04	0.00E+00	8.18E-15	5.12E-14	0.00E+00	1.27E-03	1.45E-02
KR-85M	1.66E-34	2.02E-36	3.11E-06	3.86E+00	7.39E-04	0.00E+00	1.09E-12	1.50E-12	0.00E+00	1.34E-02	4.78E-01
KR-85	3.24E-35	3.94E-37	4.81E-07	7.54E-01	1.44E-04	0.00E+00	2.27E-15	2.22E-13	0.00E+00	2.89E-05	7.73E-02
KR-87	1.43E-34	1.74E-36	4.77E-06	3.33E+00	6.37E-04	0.00E+00	1.47E-11	1.04E-11	0.00E+00	6.83E-02	2.69E+00
KR-88	3.86E-34	4.69E-36	8.25E-06	8.98E+00	1.72E-03	0.00E+00	3.24E-11	5.83E-12	0.00E+00	3.01E-01	1.77E+00

1 QDC CRDA, CR &amp; LPZ, ALL REL GLAND: SIEMENS 60 GWD/MTU: 0 - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO  
SPRAYED VOL

AT 8.000 HOURS:	X/Q(SITE)= .90E-05 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM
INTAKE=2460.0 CFM			
00.00	X/Q CONT ROOM= .65E-05 SEC/M3	SEC RELEASE RATE= .86E+05 VOL/DAY	PCT PRI LKG TO ATM =

	CLEANUP RATES (HR-1)			FILTER NON-REMOVAL FACTORS		
	SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)	CONTROL ROOM	SITE BOUNDARY DOSES (REM)	CONTROL ROOM DOSES (REM)						
	PRIMARY	SECONDARY	RELEASE	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA

ELEMENTAL														
I-131	0.00E+00	0.00E+00	1.21E-35	2.23E-03	4.27E-07	4.14E-38	1.01E-41	4.92E-42	8.99E+01	7.80E-04	1.07E-02			
I-132	0.00E+00	0.00E+00	9.24E-36	2.88E-04	5.52E-08	1.82E-40	4.99E-41	8.57E-42	2.92E-01	2.47E-03	1.38E-02			
I-133	0.00E+00	0.00E+00	2.02E-35	3.13E-03	5.99E-07	1.13E-38	2.17E-41	1.77E-41	2.38E+01	2.03E-03	3.71E-02			
I-134	0.00E+00	0.00E+00	4.80E-36	7.64E-06	1.46E-09	1.65E-41	2.10E-41	4.52E-42	1.85E-02	9.63E-04	5.06E-03			
I-135	0.00E+00	0.00E+00	1.54E-35	1.57E-03	3.00E-07	1.49E-39	6.16E-41	9.81E-42	2.89E+00	2.91E-03	1.90E-02			
PARTICULATE														
I-131	0.00E+00	0.00E+00	6.62E-37	1.23E-04	2.35E-08	2.28E-39	5.53E-43	2.70E-43	4.94E+00	4.28E-05	5.86E-04			
I-132	0.00E+00	0.00E+00	5.08E-37	1.58E-05	3.03E-09	9.99E-42	2.74E-42	4.71E-43	1.60E-02	1.36E-04	7.56E-04			
I-133	0.00E+00	0.00E+00	1.11E-36	1.72E-04	3.29E-08	6.23E-40	1.19E-42	9.71E-43	1.31E+00	1.12E-04	2.04E-03			
I-134	0.00E+00	0.00E+00	2.64E-37	4.20E-07	8.04E-11	9.06E-43	1.15E-42	2.49E-43	1.01E-03	5.29E-05	2.78E-04			
I-135	0.00E+00	0.00E+00	8.45E-37	8.61E-05	1.65E-08	8.18E-41	3.38E-42	5.39E-43	1.59E-01	1.60E-04	1.05E-03			
ORGANIC														
I-131	0.00E+00	0.00E+00	5.30E-37	9.80E-05	1.88E-08	1.82E-39	4.42E-43	2.16E-43	3.95E+00	3.43E-05	4.69E-04			
I-132	0.00E+00	0.00E+00	4.06E-37	1.27E-05	2.43E-09	7.99E-42	2.19E-42	3.77E-43	1.28E-02	1.09E-04	6.05E-04			
I-133	0.00E+00	0.00E+00	8.87E-37	1.38E-04	2.63E-08	4.99E-40	9.52E-43	7.77E-43	1.05E+00	8.94E-05	1.63E-03			
I-134	0.00E+00	0.00E+00	2.11E-37	3.36E-07	6.43E-11	7.25E-43	9.21E-43	1.99E-43	8.12E-04	4.23E-05	2.23E-04			
I-135	0.00E+00	0.00E+00	6.76E-37	6.89E-05	1.32E-08	6.55E-41	2.71E-42	4.31E-43	1.27E-01	1.28E-04	8.37E-04			
NOBLE GASES														
XE-131M	0.00E+00	0.00E+00	1.12E-35	2.09E-03	4.00E-07	0.00E+00	5.55E-43	3.14E-42	0.00E+00	1.89E-04	6.82E-03			
XE-133M	0.00E+00	0.00E+00	5.70E-35	9.98E-03	1.91E-06	0.00E+00	4.23E-42	1.83E-41	0.00E+00	4.18E-04	3.93E-02			
XE-133	0.00E+00	0.00E+00	2.37E-33	4.33E-01	8.28E-05	0.00E+00	1.60E-40	7.15E-40	0.00E+00	3.92E-02	1.55E+00			
XE-135M	0.00E+00	0.00E+00	2.92E-36	6.70E-11	1.28E-14	0.00E+00	2.77E-42	5.86E-43	0.00E+00	5.48E-05	3.16E-04			
XE-135	0.00E+00	0.00E+00	5.08E-34	6.10E-02	1.17E-05	0.00E+00	2.81E-40	3.39E-40	0.00E+00	2.01E-02	6.78E-01			
XE-138	0.00E+00	0.00E+00	1.86E-35	2.39E-09	4.58E-13	0.00E+00	1.20E-40	3.09E-41	0.00E+00	6.66E-04	1.80E-02			
KR-83M	0.00E+00	0.00E+00	2.85E-35	5.86E-04	1.12E-07	0.00E+00	3.20E-43	2.00E-42	0.00E+00	2.65E-04	3.03E-03			
KR-85M	0.00E+00	0.00E+00	1.68E-34	1.23E-02	2.36E-06	0.00E+00	5.88E-41	8.08E-41	0.00E+00	4.15E-03	1.48E-01			
KR-85	0.00E+00	0.00E+00	3.28E-35	6.20E-03	1.19E-06	0.00E+00	1.55E-43	1.52E-41	0.00E+00	1.24E-05	3.30E-02			
KR-87	0.00E+00	0.00E+00	1.43E-34	1.03E-03	1.97E-07	0.00E+00	4.43E-40	3.11E-40	0.00E+00	1.04E-02	4.11E-01			
KR-88	0.00E+00	0.00E+00	3.89E-34	1.67E-02	3.20E-06	0.00E+00	1.52E-39	2.74E-40	0.00E+00	7.86E-02	4.62E-01			

1 QDC CRDA, CR &amp; LPZ, ALL REL GLAND: SIEMENS 60 GWD/MTU: 0 - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO

SPRAYED VOL

AT 24.000 HOURS: X/Q(SITE)= .30E-05 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM
INTAKE=2460.0 CPM		
X/Q CONT ROOM=.38E-05 SEC/M3	SEC RELEASE RATE=.86E+05 VOL/DAY	PCT PRI LKG TO ATM =
00.00		

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS			
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER		
ELEMENTAL	.000	.000	.000	1.000	1.000		
PARTICULATE	.000	.000	.000	1.000	1.000		
ORGANIC	.000	.000	.000	1.000	1.000		
ACTIVITY (CURIES)				CONTROL ROOM DOSES (REM)			
ISOTOPE	PRIMARY	SECONDARY	RELEASE	(CURIES) (UCI/CM3)	THYROID	WH BODY	BETA
ELEMENTAL	0.00E+00	0.00E+00	0.00E+00	5.81E-09	1.11E-12	0.00E+00	0.00E+00
I-131	0.00E+00	0.00E+00	0.00E+00	6.41E-12	1.23E-15	0.00E+00	0.00E+00
I-132	0.00E+00	0.00E+00	0.00E+00	5.10E-09	9.76E-13	0.00E+00	0.00E+00
I-133	0.00E+00	0.00E+00	0.00E+00	5.90E-17	1.13E-20	0.00E+00	0.00E+00
I-134	0.00E+00	0.00E+00	0.00E+00	8.29E-10	1.59E-13	0.00E+00	0.00E+00
I-135	0.00E+00	0.00E+00	0.00E+00	3.19E-10	6.11E-14	0.00E+00	0.00E+00
PARTICULATE	0.00E+00	0.00E+00	0.00E+00	3.52E-13	6.75E-17	0.00E+00	0.00E+00
I-131	0.00E+00	0.00E+00	0.00E+00	2.80E-10	5.36E-14	0.00E+00	0.00E+00
I-132	0.00E+00	0.00E+00	0.00E+00	3.24E-18	6.21E-22	0.00E+00	0.00E+00
I-133	0.00E+00	0.00E+00	0.00E+00	4.55E-11	8.71E-15	0.00E+00	0.00E+00
ORGANIC	0.00E+00	0.00E+00	0.00E+00	2.56E-10	4.89E-14	0.00E+00	0.00E+00
I-131	0.00E+00	0.00E+00	0.00E+00	2.82E-13	5.40E-17	0.00E+00	0.00E+00
I-132	0.00E+00	0.00E+00	0.00E+00	2.24E-10	4.29E-14	0.00E+00	0.00E+00
I-133	0.00E+00	0.00E+00	0.00E+00	2.59E-18	4.96E-22	0.00E+00	0.00E+00
I-134	0.00E+00	0.00E+00	0.00E+00	3.64E-11	6.97E-15	0.00E+00	0.00E+00
NOBLE GASES	0.00E+00	0.00E+00	0.00E+00	5.55E-09	1.06E-12	0.00E+00	0.00E+00
XE-131M	0.00E+00	0.00E+00	0.00E+00	2.25E-08	4.30E-12	0.00E+00	0.00E+00
XE-133M	0.00E+00	0.00E+00	0.00E+00	1.09E-06	2.09E-10	0.00E+00	0.00E+00
XE-133	0.00E+00	0.00E+00	0.00E+00	5.70E-35	1.09E-38	0.00E+00	0.00E+00
XE-135M	0.00E+00	0.00E+00	0.00E+00	4.99E-08	9.56E-12	0.00E+00	0.00E+00
XE-135	0.00E+00	0.00E+00	0.00E+00	2.04E-31	3.90E-35	0.00E+00	0.00E+00
XE-138	0.00E+00	0.00E+00	0.00E+00	4.29E-12	8.22E-16	0.00E+00	0.00E+00
KR-83M	0.00E+00	0.00E+00	0.00E+00	2.73E-09	5.23E-13	0.00E+00	0.00E+00
KR-85M	0.00E+00	0.00E+00	0.00E+00	1.71E-08	3.28E-12	0.00E+00	0.00E+00
KR-85	0.00E+00	0.00E+00	0.00E+00	1.71E-08	3.28E-12	0.00E+00	0.00E+00

KR-87	0.00E+00	0.00E+00	0.00E+00	4.47E-13	8.56E-17	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.22E-06	1.27E-04
KR-88	0.00E+00	0.00E+00	0.00E+00	8.77E-10	1.68E-13	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.47E-04	8.62E-04
						0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.94E-01	6.28E-04

1 QDC CRDA, CR &amp; LPZ, ALL REL GLAND: SIEMENS 60 GWD/MTU: 0 - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO  
SPRAYED VOL

AT 720.000 HOURS:	X/Q(SITE)= .00E+00 SEC/M3	PRIMARY LEAK RATE= .000 PERCENT/DAY	CONTROL ROOM
INTAKE=2460.0 CFM			
	X/Q CONT ROOM= .00E+00 SEC/M3	SEC RELEASE RATE= .00E+00 VOL/DAY	PCT PRI LKG TO ATM =
00.00			

	CLEANUP RATES (HR-1)			FILTER NON-REMOVAL FACTORS		
	SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM (CURIES) (UCI/CM3)	SITE BOUNDARY DOSES THYROID WH BODY	(REM) BETA	CONTROL ROOM DOSES THYROID WH BODY	(REM) BETA
	PRIMARY	SECONDARY	RELEASE					
<b>ELEMENTAL</b>								
I-131	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.90E-06	1.65E-11
I-132	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.77E-12	7.44E-14
I-133	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.63E-07	2.25E-11
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.71E-18	5.06E-19
I-135	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.80E-09	6.84E-12
<b>PARTICULATE</b>								
I-131	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.05E-07	9.07E-13
I-132	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.82E-13	4.09E-15
I-133	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.45E-08	1.24E-12
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.33E-19	1.46E-19
I-135	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.74E-10	3.76E-13
<b>ORGANIC</b>								
I-131	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.36E-08	7.25E-13
I-132	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.86E-13	3.27E-15
I-133	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.16E-08	9.89E-13
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.27E-19	2.22E-20
I-135	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.99E-10	3.01E-13
<b>NOBLE GASES</b>								
XE-131M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.10E-12
XE-133M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.22E-12	6.79E-10
XE-133	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.95E-10	3.14E-08
XE-135M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.39E-38	2.53E-37
XE-135	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.63E-11	2.91E-09
XE-138	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.01E-34	8.14E-33
KR-83M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.73E-15
KR-85M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.95E-12
KR-85	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.05E-10
KR-87	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.83E-13
KR-88	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.70E-12
					0.00E+00	0.00E+00	0.00E+00	3.39E-06
								9.54E-10
								3.68E-08
TOTAL DOSES 0-30 DAYS				3.05E+01	9.82E+00	3.26E+00	6.55E+02	1.65E+00
								3.40E+01

1

QDC CRDA, CR &amp; LPZ, ALL REL GLAND: SIEMENS 60 GWD/MTU: 0 - 30 d

ISOTOPE	ACTIVITY RELEASED (CURIES)			
	2. HRS	8. HRS	24. HRS	720. HRS
<b>ELEMENTAL</b>				
I-131	1.69E+03	1.21E-35	0.00E+00	0.00E+00
I-132	2.36E+03	9.24E-36	0.00E+00	0.00E+00
I-133	3.00E+03	2.02E-35	0.00E+00	0.00E+00
I-134	3.35E+03	4.80E-36	0.00E+00	0.00E+00
I-135	2.64E+03	1.54E-35	0.00E+00	0.00E+00
<b>PARTICULATE</b>				
I-131	9.29E+01	6.62E-37	0.00E+00	0.00E+00
I-132	1.30E+02	5.08E-37	0.00E+00	0.00E+00
I-133	1.65E+02	1.11E-36	0.00E+00	0.00E+00
I-134	1.84E+02	2.64E-37	0.00E+00	0.00E+00
I-135	1.45E+02	8.45E-37	0.00E+00	0.00E+00
<b>ORGANIC</b>				
I-131	7.43E+01	5.30E-37	0.00E+00	0.00E+00
I-132	1.04E+02	4.06E-37	0.00E+00	0.00E+00

I-133	1.32E+02	8.87E-37	0.00E+00	0.00E+00	1.32E+02
I-134	1.47E+02	2.11E-37	0.00E+00	0.00E+00	1.47E+02
I-135	1.16E+02	6.76E-37	0.00E+00	0.00E+00	1.16E+02
NOBLE GASES					
XE-131M	1.57E+03	1.12E-35	0.00E+00	0.00E+00	1.57E+03
XE-133M	8.14E+03	5.70E-35	0.00E+00	0.00E+00	8.14E+03
XE-133	3.33E+05	2.37E-33	0.00E+00	0.00E+00	3.33E+05
XE-135M	8.74E+04	2.92E-36	0.00E+00	0.00E+00	8.74E+04
XE-135	8.25E+04	5.08E-34	0.00E+00	0.00E+00	8.25E+04
XE-138	3.12E+05	1.86E-35	0.00E+00	0.00E+00	3.12E+05
KR-83M	8.37E+03	2.85E-35	0.00E+00	0.00E+00	8.37E+03
KR-85M	3.21E+04	1.68E-34	0.00E+00	0.00E+00	3.21E+04
KR-85	4.57E+03	3.28E-35	0.00E+00	0.00E+00	4.57E+03
KR-87	6.01E+04	1.43E-34	0.00E+00	0.00E+00	6.01E+04
KR-88	8.92E+04	3.89E-34	0.00E+00	0.00E+00	8.92E+04

END EXECUTION DATE: 11/18/1999  
END EXECUTION TIME: 19:00:54.74

AXIDENT VER 2 MOD 4  
 PRODUCTION DATE 02/18/92  
 BEGIN EXECUTION DATE: 11/18/1999  
 BEGIN EXECUTION TIME: 19:01:07.37

1 QDC CRDA, EAB, ALL REL MVP: SIEMENS 60 GWD/MTU: 0 - 6 s  
 2 2 1 1. 1.  
 3 -2561 2.60+6 1.845+5 5.83+4  
 4 0. 0. 0. 1. 1. 2.78+5 0.  
 5 6 7200  
 6 0.2402 0.  
 7 9.058E-4 0.  
 8 2\*1.  
 9 2\*0.  
 10 2.9E-4 0.  
 11 2\*0.  
 12 2\*0.  
 13 2\*0.  
 14 2\*0.  
 15 2\*0.  
 16 2\*0.  
 17 2\*0.  
 18 2\*0.  
 19 2\*0.  
 20 2\*0.  
 21 6\*1.  
 22 3\*1.  
 23 7.43E+3 1.04E+4 1.32E+4 1.48E+4 1.16E+4 1.57E+3 8.14E+3 3.33E+5  
 24 8.89E+4 8.25E+4 3.17E+5 8.39E+3 3.21E+4 4.57E+3 6.03E+4 8.93E+4

1

QDC CRDA, EAB, ALL REL MVP: SIEMENS 60 GWD/MTU: 0 - 6 s

## INITIAL CONTAINMENT INVENTORY

## ISOTOPE ACTIVITY (CURIES)

I-131	7.430E+03
I-132	1.040E+04
I-133	1.320E+04
I-134	1.480E+04
I-135	1.160E+04
XE-131M	1.570E+03
XE-133M	8.140E+03
XE-133	3.330E+05
XE-135M	8.890E+04
XE-135	8.250E+04
XE-138	3.170E+05
KR-83M	8.390E+03
KR-85M	3.210E+04
KR-85	4.570E+03
KR-87	6.030E+04
KR-88	8.930E+04

1 QDC CRDA, EAB, ALL REL MVP: SIEMENS 60 GWD/MTU: 0 - 6 s

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO

SPRAYED VOL

AT .002 HOURS:	X/Q(SITE)= .29E-03 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM INTAKE=
.0 CFM			
	X/Q CONT ROOM= .00E+00 SEC/M3	SEC RELEASE RATE= .78E+02 VOL/DAY	PCT PRI LKG TO ATM =
00.00			

ISOTOPE	CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS	
	SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	.000	1.000	1.000
ACTIVITY (CURIES)	CONTROL ROOM	SITE BOUNDARY DOSES (REM)	CONTROL ROOM DOSES (REM)			
ISOTOPE PRIMARY SECONDARY RELEASE	(CURIES) (UCI/CM3)	THYROID WH BODY BETA	THYROID WH BODY BETA			
ELEMENTAL						
I-131	4.00E+02 1.29E+03 4.31E+00 0.00E+00 0.00E+00	4.77E-01 1.16E-04 5.67E-05 0.00E+00 0.00E+00	0.00E+00 0.00E+00 0.00E+00			
I-132	5.60E+02 1.80E+03 6.03E+00 0.00E+00 0.00E+00	3.83E-03 1.05E-03 1.80E-04 0.00E+00 0.00E+00	0.00E+00 0.00E+00 0.00E+00			
I-133	7.11E+02 2.28E+03 7.66E+00 0.00E+00 0.00E+00	1.39E-01 2.65E-04 2.16E-04 0.00E+00 0.00E+00	0.00E+00 0.00E+00 0.00E+00			
I-134	7.96E+02 2.56E+03 8.58E+00 0.00E+00 0.00E+00	9.50E-04 1.21E-03 2.60E-04 0.00E+00 0.00E+00	0.00E+00 0.00E+00 0.00E+00			

QDC 9400-M-0550 Rev. 0

## **Attachment A-K**

I-135	6.24E+02	2.01E+03	6.73E+00	0.00E+00	0.00E+00	2.10E-02	8.68E-04	1.38E-04	0.00E+00	0.00E+00	0.00E+00			
PARTICULATE														
I-131	2.20E+01	7.07E+01	2.37E-01	0.00E+00	0.00E+00	2.62E-02	6.37E-06	3.11E-06	0.00E+00	0.00E+00	0.00E+00			
I-132	3.07E+01	9.89E+01	3.32E-01	0.00E+00	0.00E+00	2.10E-04	5.77E-05	9.91E-06	0.00E+00	0.00E+00	0.00E+00			
I-133	3.90E+01	1.26E+02	4.21E-01	0.00E+00	0.00E+00	7.62E-03	1.46E-05	1.19E-05	0.00E+00	0.00E+00	0.00E+00			
I-134	4.37E+01	1.41E+02	4.72E-01	0.00E+00	0.00E+00	5.22E-05	6.63E-05	1.43E-05	0.00E+00	0.00E+00	0.00E+00			
I-135	3.43E+01	1.10E+02	3.70E-01	0.00E+00	0.00E+00	1.15E-03	4.77E-05	7.60E-06	0.00E+00	0.00E+00	0.00E+00			
ORGANIC														
I-131	1.76E+01	5.65E+01	1.90E-01	0.00E+00	0.00E+00	2.10E-02	5.10E-06	2.49E-06	0.00E+00	0.00E+00	0.00E+00			
I-132	2.46E+01	7.91E+01	2.65E-01	0.00E+00	0.00E+00	1.68E-04	4.61E-05	7.93E-06	0.00E+00	0.00E+00	0.00E+00			
I-133	3.12E+01	1.00E+02	3.37E-01	0.00E+00	0.00E+00	6.10E-03	1.16E-05	9.50E-06	0.00E+00	0.00E+00	0.00E+00			
I-134	3.50E+01	1.12E+02	3.77E-01	0.00E+00	0.00E+00	4.18E-05	5.30E-05	1.14E-05	0.00E+00	0.00E+00	0.00E+00			
I-135	2.74E+01	8.82E+01	2.96E-01	0.00E+00	0.00E+00	9.23E-04	3.82E-05	6.08E-06	0.00E+00	0.00E+00	0.00E+00			
NOBLE GASES														
XE-131M	3.72E+02	1.19E+03	4.01E+00	0.00E+00	0.00E+00	0.00E+00	6.39E-06	3.61E-05	0.00E+00	0.00E+00	0.00E+00			
XE-133M	1.93E+03	6.19E+03	2.08E+01	0.00E+00	0.00E+00	0.00E+00	4.97E-05	2.15E-04	0.00E+00	0.00E+00	0.00E+00			
XE-133	7.88E+04	2.53E+05	8.49E+02	0.00E+00	0.00E+00	0.00E+00	6.92E-03	1.46E-03	0.00E+00	0.00E+00	0.00E+00			
XE-135M	2.09E+04	6.73E+04	2.26E+02	0.00E+00	0.00E+00	0.00E+00	3.75E-03	4.52E-03	0.00E+00	0.00E+00	0.00E+00			
XE-135	1.95E+04	6.28E+04	2.10E+02	0.00E+00	0.00E+00	0.00E+00	1.68E-01	4.30E-02	0.00E+00	0.00E+00	0.00E+00			
XE-138	7.47E+04	2.40E+05	8.07E+02	0.00E+00	0.00E+00	0.00E+00	7.76E-06	4.85E-05	0.00E+00	0.00E+00	0.00E+00			
KR-83M	1.98E+03	6.38E+03	2.14E+01	0.00E+00	0.00E+00	0.00E+00	9.26E-04	1.27E-03	0.00E+00	0.00E+00	0.00E+00			
KR-85M	7.59E+03	2.44E+04	8.19E+01	0.00E+00	0.00E+00	0.00E+00	1.77E-06	1.73E-04	0.00E+00	0.00E+00	0.00E+00			
KR-85	1.08E+03	3.48E+03	1.17E+01	0.00E+00	0.00E+00	0.00E+00	1.53E-02	1.08E-02	0.00E+00	0.00E+00	0.00E+00			
KR-87	1.43E+04	4.58E+04	1.54E+02	0.00E+00	0.00E+00	0.00E+00	2.88E-02	5.18E-03	0.00E+00	0.00E+00	0.00E+00			
KR-88	2.11E+04	6.79E+04	2.28E+02	0.00E+00	0.00E+00	-----	7.05E-01	2.29E-01	7.59E-02	0.00E+00	0.00E+00			

1 QDC CRDA, EAB, ALL REL MVP: SIEMENS 60 GWD/MTU: 0 - 6 s

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

**SPRAYED VOL**

AT .0 CFM	2.000 HOURS: X/Q(SITE) = .00E+00 SEC/M3	PRIMARY LEAK RATE= .000 PERCENT/DAY	CONTROL ROOM INTAKE=
	X/Q CONT ROOM= .00E+00 SEC/M3	SEC RELEASE RATE= .00E+00 VOL/DAY	PCT PRI LKG TO ATM =
	00.00		

TOTAL DOSES 0-30 DAYS	7.05E-01	2.29E-01	7.59E-02	0.00E+00	0.00E+00	0.00E+00
-----------------------	----------	----------	----------	----------	----------	----------

1

QDC CRDA, EAB, ALL REL MVP: SIEMENS 60 GWD/MTU: 0 - 6 s

## ACTIVITY RELEASED (CURIES)

## ISOTOPE            2. HRS

## ELEMENTAL

I-131	4.31E+00	4.31E+00
I-132	6.03E+00	6.03E+00
I-133	7.66E+00	7.66E+00
I-134	8.58E+00	8.58E+00
I-135	6.73E+00	6.73E+00

## PARTICULATE

I-131	2.37E-01	2.37E-01
I-132	3.32E-01	3.32E-01
I-133	4.21E-01	4.21E-01
I-134	4.72E-01	4.72E-01
I-135	3.70E-01	3.70E-01

## ORGANIC

I-131	1.90E-01	1.90E-01
I-132	2.65E-01	2.65E-01
I-133	3.37E-01	3.37E-01
I-134	3.77E-01	3.77E-01
I-135	2.96E-01	2.96E-01

## NOBLE GASES

XE-131M	4.01E+00	4.01E+00
XE-133M	2.08E+01	2.08E+01
XE-133	8.49E+02	8.49E+02
XE-135M	2.26E+02	2.26E+02
XE-135	2.10E+02	2.10E+02
XE-138	8.07E+02	8.07E+02
KR-83M	2.14E+01	2.14E+01
KR-85M	8.19E+01	8.19E+01
KR-85	1.17E+01	1.17E+01
KR-87	1.54E+02	1.54E+02
KR-88	2.28E+02	2.28E+02

END EXECUTION DATE: 11/18/1999  
 END EXECUTION TIME: 19:01:07.37

AXIDENT VER 2 MOD 4  
 PRODUCTION DATE 02/18/92  
 BEGIN EXECUTION DATE: 11/18/1999  
 BEGIN EXECUTION TIME: 19:00:31.17

1 QDC CRDA, EAB, ALL REL GLAND: SIEMENS 60 GWD/MTU: 0 - 2 h  
 2 3 2 1. 1.  
 3 -2561 2.60+6 1.845+5 5.83+4  
 4 0. 0. 1. 1. 2.78+5 0.  
 5 6 1800 7200  
 6 0.2402 2\*1.201E-2  
 7 3\*1.  
 8 3\*1.  
 9 3\*0.  
 10 2\*2.9e-4 2.3E-5  
 11 3\*0.  
 12 3\*0.  
 13 3\*0.  
 14 3\*0.  
 15 3\*0.  
 16 3\*0.  
 17 3\*0.  
 18 3\*0.  
 19 3\*0.  
 20 3\*0.  
 21 6\*1.  
 22 3\*1.  
 23 7.43E+3 1.04E+4 1.32E+4 1.48E+4 1.16E+4 1.57E+3 8.14E+3 3.33E+5  
 24 8.89E+4 8.25E+4 3.17E+5 8.39E+3 3.21E+4 4.57E+3 6.03E+4 8.93E+4

1

QDC CRDA, EAB, ALL REL GLAND: SIEMENS 60 GWD/MTU: 0 - 2 h

## INITIAL CONTAINMENT INVENTORY

## ISOTOPE ACTIVITY (CURIES)

I-131	7.430E+03
I-132	1.040E+04
I-133	1.320E+04
I-134	1.480E+04
I-135	1.160E+04
XE-131M	1.570E+03
XE-133M	8.140E+03
XE-133	3.330E+05
XE-135M	8.890E+04
XE-135	8.250E+04
XE-138	3.170E+05
KR-83M	8.390E+03
KR-85M	3.210E+04
KR-85	4.570E+03
KR-87	6.030E+04
KR-88	8.930E+04

1 QDC CRDA, EAB, ALL REL GLAND: SIEMENS 60 GWD/MTU: 0 - 2 h

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
 1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO

## SPRAYED VOL

AT .002 HOURS:	X/Q(SITE)= .29E-03 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM INTAKE=
.0 CFM			
	X/Q CONT ROOM= .00E+00 SEC/M3	SEC RELEASE RATE= .86E+05 VOL/DAY	PCT PRI LKG TO ATM =
00.00			

SPRAY	CLEANUP RATES (HR-1)			FILTER NON-REMOVAL FACTORS	
	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM (CURIES) (UCI/CM3)	SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE		THYROID	WH BODY	BETA	THYROID	WH BODY	BETA
ELEMENTAL										
I-131	4.00E+02	1.25E+02	1.17E+03	0.00E+00	0.00E+00	1.29E+02	3.13E-02	1.53E-02	0.00E+00	0.00E+00
I-132	5.60E+02	1.75E+02	1.63E+03	0.00E+00	0.00E+00	1.03E+00	2.84E-01	4.87E-02	0.00E+00	0.00E+00
I-133	7.11E+02	2.22E+02	2.07E+03	0.00E+00	0.00E+00	3.75E+01	7.16E-02	5.84E-02	0.00E+00	0.00E+00
I-134	7.96E+02	2.49E+02	2.32E+03	0.00E+00	0.00E+00	2.57E-01	3.26E-01	7.04E-02	0.00E+00	0.00E+00

I-135	6.24E+02	1.95E+02	1.82E+03	0.00E+00	0.00E+00	5.67E+00	2.35E-01	3.74E-02	0.00E+00	0.00E+00	0.00E+00
<b>PARTICULATE</b>											
I-131	2.20E+01	6.88E+00	6.40E+01	0.00E+00	0.00E+00	7.09E+00	1.72E-03	8.41E-04	0.00E+00	0.00E+00	0.00E+00
I-132	3.07E+01	9.62E+00	8.96E+01	0.00E+00	0.00E+00	5.68E-02	1.56E-02	2.68E-03	0.00E+00	0.00E+00	0.00E+00
I-133	3.90E+01	1.22E+01	1.14E+02	0.00E+00	0.00E+00	2.06E+00	3.93E-03	3.21E-03	0.00E+00	0.00E+00	0.00E+00
I-134	4.37E+01	1.37E+01	1.27E+02	0.00E+00	0.00E+00	1.41E-02	1.79E-02	3.87E-03	0.00E+00	0.00E+00	0.00E+00
I-135	3.43E+01	1.07E+01	9.99E+01	0.00E+00	0.00E+00	3.12E-01	1.29E-02	2.05E-03	0.00E+00	0.00E+00	0.00E+00
<b>ORGANIC</b>											
I-131	1.76E+01	5.50E+00	5.12E+01	0.00E+00	0.00E+00	5.67E+00	1.38E-03	6.73E-04	0.00E+00	0.00E+00	0.00E+00
I-132	2.46E+01	7.70E+00	7.17E+01	0.00E+00	0.00E+00	4.54E-02	1.25E-02	2.14E-03	0.00E+00	0.00E+00	0.00E+00
I-133	3.12E+01	9.77E+00	9.10E+01	0.00E+00	0.00E+00	1.65E+00	3.15E-03	2.57E-03	0.00E+00	0.00E+00	0.00E+00
I-134	3.50E+01	1.09E+01	1.02E+02	0.00E+00	0.00E+00	1.13E-02	1.43E-02	3.09E-03	0.00E+00	0.00E+00	0.00E+00
I-135	2.74E+01	8.59E+00	8.00E+01	0.00E+00	0.00E+00	2.49E-01	1.03E-02	1.64E-03	0.00E+00	0.00E+00	0.00E+00
<b>NOBLE GASES</b>											
XE-131M	3.72E+02	1.16E+02	1.08E+03	0.00E+00	0.00E+00	0.00E+00	1.73E-03	9.75E-03	0.00E+00	0.00E+00	0.00E+00
XE-133M	1.93E+03	6.03E+02	5.61E+03	0.00E+00	0.00E+00	0.00E+00	1.34E-02	5.80E-02	0.00E+00	0.00E+00	0.00E+00
XE-133	7.88E+04	2.47E+04	2.30E+05	0.00E+00	0.00E+00	0.00E+00	4.99E-01	2.24E+00	0.00E+00	0.00E+00	0.00E+00
XE-135M	2.09E+04	6.55E+03	6.11E+04	0.00E+00	0.00E+00	0.00E+00	1.01E+00	1.22E+00	0.00E+00	0.00E+00	0.00E+00
XE-135	1.95E+04	6.11E+03	5.69E+04	0.00E+00	0.00E+00	0.00E+00	4.54E+01	1.16E+01	0.00E+00	0.00E+00	0.00E+00
XE-138	7.47E+04	2.34E+04	2.18E+05	0.00E+00	0.00E+00	0.00E+00	2.10E-03	1.31E-02	0.00E+00	0.00E+00	0.00E+00
KR-83M	1.98E+03	6.21E+02	5.78E+03	0.00E+00	0.00E+00	0.00E+00	2.50E-01	3.44E-01	0.00E+00	0.00E+00	0.00E+00
KR-85M	7.59E+03	2.38E+03	2.21E+04	0.00E+00	0.00E+00	0.00E+00	4.80E-04	4.69E-02	0.00E+00	0.00E+00	0.00E+00
KR-85	1.08E+03	3.38E+02	3.15E+03	0.00E+00	0.00E+00	0.00E+00	2.91E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
KR-87	1.43E+04	4.46E+03	4.15E+04	0.00E+00	0.00E+00	0.00E+00	7.78E+00	1.40E+00	0.00E+00	0.00E+00	0.00E+00
KR-88	2.11E+04	6.61E+03	6.15E+04	0.00E+00	0.00E+00	0.00E+00	1.91E+02	6.20E+01	2.05E+01	0.00E+00	0.00E+00

1 QDC CRDA, EAB, ALL REL GLAND: SIEMENS 60 GWD/MTU: 0 - 2 h

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO

## SPRAYED VOL

AT .500 HOURS:	X/Q(SITE)= .29E-03 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM INTAKE=
.0 CFM			
X/Q CONT ROOM= .00E+00 SEC/M3	SEC RELEASE RATE= .86E+05 VOL/DAY	PCT PRI LKG TO ATM =	
00.00			

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM (CURIES) (UCI/CM3)	SITE BOUNDARY DOSES (REM)	FILTER NON-REMOVAL FACTORS					
	ELEMENTAL	PRIMARY	SECONDARY	RELEASE	THYROID	WH BODY	BETA	CONTROL ROOM DOSES (REM)	THYROID	WH BODY	BETA
I-131	1.75E-07	2.13E-09	5.25E+02	0.00E+00	0.00E+00	5.81E+01	1.41E-02	6.90E-03	0.00E+00	0.00E+00	0.00E+00
I-132	2.12E-07	2.57E-09	7.31E+02	0.00E+00	0.00E+00	4.63E-01	1.27E-01	2.18E-02	0.00E+00	0.00E+00	0.00E+00
I-133	3.07E-07	3.73E-09	9.32E+02	0.00E+00	0.00E+00	1.69E+01	3.22E-02	2.63E-02	0.00E+00	0.00E+00	0.00E+00
I-134	2.35E-07	2.85E-09	1.03E+03	0.00E+00	0.00E+00	1.14E-01	1.45E-01	3.13E-02	0.00E+00	0.00E+00	0.00E+00
I-135	2.61E-07	3.17E-09	8.18E+02	0.00E+00	0.00E+00	2.55E+00	1.06E-01	1.68E-02	0.00E+00	0.00E+00	0.00E+00
<b>PARTICULATE</b>											
I-131	9.64E-09	1.17E-10	2.89E+01	0.00E+00	0.00E+00	3.19E+00	7.76E-04	3.79E-04	0.00E+00	0.00E+00	0.00E+00
I-132	1.16E-08	1.41E-10	4.02E+01	0.00E+00	0.00E+00	2.55E-02	6.99E-03	1.20E-03	0.00E+00	0.00E+00	0.00E+00
I-133	1.69E-08	2.05E-10	5.12E+01	0.00E+00	0.00E+00	9.28E-01	1.77E-03	1.45E-03	0.00E+00	0.00E+00	0.00E+00
I-134	1.29E-08	1.57E-10	5.66E+01	0.00E+00	0.00E+00	6.26E-03	7.96E-03	1.72E-03	0.00E+00	0.00E+00	0.00E+00
I-135	1.43E-08	1.74E-10	4.50E+01	0.00E+00	0.00E+00	1.40E-01	5.80E-03	9.24E-04	0.00E+00	0.00E+00	0.00E+00
<b>ORGANIC</b>											
I-131	7.71E-09	9.37E-11	2.31E+01	0.00E+00	0.00E+00	2.55E+00	6.21E-04	3.03E-04	0.00E+00	0.00E+00	0.00E+00
I-132	9.30E-09	1.13E-10	3.21E+01	0.00E+00	0.00E+00	2.04E-02	5.59E-03	9.60E-04	0.00E+00	0.00E+00	0.00E+00
I-133	1.35E-08	1.64E-10	4.10E+01	0.00E+00	0.00E+00	7.42E-01	1.42E-03	1.16E-03	0.00E+00	0.00E+00	0.00E+00
I-134	1.03E-08	1.25E-10	4.53E+01	0.00E+00	0.00E+00	5.01E-03	6.36E-03	1.37E-03	0.00E+00	0.00E+00	0.00E+00
I-135	1.15E-08	1.39E-10	3.60E+01	0.00E+00	0.00E+00	1.12E-01	4.64E-03	7.39E-04	0.00E+00	0.00E+00	0.00E+00
<b>NOBLE GASES</b>											
XE-131M	1.63E-07	1.98E-09	4.88E+02	0.00E+00	0.00E+00	0.00E+00	7.78E-04	4.39E-03	0.00E+00	0.00E+00	0.00E+00
XE-133M	8.41E-07	1.02E-08	2.53E-03	0.00E+00	0.00E+00	0.00E+00	6.05E-03	2.61E-02	0.00E+00	0.00E+00	0.00E+00
XE-133	3.45E-05	4.20E-07	1.03E-05	0.00E+00	0.00E+00	0.00E+00	2.25E-01	1.01E+00	0.00E+00	0.00E+00	0.00E+00
XE-135M	2.44E-06	2.96E-08	2.63E-04	0.00E+00	0.00E+00	0.00E+00	8.03E-01	1.70E-01	0.00E+00	0.00E+00	0.00E+00
XE-135	8.26E-06	1.00E-07	2.56E-04	0.00E+00	0.00E+00	0.00E+00	4.56E-01	5.50E-01	0.00E+00	0.00E+00	0.00E+00
XE-138	1.00E-05	1.22E-07	9.41E-04	0.00E+00	0.00E+00	0.00E+00	1.95E+01	5.02E+00	0.00E+00	0.00E+00	0.00E+00
KR-83M	7.25E-07	8.81E-09	2.59E+03	0.00E+00	0.00E+00	0.00E+00	9.38E-04	5.87E-03	0.00E+00	0.00E+00	0.00E+00
KR-85M	3.08E-06	3.75E-08	9.94E+03	0.00E+00	0.00E+00	0.00E+00	1.12E-01	1.55E-01	0.00E+00	0.00E+00	0.00E+00
KR-85	4.75E-07	5.77E-09	1.42E+03	0.00E+00	0.00E+00	0.00E+00	2.16E-04	2.11E-02	0.00E+00	0.00E+00	0.00E+00
KR-87	4.77E-06	5.80E-08	1.85E+04	0.00E+00	0.00E+00	0.00E+00	1.85E+00	1.30E+00	0.00E+00	0.00E+00	0.00E+00
KR-88	8.20E-06	9.97E-08	2.76E+04	0.00E+00	0.00E+00	0.00E+00	3.49E+00	6.28E-01	0.00E+00	0.00E+00	0.00E+00

8.59E+01 2.70E+01 9.00E+00 0.00E+00 0.00E+00 0.00E+00

1

QDC CRDA, EAB, ALL REL GLAND: SIEMENS 60 GWD/MTU: 0 - 2 h

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
 1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO  
 SPRAYED VOL

AT .0 CFM	2.000 HOURS: X/Q(SITE)= .23E-04 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM INTAKE=
	X/Q CONT ROOM= .00E+00 SEC/M3	SEC RELEASE RATE= .86E+05 VOL/DAY	PCT PRI LKG TO ATM =
00.00			

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM			SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA	
	ELEMENTAL	PARTICULATE	ORGANIC									
I-131	1.19E-35	1.45E-37	1.78E-07	0.00E+00	0.00E+00	1.56E-09	3.79E-13	1.85E-13	0.00E+00	0.00E+00	0.00E+00	
I-132	9.19E-36	1.12E-37	2.13E-07	0.00E+00	0.00E+00	1.07E-11	2.93E-12	5.04E-13	0.00E+00	0.00E+00	0.00E+00	
I-133	2.00E-35	2.43E-37	3.11E-07	0.00E+00	0.00E+00	4.46E-10	8.52E-13	6.95E-13	0.00E+00	0.00E+00	0.00E+00	
I-134	4.83E-36	5.87E-38	2.33E-07	0.00E+00	0.00E+00	2.05E-12	2.60E-12	5.61E-13	0.00E+00	0.00E+00	0.00E+00	
I-135	1.52E-35	1.85E-37	2.63E-07	0.00E+00	0.00E+00	6.51E-11	2.69E-12	4.29E-13	0.00E+00	0.00E+00	0.00E+00	
PARTICULATE												
I-131	6.54E-37	7.96E-39	9.75E-09	0.00E+00	0.00E+00	8.56E-11	2.08E-14	1.02E-14	0.00E+00	0.00E+00	0.00E+00	
I-132	5.05E-37	6.14E-39	1.17E-08	0.00E+00	0.00E+00	5.87E-13	1.61E-13	2.77E-14	0.00E+00	0.00E+00	0.00E+00	
I-133	1.10E-36	1.33E-38	1.71E-08	0.00E+00	0.00E+00	2.45E-11	4.68E-14	3.82E-14	0.00E+00	0.00E+00	0.00E+00	
I-134	2.66E-37	3.23E-39	1.28E-08	0.00E+00	0.00E+00	1.13E-13	1.43E-13	3.08E-14	0.00E+00	0.00E+00	0.00E+00	
I-135	8.37E-37	1.02E-38	1.45E-08	0.00E+00	0.00E+00	3.58E-12	1.48E-13	2.35E-14	0.00E+00	0.00E+00	0.00E+00	
ORGANIC												
I-131	5.24E-37	6.36E-39	7.80E-09	0.00E+00	0.00E+00	6.85E-11	1.66E-14	8.13E-15	0.00E+00	0.00E+00	0.00E+00	
I-132	4.04E-37	4.91E-39	9.35E-09	0.00E+00	0.00E+00	4.70E-13	1.29E-13	2.22E-14	0.00E+00	0.00E+00	0.00E+00	
I-133	8.77E-37	1.07E-38	1.37E-08	0.00E+00	0.00E+00	1.96E-11	3.74E-14	3.05E-14	0.00E+00	0.00E+00	0.00E+00	
I-134	2.12E-37	2.58E-39	1.03E-08	0.00E+00	0.00E+00	9.00E-14	1.14E-13	2.47E-14	0.00E+00	0.00E+00	0.00E+00	
I-135	6.70E-37	8.14E-39	1.16E-08	0.00E+00	0.00E+00	2.86E-12	1.18E-13	1.88E-14	0.00E+00	0.00E+00	0.00E+00	
NOBLE GASES												
XE-131M	1.11E-35	1.35E-37	1.65E-07	0.00E+00	0.00E+00	0.00E+00	2.09E-14	1.18E-13	0.00E+00	0.00E+00	0.00E+00	
XE-133M	5.63E-35	6.85E-37	8.51E-07	0.00E+00	0.00E+00	0.00E+00	1.61E-13	6.98E-13	0.00E+00	0.00E+00	0.00E+00	
XE-133	2.34E-33	2.84E-35	3.49E-05	0.00E+00	0.00E+00	0.00E+00	6.03E-12	2.70E-11	0.00E+00	0.00E+00	0.00E+00	
XE-135M	3.06E-36	3.72E-38	2.33E-06	0.00E+00	0.00E+00	0.00E+00	5.64E-12	1.19E-12	0.00E+00	0.00E+00	0.00E+00	
XE-135	5.03E-34	6.11E-36	8.34E-06	0.00E+00	0.00E+00	0.00E+00	1.18E-11	1.42E-11	0.00E+00	0.00E+00	0.00E+00	
XE-138	1.94E-35	2.36E-37	9.64E-06	0.00E+00	0.00E+00	0.00E+00	1.59E-10	4.08E-11	0.00E+00	0.00E+00	0.00E+00	
KR-83M	2.84E-35	3.45E-37	7.27E-07	0.00E+00	0.00E+00	0.00E+00	2.09E-14	1.31E-13	0.00E+00	0.00E+00	0.00E+00	
KR-85M	1.66E-34	2.02E-36	3.11E-06	0.00E+00	0.00E+00	0.00E+00	2.79E-12	3.83E-12	0.00E+00	0.00E+00	0.00E+00	
KR-85	3.24E-35	3.94E-37	4.81E-07	0.00E+00	0.00E+00	0.00E+00	5.81E-15	5.67E-13	0.00E+00	0.00E+00	0.00E+00	
KR-87	1.43E-34	1.74E-36	4.77E-06	0.00E+00	0.00E+00	0.00E+00	3.77E-11	2.65E-11	0.00E+00	0.00E+00	0.00E+00	
KR-88	3.86E-34	4.69E-36	8.25E-06	0.00E+00	0.00E+00	0.00E+00	8.27E-11	1.49E-11	0.00E+00	0.00E+00	0.00E+00	
							2.29E-09	3.16E-10	1.32E-10	0.00E+00	0.00E+00	0.00E+00
TOTAL DOSES 0-30 DAYS				2.76E+02	8.90E+01	2.95E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	

1

QDC CRDA, EAB, ALL REL GLAND: SIEMENS 60 GWD/MTU: 0 - 2 h

ISOTOPE	ACTIVITY RELEASED (CURIES)	
	2. HRS	
ELEMENTAL		
I-131	1.69E+03	1.69E+03
I-132	2.36E+03	2.36E+03
I-133	3.00E+03	3.00E+03
I-134	3.35E+03	3.35E+03
I-135	2.64E+03	2.64E+03
PARTICULATE		
I-131	9.29E+01	9.29E+01
I-132	1.30E+02	1.30E+02
I-133	1.65E+02	1.65E+02
I-134	1.84E+02	1.84E+02
I-135	1.45E+02	1.45E+02
ORGANIC		
I-131	7.43E+01	7.43E+01
I-132	1.04E+02	1.04E+02
I-133	1.32E+02	1.32E+02
I-134	1.47E+02	1.47E+02
I-135	1.16E+02	1.16E+02
NOBLE GASES		
XE-131M	1.57E+03	1.57E+03

XE-133M	8.14E+03	8.14E+03
XE-133	3.33E+05	3.33E+05
XE-135M	8.74E+04	8.74E+04
XE-135	8.25E+04	8.25E+04
XE-138	3.12E+05	3.12E+05
KR-83M	8.37E+03	8.37E+03
KR-85M	3.21E+04	3.21E+04
KR-85	4.57E+03	4.57E+03
KR-87	6.01E+04	6.01E+04
KR-88	8.92E+04	8.92E+04

END EXECUTION DATE: 11/18/1999  
END EXECUTION TIME: 19:00:31.28

AXIDENT VER 2 MOD 4  
PRODUCTION DATE 02/18/92  
BEGIN EXECUTION DATE: 10/22/1999  
BEGIN EXECUTION TIME: 15:47:55.29

1 QDC TID-14844 SOURCE TERM  
2 1 2 1.0 1.0  
3 2561 2.60+6 1.845+5 5.83+4  
4 0.0 0.0 0.0 1.0 1.0 2.78+5 0.0  
5 1.  
6 1.  
7 1.  
8 1.  
9 1.  
10 0.  
11 0.  
12 0.  
13 0.  
14 0.  
15 0.  
16 0.  
17 0.  
18 0.  
19 0.  
20 0.  
21 6\*.1.  
22 3\*.1.

## QDC TID-14844 SOURCE TERM

## INITIAL CONTAINMENT INVENTORY

## ISOTOPE ACTIVITY (CURIES)

I-131	6.446E+07
I-132	9.592E+07
I-133	1.482E+08
I-134	1.728E+08
I-135	1.373E+08
XE-131M	4.874E+05
XE-133M	3.766E+06
XE-133	1.482E+08
XE-135M	3.987E+07
XE-135	1.396E+08
XE-138	1.307E+08
KR-83M	1.152E+07
KR-85M	2.880E+07
KR-85	9.665E+05
KR-87	5.538E+07
KR-88	7.886E+07

AIXDENT VER 2 MOD 4  
 PRODUCTION DATE 02/18/92  
 BEGIN EXECUTION DATE: 11/18/1999  
 BEGIN EXECUTION TIME: 16:55:44.00

```

1 QDC CRDA, CR & LPZ, ALL REL MVP: TID-14844: 0 - 6 s
2 2 2 1. 1.
3 -2561 2.60+6 1.845+5 5.83+4
4 0. 0. 0. 1. 1. 2.78+5 0.
5 6 2.592E6
6 0.2402 0.
7 9.058E-4 0.
8 2*1.
9 2*2460
10 3.2E-5 0.
11 7.00E-4 0.
12 2*0.
13 2*0.
14 2*0.
15 2*0.
16 2*0.
17 2*0.
18 2*0.
19 2*0.
20 2*0.
21 6*1.
22 3*1.
23 7.16E+3      1.06E+4   1.65E+4   1.92E+4   1.52E+4   1.36E+3   1.05E+4   4.13E+5
24 1.11E+5      3.89E+5   3.65E+5   3.21E+4   8.04E+4   2.70E+3   1.55E+5   2.20E+5

```

1

QDC CRDA, CR &amp; LPZ, ALL REL MVP: TID-14844: 0 - 6 s

## INITIAL CONTAINMENT INVENTORY

ISOTOPE	ACTIVITY (CURIES)
I-131	7.160E+03
I-132	1.060E+04
I-133	1.650E+04
I-134	1.920E+04
I-135	1.520E+04
XE-131M	1.360E+03
XE-133M	1.050E+04
XE-133	4.130E+05
XE-135M	1.110E+05
XE-135	3.890E+05
XE-138	3.650E+05
KR-83M	3.210E+04
KR-85M	8.040E+04
KR-85	2.700E+03
KR-87	1.550E+05
KR-88	2.200E+05

1 QDC CRDA, CR &amp; LPZ, ALL REL MVP: TID-14844: 0 - 6 s

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

VOL	1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL,	1. CFM MIXING, 00.00 PCT REL TO SPRAYED
-----	--	---

AT .002 HOURS:	X/Q(SITE)= .32E-04 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM INTAKE=2460.0
----------------	---------------------------	-------------------------------------	----------------------------

CFM	X/Q CONT ROOM= .70E-03 SEC/M3	SEC RELEASE RATE= .78E+02 VOL/DAY	PCT PRI LKG TO ATM =
-----	-------------------------------	-----------------------------------	----------------------

	CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS	
	SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)	CONTROL ROOM (CURIES)	SITE BOUNDARY DOSES (REM)	CONTROL ROOM DOSES (REM)
	PRIMARY SECONDARY RELEASE	(UCI/CM3)	THYROID WH BODY BETA	THYROID WH BODY BETA
ELEMENTAL				
I-131	3.85E+02 1.24E+03 4.16E+00	3.38E-03 6.46E-07 6.83E-02	1.23E-05 6.02E-06 7.36E-04	4.74E-09 6.49E-08
I-132	5.70E+02 1.83E+03 6.15E+00	4.99E-03 9.56E-07 3.65E-03	1.18E-04 2.03E-05 3.93E-05	3.93E-08 2.18E-07
I-133	8.88E+02 2.86E+03 9.58E+00	7.78E-03 1.49E-06 4.25E-02	3.65E-05 2.98E-05 4.58E-04	1.76E-08 3.21E-07

I-134	1.03E+03	3.32E+03	1.11E+01	9.04E-03	1.73E-06	3.09E-03	1.73E-04	3.73E-05	3.33E-05	7.64E-08	4.02E-07
I-135	8.18E+02	2.63E+03	8.82E+00	7.16E-03	1.37E-06	1.21E-02	1.26E-04	2.00E-05	1.31E-04	3.29E-08	2.15E-07
<b>PARTICULATE</b>											
I-131	2.12E+01	6.81E+01	2.28E-01	1.85E-04	3.55E-08	3.75E-03	6.78E-07	3.31E-07	4.04E-05	2.61E-10	3.57E-09
I-132	3.13E+01	1.01E+02	3.38E-01	2.74E-04	5.25E-08	2.01E-04	6.49E-06	1.11E-06	2.16E-06	2.16E-09	1.20E-08
I-133	4.88E+01	1.57E+02	5.26E-01	4.27E-04	8.18E-08	2.34E-03	2.01E-06	1.64E-06	2.52E-05	9.68E-10	1.76E-08
I-134	5.67E+01	1.82E+02	6.12E-01	4.97E-04	9.51E-08	1.70E-04	9.49E-06	2.05E-06	1.83E-06	4.20E-09	2.21E-08
I-135	4.50E+01	1.45E+02	4.85E-01	3.94E-04	7.53E-08	6.67E-04	6.90E-06	1.10E-06	7.19E-06	1.81E-09	1.18E-08
<b>ORGANIC</b>											
I-131	1.69E+01	5.45E+01	1.83E-01	1.48E-04	2.84E-08	3.00E-03	5.42E-07	2.65E-07	3.23E-05	2.08E-10	2.85E-09
I-132	2.51E+01	8.06E+01	2.70E-01	2.20E-04	4.20E-08	1.61E-04	5.19E-06	8.91E-07	1.73E-06	1.73E-09	9.60E-09
I-133	3.90E+01	1.26E+02	4.21E-01	3.42E-04	6.54E-08	1.87E-03	1.61E-06	1.31E-06	2.01E-05	7.74E-10	1.41E-08
I-134	4.54E+01	1.46E+02	4.89E-01	3.97E-04	7.61E-08	1.36E-04	7.59E-06	1.64E-06	1.46E-06	3.36E-09	1.76E-08
I-135	3.60E+01	1.16E+02	3.88E-01	3.15E-04	6.03E-08	5.34E-04	5.52E-06	8.79E-07	5.75E-06	1.45E-09	9.47E-09
<b>NOBLE GASES</b>											
XE-131M	3.22E+02	1.03E+03	3.47E+00	2.82E-03	5.39E-07	0.00E+00	6.11E-07	3.45E-06	0.00E+00	1.03E-09	3.71E-08
XE-133M	2.48E+03	7.99E+03	2.68E+01	2.18E-02	4.15E-06	0.00E+00	7.07E-06	3.06E-05	0.00E+00	3.50E-09	3.29E-07
XE-133	9.77E+04	3.14E+05	1.05E+03	8.56E-01	1.64E-04	0.00E+00	2.53E-04	1.13E-03	0.00E+00	3.08E-07	1.22E-05
XE-135M	2.62E+04	8.41E+04	2.82E+02	2.29E-01	4.38E-05	0.00E+00	9.53E-04	2.02E-04	0.00E+00	3.77E-07	2.17E-06
XE-135	9.20E+04	2.96E+05	9.92E+02	8.06E-01	1.54E-04	0.00E+00	1.95E-03	2.35E-03	0.00E+00	7.51E-07	2.53E-05
XE-138	8.60E+04	2.77E+05	9.29E+02	7.53E-01	1.44E-04	0.00E+00	2.13E-02	5.47E-03	0.00E+00	2.18E-06	5.89E-05
KR-83M	7.59E+03	2.44E+04	8.19E+01	6.65E-02	1.27E-05	0.00E+00	3.27E-06	2.05E-05	0.00E+00	1.93E-08	2.21E-07
KR-85M	1.90E+04	6.12E+04	2.05E+02	1.67E-01	3.19E-05	0.00E+00	2.56E-04	3.52E-04	0.00E+00	1.06E-07	3.79E-06
KR-85	6.39E+02	2.05E+03	6.89E+00	5.59E-03	1.07E-06	0.00E+00	1.16E-07	1.13E-05	0.00E+00	4.55E-11	1.22E-07
KR-87	3.66E+04	1.18E+05	3.95E+02	3.21E-01	6.14E-05	0.00E+00	4.35E-03	3.05E-03	0.00E+00	8.34E-07	3.29E-05
KR-88	5.20E+04	1.67E+05	5.61E+02	4.56E-01	8.72E-05	0.00E+00	7.82E-03	1.41E-03	0.00E+00	2.58E-06	1.52E-05
										-----	-----
										1.43E-01	3.74E-02
										1.42E-02	1.54E-03
										7.34E-06	1.52E-04

1

QDC CRDA, CR &amp; LPZ, ALL REL MVP: TID-14844: 0 - 6 s

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
 1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO SPRAYED

VOL

AT 720.000 HOURS: X/Q(SITE)= .00E+00 SEC/M3 PRIMARY LEAK RATE= .000 PERCENT/DAY CONTROL ROOM INTAKE=2460.0  
 CFM X/Q CONT ROOM= .00E+00 SEC/M3 SEC RELEASE RATE= .00E+00 VOL/DAY PCT PRI LKG TO ATM =  
 00.00

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM (CURIES) (UCI/CM3)		SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
	ELEMENTAL	PRIMARY	SECONDARY	RELEASE	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA	
I-131	2.91E+01	9.35E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.49E+00	9.58E-06	1.31E-04
I-132	3.44E-92	1.10E-91	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.80E-02	5.79E-05	3.22E-04
I-133	4.23E-08	1.36E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.93E-01	3.43E-05	6.26E-04
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.38E-02	7.75E-05	4.08E-04
I-135	4.03E-30	1.30E-29	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.35E-01	5.91E-05	3.87E-04
<b>PARTICULATE</b>											
I-131	1.60E+00	5.14E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.17E-02	5.26E-07	7.21E-06
I-132	1.89E-93	6.07E-93	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.19E-03	3.18E-06	1.77E-05
I-133	2.32E-09	7.47E-09	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.91E-02	1.89E-06	3.44E-05
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.86E-03	4.26E-06	2.24E-05
I-135	2.22E-31	7.12E-31	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.29E-02	3.25E-06	2.13E-05
<b>ORGANIC</b>											
I-131	1.28E+00	4.11E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.53E-02	4.21E-07	5.76E-06
I-132	1.51E-93	4.86E-93	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.55E-03	2.55E-06	1.42E-05
I-133	1.86E-09	5.97E-09	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.93E-02	1.51E-06	2.75E-05
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.49E-03	3.41E-06	1.79E-05
I-135	1.77E-31	5.70E-31	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.03E-02	2.60E-06	1.70E-05
<b>NOBLE GASES</b>											
XE-131M	5.54E+01	1.78E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.08E-06	7.51E-05
XE-133M	2.51E-01	8.05E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.00E-06	6.58E-04
XE-133	1.90E+03	6.11E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.22E-04	2.46E-02
XE-135M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.76E-04	1.02E-03
XE-135	1.63E-19	5.24E-19	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.39E-03	4.70E-02
XE-138	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.11E-03	3.01E-02
KR-83M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.67E-05	3.06E-04
KR-85M	9.42E-46	3.03E-45	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.80E-04	6.42E-03
KR-85	6.36E+02	2.04E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.25E-08	2.47E-04
KR-87	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.01E-03	3.96E-02
KR-88	1.86E-73	5.97E-73	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.00E-03	2.35E-02

QDC 9400-M-0550 Rev. 0

## Attachment B

	0.00E+00	0.00E+00	0.00E+00	2.97E+00	8.78E-03	1.76E-01
TOTAL DOSES 0-30 DAYS	1.43E-01	3.74E-02	1.42E-02	2.98E+00	8.79E-03	1.76E-01

1

QDC CRDA, CR &amp; LPZ, ALL REL MVP: TID-14844: 0 - 6 s

## ACTIVITY RELEASED (CURIES)

ISOTOPE	0. HRS	720. HRS
ELEMENTAL		
I-131	4.16E+00	0.00E+00
I-132	6.15E+00	0.00E+00
I-133	9.58E+00	0.00E+00
I-134	1.11E+01	0.00E+00
I-135	8.82E+00	0.00E+00
PARTICULATE		
I-131	2.28E-01	0.00E+00
I-132	3.38E-01	0.00E+00
I-133	5.26E-01	0.00E+00
I-134	6.12E-01	0.00E+00
I-135	4.85E-01	0.00E+00
ORGANIC		
I-131	1.83E-01	0.00E+00
I-132	2.70E-01	0.00E+00
I-133	4.21E-01	0.00E+00
I-134	4.89E-01	0.00E+00
I-135	3.88E-01	0.00E+00
NOBLE GASES		
XE-131M	3.47E+00	0.00E+00
XE-133M	2.68E+01	0.00E+00
XE-133	1.05E+03	0.00E+00
XE-135M	2.82E+02	0.00E+00
XE-135	9.92E+02	0.00E+00
XE-138	9.29E+02	0.00E+00
KR-83M	8.19E+01	0.00E+00
KR-85M	2.05E+02	0.00E+00
KR-85	6.89E+00	0.00E+00
KR-87	3.95E+02	0.00E+00
KR-88	5.61E+02	0.00E+00

END EXECUTION DATE: 11/18/1999  
 END EXECUTION TIME: 16:55:44.44

AXIDENT VER 2 MOD 4  
PRODUCTION DATE 02/18/92  
BEGIN EXECUTION DATE: 11/18/1999  
BEGIN EXECUTION TIME: 16:55:51.86

```

1 QDC CRDA, CR & LPZ, ALL REL AOG: TID-14844: 6 s - 30 d
2 6 2 1. 1.
3 -2561 2.60+6 1.845+5 5.83+4
4 0. 0. 0. 1. 1. 2.78+5 0.
5 6 1800 7200 2.88+4 8.64+4 2.592E6
6 0.2402 4*1.201E-2 0.
7 9.058E-4 4*1.157E-5 0.
8 6*1.
9 6*2460
10 0. 3.2E-5 2*9.0E-6 3.0E-6 0.
11 0. 2*7.00E-4 6.45E-6 3.81E-6 0.
12 6*0.
13 6*0.
14 6*0.
15 6*0.
16 6*0.
17 6*0.
18 6*0.
19 6*0.
20 6*0.
21 3*0. 3*1.
22 3*1.
23 7.16E+3 1.06E+4 1.65E+4 1.92E+4 1.52E+4 1.36E+3 1.05E+4 4.13E+5
24 1.11E+5 3.89E+5 3.65E+5 3.21E+4 8.04E+4 2.70E+3 1.55E+5 2.20E+5

```

1

OPC CRDA CB & LPZ. ALL REL AOG: TID-14844: 6 s - 30 d

#### INITIAL CONTAINMENT INVENTORY

**ISOTOPE ACTIVITY (CURIES)**

I-131	7.160E+03
I-132	1.060E+04
I-133	1.650E+04
I-134	1.920E+04
I-135	1.520E+04
XE-131M	1.360E+03
XE-133M	1.050E+04
XE-133	4.130E+05
XE-135M	1.110E+05
XE-135	3.890E+05
XE-138	3.650E+05
KR-83M	3.210E+04
KR-85M	8.040E+04
KR-85	2.700E+03
KR-87	1.550E+05
KR-88	2.200E+05

四

ODC CRDA, CR & LPZ, ALL REL AOG: TID-14844: 6 s - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

AT .002 HOURS: X/Q(SITE)= .00E+00 SEC/M3 PRIMARY LEAK RATE=\*\*\*\*\* PERCENT/DAY CONTROL ROOM INTAKE=2460.0  
 CFM  
 X/Q CONT ROOM= .00E+00 SEC/M3 SEC RELEASE RATE= .78E+02 VOL/DAY PCT PRI LKG TO ATM =  
 00.00

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS	
	SPRAY	PRIMARY	SECONDARY	CONT	CENTER
ELEMENTAL	.000	.000	.000	.000	.000
PARTICULATE	.000	.000	.000	.000	.000
ORGANIC	.000	.000	.000	.000	.000

ACTIVITY (CURIES)		CONTROL ROOM	SITE BOUNDARY DOSES (REM)	CONTROL ROOM DOSES (REM)
ISOTOPES	PRIMARY SECONDARY RELEASE	(CURIES) (UCI/CM3)	THYROID WH BODY BETA	THYROID WH BODY BETA

I-133	8.88E+02	2.86E+03	0.00E+00								
I-134	1.03E+03	3.32E+03	0.00E+00								
I-135	8.18E+02	2.63E+03	0.00E+00								
PARTICULATE											
I-131	2.12E+01	6.81E+01	0.00E+00								
I-132	3.13E+01	1.01E+02	0.00E+00								
I-133	4.88E+01	1.57E+02	0.00E+00								
I-134	5.67E+01	1.82E+02	0.00E+00								
I-135	4.50E+01	1.45E+02	0.00E+00								
ORGANIC											
I-131	1.69E+01	5.45E+01	0.00E+00								
I-132	2.51E+01	8.06E+01	0.00E+00								
I-133	3.90E+01	1.26E+02	0.00E+00								
I-134	4.54E+01	1.46E+02	0.00E+00								
I-135	3.60E+01	1.16E+02	0.00E+00								
NOBLE GASES											
XE-131M	3.22E+02	1.03E+03	3.47E+00	0.00E+00							
XE-133M	2.48E+03	7.99E+03	2.68E+01	0.00E+00							
XE-133	9.77E+04	3.14E+05	1.05E+03	0.00E+00							
XE-135M	2.62E+04	8.41E+04	2.82E+02	0.00E+00							
XE-135	9.20E+04	2.96E+05	9.92E+02	0.00E+00							
XE-138	8.60E+04	2.77E+05	9.29E+02	0.00E+00							
KR-83M	7.559E+03	2.44E+04	8.19E+01	0.00E+00							
KR-85M	1.90E+04	6.12E+04	2.05E+02	0.00E+00							
KR-85	6.39E+02	2.05E+03	6.89E+00	0.00E+00							
KR-87	3.66E+04	1.18E+05	3.95E+02	0.00E+00							
KR-88	5.20E+04	1.67E+05	5.61E+02	0.00E+00							

1 QDC CRDA, CR &amp; LPZ, ALL REL AOG: TID-14844: 6 s - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO SPRAYED VOL

AT	.500 HOURS:	X/Q(SITE)= .32E-04 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM INTAKE=2460.0
CFM				
	X/Q CONT ROOM= .70E-03 SEC/M3	SEC RELEASE RATE= .10E+01 VOL/DAY	PCT PRI LKG TO ATM =	
00.00				

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	.000	1.000
PARTICULATE	.000	.000	.000	.000	1.000
ORGANIC	.000	.000	.000	.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM (CURIES)	SITE BOUNDARY DOSES (REM)	CONTROL ROOM DOSES (REM)				
	PRIMARY	SECONDARY	RELEASE	(UCI/CM3)	THYROID WH BODY	BETA	THYROID WH BODY	BETA		
ELEMENTAL										
I-131	1.69E-07	1.59E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
I-132	2.16E-07	2.03E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
I-133	3.84E-07	3.61E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
I-134	3.04E-07	2.86E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
I-135	3.41E-07	3.21E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
PARTICULATE										
I-131	9.29E-09	8.73E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
I-132	1.18E-08	1.11E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
I-133	2.11E-08	1.98E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
I-134	1.67E-08	1.57E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
I-135	1.88E-08	1.76E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
ORGANIC										
I-131	7.43E-09	6.98E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
I-132	9.48E-09	8.91E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
I-133	1.69E-08	1.59E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
I-134	1.34E-08	1.26E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
I-135	1.50E-08	1.41E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
NOBLE GASES										
XE-131M	1.41E-07	1.33E+03	2.75E+01	1.85E-02	3.54E-06	4.85E-06	2.74E-05	0.00E+00	2.89E-06	1.04E-04
XE-133M	1.08E-06	1.02E+04	2.12E+02	1.42E-01	2.72E-05	5.60E-05	2.42E-04	0.00E+00	9.81E-06	9.22E-04
XE-133	4.28E-05	4.02E+05	8.36E+03	5.60E+00	1.07E-03	0.00E+00	2.01E-03	8.98E-03	0.00E+00	8.66E-04
XE-135M	3.05E-06	2.86E+04	1.23E+03	3.98E-01	7.63E-05	0.00E+00	4.16E-03	8.80E-04	0.00E+00	4.65E-04
XE-135	3.89E-05	3.66E+05	7.73E+03	5.09E+00	9.75E-04	0.00E+00	1.52E-02	1.83E-02	0.00E+00	2.06E-03
XE-138	1.16E-05	1.09E+05	4.30E+03	1.51E+00	2.90E-04	0.00E+00	9.87E-02	2.53E-02	0.00E+00	2.92E-03
KR-83M	2.77E-06	2.61E+04	5.93E+02	3.63E-01	6.94E-05	0.00E+00	2.37E-05	1.48E-04	0.00E+00	4.80E-05
KR-85M	7.72E-06	7.26E+04	1.57E+03	1.01E+00	1.93E-04	0.00E+00	1.95E-03	2.69E-03	0.00E+00	2.83E-04
KR-85	2.81E-07	2.64E+03	5.47E+01	3.67E-02	7.03E-06	0.00E+00	9.19E-07	8.98E-05	0.00E+00	1.28E-07
KR-87	1.23E-05	1.15E+05	2.74E+03	1.60E+00	3.07E-04	0.00E+00	3.02E-02	2.12E-02	0.00E+00	1.96E-03

KR-88	2.02E-05	1.90E+05	4.19E+03	2.64E+00	5.06E-04	0.00E+00	5.84E-02	1.05E-02	0.00E+00	6.69E-03	3.93E-02
						0.00E+00	2.11E-01	8.84E-02	0.00E+00	1.53E-02	3.14E-01

1 QDC CRDA, CR & LPZ, ALL REL AOG: TID-14844: 6 s - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
 VOL

AT	2.000 HOURS:	X/Q(SITE)= .90E-05 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM INTAKE=2460.0
CFM				
00.00		X/Q CONT ROOM= .70E-03 SEC/M3	SEC RELEASE RATE= .10E+01 VOL/DAY	PCT PRI LKG TO ATM =

CLEANUP RATES (HR-1)						FILTER NON-REMOVAL FACTORS					
	SPRAY	PRIMARY	SECONDARY	CONT CENTER		RELEASE	CONT CENTER				
ELEMENTAL	.000	.000	.000	.000		.000	1.000				
PARTICULATE	.000	.000	.000	.000		.000	1.000				
ORGANIC	.000	.000	.000	.000		.000	1.000				
ISOTOPE ACTIVITY (CURIES)	PRIMARY	SECONDARY	RELEASE	CONTROL ROOM (CURIES) (UCI/CM3)	THYROID	SITE BOUNDARY DOSES (REM)	BETA	CONTROL ROOM DOSES (REM)	THYROID	WH BODY	BETA
ELEMENTAL	I-131 1.15E-35	1.48E+03	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00
I-132 9.37E-36	1.21E+03	0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00
I-133 2.49E-35	3.23E+03	0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00
I-134 6.27E-36	8.11E+02	0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00
I-135 2.00E-35	2.58E+03	0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00
PARTICULATE	I-131 6.31E-37	8.16E+01	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00
I-132 5.15E-37	6.66E+01	0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00
I-133 1.37E-36	1.77E+02	0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00
I-134 3.44E-37	4.46E+01	0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00
I-135 1.10E-36	1.42E+02	0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00
ORGANIC	I-131 5.05E-37	6.53E+01	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00
I-132 4.12E-37	5.33E+01	0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00
I-133 1.10E-36	1.42E+02	0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00
I-134 2.76E-37	3.56E+01	0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00
I-135 8.77E-37	1.13E+02	0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00	0.00E+00 0.00E+00	0.00E+00
NOBLE GASES	XE-131M 9.60E-36	1.24E+03	8.02E+01	4.32E-02 8.27E-06	0.00E+00	3.97E-06 2.24E-05	0.00E+00	2.99E-05 1.08E-03			
XE-132M 7.26E-35	9.40E+03	6.12E+02	3.27E-01	6.26E-05 0.00E+00		4.54E-05 1.96E-04	0.00E+00	1.00E-04 9.43E-03			
XE-133M 2.90E-33	3.75E+05	2.43E+04	1.30E+01	2.50E-03 0.00E+00		1.64E-03 7.34E-03	0.00E+00	8.93E-03 3.53E-01			
XE-135M 3.82E-36	4.95E+02	4.33E+02	1.72E-02	3.29E-06 0.00E+00		4.11E-04 8.70E-05	0.00E+00	5.65E-04 3.25E-03			
XE-135 2.37E-33	3.07E+05	2.10E+04	1.07E+01	2.04E-03 0.00E+00		1.16E-02 1.40E-02	0.00E+00	1.98E-02 6.67E-01			
XE-138 2.24E-35	2.89E+03	1.82E+03	1.01E-01	1.93E-05 0.00E+00		1.18E-02 3.02E-03	0.00E+00	4.27E-03 1.16E-01			
KR-83M 1.09E-34	1.40E+04	1.21E+03	4.88E-01	9.35E-05 0.00E+00		1.37E-05 8.54E-05	0.00E+00	3.46E-04 3.96E-03			
KR-85M 4.16E-34	5.38E+04	3.92E+03	1.87E+00	3.59E-04 0.00E+00		1.38E-03 1.89E-03	0.00E+00	2.51E-03 8.96E-02			
KR-85 1.92E-35	2.48E+03	1.60E+02	8.62E-02	1.65E-05 0.00E+00		7.55E-07 7.38E-05	0.00E+00	1.33E-06 3.55E-03			
KR-87 3.68E-34	4.76E+04	4.78E+03	1.66E+00	3.17E-04 0.00E+00		1.48E-02 1.04E-02	0.00E+00	1.20E-02 4.73E-01			
KR-88 9.51E-34	1.23E+05	9.63E+03	4.28E+00	8.19E-04 0.00E+00		3.78E-02 6.80E-03	0.00E+00	5.43E-02 3.19E-01			
						0.00E+00 7.94E-02	4.39E-02 0.00E+00	1.03E-01 2.04E+00			

1 QDC CRDA, CR & LPZ, ALL REL AOG: TID-14844: 6 s - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
 VOL

AT	8.000 HOURS:	X/Q(SITE)= .90E-05 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM INTAKE=2460.0
CFM				
00.00		X/Q CONT ROOM= .65E-05 SEC/M3	SEC RELEASE RATE= .10E+01 VOL/DAY	PCT PRI LKG TO ATM =

CLEANUP RATES (HR-1)						FILTER NON-REMOVAL FACTORS					
	SPRAY	PRIMARY	SECONDARY	CONT CENTER		RELEASE	CONT CENTER				
ELEMENTAL	.000	.000	.000	.000		.000	1.000				
PARTICULATE	.000	.000	.000	.000		.000	1.000				

## Attachment C

	ORGANIC	.000	.000	.000	.000	.000	1.000				
ISOTOPE	ACTIVITY (CURIES)	PRIMARY	SECONDARY	RELEASE	CONTROL ROOM (CURIES)	SITE BOUNDARY DOSES (REM)	BETA	CONTROL ROOM DOSES (REM)	THYROID	WH BODY	BETA
		(UCI/CM3)	THYROID	WH BODY				THYROID	WH BODY	BETA	
ELEMENTAL											
I-131	0.00E+00	1.13E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	0.00E+00	1.55E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	0.00E+00	2.06E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	0.00E+00	5.22E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	0.00E+00	1.08E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
PARTICULATE											
I-131	0.00E+00	6.22E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	0.00E+00	8.50E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	0.00E+00	1.13E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	0.00E+00	2.87E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	0.00E+00	5.94E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ORGANIC											
I-131	0.00E+00	4.97E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	0.00E+00	6.80E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	0.00E+00	9.06E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	0.00E+00	2.30E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	0.00E+00	4.76E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
NOBLE GASES											
XE-131M	0.00E+00	9.54E+02	2.73E+02	7.39E-04	1.41E-07	0.00E+00	1.35E-05	7.62E-05	0.00E+00	3.29E-05	1.19E-03
XE-133M	0.00E+00	6.78E+03	2.00E+03	5.25E-03	1.00E-06	0.00E+00	1.49E-04	6.43E-04	0.00E+00	1.08E-04	1.02E-02
XE-133	0.00E+00	2.83E+05	8.16E+04	2.19E-01	4.19E-05	0.00E+00	5.51E-03	2.47E-02	0.00E+00	9.77E-03	3.86E-01
XE-135M	0.00E+00	4.40E-05	7.61E+00	3.41E-11	6.53E-15	0.00E+00	7.23E-06	1.53E-06	0.00E+00	1.33E-05	7.66E-05
XE-135	0.00E+00	1.51E+05	5.50E+04	1.17E-01	2.25E-05	0.00E+00	3.04E-02	3.67E-02	0.00E+00	1.89E-02	6.39E-01
XE-138	0.00E+00	1.45E-03	4.98E+01	1.12E-09	2.15E-13	0.00E+00	3.22E-04	8.25E-05	0.00E+00	1.49E-04	4.03E-03
KR-83M	0.00E+00	1.18E+03	1.30E+03	9.15E-04	1.75E-07	0.00E+00	1.46E-05	9.14E-05	0.00E+00	2.00E-04	2.29E-03
KR-85M	0.00E+00	1.63E+04	7.85E+03	1.26E-02	2.41E-06	0.00E+00	2.75E-03	3.79E-03	0.00E+00	2.07E-03	7.40E-02
KR-85	0.00E+00	1.93E+03	5.48E+02	1.50E-03	2.86E-07	0.00E+00	2.59E-06	2.53E-04	0.00E+00	1.47E-06	3.92E-03
KR-87	0.00E+00	1.39E+03	3.27E+03	1.08E-03	2.06E-07	0.00E+00	1.01E-02	7.11E-03	0.00E+00	5.26E-03	2.08E-01
KR-88	0.00E+00	2.17E+04	1.46E+04	1.68E-02	3.22E-06	0.00E+00	5.72E-02	1.03E-02	0.00E+00	3.84E-02	2.26E-01
						0.00E+00	1.07E-01	8.37E-02	0.00E+00	7.49E-02	1.55E+00

1 QDC CRDA, CR &amp; LPZ, ALL REL AOG: TID-14844: 6 s - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO SPRAYED

VOL

AT	24.000 HOURS:	X/Q(SITE)= .30E-05 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM INTAKE=2460.0
CFM				
		X/Q CONT ROOM=.38E-05 SEC/M3	SEC RELEASE RATE=.10E+01 VOL/DAY	PCT PRI LKG TO ATM =
		00.00		

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS			
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER		
ELEMENTAL	.000	.000	.000	.000	.000	1.000	
PARTICULATE	.000	.000	.000	.000	.000	1.000	
ORGANIC	.000	.000	.000	.000	.000	1.000	
ISOTOPE ACTIVITY (CURIES)	CONTROL ROOM (CURIES)	SITE BOUNDARY DOSES (REM)	THYROID WH BODY BETA	CONTROL ROOM DOSES (REM)	THYROID WH BODY BETA		
ISOTOPE PRIMARY SECONDARY RELEASE	(UCI/CM3)	THYROID WH BODY	BETA	THYROID WH BODY	BETA		
ELEMENTAL							
I-131	0.00E+00	5.49E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	0.00E+00	6.40E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	0.00E+00	6.24E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	0.00E+00	7.50E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	0.00E+00	1.06E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
PARTICULATE							
I-131	0.00E+00	3.02E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	0.00E+00	3.52E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	0.00E+00	3.43E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	0.00E+00	4.12E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	0.00E+00	5.84E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ORGANIC							
I-131	0.00E+00	2.41E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	0.00E+00	2.82E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	0.00E+00	2.74E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	0.00E+00	3.30E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	0.00E+00	4.68E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
NOBLE GASES							
XE-131M	0.00E+00	4.71E+02	4.56E+02	1.14E-04	2.19E-08	0.00E+00	7.52E-06
						4.25E-05	0.00E+00
						1.95E-06	7.04E-05

XE-133M	0.00E+00	2.84E+03	3.02E+03	6.89E-04	1.32E-07	0.00E+00	7.46E-05	3.23E-04	0.00E+00	5.76E-06	5.41E-04
XE-133	0.00E+00	1.33E+05	1.32E+05	3.23E-02	6.18E-06	0.00E+00	2.98E-03	1.33E-02	0.00E+00	5.61E-04	2.22E-02
XE-135M	0.00E+00	6.97E-24	6.78E-07	1.69E-30	3.24E-34	0.00E+00	2.15E-13	4.54E-14	0.00E+00	2.86E-14	1.65E-13
XE-135	0.00E+00	2.31E+04	4.55E+04	5.61E-03	1.07E-06	0.00E+00	8.39E-03	1.01E-02	0.00E+00	5.40E-04	1.82E-02
XE-138	0.00E+00	2.30E-20	2.50E-05	5.59E-27	1.07E-30	0.00E+00	5.38E-11	1.38E-11	0.00E+00	1.82E-12	4.93E-11
KR-83M	0.00E+00	1.61E+00	1.19E+02	3.91E-07	7.48E-11	0.00E+00	4.47E-07	2.80E-06	0.00E+00	5.80E-07	6.64E-06
KR-85M	0.00E+00	6.71E+02	3.26E+03	1.63E-04	3.12E-08	0.00E+00	3.82E-04	5.24E-04	0.00E+00	2.90E-05	1.04E-03
KR-85	0.00E+00	9.91E+02	9.39E+02	2.41E-04	4.61E-08	0.00E+00	1.48E-06	1.44E-04	0.00E+00	8.94E-08	2.39E-04
KR-87	0.00E+00	1.13E-01	9.84E+01	2.74E-08	5.24E-12	0.00E+00	1.01E-04	7.13E-05	0.00E+00	4.74E-06	1.87E-04
KR-88	0.00E+00	2.12E+02	3.09E+03	5.14E-05	9.84E-09	0.00E+00	4.04E-03	7.27E-04	0.00E+00	2.67E-04	1.57E-03
						-----	-----	-----	-----	-----	-----
						0.00E+00	1.60E-02	2.53E-02	0.00E+00	1.41E-03	4.40E-02

1 QDC CRDA, CR &amp; LPZ, ALL REL AOG: TID-14844: 6 s - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
 1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO SPRAYED

VOL

AT 720.000 HOURS: X/Q(SITE)= .00E+00 SEC/M3 PRIMARY LEAK RATE= .000 PERCENT/DAY CONTROL ROOM INTAKE=2460.0  
 CFM X/Q CONT ROOM= .00E+00 SEC/M3 SEC RELEASE RATE= .00E+00 VOL/DAY PCT PRI LKG TO ATM =  
 00.00

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM (CURIES) (UCI/CM3)			SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA	FILTER NON-REMOVAL FACTORS		
				SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER	RELEASE	CONT CENTER	---
ELEMENTAL	0.00E+00	4.51E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-131	0.00E+00	5.33E-92	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	0.00E+00	6.56E-08	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	0.00E+00	6.26E-30	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	0.00E+00	2.48E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	0.00E+00	2.93E-93	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
PARTICULATE	0.00E+00	3.60E-09	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-131	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ORGANIC	0.00E+00	1.98E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-131	0.00E+00	2.34E-93	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	0.00E+00	3.88E-09	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	0.00E+00	2.75E-31	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
NOBLE GASES	0.00E+00	8.59E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
XE-131M	0.00E+00	3.89E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.22E-07	2.08E-05
XE-133M	0.00E+00	2.95E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.35E-05	9.28E-04
XE-135M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.30E-33	7.51E-33
XE-135	0.00E+00	2.53E-19	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.68E-06	3.27E-04
XE-138	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.25E-30	2.23E-28
KR-83M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.57E-10	1.80E-09
KR-85M	0.00E+00	1.46E-45	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.76E-07	6.28E-06
KR-85	0.00E+00	9.86E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.98E-09	1.06E-05
KR-87	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.57E-11	3.38E-09
KR-88	0.00E+00	2.88E-73	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.51E-07	2.65E-06
							0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.41E-05	1.30E-03
							0.00E+00	4.13E-01	2.41E-01	0.00E+00	1.95E-01	3.95E+00

1

QDC CRDA, CR &amp; LPZ, ALL REL AOG: TID-14844: 6 s - 30 d

ISOTOPE	ACTIVITY RELEASED (CURIES)			
	2. HRS	8. HRS	24. HRS	720. HRS
ELEMENTAL				
I-131	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00

I-135	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
PARTICULATE					
I-131	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ORGANIC					
I-131	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
NOBLE GASES					
XE-131M	1.11E+02	2.73E+02	4.56E+02	0.00E+00	8.40E+02
XE-133M	8.51E+02	2.00E+03	3.02E+03	0.00E+00	5.87E+03
XE-133	3.37E+04	8.16E+04	1.32E+05	0.00E+00	2.48E+05
XE-135M	1.95E+03	7.61E+00	6.78E-07	0.00E+00	1.96E+03
XE-135	2.97E+04	5.50E+04	4.55E+04	0.00E+00	1.30E+05
XE-138	7.05E+03	4.98E+01	2.50E-05	0.00E+00	7.10E+03
KR-83M	1.89E+03	1.30E+03	1.19E+02	0.00E+00	3.31E+03
KR-85M	5.69E+03	7.85E+03	3.26E+03	0.00E+00	1.68E+04
KR-85	2.21E+02	5.48E+02	9.39E+02	0.00E+00	1.71E+03
KR-87	7.92E+03	3.27E+03	9.84E+01	0.00E+00	1.13E+04
KR-88	1.44E+04	1.46E+04	3.09E+03	0.00E+00	3.21E+04

END EXECUTION DATE: 11/18/1999  
END EXECUTION TIME: 16:55:52.02

AXIDENT VER 2 MOD 4  
 PRODUCTION DATE 02/18/92  
 BEGIN EXECUTION DATE: 11/18/1999  
 BEGIN EXECUTION TIME: 16:56:01.91

```

1 QDC CRDA, CR & LPZ, ALL REL GLAND: TID-14844: 0 - 30 d
2 6 2 1. 1.
3 -2561 2.60+6 1.845+5 5.83+4
4 0. 0. 0. 1. 1. 2.78+5 0.
5 6 1800 7200 2.88+4 8.64+4 2.592E6
6 0.2402 4*1.201E-2 0.
7 5*1. 0.
8 6*1.
9 6*2460
10 2*3.2E-5 2*9.0E-6 3.0E-6 0.
11 3*7.00E-4 6.45E-6 3.81E-6 0.
12 6*0.
13 6*0.
14 6*0.
15 6*0.
16 6*0.
17 6*0.
18 6*0.
19 6*0.
20 6*0.
21 6*1.
22 3*1.
23 7.16E+3 1.06E+4 1.65E+4 1.92E+4 1.52E+4 1.36E+3 1.05E+4 4.13E+5
24 1.11E+5 3.89E+5 3.65E+5 3.21E+4 8.04E+4 2.70E+3 1.55E+5 2.20E+5

```

1

QDC CRDA, CR &amp; LPZ, ALL REL GLAND: TID-14844: 0 - 30 d

## INITIAL CONTAINMENT INVENTORY

## ISOTOPE ACTIVITY (CURIES)

I-131	7.160E+03
I-132	1.060E+04
I-133	1.650E+04
I-134	1.920E+04
I-135	1.520E+04
XE-131M	1.360E+03
XE-133M	1.050E+04
XE-133	4.130E+05
XE-135M	1.110E+05
XE-135	3.890E+05
XE-138	3.650E+05
KR-83M	3.210E+04
KR-85M	8.040E+04
KR-85	2.700E+03
KR-87	1.550E+05
KR-88	2.200E+05

1

QDC CRDA, CR &amp; LPZ, ALL REL GLAND: TID-14844: 0 - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

VOL	1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL,	1. CFM MIXING, 00.00 PCT REL TO SPRAYED
-----	--	---

AT .002 HOURS:	X/Q(SITE)= .32E-04 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM INTAKE=2460.0
CFM			
	X/Q CONT ROOM= .70E-03 SEC/M3	SEC RELEASE RATE= .86E+05 VOL/DAY	PCT PRI LKG TO ATM =
00.00			

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM (CURIES)	SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)			
	PRIMARY	SECONDARY	RELEASE	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA	
ELEMENTAL											
I-131	3.85E+02	1.21E+02	1.12E+03	9.12E-01	1.75E-04	1.85E+01	3.33E-03	1.63E-03	2.77E-01	1.79E-06	2.45E-05
I-132	5.70E+02	1.78E+02	1.66E+03	1.35E+00	2.58E-04	9.87E-01	3.19E-02	5.48E-03	1.48E-02	1.48E-05	8.24E-05

## **Attachment D**

QDC 9400-M-0550 Rev. 0

I-133	8.88E+02	2.78E+02	2.59E+03	2.10E+00	4.02E-04	1.15E+01	9.87E-03	8.06E-03	1.73E-01	6.64E-06	1.21E-04				
I-134	1.03E+03	3.23E+02	3.01E+03	2.44E+00	4.67E-04	8.35E-01	4.67E-02	1.01E-02	1.26E-02	2.88E-05	1.51E-04				
I-135	8.18E+02	2.56E+02	2.38E+03	1.94E+00	3.70E-04	3.28E+00	3.39E-02	5.40E-03	4.93E-02	1.24E-05	8.12E-05				
PARTICULATE															
I-131	2.12E+01	6.63E+00	6.17E+01	5.01E-02	9.59E-06	1.01E+00	1.83E-04	8.95E-05	1.52E-02	9.82E-08	1.34E-06				
I-132	3.13E+01	9.80E+00	9.13E+01	7.41E-02	1.42E-05	5.42E-02	1.75E-03	3.01E-04	8.15E-04	8.14E-07	4.53E-06				
I-133	4.88E+01	1.53E+01	1.42E+02	1.15E-01	2.21E-05	6.31E-01	5.43E-04	4.43E-04	9.49E-03	3.65E-07	6.65E-06				
I-134	5.67E+01	1.77E+01	1.65E+02	1.34E-01	2.57E-05	4.59E-02	2.56E-03	5.54E-04	6.90E-04	1.58E-06	8.32E-06				
I-135	4.50E+01	1.41E+01	1.31E+02	1.06E-01	2.04E-05	1.80E-01	1.86E-03	2.97E-04	2.71E-03	6.82E-07	4.46E-06				
ORGANIC															
I-131	1.69E+01	5.30E+00	4.94E+01	4.01E-02	7.67E-06	8.11E-01	1.46E-04	7.16E-05	1.22E-02	7.86E-08	1.08E-06				
I-132	2.51E+01	7.84E+00	7.31E+01	5.93E-02	1.14E-05	4.34E-02	1.40E-03	2.41E-04	6.52E-04	6.51E-07	3.62E-06				
I-133	3.90E+01	1.22E+01	1.14E+02	9.24E-02	1.77E-05	5.05E-01	4.34E-04	3.54E-04	7.59E-03	2.92E-07	5.32E-06				
I-134	4.54E+01	1.42E+01	1.32E+02	1.07E-01	2.05E-05	3.67E-02	2.05E-03	4.43E-04	5.52E-04	1.27E-06	6.66E-06				
I-135	3.60E+01	1.13E+01	1.05E+02	8.51E-02	1.63E-05	1.44E-01	1.49E-03	2.37E-04	2.17E-03	5.45E-07	3.57E-06				
NOBLE GASES															
XE-131M	3.22E+02	1.01E+02	9.37E+02	7.61E-01	1.46E-04	0.00E+00	1.65E-04	9.31E-04	0.00E+00	3.88E-07	1.40E-05				
XE-133M	2.48E+03	7.77E+02	7.24E+03	5.88E+00	1.13E-03	0.00E+00	1.91E-03	8.26E-03	0.00E+00	1.32E-06	1.24E-04				
XE-133	9.77E+04	3.06E+04	2.85E+05	2.31E+02	4.43E-02	0.00E+00	6.83E-02	3.06E-01	0.00E+00	1.16E-04	4.60E-03				
XE-135M	2.62E+04	8.18E+03	7.64E+04	6.19E+01	1.18E-02	0.00E+00	2.58E-01	5.45E-02	0.00E+00	1.42E-04	8.19E-04				
XE-135	9.20E+04	2.88E+04	2.68E+05	2.18E+02	4.17E-02	0.00E+00	5.28E-01	6.35E-01	0.00E+00	2.83E-04	9.55E-03				
XE-138	8.60E+04	2.69E+04	2.51E+05	2.04E+02	3.90E-02	0.00E+00	5.77E+00	1.48E+00	0.00E+00	8.21E-04	2.22E-02				
XE-138	8.60E+04	2.69E+04	1.80E+04	3.48E-03	0.00E+00	8.85E-04	5.54E-03	0.00E+00	7.27E-06	8.32E-05					
KR-83M	7.59E+03	2.37E+03	2.21E+04	1.80E+01	3.48E-03	0.00E+00	6.92E-02	9.50E-02	0.00E+00	3.99E-05	1.43E-03				
KR-85M	1.90E+04	5.95E+03	5.54E+04	4.50E+01	8.61E-03	0.00E+00	3.13E-05	3.05E-03	0.00E+00	1.72E-08	4.59E-05				
KR-85	6.39E+02	2.00E+02	1.86E+03	1.51E+00	2.89E-04	0.00E+00	1.17E+00	8.25E-01	0.00E+00	3.15E-04	1.24E-02				
KR-87	3.66E+04	1.15E+04	1.07E+05	8.67E+01	1.66E-02	0.00E+00	2.11E+00	3.81E-01	0.00E+00	9.73E-04	5.72E-03				
KR-88	5.20E+04	1.63E+04	1.52E+05	1.23E+02	2.36E-02	0.00E+00	-----	-----	-----	-----	-----				
						3.85E+01	1.01E+01	3.83E+00	5.79E-01	2.77E-03	5.75E-02				

OPC CRDA, CR & LPZ, ALL REL GLAND: TID-14844: 0 - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
NO SPRAYED VOL 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO SPRAY

vol.

AT .500 HOURS: X/Q(SITE) = .32E-04 SEC/M3 PRIMARY LEAK RATE=\*\*\*\*\* PERCENT/DAY CONTROL ROOM INTAKE=2460.0  
 CFM X/Q CONT ROOM= .70E-03 SEC/M3 SEC RELEASE RATE= .86E+05 VOL/DAY PCT PRI LKG TO ATM =  
 00.00

CLEANUP RATES (HR-1)					FILTER NON-REMPTION FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT	CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM (CURIES) (UCI/CM3)		SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA	THYROID	WH BODY
<b>ELEMENTAL</b>											
I-131	1.69E-07	2.05E-09	5.06E+02	8.91E-01	1.70E-04	8.32E+00	1.50E-03	7.34E-04	1.90E+02	1.23E-03	1.68E-02
I-132	2.16E-07	2.62E-09	7.45E+02	1.14E+00	2.17E-04	4.42E-01	1.43E-02	2.46E-03	9.51E+00	9.49E-03	5.28E-02
I-133	3.84E-07	4.67E-09	1.17E+03	2.02E+00	3.87E-04	5.18E+00	4.45E-03	3.63E-03	1.18E+02	4.53E-03	8.26E-02
I-134	3.04E-07	3.70E-09	1.34E+03	1.60E+00	3.07E-04	3.71E-01	2.07E-02	4.47E-03	7.19E+00	1.65E-02	8.67E-02
I-135	3.41E-07	4.15E-09	1.07E+03	1.80E+00	3.44E-04	1.48E+00	1.53E-02	2.43E-03	3.31E+01	8.32E-03	5.45E-02
<b>PARTICULATE</b>											
I-131	9.29E-09	1.13E-10	2.78E+01	4.89E-02	9.37E-06	4.57E-01	8.25E-05	4.03E-05	1.05E+01	6.75E-05	9.23E-04
I-132	1.18E-08	1.44E-10	4.09E+01	6.24E-02	1.19E-05	2.43E-02	7.86E-04	1.35E-04	5.22E-01	5.22E-04	2.90E-03
I-133	2.11E-08	2.56E-10	6.40E+01	1.11E-01	2.13E-05	2.84E-01	2.44E-04	1.99E-04	6.47E+00	2.49E-04	4.54E-03
I-134	1.67E-08	2.03E-10	7.34E+01	8.81E-02	1.69E-05	2.04E-02	1.14E-03	2.46E-04	3.95E-01	9.06E-04	4.77E-03
I-135	1.88E-08	2.28E-10	5.89E+01	9.88E-02	1.89E-05	8.11E-02	8.38E-04	1.34E-04	1.82E+00	4.57E-04	2.99E-03
<b>ORGANIC</b>											
I-131	7.43E-09	9.03E-11	2.22E+01	3.91E-02	7.49E-06	3.66E-01	6.60E-05	3.22E-05	8.37E+00	5.40E-05	7.39E-04
I-132	9.48E-09	1.15E-10	3.27E+01	4.99E-02	9.56E-06	1.94E-02	6.29E-04	1.08E-04	4.18E-01	4.17E-04	2.32E-03
I-133	1.69E-08	2.05E-10	5.12E+01	8.89E-02	1.70E-05	2.28E-01	1.95E-04	1.59E-04	5.18E+00	1.99E-04	3.63E-03
I-134	1.34E-08	1.63E-10	5.87E+01	7.05E-02	1.35E-05	1.63E-02	9.11E-04	1.97E-04	3.16E-01	7.25E-04	3.81E-03
I-135	1.50E-08	1.82E-10	4.71E+01	7.91E-02	1.51E-05	6.49E-02	6.71E-04	1.07E-04	1.45E+00	3.66E-04	2.39E-03
<b>NOBLE GASES</b>											
XE-131M	1.41E-07	1.72E-09	4.22E+02	7.44E-01	1.42E-04	0.00E+00	7.44E-05	4.20E-04	0.00E+00	2.67E-04	9.62E-03
XE-133M	1.08E-06	1.32E-08	3.26E+03	5.71E+00	1.09E-03	0.00E+00	8.61E-04	3.72E-03	0.00E+00	9.06E-04	8.51E-02
XE-133	4.28E-05	5.20E-07	1.28E+05	2.26E+02	4.32E-02	0.00E+00	3.08E-02	1.38E-01	0.00E+00	7.99E-02	3.16E+00
XE-135M	3.05E-06	3.70E-08	3.28E+04	1.60E+01	3.07E-03	0.00E+00	1.11E-01	2.34E-02	0.00E+00	5.58E-02	3.22E+01
XE-135	3.89E-05	4.73E-07	1.21E+05	2.05E+02	3.93E-02	0.00E+00	2.37E-01	2.86E-01	0.00E+00	1.91E-01	6.45E+00
XE-138	1.16E-05	1.41E-07	1.08E+05	6.09E+01	1.17E-02	0.00E+00	2.49E+00	6.38E-01	0.00E+00	3.40E-01	9.21E+00
KR-83M	2.77E-06	3.37E-08	9.90E+03	1.46E+01	2.80E-03	0.00E+00	3.96E-04	2.48E-03	0.00E+00	4.59E-03	5.25E-02
KR-85M	7.72E-06	9.39E-08	2.49E+04	4.07E+01	7.79E-03	0.00E+00	3.11E-02	4.27E-02	0.00E+00	2.65E-02	9.46E-02
KR-85	2.81E-07	3.41E-09	8.39E+02	1.48E+00	2.83E-04	0.00E+00	1.41E-05	1.38E-03	0.00E+00	1.18E-05	3.16E-02
KR-87	1.23E-05	1.49E-07	4.76E+04	6.46E+01	1.24E-02	0.00E+00	5.24E-01	3.68E-01	0.00E+00	1.91E-01	7.52E+00

KR-88	2.02E-05	2.46E-07	6.80E+04	1.06E+02	2.04E-02	0.00E+00	9.48E-01	1.71E-01	0.00E+00	6.31E-01	3.71E+00	
							-----	-----	-----	-----	-----	
							1.73E+01	4.43E+00	1.69E+00	3.94E+02	1.57E+00	3.18E+01

1 QDC CRDA, CR & LPZ, ALL REL GLAND: TID-14844: 0 - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
 1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO SPRAYED

VOL

AT	2.000 HOURS:	X/Q(SITE)= .90E-05 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM INTAKE=2460.0
CFM				
		X/Q CONT ROOM= .70E-03 SEC/M3	SEC RELEASE RATE= .86E+05 VOL/DAY	PCT·PRI LKG TO ATM =
	00.00			

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM			SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)			
	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA		
ELEMENTAL	.000	.000	.000	.000		.000	1.000	1.000					
PARTICULATE	.000	.000	.000	.000		.000	1.000	1.000					
ORGANIC	.000	.000	.000	.000		.000	1.000	1.000					
I-131	1.15E-35	1.40E-37	1.71E-07	2.67E-01	5.11E-05	7.91E-10	1.43E-13	6.98E-14	2.75E+02	1.77E-03	2.42E-02		
I-132	9.37E-36	1.14E-37	2.17E-07	2.18E-01	4.17E-05	3.62E-11	1.17E-12	2.01E-13	1.07E+01	1.06E-02	5.92E-02		
I-133	2.49E-35	3.03E-37	3.88E-07	5.80E-01	1.11E-04	4.85E-10	4.17E-13	3.40E-13	1.66E+02	6.37E-03	1.16E-01		
I-134	6.27E-36	7.62E-38	3.03E-07	1.46E-01	2.79E-05	2.36E-11	1.32E-12	2.85E-13	5.45E+00	1.25E-02	5.58E-02		
I-135	2.00E-35	2.43E-37	3.45E-07	4.64E-01	8.88E-05	1.33E-10	1.38E-12	2.20E-13	4.38E+01	1.10E-02	7.21E-02		
PARTICULATE													
I-131	6.31E-37	7.67E-39	9.40E-09	1.47E-02	2.81E-06	4.34E-11	7.85E-15	3.83E-15	1.51E+01	9.73E-05	1.33E-03		
I-132	5.15E-37	6.26E-39	1.19E-08	1.20E-02	2.29E-06	1.99E-12	6.43E-14	1.10E-14	5.86E-01	5.85E-04	3.25E-03		
I-133	1.37E-36	1.67E-38	2.13E-08	3.19E-02	6.10E-06	2.66E-11	2.29E-14	1.87E-14	9.10E+00	3.50E-04	6.38E-03		
I-134	3.44E-37	4.19E-39	1.66E-08	8.01E-03	1.53E-06	1.30E-12	7.25E-14	1.57E-14	3.00E-01	6.87E-04	3.61E-03		
I-135	1.10E-36	1.33E-38	1.89E-08	2.55E-02	4.88E-06	7.33E-12	7.58E-14	1.21E-14	2.41E+00	6.05E-04	3.96E-03		
ORGANIC													
I-131	5.05E-37	6.13E-39	7.52E-09	1.17E-02	2.24E-06	3.48E-11	6.28E-15	3.07E-15	1.21E+01	7.78E-05	1.07E-03		
I-132	4.12E-37	5.01E-39	9.53E-09	9.57E-03	1.83E-06	1.59E-12	5.14E-14	8.83E-15	4.69E-01	4.68E-04	2.60E-03		
I-133	1.10E-36	1.33E-38	1.71E-08	2.55E-02	4.88E-06	2.13E-11	1.83E-14	1.49E-14	7.28E+00	2.80E-04	5.10E-03		
I-134	2.76E-37	3.35E-39	1.33E-08	6.41E-03	1.23E-02	1.04E-12	5.80E-14	1.25E-14	2.40E-01	5.50E-04	2.89E-03		
I-135	8.77E-37	1.07E-38	1.52E-08	2.04E-02	3.90E-06	5.87E-12	6.06E-14	9.66E-15	1.93E+00	4.84E-04	3.17E-03		
NOBLE GASES													
XE-131M	9.60E-36	1.17E-37	1.43E-07	2.23E-01	4.27E-05	0.00E+00	7.07E-15	3.99E-14	0.00E+00	3.85E-04	1.39E-02		
XE-132M	7.26E-35	8.83E-37	1.10E-06	1.69E+00	3.23E-04	0.00E+00	8.15E-14	3.52E-13	0.00E+00	1.30E-03	1.22E-01		
XE-133M	2.90E-33	3.52E-35	4.33E-05	6.74E+01	1.29E-02	0.00E+00	2.92E-12	1.31E-11	0.00E+00	1.15E-01	4.54E+00		
XE-135M	3.82E-36	4.65E-38	2.90E-06	8.89E-02	1.70E-05	0.00E+00	2.76E-12	5.83E-13	0.00E+00	1.23E-02	7.08E-02		
XE-135	2.37E-33	2.88E-35	3.93E-05	5.51E+01	1.06E-02	0.00E+00	2.18E-11	2.62E-11	0.00E+00	2.59E-01	8.74E+00		
XE-138	2.24E-35	2.72E-37	1.11E-05	5.20E-01	9.95E-05	0.00E+00	7.17E-11	1.84E-11	0.00E+00	8.91E-02	2.41E+00		
KR-83M	1.09E-34	1.32E-36	2.78E-06	2.52E+00	4.83E-04	0.00E+00	3.13E-14	1.96E-13	0.00E+00	4.86E-03	5.56E-02		
KR-85M	4.16E-34	5.06E-36	7.79E-06	9.68E+00	1.85E-03	0.00E+00	2.73E-12	3.76E-12	0.00E+00	3.34E-02	1.20E+00		
KR-85	1.92E-35	2.33E-37	2.84E-07	4.45E-01	8.53E-05	0.00E+00	1.34E-15	1.31E-13	0.00E+00	1.71E-05	4.57E-02		
KR-87	3.68E-34	4.48E-36	1.22E-05	8.56E+00	1.64E-03	0.00E+00	3.79E-11	2.66E-11	0.00E+00	1.75E-01	6.92E+00		
KR-88	9.51E-34	1.16E-35	2.03E-05	2.21E+01	4.23E-03	0.00E+00	7.97E-11	1.44E-11	0.00E+00	7.40E-01	4.35E+00		
							-----	-----	-----	-----	-----		
							1.61E-09	2.24E-10	1.05E-10	5.50E+02	1.48E+00	2.88E+01	

1 QDC CRDA, CR & LPZ, ALL REL GLAND: TID-14844: 0 - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
 1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO SPRAYED

VOL

AT	8.000 HOURS:	X/Q(SITE)= .90E-05 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM INTAKE=2460.0
CFM				
		X/Q CONT ROOM= .65E-05 SEC/M3	SEC RELEASE RATE= .86E+05 VOL/DAY	PCT PRI LKG TO ATM =
	00.00			

ELEMENTAL	CLEANUP RATES (HR-1)			FILTER NON-REMOVAL FACTORS		
	SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	
PARTICULATE	.000	.000	.000	.000	1.000	1.000

	ORGANIC	.000	.000	.000	.000	1.000	1.000	
ISOTOPE	ACTIVITY (CURIES)	PRIMARY	SECONDARY	RELEASE	CONTROL ROOM (CURIES)	SITE BOUNDARY DOSES (REM)	CONTROL ROOM DOSES (REM)	
					(UCI/CM3)	THYROID WH BODY	THYROID WH BODY	BETA
ELEMENTAL								
I-131	0.00E+00	0.00E+00	1.16E-35	2.15E-03	4.11E-07	5.37E-38	9.70E-42	4.74E-42
I-132	0.00E+00	0.00E+00	9.42E-36	2.94E-04	5.63E-08	1.57E-39	5.08E-41	8.73E-42
I-133	0.00E+00	0.00E+00	2.52E-35	3.91E-03	7.49E-07	3.15E-38	2.71E-41	2.21E-41
I-134	0.00E+00	0.00E+00	6.23E-36	9.92E-06	1.90E-09	4.86E-40	2.72E-41	5.87E-42
I-135	0.00E+00	0.00E+00	2.02E-35	2.05E-03	3.93E-07	7.80E-39	8.07E-41	1.28E-41
PARTICULATE								
I-131	0.00E+00	0.00E+00	6.38E-37	1.18E-04	2.26E-08	2.95E-39	5.33E-43	2.60E-43
I-132	0.00E+00	0.00E+00	5.17E-37	1.61E-05	3.09E-09	8.64E-41	2.79E-42	4.80E-43
I-133	0.00E+00	0.00E+00	1.39E-36	2.15E-04	4.12E-08	1.73E-39	1.49E-42	1.21E-42
I-134	0.00E+00	0.00E+00	3.42E-37	5.45E-07	1.04E-10	2.67E-41	1.49E-42	3.22E-43
I-135	0.00E+00	0.00E+00	1.11E-36	1.13E-04	2.16E-08	4.29E-40	4.43E-42	7.06E-43
ORGANIC								
I-131	0.00E+00	0.00E+00	5.11E-37	9.45E-05	1.81E-08	2.36E-39	4.26E-43	2.08E-43
I-132	0.00E+00	0.00E+00	4.14E-37	1.29E-05	2.47E-09	6.92E-41	2.24E-42	3.84E-43
I-133	0.00E+00	0.00E+00	1.11E-36	1.72E-04	3.29E-08	1.38E-39	1.19E-42	9.71E-43
I-134	0.00E+00	0.00E+00	2.74E-37	4.36E-07	8.34E-11	2.14E-41	1.19E-42	2.58E-43
I-135	0.00E+00	0.00E+00	8.86E-37	9.03E-05	1.73E-08	3.43E-40	3.55E-42	5.65E-43
NOBLE GASES								
XE-131M	0.00E+00	0.00E+00	9.72E-36	1.81E-03	3.47E-07	0.00E+00	4.81E-43	2.72E-42
XE-133M	0.00E+00	0.00E+00	7.35E-35	1.29E-02	2.46E-06	0.00E+00	5.46E-42	2.36E-41
XE-133	0.00E+00	0.00E+00	2.93E-33	5.37E-01	1.03E-04	0.00E+00	1.98E-40	8.87E-40
XE-135M	0.00E+00	0.00E+00	3.65E-36	8.36E-11	1.60E-14	0.00E+00	3.46E-42	7.32E-43
XE-135	0.00E+00	0.00E+00	2.40E-33	2.88E-01	5.51E-05	0.00E+00	1.33E-39	1.60E-39
XE-138	0.00E+00	0.00E+00	2.15E-35	2.75E-09	5.27E-13	0.00E+00	1.39E-40	3.55E-41
KR-83M	0.00E+00	0.00E+00	1.09E-34	2.24E-03	4.29E-07	0.00E+00	1.23E-42	7.66E-42
KR-85M	0.00E+00	0.00E+00	4.20E-34	3.09E-02	5.92E-06	0.00E+00	1.47E-40	2.02E-40
KR-85	0.00E+00	0.00E+00	1.94E-35	3.67E-03	7.02E-07	0.00E+00	9.16E-44	8.95E-42
KR-87	0.00E+00	0.00E+00	3.68E-34	2.64E-03	5.06E-07	0.00E+00	1.14E-39	8.00E-40
KR-88	0.00E+00	0.00E+00	9.57E-34	4.12E-02	7.88E-06	0.00E+00	3.76E-39	6.76E-40

1 QDC CRDA, CR &amp; LPZ, ALL REL GLAND: TID-14844: 0 - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
 1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO SPRAYED

VOL

AT 24.000 HOURS: X/Q(SITE)= .30E-05 SEC/M3 PRIMARY LEAK RATE=\*\*\*\*\* PERCENT/DAY CONTROL ROOM INTAKE=2460.0  
 CFM X/Q CONT ROOM= .38E-05 SEC/M3 SEC RELEASE RATE= .86E+05 VOL/DAY PCT PRI LKG TO ATM =  
 00.00

SPRAY	CLEANUP RATES (HR-1)			FILTER NON-REMOVAL FACTORS	
	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)	CONTROL ROOM (CURIES)	SITE BOUNDARY DOSES (REM)	CONTROL ROOM DOSES (REM)						
	PRIMARY	SECONDARY	RELEASE	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA
ELEMENTAL										
I-131	0.00E+00	0.00E+00	0.00E+00	5.60E-09	1.07E-12	0.00E+00	0.00E+00	0.00E+00	9.46E-01	6.10E-06
I-132	0.00E+00	0.00E+00	0.00E+00	6.54E-12	1.25E-15	0.00E+00	0.00E+00	0.00E+00	3.41E-03	3.41E-06
I-133	0.00E+00	0.00E+00	0.00E+00	6.37E-09	1.22E-12	0.00E+00	0.00E+00	0.00E+00	4.49E-01	1.73E-05
I-134	0.00E+00	0.00E+00	0.00E+00	7.66E-17	1.47E-20	0.00E+00	0.00E+00	0.00E+00	3.71E-05	8.50E-08
I-135	0.00E+00	0.00E+00	0.00E+00	1.09E-09	2.08E-13	0.00E+00	0.00E+00	0.00E+00	6.74E-02	1.70E-05
PARTICULATE										
I-131	0.00E+00	0.00E+00	0.00E+00	3.08E-10	5.89E-14	0.00E+00	0.00E+00	0.00E+00	5.20E-02	3.35E-07
I-132	0.00E+00	0.00E+00	0.00E+00	3.59E-13	6.88E-17	0.00E+00	0.00E+00	0.00E+00	1.88E-04	1.87E-07
I-133	0.00E+00	0.00E+00	0.00E+00	3.50E-10	6.70E-14	0.00E+00	0.00E+00	0.00E+00	2.47E-02	9.49E-07
I-134	0.00E+00	0.00E+00	0.00E+00	4.21E-18	8.05E-22	0.00E+00	0.00E+00	0.00E+00	2.04E-06	4.67E-09
I-135	0.00E+00	0.00E+00	0.00E+00	5.97E-11	1.14E-14	0.00E+00	0.00E+00	0.00E+00	3.70E-03	9.32E-07
ORGANIC										
I-131	0.00E+00	0.00E+00	0.00E+00	2.46E-10	4.71E-14	0.00E+00	0.00E+00	0.00E+00	4.16E-02	2.68E-07
I-132	0.00E+00	0.00E+00	0.00E+00	2.87E-13	5.50E-17	0.00E+00	0.00E+00	0.00E+00	1.50E-04	1.50E-07
I-133	0.00E+00	0.00E+00	0.00E+00	2.80E-10	5.36E-14	0.00E+00	0.00E+00	0.00E+00	1.97E-02	7.59E-07
I-134	0.00E+00	0.00E+00	0.00E+00	3.37E-18	6.44E-22	0.00E+00	0.00E+00	0.00E+00	1.63E-06	3.74E-09
I-135	0.00E+00	0.00E+00	0.00E+00	4.77E-11	9.13E-15	0.00E+00	0.00E+00	0.00E+00	2.96E-03	7.45E-07
NOBLE GASES										
XE-131M	0.00E+00	0.00E+00	0.00E+00	4.81E-09	9.20E-13	0.00E+00	0.00E+00	0.00E+00	1.34E-06	4.83E-05

QDC 9400-M-0550 Rev. 0

## Attachment D

XE-133M	0.00E+00	0.00E+00	0.00E+00	2.90E-08	5.54E-12	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.14E-06	3.89E-04
XE-133	0.00E+00	0.00E+00	0.00E+00	1.36E-06	2.60E-10	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.90E-04	1.54E-02
XE-135M	0.00E+00	0.00E+00	0.00E+00	7.11E-35	1.36E-38	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.44E-14	3.71E-13
XE-135	0.00E+00	0.00E+00	0.00E+00	2.36E-07	4.51E-11	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.97E-04	1.68E-02
XE-138	0.00E+00	0.00E+00	0.00E+00	2.35E-31	4.50E-35	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.06E-12	1.10E-10
KR-83M	0.00E+00	0.00E+00	0.00E+00	1.64E-11	3.14E-15	0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.03E-07	1.03E-05
KR-85M	0.00E+00	0.00E+00	0.00E+00	6.85E-09	1.31E-12	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.06E-08	1.62E-04
KR-85	0.00E+00	0.00E+00	0.00E+00	1.01E-08	1.94E-12	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.28E-06	3.26E-04
KR-87	0.00E+00	0.00E+00	0.00E+00	1.15E-12	2.20E-16	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.61E-04	2.12E-03
KR-88	0.00E+00	0.00E+00	0.00E+00	2.16E-09	4.14E-13	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.61E+00	1.34E-03
						0.00E+00	0.00E+00	0.00E+00	0.00E+00		3.70E-02

1 QDC CRDA, CR &amp; LPZ, ALL REL GLAND: TID-14844: 0 - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
 1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO SPRAYED

VOL

AT 720.000 HOURS: X/Q(SITE) = .00E+00 SEC/M3 PRIMARY LEAK RATE= .000 PERCENT/DAY CONTROL ROOM INTAKE=2460.0  
 CFM X/Q CONT ROOM= .00E+00 SEC/M3 SEC RELEASE RATE= .00E+00 VOL/DAY PCT PRI LKG TO ATM =  
 00.00

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM (CURIES) (UCI/CM3)	SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)						
	ELEMENTAL	PARTICULATE	ORGANIC		PRIMARY	SECONDARY	RELEASE	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA	
					CLEANUP RATES (HR-1)	SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER			
XE-131M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.47E-06	1.59E-11	2.18E-10		
I-131	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.59E-11	7.58E-14	4.21E-13		
I-132	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.31E-07	2.81E-11	5.13E-10		
I-133	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.85E-16	6.55E-19	3.45E-18		
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.56E-08	8.96E-12	5.87E-11		
I-135	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.36E-07	8.74E-13	1.20E-11		
I-132	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.17E-12	4.17E-15	2.32E-14		
I-133	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.02E-08	1.55E-12	2.82E-11		
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.57E-17	3.61E-20	1.90E-19		
I-135	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.96E-09	4.92E-13	3.22E-12		
I-131	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.08E-07	6.99E-13	9.57E-12		
I-132	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.34E-12	3.33E-15	1.85E-14		
I-133	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.22E-08	1.24E-12	2.25E-11		
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.57E-09	3.94E-13	2.58E-12		
I-135	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.08E-07	6.99E-13	9.57E-12		
XE-131M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.32E-12	8.75E-10			
XE-133M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.86E-10	3.90E-08			
XE-133	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.48E-38	3.16E-37			
XE-135M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.07E-10	1.37E-08			
XE-135	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.46E-34	9.38E-33			
XE-138	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.61E-15	7.56E-14			
KR-83M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.38E-12	2.64E-10			
KR-85M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.67E-13	4.47E-10			
KR-85	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.60E-15	1.42E-13			
KR-87	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.90E-11	1.11E-10			
KR-88	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.55E-06	1.49E-09	5.54E-08		
				TOTAL DOSES 0-30 DAYS	5.59E+01	1.46E+01	5.52E+00	1.17E+03	3.44E+00	6.86E+01				

1

QDC CRDA, CR &amp; LPZ, ALL REL GLAND: TID-14844: 0 - 30 d

ISOTOPE	2. HRS	8. HRS	24. HRS	720. HRS	ACTIVITY RELEASED (CURIES)			
					ELEMENTAL	ORGANIC	NOBLE GASES	ALL
I-131	1.63E+03	1.16E-35	0.00E+00	0.00E+00	1.63E+03			
I-132	2.41E+03	9.42E-36	0.00E+00	0.00E+00	2.41E+03			
I-133	3.75E+03	2.52E-35	0.00E+00	0.00E+00	3.75E+03			
I-134	4.35E+03	6.23E-36	0.00E+00	0.00E+00	4.35E+03			

## Attachment D

I-135	3.46E+03	2.02E-35	0.00E+00	0.00E+00	3.46E+03
<b>PARTICULATE</b>					
I-131	8.95E+01	6.38E-37	0.00E+00	0.00E+00	8.95E+01
I-132	1.32E+02	5.17E-37	0.00E+00	0.00E+00	1.32E+02
I-133	2.06E+02	1.39E-36	0.00E+00	0.00E+00	2.06E+02
I-134	2.39E+02	3.42E-37	0.00E+00	0.00E+00	2.39E+02
I-135	1.90E+02	1.11E-36	0.00E+00	0.00E+00	1.90E+02
<b>ORGANIC</b>					
I-131	7.16E+01	5.11E-37	0.00E+00	0.00E+00	7.16E+01
I-132	1.06E+02	4.14E-37	0.00E+00	0.00E+00	1.06E+02
I-133	1.65E+02	1.11E-36	0.00E+00	0.00E+00	1.65E+02
I-134	1.91E+02	2.74E-37	0.00E+00	0.00E+00	1.91E+02
I-135	1.52E+02	8.86E-37	0.00E+00	0.00E+00	1.52E+02
<b>NOBLE GASES</b>					
XE-131M	1.36E+03	9.72E-36	0.00E+00	0.00E+00	1.36E+03
XE-133M	1.05E+04	7.35E-35	0.00E+00	0.00E+00	1.05E+04
XE-133	4.13E+05	2.93E-33	0.00E+00	0.00E+00	4.13E+05
XE-135M	1.09E+05	3.65E-36	0.00E+00	0.00E+00	1.09E+05
XE-135	3.89E+05	2.40E-33	0.00E+00	0.00E+00	3.89E+05
XE-138	3.60E+05	2.15E-35	0.00E+00	0.00E+00	3.60E+05
KR-83M	3.20E+04	1.09E-34	0.00E+00	0.00E+00	3.20E+04
KR-85M	8.03E+04	4.20E-34	0.00E+00	0.00E+00	8.03E+04
KR-85	2.70E+03	1.94E-35	0.00E+00	0.00E+00	2.70E+03
KR-87	1.54E+05	3.68E-34	0.00E+00	0.00E+00	1.54E+05
KR-88	2.20E+05	9.57E-34	0.00E+00	0.00E+00	2.20E+05

END EXECUTION DATE: 11/18/1999  
 END EXECUTION TIME: 16:56:02.13

AXIDENT VER 2 MOD 4  
 PRODUCTION DATE 02/18/92  
 BEGIN EXECUTION DATE: 11/18/1999  
 BEGIN EXECUTION TIME: 16:56:11.85

```

1 QDC CRDA, EAB, ALL REL MVP: TID-14844: 0 - 6 s
2 2 1 1. 1.
3 -2561 2.60+6 1.845+5 5.83+4
4 0. 0. 1. 1. 2.78+5 0.
5 6 7200
6 0.2402 0.
7 9.058E-4 0.
8 2*1.
9 2*0.
10 2.98-4 0.
11 2*0.
12 2*0.
13 2*0.
14 2*0.
15 2*0.
16 2*0.
17 2*0.
18 2*0.
19 2*0.
20 2*0.
21 6*1.
22 3*1.
23 7.16E+3      1.06E+4   1.65E+4   1.92E+4   1.52E+4   1.36E+3   1.05E+4   4.13E+5
24 1.11E+5      3.89E+5   3.65E+5   3.21E+4   8.04E+4   2.70E+3   1.55E+5   2.20E+5

```

1

QDC CRDA, EAB, ALL REL MVP: TID-14844: 0 - 6 s

## INITIAL CONTAINMENT INVENTORY

ISOTOPE	ACTIVITY (CURIES)
I-131	7.160E+03
I-132	1.060E+04
I-133	1.650E+04
I-134	1.920E+04
I-135	1.520E+04
XE-131M	1.360E+03
XE-133M	1.050E+04
XE-133	4.130E+05
XE-135M	1.110E+05
XE-135	3.890E+05
XE-138	3.650E+05
KR-83M	3.210E+04
KR-85M	8.040E+04
KR-85	2.700E+03
KR-87	1.550E+05
KR-88	2.200E+05

1 QDC CRDA, EAB, ALL REL MVP: TID-14844: 0 - 6 s

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
 VOL  
 1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO SPRAYED

AT .002 HOURS:	X/Q(SITE)= .29E-03 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM INTAKE= .0
CFM			
00.00	X/Q CONT ROOM= .00E+00 SEC/M3	SEC RELEASE RATE= .78E+02 VOL/DAY	PCT PRI LKG TO ATM =

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM (CURIES) (UCI/CM3)			SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA
ELEMENTAL												
I-131	3.85E+02	1.24E+03	4.16E+00	0.00E+00	0.00E+00	6.19E-01	1.12E-04	5.46E-05	0.00E+00	0.00E+00	0.00E+00	
I-132	5.70E+02	1.83E+03	6.15E+00	0.00E+00	0.00E+00	3.31E-02	1.07E-03	1.84E-04	0.00E+00	0.00E+00	0.00E+00	

I-133	8.88E+02	2.86E+03	9.58E+00	0.00E+00	0.00E+00	3.85E-01	3.31E-04	2.70E-04	0.00E+00	0.00E+00	0.00E+00
I-134	1.03E+03	3.32E+03	1.11E+01	0.00E+00	0.00E+00	2.80E-02	1.57E-03	3.38E-04	0.00E+00	0.00E+00	0.00E+00
I-135	8.18E+02	2.63E+03	8.82E+00	0.00E+00	0.00E+00	1.10E-01	1.14E-03	1.81E-04	0.00E+00	0.00E+00	0.00E+00
PARTICULATE											
I-131	2.12E+01	6.81E+01	2.28E-01	0.00E+00	0.00E+00	3.40E-02	6.14E-06	3.00E-06	0.00E+00	0.00E+00	0.00E+00
I-132	3.13E+01	1.01E+02	3.38E-01	0.00E+00	0.00E+00	1.82E-03	5.88E-05	1.01E-05	0.00E+00	0.00E+00	0.00E+00
I-133	4.88E+01	1.57E+02	5.26E-01	0.00E+00	0.00E+00	2.12E-02	1.82E-05	1.48E-05	0.00E+00	0.00E+00	0.00E+00
I-134	5.67E+01	1.82E+02	6.12E-01	0.00E+00	0.00E+00	1.54E-03	8.60E-05	1.86E-05	0.00E+00	0.00E+00	0.00E+00
I-135	4.50E+01	1.45E+02	4.85E-01	0.00E+00	0.00E+00	6.05E-03	6.25E-05	9.96E-06	0.00E+00	0.00E+00	0.00E+00
ORGANIC											
I-131	1.69E+01	5.45E+01	1.83E-01	0.00E+00	0.00E+00	2.72E-02	4.91E-06	2.40E-06	0.00E+00	0.00E+00	0.00E+00
I-132	2.51E+01	8.06E+01	2.70E-01	0.00E+00	0.00E+00	1.46E-03	4.70E-05	8.08E-06	0.00E+00	0.00E+00	0.00E+00
I-133	3.90E+01	1.26E+02	4.21E-01	0.00E+00	0.00E+00	1.69E-02	1.46E-05	1.19E-05	0.00E+00	0.00E+00	0.00E+00
I-134	4.54E+01	1.46E+02	4.89E-01	0.00E+00	0.00E+00	1.23E-03	6.88E-05	1.49E-05	0.00E+00	0.00E+00	0.00E+00
I-135	3.60E+01	1.16E+02	3.88E-01	0.00E+00	0.00E+00	4.84E-03	5.00E-05	7.97E-06	0.00E+00	0.00E+00	0.00E+00
NOBLE GASES											
XE-131M	3.22E+02	1.03E+03	3.47E+00	0.00E+00	0.00E+00	0.00E+00	5.53E-06	3.12E-05	0.00E+00	0.00E+00	0.00E+00
XE-133M	2.48E+03	7.99E+03	2.68E+01	0.00E+00	0.00E+00	0.00E+00	6.41E-05	2.77E-04	0.00E+00	0.00E+00	0.00E+00
XE-133	9.77E+04	3.14E+05	1.05E+03	0.00E+00	0.00E+00	0.00E+00	2.29E-03	1.03E-02	0.00E+00	0.00E+00	0.00E+00
XE-135M	2.62E+04	8.41E+04	2.82E+02	0.00E+00	0.00E+00	0.00E+00	8.64E-03	1.83E-03	0.00E+00	0.00E+00	0.00E+00
XE-135	9.20E+04	2.96E+05	9.92E+02	0.00E+00	0.00E+00	0.00E+00	1.77E-02	2.13E-02	0.00E+00	0.00E+00	0.00E+00
XE-138	8.60E+04	2.77E+05	9.29E+02	0.00E+00	0.00E+00	0.00E+00	1.93E-01	4.96E-02	0.00E+00	0.00E+00	0.00E+00
KR-83M	7.59E+03	2.44E+04	8.19E+01	0.00E+00	0.00E+00	0.00E+00	2.97E-05	1.86E-04	0.00E+00	0.00E+00	0.00E+00
KR-85M	1.90E+04	6.12E+04	2.05E+02	0.00E+00	0.00E+00	0.00E+00	2.32E-03	3.19E-03	0.00E+00	0.00E+00	0.00E+00
KR-85	6.39E+02	2.05E+03	6.89E+00	0.00E+00	0.00E+00	0.00E+00	1.05E-06	1.02E-04	0.00E+00	0.00E+00	0.00E+00
KR-87	3.66E+04	1.18E+05	3.95E+02	0.00E+00	0.00E+00	0.00E+00	3.94E-02	2.77E-02	0.00E+00	0.00E+00	0.00E+00
KR-88	5.20E+04	1.67E+05	5.61E+02	0.00E+00	0.00E+00	0.00E+00	7.09E-02	1.28E-02	0.00E+00	0.00E+00	0.00E+00
-----											
						1.29E+00	3.39E-01	1.28E-01	0.00E+00	0.00E+00	0.00E+00

1 QDC CRDA, EAB, ALL REL MVP: TID-14844: 0 - 6 s

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

VOL 1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO SPRAYED

AT 2.000 HOURS: X/Q(SITE)= .00E+00 SEC/M3 PRIMARY LEAK RATE= .000 PERCENT/DAY CONTROL ROOM INTAKE=.0  
 CFM  
 X/Q CONT ROOM= .00E+00 SEC/M3 SEC RELEASE RATE= .00E+00 VOL/DAY PCT PRI LKG TO ATM =  
 00.00

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	1.000	1.000

KR-88	3.17E+04	1.02E+05	0.00E+00								
	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----
	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====
	TOTAL DOSES	0-30	DAYS	1.29E+00	3.39E-01	1.28E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

1

ODC CRDA, EAB, ALL REL MVP: TID-14844: 0 - 6 s

ACTIVITY RELEASED (CURIES)

ISOTOPE	2. HRS
ELEMENTAL	
I-131	4.16E+00
I-132	6.15E+00
I-133	9.58E+00
I-134	1.11E+01
I-135	8.82E+00
PARTICULATE	
I-131	2.28E-01
I-132	3.38E-01
I-133	5.26E-01
I-134	6.12E-01
I-135	4.85E-01
ORGANIC	
I-131	1.83E-01
I-132	2.70E-01
I-133	4.21E-01
I-134	4.89E-01
I-135	3.88E-01
NOBLE GASES	
XE-131M	3.47E+00
XE-133M	2.68E+01
XE-133	1.05E+03
XE-135M	2.82E+02
XE-135	9.92E+02
XE-138	9.29E+02
KR-83M	8.19E+01
KR-85M	2.05E+02
KR-85	6.89E+00
KR-87	3.95E+02
KR-88	5.61E+02

END EXECUTION DATE: 11/18/1999  
END EXECUTION TIME: 16:56:11.91

AXIDENT VER 2 MOD 4  
PRODUCTION DATE 02/18/92  
BEGIN EXECUTION DATE: 11/18/1999  
BEGIN EXECUTION TIME: 16:56:19.05

```

1 QDC CRDA, EAB, ALL REL AOG: TID-14844: 6 s - 2 h
2 3 1 1. 1.
3 -2561 2.60+6 1.845+5 5.83+4
4 0. 0. 1. 1. 2.78+5 0.
5 6 1800 7200
6 0.2402 2*1.201E-2
7 9.058E-4 2*1.157E-5
8 3*1.
9 3*0.
10 0. 2.9e-4 2.3E-5
11 3*0.
12 3*0.
13 3*0.
14 3*0.
15 3*0.
16 3*0.
17 3*0.
18 3*0.
19 3*0.
20 3*0.
21 3*0. 3*1.
22 3*1.
23 7.16E+3      1.06E+4   1.65E+4   1.92E+4   1.52E+4   1.36E+3   1.05E+4   4.13E+5
24 1.11E+5      3.89E+5   3.65E+5   3.21E+4   8.04E+4   2.70E+3   1.55E+5   2.20E+5

```

1

ODC CRDA, EAB, ALL REL AOG: TID-14844: 6 s - 2 h

## INITIAL CONTAINMENT INVENTORY

ISOTOPE	ACTIVITY (CURIOS)
I-131	7.160E+03
I-132	1.060E+04
I-133	1.650E+04
I-134	1.920E+04
I-135	1.520E+04
XE-131M	1.360E+03
XE-133M	1.050E+04
XE-133	4.130E+05
XE-135M	1.110E+05
XE-135	3.890E+05
XE-138	3.650E+05
KR-83M	3.210E+04
KR-85M	8.040E+04
KR-85	2.700E+03
KR-87	1.550E+05
KR-88	2.200E+05

1 ODC CRDA, EAB, ALL REL AOG: TID-14844: 6 s - 2 h

MANUFACTURED BY: 2561 MWT 284500 FT3 CONT CENTER VOLUME: 58300 FT3 CONTROL ROOM VOLUME: 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO SPRAYED VOL

AT	.002 HOURS:	X/Q(SITE)= .00E+00 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM INTAKE= .0
CFM		X/Q CONT ROOM= .00E+00 SEC/M3	SEC RELEASE RATE= .78E+02 VOL/DAY	PCT PRI LKG TO ATM =
00.00				

CLEANUP RATES (HR-1)				FILTER NON-REMPTION FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
.000	.000	.000	.000	.000	1.000
.000	.000	.000	.000	.000	1.000
.000	.000	.000	.000	.000	1.000

ACTIVITY (CURIES)		CONTROL ROOM	SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)				
ISOTOPe	PRIMARY RELEASE	SECONDARY RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA

I-133	8.88E+02	2.86E+03	0.00E+00									
I-134	1.03E+03	3.32E+03	0.00E+00									
I-135	8.18E+02	2.63E+03	0.00E+00									
PARTICULATE												
I-131	2.12E+01	6.81E+01	0.00E+00									
I-132	3.13E+01	1.01E+02	0.00E+00									
I-133	4.88E+01	1.57E+02	0.00E+00									
I-134	5.67E+01	1.82E+02	0.00E+00									
I-135	4.50E+01	1.45E+02	0.00E+00									
ORGANIC												
I-131	1.69E+01	5.45E+01	0.00E+00									
I-132	2.51E+01	8.06E+01	0.00E+00									
I-133	3.90E+01	1.26E+02	0.00E+00									
I-134	4.54E+01	1.46E+02	0.00E+00									
I-135	3.60E+01	1.16E+02	0.00E+00									
NOBLE GASES												
XE-131M	3.22E+02	1.03E+03	3.47E+00	0.00E+00								
XE-133M	2.48E+03	7.99E+03	2.68E+01	0.00E+00								
XE-133	9.77E+04	3.14E+05	1.05E+03	0.00E+00								
XE-135M	2.62E+04	8.41E+04	2.82E+02	0.00E+00								
XE-135	9.20E+04	2.96E+05	9.92E+02	0.00E+00								
XE-138	8.60E+04	2.77E+05	9.29E+02	0.00E+00								
KR-83M	7.59E+03	2.44E+04	8.19E+01	0.00E+00								
KR-85M	1.90E+04	6.12E+04	2.05E+02	0.00E+00								
KR-85	6.39E+02	2.05E+03	6.89E+00	0.00E+00								
KR-87	3.66E+04	1.18E+05	3.95E+02	0.00E+00								
KR-88	5.20E+04	1.67E+05	5.61E+02	0.00E+00								

1 QDC CRDA, EAB, ALL REL AOG: TID-14844: 6 s - 2 h

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
 1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO SPRAYED

VOL

AT	.500 HOURS:	X/Q(SITE)= .29E-03 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM INTAKE= .0
CFM				
		X/Q CONT ROOM= .00E+00 SEC/M3	SEC RELEASE RATE= .10E+01 VOL/DAY	PCT PRI LKG TO ATM =
		00.00		

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS					
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER				
ELEMENTAL	.000	.000	.000	.000	.000	1.000			
PARTICULATE	.000	.000	.000	.000	.000	1.000			
ORGANIC	.000	.000	.000	.000	.000	1.000			
ISOTOPE	ACTIVITY (CURIES)	CONTROL ROOM (CURIES)	SITE BOUNDARY DOSES (REM)	(THYROID WH BODY BETA)	CONTROL ROOM DOSES (REM)				
	PRIMARY SECONDARY RELEASE	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY		
ELEMENTAL									
I-131	1.69E-07	1.59E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00		
I-132	2.16E-07	2.03E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00		
I-133	3.84E-07	3.61E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00		
I-134	3.04E-07	2.86E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00		
I-135	3.41E-07	3.21E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00		
PARTICULATE									
I-131	9.29E-09	8.73E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00		
I-132	1.18E-08	1.11E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00		
I-133	2.11E-08	1.98E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00		
I-134	1.67E-08	1.57E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00		
I-135	1.88E-08	1.76E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00		
ORGANIC									
I-131	7.43E-09	6.98E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00		
I-132	9.48E-09	8.91E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00		
I-133	1.69E-08	1.59E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00		
I-134	1.34E-08	1.26E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00		
I-135	1.50E-08	1.41E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00		
NOBLE GASES									
XE-131M	1.41E-07	1.33E+03	2.75E+01	0.00E+00	0.00E+00	4.39E-05	2.48E-04	0.00E+00	0.00E+00
XE-133M	1.08E-06	1.02E+04	2.12E+02	0.00E+00	0.00E+00	5.07E-04	2.19E-03	0.00E+00	0.00E+00
XE-133	4.28E-05	4.02E+05	8.36E+03	0.00E+00	0.00E+00	1.82E-02	8.14E-02	0.00E+00	0.00E+00
XE-135M	3.05E-06	2.86E+04	1.23E+03	0.00E+00	0.00E+00	3.77E-02	7.98E-03	0.00E+00	0.00E+00
XE-135	3.89E-05	3.66E+05	7.73E+03	0.00E+00	0.00E+00	1.38E-01	1.66E-01	0.00E+00	0.00E+00
XE-138	1.16E-05	1.09E+05	4.30E+03	0.00E+00	0.00E+00	8.94E-01	2.29E-01	0.00E+00	0.00E+00
KR-83M	2.77E-06	2.61E+04	5.93E+02	0.00E+00	0.00E+00	2.15E-04	1.35E-03	0.00E+00	0.00E+00
KR-85M	7.72E-06	7.26E+04	1.57E+03	0.00E+00	0.00E+00	1.77E-02	2.43E-02	0.00E+00	0.00E+00
KR-85	2.81E-07	2.64E+03	5.47E+01	0.00E+00	0.00E+00	8.33E-06	8.14E-04	0.00E+00	0.00E+00
KR-87	1.23E-05	1.15E+05	2.74E+03	0.00E+00	0.00E+00	2.74E-01	1.92E-01	0.00E+00	0.00E+00

KR-88	2.02E-05	1.90E+05	4.19E+03	0.00E+00	0.00E+00	0.00E+00	5.30E-01	9.53E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00
							0.00E+00	1.91E+00	8.01E-01	0.00E+00	0.00E+00	0.00E+00

1 QDC CRDA, EAB, ALL REL AOG: TID-14844: 6 s - 2 h

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO SPRAYED  
VOL

CFM	AT 2.000 HOURS: X/Q(SITE) = .23E-04 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM INTAKE= .0
	X/Q CONT ROOM= .00E+00 SEC/M3	SEC RELEASE RATE= .10E+01 VOL/DAY	PCT. PRI LKG TO ATM =
	00.00		

	CLEANUP RATES (HR-1)			FILTER NON-REMOVAL FACTORS	
	SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE
ELEMENTAL	.000	.000	.000	.000	1.000
PARTICULATE	.000	.000	.000	.000	1.000
ORGANIC	.000	.000	.000	.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM		SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA
ELEMENTAL											
I-131	1.15E-35	1.48E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	9.37E-36	1.21E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	2.49E-35	3.33E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	6.27E-36	8.11E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	2.00E-35	2.58E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
PARTICULATE											
I-131	6.31E-37	8.16E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	5.15E-37	6.66E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	1.37E-36	1.77E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	3.44E-37	4.46E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	1.10E-36	1.42E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ORGANIC											
I-131	5.05E-37	6.53E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	4.12E-37	5.33E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	1.10E-36	1.42E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	2.76E-37	3.56E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	8.77E-37	1.13E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
NOBLE GASES											
XE-131M	9.60E-36	1.24E+03	8.02E+01	0.00E+00	0.00E+00	0.00E+00	1.02E-05	5.73E-05	0.00E+00	0.00E+00	0.00E+00
XE-133M	7.26E-35	9.40E+03	6.12E+02	0.00E+00	0.00E+00	0.00E+00	1.16E-04	5.02E-04	0.00E+00	0.00E+00	0.00E+00
XE-133	2.90E-33	3.75E+05	2.43E+04	0.00E+00	0.00E+00	0.00E+00	4.19E-03	1.88E-02	0.00E+00	0.00E+00	0.00E+00
XE-135M	3.82E-36	4.95E+02	4.33E+02	0.00E+00	0.00E+00	0.00E+00	1.05E-03	2.22E-02	0.00E+00	0.00E+00	0.00E+00
XE-135	2.37E-33	3.07E+05	2.10E+04	0.00E+00	0.00E+00	0.00E+00	2.96E-02	3.57E-02	0.00E+00	0.00E+00	0.00E+00
XE-138	2.24E-35	2.89E+03	1.82E+03	0.00E+00	0.00E+00	0.00E+00	3.01E-02	7.72E-03	0.00E+00	0.00E+00	0.00E+00
KR-83M	1.09E-34	1.40E+04	1.21E+03	0.00E+00	0.00E+00	0.00E+00	3.49E-05	2.18E-04	0.00E+00	0.00E+00	0.00E+00
KR-85M	4.16E-34	5.38E+04	3.92E+03	0.00E+00	0.00E+00	0.00E+00	3.52E-03	4.83E-03	0.00E+00	0.00E+00	0.00E+00
KR-85	1.92E-35	2.48E+03	1.60E+02	0.00E+00	0.00E+00	0.00E+00	1.93E-06	1.89E-04	0.00E+00	0.00E+00	0.00E+00
KR-87	3.68E-34	4.76E+04	4.78E+03	0.00E+00	0.00E+00	0.00E+00	3.78E-02	2.66E-02	0.00E+00	0.00E+00	0.00E+00
KR-88	9.51E-34	1.23E+05	9.63E+03	0.00E+00	0.00E+00	0.00E+00	9.65E-02	1.74E-02	0.00E+00	0.00E+00	0.00E+00
TOTAL DOSES 0-30 DAYS				0.00E+00	2.11E+00	9.13E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

1

QDC CRDA, EAB, ALL REL AOG: TID-14844: 6 s - 2 h

ISOTOPE	ACTIVITY RELEASED (CURIES)	
	2. HRS	
ELEMENTAL		
I-131	0.00E+00	0.00E+00
I-132	0.00E+00	0.00E+00
I-133	0.00E+00	0.00E+00
I-134	0.00E+00	0.00E+00
I-135	0.00E+00	0.00E+00
PARTICULATE		
I-131	0.00E+00	0.00E+00
I-132	0.00E+00	0.00E+00
I-133	0.00E+00	0.00E+00
I-134	0.00E+00	0.00E+00
I-135	0.00E+00	0.00E+00
ORGANIC		
I-131	0.00E+00	0.00E+00

I-132 0.00E+00 0.00E+00  
I-133 0.00E+00 0.00E+00  
I-134 0.00E+00 0.00E+00  
I-135 0.00E+00 0.00E+00

## NOBLE GASES

XE-131M 1.11E+02 1.11E+02  
XE-133M 8.51E+02 8.51E+02  
XE-133 3.37E+04 3.37E+04  
XE-135M 1.95E+03 1.95E+03  
XE-135 2.97E+04 2.97E+04  
XE-138 7.05E+03 7.05E+03  
KR-83M 1.89E+03 1.89E+03  
KR-85M 5.69E+03 5.69E+03  
KR-85 2.21E+02 2.21E+02  
KR-87 7.92E+03 7.92E+03  
KR-88 1.44E+04 1.44E+04

END EXECUTION DATE: 11/18/1999  
END EXECUTION TIME: 16:56:19.05

AXIDENT VER 2 MOD 4  
PRODUCTION DATE 02/18/92  
BEGIN EXECUTION DATE: 11/18/1999  
BEGIN EXECUTION TIME: 16:56:34.21

1 QDC CRDA, EAB, ALL REL GLAND: TID-14844: 0 - 2 h  
2 3 2 1. 1.  
3 -2561 2.60+6 1:845+5 5.83+4  
4 0. 0. 1. 1. 2.78+5 0.  
5 6 1800 7200  
6 0.2402 2\*1.201E-2  
7 3\*1.  
8 3\*1.  
9 3\*0.  
10 2\*2.9e-4 2.3E-5  
11 3\*0.  
12 3\*0.  
13 3\*0.  
14 3\*0.  
15 3\*0.  
16 3\*0.  
17 3\*0.  
18 3\*0.  
19 3\*0.  
20 3\*0.  
21 6\*1.  
22 3\*1.  
23 7.16E+3 1.06E+4 1.65E+4 1.92E+4 1.52E+4 1.36E+3 1.05E+4 4.13E+5  
24 1.11E+5 3.89E+5 3.65E+5 3.21E+4 8.04E+4 2.70E+3 1.55E+5 2.20E+5

1

ODC CRDA. EAB. ALL REL GLAND: TID-14844: 0 - 2 h

## INITIAL CONTAINMENT INVENTORY

ISOTOPE	ACTIVITY (CURIES)
I-131	7.160E+03
I-132	1.060E+04
I-133	1.650E+04
I-134	1.920E+04
I-135	1.520E+04
XE-131M	1.360E+03
XE-133M	1.050E+04
XE-133	4.130E+05
XE-135M	1.110E+05
XE-135	3.890E+05
XE-138	3.650E+05
KR-83M	3.210E+04
KR-85M	8.040E+04
KR-85	2.700E+03
KR-87	1.550E+05
KR-88	2.200E+05

1

ODC CRDA, EAB, ALL REL GLAND: TID-14844: 0 - 2 h

ANALYSIS BASED ON: 2561 MWt 184500 FT<sup>3</sup> CONT CENTER VOLUME, 58300 FT<sup>3</sup> CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO SPRAYED

AT	.002 HOURS:	X/Q(SITE) = .29E-03 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM INTAKE= .0
CFM		X/Q CONT ROOM= .00E+00 SEC/M3	SEC RELEASE RATE= .86E+05 VOL/DAY	PCT PRI LKG TO ATM =
00.00				

CLEANUP RATES (HR-1)				FILTER NON-REMPTION FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
.000	.000	.000	.000	1.000	1.000
.000	.000	.000	.000	1.000	1.000
.000	.000	.000	.000	1.000	1.000

ACTIVITY (CURIES)		CONTROL ROOM	SITE BOUNDARY DOSES (REM)	CONTROL ROOM DOSES (REM)
ISOTOPE	PRIMARY RELEASE	(CURIES) (UCI/CM3)	THYROID WH BODY BETA	THYROID WH BODY BETA

<b>ELEMENTAL</b>														
I-131	3.85E+02	1.21E+02	1.12E+03	0.00E+00	0.00E+00	1.67E+02	3.02E-02	1.48E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00		
S-32	5.59E+02	1.38E+02	1.56E+03	0.00E+00	0.00E+00	8.95E+00	2.89E-01	4.97E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00		

I-133	8.88E+02	2.78E+02	2.59E+03	0.00E+00	0.00E+00	1.04E+02	8.95E-02	7.30E-02	0.00E+00	0.00E+00	0.00E+00
I-134	1.03E+03	3.23E+02	3.01E+03	0.00E+00	0.00E+00	7.57E+00	4.23E-01	9.13E-02	0.00E+00	0.00E+00	0.00E+00
I-135	8.18E+02	2.56E+02	2.38E+03	0.00E+00	0.00E+00	2.97E+01	3.07E-01	4.90E-02	0.00E+00	0.00E+00	0.00E+00
PARTICULATE											
I-131	2.12E+01	6.63E+00	6.17E+01	0.00E+00	0.00E+00	9.19E+00	1.66E-03	8.11E-04	0.00E+00	0.00E+00	0.00E+00
I-132	3.13E+01	9.80E+00	9.13E+01	0.00E+00	0.00E+00	4.92E-01	1.59E-02	2.73E-03	0.00E+00	0.00E+00	0.00E+00
I-133	4.88E+01	1.53E+01	1.42E+02	0.00E+00	0.00E+00	5.72E+00	4.92E-03	4.01E-03	0.00E+00	0.00E+00	0.00E+00
I-134	5.67E+01	1.77E+01	1.65E+02	0.00E+00	0.00E+00	4.16E-01	2.32E-02	5.02E-03	0.00E+00	0.00E+00	0.00E+00
I-135	4.50E+01	1.41E+01	1.31E+02	0.00E+00	0.00E+00	1.63E+00	1.69E-02	2.69E-03	0.00E+00	0.00E+00	0.00E+00
ORGANIC											
I-131	1.69E+01	5.30E+00	4.94E+01	0.00E+00	0.00E+00	7.35E+00	1.33E-03	6.49E-04	0.00E+00	0.00E+00	0.00E+00
I-132	2.51E+01	7.84E+00	7.31E+01	0.00E+00	0.00E+00	3.93E-01	1.27E-02	2.18E-03	0.00E+00	0.00E+00	0.00E+00
I-133	3.90E+01	1.22E+01	1.14E+02	0.00E+00	0.00E+00	4.58E+00	3.93E-03	3.21E-03	0.00E+00	0.00E+00	0.00E+00
I-134	4.54E+01	1.42E+01	1.32E+02	0.00E+00	0.00E+00	3.33E-01	1.86E-02	4.01E-03	0.00E+00	0.00E+00	0.00E+00
I-135	3.60E+01	1.13E+01	1.05E+02	0.00E+00	0.00E+00	1.31E+00	1.35E-02	2.15E-03	0.00E+00	0.00E+00	0.00E+00
NOBLE GASES											
XE-131M	3.22E+02	1.01E+02	9.37E+02	0.00E+00	0.00E+00	0.00E+00	1.50E-03	8.44E-03	0.00E+00	0.00E+00	0.00E+00
XE-133M	2.48E+03	7.77E+02	7.24E+03	0.00E+00	0.00E+00	0.00E+00	1.73E-02	7.48E-02	0.00E+00	0.00E+00	0.00E+00
XE-133	9.77E+04	3.06E+04	2.85E+05	0.00E+00	0.00E+00	0.00E+00	6.19E+00	2.77E+00	0.00E+00	0.00E+00	0.00E+00
XE-135M	2.62E+04	8.18E+03	7.64E+04	0.00E+00	0.00E+00	0.00E+00	2.34E+00	4.94E-01	0.00E+00	0.00E+00	0.00E+00
XE-135	9.20E+04	2.88E+04	2.68E+05	0.00E+00	0.00E+00	0.00E+00	4.78E+00	5.76E+00	0.00E+00	0.00E+00	0.00E+00
XE-138	8.60E+04	2.69E+04	2.51E+05	0.00E+00	0.00E+00	0.00E+00	5.23E+01	1.34E+01	0.00E+00	0.00E+00	0.00E+00
KR-83M	7.59E+03	2.37E+03	2.21E+04	0.00E+00	0.00E+00	0.00E+00	8.02E-03	5.02E-02	0.00E+00	0.00E+00	0.00E+00
KR-85M	1.90E+04	5.95E+03	5.54E+04	0.00E+00	0.00E+00	0.00E+00	6.27E-01	8.61E-01	0.00E+00	0.00E+00	0.00E+00
KR-85	6.39E+02	2.00E+02	1.86E+03	0.00E+00	0.00E+00	0.00E+00	2.83E-04	2.77E-02	0.00E+00	0.00E+00	0.00E+00
KR-87	3.66E+04	1.15E+04	1.07E+05	0.00E+00	0.00E+00	0.00E+00	1.06E+01	7.48E+00	0.00E+00	0.00E+00	0.00E+00
KR-88	5.20E+04	1.63E+04	1.52E+05	0.00E+00	0.00E+00	0.00E+00	1.92E+01	3.45E+00	0.00E+00	0.00E+00	0.00E+00

1

QDC CRDA, EAB, ALL REL GLAND: TID-14844: 0 - 2 h

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO SPRAYED

VOL

AT	.500 HOURS:	X/Q(SITE)= .29E-03 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM INTAKE= .0
CFM				
	X/Q CONT ROOM= .00E+00 SEC/M3	SEC RELEASE RATE= .86E+05 VOL/DAY	PCT PRI LKG TO ATM =	
00.00				

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM (CURIES) (UCI/CM3)	SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)	
	ELEMENTAL	PARTICULATE	ORGANIC		SPRAY	PRIMARY	SECONDARY		
					RELEASE	CONT CENTER			
I-131	1.69E-07	2.05E-09	5.06E+02	0.00E+00	0.00E+00	7.54E+01	1.36E-02	6.65E-03	
I-132	2.16E-07	2.62E-09	7.45E+02	0.00E+00	0.00E+00	4.01E+01	1.30E-01	2.23E-02	
I-133	3.84E-07	4.67E-09	1.17E+03	0.00E+00	0.00E+00	4.69E+01	4.03E-02	3.29E-02	
I-134	3.04E-07	3.70E-09	1.34E+03	0.00E+00	0.00E+00	3.36E+00	1.88E-01	4.06E-02	
I-135	3.41E-07	4.15E-09	1.07E+03	0.00E+00	0.00E+00	1.34E+01	1.38E-01	2.20E-02	
PARTICULATE									
I-131	9.29E-09	1.13E-10	2.78E+01	0.00E+00	0.00E+00	4.14E+00	7.48E-04	3.65E-04	
I-132	1.18E-08	1.44E-10	4.09E+01	0.00E+00	0.00E+00	2.20E-01	7.12E-03	1.22E-03	
I-133	2.11E-08	2.56E-10	6.40E+01	0.00E+00	0.00E+00	2.58E+00	2.21E-03	1.81E-03	
I-134	1.67E-08	2.03E-10	7.34E+01	0.00E+00	0.00E+00	1.85E+01	1.03E-02	2.23E-03	
I-135	1.88E-08	2.28E-10	5.89E+01	0.00E+00	0.00E+00	7.35E-01	7.60E-03	1.21E-03	
ORGANIC									
I-131	7.43E-09	9.03E-11	2.22E+01	0.00E+00	0.00E+00	3.31E+00	5.98E-04	2.92E-04	
I-132	9.48E-09	1.15E-10	3.27E+01	0.00E+00	0.00E+00	1.76E-01	5.70E-03	9.78E-04	
I-133	1.69E-08	2.05E-10	5.12E+01	0.00E+00	0.00E+00	2.06E+00	1.77E-03	1.45E-03	
I-134	1.34E-08	1.63E-10	5.87E+01	0.00E+00	0.00E+00	1.48E-01	8.26E-03	1.78E-03	
I-135	1.50E-08	1.82E-10	4.71E+01	0.00E+00	0.00E+00	5.88E-01	6.08E-03	9.68E-04	
NOBLE GASES									
XE-131M	1.41E-07	1.72E-09	4.22E+02	0.00E+00	0.00E+00	0.00E+00	6.74E-04	3.80E-03	
XE-133M	1.08E-06	1.32E-08	3.26E+03	0.00E+00	0.00E+00	0.00E+00	7.80E-03	3.37E-02	
XE-133	4.28E-05	5.20E-07	1.28E+05	0.00E+00	0.00E+00	0.00E+00	2.79E-01	1.25E+00	
XE-135M	3.05E-06	3.70E-08	3.28E+04	0.00E+00	0.00E+00	0.00E+00	1.00E+00	2.12E-01	
XE-135	3.89E-05	4.73E-07	1.21E+05	0.00E+00	0.00E+00	0.00E+00	2.15E+00	2.59E+00	
XE-138	1.16E-05	1.41E-07	1.08E+05	0.00E+00	0.00E+00	0.00E+00	2.26E+01	5.78E+00	
KR-83M	2.77E-06	3.37E-08	9.90E+03	0.00E+00	0.00E+00	0.00E+00	3.59E-03	2.25E-02	
KR-85M	7.72E-06	9.39E-08	2.49E+04	0.00E+00	0.00E+00	0.00E+00	2.82E-01	3.87E-01	
KR-85	2.81E-07	3.41E-09	8.39E+02	0.00E+00	0.00E+00	0.00E+00	1.28E-04	1.25E-02	
KR-87	1.23E-05	1.49E-07	4.76E+04	0.00E+00	0.00E+00	0.00E+00	4.75E+00	3.34E+00	

KR-88	2.02E-05	2.46E-07	6.80E+04	0.00E+00	0.00E+00	0.00E+00	8.60E+00	1.55E+00	0.00E+00	0.00E+00	0.00E+00
							-----	-----	-----	-----	-----
							1.57E+02	4.02E+01	1.53E+01	0.00E+00	0.00E+00

1 QDC CRDA, EAB, ALL REL GLAND: TID-14844: 0 - 2 h

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
 1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO SPRAYED  
 VOL

AT	2.000 HOURS:	X/Q(SITE)= .23E-04 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM INTAKE= .0
CFM				
		X/Q CONT ROOM= .00E+00 SEC/M3	SEC RELEASE RATE= .86E+05 VOL/DAY	PCT PRI LKG TO ATM =
		00.00		

	CLEANUP RATES (HR-1)			FILTER NON-REMOVAL FACTORS		
	SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM		SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA
<b>ELEMENTAL</b>											
I-131	1.15E-35	1.40E-37	1.71E-07	0.00E+00	0.00E+00	2.02E-09	3.65E-13	1.78E-13	0.00E+00	0.00E+00	0.00E+00
I-132	9.37E-36	1.14E-37	2.17E-07	0.00E+00	0.00E+00	9.25E-11	2.99E-12	5.14E-13	0.00E+00	0.00E+00	0.00E+00
I-133	2.49E-35	3.03E-37	3.88E-07	0.00E+00	0.00E+00	1.24E-09	1.06E-12	8.69E-13	0.00E+00	0.00E+00	0.00E+00
I-134	6.27E-36	7.62E-38	3.03E-07	0.00E+00	0.00E+00	6.04E-11	3.37E-12	7.28E-13	0.00E+00	0.00E+00	0.00E+00
I-135	2.00E-35	2.43E-37	3.45E-07	0.00E+00	0.00E+00	3.41E-10	3.53E-12	5.62E-13	0.00E+00	0.00E+00	0.00E+00
<b>PARTICULATE</b>											
I-131	6.31E-37	7.67E-39	9.40E-09	0.00E+00	0.00E+00	1.11E-10	2.00E-14	9.79E-15	0.00E+00	0.00E+00	0.00E+00
I-132	5.15E-37	6.26E-39	1.19E-08	0.00E+00	0.00E+00	5.08E-12	1.64E-13	2.82E-14	0.00E+00	0.00E+00	0.00E+00
I-133	1.37E-36	1.67E-38	2.13E-08	0.00E+00	0.00E+00	6.81E-11	5.85E-14	4.77E-14	0.00E+00	0.00E+00	0.00E+00
I-134	3.44E-37	4.19E-39	1.66E-08	0.00E+00	0.00E+00	3.32E-12	1.85E-13	4.00E-14	0.00E+00	0.00E+00	0.00E+00
I-135	1.10E-36	1.33E-38	1.89E-08	0.00E+00	0.00E+00	1.87E-11	1.94E-13	3.09E-14	0.00E+00	0.00E+00	0.00E+00
<b>ORGANIC</b>											
I-131	5.05E-37	6.13E-39	7.52E-09	0.00E+00	0.00E+00	8.88E-11	1.60E-14	7.84E-15	0.00E+00	0.00E+00	0.00E+00
I-132	4.12E-37	5.01E-39	9.53E-09	0.00E+00	0.00E+00	4.07E-12	1.31E-13	2.26E-14	0.00E+00	0.00E+00	0.00E+00
I-133	1.10E-36	1.33E-38	1.71E-08	0.00E+00	0.00E+00	5.45E-11	4.68E-14	3.82E-14	0.00E+00	0.00E+00	0.00E+00
I-134	2.76E-37	3.35E-39	1.33E-08	0.00E+00	0.00E+00	2.65E-12	1.48E-13	3.20E-14	0.00E+00	0.00E+00	0.00E+00
I-135	8.77E-37	1.07E-38	1.52E-08	0.00E+00	0.00E+00	1.50E-11	1.55E-13	2.47E-14	0.00E+00	0.00E+00	0.00E+00
<b>NOBLE GASES</b>											
XE-131M	9.60E-36	1.17E-37	1.43E-07	0.00E+00	0.00E+00	0.00E+00	1.81E-14	1.02E-13	0.00E+00	0.00E+00	0.00E+00
XE-133M	7.26E-35	8.83E-37	1.10E-06	0.00E+00	0.00E+00	0.00E+00	2.08E-13	9.00E-13	0.00E+00	0.00E+00	0.00E+00
XE-133	2.90E-33	3.52E-35	4.33E-05	0.00E+00	0.00E+00	0.00E+00	7.47E-12	3.35E-11	0.00E+00	0.00E+00	0.00E+00
XE-135M	3.82E-36	4.65E-38	2.90E-06	0.00E+00	0.00E+00	0.00E+00	7.05E-12	1.49E-12	0.00E+00	0.00E+00	0.00E+00
XE-135	2.37E-33	2.88E-35	3.93E-05	0.00E+00	0.00E+00	0.00E+00	5.56E-11	6.70E-11	0.00E+00	0.00E+00	0.00E+00
XE-138	2.24E-35	2.72E-37	1.11E-05	0.00E+00	0.00E+00	0.00E+00	1.83E-10	4.70E-11	0.00E+00	0.00E+00	0.00E+00
KR-83M	1.09E-34	1.32E-36	2.78E-06	0.00E+00	0.00E+00	0.00E+00	8.00E-14	5.00E-13	0.00E+00	0.00E+00	0.00E+00
KR-85M	4.16E-34	5.06E-36	7.79E-06	0.00E+00	0.00E+00	0.00E+00	6.99E-12	9.60E-12	0.00E+00	0.00E+00	0.00E+00
KR-85	1.92E-35	2.33E-37	2.84E-07	0.00E+00	0.00E+00	0.00E+00	3.43E-15	3.35E-13	0.00E+00	0.00E+00	0.00E+00
KR-87	3.68E-34	4.48E-36	1.22E-05	0.00E+00	0.00E+00	0.00E+00	9.68E-11	6.80E-11	0.00E+00	0.00E+00	0.00E+00
KR-88	9.51E-34	1.16E-35	2.03E-05	0.00E+00	0.00E+00	0.00E+00	2.04E-10	3.67E-11	0.00E+00	0.00E+00	0.00E+00
							4.12E-09	5.74E-10	2.68E-10	0.00E+00	0.00E+00
TOTAL DOSES 0-30 DAYS							5.06E+02	1.32E+02	5.00E+01	0.00E+00	0.00E+00

1

QDC CRDA, EAB, ALL REL GLAND: TID-14844: 0 - 2 h

ISOTOPE	ACTIVITY RELEASED (CURIES)	
	2. HRS	
<b>ELEMENTAL</b>		
I-131	1.63E+03	1.63E+03
I-132	2.41E+03	2.41E+03
I-133	3.75E+03	3.75E+03
I-134	4.35E+03	4.35E+03
I-135	3.46E+03	3.46E+03
<b>PARTICULATE</b>		
I-131	8.95E+01	8.95E+01
I-132	1.32E+02	1.32E+02
I-133	2.06E+02	2.06E+02
I-134	2.39E+02	2.39E+02
I-135	1.90E+02	1.90E+02
<b>ORGANIC</b>		
I-131	7.16E+01	7.16E+01

QDC 9400-M-0550 Rev. 0

## Attachment G

I-132	1.06E+02	1.06E+02
I-133	1.65E+02	1.65E+02
I-134	1.91E+02	1.91E+02
I-135	1.52E+02	1.52E+02
NOBLE GASES		
XE-131M	1.36E+03	1.36E+03
XE-133M	1.05E+04	1.05E+04
XE-133	4.13E+05	4.13E+05
XE-135M	1.09E+05	1.09E+05
XE-135	3.89E+05	3.89E+05
XE-138	3.60E+05	3.60E+05
KR-83M	3.20E+04	3.20E+04
KR-85M	8.03E+04	8.03E+04
KR-85	2.70E+03	2.70E+03
KR-87	1.54E+05	1.54E+05
KR-88	2.20E+05	2.20E+05

END EXECUTION DATE: 11/18/1999  
END EXECUTION TIME: 16:56:34.26

AXIDENT VER 2 MOD 4  
 PRODUCTION DATE 02/18/92  
 BEGIN EXECUTION DATE: 11/18/1999  
 BEGIN EXECUTION TIME: 17:18:57.35

1 QDC CRDA, CR & LPZ, ALL REL MVP: SIEMENS 20 GWD/MTU: 0 - 6 s  
 2 2 2 1. 1.  
 3 -2561 2.60+6 1.845+5 5.83+4  
 4 0. 0. 1. 1. 2.78+5 0.  
 5 6 2.592E6  
 6 0.2402 0.  
 7 9.058E-4 0.  
 8 2\*1.  
 9 2\*2460  
 10 3.2B-5 0.  
 11 7.00E-4 0.  
 12 2\*0.  
 13 2\*0.  
 14 2\*0.  
 15 2\*0.  
 16 2\*0.  
 17 2\*0.  
 18 2\*0.  
 19 2\*0.  
 20 2\*0.  
 21 6\*1.  
 22 3\*1.  
 23 6.76E+3 9.73E+3 1.36E+4 1.57E+4 1.22E+4 1.21E+3 8.18E+3 3.40E+5  
 24 9.21E+4 1.12E+5 3.07E+5 1.82E+4 4.99E+4 2.28E+3 9.80E+4 1.42E+5

1

QDC CRDA, CR &amp; LPZ, ALL REL MVP: SIEMENS 20 GWD/MTU: 0 - 6 s

## INITIAL CONTAINMENT INVENTORY

ISOTOPE	ACTIVITY (CURIES)
I-131	6.760E+03
I-132	9.730E+03
I-133	1.360E+04
I-134	1.570E+04
I-135	1.220E+04
XE-131M	1.210E+03
XE-133M	8.180E+03
XE-133	3.400E+05
XE-135M	9.210E+04
XE-135	1.120E+05
XE-138	3.070E+05
KR-83M	1.820E+04
KR-85M	4.990E+04
KR-85	2.280E+03
KR-87	9.800E+04
KR-88	1.420E+05

1

QDC CRDA, CR &amp; LPZ, ALL REL MVP: SIEMENS 20 GWD/MTU: 0 - 6 s

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
 1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO

## SPRAYED VOL

AT .002 HOURS:	X/Q(SITE)= .32E-04 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM
INTAKE=2460.0 CFM			
	X/Q CONT ROOM= .70E-03 SEC/M3	SEC RELEASE RATE= .78E+02 VOL/DAY	PCT PRI LKG TO ATM =
00.00			

ISOTOPE	CLEANUP RATES (HR-1)			FILTER NON-REMOVAL FACTORS		
	SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM		SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA
ELEMENTAL											
I-131	3.64E+02	1.17E+03	3.92E+00	3.19E-03	6.10E-07	6.45E-02	1.16E-05	5.69E-06	6.94E-04	4.48E-09	6.13E-08
I-132	5.24E+02	1.68E+03	5.65E+00	4.58E-03	8.78E-07	3.35E-03	1.08E-04	1.86E-05	3.61E-05	3.61E-08	2.00E-07
I-133	7.32E+02	2.35E+03	7.89E+00	6.41E-03	1.23E-06	3.51E-02	3.01E-05	2.46E-05	3.78E-04	1.45E-08	2.65E-07
I-134	8.44E+02	2.71E+03	9.10E+00	7.39E-03	1.41E-06	2.53E-03	1.41E-04	3.05E-05	2.72E-05	6.24E-08	3.28E-07

I-135	6.57E+02	2.11E+03	7.08E+00	5.75E-03	1.10E-06	9.75E-03	1.01E-04	1.60E-05	1.05E-04	2.64E-08	1.73E-07
<b>PARTICULATE</b>											
I-131	2.00E+01	6.43E+01	2.16E-01	1.75E-04	3.35E-08	3.54E-03	6.40E-07	3.13E-07	3.82E-05	2.46E-10	3.37E-09
I-132	2.88E+01	9.25E+01	3.10E-01	2.52E-04	4.82E-08	1.84E-04	5.96E-06	1.02E-06	1.98E-06	1.98E-09	1.10E-08
I-133	4.02E+01	1.29E+02	4.34E-01	3.52E-04	6.74E-08	1.93E-03	1.65E-06	1.35E-06	2.07E-05	7.98E-10	1.45E-08
I-134	4.64E+01	1.49E+02	5.00E-01	4.06E-04	7.77E-08	1.39E-04	7.76E-06	1.68E-06	1.50E-06	3.43E-09	1.80E-08
I-135	3.61E+01	1.16E+02	3.89E-01	3.16E-04	6.05E-08	5.36E-04	5.54E-06	8.82E-07	5.77E-06	1.45E-09	9.50E-09
<b>ORGANIC</b>											
I-131	1.60E+01	5.14E+01	1.72E-01	1.40E-04	2.68E-08	2.83E-03	5.12E-07	2.50E-07	3.05E-05	1.97E-10	2.69E-09
I-132	2.30E+01	7.40E+01	2.48E-01	2.02E-04	3.86E-08	1.47E-04	4.76E-06	8.18E-07	1.59E-06	1.58E-09	8.81E-09
I-133	3.22E+01	1.03E+02	3.47E-01	2.82E-04	5.39E-08	1.54E-03	1.32E-06	1.08E-06	1.66E-05	6.38E-10	1.16E-08
I-134	3.71E+01	1.19E+02	4.00E-01	3.25E-04	6.22E-08	1.11E-04	6.21E-06	1.34E-06	1.20E-06	2.74E-09	1.44E-08
I-135	2.89E+01	9.28E+01	3.11E-01	2.53E-04	4.84E-08	4.28E-04	4.43E-06	7.05E-07	4.62E-06	1.16E-09	7.60E-09
<b>NOBLE GASES</b>											
XE-131M	2.86E+02	9.21E+02	3.09E+00	2.51E-03	4.80E-07	0.00E+00	5.43E-07	3.07E-06	0.00E+00	9.15E-10	3.30E-08
XE-133M	1.94E+03	6.22E+03	2.09E+01	1.70E-02	3.24E-06	0.00E+00	5.51E-06	2.38E-05	0.00E+00	2.73E-09	2.56E-07
XE-133	8.05E+04	2.59E+05	8.67E+02	7.05E-01	1.35E-04	0.00E+00	2.08E-04	9.32E-04	0.00E+00	2.54E-07	1.00E-05
XE-135M	2.17E+04	6.98E+04	2.34E+02	1.90E-01	3.64E-05	0.00E+00	7.91E-04	1.67E-04	0.00E+00	3.12E-07	1.80E-06
XE-135	2.65E+04	8.52E+04	2.85E+02	2.32E-01	4.44E-05	0.00E+00	5.62E-04	6.77E-04	0.00E+00	2.16E-07	7.29E-06
XE-138	7.24E+04	2.33E+05	7.81E+02	6.34E-01	1.21E-04	0.00E+00	1.79E-02	4.60E-03	0.00E+00	1.83E-06	4.95E-05
KR-83M	4.30E+03	1.38E+04	4.64E+01	3.77E-02	7.21E-06	0.00E+00	1.86E-06	1.16E-05	0.00E+00	1.09E-08	1.25E-07
KR-85M	1.18E+04	3.80E+04	1.27E+02	1.03E-01	1.98E-05	0.00E+00	1.59E-04	2.18E-04	0.00E+00	6.57E-08	2.35E-06
KR-85	5.40E+02	1.73E+03	5.82E+00	4.72E-03	9.04E-07	0.00E+00	9.77E-08	9.55E-06	0.00E+00	3.85E-11	1.03E-07
KR-87	2.32E+04	7.45E+04	2.50E+02	2.03E-01	3.88E-05	0.00E+00	2.75E-03	1.93E-03	0.00E+00	5.27E-07	2.08E-05
KR-88	3.36E+04	1.08E+05	3.62E+02	2.94E-01	5.63E-05	0.00E+00	5.05E-03	9.09E-04	0.00E+00	1.67E-06	9.79E-06

1

QDC CRDA, CR &amp; LPZ, ALL REL MVP: SIEMENS 20 GWD/MTU: 0 - 6 s

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CPM MIXING, 00.00 PCT REL TO

SPRAYED VOL

AT 720.000 HOURS:	X/Q(SITE)= .00E+00 SEC/M3	PRIMARY LEAK RATE= .000 PERCENT/DAY	CONTROL ROOM
INTAKE=2460.0 CFM			
	X/Q CONT ROOM= .00E+00 SEC/M3	SEC RELEASE RATE= .00E+00 VOL/DAY	PCT PRI LKG TO ATM =
00.00			

	CLEANUP RATES (HR-1)			FILTER NON-REMOVAL FACTORS		
	SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM			SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA	
<b>ELEMENTAL</b>												
I-131	2.75E+01	8.83E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.40E+00	9.05E-06	1.24E-04	
I-132	3.15E-92	1.01E-91	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.33E-02	5.32E-05	2.92E-06	
I-133	3.48E-08	1.12E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.36E-01	2.83E-05	5.16E-04	
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.76E-02	6.34E-05	3.33E-04	
I-135	3.24E-30	1.04E-29	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.89E-01	4.75E-05	3.11E-04	
<b>PARTICULATE</b>												
I-131	1.51E+00	4.85E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.71E-02	4.97E-07	6.80E-06	
I-132	1.73E-93	5.57E-93	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.93E-03	2.92E-06	1.62E-05	
I-133	1.91E-09	6.15E-09	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.04E-02	1.56E-06	2.83E-05	
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.52E-03	3.48E-06	1.83E-05	
I-135	1.78E-31	5.72E-31	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.04E-02	2.61E-06	1.71E-05	
<b>ORGANIC</b>												
I-131	1.21E+00	3.88E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.17E-02	3.98E-07	5.44E-06	
I-132	1.39E-93	4.46E-93	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.34E-03	2.34E-06	1.30E-05	
I-133	1.53E-09	4.92E-09	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.24E-02	1.24E-06	2.27E-05	
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.21E-03	2.79E-06	1.47E-05	
I-135	1.42E-31	4.57E-31	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.30E-03	2.09E-06	1.37E-05	
<b>NOBLE GASES</b>												
XE-131M	4.93E+01	1.58E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.85E-06	6.69E-05	
XE-133M	1.95E-01	6.28E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.45E-06	5.12E-04	
XE-133	1.57E+03	5.03E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.12E-04	2.02E-02	
XE-135M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.46E-04	8.43E-04	
XE-135	4.69E-20	1.51E-19	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.01E-04	1.35E-02	
XE-138	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.34E-04	2.53E-02	
KR-83M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.52E-05	1.73E-04	
KR-85M	5.85E-46	1.88E-45	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.11E-04	3.99E-03	
KR-85	5.37E+02	1.73E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.52E-02	2.09E-04	
KR-87	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.36E-04	2.51E-02	
KR-88	1.20E-73	3.85E-73	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.58E-03	1.52E-02	

0.00E+00 0.00E+00 0.00E+00 2.65E+00 5.57E-03 1.07E-01

1

QDC CRDA, CR &amp; LPZ, ALL REL MVP: SIEMENS 20 GWD/MTU: 0 - 6 s

ISOTOPE	0. HRS	720. HRS	ACTIVITY RELEASED (CURIES)
ELEMENTAL			
I-131	3.92E+00	0.00E+00	3.92E+00
I-132	5.65E+00	0.00E+00	5.65E+00
I-133	7.89E+00	0.00E+00	7.89E+00
I-134	9.10E+00	0.00E+00	9.10E+00
I-135	7.08E+00	0.00E+00	7.08E+00
PARTICULATE			
I-131	2.16E-01	0.00E+00	2.16E-01
I-132	3.10E-01	0.00E+00	3.10E-01
I-133	4.34E-01	0.00E+00	4.34E-01
I-134	5.00E-01	0.00E+00	5.00E-01
I-135	3.89E-01	0.00E+00	3.89E-01
ORGANIC			
I-131	1.72E-01	0.00E+00	1.72E-01
I-132	2.48E-01	0.00E+00	2.48E-01
I-133	3.47E-01	0.00E+00	3.47E-01
I-134	4.00E-01	0.00E+00	4.00E-01
I-135	3.11E-01	0.00E+00	3.11E-01
NOBLE GASES			
XE-131M	3.09E+00	0.00E+00	3.09E+00
XE-133M	2.09E+01	0.00E+00	2.09E+01
XE-133	8.67E+02	0.00E+00	8.67E+02
XE-135M	2.34E+02	0.00E+00	2.34E+02
XE-135	2.86E+02	0.00E+00	2.86E+02
XE-138	7.81E+02	0.00E+00	7.81E+02
KR-83M	4.64E+01	0.00E+00	4.64E+01
KR-85M	1.27E+02	0.00E+00	1.27E+02
KR-85	5.82E+00	0.00E+00	5.82E+00
KR-87	2.50E+02	0.00E+00	2.50E+02
KR-88	3.62E+02	0.00E+00	3.62E+02

END EXECUTION DATE: 11/18/1999  
 END EXECUTION TIME: 17:18:57.41

AXIDENT VER 2 MOD 4  
PRODUCTION DATE 02/18/92  
BEGIN EXECUTION DATE: 11/18/1999  
BEGIN EXECUTION TIME: 17:19:27.23

```

1 QDC CRDA, CR & LPZ, ALL REL AOG: SIEMENS 20 GWD/MTU: 6 s - 30 d
2 6 2 1. 1.
3 -2561 2.60+6 1.845+5 5.83+4
4 0. 0. 1. 1. 2.78+5 0.
5 6 1800 7200 2.88+4 8.64+4 2.592E6
6 0.2402 4*1.201E-2 0.
7 9.058E-4 4*1.157E-5 0.
8 6*1.
9 6*2460
10 0. 3.2E-5 2*9.0E-6 3.0E-6 0.
11 0. 2*7.00E-4 6.45E-6 3.81E-6 0.
12 6*0.
13 6*0.
14 6*0.
15 6*0.
16 6*0.
17 6*0.
18 6*0.
19 6*0.
20 6*0.
21 3*0. 3*1.
22 3*1.
23 6.76E+3 9.73E+3 1.36E+4 1.57E+4 1.22E+4 1.21E+3 8.18E+3 3.40E+5
24 9.21E+4 1.12E+5 3.07E+5 1.82E+4 4.99E+4 2.28E+3 9.80E+4 1.42E+5

```

1

QDC CRDA, CR & LPZ, ALL REL AOG: SIEMENS 20 GWD/MTU: 6 s - 30 d

## INITIAL CONTAINMENT INVENTORY

ISOTOPE	ACTIVITY (CURIOS)
I-131	6.760E+03
I-132	9.730E+03
I-133	1.360E+04
I-134	1.570E+04
I-135	1.220E+04
XE-131M	1.210E+03
XE-133M	8.180E+03
XE-133	3.400E+05
XE-135M	9.210E+04
XE-135	1.120E+05
XE-138	3.070E+05
KR-83M	1.820E+04
KR-85M	4.990E+04
KR-85	2.280E+03
KR-87	9.800E+04
KR-88	1.420E+05

1 QDC CRDA, CR & LPZ, ALL REL AOG: SIEMENS 20 GWD/MTU: 6 S - 30 G

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
SPRAYED VOL 1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO

AT .002 HOURS: X/Q(SITE)= .00E+00 SEC/M3 PRIMARY LEAK RATE=\*\*\*\*\* PERCENT/DAY CONTROL ROOM  
 INTAKE=2460.0 CFM  
 00.00 X/Q CONT ROOM= .00E+00 SEC/M3 SEC RELEASE RATE= .78E+02 VOL/DAY PCT PRI LKG TO ATM =

	CLEANUP RATES (HR-1)			FILTER NON-REMPTION FACTORS	
	SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE
ELEMENTAL	.000	.000	.000	.000	.000
PARTICULATE	.000	.000	.000	.000	.000
ORGANIC	.000	.000	.000	.000	.000

I-135	6.57E+02	2.11E+03	0.00E+00										
<b>PARTICULATE</b>													
I-131	2.00E+01	6.43E+01	0.00E+00										
I-132	2.88E+01	9.25E+01	0.00E+00										
I-133	4.02E+01	1.29E+02	0.00E+00										
I-134	4.64E+01	1.49E+02	0.00E+00										
I-135	3.61E+01	1.16E+02	0.00E+00										
<b>ORGANIC</b>													
I-131	1.60E+01	5.14E+01	0.00E+00										
I-132	2.30E+01	7.40E+01	0.00E+00										
I-133	3.22E+01	1.03E+02	0.00E+00										
I-134	3.71E+01	1.19E+02	0.00E+00										
I-135	2.89E+01	9.28E+01	0.00E+00										
<b>NOBLE GASES</b>													
XE-131M	2.86E+02	9.21E+02	3.09E+00	0.00E+00									
XE-133M	1.94E+03	6.22E+03	2.90E+01	0.00E+00									
XE-133	8.05E+04	2.59E+05	8.67E+02	0.00E+00									
XE-135M	2.17E+04	6.98E+04	2.34E+02	0.00E+00									
XE-135	2.65E+04	8.52E+04	2.86E+02	0.00E+00									
XE-138	7.24E+04	2.33E+05	7.81E+02	0.00E+00									
KR-83M	4.30E+03	1.38E+04	4.64E+01	0.00E+00									
KR-85M	1.18E+04	3.80E+04	1.27E+02	0.00E+00									
KR-85	5.40E+02	1.73E+03	5.82E+00	0.00E+00									
KR-87	2.32E+04	7.45E+04	2.50E+02	0.00E+00									
KR-88	3.36E+04	1.08E+05	3.62E+02	0.00E+00									
									0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

1 QDC CRDA, CR & LPZ, ALL REL AOG: SIEMENS 20 GWD/MTU: 6 s - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
SPRAYED VOL 1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO

AT .500 HOURS: X/Q(SITE)= .32E-04 SEC/M3 PRIMARY LEAK RATE=\*\*\*\*\* PERCENT/DAY CONTROL ROOM  
 INTAKE=2460.0 CFM

X/Q CONT ROOM= .70E-03 SEC/M3 SEC RELEASE RATE= .10E+01 VOL/DAY PCT PRI LKG TO ATM =  
 00.00

ACTIVITY (CURIOS)				CONTROL ROOM		SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
ISOTOPE	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA
<b>ELEMENTAL</b>											
I-131	1.60E-07	1.50E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	1.98E-07	1.86E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	3.16E-07	2.97E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	2.49E-07	2.34E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	2.74E-07	2.58E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>PARTICULATE</b>											
I-131	8.77E-09	8.24E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	1.09E-08	1.02E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	1.74E-08	1.63E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	1.37E-08	1.29E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	1.51E-08	1.42E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>ORGANIC</b>											
I-131	7.01E-09	6.59E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	8.70E-09	8.18E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	1.39E-08	1.31E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	1.09E-08	1.03E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	1.20E-08	1.13E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>NOBLE GASES</b>											
XE-131M	1.26E-07	1.18E+03	2.45E+01	1.64E-02	3.15E-06	0.00E+00	4.31E-06	2.44E-05	0.00E+00	2.57E-06	9.28E-05
XE-133M	8.45E-07	7.94E+03	1.65E+02	1.11E-01	2.12E-05	0.00E+00	4.36E-05	1.89E-04	0.00E+00	7.64E-06	7.18E-04
XE-133	3.52E-05	3.31E+05	6.88E+03	4.61E+00	8.83E-04	0.00E+00	1.65E-03	7.39E-03	0.00E+00	7.13E-04	2.82E-02
XE-135M	2.53E-06	2.38E+04	1.02E+03	3.31E-01	6.33E-05	0.00E+00	3.45E-03	7.30E-04	0.00E+00	3.85E-04	2.22E-03
XE-135	1.12E-05	1.05E+05	2.23E+03	1.47E+00	2.81E-04	0.00E+00	4.38E-03	5.28E-03	0.00E+00	5.93E-04	2.00E-02
XE-138	9.73E-06	9.14E+04	3.61E+03	1.27E+00	2.44E-04	0.00E+00	8.30E-02	2.13E-02	0.00E+00	2.45E-03	6.65E-02
KR-83M	1.57E-06	4.48E+04	3.36E+02	2.06E-01	3.94E-05	0.00E+00	1.35E-05	8.42E-05	0.00E+00	2.72E-05	3.12E-04
KR-85M	4.79E-06	4.51E+04	9.72E+02	6.27E-01	1.20E-04	0.00E+00	1.21E-03	1.67E-03	0.00E+00	1.76E-04	6.28E-03
KR-85	2.37E-07	2.23E+03	4.62E+01	3.10E-02	5.94E-06	0.00E+00	7.76E-07	7.58E-05	0.00E+00	1.08E-07	2.89E-04
KR-87	7.75E-06	7.28E+04	1.74E+03	1.01E+00	1.94E-04	0.00E+00	1.91E-02	1.34E-02	0.00E+00	1.24E-03	4.90E-02
KR-88	1.30E-05	1.23E+05	2.71E+03	1.71E+00	3.27E-04	0.00E+00	3.77E-02	6.79E-03	0.00E+00	4.32E-03	2.54E-02
						0.00E+00	1.51E-01	5.69E-02	0.00E+00	9.92E-03	1.99E-01

ODC CRDA, CR & LPZ, ALL REL AOG: SIEMENS 20 GWD/MTU: 6 s - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO

SPRAYED VOL

AT 2.000 HOURS:	X/Q(SITE)= .90E-05 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM
INTAKE=2460.0 CFM			
	X/Q CONT ROOM= .70E-03 SEC/M3	SEC RELEASE RATE= .10E+01 VOL/DAY	PCT PRI LKG TO ATM =
00.00			

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM (CURIES) (UCI/CM3)		SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA	THYROID	WH BODY
<b>ELEMENTAL</b>											
I-131	1.09E-35	1.40E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	8.60E-36	1.11E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	2.06E-35	2.66E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	5.13E-36	6.63E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	1.60E-35	2.07E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>PARTICULATE</b>											
I-131	5.95E-37	7.70E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	4.72E-37	6.11E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	1.13E-36	1.46E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	2.82E-37	3.64E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	8.80E-37	1.14E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>ORGANIC</b>											
I-131	4.76E-37	6.16E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	3.78E-37	4.89E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	9.04E-37	1.17E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	2.25E-37	2.91E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	7.04E-37	9.11E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>NOBLE GASES</b>											
XE-131M	8.55E-36	1.11E+03	7.14E+01	3.85E-02	7.36E-06	0.00E+00	3.53E-06	2.00E-05	0.00E+00	2.66E-05	9.60E-04
XE-133M	5.66E-35	7.32E+03	4.77E+02	2.55E-01	4.87E-05	0.00E+00	3.54E-05	1.53E-04	0.00E+00	7.82E-05	7.35E-03
XE-133	2.39E-33	3.09E+05	2.00E+04	1.07E+01	2.06E-03	0.00E+00	1.35E-03	6.04E-03	0.00E+00	7.35E-03	2.91E-01
XE-135M	3.17E-36	4.10E+02	3.59E+02	1.43E-02	2.73E-06	0.00E+00	3.41E-04	7.22E-05	0.00E+00	4.68E-04	2.70E-03
XE-135	6.83E-34	8.83E+04	6.04E+03	3.07E+00	5.88E-04	0.00E+00	3.34E-03	4.02E-03	0.00E+00	5.70E-03	1.92E-01
XE-138	1.88E-35	2.43E+03	1.53E+03	4.87E-02	1.62E-05	0.00E+00	9.90E-03	2.54E-03	0.00E+00	3.59E-03	9.72E-02
KR-83M	6.15E-35	7.96E+03	6.88E+02	2.77E-01	5.30E-05	0.00E+00	7.74E-06	4.84E-05	0.00E+00	1.96E-04	2.25E-03
KR-85M	2.58E-34	3.34E+04	2.43E+03	1.16E+00	2.23E-04	0.00E+00	8.54E-04	1.17E-03	0.00E+00	1.56E-03	5.56E-02
KR-85	1.62E-35	2.09E+03	1.35E+02	7.28E-02	1.39E-05	0.00E+00	6.38E-07	6.23E-05	0.00E+00	1.12E-06	3.00E-03
KR-87	2.33E-34	3.01E+04	3.02E+03	1.05E+00	2.01E-04	0.00E+00	9.35E-03	6.57E-03	0.00E+00	7.59E-03	2.99E-01
KR-88	6.14E-34	7.94E+04	6.21E+03	2.76E+00	5.29E-04	0.00E+00	2.44E-02	4.39E-03	0.00E+00	3.51E-02	2.06E-01

ODC CRDA, CR & LPZ, ALL REL AOG: SIEMENS 20 GWD/MTU: 6 s - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO

SPRAYED VOL

AT 8.000 HOURS: X/Q(SITE)= .90E-05 SEC/M3 PRIMARY LEAK RATE=\*\*\*\*\* PERCENT/DAY CONTROL ROOM  
INTAKE=2460.0 CFM  
X/Q CONT ROOM= .65E-05 SEC/M3 SEC RELEASE RATE= .10E+01 VOL/DAY PCT PRI LKG TO ATM =  
00.00

ELEMENTAL												
I-131	0.00E+00	1.07E+03	0.00E+00									
I-132	0.00E+00	1.42E+02	0.00E+00									
I-133	0.00E+00	1.70E+03	0.00E+00									
I-134	0.00E+00	4.27E+00	0.00E+00									
I-135	0.00E+00	8.68E+02	0.00E+00									
PARTICULATE												
I-131	0.00E+00	5.87E+01	0.00E+00									
I-132	0.00E+00	7.81E+00	0.00E+00									
I-133	0.00E+00	9.33E+01	0.00E+00									
I-134	0.00E+00	2.35E-01	0.00E+00									
I-135	0.00E+00	4.77E+01	0.00E+00									
ORGANIC												
I-131	0.00E+00	4.70E+01	0.00E+00									
I-132	0.00E+00	6.24E+00	0.00E+00									
I-133	0.00E+00	7.47E+01	0.00E+00									
I-134	0.00E+00	1.88E-01	0.00E+00									
I-135	0.00E+00	3.82E+01	0.00E+00									
NOBLE GASES												
XE-131M	0.00E+00	8.48E+02	2.43E+02	6.57E-04	1.26E-07	0.00E+00	1.20E-05	6.78E-05	0.00E+00	2.93E-05	1.06E-03	
XE-133M	0.00E+00	5.28E+03	1.56E+03	4.09E-03	7.83E-07	0.00E+00	1.16E-04	5.01E-04	0.00E+00	8.44E-05	7.93E-03	
XE-133	0.00E+00	2.33E+05	6.72E+04	1.80E-01	3.45E-05	0.00E+00	4.54E-03	2.03E-02	0.00E+00	8.04E-03	3.18E-01	
XE-135M	0.00E+00	3.65E-05	6.32E+00	2.83E-11	5.42E-15	0.00E+00	6.00E-06	1.27E-06	0.00E+00	1.10E-05	6.36E-05	
XE-135	0.00E+00	4.36E+04	1.58E+04	3.38E-02	6.47E-06	0.00E+00	8.76E-03	1.06E-02	0.00E+00	5.45E-03	1.84E-01	
XE-138	0.00E+00	1.22E-03	4.19E+01	9.45E-10	1.81E-13	0.00E+00	2.71E-04	6.94E-05	0.00E+00	1.25E-04	3.39E-03	
KR-83M	0.00E+00	6.70E+02	3.73E+02	5.19E-04	9.93E-08	0.00E+00	8.28E-06	5.18E-05	0.00E+00	1.13E-04	1.30E-03	
KR-85M	0.00E+00	1.01E+04	4.87E+03	7.83E-03	1.50E-06	0.00E+00	1.71E-03	2.35E-03	0.00E+00	1.28E-03	4.59E-02	
KR-85	0.00E+00	1.63E+03	4.63E+02	1.26E-03	2.42E-07	0.00E+00	2.19E-06	2.14E-04	0.00E+00	1.24E-06	3.31E-03	
KR-87	0.00E+00	8.80E+02	2.07E+03	6.81E-04	1.30E-07	0.00E+00	6.40E-03	4.49E-03	0.00E+00	3.33E-03	1.31E-01	
KR-88	0.00E+00	1.40E+04	9.42E+03	1.08E-02	2.08E-06	0.00E+00	3.69E-02	6.65E-03	0.00E+00	2.48E-02	1.46E-01	
						0.00E+00	5.88E-02	4.53E-02	0.00E+00	4.32E-02	8.42E-01	

1 QDC CRDA, CR & LPZ, ALL REL AOG: SIEMENS 20 GWD/MTU: 6 s - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO

SPRAYED VOL

AT 24.000 HOURS: X/Q(SITE)= .30E-05 SEC/M3 PRIMARY LEAK RATE=\*\*\*\*\* PERCENT/DAY CONTROL ROOM  
 INTAKE=2460.0 CFM  
 X/Q CONT ROOM= .38E-05 SEC/M3 SEC RELEASE RATE= .10E+01 VOL/DAY PCT PRI LKG TO ATM =  
 00.00

CLEANUP RATES (HR-1)				FILTER NON-REMPTION FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
.000	.000	.000	.000	.000	1.000
.000	.000	.000	.000	.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM		SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA
<b>ELEMENTAL</b>											
I-131	0.00E+00	5.18E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	0.00E+00	5.88E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	0.00E+00	5.14E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	0.00E+00	6.13E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	0.00E+00	8.54E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>PARTICULATE</b>											
I-131	0.00E+00	2.85E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	0.00E+00	3.23E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	0.00E+00	2.83E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	0.00E+00	3.37E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	0.00E+00	4.69E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>ORGANIC</b>											
I-131	0.00E+00	2.28E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	0.00E+00	2.58E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	0.00E+00	2.26E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	0.00E+00	2.70E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	0.00E+00	3.75E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>NOBLE GASES</b>											
XE-131M	0.00E+00	4.19E+02	4.06E+02	1.02E-04	1.95E-08	0.00E+00	6.69E-06	3.78E-05	0.00E+00	1.74E-06	6.26E-05
XE-133M	0.00E+00	2.21E+03	2.35E+03	5.37E-04	1.03E-07	0.00E+00	5.81E-05	2.51E-04	0.00E+00	4.49E-06	4.21E-04
XE-133	0.00E+00	1.09E+05	1.09E+05	2.66E-02	5.09E-06	0.00E+00	2.45E-03	1.10E-02	0.00E+00	4.62E-04	1.83E-02
XE-135M	0.00E+00	5.78E-24	5.63E-07	1.40E-30	2.69E-34	0.00E+00	1.78E-13	3.77E-14	0.00E+00	2.37E-14	1.37E-13
XE-135	0.00E+00	6.64E+03	1.31E+04	1.61E-03	3.09E-07	0.00E+00	2.42E-03	2.91E-03	0.00E+00	1.56E-04	5.25E-03
XE-138	0.00E+00	1.94E-20	2.10E-05	4.70E-27	9.00E-31	0.00E+00	4.52E-11	1.16E-11	0.00E+00	1.53E-12	4.14E-11
KR-83M	0.00E+00	9.12E-01	6.76E+01	2.22E-07	4.24E-11	0.00E+00	2.53E-07	1.59E-06	0.00E+00	3.29E-07	3.76E-06
KR-85M	0.00E+00	4.16E+02	2.02E+03	1.01E-04	1.94E-08	0.00E+00	2.37E-04	3.26E-04	0.00E+00	1.80E-05	6.43E-04
KR-85	0.00E+00	8.37E+02	7.93E+02	2.03E-04	3.89E-08	0.00E+00	1.25E-06	1.22E-04	0.00E+00	7.55E-08	2.02E-04

KR-87	0.00E+00	7.12E-02	6.22E+01	1.73E-08	3.31E-12	0.00E+00	6.42E-05	4.51E-05	0.00E+00	3.00E-06	1.18E-04
KR-88	0.00E+00	1.37E+02	2.00E+03	3.32E-05	6.35E-09	0.00E+00	2.61E-03	4.70E-04	0.00E+00	1.72E-04	1.01E-03
						-----	-----	-----	-----	-----	-----
						0.00E+00	7.84E-03	1.51E-02	0.00E+00	8.17E-04	2.60E-02

1 QDC CRDA, CR & LPZ, ALL REL AOG: SIEMENS 20 GWD/MTU: 6 s - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
 1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO  
 SPRAYED VOL

AT 720.000 HOURS: X/Q(SITE)= .00E+00 SEC/M3 PRIMARY LEAK RATE= .000 PERCENT/DAY CONTROL ROOM  
 INTAKE=2460.0 CFM X/Q CONT ROOM= .00E+00 SEC/M3 SEC RELEASE RATE= .00E+00 VOL/DAY PCT PRI LKG TO ATM =  
 00.00

CLEANUP RATES (HR-1)						FILTER NON-REMOVAL FACTORS					
	SPRAY	PRIMARY	SECONDARY	CONT CENTER		RELEASE	CONT CENTER				
ELEMENTAL	.000	.000	.000	.000		.000	.000	1.000			
PARTICULATE	.000	.000	.000	.000		.000	.000	1.000			
ORGANIC	.000	.000	.000	.000		.000	.000	1.000			
ISOTOPE	ACTIVITY (CURIES)	CONTROL ROOM	SITE BOUNDARY DOSES (REM)	THYROID WH BODY BETA	THYROID	CONTROL ROOM DOSES (REM)	THYROID WH BODY BETA				
	PRIMARY SECONDARY RELEASE	(CURIES) (UCI/CM3)	THYROID WH BODY	BETA	THYROID	THYROID WH BODY BETA					
ELEMENTAL											
I-131	0.00E+00	4.26E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	0.00E+00	4.89E-92	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	0.00E+00	5.41E-08	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	0.00E+00	5.02E-30	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
PARTICULATE											
I-131	0.00E+00	2.34E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	0.00E+00	2.69E-93	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	0.00E+00	2.97E-09	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	0.00E+00	2.76E-31	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ORGANIC											
I-131	0.00E+00	1.87E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	0.00E+00	2.15E-93	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	0.00E+00	2.38E-09	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	0.00E+00	2.21E-31	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
NOBLE GASES											
XE-131M	0.00E+00	7.64E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.52E-08	2.71E-06
XE-133M	0.00E+00	3.03E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.73E-07	1.62E-05
XE-133	0.00E+00	2.43E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.93E-05	7.64E-04
XE-135M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.08E-33	6.23E-33
XE-135	0.00E+00	7.28E-20	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.79E-06	9.40E-05
XE-138	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.94E-30	1.88E-28
KR-83M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.92E-11	1.02E-09
KR-85M	0.00E+00	9.07E-46	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.09E-07	3.90E-06
KR-85	0.00E+00	8.33E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.36E-09	8.98E-06
KR-87	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.42E-11	2.14E-09
KR-88	0.00E+00	1.86E-73	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.91E-07	1.71E-06
TOTAL DOSES 0-30 DAYS					0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.28E-05	8.92E-04	

1

QDC CRDA, CR & LPZ, ALL REL AOG: SIEMENS 20 GWD/MTU: 6 s - 30 d

ISOTOPE	ACTIVITY RELEASED (CURIES)			
	2. HRS	8. HRS	24. HRS	720. HRS
ELEMENTAL				
I-131	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	0.00E+00	0.00E+00	0.00E+00	0.00E+00
PARTICULATE				
I-131	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ORGANIC				
I-131	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	0.00E+00	0.00E+00	0.00E+00	0.00E+00

I-133	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>NOBLE GASES</b>					
XE-131M	9.90E+01	2.43E+02	4.06E+02	0.00E+00	7.47E+02
XE-133M	6.63E+02	1.56E+03	2.35E+03	0.00E+00	4.57E+03
XE-133	2.77E+04	6.72E+04	1.09E+05	0.00E+00	2.04E+05
XE-135M	1.62E+03	6.32E+00	5.63E-07	0.00E+00	1.62E+03
XE-135	8.55E+03	1.58E+04	1.31E+04	0.00E+00	3.75E+04
XE-138	5.93E+03	4.19E+01	2.10E-05	0.00E+00	5.97E+03
KR-83M	1.07E+03	7.36E+02	6.76E+01	0.00E+00	1.87E+03
KR-85M	3.53E+03	4.87E+03	2.02E+03	0.00E+00	1.04E+04
KR-85	1.87E+02	4.63E+02	7.93E+02	0.00E+00	1.44E+03
KR-87	5.01E+03	2.07E+03	6.22E+01	0.00E+00	7.14E+03
KR-88	9.28E+03	9.42E+03	2.00E+03	0.00E+00	2.07E+04

END EXECUTION DATE: 11/18/1999  
END EXECUTION TIME: 17:19:27.40

AXIDENT VER 2 MOD 4  
 PRODUCTION DATE 02/18/92  
 BEGIN EXECUTION DATE: 11/18/1999  
 BEGIN EXECUTION TIME: 17:19:18.72

1 QDC CRDA, CR & LPZ, ALL REL GLAND: SIEMENS 20 GWD/MTU: 0 - 30 d  
 2 6 2 1. 1.  
 3 -2561 2.60+6 1.845+5 5.83+4  
 4 0. 0. 0. 1. 1. 2.78+5 0.  
 5 6 1800 7200 2.88+4 8.64+4 2.592E6  
 6 0.2402 4\*1.201E-2 0.  
 7 5\*1. 0.  
 8 6\*1.  
 9 6\*2460  
 10 2\*3.2E-5 2\*9.0E-6 3.0E-6 0.  
 11 3\*7.00E-4 6.45E-6 3.81E-6 0.  
 12 6\*0.  
 13 6\*0.  
 14 6\*0.  
 15 6\*0.  
 16 6\*0.  
 17 6\*0.  
 18 6\*0.  
 19 6\*0.  
 20 6\*0.  
 21 6\*1.  
 22 3\*1.  
 23 6.76E+3 9.73E+3 1.36E+4 1.57E+4 1.22E+4 1.21E+3 8.18E+3 3.40E+5  
 24 9.21E+4 1.12E+5 3.07E+5 1.82E+4 4.99E+4 2.28E+3 9.80E+4 1.42E+5

1

QDC CRDA, CR &amp; LPZ, ALL REL GLAND: SIEMENS 20 GWD/MTU: 0 - 30 d

## INITIAL CONTAINMENT INVENTORY

ISOTOPE	ACTIVITY (CURIES)
I-131	6.760E+03
I-132	9.730E+03
I-133	1.360E+04
I-134	1.570E+04
I-135	1.220E+04
XE-131M	1.210E+03
XE-133M	8.180E+03
XE-133	3.400E+05
XE-135M	9.210E+04
XE-135	1.120E+05
XE-138	3.070E+05
KR-83M	1.820E+04
KR-85M	4.990E+04
KR-85	2.280E+03
KR-87	9.800E+04
KR-88	1.420E+05

1

QDC CRDA, CR &amp; LPZ, ALL REL GLAND: SIEMENS 20 GWD/MTU: 0 - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

SPRAYED VOL	1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL,	1. CFM MIXING, 00.00 PCT REL TO
-------------	--	---------------------------------

AT .002 HOURS: X/Q(SITE)= .32E-04 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM
INTAKE=2460.0 CFM		

00.00	X/Q CONT ROOM= .70E-03 SEC/M3	SEC RELEASE RATE= .86E+05 VOL/DAY	PCT PRI LKG TO ATM =
-------	-------------------------------	-----------------------------------	----------------------

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM		SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE	(CURIOS)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA
ELEMENTAL											
I-131	3.64E+02	1.14E+02	1.06E+03	8.61E-01	1.65E-04	1.74E+01	3.15E-03	1.54E-03	2.62E-01	1.69E-06	2.31E-05
I-132	5.24E+02	1.64E+02	1.53E+03	1.24E+00	2.37E-04	9.06E-01	2.93E-02	5.03E-03	1.36E-02	1.36E-05	7.56E-05
I-133	7.32E+02	2.29E+02	2.13E+03	1.73E+00	3.32E-04	9.47E+00	8.14E-03	6.64E-03	1.42E-01	5.48E-06	9.98E-05
I-134	8.44E+02	2.64E+02	2.46E+03	2.00E+00	3.82E-04	6.83E-01	3.82E-02	8.24E-03	1.03E-02	2.36E-05	1.24E-04

I-135	6.57E+02	2.05E+02	1.91E+03	1.55E+00	2.97E-04	2.63E+00	2.72E-02	4.34E-03	3.96E-02	9.96E-06	6.52E-05	
<b>PARTICULATE</b>												
I-131	2.00E+01	6.26E+00	5.82E+01	4.73E-02	9.05E-06	9.57E-01	1.73E-04	8.45E-05	1.44E-02	9.28E-08	1.27E-06	
I-132	2.88E+01	9.00E+00	8.38E+01	6.81E-02	1.30E-05	4.98E-02	1.61E-03	2.76E-04	7.48E-04	7.47E-07	4.15E-06	
I-133	4.02E+01	1.26E+01	1.17E+02	9.52E-02	1.82E-05	5.20E-01	4.47E-04	3.65E-04	7.82E-03	3.01E-07	5.48E-06	
I-134	4.64E+01	1.45E+01	1.35E+02	1.10E-01	2.10E-05	3.75E-02	2.10E-03	4.53E-04	5.64E-04	1.29E-06	6.80E-06	
I-135	3.61E+01	1.13E+01	1.05E+02	8.54E-02	1.63E-05	1.45E-01	1.50E-03	2.38E-04	2.18E-03	5.47E-07	3.58E-06	
<b>ORGANIC</b>												
I-131	1.60E+01	5.00E+00	4.66E+01	3.78E-02	7.24E-06	7.66E-01	1.38E-04	6.76E-05	1.15E-02	7.42E-08	1.02E-06	
I-132	2.30E+01	7.20E+00	6.71E+01	5.44E-02	1.04E-05	3.98E-02	1.29E-03	2.21E-04	5.99E-04	5.98E-07	3.32E-06	
I-133	3.22E+01	1.01E+01	9.37E+01	7.61E-02	1.46E-05	4.16E-01	3.58E-04	2.92E-04	6.26E-03	2.41E-07	4.39E-06	
I-134	3.71E+01	1.16E+01	1.08E+02	8.78E-02	1.68E-05	3.00E-02	1.68E-03	3.62E-04	4.51E-04	1.04E-06	5.44E-06	
I-135	2.89E+01	9.03E+00	8.41E+01	6.83E-02	1.31E-05	1.16E-01	1.20E-03	1.91E-04	1.74E-03	4.38E-07	2.87E-06	
<b>NOBLE GASES</b>												
XE-131M	2.86E+02	8.96E+01	8.34E+02	6.77E-01	1.30E-04	0.00E+00	1.47E-04	8.29E-04	0.00E+00	3.45E-07	1.25E-05	
XE-133M	1.94E+03	6.06E+02	5.64E+03	4.58E+00	8.77E-04	0.00E+00	1.49E-03	6.43E-03	0.00E+00	1.03E-06	9.67E-05	
XE-133	8.05E+04	2.52E+04	2.34E+05	1.90E+02	3.64E-02	0.00E+00	5.62E-02	2.52E-01	0.00E+00	9.58E-05	3.79E-03	
XE-135M	2.17E+04	6.79E+03	6.34E+04	5.13E+01	9.83E-03	0.00E+00	2.14E-01	4.52E-02	0.00E+00	1.18E-04	6.79E-04	
XE-135	2.65E+04	8.29E+03	7.72E+04	6.27E+01	1.20E-02	0.00E+00	1.52E-01	1.83E-01	0.00E+00	8.15E-05	2.75E-03	
XE-138	7.24E+04	2.26E+04	2.11E+05	1.71E+02	3.28E-02	0.00E+00	4.85E+00	1.24E+00	0.00E+00	6.90E-04	1.87E-02	
KR-83M	4.30E+03	1.35E+03	1.25E+04	1.02E+01	1.95E-03	0.00E+00	5.02E-04	3.14E-03	0.00E+00	4.12E-06	4.72E-05	
KR-85M	1.18E+04	3.69E+03	3.44E+04	2.79E+01	5.35E-03	0.00E+00	4.29E-02	5.90E-02	0.00E+00	2.48E-05	8.87E-04	
KR-85	5.40E+02	1.69E+02	1.57E+03	1.28E+00	2.44E-04	0.00E+00	2.64E-05	2.58E-03	0.00E+00	1.45E-08	3.88E-05	
KR-87	2.32E+04	7.25E+03	6.75E+04	5.48E+01	1.05E-02	0.00E+00	7.43E-01	5.22E-01	0.00E+00	1.99E-04	7.84E-03	
KR-88	3.36E+04	1.05E+04	9.79E+04	7.95E+01	1.52E-02	0.00E+00	1.36E+00	2.46E-01	0.00E+00	6.28E-04	3.69E-03	
							3.42E+01	7.54E+00	2.59E+00	5.14E-01	1.90E-03	3.89E-02

1 QDC CRDA, CR &amp; LPZ, ALL REL GLAND: SIEMENS 20 GWD/MTU: 0 - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO SPRAYED VOL

AT .500 HOURS: X/Q(SITE)= .32E-04 SEC/M3 PRIMARY LEAK RATE=\*\*\*\*\* PERCENT/DAY CONTROL ROOM INTAKE=2460.0 CFM

X/Q CONT ROOM= .70E-03 SEC/M3 SEC RELEASE RATE= .86E+05 VOL/DAY PCT PRI LKG TO ATM = 00.00

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM			SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA	
<b>ELEMENTAL</b>												
I-131	1.60E-07	1.94E-09	4.78E+02	8.41E-01	1.61E-04	7.85E+00	1.42E-03	6.93E-04	1.80E+02	1.16E-03	1.59E-02	
I-132	1.98E-07	2.41E-09	6.84E+02	1.04E+00	2.00E-04	4.06E-01	1.31E-02	2.25E-03	8.73E+00	8.71E-03	4.84E-02	
I-133	3.16E-07	3.85E-09	9.61E+02	1.67E+00	3.19E-04	4.27E+00	3.67E-03	2.99E-03	9.71E+01	3.73E-03	6.81E-02	
I-134	2.49E-07	3.03E-09	1.09E+03	1.31E+00	2.51E-04	3.03E-01	1.69E-02	3.66E-03	5.88E+00	1.35E-02	7.09E-02	
I-135	2.74E-07	3.33E-09	8.61E+02	1.44E+00	2.76E-04	1.18E+00	1.22E-02	1.95E-03	2.66E+01	6.68E-03	4.37E-02	
<b>PARTICULATE</b>												
I-131	8.77E-09	1.07E-10	2.62E+01	4.62E-02	8.84E-06	4.31E-01	7.79E-05	3.81E-05	9.88E+00	6.37E-05	8.72E-04	
I-132	1.09E-08	1.32E-10	3.76E+01	5.73E-02	1.10E-05	2.23E-02	7.21E-04	1.24E-04	4.80E-01	4.79E-04	2.66E-03	
I-133	1.74E-08	2.11E-10	5.28E+01	9.16E-02	1.75E-05	2.34E-01	2.01E-04	1.64E-04	5.34E+00	2.05E-04	3.74E-03	
I-134	1.37E-08	1.66E-10	6.00E+01	7.21E-02	1.38E-05	1.67E-02	9.31E-04	2.01E-04	3.23E-01	7.41E-04	3.90E-03	
I-135	1.51E-08	1.83E-10	4.73E+01	7.93E-02	1.52E-05	6.51E-02	6.73E-04	1.07E-04	1.46E+00	3.67E-04	2.40E-03	
<b>ORGANIC</b>												
I-131	7.01E-09	8.53E-11	2.10E+01	3.70E-02	7.07E-06	3.45E-01	6.23E-05	3.04E-05	7.91E+00	5.10E-05	6.97E-04	
I-132	8.70E-09	1.06E-10	3.01E+01	4.58E-02	8.77E-06	1.79E-02	5.77E-04	9.91E-05	3.84E-01	3.83E-04	2.13E-03	
I-133	1.39E-08	1.69E-08	4.22E+01	7.33E-02	1.40E-05	1.88E-01	1.61E-04	1.31E-04	4.27E+00	1.64E-04	2.99E-03	
I-134	1.09E-08	1.33E-10	4.80E+01	5.77E-02	1.10E-05	1.33E-02	7.45E-04	1.61E-04	2.58E-01	5.93E-04	3.12E-03	
I-135	1.20E-08	1.46E-10	3.78E+01	6.35E-02	1.21E-05	5.21E-02	5.38E-04	8.57E-05	1.17E+00	2.94E-04	1.92E-03	
<b>NOBLE GASES</b>												
XE-131M	1.26E-07	1.53E-09	3.76E+02	6.62E-01	1.27E-04	0.00E+00	6.62E-05	3.73E-04	0.00E+00	2.37E-04	8.56E-03	
XE-133M	8.45E-07	1.03E-08	2.54E+03	4.45E+00	8.52E-04	0.00E+00	6.71E-04	2.90E-03	0.00E+00	7.05E-04	6.63E-02	
XE-133	3.52E-05	4.28E-07	1.06E+05	1.86E+02	3.55E-02	0.00E+00	2.53E-02	1.13E-01	0.00E+00	6.57E-02	2.60E+00	
XE-135M	2.53E-06	3.07E-08	2.72E+04	1.33E+01	2.55E-03	0.00E+00	9.18E-02	1.94E-02	0.00E+00	4.63E-02	2.67E-01	
XE-135	1.12E-05	1.36E-07	3.47E+04	5.91E+01	1.13E-02	0.00E+00	6.84E-02	8.23E-02	0.00E+00	5.50E-02	1.86E+00	
XE-138	9.73E-06	1.18E-07	9.12E+04	5.13E+01	9.81E-03	0.00E+00	2.09E+00	5.37E-01	0.00E+00	2.86E-01	7.75E+00	
KR-83M	1.57E-06	1.91E-08	5.61E+03	8.28E+00	1.59E-03	0.00E+00	2.25E-04	1.40E-03	0.00E+00	2.60E-03	2.97E-02	
KR-85M	4.79E-06	5.83E-08	1.55E+04	2.53E+01	4.83E-03	0.00E+00	1.93E-02	2.65E-02	0.00E+00	1.64E-02	5.87E-01	
KR-85	2.37E-07	2.88E-09	7.08E+00	1.25E+00	2.39E-04	0.00E+00	1.19E-05	1.16E-03	0.00E+00	9.97E-06	2.67E-02	
KR-87	7.75E-06	9.42E-08	3.01E+04	4.08E+01	7.81E-03	0.00E+00	3.31E-01	2.33E-01	0.00E+00	1.21E-01	4.75E+00	
KR-88	1.30E-05	1.59E-07	4.39E+04	6.87E+01	1.32E-02	0.00E+00	6.12E-01	1.10E-01	0.00E+00	4.08E-01	2.39E+00	
						1.54E+01	3.29E+00	1.14E+00	3.50E+02	1.04E+00	2.06E+01	

1 QDC CRDA, CR &amp; LPZ, ALL REL GLAND: SIEMENS 20 GWD/MTU: 0 - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO  
SPRAYED VOL

AT 2.000 HOURS:	X/Q(SITE)= .90E-05 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM
INTAKE=2460.0 CFM			
00.00	X/Q CONT ROOM= .70E-03 SEC/M3	SEC RELEASE RATE= .86E+05 VOL/DAY	PCT PRI LKG TO ATM =

	CLEANUP RATES (HR-1)			FILTER NON-REMOVAL FACTORS		
	SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)	CONTROL ROOM (CURIES)	SITE BOUNDARY DOSES (REM)	CONTROL ROOM DOSES (REM)	
	PRIMARY	SECONDARY	THYROID WH BODY	THYROID WH BODY	
ELEMENTAL					
I-131	1.08E-35	1.32E-37	1.61E-07 2.52E-01 4.82E-05	7.46E-10 1.35E-13 6.59E-14	2.59E+02 1.67E-03 2.29E-02
I-132	8.60E-36	1.05E-37	1.99E-07 2.00E-01 3.83E-05	3.32E-11 1.07E-12 1.84E-13	9.79E+00 9.77E-03 5.43E-02
I-133	2.06E-35	2.50E-37	3.20E-07 4.78E-01 9.15E-05	4.00E-10 3.43E-13 2.80E-13	1.37E+02 5.25E-03 9.57E-02
I-134	5.13E-36	6.23E-38	2.47E-07 1.19E-01 2.28E-05	1.93E-11 1.08E-12 2.33E-13	4.46E+00 1.02E-02 5.38E-02
I-135	1.60E-35	1.95E-37	2.77E-07 3.72E-01 7.13E-05	1.07E-10 1.11E-12 1.76E-13	3.52E+01 8.84E-03 5.79E-02
PARTICULATE					
I-131	5.95E-37	7.24E-39	8.87E-09 1.38E-02 2.65E-06	4.10E-11 7.41E-15 3.62E-15	1.42E+01 9.19E-05 1.26E-03
I-132	4.72E-37	5.74E-39	1.09E-08 1.10E-02 2.10E-06	1.83E-12 5.90E-14 1.01E-14	5.38E-01 5.37E-04 2.99E-03
I-133	1.13E-36	1.37E-38	1.76E-08 2.63E-02 5.02E-06	2.20E-11 1.89E-14 1.54E-14	7.50E+00 2.88E-04 5.26E-03
I-134	2.82E-37	3.42E-39	1.36E-08 6.55E-03 1.25E-06	1.05E-12 5.93E-14 1.28E-14	2.45E-01 5.62E-04 2.95E-03
I-135	8.80E-37	1.07E-38	1.52E-08 2.05E-02 3.92E-06	5.89E-12 6.08E-14 9.69E-15	1.93E+00 4.86E-04 3.18E-03
ORGANIC					
I-131	4.76E-37	5.79E-39	7.10E-09 1.11E-02 2.12E-06	3.28E-11 5.93E-15 2.89E-15	1.14E+01 7.35E-05 1.01E-03
I-132	3.78E-37	4.59E-39	8.74E-09 8.79E-03 1.68E-06	1.46E-12 4.72E-14 8.11E-15	4.30E-01 4.30E-04 2.39E-03
I-133	9.04E-37	1.10E-38	1.41E-08 2.10E-02 4.02E-06	1.76E-11 1.51E-14 1.23E-14	6.00E+00 2.31E-04 4.21E-03
I-134	2.25E-37	2.74E-39	1.09E-08 5.24E-03 1.00E-06	8.49E-13 4.74E-14 1.02E-14	1.96E-01 4.50E-04 2.36E-03
I-135	7.04E-37	8.56E-39	1.22E-08 1.64E-02 3.13E-06	4.71E-12 4.87E-14 7.75E-15	1.55E+00 3.89E-04 2.54E-03
NOBLE GASES					
XE-131M	8.55E-36	1.04E-37	1.27E-07 1.99E-01 3.80E-05	0.00E+00 6.29E-15 3.55E-14	0.00E+00 3.42E-04 1.24E-02
XE-133M	5.66E-35	6.88E-37	8.55E-07 1.32E+00 2.52E-04	0.00E+00 6.35E-14 2.74E-13	0.00E+00 1.01E-03 9.48E-02
XE-133	2.39E-33	2.90E-35	3.57E-05 5.55E+01 1.06E-02	0.00E+00 2.41E-12 1.08E-11	0.00E+00 9.46E-02 3.74E+00
XE-135M	3.17E-36	3.86E-38	2.41E-06 7.37E-02 1.41E-05	0.00E+00 2.29E-12 4.84E-13	0.00E+00 1.02E-02 5.88E-02
XE-135	6.83E-34	8.30E-36	1.13E-05 1.59E+01 3.04E-03	0.00E+00 6.27E-12 7.55E-12	0.00E+00 7.46E-02 2.52E+00
XE-138	1.88E-35	2.29E-37	9.33E-06 4.37E-01 8.37E-05	0.00E+00 6.03E-11 1.55E-11	0.00E+00 7.49E-02 2.03E+00
KR-83M	6.15E-35	7.48E-37	1.58E-06 1.43E+00 2.74E-04	0.00E+00 1.77E-14 1.11E-13	0.00E+00 2.76E-03 3.15E-02
KR-85M	2.58E-34	3.14E-36	4.83E-06 6.01E+00 1.15E-03	0.00E+00 1.70E-12 2.33E-12	0.00E+00 2.08E-02 7.42E-01
KR-85	1.62E-35	1.97E-37	2.40E-07 3.76E-01 7.20E-05	0.00E+00 1.13E-15 1.11E-13	0.00E+00 1.44E-05 3.86E-02
KR-87	2.33E-34	2.83E-36	7.74E-06 5.41E+00 1.04E-03	0.00E+00 2.40E-11 1.68E-11	0.00E+00 1.11E-01 4.37E+00
KR-88	6.14E-34	7.46E-36	1.31E-05 1.43E+01 2.73E-03	0.00E+00 5.15E-11 9.26E-12	0.00E+00 4.78E-01 2.81E+00

1 QDC CRDA, CR &amp; LPZ, ALL REL GLAND: SIEMENS 20 GWD/MTU: 0 - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO  
SPRAYED VOL

AT 8.000 HOURS:	X/Q(SITE)= .90E-05 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM
INTAKE=2460.0 CFM			
00.00	X/Q CONT ROOM= .65E-05 SEC/M3	SEC RELEASE RATE= .86E+05 VOL/DAY	PCT PRI LKG TO ATM =

	CLEANUP RATES (HR-1)			FILTER NON-REMOVAL FACTORS		
	SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)	CONTROL ROOM (CURIES)	SITE BOUNDARY DOSES (REM)	CONTROL ROOM DOSES (REM)
	PRIMARY	SECONDARY	THYROID WH BODY	THYROID WH BODY

ELEMENTAL												
I-131	0.00E+00	0.00E+00	1.10E-35	2.03E-03	3.88E-07	5.07E-38	9.15E-42	4.47E-42	1.10E+02	7.09E-04	9.71E-03	
I-132	0.00E+00	0.00E+00	8.64E-36	2.70E-04	5.16E-08	1.44E-39	4.67E-41	8.02E-42	2.32E+00	2.31E-03	1.29E-02	
I-133	0.00E+00	0.00E+00	2.08E-35	3.23E-03	6.17E-07	2.60E-38	2.23E-41	1.82E-41	5.45E+01	2.09E-03	3.82E-02	
I-134	0.00E+00	0.00E+00	5.09E-36	8.11E-06	1.55E-09	3.98E-40	2.22E-41	4.80E-42	4.45E-01	1.02E-03	5.37E-03	
I-135	0.00E+00	0.00E+00	1.62E-35	1.65E-03	3.16E-07	6.26E-39	6.48E-41	1.03E-41	1.22E+01	3.06E-03	2.00E-02	
PARTICULATE												
I-131	0.00E+00	0.00E+00	6.03E-37	1.11E-04	2.13E-08	2.79E-39	5.03E-43	2.46E-43	6.05E+00	3.90E-05	5.33E-04	
I-132	0.00E+00	0.00E+00	4.75E-37	1.48E-05	2.84E-09	7.93E-41	2.56E-42	4.40E-43	1.27E-01	1.27E-04	7.07E-04	
I-133	0.00E+00	0.00E+00	1.14E-36	1.77E-04	3.39E-08	1.43E-39	1.23E-42	1.00E-42	2.99E+00	1.15E-04	2.10E-03	
I-134	0.00E+00	0.00E+00	2.80E-37	4.46E-07	8.53E-11	2.19E-41	1.22E-42	2.64E-43	2.45E-02	5.61E-05	2.95E-04	
I-135	0.00E+00	0.00E+00	8.89E-37	9.06E-05	1.73E-08	3.44E-40	3.56E-42	5.67E-43	6.69E-01	1.68E-04	1.10E-03	
ORGANIC												
I-131	0.00E+00	0.00E+00	4.82E-37	8.92E-05	1.71E-08	2.23E-39	4.02E-43	1.97E-43	4.84E+00	3.12E-05	4.27E-04	
I-132	0.00E+00	0.00E+00	3.80E-37	1.19E-05	2.27E-09	6.35E-41	2.05E-42	3.52E-43	1.02E-01	1.02E-04	5.66E-04	
I-133	0.00E+00	0.00E+00	9.14E-37	1.42E-04	2.71E-08	1.14E-39	9.81E-43	8.00E-43	2.40E+00	9.21E-05	1.68E-03	
I-134	0.00E+00	0.00E+00	2.24E-37	3.56E-07	6.82E-11	1.75E-41	9.77E-43	2.11E-43	1.96E-02	4.49E-05	2.36E-04	
I-135	0.00E+00	0.00E+00	7.11E-37	7.25E-05	1.39E-08	2.75E-40	2.85E-42	4.53E-43	5.35E-01	1.35E-04	8.81E-04	
NOBLE GASES												
XE-131M	0.00E+00	0.00E+00	8.65E-36	1.61E-03	3.08E-07	0.00E+00	4.28E-43	2.42E-42	0.00E+00	1.46E-04	5.25E-03	
XE-133M	0.00E+00	0.00E+00	5.73E-35	1.00E-02	1.92E-06	0.00E+00	4.25E-42	1.84E-41	0.00E+00	4.20E-04	3.95E-02	
XE-133	0.00E+00	0.00E+00	2.42E-33	4.42E-01	8.46E-05	0.00E+00	1.63E-40	7.30E-40	0.00E+00	4.00E-02	1.58E-00	
XE-135M	0.00E+00	0.00E+00	3.02E-36	6.94E-11	1.33E-14	0.00E+00	2.87E-42	6.07E-43	0.00E+00	5.68E-05	3.27E-04	
XE-135	0.00E+00	0.00E+00	6.90E-34	8.28E-02	1.59E-05	0.00E+00	3.82E-40	4.60E-40	0.00E+00	2.73E-02	9.20E-01	
XE-138	0.00E+00	0.00E+00	1.80E-35	2.32E-09	4.43E-13	0.00E+00	1.17E-40	2.99E-41	0.00E+00	6.45E-04	1.75E-02	
KR-83M	0.00E+00	0.00E+00	6.17E-35	1.27E-03	2.44E-07	0.00E+00	6.95E-43	4.35E-42	0.00E+00	5.75E-04	6.58E-03	
KR-85M	0.00E+00	0.00E+00	2.61E-34	1.92E-02	3.67E-06	0.00E+00	9.15E-41	1.26E-40	0.00E+00	6.45E-03	2.31E-01	
KR-85	0.00E+00	0.00E+00	1.64E-35	3.10E-03	5.92E-07	0.00E+00	7.74E-44	7.56E-42	0.00E+00	6.16E-06	1.65E-02	
KR-87	0.00E+00	0.00E+00	2.33E-34	1.67E-03	3.20E-07	0.00E+00	7.20E-40	5.06E-40	0.00E+00	1.69E-02	6.68E-01	
KR-88	0.00E+00	0.00E+00	6.18E-34	2.66E-02	5.09E-06	0.00E+00	2.42E-39	4.36E-40	0.00E+00	1.25E-01	7.35E-01	

1 QDC CRDA, CR &amp; LPZ, ALL REL GLAND: SIEMENS 20 GWD/MTU: 0 - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO SPRAYED VOL

AT 24.000 HOURS: X/Q(SITE)= .30E-05 SEC/M3 PRIMARY LEAK RATE=\*\*\*\*\* PERCENT/DAY CONTROL ROOM INTAKE=2460.0 CFM

X/Q CONT ROOM= .38E-05 SEC/M3 SEC RELEASE RATE= .86E+05 VOL/DAY PCT PRI LKG TO ATM = 00.00

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM		SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA
<b>ELEMENTAL</b>											
I-131	0.00E+00	0.00E+00	0.00E+00	5.29E-09	1.01E-12	0.00E+00	0.00E+00	0.00E+00	8.93E-01	5.76E-06	7.88E-05
I-132	0.00E+00	0.00E+00	0.00E+00	6.00E-12	1.15E-15	0.00E+00	0.00E+00	0.00E+00	3.13E-03	3.13E-06	1.74E-05
I-133	0.00E+00	0.00E+00	0.00E+00	5.25E-09	1.01E-12	0.00E+00	0.00E+00	0.00E+00	3.70E-01	1.42E-05	2.60E-04
I-134	0.00E+00	0.00E+00	0.00E+00	6.26E-17	1.20E-20	0.00E+00	0.00E+00	0.00E+00	3.03E-05	6.95E-08	3.66E-07
I-135	0.00E+00	0.00E+00	0.00E+00	8.71E-10	1.67E-13	0.00E+00	0.00E+00	0.00E+00	5.41E-02	1.36E-05	8.91E-05
<b>PARTICULATE</b>											
I-131	0.00E+00	0.00E+00	0.00E+00	2.91E-10	5.56E-14	0.00E+00	0.00E+00	0.00E+00	4.91E-02	3.16E-07	4.33E-06
I-132	0.00E+00	0.00E+00	0.00E+00	3.30E-13	6.31E-17	0.00E+00	0.00E+00	0.00E+00	1.72E-04	1.72E-07	9.56E-07
I-133	0.00E+00	0.00E+00	0.00E+00	2.89E-10	5.52E-14	0.00E+00	0.00E+00	0.00E+00	2.03E-02	7.82E-07	1.43E-05
I-134	0.00E+00	0.00E+00	0.00E+00	3.44E-18	6.58E-22	0.00E+00	0.00E+00	0.00E+00	1.67E-06	3.82E-09	2.01E-08
I-135	0.00E+00	0.00E+00	0.00E+00	4.79E-11	9.16E-15	0.00E+00	0.00E+00	0.00E+00	2.97E-03	7.48E-07	4.90E-06
<b>ORGANIC</b>											
I-131	0.00E+00	0.00E+00	0.00E+00	2.32E-10	4.45E-14	0.00E+00	0.00E+00	0.00E+00	3.93E-02	2.53E-07	3.46E-06
I-132	0.00E+00	0.00E+00	0.00E+00	2.64E-13	5.05E-17	0.00E+00	0.00E+00	0.00E+00	1.38E-04	1.37E-07	7.64E-07
I-133	0.00E+00	0.00E+00	0.00E+00	2.31E-10	4.42E-14	0.00E+00	0.00E+00	0.00E+00	1.63E-02	6.26E-07	1.14E-05
I-134	0.00E+00	0.00E+00	0.00E+00	2.75E-18	5.27E-22	0.00E+00	0.00E+00	0.00E+00	1.33E-06	3.06E-09	1.61E-08
I-135	0.00E+00	0.00E+00	0.00E+00	3.83E-11	7.33E-15	0.00E+00	0.00E+00	0.00E+00	2.38E-03	5.98E-07	3.92E-06
<b>NOBLE GASES</b>											
XE-131M	0.00E+00	0.00E+00	0.00E+00	4.28E-09	8.19E-13	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.19E-06	4.30E-05
XE-133M	0.00E+00	0.00E+00	0.00E+00	2.26E-08	4.32E-12	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.23E-06	3.03E-04
XE-133	0.00E+00	0.00E+00	0.00E+00	1.12E-06	2.14E-10	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.21E-04	1.27E-02
XE-135M	0.00E+00	0.00E+00	0.00E+00	5.90E-35	1.13E-38	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.34E-14	3.08E-13
XE-135	0.00E+00	0.00E+00	0.00E+00	6.78E-08	1.30E-11	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.43E-04	4.82E-03
XE-138	0.00E+00	0.00E+00	0.00E+00	1.98E-31	3.78E-35	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.42E-12	9.25E-11
KR-83M	0.00E+00	0.00E+00	0.00E+00	9.31E-12	1.78E-15	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.12E-07	5.86E-06
KR-85M	0.00E+00	0.00E+00	0.00E+00	4.25E-09	8.14E-13	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.07E-05	7.40E-04
KR-85	0.00E+00	0.00E+00	0.00E+00	8.54E-09	1.64E-12	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.12E-08	1.37E-04

KR-87	0.00E+00	0.00E+00	0.00E+00	7.27E-13	1.39E-16	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.23E-06	2.05E-04
KR-88	0.00E+00	0.00E+00	0.00E+00	1.39E-09	2.67E-13	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.33E-04	1.37E-03
						-----	-----	-----	-----	-----	-----
						0.00E+00	0.00E+00	0.00E+00	1.45E+00	7.69E-04	2.08E-02

1 QDC CRDA, CR & LPZ, ALL REL GLAND: SIEMENS 20 GWD/MTU: 0 - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO

## SPRAYED VOL

AT 720.000 HOURS: X/Q(SITE) = .00E+00 SEC/M3	PRIMARY LEAK RATE= .000 PERCENT/DAY	CONTROL ROOM
INTAKE=2460.0 CFM		
X/Q CONT ROOM= .00E+00 SEC/M3	SEC RELEASE RATE= .00E+00 VOL/DAY	PCT PRI LKG TO ATM =
00.00		

	CLEANUP RATES (HR-1)			FILTER NON-REMOVAL FACTORS		
	SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM		SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA
ELEMENTAL											
I-131	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.33E-06	1.50E-11	2.05E-10
I-132	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.97E-11	6.96E-14	3.87E-13
I-133	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.03E-07	2.32E-11	4.23E-10
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.34E-16	5.37E-19	2.82E-18
I-135	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.86E-08	7.19E-12	4.71E-11
PARTICULATE											
I-131	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.28E-07	8.25E-13	1.13E-11
I-132	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.83E-12	3.82E-15	2.13E-14
I-133	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.31E-08	1.27E-12	2.32E-11
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.29E-17	2.95E-20	1.55E-19
I-135	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.57E-09	3.95E-13	2.59E-12
ORGANIC											
I-131	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.02E-07	6.60E-13	9.03E-12
I-132	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.06E-12	3.06E-15	1.70E-14
I-133	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.65E-08	1.02E-12	1.86E-11
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.03E-17	2.36E-20	1.24E-19
I-135	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.26E-09	3.16E-13	2.07E-12
NOBLE GASES											
XE-131M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.16E-12	1.14E-10	
XE-133M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.26E-12	6.82E-10	
XE-133	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.12E-10	3.21E-08	
XE-135M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.54E-38	2.62E-37	
XE-135	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.17E-10	3.95E-09	
XE-138	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.91E-34	7.89E-33	
XE-138	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.75E-15	4.29E-14	
KR-83M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.58E-12	1.64E-10	
KR-85M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.41E-13	3.77E-10
KR-85	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.28E-15	8.98E-14
KR-87	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.22E-11	7.19E-11
KR-88	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
						0.00E+00	0.00E+00	0.00E+00	3.25E-06	1.01E-09	3.82E-08
TOTAL DOSES 0-30 DAYS						4.96E+01	1.08E+01	3.73E+00	1.04E+03	2.18E+00	4.17E+01

1

QDC CRDA, CR & LPZ, ALL REL GLAND: SIEMENS 20 GWD/MTU: 0 - 30 d

ISOTOPE	ACTIVITY RELEASED (CURIES)			
	2. HRS	8. HRS	24. HRS	720. HRS
ELEMENTAL				
I-131	1.54E+03	1.10E-35	0.00E+00	0.00E+00
I-132	2.21E+03	8.64E-36	0.00E+00	0.00E+00
I-133	3.09E+03	2.08E-35	0.00E+00	0.00E+00
I-134	3.55E+03	5.09E-36	0.00E+00	0.00E+00
I-135	2.77E+03	1.62E-35	0.00E+00	0.00E+00
PARTICULATE				
I-131	8.45E+01	6.03E-37	0.00E+00	0.00E+00
I-132	1.21E+02	4.75E-37	0.00E+00	0.00E+00
I-133	1.70E+02	1.14E-36	0.00E+00	0.00E+00
I-134	1.95E+02	2.80E-37	0.00E+00	0.00E+00
I-135	1.52E+02	8.89E-37	0.00E+00	0.00E+00
ORGANIC				
I-131	6.76E+01	4.82E-37	0.00E+00	0.00E+00
I-132	9.71E+01	3.80E-37	0.00E+00	0.00E+00

I-133	1.36E+02	9.14E-37	0.00E+00	0.00E+00	1.36E+02
I-134	1.56E+02	2.24E-37	0.00E+00	0.00E+00	1.56E+02
I-135	1.22E+02	7.11E-37	0.00E+00	0.00E+00	1.22E+02
NOBLE GASES					
XE-131M	1.21E+03	8.65E-36	0.00E+00	0.00E+00	1.21E+03
XE-133M	8.18E+03	5.73E-35	0.00E+00	0.00E+00	8.18E+03
XE-133	3.40E+05	2.42E-33	0.00E+00	0.00E+00	3.40E+05
XE-135M	9.06E+04	3.02E-36	0.00E+00	0.00E+00	9.06E+04
XE-135	1.12E+05	6.90E-34	0.00E+00	0.00E+00	1.12E+05
XE-138	3.02E+05	1.80E-35	0.00E+00	0.00E+00	3.02E+05
KR-83M	1.82E+04	6.17E-35	0.00E+00	0.00E+00	1.82E+04
KR-85M	4.98E+04	2.61E-34	0.00E+00	0.00E+00	4.98E+04
KR-85	2.28E+03	1.64E-35	0.00E+00	0.00E+00	2.28E+03
KR-87	9.76E+04	2.33E-34	0.00E+00	0.00E+00	9.76E+04
KR-88	1.42E+05	6.18E-34	0.00E+00	0.00E+00	1.42E+05

END EXECUTION DATE: 11/18/1999  
END EXECUTION TIME: 17:19:18.94

AXIDENT VER 2 MOD 4  
 PRODUCTION DATE 02/18/92  
 BEGIN EXECUTION DATE: 11/18/1999  
 BEGIN EXECUTION TIME: 17:19:12.51

1 QDC CRDA, EAB, ALL REL MVP: SIEMENS 20 GWD/MTU: 0 - 6 s  
 2 2 1 1. 1.  
 3 -2561 2.60+6 1.845+5 5.83+4  
 4 0. 0. 0. 1. 1. 2.78+5 0.  
 5 6 7200  
 6 0.2402 0.  
 7 9.058E-4 0.  
 8 2\*1.  
 9 2\*0.  
 10 2.9E-4 0.  
 11 2\*0.  
 12 2\*0.  
 13 2\*0.  
 14 2\*0.  
 15 2\*0.  
 16 2\*0.  
 17 2\*0.  
 18 2\*0.  
 19 2\*0.  
 20 2\*0.  
 21 6\*1.  
 22 3\*1.  
 23 6.76E+3 9.73E+3 1.36E+4 1.57E+4 1.22E+4 1.21E+3 8.18E+3 3.40E+5  
 24 9.21E+4 1.12E+5 3.07E+5 1.82E+4 4.99E+4 2.28E+3 9.80E+4 1.42E+5

1

QDC CRDA, EAB, ALL REL MVP: SIEMENS 20 GWD/MTU: 0 - 6 s

## INITIAL CONTAINMENT INVENTORY

## ISOTOPE ACTIVITY (CURIES)

I-131	6.760E+03
I-132	9.730E+03
I-133	1.360E+04
I-134	1.570E+04
I-135	1.220E+04
XE-131M	1.210E+03
XE-133M	8.180E+03
XE-133	3.400E+05
XE-135M	9.210E+04
XE-135	1.120E+05
XE-138	3.070E+05
KR-83M	1.820E+04
KR-85M	4.990E+04
KR-85	2.280E+03
KR-87	9.800E+04
KR-88	1.420E+05

1

QDC CRDA, EAB, ALL REL MVP: SIEMENS 20 GWD/MTU: 0 - 6 s

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

SPRAYED VOL 1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO

AT .002 HOURS: X/Q(SITE) = .29E-03 SEC/M3 PRIMARY LEAK RATE=\*\*\*\*\* PERCENT/DAY CONTROL ROOM INTAKE= .0 CFM

X/Q CONT ROOM= .00E+00 SEC/M3 SEC RELEASE RATE= .78E+02 VOL/DAY PCT PRI LKG TO ATM = 00.00

SPRAY	CLEANUP RATES (HR-1)			FILTER NON-REMOVAL FACTORS	
	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM		SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA
I-131	3.64E+02	1.17E+03	3.92E+00	0.00E+00	0.00E+00	5.84E-01	1.06E-04	5.16E-05	0.00E+00	0.00E+00	0.00E+00
I-132	5.24E+02	1.68E+03	5.65E+00	0.00E+00	0.00E+00	3.04E-02	9.82E-04	1.69E-04	0.00E+00	0.00E+00	0.00E+00
I-133	7.32E+02	2.35E+03	7.89E+00	0.00E+00	0.00E+00	3.18E-01	2.73E-04	2.23E-04	0.00E+00	0.00E+00	0.00E+00
I-134	8.44E+02	2.71E+03	9.10E+00	0.00E+00	0.00E+00	2.29E-02	1.28E-03	2.76E-04	0.00E+00	0.00E+00	0.00E+00

I-135	6.57E+02	2.11E+03	7.08E+00	0.00E+00	0.00E+00	8.83E-02	9.13E-04	1.45E-04	0.00E+00	0.00E+00	0.00E+00
<b>PARTICULATE</b>											
I-131	2.00E+01	6.43E+01	2.16E-01	0.00E+00	0.00E+00	3.21E-02	5.80E-06	2.83E-06	0.00E+00	0.00E+00	0.00E+00
I-132	2.88E+01	9.25E+01	3.10E-01	0.00E+00	0.00E+00	1.67E-03	5.40E-05	9.27E-06	0.00E+00	0.00E+00	0.00E+00
I-133	4.02E+01	1.29E+02	4.34E-01	0.00E+00	0.00E+00	1.75E-02	1.50E-05	1.22E-05	0.00E+00	0.00E+00	0.00E+00
I-134	4.64E+01	1.49E+02	5.00E-01	0.00E+00	0.00E+00	1.26E-03	7.03E-05	1.52E-05	0.00E+00	0.00E+00	0.00E+00
I-135	3.61E+01	1.16E+02	3.89E-01	0.00E+00	0.00E+00	4.85E-03	5.02E-05	7.99E-06	0.00E+00	0.00E+00	0.00E+00
<b>ORGANIC</b>											
I-131	1.60E+01	5.14E+01	1.72E-01	0.00E+00	0.00E+00	2.57E-02	4.64E-06	2.27E-06	0.00E+00	0.00E+00	0.00E+00
I-132	2.30E+01	7.40E+01	2.48E-01	0.00E+00	0.00E+00	1.34E-03	4.32E-05	7.41E-06	0.00E+00	0.00E+00	0.00E+00
I-133	3.22E+01	1.03E+02	3.47E-01	0.00E+00	0.00E+00	1.40E-02	1.20E-05	9.79E-06	0.00E+00	0.00E+00	0.00E+00
I-134	3.71E+01	1.19E+02	4.00E-01	0.00E+00	0.00E+00	1.01E-03	5.63E-05	1.21E-05	0.00E+00	0.00E+00	0.00E+00
I-135	2.89E+01	9.28E+01	3.11E-01	0.00E+00	0.00E+00	3.88E-03	4.01E-05	6.39E-06	0.00E+00	0.00E+00	0.00E+00
<b>NOBLE GASES</b>											
XE-131M	2.86E+02	9.21E+02	3.09E+00	0.00E+00	0.00E+00	0.00E+00	4.92E-06	2.78E-05	0.00E+00	0.00E+00	0.00E+00
XE-133M	1.94E+03	6.22E+03	2.09E+01	0.00E+00	0.00E+00	0.00E+00	4.99E-05	2.16E-04	0.00E+00	0.00E+00	0.00E+00
XE-133	8.05E+04	2.59E+05	8.67E+02	0.00E+00	0.00E+00	0.00E+00	1.89E-03	8.45E-03	0.00E+00	0.00E+00	0.00E+00
XE-135M	2.17E+04	6.98E+04	2.34E+02	0.00E+00	0.00E+00	0.00E+00	7.17E-03	1.52E-03	0.00E+00	0.00E+00	0.00E+00
XE-135	2.65E+04	8.52E+04	2.86E+02	0.00E+00	0.00E+00	0.00E+00	5.10E-03	6.14E-03	0.00E+00	0.00E+00	0.00E+00
XE-138	7.24E+04	2.33E+05	7.81E+02	0.00E+00	0.00E+00	0.00E+00	1.63E-01	4.17E-02	0.00E+00	0.00E+00	0.00E+00
KR-83M	4.30E+03	1.38E+04	4.64E+01	0.00E+00	0.00E+00	0.00E+00	1.68E-05	1.05E-04	0.00E+00	0.00E+00	0.00E+00
KR-85M	1.18E+04	3.80E+04	1.27E+02	0.00E+00	0.00E+00	0.00E+00	1.44E-03	1.98E-03	0.00E+00	0.00E+00	0.00E+00
KR-85	5.40E+02	1.73E+03	5.82E+00	0.00E+00	0.00E+00	0.00E+00	8.86E-07	8.65E-05	0.00E+00	0.00E+00	0.00E+00
KR-87	2.32E+04	7.45E+04	2.50E+02	0.00E+00	0.00E+00	0.00E+00	2.49E-02	1.75E-02	0.00E+00	0.00E+00	0.00E+00
KR-88	3.36E+04	1.08E+05	3.62E+02	0.00E+00	0.00E+00	0.00E+00	4.58E-02	8.24E-03	0.00E+00	0.00E+00	0.00E+00
						1.15E+00	2.53E-01	8.69E-02	0.00E+00	0.00E+00	0.00E+00

QDC CRDA, EAB, ALL REL MVP: SIEMENS 20 GWD/MTU: 0 - 6 s

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO

SPRAYED VOL

AT 2.000 HOURS: X/Q(SITE)= .00E+00 SEC/M3 PRIMARY LEAK RATE= .000 PERCENT/DAY CONTROL ROOM INTAKE=  
 .0 CPM  
 X/Q CONT ROOM= .00E+00 SEC/M3 SEC RELEASE RATE= .00E+00 VOL/DAY PCT PRI LKG TO ATM =  
 00.00

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
.000	.000	.000	.000	1.000	1.000
.000	.000	.000	.000	1.000	1.000
.000	.000	.000	.000	1.000	1.000

TOTAL DOSES 0-30 DAYS	1.15E+00	2.53E-01	8.69E-02	0.00E+00	0.00E+00	0.00E+00
-----------------------	----------	----------	----------	----------	----------	----------

1

QDC CRDA, EAB, ALL REL MVP: SIEMENS 20 GWD/MTU: 0 - 6 s

## ACTIVITY RELEASED (CURIES)

## ISOTOPE            2. HRS

## ELEMENTAL

I-131	3.92E+00	3.92E+00
I-132	5.65E+00	5.65E+00
I-133	7.89E+00	7.89E+00
I-134	9.10E+00	9.10E+00
I-135	7.08E+00	7.08E+00

## PARTICULATE

I-131	2.16E-01	2.16E-01
I-132	3.10E-01	3.10E-01
I-133	4.34E-01	4.34E-01
I-134	5.00E-01	5.00E-01
I-135	3.89E-01	3.89E-01

## ORGANIC

I-131	1.72E-01	1.72E-01
I-132	2.48E-01	2.48E-01
I-133	3.47E-01	3.47E-01
I-134	4.00E-01	4.00E-01
I-135	3.11E-01	3.11E-01

## NOBLE GASES

XE-131M	3.09E+00	3.09E+00
XE-133M	2.09E+01	2.09E+01
XE-133	8.67E+02	8.67E+02
XE-135M	2.34E+02	2.34E+02
XE-135	2.86E+02	2.86E+02
XE-138	7.81E+02	7.81E+02
KR-83M	4.64E+01	4.64E+01
KR-85M	1.27E+02	1.27E+02
KR-85	5.82E+00	5.82E+00
KR-87	2.50E+02	2.50E+02
KR-88	3.62E+02	3.62E+02

END EXECUTION DATE: 11/18/1999

END EXECUTION TIME: 17:19:12.51

AXIDENT VER 2 MOD 4  
 PRODUCTION DATE 02/18/92  
 BEGIN EXECUTION DATE: 11/18/1999  
 BEGIN EXECUTION TIME: 17:19:12.51

1 QDC CRDA, EAB, ALL REL MVP: SIEMENS 20 GWD/MTU: 0 - 6 s  
 2 2 1 1. 1.  
 3 -2561 2.60+6 1.845+5 5.83+4  
 4 0. 0. 0. 1. 1. 2.78+5 0.  
 5 6 7200  
 6 0.2402 0.  
 7 9.058E-4 0.  
 8 2\*1.  
 9 2\*0.  
 10 2.9E-4 0.  
 11 2\*0.  
 12 2\*0.  
 13 2\*0.  
 14 2\*0.  
 15 2\*0.  
 16 2\*0.  
 17 2\*0.  
 18 2\*0.  
 19 2\*0.  
 20 2\*0.  
 21 6\*1.  
 22 3\*1.  
 23 6.75E+3 9.73E+3 1.36E+4 1.57E+4 1.22E+4 1.21E+3 8.18E+3 3.40E+5  
 24 9.21E+4 1.12E+5 3.07E+5 1.82E+4 4.99E+4 2.28E+3 9.80E+4 1.42E+5

1

QDC CRDA, EAB, ALL REL MVP: SIEMENS 20 GWD/MTU: 0 - 6 s

## INITIAL CONTAINMENT INVENTORY

ISOTOPE	ACTIVITY (CURIES)
I-131	6.760E+03
I-132	9.730E+03
I-133	1.360E+04
I-134	1.570E+04
I-135	1.220E+04
XE-131M	1.210E+03
XE-133M	8.180E+03
XE-133	3.400E+05
XE-135M	9.210E+04
XE-135	1.120E+05
XE-138	3.070E+05
KR-83M	1.820E+04
KR-85M	4.990E+04
KR-85	2.280E+03
KR-87	9.800E+04
KR-88	1.420E+05

1

QDC CRDA, EAB, ALL REL MVP: SIEMENS 20 GWD/MTU: 0 - 6 s

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

SPRAYED VOL	1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL,	1. CFM MIXING, 00.00 PCT REL TO
-------------	--	---------------------------------

AT .002 HOURS: X/Q(SITE)= .29E-03 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM INTAKE=
.0 CFM		
X/Q CONT ROOM= .00E+00 SEC/M3	SEC RELEASE RATE= .78E+02 VOL/DAY	PCT PRI LKG TO ATM =
00.00		

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM (CURIES) (UCI/CM3)	SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE		THYROID	WH BODY	BETA	THYROID	WH BODY	BETA
ELEMENTAL										
I-131	3.64E+02	1.17E+03	3.92E+00	0.00E+00	0.00E+00	5.84E-01	1.06E-04	5.16E-05	0.00E+00	0.00E+00
I-132	5.24E+02	1.68E+03	5.65E+00	0.00E+00	0.00E+00	3.04E-02	9.82E-04	1.69E-04	0.00E+00	0.00E+00
I-133	7.32E+02	2.35E+03	7.89E+00	0.00E+00	0.00E+00	3.18E-01	2.73E-04	2.23E-04	0.00E+00	0.00E+00
I-134	8.44E+02	2.71E+03	9.10E+00	0.00E+00	0.00E+00	2.29E-02	1.28E-03	2.76E-04	0.00E+00	0.00E+00

I-135	6.57E+02	2.11E+03	7.08E+00	0.00E+00	0.00E+00	8.83E-02	9.13E-04	1.45E-04	0.00E+00	0.00E+00	0.00E+00
<b>PARTICULATE</b>											
I-131	2.00E+01	6.43E+01	2.16E-01	0.00E+00	0.00E+00	3.21E-02	5.80E-06	2.83E-06	0.00E+00	0.00E+00	0.00E+00
I-132	2.88E+01	9.25E+01	3.10E-01	0.00E+00	0.00E+00	1.67E-03	5.40E-05	9.27E-06	0.00E+00	0.00E+00	0.00E+00
I-133	4.02E+01	1.29E+02	4.34E-01	0.00E+00	0.00E+00	1.75E-02	1.50E-05	1.22E-05	0.00E+00	0.00E+00	0.00E+00
I-134	4.64E+01	1.49E+02	5.00E-01	0.00E+00	0.00E+00	1.26E-03	7.03E-05	1.52E-05	0.00E+00	0.00E+00	0.00E+00
I-135	3.51E+01	1.16E+02	3.89E-01	0.00E+00	0.00E+00	4.85E-03	5.02E-05	7.99E-06	0.00E+00	0.00E+00	0.00E+00
<b>ORGANIC</b>											
I-131	1.60E+01	5.14E+01	1.72E-01	0.00E+00	0.00E+00	2.57E-02	4.64E-06	2.27E-06	0.00E+00	0.00E+00	0.00E+00
I-132	2.30E+01	7.40E+01	2.48E-01	0.00E+00	0.00E+00	1.34E-03	4.32E-05	7.41E-06	0.00E+00	0.00E+00	0.00E+00
I-133	3.22E+01	1.03E+02	3.47E-01	0.00E+00	0.00E+00	1.40E-02	1.20E-05	9.79E-06	0.00E+00	0.00E+00	0.00E+00
I-134	3.71E+01	1.19E+02	4.00E-01	0.00E+00	0.00E+00	1.01E-03	5.63E-05	1.21E-05	0.00E+00	0.00E+00	0.00E+00
I-135	2.89E+01	9.28E+01	3.11E-01	0.00E+00	0.00E+00	3.88E-03	4.01E-05	6.39E-06	0.00E+00	0.00E+00	0.00E+00
<b>NOBLE GASES</b>											
XE-131M	2.86E+02	9.21E+02	3.09E+00	0.00E+00	0.00E+00	0.00E+00	4.92E-06	2.78E-05	0.00E+00	0.00E+00	0.00E+00
XE-133M	1.94E+03	6.22E+03	2.09E+01	0.00E+00	0.00E+00	0.00E+00	4.99E-05	2.16E-04	0.00E+00	0.00E+00	0.00E+00
XE-133	8.05E+04	2.59E+05	8.67E+02	0.00E+00	0.00E+00	0.00E+00	1.89E-03	8.45E-03	0.00E+00	0.00E+00	0.00E+00
XE-135M	2.17E+04	6.98E+04	2.34E+02	0.00E+00	0.00E+00	0.00E+00	7.17E-03	1.52E-03	0.00E+00	0.00E+00	0.00E+00
XE-135	2.65E+04	8.52E+04	2.86E+02	0.00E+00	0.00E+00	0.00E+00	5.10E-03	6.14E-03	0.00E+00	0.00E+00	0.00E+00
XE-136	7.24E+04	2.33E+05	7.81E+02	0.00E+00	0.00E+00	0.00E+00	1.63E-01	4.17E-02	0.00E+00	0.00E+00	0.00E+00
KR-83M	4.30E+03	1.38E+04	4.64E+01	0.00E+00	0.00E+00	0.00E+00	1.68E-05	1.05E-04	0.00E+00	0.00E+00	0.00E+00
KR-85M	1.18E+04	3.80E+04	1.27E+02	0.00E+00	0.00E+00	0.00E+00	1.44E-03	1.98E-03	0.00E+00	0.00E+00	0.00E+00
KR-85	5.40E+02	1.73E+03	5.82E+00	0.00E+00	0.00E+00	0.00E+00	8.86E-07	8.65E-05	0.00E+00	0.00E+00	0.00E+00
KR-87	2.32E+04	7.45E+04	2.50E+02	0.00E+00	0.00E+00	0.00E+00	2.49E-02	1.75E-02	0.00E+00	0.00E+00	0.00E+00
KR-88	3.36E+04	1.08E+05	3.62E+02	0.00E+00	0.00E+00	0.00E+00	4.58E-02	8.24E-03	0.00E+00	0.00E+00	0.00E+00
							1.15E+00	2.53E-01	8.69E-02	0.00E+00	0.00E+00

1

QDC CRDA, EAB, ALL REL MVP: SIEMENS 20 GWD/MTU: 0 - 6 s

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO

SPRAYED VOL

AT	2.000 HOURS:	X/Q(SITE)= .00E+00 SEC/M3	PRIMARY LEAK RATE= .000 PERCENT/DAY	CONTROL ROOM INTAKE=
.0 CFM				
		X/Q CONT ROOM= .00E+00 SEC/M3	SEC RELEASE RATE= .00E+00 VOL/DAY	PCT PRI LKG TO ATM =
00.00				

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM		SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA
<b>ELEMENTAL</b>											
I-131	3.61E+02	1.16E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	2.87E+02	9.22E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	6.85E+02	2.20E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	1.71E+02	5.50E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	5.34E+02	1.72E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>PARTICULATE</b>											
I-131	1.99E+01	6.38E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	1.58E+01	5.06E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	3.77E+01	1.21E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	9.39E+00	3.02E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	2.94E+01	9.44E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>ORGANIC</b>											
I-131	1.59E+01	5.11E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.60E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	1.26E+01	4.05E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	3.01E+01	9.69E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	7.51E+00	2.42E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	2.35E+01	7.55E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>NOBLE GASES</b>											
XE-131M	2.85E+02	9.16E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
XE-133M	1.89E+03	6.07E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
XE-133	7.96E+04	2.56E+05	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
XE-135M	1.06E+02	3.40E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
XE-135	2.28E+04	7.32E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
XE-138	6.27E+02	2.02E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
KR-83M	2.05E+03	6.60E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
KR-85M	8.61E+03	2.77E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
KR-85	5.40E+02	1.73E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
KR-87	7.76E+03	2.50E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
KR-88	2.05E+04	6.58E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

0.00E+00 0.00E+00 0.00E+00 0.00E+00 0.00E+00 0.00E+00

TOTAL DOSES 0-30 DAYS	1.15E+00	2.53E-01	8.69E-02	0.00E+00	0.00E+00	0.00E+00
-----------------------	----------	----------	----------	----------	----------	----------

1

QDC CRDA, EAB, ALL REL MVP: SIEMENS 20 GWD/MTU: 0 - 6 s

ISOTOPE	ACTIVITY RELEASED (CURIES)
2. HRS	
ELEMENTAL	
I-131	3.92E+00 3.92E+00
I-132	5.65E+00 5.65E+00
I-133	7.89E+00 7.89E+00
I-134	9.10E+00 9.10E+00
I-135	7.08E+00 7.08E+00
PARTICULATE	
I-131	2.16E-01 2.16E-01
I-132	3.10E-01 3.10E-01
I-133	4.34E-01 4.34E-01
I-134	5.00E-01 5.00E-01
I-135	3.89E-01 3.89E-01
ORGANIC	
I-131	1.72E-01 1.72E-01
I-132	2.48E-01 2.48E-01
I-133	3.47E-01 3.47E-01
I-134	4.00E-01 4.00E-01
I-135	3.11E-01 3.11E-01
NOBLE GASES	
XE-131M	3.09E+00 3.09E+00
XE-133M	2.09E+01 2.09E+01
XE-133	8.67E+02 8.67E+02
XE-135M	2.34E+02 2.34E+02
XE-135	2.86E+02 2.86E+02
XE-138	7.81E+02 7.81E+02
KR-83M	4.64E+01 4.64E+01
KR-85M	1.27E+02 1.27E+02
KR-85	5.82E+00 5.82E+00
KR-87	2.50E+02 2.50E+02
KR-88	3.62E+02 3.62E+02

END EXECUTION DATE: 11/18/1999  
 END EXECUTION TIME: 17:19:12.51

AXIDENT VER 2 MOD 4  
PRODUCTION DATE 02/18/92  
BEGIN EXECUTION DATE: 11/18/1999  
BEGIN EXECUTION TIME: 17:19:04.99

```

1 QDC CRDA, EAB, ALL REL AOG: SIEMENS 20 GWD/MTU: 6 s - 2 h
2 3 1 1. 1.
3 -2561 2.60+6 1.845+5 5.83+4
4 0. 0. 0. 1. 1. 2.78+5 0.
5 6 1800 7200
6 0.2402 2*1.201E-2
7 9.058E-4 2*1.157E-5
8 3*1.
9 3*0.
10 0. 2.9e-4 2.3E-5
11 3*0.
12 3*0.
13 3*0.
14 3*0.
15 3*0.
16 3*0.
17 3*0.
18 3*0.
19 3*0.
20 3*0.
21 3*0. 3*1.
22 3*1.
23 6.76E+3      9.73E+3   1.36E+4   1.57E+4   1.22E+4   1.21E+3   8.18E+3   3.40E+5
24 9.21E+4      1.12E+5   3.07E+5   1.82E+4   4.99E+4   2.28E+3   9.80E+4   1.42E+5

```

1

ODC CRDA, EAB, ALL REL AOG: SIEMENS 20 GWD/MTU: 6 s - 2 h

## INITIAL CONTAINMENT INVENTORY

ISOTOPE	ACTIVITY (CURIES)
I-131	6.760E+03
I-132	9.730E+03
I-133	1.360E+04
I-134	1.570E+04
I-135	1.220E+04
XE-131M	1.210E+03
XE-133M	8.180E+03
XE-133	3.400E+05
XE-135M	9.210E+04
XE-135	1.120E+05
XE-138	3.070E+05
KR-83M	1.820E+04
KR-85M	4.990E+04
KR-85	2.280E+03
KR-87	9.800E+04
KR-88	1.420E+05

1

RR 03 1400Z 03  
ODC CRDA, EAB, ALL REL AOG: SIEMENS 20 GWD/MTU: 6 s - 2 h

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO  
SPRAYED VOL

AT .0002 HOURS: X/Q(SITE)= .00E+00 SEC/M3 PRIMARY LEAK RATE=\*\*\*\*\* PERCENT/DAY CONTROL ROOM INTAKE=.  
 .0 CFM  
 X/Q CONT ROOM= .00E+00 SEC/M3 SEC RELEASE RATE= .78E+02 VOL/DAY PCT PRI LKG TO ATM =  
 00.00

CLEANUP RATES (HR-1)				FILTER NON-REMPTION FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
.000	.000	.000	.000	.000	1.000
.000	.000	.000	.000	.000	1.000
.000	.000	.000	.000	.000	1.000

I-135	6.57E+02	2.11E+03	0.00E+00								
PARTICULATE											
I-131	2.00E+01	6.43E+01	0.00E+00								
I-132	2.88E+01	9.25E+01	0.00E+00								
I-133	4.02E+01	1.29E+02	0.00E+00								
I-134	4.64E+01	1.49E+02	0.00E+00								
I-135	3.61E+01	1.16E+02	0.00E+00								
ORGANIC											
I-131	1.60E+01	5.14E+01	0.00E+00								
I-132	2.30E+01	7.40E+01	0.00E+00								
I-133	3.22E+01	1.03E+02	0.00E+00								
I-134	3.71E+01	1.19E+02	0.00E+00								
I-135	2.89E+01	9.28E+01	0.00E+00								
NOBLE GASES											
XE-131M	2.86E+02	9.21E+02	3.09E+00	0.00E+00							
XE-133M	1.94E+03	6.22E+03	2.09E+01	0.00E+00							
XE-133	8.05E+04	2.59E+05	8.67E+02	0.00E+00							
XE-135M	2.17E+04	6.98E+04	2.34E+02	0.00E+00							
XE-135	2.65E+04	8.52E+04	2.86E+02	0.00E+00							
XE-138	7.24E+04	2.33E+05	7.81E+02	0.00E+00							
KR-83M	4.30E+03	1.38E+04	4.64E+01	0.00E+00							
KR-85M	1.18E+04	3.80E+04	1.27E+02	0.00E+00							
KR-85	5.40E+02	1.73E+03	5.82E+00	0.00E+00							
KR-87	2.32E+04	7.45E+04	2.50E+02	0.00E+00							
KR-88	3.36E+04	1.08E+05	3.62E+02	0.00E+00							

1 QDC CRDA, EAB, ALL REL AOG: SIEMENS 20 GWD/MTU: 6 s - 2 h

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO

SPRAYED VOL

AT	.500 HOURS:	X/Q(SITE)= .29E-03 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM INTAKE=
.0 CFM				
		X/Q CONT ROOM= .00E+00 SEC/M3	SEC RELEASE RATE= .10E+01 VOL/DAY	PCT PRI LKG TO ATM =
00.00				

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	.000	1.000
PARTICULATE	.000	.000	.000	.000	1.000
ORGANIC	.000	.000	.000	.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM (CURIES)	SITE BOUNDARY DOSES (REM)	CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE	(UCI/CM3)	THYROID WH BODY	BETA	THYROID WH BODY	BETA
ELEMENTAL								
I-131	1.60E-07	1.50E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	1.98E-07	1.86E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	3.16E-07	2.97E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	2.49E-07	2.34E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	2.74E-07	2.58E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
PARTICULATE								
I-131	8.77E-09	8.24E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	1.09E-08	1.02E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	1.74E-08	1.63E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	1.37E-08	1.29E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	1.51E-08	1.42E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ORGANIC								
I-131	7.01E-09	6.59E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	8.70E-09	8.18E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	1.39E-08	1.31E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	1.09E-08	1.03E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	1.20E-08	1.13E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
NOBLE GASES								
XE-131M	1.26E-07	1.18E+03	2.45E+01	0.00E+00	0.00E+00	3.91E-05	2.21E-04	0.00E+00
XE-133M	8.45E-07	7.94E+03	1.65E+02	0.00E+00	0.00E+00	3.95E-04	1.71E-03	0.00E+00
XE-133	3.52E-05	3.31E+05	6.88E+03	0.00E+00	0.00E+00	1.50E-02	6.70E-02	0.00E+00
XE-135M	2.53E-06	2.38E+04	1.02E+03	0.00E+00	0.00E+00	3.13E-02	6.62E-03	0.00E+00
XE-135	1.12E-05	1.05E+05	2.23E+03	0.00E+00	0.00E+00	3.97E-02	4.78E-02	0.00E+00
XE-138	9.73E-06	9.14E+04	3.61E+03	0.00E+00	0.00E+00	7.52E-01	1.93E-01	0.00E+00
KR-83M	1.57E-06	1.48E+04	3.36E+02	0.00E+00	0.00E+00	1.22E-04	7.63E-04	0.00E+00
KR-85M	4.79E-06	4.51E+04	9.72E+02	0.00E+00	0.00E+00	1.10E-02	1.51E-02	0.00E+00
KR-85	2.37E-07	2.23E+03	4.62E+01	0.00E+00	0.00E+00	7.04E-06	6.87E-04	0.00E+00
KR-87	7.75E-06	7.28E+04	1.74E+03	0.00E+00	0.00E+00	1.73E-01	1.22E-01	0.00E+00
KR-88	1.30E-05	1.23E+05	2.71E+03	0.00E+00	0.00E+00	3.42E-01	6.15E-02	0.00E+00

1 QDC CRDA, EAB, ALL REL AOG: SIEMENS 20 GWD/MTU: 6 s - 2 h

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO  
SPRAYED VOL

AT .0 CFM	2.000 HOURS:	X/Q(SITE) = .23E-04 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM INTAKE=
		X/Q CONT ROOM= .00E+00 SEC/M3	SEC RELEASE RATE= .10E+01 VOL/DAY	PCT PRI LKG TO ATM =
		00.00		

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS		
	SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	.000	.000	1.000
PARTICULATE	.000	.000	.000	.000	.000	1.000
ORGANIC	.000	.000	.000	.000	.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM (CURIES) (UCI/CM3)	SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)			
	PRIMARY	SECONDARY	RELEASE		THYROID	WH BODY	BETA	THYROID	WH BODY	BETA	
ELEMENTAL											
I-131	1.08E-35	1.40E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00		
I-132	8.60E-36	1.11E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00		
I-133	2.06E-35	2.66E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00		
I-134	5.13E-36	6.63E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00		
I-135	1.60E-35	2.07E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00		
PARTICULATE											
I-131	5.95E-37	7.70E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00		
I-132	4.72E-37	6.11E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00		
I-133	1.13E-36	1.46E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00		
I-134	2.82E-37	3.64E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00		
I-135	8.80E-37	1.14E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00		
ORGANIC											
I-131	4.76E-37	6.16E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00		
I-132	3.78E-37	4.89E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00		
I-133	9.04E-37	1.17E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00		
I-134	2.25E-37	2.91E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00		
I-135	7.04E-37	9.11E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00		
NOBLE GASES											
XE-131M	8.55E-36	1.11E+03	7.14E+01	0.00E+00	0.00E+00	0.00E+00	9.03E-06	5.10E-05	0.00E+00	0.00E+00	
XE-133M	5.66E-35	7.32E+03	4.77E+02	0.00E+00	0.00E+00	0.00E+00	9.04E-05	3.91E-04	0.00E+00	0.00E+00	
XE-133	2.39E-33	3.09E+05	2.00E+04	0.00E+00	0.00E+00	0.00E+00	3.45E-03	1.54E-02	0.00E+00	0.00E+00	
XE-135M	3.17E-36	4.10E+02	3.59E+02	0.00E+00	0.00E+00	0.00E+00	8.72E-04	1.84E-04	0.00E+00	0.00E+00	
XE-135	6.83E-34	8.83E+04	6.04E+03	0.00E+00	0.00E+00	0.00E+00	8.54E-03	1.03E-02	0.00E+00	0.00E+00	
XE-138	1.88E-35	2.43E+03	1.53E+03	0.00E+00	0.00E+00	0.00E+00	2.53E-02	6.49E-03	0.00E+00	0.00E+00	
KR-83M	6.15E-35	7.96E+03	6.88E+02	0.00E+00	0.00E+00	0.00E+00	1.98E-05	1.24E-04	0.00E+00	0.00E+00	
KR-85M	2.58E-34	3.34E+04	2.43E+03	0.00E+00	0.00E+00	0.00E+00	2.18E-03	3.00E-03	0.00E+00	0.00E+00	
KR-85	1.62E-35	2.09E+03	1.35E+02	0.00E+00	0.00E+00	0.00E+00	1.63E-06	1.59E-04	0.00E+00	0.00E+00	
KR-87	2.33E-34	3.01E+04	3.02E+03	0.00E+00	0.00E+00	0.00E+00	2.39E-02	1.68E-02	0.00E+00	0.00E+00	
KR-88	6.14E-34	7.94E+04	6.21E+03	0.00E+00	0.00E+00	0.00E+00	6.23E-02	1.12E-02	0.00E+00	0.00E+00	
							0.00E+00	1.27E-01	6.41E-02	0.00E+00	0.00E+00
				TOTAL DOSES 0-30 DAYS	0.00E+00	1.49E+00	5.80E-01	0.00E+00	0.00E+00	0.00E+00	

1

QDC CRDA, EAB, ALL REL AOG: SIEMENS 20 GWD/MTU: 6 s - 2 h

ISOTOPE ACTIVITY RELEASED (CURIES)

2. HRS

ELEMENTAL		
I-131	0.00E+00	0.00E+00
I-132	0.00E+00	0.00E+00
I-133	0.00E+00	0.00E+00
I-134	0.00E+00	0.00E+00
I-135	0.00E+00	0.00E+00

PARTICULATE		
I-131	0.00E+00	0.00E+00
I-132	0.00E+00	0.00E+00
I-133	0.00E+00	0.00E+00
I-134	0.00E+00	0.00E+00
I-135	0.00E+00	0.00E+00

ORGANIC		
I-131	0.00E+00	0.00E+00
I-132	0.00E+00	0.00E+00
I-133	0.00E+00	0.00E+00
I-134	0.00E+00	0.00E+00
I-135	0.00E+00	0.00E+00

NOBLE GASES		
XE-131M	9.90E+01	9.90E+01

XE-133M	6.63E+02	6.63E+02
XE-133	2.77E+04	2.77E+04
XE-135M	1.62E+03	1.62E+03
XE-135	8.55E+03	8.55E+03
XE-138	5.93E+03	5.93E+03
KR-83M	1.07E+03	1.07E+03
KR-85M	3.53E+03	3.53E+03
KR-85	1.87E+02	1.87E+02
KR-87	5.01E+03	5.01E+03
KR-88	9.28E+03	9.28E+03

END EXECUTION DATE: 11/18/1999  
END EXECUTION TIME: 17:19:05.04

AXIDENT VER 2 MOD 4  
 PRODUCTION DATE 02/18/92  
 BEGIN EXECUTION DATE: 11/18/1999  
 BEGIN EXECUTION TIME: 17:19:37.17

1 QDC CRDA, EAB, ALL REL GLAND: SIEMENS 20 GWD/MTU: 0 - 2 h  
 2 3 2 1. 1.  
 3 -2561 2.60+6 1.845+5 5.83+4  
 4 0. 0. 0. 1. 1. 2.78+5 0.  
 5 6 1800 7200  
 6 0.2402 2\*1.201E-2  
 7 3\*1.  
 8 3\*1.  
 9 3\*0.  
 10 2\*2.9e-4 2.3E-5  
 11 3\*0.  
 12 3\*0.  
 13 3\*0.  
 14 3\*0.  
 15 3\*0.  
 16 3\*0.  
 17 3\*0.  
 18 3\*0.  
 19 3\*0.  
 20 3\*0.  
 21 6\*1.  
 22 3\*1.  
 23 6.76E+3 9.73E+3 1.36E+4 1.57E+4 1.22E+4 1.21E+3 8.18E+3 3.40E+5  
 24 9.21E+4 1.12E+5 3.07E+5 1.82E+4 4.99E+4 2.28E+3 9.80E+4 1.42E+5

1

QDC CRDA, EAB, ALL REL GLAND: SIEMENS 20 GWD/MTU: 0 - 2 h

## INITIAL CONTAINMENT INVENTORY

## ISOTOPE ACTIVITY (CURIES)

I-131	6.760E+03
I-132	9.730E+03
I-133	1.360E+04
I-134	1.570E+04
I-135	1.220E+04
XE-131M	1.210E+03
XE-133M	8.180E+03
XE-133	3.400E+05
XE-135M	9.210E+04
XE-135	1.120E+05
XE-138	3.070E+05
KR-83M	1.820E+04
KR-85M	4.990E+04
KR-85	2.280E+03
KR-87	9.800E+04
KR-88	1.420E+05

1

QDC CRDA, EAB, ALL REL GLAND: SIEMENS 20 GWD/MTU: 0 - 2 h

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
 SPRAYED VOL 1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO

AT .002 HOURS:	X/Q(SITE)= .29E-03 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM INTAKE=
.0 CFM			
	X/Q CONT ROOM= .00E+00 SEC/M3	SEC RELEASE RATE= .86E+05 VOL/DAY	PCT PRI LKG TO ATM =
00.00			

	CLEANUP RATES (HR-1)			FILTER NON-REMOVAL FACTORS		
	SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM		SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA
ELEMENTAL											
I-131	3.64E+02	1.14E+02	1.06E+03	0.00E+00	0.00E+00	1.58E+02	2.85E-02	1.39E-02	0.00E+00	0.00E+00	0.00E+00
I-132	5.24E+02	1.64E+02	1.53E+03	0.00E+00	0.00E+00	8.21E+00	2.65E-01	4.56E-02	0.00E+00	0.00E+00	0.00E+00
I-133	7.32E+02	2.29E+02	2.13E+03	0.00E+00	0.00E+00	8.58E+01	7.38E-02	6.02E-02	0.00E+00	0.00E+00	0.00E+00
I-134	8.44E+02	2.64E+02	2.46E+03	0.00E+00	0.00E+00	6.19E+00	3.46E-01	7.47E-02	0.00E+00	0.00E+00	0.00E+00

I-135	6.57E+02	2.05E+02	1.91E+03	0.00E+00	0.00E+00	2.39E+01	2.47E-01	3.93E-02	0.00E+00	0.00E+00	0.00E+00
<b>PARTICULATE</b>											
I-131	2.00E+01	6.26E+00	5.82E+01	0.00E+00	0.00E+00	8.68E+00	1.57E-03	7.65E-04	0.00E+00	0.00E+00	0.00E+00
I-132	2.88E+01	9.00E+00	8.38E+01	0.00E+00	0.00E+00	4.51E-01	1.46E-02	2.50E-03	0.00E+00	0.00E+00	0.00E+00
I-133	4.02E+01	1.26E+01	1.17E+02	0.00E+00	0.00E+00	4.72E+00	4.05E-03	3.31E-03	0.00E+00	0.00E+00	0.00E+00
I-134	4.64E+01	1.45E+01	1.35E+02	0.00E+00	0.00E+00	3.40E-01	1.90E-02	4.10E-03	0.00E+00	0.00E+00	0.00E+00
I-135	3.61E+01	1.13E+01	1.05E+02	0.00E+00	0.00E+00	1.31E+00	1.36E-02	2.16E-03	0.00E+00	0.00E+00	0.00E+00
<b>ORGANIC</b>											
I-131	1.60E+01	5.00E+00	4.66E+01	0.00E+00	0.00E+00	6.94E+00	1.25E-03	6.12E-04	0.00E+00	0.00E+00	0.00E+00
I-132	2.30E+01	7.20E+00	6.71E+01	0.00E+00	0.00E+00	3.61E-01	1.17E-02	2.00E-03	0.00E+00	0.00E+00	0.00E+00
I-133	3.22E+01	1.01E+01	9.37E+01	0.00E+00	0.00E+00	3.77E+00	3.24E-03	2.64E-03	0.00E+00	0.00E+00	0.00E+00
I-134	3.71E+01	1.16E+01	1.08E+02	0.00E+00	0.00E+00	2.72E-01	1.52E-02	3.28E-03	0.00E+00	0.00E+00	0.00E+00
I-135	2.89E+01	9.03E+00	8.41E+01	0.00E+00	0.00E+00	1.05E+00	1.08E-02	1.73E-03	0.00E+00	0.00E+00	0.00E+00
<b>NOBLE GASES</b>											
XE-131M	2.86E+02	8.96E+01	8.34E+02	0.00E+00	0.00E+00	0.00E+00	1.33E-03	7.51E-03	0.00E+00	0.00E+00	0.00E+00
XE-133M	1.94E+03	6.06E+02	5.64E+03	0.00E+00	0.00E+00	0.00E+00	1.35E-02	5.83E-02	0.00E+00	0.00E+00	0.00E+00
XE-133	8.05E+04	2.52E+04	2.34E+05	0.00E+00	0.00E+00	0.00E+00	5.10E-01	2.28E+00	0.00E+00	0.00E+00	0.00E+00
XE-135M	2.17E+04	6.79E+03	6.34E+04	0.00E+00	0.00E+00	0.00E+00	1.94E+00	4.10E-01	0.00E+00	0.00E+00	0.00E+00
XE-135	2.65E+04	8.29E+03	7.72E+04	0.00E+00	0.00E+00	0.00E+00	1.38E+00	1.66E+00	0.00E+00	0.00E+00	0.00E+00
XE-138	7.24E+04	2.26E+04	2.11E+05	0.00E+00	0.00E+00	0.00E+00	4.39E+01	1.13E+01	0.00E+00	0.00E+00	0.00E+00
KR-83M	4.30E+03	1.35E+03	1.25E+04	0.00E+00	0.00E+00	0.00E+00	4.55E-03	2.84E-02	0.00E+00	0.00E+00	0.00E+00
KR-85M	1.18E+04	3.69E+03	3.44E+04	0.00E+00	0.00E+00	0.00E+00	3.89E-01	5.35E-01	0.00E+00	0.00E+00	0.00E+00
KR-85	5.40E+02	1.69E+02	1.57E+03	0.00E+00	0.00E+00	0.00E+00	2.39E-04	2.34E-02	0.00E+00	0.00E+00	0.00E+00
KR-87	2.32E+04	7.25E+03	6.75E+04	0.00E+00	0.00E+00	0.00E+00	6.73E+00	4.73E+00	0.00E+00	0.00E+00	0.00E+00
KR-88	3.36E+04	1.05E+04	9.79E+04	0.00E+00	0.00E+00	0.00E+00	1.24E+01	2.23E+00	0.00E+00	0.00E+00	0.00E+00
							3.10E+02	6.83E+01	2.35E+01	0.00E+00	0.00E+00

1 QDC CRDA, EAB, ALL REL GLAND: SIEMENS 20 GWD/MTU: 0 - 2 h

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO

SPRAYED VOL

AT .500 HOURS:	X/Q(SITE)= .29E-03 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM INTAKE=
.0 CFM	X/Q CONT ROOM= .00E+00 SEC/M3	SEC RELEASE RATE= .86E+05 VOL/DAY	PCT PRI LKG TO ATM =
00.00			

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS		
	SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM (CURIES) (UCI/CM3)	SITE BOUNDARY DOSES (REM)	THYROID WH BODY BETA	CONTROL ROOM DOSES (REM)			
	PRIMARY	SECONDARY	RELEASE				THYROID	WH BODY	BETA	
<b>ELEMENTAL</b>										
I-131	1.60E-07	1.94E-09	4.78E+02	0.00E+00	0.00E+00	7.12E+01	1.29E-02	6.28E-03	0.00E+00	0.00E+00
I-132	1.98E-07	2.41E-09	6.84E+02	0.00E+00	0.00E+00	3.68E+00	1.19E-01	2.04E-02	0.00E+00	0.00E+00
I-133	3.16E-07	3.85E-09	9.61E+02	0.00E+00	0.00E+00	3.87E+01	3.32E-02	2.71E-02	0.00E+00	0.00E+00
I-134	2.49E-07	3.03E-09	1.09E+03	0.00E+00	0.00E+00	2.75E+00	1.54E-01	3.32E-02	0.00E+00	0.00E+00
I-135	2.74E-07	3.33E-09	8.61E+02	0.00E+00	0.00E+00	1.07E+01	1.11E-01	1.77E-02	0.00E+00	0.00E+00
<b>PARTICULATE</b>										
I-131	8.77E-09	1.07E-10	2.62E+01	0.00E+00	0.00E+00	3.91E+00	7.06E-04	3.45E-04	0.00E+00	0.00E+00
I-132	1.09E-08	1.32E-10	3.76E+01	0.00E+00	0.00E+00	2.02E-01	6.54E-03	1.12E-03	0.00E+00	0.00E+00
I-133	1.74E-08	2.11E-10	5.28E+01	0.00E+00	0.00E+00	2.12E+00	1.83E-03	1.49E-03	0.00E+00	0.00E+00
I-134	1.37E-08	1.66E-10	6.00E+01	0.00E+00	0.00E+00	1.51E-01	8.44E-03	1.82E-03	0.00E+00	0.00E+00
I-135	1.51E-08	1.83E-10	4.73E+01	0.00E+00	0.00E+00	5.90E-01	6.10E-03	9.71E-04	0.00E+00	0.00E+00
<b>ORGANIC</b>										
I-131	7.01E-09	8.53E-11	2.10E+01	0.00E+00	0.00E+00	3.13E+00	5.65E-04	2.76E-04	0.00E+00	0.00E+00
I-132	8.70E-09	1.06E-10	3.01E+01	0.00E+00	0.00E+00	1.62E-01	5.23E-03	8.98E-04	0.00E+00	0.00E+00
I-133	1.39E-08	1.69E-10	4.22E+01	0.00E+00	0.00E+00	1.70E+00	1.46E-03	1.19E-03	0.00E+00	0.00E+00
I-134	1.09E-08	1.33E-10	4.80E+01	0.00E+00	0.00E+00	1.21E-01	6.75E-03	1.46E-03	0.00E+00	0.00E+00
I-135	1.20E-08	1.46E-10	3.78E+01	0.00E+00	0.00E+00	4.72E-01	4.88E-03	7.77E-04	0.00E+00	0.00E+00
<b>NOBLE GASES</b>										
XE-131M	1.26E-07	1.53E-09	3.76E+02	0.00E+00	0.00E+00	6.00E-04	3.38E-03	0.00E+00	0.00E+00	0.00E+00
XE-133M	8.45E-07	1.03E-08	2.54E+03	0.00E+00	0.00E+00	6.08E-03	2.63E-02	0.00E+00	0.00E+00	0.00E+00
XE-133	3.52E-05	4.28E-07	1.06E+05	0.00E+00	0.00E+00	0.00E+00	2.30E-01	1.03E+00	0.00E+00	0.00E+00
XE-135M	2.53E-06	3.07E-08	2.72E+04	0.00E+00	0.00E+00	0.00E+00	8.32E-01	1.76E-01	0.00E+00	0.00E+00
XE-135	1.12E-05	1.36E-07	3.47E+04	0.00E+00	0.00E+00	0.00E+00	6.20E-01	7.46E-01	0.00E+00	0.00E+00
XE-138	9.73E-06	1.18E-07	9.12E+04	0.00E+00	0.00E+00	0.00E+00	1.90E+01	4.86E+00	0.00E+00	0.00E+00
KR-83M	1.57E-06	1.91E-08	5.61E+03	0.00E+00	0.00E+00	0.00E+00	2.03E-03	1.27E-02	0.00E+00	0.00E+00
KR-85M	4.79E-06	5.83E-08	1.55E+04	0.00E+00	0.00E+00	0.00E+00	1.75E-01	2.40E-01	0.00E+00	0.00E+00
KR-85	2.37E-07	2.88E-09	7.08E+02	0.00E+00	0.00E+00	0.00E+00	1.08E-04	1.05E-02	0.00E+00	0.00E+00
KR-87	7.75E-06	9.42E-08	3.01E+04	0.00E+00	0.00E+00	0.00E+00	3.00E+00	2.11E+00	0.00E+00	0.00E+00
KR-88	1.30E-05	1.59E-07	4.39E+04	0.00E+00	0.00E+00	0.00E+00	5.55E+00	9.99E-01	0.00E+00	0.00E+00

1 QDC CRDA, EAB, ALL REL GLAND: SIEMENS 20 GWD/MTU: 0 - 2 h

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO  
SPRAYED VOL

AT .0 CFM	2.000 HOURS: X/Q(SITE)= .23E-04 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM INTAKE=
	X/Q CONT ROOM= .00E+00 SEC/M3	SEC RELEASE RATE= .86E+05 VOL/DAY	PCT PRI LKG TO ATM =
	00.00		

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM (CURIES) (UCI/CM3)	SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE		THYROID	WH BODY	BETA	THYROID	WH BODY	BETA
<b>ELEMENTAL</b>										
I-131	1.08E-35	1.32E-37	1.61E-07	0.00E+00	0.00E+00	1.91E-09	3.45E-13	1.68E-13	0.00E+00	0.00E+00
I-132	8.60E-36	1.05E-37	1.99E-07	0.00E+00	0.00E+00	8.49E-11	2.75E-12	4.71E-13	0.00E+00	0.00E+00
I-133	2.06E-35	2.50E-37	3.20E-07	0.00E+00	0.00E+00	1.02E-09	8.78E-13	7.16E-13	0.00E+00	0.00E+00
I-134	5.13E-36	6.23E-38	2.47E-07	0.00E+00	0.00E+00	4.94E-11	2.76E-12	5.96E-13	0.00E+00	0.00E+00
I-135	1.60E-35	1.95E-37	2.77E-07	0.00E+00	0.00E+00	2.74E-10	2.83E-12	4.51E-13	0.00E+00	0.00E+00
<b>PARTICULATE</b>										
I-131	5.95E-37	7.24E-39	8.87E-09	0.00E+00	0.00E+00	1.05E-10	1.89E-14	9.25E-15	0.00E+00	0.00E+00
I-132	4.72E-37	5.74E-39	1.09E-08	0.00E+00	0.00E+00	4.67E-12	1.51E-13	2.59E-14	0.00E+00	0.00E+00
I-133	1.13E-36	1.37E-38	1.76E-08	0.00E+00	0.00E+00	5.61E-11	4.82E-14	3.93E-14	0.00E+00	0.00E+00
I-134	2.82E-37	3.42E-39	1.36E-08	0.00E+00	0.00E+00	2.71E-12	1.52E-13	3.27E-14	0.00E+00	0.00E+00
I-135	8.80E-37	1.07E-38	1.52E-08	0.00E+00	0.00E+00	1.50E-11	1.55E-13	2.48E-14	0.00E+00	0.00E+00
<b>ORGANIC</b>										
I-131	4.76E-37	5.79E-39	7.10E-09	0.00E+00	0.00E+00	8.39E-11	1.51E-14	7.40E-15	0.00E+00	0.00E+00
I-132	3.78E-37	4.59E-39	8.74E-09	0.00E+00	0.00E+00	3.73E-12	2.12E-13	2.07E-14	0.00E+00	0.00E+00
I-133	9.04E-37	1.10E-38	1.41E-08	0.00E+00	0.00E+00	4.49E-11	3.86E-14	3.15E-14	0.00E+00	0.00E+00
I-134	2.25E-37	2.74E-39	1.09E-08	0.00E+00	0.00E+00	2.17E-12	2.12E-13	2.62E-14	0.00E+00	0.00E+00
I-135	7.04E-37	8.56E-39	1.22E-08	0.00E+00	0.00E+00	1.20E-11	1.24E-13	1.98E-14	0.00E+00	0.00E+00
<b>NOBLE GASES</b>										
XE-131M	8.55E-36	1.04E-37	1.27E-07	0.00E+00	0.00E+00	0.00E+00	1.61E-14	9.08E-14	0.00E+00	0.00E+00
XE-133M	5.66E-35	6.88E-37	8.55E-07	0.00E+00	0.00E+00	0.00E+00	1.62E-13	7.01E-13	0.00E+00	0.00E+00
XE-133	2.39E-33	2.90E-35	3.57E-05	0.00E+00	0.00E+00	0.00E+00	6.15E-12	2.75E-11	0.00E+00	0.00E+00
XE-135M	3.17E-36	3.86E-38	2.41E-06	0.00E+00	0.00E+00	0.00E+00	5.85E-12	2.24E-12	0.00E+00	0.00E+00
XE-135	6.83E-34	8.30E-36	1.13E-05	0.00E+00	0.00E+00	0.00E+00	1.60E-11	1.93E-11	0.00E+00	0.00E+00
XE-138	1.88E-35	2.29E-37	9.33E-06	0.00E+00	0.00E+00	0.00E+00	1.54E-10	3.95E-11	0.00E+00	0.00E+00
KR-83M	6.15E-35	7.48E-37	1.58E-06	0.00E+00	0.00E+00	0.00E+00	4.53E-14	2.84E-13	0.00E+00	0.00E+00
KR-85M	2.58E-34	3.14E-36	4.83E-06	0.00E+00	0.00E+00	0.00E+00	4.34E-12	5.96E-12	0.00E+00	0.00E+00
KR-85	1.62E-35	1.97E-37	2.40E-07	0.00E+00	0.00E+00	0.00E+00	2.90E-15	2.83E-13	0.00E+00	0.00E+00
KR-87	2.33E-34	2.83E-36	7.74E-06	0.00E+00	0.00E+00	0.00E+00	6.12E-11	4.30E-11	0.00E+00	0.00E+00
KR-88	6.14E-34	7.46E-36	1.31E-05	0.00E+00	0.00E+00	0.00E+00	1.32E-10	2.37E-11	0.00E+00	0.00E+00
							3.67E-09	3.90E-10	1.64E-10	0.00E+00
										0.00E+00
				TOTAL DOSES 0-30 DAYS			4.49E+02	9.82E+01	3.38E+01	0.00E+00
										0.00E+00

1

QDC CRDA, EAB, ALL REL GLAND: SIEMENS 20 GWD/MTU: 0 - 2 h

ISOTOPE	ACTIVITY RELEASED (CURIES)	
	2. HRS	
<b>ELEMENTAL</b>		
I-131	1.54E+03	1.54E+03
I-132	2.21E+03	2.21E+03
I-133	3.09E+03	3.09E+03
I-134	3.55E+03	3.55E+03
I-135	2.77E+03	2.77E+03
<b>PARTICULATE</b>		
I-131	8.45E+01	8.45E+01
I-132	1.21E+02	1.21E+02
I-133	1.70E+02	1.70E+02
I-134	1.95E+02	1.95E+02
I-135	1.52E+02	1.52E+02
<b>ORGANIC</b>		
I-131	6.76E+01	6.76E+01
I-132	9.71E+01	9.71E+01
I-133	1.36E+02	1.36E+02
I-134	1.56E+02	1.56E+02
I-135	1.22E+02	1.22E+02
<b>NOBLE GASES</b>		
XE-131M	1.21E+03	1.21E+03

XE-133M	8.18E+03	8.18E+03
XE-133	3.40E+05	3.40E+05
XE-135M	9.06E+04	9.06E+04
XE-135	1.12E+05	1.12E+05
XE-138	3.02E+05	3.02E+05
KR-83M	1.82E+04	1.82E+04
KR-85M	4.98E+04	4.98E+04
KR-85	2.28E+03	2.28E+03
KR-87	9.76E+04	9.76E+04
KR-88	1.42E+05	1.42E+05

END EXECUTION DATE: 11/18/1999  
END EXECUTION TIME: 17:19:37.23

AIXIDENT VER 2 MOD 4  
 PRODUCTION DATE 02/18/92  
 BEGIN EXECUTION DATE: 11/18/1999  
 BEGIN EXECUTION TIME: 17:45:17.01

1 QDC CRDA, CR & LPZ, ALL REL MVP: SIEMENS 60 GWD/MTU: 0 - 6 s  
 2 2 2 1. 1.  
 3 -2561 2.60+6 1.845+5 5.83+4  
 4 0. 0. 1. 1. 2.78+5 0.  
 5 6 2.592E6  
 6 0.2402 0.  
 7 9.058E-4 0.  
 8 2\*1.  
 9 2\*2460  
 10 3.2E-5 0.  
 11 7.00E-4 0.  
 12 2\*0.  
 13 2\*0.  
 14 2\*0.  
 15 2\*0.  
 16 2\*0.  
 17 2\*0.  
 18 2\*0.  
 19 2\*0.  
 20 2\*0.  
 21 6\*1.  
 22 3\*1.  
 23 7.43E+3 1.04E+4 1.32E+4 1.48E+4 1.16E+4 1.57E+3 8.14E+3 3.33E+5  
 24 8.89E+4 8.25E+4 3.17E+5 8.39E+3 3.21E+4 4.57E+3 6.03E+4 8.93E+4

1

QDC CRDA, CR &amp; LPZ, ALL REL MVP: SIEMENS 60 GWD/MTU: 0 - 6 s

## INITIAL CONTAINMENT INVENTORY

ISOTOPE	ACTIVITY (CURIES)
I-131	7.430E+03
I-132	1.040E+04
I-133	1.320E+04
I-134	1.480E+04
I-135	1.160E+04
XE-131M	1.570E+03
XE-133M	8.140E+03
XE-133	3.330E+05
XE-135M	8.890E+04
XE-135	8.250E+04
XE-138	3.170E+05
KR-83M	8.390E+03
KR-85M	3.210E+04
KR-85	4.570E+03
KR-87	6.030E+04
KR-88	8.930E+04

1

QDC CRDA, CR &amp; LPZ, ALL REL MVP: SIEMENS 60 GWD/MTU: 0 - 6 s

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
 1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO

## SPRAYED VOL

AT .002 HOURS: X/Q(SITE)= .32E-04 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM
INTAKE=2460.0 CFM		
X/Q CONT ROOM= .70E-03 SEC/M3	SEC RELEASE RATE= .78E+02 VOL/DAY	PCT PRI LKG TO ATM =
00.00		

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM		SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE	(CURIOS)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA
ELEMENTAL											
I-131	4.00E+02	1.29E+03	4.31E+00	3.50E-03	6.70E-07	7.09E-02	1.28E-05	6.25E-06	7.63E-04	4.92E-09	6.73E-08
I-132	5.60E+02	1.80E+03	6.03E+00	4.90E-03	9.38E-07	3.58E-03	1.16E-04	1.99E-05	3.86E-05	3.85E-08	2.14E-07
I-133	7.11E+02	2.28E+03	7.66E+00	6.22E-03	1.19E-06	3.40E-02	2.92E-05	2.38E-05	3.66E-04	1.41E-08	2.57E-07
I-134	7.96E+02	2.56E+03	8.58E+00	6.97E-03	1.33E-06	2.38E-03	1.33E-04	2.87E-05	2.57E-05	5.89E-08	3.10E-07

I-135	6.24E+02	2.01E+03	6.73E+00	5.47E-03	1.05E-06	9.27E-03	9.58E-05	1.53E-05	9.98E-05	2.51E-08	1.64E-07
<b>PARTICULATE</b>											
I-131	2.20E+01	7.07E+01	2.37E-01	1.92E-04	3.68E-08	3.89E-03	7.03E-07	3.44E-07	4.19E-05	2.70E-10	3.70E-09
I-132	3.07E+01	9.89E+01	3.32E-01	2.69E-04	5.15E-08	1.97E-04	6.37E-06	1.09E-06	2.12E-06	2.12E-09	1.18E-08
I-133	3.90E+01	1.26E+02	4.21E-01	3.42E-04	6.54E-08	1.87E-03	1.61E-06	1.31E-06	2.01E-05	7.74E-10	1.41E-08
I-134	4.37E+01	1.41E+02	4.72E-01	3.83E-04	7.33E-08	1.31E-04	7.31E-06	1.58E-06	1.41E-06	3.23E-09	1.70E-08
I-135	3.43E+01	1.10E+02	3.70E-01	3.00E-04	5.75E-08	5.09E-04	5.26E-06	8.38E-07	5.49E-06	1.38E-09	9.03E-09
<b>ORGANIC</b>											
I-131	1.76E+01	5.65E+01	1.90E-01	1.54E-04	2.95E-08	3.11E-03	5.63E-07	2.75E-07	3.36E-05	2.16E-10	2.96E-09
I-132	2.46E+01	7.91E+01	2.65E-01	2.15E-04	4.12E-08	1.58E-04	5.09E-06	8.75E-07	1.70E-06	1.69E-09	9.42E-09
I-133	3.12E+01	1.00E+02	3.37E-01	2.74E-04	5.24E-08	1.50E-03	1.28E-06	1.05E-06	1.61E-05	6.19E-10	1.13E-08
I-134	3.50E+01	1.12E+02	3.77E-01	3.06E-04	5.86E-08	1.05E-04	5.85E-06	1.26E-06	1.13E-06	2.59E-09	1.36E-08
I-135	2.74E+01	8.82E+01	2.96E-01	2.40E-04	4.60E-08	4.07E-04	4.21E-06	6.71E-07	4.39E-06	1.10E-09	7.22E-09
<b>NOBLE GASES</b>											
XE-131M	3.72E+02	1.19E+03	4.01E+00	3.25E-03	6.23E-07	0.00E+00	7.05E-07	3.98E-06	0.00E+00	1.19E-09	4.29E-08
XE-133M	1.93E+03	6.19E+03	2.08E+01	1.69E-02	3.23E-06	0.00E+00	5.48E-06	2.37E-05	0.00E+00	2.72E-09	2.55E-07
XE-133	7.88E+04	2.53E+05	8.49E+02	6.90E-01	1.32E-04	0.00E+00	2.04E-04	9.13E-04	0.00E+00	2.49E-07	9.83E-06
XE-135M	2.09E+04	6.73E+04	2.26E+02	1.83E-01	3.51E-05	0.00E+00	7.63E-04	1.61E-04	0.00E+00	3.02E-07	1.74E-06
XE-135	1.95E+04	6.28E+04	2.10E+02	1.71E-01	3.27E-05	0.00E+00	4.14E-04	4.99E-04	0.00E+00	1.59E-07	5.37E-06
XE-138	7.47E+04	2.40E+05	8.07E+02	6.54E-01	1.25E-04	0.00E+00	1.85E-02	4.75E-03	0.00E+00	1.89E-06	5.11E-05
KR-83M	1.98E+03	6.38E+03	2.14E+01	1.74E-02	3.33E-06	0.00E+00	8.56E-07	5.35E-06	0.00E+00	5.04E-09	5.77E-08
KR-85M	7.59E+03	2.44E+04	8.19E+01	6.65E-02	1.27E-05	0.00E+00	1.02E-04	1.40E-04	0.00E+00	4.23E-08	1.51E-06
KR-85	1.08E+03	3.48E+03	1.17E+01	9.47E-03	1.81E-06	0.00E+00	1.95E-07	1.91E-05	0.00E+00	7.71E-11	2.06E-07
KR-87	1.43E+04	4.58E+04	1.54E+02	1.25E-01	2.39E-05	0.00E+00	1.69E-03	1.19E-03	0.00E+00	3.25E-07	1.28E-05
KR-88	2.11E+04	6.79E+04	2.28E+02	1.85E-01	3.54E-05	0.00E+00	3.18E-03	5.72E-04	0.00E+00	1.05E-06	6.16E-06
						-----	-----	-----	-----	-----	-----
						1.32E-01	2.53E-02	8.38E-03	1.42E-03	4.18E-06	9.02E-05

1 QDC CRDA, CR & LPZ, ALL REL MVP: SIEMENS 60 GWD/MTU: 0 - 6 s

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT E/F RADIUS

1. FT3 SPRAYED VOL. 278000. FT3 UNSPRAYED VOL. 1. CPM MIXING, 00.00 PCT REL TO

**SPRAYED VOL**

AT 720.000 HOURS: X/Q(SITE)= .00E+00 SEC/M3 PRIMARY LEAK RATE= .000 PERCENT/DAY CONTROL ROOM  
INTAKE=2460.0 CFM

X/Q CONT ROOM= .00E+00 SEC/M3 SEC RELEASE RATE= .00E+00 VOL/DAY PCT PRI LKG TO ATM =  
0.00

CLEANUP RATES (HR-1)				FILTER NON-removal FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL .000	.000	.000	.000	1.000	1.000
PARTICULATE .000	.000	.000	.000	1.000	1.000
ORGANIC .000	.000	.000	.000	1.000	1.000

ACTIVITY (CURIES)				CONTROL ROOM		SITE BOUNDARY DOSES (REM)				CONTROL ROOM DOSES (REM)		
ISOTOPE	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA	
<b>ELEMENTAL</b>												
I-131	3.02E+01	9.70E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.54E+00	9.94E-06	1.36E-04	
I-132	3.37E-92	1.08E-91	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.69E-02	5.68E-05	3.16E-04	
I-133	3.38E-08	1.09E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.14E-01	2.75E-05	5.01E-04	
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.60E-02	5.98E-05	3.14E-04	
I-135	3.08E-30	9.89E-30	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.79E-01	4.51E-05	2.95E-04	
<b>PARTICULATE</b>												
I-131	1.66E+00	5.33E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.48E-02	5.46E-07	7.48E-06	
I-132	1.85E-93	5.95E-93	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.13E-03	3.12E-06	1.74E-05	
I-133	1.86E-09	5.97E-09	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.93E-02	1.51E-06	2.75E-05	
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.43E-03	3.28E-06	1.73E-05	
I-135	1.69E-31	5.44E-31	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.86E-03	2.48E-06	1.62E-05	
<b>ORGANIC</b>												
I-131	1.33E+00	4.27E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.78E-02	4.37E-07	5.98E-06	
I-132	1.48E-93	4.76E-93	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.50E-03	2.50E-06	1.39E-05	
I-133	1.49E-09	4.78E-09	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.14E-02	1.21E-06	2.20E-05	
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.14E-03	2.63E-06	1.38E-05	
I-135	1.35E-31	4.35E-31	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.89E-03	1.98E-06	1.30E-05	
<b>NOBLE GASES</b>												
XE-131M	6.39E+01	2.06E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.40E-06	8.67E-05	
XE-133M	1.94E-01	6.25E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.43E-05	5.10E-04	
XE-133	1.53E+03	4.93E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.01E-04	1.98E-02	
XE-135M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.41E-04	8.14E-04	
XE-135	3.46E-20	1.11E-19	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.95E-04	9.96E-03	
XE-138	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.65E-04	2.61E-02	
KR-83M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.99E-06	8.00E-05	
KR-85M	3.76E-46	1.21E-45	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.17E-05	
KR-85	1.08E+03	3.46E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.56E-07	
KR-87	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.91E-04	
KR-88	7.54E-74	2.42E-73	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.62E-03	
						-----	-----	-----	0.00E+00	0.00E+00	0.00E+00	
						0.00E+00	0.00E+00	0.00E+00	2.77E+00	4.22E-03	8.71E-02	

TOTAL DOSES 0-30 DAYS	1.32E-01	2.53E-02	8.38E-03	2.77E+00	4.23E-03	8.71E-02
-----------------------	----------	----------	----------	----------	----------	----------

1

QDC CRDA, CR &amp; LPZ, ALL REL MVP: SIEMENS 60 GWD/MTU: 0 - 6 s

ISOTOPE	0. HRS	720. HRS	ACTIVITY RELEASED (CURIES)
ELEMENTAL			
I-131	4.31E+00	0.00E+00	4.31E+00
I-132	6.03E+00	0.00E+00	6.03E+00
I-133	7.66E+00	0.00E+00	7.66E+00
I-134	8.58E+00	0.00E+00	8.58E+00
I-135	6.73E+00	0.00E+00	6.73E+00
PARTICULATE			
I-131	2.37E-01	0.00E+00	2.37E-01
I-132	3.32E-01	0.00E+00	3.32E-01
I-133	4.21E-01	0.00E+00	4.21E-01
I-134	4.72E-01	0.00E+00	4.72E-01
I-135	3.70E-01	0.00E+00	3.70E-01
ORGANIC			
I-131	1.90E-01	0.00E+00	1.90E-01
I-132	2.65E-01	0.00E+00	2.65E-01
I-133	3.37E-01	0.00E+00	3.37E-01
I-134	3.77E-01	0.00E+00	3.77E-01
I-135	2.96E-01	0.00E+00	2.96E-01
NOBLE GASES			
XE-131M	4.01E+00	0.00E+00	4.01E+00
XE-133M	2.08E+01	0.00E+00	2.08E+01
XE-133	8.49E+02	0.00E+00	8.49E+02
XE-135M	2.26E+02	0.00E+00	2.26E+02
XE-135	2.10E+02	0.00E+00	2.10E+02
XE-138	8.07E+02	0.00E+00	8.07E+02
KR-83M	2.14E+01	0.00E+00	2.14E+01
KR-85M	8.19E+01	0.00E+00	8.19E+01
KR-85	1.17E+01	0.00E+00	1.17E+01
KR-87	1.54E+02	0.00E+00	1.54E+02
KR-88	2.28E+02	0.00E+00	2.28E+02

END EXECUTION DATE: 11/18/1999  
 END EXECUTION TIME: 17:45:17.07

**ISOTOPE ACTIVITY (CURIES)**

I-131	7.430E+03
I-132	1.040E+04
I-133	1.320E+04
I-134	1.480E+04
I-135	1.160E+04
XE-131M	1.570E+03
XE-133M	8.140E+03
XE-133	3.330E+05
XE-135M	8.890E+04
XE-135	8.250E+04
XE-138	3.170E+05
KR-83M	8.390E+03
KR-85M	3.210E+04
KR-85	4.570E+03
KR-87	6.030E+04
KR-88	8.930E+04

1

ODC CRDA, CR & LPZ, ALL REL AOG: SIEMENS 60 GWD/MTU: 6 s - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO  
SPRAYED VOL.

AT .002 HOURS: X/Q(SITE)= .00E+00 SEC/M3 PRIMARY LEAK RATE=\*\*\*\*\* PERCENT/DAY CONTROL ROOM  
 INTAKE=2460.0 CFM

X/Q CONT ROOM= .00E+00 SEC/M3 SEC RELEASE RATE= .78E+02 VOL/DAY PCT PRI LKG TO ATM =  
 00.00

	CLEANUP RATES (HR-1)			FILTER NON-REMPTION FACTORS	
	SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE
ELEMENTAL	.000	.000	.000	.000	.000
PARTICULATE	.000	.000	.000	.000	.000
ORGANIC	.000	.000	.000	.000	.000

I-135	6.24E+02	2.01E+03	0.00E+00								
PARTICULATE											
I-131	2.20E+01	7.07E+01	0.00E+00								
I-132	3.07E+01	9.89E+01	0.00E+00								
I-133	3.90E+01	1.26E+02	0.00E+00								
I-134	4.37E+01	1.41E+02	0.00E+00								
I-135	3.43E+01	1.10E+02	0.00E+00								
ORGANIC											
I-131	1.76E+01	5.65E+01	0.00E+00								
I-132	2.46E+01	7.91E+01	0.00E+00								
I-133	3.12E+01	1.00E+02	0.00E+00								
I-134	3.50E+01	1.12E+02	0.00E+00								
I-135	2.74E+01	8.62E+01	0.00E+00								
NOBLE GASES											
XE-131M	3.72E+02	1.19E+03	4.01E+00	0.00E+00							
XE-133M	1.93E+03	6.19E+03	2.08E+01	0.00E+00							
XE-133	7.88E+04	2.53E+05	8.49E+02	0.00E+00							
XE-135M	2.09E+04	6.73E+04	2.26E+02	0.00E+00							
XE-135	1.95E+04	6.28E+04	2.10E+02	0.00E+00							
XE-138	7.47E+04	2.40E+05	8.07E+02	0.00E+00							
KR-83M	1.98E+03	6.38E+03	2.14E+01	0.00E+00							
KR-85M	7.59E+03	2.44E+04	8.19E+01	0.00E+00							
KR-85	1.08E+03	3.48E+03	1.17E+01	0.00E+00							
KR-87	1.43E+04	4.58E+04	1.54E+02	0.00E+00							
KR-88	2.11E+04	6.79E+04	2.28E+02	0.00E+00							

1 QDC CRDA, CR &amp; LPZ, ALL REL AOG: SIEMENS 60 GWD/MTU: 6 s - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO SPRAYED VOL

AT .500 HOURS: X/Q(SITE)= .32E-04 SEC/M3 PRIMARY LEAK RATE=\*\*\*\*\* PERCENT/DAY CONTROL ROOM  
INTAKE=2460.0 CFMX/Q CONT ROOM= .70E-03 SEC/M3 SEC RELEASE RATE= .10E+01 VOL/DAY PCT PRI LKG TO ATM =  
00.00

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	.000	1.000
PARTICULATE	.000	.000	.000	.000	1.000
ORGANIC	.000	.000	.000	.000	1.000

ISOTOPE	ACTIVITY (CURIES)	CONTROL ROOM (CURIES)	SITE BOUNDARY DOSES (REM)	CONTROL ROOM DOSES (REM)							
	PRIMARY	SECONDARY	RELEASE	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA	
ELEMENTAL											
I-131	1.75E-07	1.65E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	2.12E-07	1.99E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	3.07E-07	2.89E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	2.35E-07	2.21E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	2.61E-07	2.45E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
PARTICULATE											
I-131	9.64E-09	9.06E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	1.16E-08	1.09E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	1.69E-08	1.59E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	1.29E-08	1.21E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	1.43E-08	1.35E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ORGANIC											
I-131	7.71E-09	7.25E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	9.30E-09	8.74E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	1.35E-08	1.27E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	1.03E-08	9.70E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	1.15E-08	1.08E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
NOBLE GASES											
XE-131M	1.63E-07	1.53E+03	3.18E+01	2.13E-02	4.08E-06	0.00E+00	5.60E-06	3.16E-05	0.00E+00	3.34E-06	1.20E-04
XE-133M	8.41E-07	7.90E+03	1.64E+02	1.10E-01	2.11E-05	0.00E+00	4.34E-05	1.88E-04	0.00E+00	7.61E-06	7.14E-04
XE-133	3.45E-05	3.25E+05	6.74E+03	4.52E+00	8.64E-04	0.00E+00	1.62E-03	7.24E-03	0.00E+00	6.98E-04	2.76E-02
XE-135M	2.44E-06	2.29E+04	9.87E+02	3.19E-01	6.11E-05	0.00E+00	3.33E-03	7.05E-04	0.00E+00	3.72E-04	2.14E-03
XE-135	8.26E-06	7.76E+04	1.64E+03	1.08E+00	2.07E-04	0.00E+00	3.23E-03	3.89E-03	0.00E+00	4.37E-04	1.47E-02
XE-138	1.00E-05	9.44E+04	3.73E+03	1.31E+00	2.52E-04	0.00E+00	8.57E-02	2.20E-02	0.00E+00	2.53E-03	6.86E-02
KR-83M	7.25E-07	6.81E+03	1.55E+02	9.48E-02	1.81E-05	0.00E+00	6.20E-06	3.88E-05	0.00E+00	1.26E-05	1.44E-04
KR-85M	3.08E-06	2.90E+04	6.25E+02	4.03E-01	7.72E-05	0.00E+00	7.80E-04	1.07E-03	0.00E+00	1.13E-04	4.04E-03
KR-85	4.75E-07	4.47E+03	9.26E+01	6.22E-02	1.19E-05	0.00E+00	1.56E-06	1.52E-04	0.00E+00	2.17E-07	5.80E-02
KR-87	4.77E-06	4.48E+04	1.07E+03	6.24E-01	1.19E-04	0.00E+00	1.17E-02	8.25E-03	0.00E+00	7.64E-04	3.01E-02
KR-88	8.20E-06	7.71E+04	1.70E+03	1.07E+00	2.05E-04	0.00E+00	2.37E-02	4.27E-03	0.00E+00	2.72E-03	1.60E-02

0.00E+00 1.30E-01 4.78E-02 0.00E+00 7.66E-03 1.65E-01

1

QDC CRDA, CR &amp; LPZ, ALL REL AOG: SIEMENS 60 GWD/MTU: 6 s - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO  
SPRAYED VOL

AT 2.000 HOURS:	X/Q(SITE)= .90E-05 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM
INTAKE=2460.0 CFM			
00.00	X/Q CONT ROOM= .70E-03 SEC/M3	SEC RELEASE RATE= .10E+01 VOL/DAY	PCT PRI LKG TO ATM =

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	.000	1.000
PARTICULATE	.000	.000	.000	.000	1.000
ORGANIC	.000	.000	.000	.000	1.000

ISOTOPE	ACTIVITY (CURIES)	CONTROL ROOM (CURIES)	SITE BOUNDARY DOSES (REM)	CONTROL ROOM DOSES (REM)							
	PRIMARY	SECONDARY	RELEASE	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA	
<b>ELEMENTAL</b>											
I-131	1.19E-35	1.54E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
I-132	9.19E-36	1.19E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
I-133	2.00E-35	2.58E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
I-134	4.83E-36	6.25E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
I-135	1.52E-35	1.97E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
<b>PARTICULATE</b>											
I-131	6.54E-37	8.46E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
I-132	5.05E-37	6.53E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
I-133	1.10E-36	1.42E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
I-134	2.66E-37	3.43E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
I-135	8.37E-37	1.08E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
<b>ORGANIC</b>											
I-131	5.24E-37	6.77E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
I-132	4.04E-37	5.23E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
I-133	8.77E-37	1.13E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
I-134	2.12E-37	2.75E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
I-135	6.70E-37	8.66E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
<b>NOBLE GASES</b>											
XE-131M	1.11E-35	1.43E+03	9.26E+01	4.99E-02	9.55E-06	0.00E+00	4.59E-06	2.59E-05	0.00E+00	3.45E-05	1.25E-03
XE-133M	5.63E-35	7.28E+03	4.74E+02	2.53E-01	4.85E-05	0.00E+00	3.52E-05	1.52E-04	0.00E+00	7.79E-05	7.31E-03
XE-133	2.34E-33	3.02E+05	1.96E+04	1.05E+01	2.01E-03	0.00E+00	1.32E-03	5.92E-03	0.00E+00	7.20E-03	2.85E-01
XE-135M	3.06E-36	3.96E+02	3.47E+02	1.38E-02	2.64E-06	0.00E+00	3.29E-04	6.97E-05	0.00E+00	4.52E-04	2.61E-03
XE-135	5.03E-34	6.51E+04	4.45E+03	2.26E+00	4.33E-04	0.00E+00	2.46E-03	2.96E-03	0.00E+00	4.20E-03	1.42E-01
XE-138	1.94E-35	2.51E+03	1.58E+03	8.74E-02	1.67E-05	0.00E+00	1.02E-02	2.62E-03	0.00E+00	3.71E-03	1.00E-01
KR-83M	2.84E-35	3.67E+03	3.17E+02	1.28E-01	2.44E-05	0.00E+00	3.57E-06	2.23E-05	0.00E+00	9.05E-05	1.04E-03
KR-85M	1.66E-34	2.15E+04	1.57E+03	7.48E-01	1.43E-04	0.00E+00	5.49E-04	7.55E-04	0.00E+00	1.00E-03	3.58E-02
KR-85	3.24E-35	4.20E+03	2.70E+02	1.46E-01	2.79E-05	0.00E+00	1.25E-06	1.25E-04	0.00E+00	2.25E-06	6.01E-03
KR-87	1.43E-34	1.85E+04	1.86E+03	6.45E-01	1.23E-04	0.00E+00	5.75E-03	4.04E-03	0.00E+00	4.67E-03	1.84E-01
KR-88	3.86E-34	5.00E+04	3.91E+03	1.74E+00	3.33E-04	0.00E+00	1.53E-02	2.76E-03	0.00E+00	2.20E-02	1.30E-01

1 QDC CRDA, CR &amp; LPZ, ALL REL AOG: SIEMENS 60 GWD/MTU: 6 s - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO  
SPRAYED VOL

AT 8.000 HOURS:	X/Q(SITE)= .90E-05 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM
INTAKE=2460.0 CFM			
00.00	X/Q CONT ROOM= .65E-05 SEC/M3	SEC RELEASE RATE= .10E+01 VOL/DAY	PCT PRI LKG TO ATM =

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	.000	1.000
PARTICULATE	.000	.000	.000	.000	1.000
ORGANIC	.000	.000	.000	.000	1.000

ISOTOPE	ACTIVITY (CURIES)	CONTROL ROOM (CURIES)	SITE BOUNDARY DOSES (REM)	CONTROL ROOM DOSES (REM)						
	PRIMARY	SECONDARY	RELEASE	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA

ELEMENTAL												
I-131	0.00E+00	1.17E+03	0.00E+00									
I-132	0.00E+00	1.52E+02	0.00E+00									
I-133	0.00E+00	1.65E+03	0.00E+00									
I-134	0.00E+00	4.03E+00	0.00E+00									
I-135	0.00E+00	8.26E+02	0.00E+00									
PARTICULATE												
I-131	0.00E+00	6.45E+01	0.00E+00									
I-132	0.00E+00	8.34E+00	0.00E+00									
I-133	0.00E+00	9.06E+01	0.00E+00									
I-134	0.00E+00	2.21E-01	0.00E+00									
I-135	0.00E+00	4.54E+01	0.00E+00									
ORGANIC												
I-131	0.00E+00	5.16E+01	0.00E+00									
I-132	0.00E+00	6.67E+00	0.00E+00									
I-133	0.00E+00	7.25E+01	0.00E+00									
I-134	0.00E+00	1.77E-01	0.00E+00									
I-135	0.00E+00	3.63E+01	0.00E+00									
NOBLE GASES												
XE-131M	0.00E+00	1.10E+03	3.15E+02	8.53E-04	1.63E-07	0.00E+00	1.56E-05	8.80E-05	0.00E+00	3.80E-05	1.37E-03	
XE-133M	0.00E+00	5.25E+03	1.55E+03	4.07E-03	7.79E-07	0.00E+00	1.15E-04	4.98E-04	0.00E+00	8.40E-05	7.89E-03	
XE-133	0.00E+00	2.28E+05	6.58E+04	1.77E-01	3.38E-05	0.00E+00	4.44E-03	1.99E-02	0.00E+00	7.87E-03	3.11E-01	
XE-135M	0.00E+00	3.53E-05	6.10E+00	2.73E-11	5.23E-15	0.00E+00	5.79E-06	1.22E-06	0.00E+00	1.06E-05	6.14E-05	
XE-135	0.00E+00	3.21E+04	1.17E+04	2.49E-02	4.76E-06	0.00E+00	6.46E-03	7.77E-03	0.00E+00	4.02E-03	1.35E-01	
XE-138	0.00E+00	1.26E-03	4.33E+01	9.76E-10	1.87E-13	0.00E+00	2.80E-04	7.17E-05	0.00E+00	1.29E-04	3.50E-03	
KR-83M	0.00E+00	3.09E+02	3.39E+02	2.39E-04	4.58E-08	0.00E+00	3.82E-06	2.39E-05	0.00E+00	5.23E-05	5.98E-04	
KR-85M	0.00E+00	6.50E+03	3.13E+03	5.04E-03	9.64E-07	0.00E+00	1.10E-03	1.51E-03	0.00E+00	8.26E-04	2.95E-02	
KR-85	0.00E+00	3.27E+03	9.28E+02	2.53E+03	4.84E-07	0.00E+00	4.38E-06	4.28E-04	0.00E+00	2.48E-06	6.64E-03	
KR-87	0.00E+00	5.41E+02	1.27E+03	4.19E-04	8.03E-08	0.00E+00	3.94E-03	2.77E-03	0.00E+00	2.05E-03	8.07E-02	
KR-88	0.00E+00	8.80E+03	5.92E+03	6.82E-03	1.31E-06	0.00E+00	2.32E-02	4.18E-03	0.00E+00	1.56E-02	9.16E-02	
						0.00E+00	3.96E-02	3.72E-02	0.00E+00	3.07E-02	6.69E-01	

1 QDC CRDA, CR &amp; LPZ, ALL REL AOG: SIEMENS 60 GWD/MTU: 6 s - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

SPRAYED VOL  
1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TOAT 24.000 HOURS: X/Q(SITE)= .30E-05 SEC/M3 PRIMARY LEAK RATE=\*\*\*\*\* PERCENT/DAY CONTROL ROOM  
INTAKE=2460.0 CFMX/Q CONT ROOM= .38E-05 SEC/M3 SEC RELEASE RATE= .10E+01 VOL/DAY PCT PRI LKG TO ATM =  
00.00

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS			
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER		
ELEMENTAL	.000	.000	.000	.000	.000	1.000	
PARTICULATE	.000	.000	.000	.000	.000	1.000	
ORGANIC	.000	.000	.000	.000	.000	1.000	
ACTIVITY (CURIES)				CONTROL ROOM DOSES (REM)			
ISOTOPE	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY
ELEMENTAL	0.00E+00	5.69E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-131	0.00E+00	6.28E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	0.00E+00	4.99E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	0.00E+00	5.78E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	0.00E+00	8.12E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	0.00E+00	3.13E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ACTIVITY (CURIES)				CONTROL ROOM DOSES (REM)			
ISOTOPE	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY
PARTICULATE	0.00E+00	3.13E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-131	0.00E+00	3.45E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	0.00E+00	2.74E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	0.00E+00	3.18E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	0.00E+00	4.54E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ACTIVITY (CURIES)				CONTROL ROOM DOSES (REM)			
ISOTOPE	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY
ORGANIC	0.00E+00	2.50E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-131	0.00E+00	2.19E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	0.00E+00	2.54E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	0.00E+00	3.57E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Noble Gases	0.00E+00	5.44E+02	5.26E+02	1.32E-04	2.53E-08	0.00E+00	8.68E-06
XE-131M	0.00E+00	2.20E+03	2.34E+03	5.34E-04	1.02E-07	0.00E+00	5.79E-05
XE-133M	0.00E+00	1.07E+05	1.07E+05	2.61E-02	4.99E-06	0.00E+00	2.40E-03
XE-133	0.00E+00	1.07E+05	1.07E+05	2.61E-02	4.99E-06	0.00E+00	2.40E-03
XE-135M	0.00E+00	5.58E-24	5.43E-07	1.36E-30	2.60E-34	0.00E+00	1.72E-13
XE-135	0.00E+00	4.89E+03	9.64E+03	1.19E-03	2.28E-07	0.00E+00	1.78E-03
XE-138	0.00E+00	2.00E-20	2.17E-05	4.86E-27	9.29E-31	0.00E+00	4.67E-11
KR-83M	0.00E+00	4.21E-01	3.11E+01	1.02E-07	1.96E-11	0.00E+00	1.17E-07
KR-85M	0.00E+00	2.68E+02	1.30E+03	6.51E-05	1.25E-08	0.00E+00	1.52E-04
KR-85	0.00E+00	1.68E+03	1.59E+03	4.08E-04	7.80E-08	0.00E+00	2.50E-06

KR-87	0.00E+00	4.38E-02	3.83E+01	1.06E-08	2.04E-12	0.00E+00	3.95E-05	2.77E-05	0.00E+00	1.84E-06	7.27E-05
KR-88	0.00E+00	8.59E+01	1.25E+03	2.09E-05	4.00E-09	0.00E+00	1.64E-03	2.95E-04	0.00E+00	1.08E-04	6.37E-04
						0.00E+00	6.08E-03	1.40E-02	0.00E+00	6.96E-04	2.38E-02

1 QDC CRDA, CR & LPZ, ALL REL AOG: SIEMENS 60 GWD/MTU: 6 s - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO SPRAYED VOL

AT 720.000 HOURS:	X/Q(SITE)= .00E+00 SEC/M3	PRIMARY LEAK RATE= .000 PERCENT/DAY	CONTROL ROOM
INTAKE=2460.0 CFM			
00.00	X/Q CONT ROOM= .00E+00 SEC/M3	SEC RELEASE RATE= .00E+00 VOL/DAY	PCT PRI LKG TO ATM =

	CLEANUP RATES (HR-1)			FILTER NON-REMOVAL FACTORS	
	SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE
ELEMENTAL	.000	.000	.000	.000	1.000
PARTICULATE	.000	.000	.000	.000	1.000
ORGANIC	.000	.000	.000	.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM			SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA	
ELEMENTAL												
I-131	0.00E+00	4.68E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
I-132	0.00E+00	5.23E-92	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
I-133	0.00E+00	5.25E-08	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
I-135	0.00E+00	4.78E-30	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
PARTICULATE												
I-131	0.00E+00	2.57E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
I-132	0.00E+00	2.87E-93	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
I-133	0.00E+00	2.88E-09	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
I-135	0.00E+00	2.62E-31	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
ORGANIC												
I-131	0.00E+00	2.06E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
I-132	0.00E+00	2.30E-93	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
I-133	0.00E+00	2.31E-09	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
I-135	0.00E+00	2.10E-31	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
NOBLE GASES												
XE-131M	0.00E+00	9.92E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.76E-08	3.52E-06	
XE-133M	0.00E+00	3.02E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.72E-07	1.61E-05	
XE-133	0.00E+00	2.38E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.89E-05	7.48E-04	
XE-135M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.04E-33	6.02E-33	
XE-135	0.00E+00	5.36E-20	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.05E-06	6.93E-05	
XE-138	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.16E-30	1.94E-28	
KR-83M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.11E-11	4.70E-10	
KR-85M	0.00E+00	5.84E-46	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.02E-08	2.51E-06	
KR-85	0.00E+00	1.67E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.74E-09	1.80E-05	
KR-87	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.34E-11	1.32E-09	
KR-88	0.00E+00	1.17E-73	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.83E-07	1.08E-06	
						0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.15E-05	8.59E-04	
TOTAL DOSES 0-30 DAYS						0.00E+00	2.12E-01	1.18E-01	0.00E+00	8.25E-02	1.75E+00	

1

QDC CRDA, CR & LPZ, ALL REL AOG: SIEMENS 60 GWD/MTU: 6 s - 30 d

ISOTOPE	ACTIVITY RELEASED (CURIES)			
	2. HRS	8. HRS	24. HRS	720. HRS
ELEMENTAL				
I-131	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	0.00E+00	0.00E+00	0.00E+00	0.00E+00
PARTICULATE				
I-131	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ORGANIC				
I-131	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-132	0.00E+00	0.00E+00	0.00E+00	0.00E+00

I-133	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
NOBLE GASES					
XE-131M	1.28E+02	3.15E+02	5.26E+02	0.00E+00	9.70E+02
XE-133M	6.59E+02	1.55E+03	2.34E+03	0.00E+00	4.55E+03
XE-133	2.72E+04	6.58E+04	1.07E+05	0.00E+00	2.00E+05
XE-135M	1.56E+03	6.10E+00	5.43E-07	0.00E+00	1.57E+03
XE-135	6.30E+03	1.17E+04	9.64E+03	0.00E+00	2.76E+04
XE-138	6.12E+03	4.33E+01	2.17E-05	0.00E+00	6.17E+03
KR-83M	4.94E+02	3.39E+02	3.11E+01	0.00E+00	8.64E+02
KR-85M	2.27E+03	3.13E+03	1.30E+03	0.00E+00	6.71E+03
KR-85	3.75E+02	9.28E+02	1.59E+03	0.00E+00	2.89E+03
KR-87	3.08E+03	1.27E+03	3.83E+01	0.00E+00	4.39E+03
KR-88	5.84E+03	5.92E+03	1.25E+03	0.00E+00	1.30E+04

END EXECUTION DATE: 11/18/1999  
END EXECUTION TIME: 17:45:26.13

AXIDENT VER 2 MOD 4  
 PRODUCTION DATE 02/18/92  
 BEGIN EXECUTION DATE: 11/18/1999  
 BEGIN EXECUTION TIME: 17:45:33.82

1 QDC CRDA, CR & LPZ, ALL REL GLAND: SIEMENS 60 GWD/MTU: 0 - 30 d  
 2 6 2 1. 1.  
 3 -2561 2.60+6 1.845+5 5.83+4  
 4 0. 0. 0. 1. 1. 2.78+5 0.  
 5 6 1800 7200 2.88+4 8.64+4 2.592E6  
 6 0.2402 4\*1.201E-2 0.  
 7 5\*1. 0.  
 8 6\*1.  
 9 6\*2460  
 10 2\*3.2E-5 2\*9.0E-6 3.0E-6 0.  
 11 3\*7.00E-4 6.45E-6 3.81E-6 0.  
 12 6\*0.  
 13 6\*0.  
 14 6\*0.  
 15 6\*0.  
 16 6\*0.  
 17 6\*0.  
 18 6\*0.  
 19 6\*0.  
 20 6\*0.  
 21 6\*1.  
 22 3\*1.  
 23 7.43E+3 1.04E+4 1.32E+4 1.48E+4 1.16E+4 1.57E+3 8.14E+3 3.33E+5  
 24 8.89E+4 8.25E+4 3.17E+5 8.39E+3 3.21E+4 4.57E+3 6.03E+4 8.93E+4

1

QDC CRDA, CR &amp; LPZ, ALL REL GLAND: SIEMENS 60 GWD/MTU: 0 - 30 d

## INITIAL CONTAINMENT INVENTORY

## ISOTOPE ACTIVITY (CURIES)

I-131	7.430E+03
I-132	1.040E+04
I-133	1.320E+04
I-134	1.480E+04
I-135	1.160E+04
XE-131M	1.570E+03
XE-133M	8.140E+03
XE-133	3.330E+05
XE-135M	8.890E+04
XE-135	8.250E+04
XE-138	3.170E+05
KR-83M	8.390E+03
KR-85M	3.210E+04
KR-85	4.570E+03
KR-87	6.030E+04
KR-88	8.930E+04

1

QDC CRDA, CR &amp; LPZ, ALL REL GLAND: SIEMENS 60 GWD/MTU: 0 - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

SPRAYED VOL 1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO

AT .002 HOURS: X/Q(SITE)= .32E-04 SEC/M3 PRIMARY LEAK RATE=\*\*\*\*\* PERCENT/DAY CONTROL ROOM  
 INTAKE=2460.0 CFM

X/Q CONT ROOM= .70E-03 SEC/M3 SEC RELEASE RATE= .86E+05 VOL/DAY PCT PRI LKG TO ATM =  
 00.00

ISOTOPE	CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS							
	SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER						
						ELEMENTAL	PARTICULATE	ORGANIC				
I-131	.000	.000	.000	.000	1.000	1.000						
I-132	.000	.000	.000	.000	1.000	1.000						
I-133	.000	.000	.000	.000	1.000	1.000						
I-134	.000	.000	.000	.000	1.000	1.000						
	ACTIVITY (CURIES)	CONTROL ROOM	SITE BOUNDARY DOSES (REM)	CONTROL ROOM DOSES (REM)								
	ISOTOPE	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA
ELEMENTAL												
I-131	4.00E+02	1.25E+02	1.17E+03	9.46E-01	1.81E-04	1.91E+01	3.46E-03	1.69E-03	2.88E-01	1.86E-06	2.54E-05	
I-132	5.60E+02	1.75E+02	1.63E+03	1.32E+00	2.53E-04	9.69E-01	3.13E-02	5.38E-03	1.46E-02	1.45E-05	8.08E-05	
I-133	7.11E+02	2.22E+02	2.07E+03	1.68E+00	3.22E-04	9.19E+00	7.90E-03	6.44E-03	1.38E-01	5.31E-06	9.69E-05	
I-134	7.96E+02	2.49E+02	2.32E+03	1.88E+00	3.60E-04	6.44E-01	3.60E-02	7.77E-03	9.68E-03	2.22E-05	1.17E-04	

I-135	6.24E+02	1.95E+02	1.82E+03	1.48E+00	2.83E-04	2.50E+00	2.59E-02	4.12E-03	3.76E-02	9.47E-06	6.20E-05
<b>PARTICULATE</b>											
I-131	2.20E+01	6.88E+00	6.40E+01	5.20E-02	9.95E-06	1.05E+00	1.90E-04	9.28E-05	1.58E-02	1.02E-07	1.40E-06
I-132	3.07E+01	9.62E+00	8.96E+01	7.27E-02	1.39E-05	5.32E-02	1.72E-03	2.95E-04	8.00E-04	7.99E-07	4.44E-06
I-133	3.90E+01	1.22E+01	1.14E+02	9.24E-02	1.77E-05	5.05E-01	4.34E-04	3.54E-04	7.59E-03	2.92E-07	5.32E-06
I-134	4.37E+01	1.37E+01	1.27E+02	1.03E-01	1.98E-05	3.54E-02	1.98E-03	4.27E-04	5.32E-04	1.22E-06	6.41E-06
I-135	3.43E+01	1.07E+01	9.99E+01	8.12E-02	1.55E-05	1.38E-01	1.42E-03	2.27E-04	2.07E-03	5.20E-07	3.41E-06
<b>ORGANIC</b>											
I-131	1.76E+01	5.50E+00	5.12E+01	4.16E-02	7.96E-06	8.42E-01	1.52E-04	7.43E-05	1.27E-02	8.16E-08	1.12E-06
I-132	2.46E+01	7.70E+00	7.17E+01	5.82E-02	1.11E-05	4.26E-02	1.38E-03	2.36E-04	6.40E-04	6.39E-07	3.55E-06
I-133	3.12E+01	9.77E+00	9.10E+01	7.39E-02	1.41E-05	4.04E-01	3.47E-04	2.83E-04	6.08E-03	2.34E-07	4.26E-06
I-134	3.50E+01	1.09E+01	1.02E+02	8.27E-02	1.58E-05	2.83E-02	1.58E-03	3.41E-04	4.25E-04	9.76E-07	5.13E-06
I-135	2.74E+01	8.59E+00	8.00E+01	6.49E-02	1.24E-05	1.10E-01	1.14E-03	1.81E-04	1.65E-03	4.16E-07	2.72E-06
<b>NOBLE GASES</b>											
XE-131M	3.72E+02	1.16E+02	1.08E+03	8.79E-01	1.68E-04	0.00E+00	1.90E-04	1.08E-03	0.00E+00	4.48E-07	1.62E-05
XE-133M	1.93E+03	6.03E+02	5.61E+03	4.56E+00	8.72E-04	0.00E+00	1.48E-03	6.40E-03	0.00E+00	1.02E-06	9.62E-05
XE-133	7.88E+04	2.47E+04	2.30E+05	1.86E+02	3.57E-02	0.00E+00	5.51E-02	2.47E-01	0.00E+00	9.38E-05	3.71E-03
XE-135M	2.09E+04	6.55E+03	6.11E+04	4.95E+01	9.48E-03	0.00E+00	2.06E-01	4.37E-02	0.00E+00	1.14E-04	6.56E-04
XE-135	1.95E+04	6.11E+03	5.69E+04	4.62E+01	8.84E-03	0.00E+00	1.12E-01	1.35E-01	0.00E+00	6.01E-05	2.03E-03
XE-138	7.47E+04	2.34E+04	2.18E+05	1.77E+02	3.38E-02	0.00E+00	5.01E+00	1.28E+00	0.00E+00	7.13E-04	1.93E-02
KR-83M	1.98E+03	6.21E+02	5.78E+03	4.69E+00	8.98E-04	0.00E+00	2.31E-04	1.45E-03	0.00E+00	1.90E-06	2.17E-05
KR-85M	7.59E+03	2.38E+03	2.21E+04	1.80E+01	3.44E-03	0.00E+00	2.76E-02	3.79E-02	0.00E+00	1.59E-05	5.70E-04
KR-85	1.08E+03	3.38E+02	3.15E+03	2.56E+00	4.90E-04	0.00E+00	5.29E-05	5.17E-03	0.00E+00	2.91E-08	7.77E-05
KR-87	1.43E+04	4.46E+03	4.15E+04	3.37E+01	6.46E-03	0.00E+00	4.57E-01	3.21E-01	0.00E+00	1.22E-04	4.83E-03
KR-88	2.11E+04	6.61E+03	6.15E+04	5.00E+01	9.57E-03	0.00E+00	8.58E-01	1.54E-01	0.00E+00	3.95E-04	2.32E-03
						3.57E-01	6.84E+00	2.26E+00	5.36E-01	1.58E-03	3.40E-02

QDC CRDA, CR & LPZ, ALL REL GLAND: SIEMENS 60 GWD/MTU: 0 - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL. 278000. FT3 UNSPRAYED VOL. 1. CFM MIXING, 00.00 PCT REL TO

SPRAYED VOL

AT .500 HOURS: X/Q(SITE)= .32E-04 SEC/M3 PRIMARY LEAK RATE=\*\*\*\*\* PERCENT/DAY CONTROL ROOM  
 INTAKE=2460.0 CFM

X/Q CONT ROOM= .70E-03 SEC/M3 SEC RELEASE RATE= .86E+05 VOL/DAY PCT PRI LKG TO ATM =  
 00.00

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS		
	SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	.000	1.000	1.000

ACTIVITY (CURIES)				CONTROL ROOM		SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
ISOTOPE	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA
<b>ELEMENTAL</b>											
I-131	1.75E-07	2.13E-09	5.25E+02	9.24E-01	1.77E-04	8.63E+00	1.56E-03	7.61E-04	1.98E+02	1.27E-03	1.74E-02
I-132	2.12E-07	2.57E-09	7.31E+02	1.11E+00	2.13E-04	4.34E-01	1.40E-03	2.41E-03	9.33E+00	9.31E-03	5.18E-02
I-133	3.07E-07	3.73E-09	9.32E+02	1.62E+00	3.10E-04	4.14E+00	3.56E-03	2.90E-03	9.43E+01	3.62E-03	6.61E-02
I-134	2.35E-07	2.85E-09	1.03E+03	1.24E+00	2.37E-04	2.86E-01	1.60E-02	3.45E-03	5.54E+00	1.27E-02	6.69E-02
I-135	2.61E-07	3.17E-09	8.18E+02	1.37E+00	2.63E-04	1.13E+00	1.16E-02	1.85E-03	2.53E+01	6.35E-03	4.16E-02
<b>PARTICULATE</b>											
I-131	9.64E-09	1.17E-10	2.89E+01	5.08E-02	9.72E-06	4.74E-01	8.56E-05	4.18E-05	1.09E+01	7.00E-05	9.58E-04
I-132	1.16E-08	1.41E-10	4.02E+01	6.12E-02	1.17E-05	2.39E-02	7.71E-04	1.32E-04	5.13E-01	5.12E-04	2.84E-03
I-133	1.69E-08	2.05E-10	5.12E+01	8.89E-02	1.70E-05	2.28E-01	1.95E-04	1.59E-04	5.18E+00	1.99E-04	3.63E-03
I-134	1.29E-08	1.57E-10	5.66E+01	6.79E-02	1.30E-05	1.57E-02	8.78E-04	1.90E-04	3.05E-01	6.99E-04	3.67E-03
I-135	1.43E-08	1.74E-10	4.50E+01	7.54E-02	1.44E-05	6.19E-02	6.40E-04	1.02E-04	1.39E+00	3.49E-04	2.28E-03
<b>ORGANIC</b>											
I-131	7.71E-09	9.37E-11	2.31E+01	4.06E-02	7.78E-06	3.79E-01	6.85E-05	3.35E-05	8.69E+00	5.60E-05	7.67E-04
I-132	9.30E-09	1.13E-10	3.21E+01	4.90E-02	9.38E-06	1.91E-02	6.17E-04	1.06E-04	4.10E-01	4.09E-04	2.28E-03
I-133	1.35E-08	1.64E-10	4.10E+01	7.11E-02	1.36E-05	1.82E-01	1.56E-04	1.28E-04	4.14E+00	1.59E-04	2.90E-03
I-134	1.03E-08	1.25E-10	4.53E+01	5.44E-02	1.04E-05	1.26E-02	7.02E-04	1.52E-04	2.44E-01	5.59E-04	2.94E-03
I-135	1.15E-08	1.39E-10	3.60E+01	6.03E-02	1.15E-05	4.95E-02	5.12E-04	8.15E-05	1.11E+00	2.79E-04	1.83E-03
<b>NOBLE GASES</b>											
XE-131M	1.63E-07	1.98E-09	4.88E+02	8.59E-01	1.64E-04	0.00E+00	8.58E-05	4.85E-04	0.00E+00	3.08E-04	1.11E-02
XE-133M	8.41E-07	1.02E-08	2.53E+03	4.43E+00	8.48E-04	0.00E+00	6.67E-04	2.88E-03	0.00E+00	7.02E-04	6.59E-02
XE-133	3.45E-05	4.20E-07	1.03E+05	1.82E+02	3.48E-02	0.00E+00	2.48E-02	1.11E-01	0.00E+00	6.44E-02	2.55E+00
XE-135M	2.44E-06	2.96E-08	2.63E+04	1.29E+01	2.46E-03	0.00E+00	8.87E-02	1.87E-02	0.00E+00	4.47E-02	2.58E-01
XE-135	8.26E-06	1.00E-07	2.56E+04	4.35E+01	8.33E-03	0.00E+00	5.04E-02	6.07E-02	0.00E+00	4.05E-02	1.37E-00
XE-138	1.00E-05	1.22E-07	9.41E+04	5.29E+01	1.01E-02	0.00E+00	2.16E+00	5.54E-01	0.00E+00	2.95E-01	8.00E+00
KR-83M	7.25E-07	8.81E-09	2.59E+03	3.82E+00	7.31E-04	0.00E+00	1.04E-04	6.48E-04	0.00E+00	1.20E-03	1.37E-02
KR-85M	3.08E-06	3.75E-08	9.94E+03	1.62E+01	3.11E-03	0.00E+00	1.24E-02	1.70E-02	0.00E+00	1.06E-02	3.78E-01
KR-85	4.75E-07	5.77E-09	1.42E+03	2.50E+00	4.79E-04	0.00E+00	2.39E-05	2.33E-03	0.00E+00	2.00E-05	5.34E-02
KR-87	4.77E-06	5.80E-08	1.85E+04	2.51E+01	4.81E-03	0.00E+00	2.04E-01	1.43E-01	0.00E+00	7.42E-02	2.92E+00
KR-88	8.20E-06	9.97E-08	2.76E+04	4.32E+01	8.27E-03	0.00E+00	3.85E-01	6.93E-02	0.00E+00	2.56E-01	1.51E+00
						1.61E-01	2.98E+00	9.93E-01	3.65E+02	8.25E-01	1.74E+01

QDC CRDA, CR & LPZ, ALL REL GLAND: SIEMENS 60 GWD/MTU: 0 - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO  
SPRAYED VOL

AT 2.000 HOURS: X/Q(SITE) = .90E-05 SEC/M3 PRIMARY LEAK RATE=\*\*\*\*\* PERCENT/DAY CONTROL ROOM  
 INTAKE=2460.0 CFM

X/Q CONT ROOM= .70E-03 SEC/M3 SEC RELEASE RATE= .86E+05 VOL/DAY PCT PRI LKG TO ATM =  
 00.00

QDC CRDA, CR & LPZ, ALL REL GLAND: SIEMENS 60 GWD/MTU: 0 - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO  
SPRAYED VOL

AT 8.000 HOURS: X/Q(SITE)= .90E-05 SEC/M3 PRIMARY LEAK RATE=\*\*\*\*\* PERCENT/DAY CONTROL ROOM  
 INTAKE=2460.0 CFM

X/Q CONT ROOM= .65E-05 SEC/M3 SEC RELEASE RATE= .86E+05 VOL/DAY PCT PRI LKG TO ATM =  
 00.00

ELEMENTAL												
I-131	0.00E+00	0.00E+00	1.21E-35	2.23E-03	4.27E-07	5.57E-38	1.01E-41	4.92E-42	1.21E+02	7.80E-04	1.07E-02	
I-132	0.00E+00	0.00E+00	9.24E-36	2.88E-04	5.52E-08	1.54E-39	4.99E-41	8.57E-42	2.48E+00	2.47E-03	1.38E-02	
I-133	0.00E+00	0.00E+00	2.02E-35	3.13E-03	5.99E-07	2.52E-38	2.17E-41	1.77E-41	5.29E+01	2.03E-03	3.71E-02	
I-134	0.00E+00	0.00E+00	4.80E-36	7.64E-06	1.46E-09	3.75E-40	2.10E-41	4.52E-42	4.20E-01	9.63E-04	5.06E-03	
I-135	0.00E+00	0.00E+00	1.54E-35	1.57E-03	3.00E-07	5.96E-39	6.16E-41	9.81E-42	1.16E+01	2.91E-03	1.90E-02	
PARTICULATE												
I-131	0.00E+00	0.00E+00	6.62E-37	1.23E-04	2.35E-08	3.06E-39	5.53E-43	2.70E-43	6.64E+00	4.28E-05	5.86E-04	
I-132	0.00E+00	0.00E+00	5.08E-37	1.58E-05	3.03E-09	8.48E-41	2.74E-42	4.71E-43	1.36E-01	1.36E-04	7.56E-04	
I-133	0.00E+00	0.00E+00	1.11E-36	1.72E-04	3.29E-08	1.38E-39	1.19E-42	9.71E-43	2.91E+00	1.12E-04	2.04E-03	
I-134	0.00E+00	0.00E+00	2.64E-37	4.20E-07	8.04E-11	2.06E-41	1.15E-42	2.49E-43	2.31E-02	5.29E-05	2.78E-04	
I-135	0.00E+00	0.00E+00	8.45E-37	8.61E-05	1.65E-08	3.27E-40	3.38E-42	5.39E-43	6.36E-01	1.60E-04	1.05E-03	
ORGANIC												
I-131	0.00E+00	0.00E+00	5.30E-37	9.80E-05	1.88E-08	2.45E-39	4.42E-43	2.16E-43	5.32E+00	3.43E-05	4.69E-04	
I-132	0.00E+00	0.00E+00	4.06E-37	1.27E-05	2.43E-09	6.78E-41	2.19E-42	3.77E-43	1.09E-01	1.09E-04	6.05E-04	
I-133	0.00E+00	0.00E+00	8.87E-00	1.38E-04	2.63E-08	1.11E-39	9.52E-43	7.77E-43	2.32E+00	8.94E-05	1.63E-03	
I-134	0.00E+00	0.00E+00	2.11E-37	3.36E-07	6.43E-11	1.65E-41	9.21E-43	1.99E-43	1.85E-02	4.23E-05	2.23E-04	
I-135	0.00E+00	0.00E+00	6.76E-37	6.89E-05	1.32E-08	2.62E-40	2.71E-42	4.31E-43	5.09E-01	1.28E-04	8.37E-04	
NOBLE GASES												
XE-131M	0.00E+00	0.00E+00	1.12E-35	2.09E-03	4.00E-07	0.00E+00	5.55E-43	3.14E-42	0.00E+00	1.89E-04	6.82E-03	
XE-133M	0.00E+00	0.00E+00	5.70E-35	9.98E-03	1.91E-06	0.00E+00	4.23E-42	1.83E-41	0.00E+00	4.18E-04	3.93E-02	
XE-133	0.00E+00	0.00E+00	2.37E-37	4.33E-01	8.28E-05	0.00E+00	1.60E-40	7.15E-40	0.00E+00	3.92E-02	1.55E+00	
XE-135M	0.00E+00	0.00E+00	2.92E-36	6.70E-11	1.28E-14	0.00E+00	2.77E-42	5.86E-43	0.00E+00	5.48E-05	3.16E-04	
XE-135	0.00E+00	0.00E+00	5.08E-34	6.10E-02	1.17E-05	0.00E+00	2.81E-40	3.39E-40	0.00E+00	2.01E-02	6.78E-01	
XE-138	0.00E+00	0.00E+00	1.86E-35	2.39E-09	4.58E-13	0.00E+00	1.20E-40	3.09E-41	0.00E+00	6.66E-04	1.80E-02	
KR-83M	0.00E+00	0.00E+00	2.85E-35	5.86E-04	1.12E-07	0.00E+00	3.20E-43	2.00E-42	0.00E+00	2.65E-04	3.03E-03	
KR-85M	0.00E+00	0.00E+00	1.68E-34	1.23E-02	2.36E-06	0.00E+00	5.88E-41	8.08E-41	0.00E+00	4.15E-03	1.48E-01	
KR-85	0.00E+00	0.00E+00	3.28E-35	6.20E-03	1.19E-06	0.00E+00	1.55E-43	1.52E-41	0.00E+00	1.24E-05	3.30E-02	
KR-87	0.00E+00	0.00E+00	1.43E-34	1.03E-03	1.97E-07	0.00E+00	4.43E-40	3.11E-40	0.00E+00	1.04E-02	4.11E-01	
KR-88	0.00E+00	0.00E+00	3.89E-34	1.67E-02	3.20E-06	0.00E+00	1.52E-39	2.74E-40	0.00E+00	7.86E-02	4.62E-01	
						9.76E-38	2.79E-39	1.84E-39	2.07E+02	1.64E-01	3.44E+00	

1 QDC CRDA, CR & LPZ, ALL REL GLAND: SIEMENS 60 GWD/MTU: 0 - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO  
SPRAYED VOL

AT 24.000 HOURS: X/Q(SITE)= .30E-05 SEC/M3 PRIMARY LEAK RATE=\*\*\*\*\* PERCENT/DAY CONTROL ROOM  
INTAKE=2460.0 CFM

X/Q CONT ROOM=.38E-05 SEC/M3 SEC RELEASE RATE=.86E+05 VOL/DAY PCT PRI LKG TO ATM =  
00.00

CLEANUP RATES (HR-1)													FILTER NON-REMOVAL FACTORS		
SPRAY			PRIMARY		SECONDARY		CONT CENTER		RELEASE		CONT CENTER				
ELEMENTAL	.000	.000	.000	.000	.000	.000	.000	.000	1.000	1.000	1.000	1.000			
I-131	0.00E+00	0.00E+00	0.00E+00	5.81E-09	1.11E-12	0.00E+00	0.00E+00	0.00E+00	9.82E-01	6.33E-06	8.66E-05				
I-132	0.00E+00	0.00E+00	0.00E+00	6.41E-12	1.23E-15	0.00E+00	0.00E+00	0.00E+00	3.35E-03	3.34E-06	1.86E-05				
I-133	0.00E+00	0.00E+00	0.00E+00	5.10E-09	9.76E-13	0.00E+00	0.00E+00	0.00E+00	3.59E-01	1.38E-05	2.52E-04				
I-134	0.00E+00	0.00E+00	0.00E+00	5.90E-17	1.13E-20	0.00E+00	0.00E+00	0.00E+00	2.86E-05	6.55E-08	3.45E-07				
I-135	0.00E+00	0.00E+00	0.00E+00	8.29E-10	1.59E-13	0.00E+00	0.00E+00	0.00E+00	5.15E-02	1.29E-05	8.47E-05				
PARTICULATE	.000	.000	.000	.000	.000	.000	.000	.000	1.000	1.000	1.000	1.000			
I-131	0.00E+00	0.00E+00	0.00E+00	3.19E-10	6.11E-14	0.00E+00	0.00E+00	0.00E+00	5.40E-02	3.48E-07	4.76E-06				
I-132	0.00E+00	0.00E+00	0.00E+00	3.52E-13	6.75E-17	0.00E+00	0.00E+00	0.00E+00	1.84E-04	1.84E-07	1.02E-06				
I-133	0.00E+00	0.00E+00	0.00E+00	2.80E-10	5.36E-14	0.00E+00	0.00E+00	0.00E+00	1.97E-02	7.59E-07	1.38E-05				
I-134	0.00E+00	0.00E+00	0.00E+00	3.24E-18	6.21E-22	0.00E+00	0.00E+00	0.00E+00	1.57E-06	3.60E-09	1.89E-08				
I-135	0.00E+00	0.00E+00	0.00E+00	4.55E-11	8.71E-15	0.00E+00	0.00E+00	0.00E+00	2.83E-03	7.11E-07	4.65E-06				
ORGANIC	.000	.000	.000	.000	.000	.000	.000	.000	1.000	1.000	1.000	1.000			
I-131	0.00E+00	0.00E+00	0.00E+00	2.56E-10	4.89E-14	0.00E+00	0.00E+00	0.00E+00	4.32E-02	2.78E-07	3.81E-06				
I-132	0.00E+00	0.00E+00	0.00E+00	2.82E-13	5.40E-17	0.00E+00	0.00E+00	0.00E+00	1.47E-04	1.47E-07	8.17E-07				
I-133	0.00E+00	0.00E+00	0.00E+00	2.24E-10	4.29E-14	0.00E+00	0.00E+00	0.00E+00	1.58E-02	6.07E-07	1.11E-05				
I-134	0.00E+00	0.00E+00	0.00E+00	2.59E-18	4.96E-22	0.00E+00	0.00E+00	0.00E+00	1.26E-06	2.88E-09	1.52E-08				
I-135	0.00E+00	0.00E+00	0.00E+00	3.64E-11	6.97E-15	0.00E+00	0.00E+00	0.00E+00	2.26E-03	5.69E-07	3.72E-06				
NOBLE GASES	.000	.000	.000	.000	.000	.000	.000	.000	1.000	1.000	1.000	1.000			
XE-131M	0.00E+00	0.00E+00	0.00E+00	5.55E-09	1.06E-12	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.54E-06	5.57E-05		
XE-133M	0.00E+00	0.00E+00	0.00E+00	2.25E-08	4.30E-12	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.21E-06	3.02E-04		
XE-133	0.00E+00	0.00E+00	0.00E+00	1.09E-06	2.09E-10	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.14E-04	1.24E-02		
XE-135M	0.00E+00	0.00E+00	0.00E+00	5.70E-35	1.09E-38	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.16E-14	2.97E-13		
XE-135	0.00E+00	0.00E+00	0.00E+00	4.99E-08	9.56E-12	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.05E-04	3.55E-03		
XE-138	0.00E+00	0.00E+00	0.00E+00	2.04E-31	3.90E-35	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.53E-12	9.55E-11		
KR-83M	0.00E+00	0.00E+00	0.00E+00	4.29E-12	8.22E-16	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.36E-07	2.70E-06		
KR-85M	0.00E+00	0.00E+00	0.00E+00	2.73E-09	5.23E-13	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.33E-05	4.76E-04		
KR-85	0.00E+00	0.00E+00	0.00E+00	1.71E-08	3.28E-12	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.03E-07	2.74E-04		

KR-87	0.00E+00	0.00E+00	0.00E+00	4.47E-13	8.56E-17	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.22E-06	1.27E-04
KR-88	0.00E+00	0.00E+00	0.00E+00	8.77E-10	1.68E-13	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.47E-04	8.62E-04
						-----	-----	-----	-----	-----	-----	-----
						0.00E+00	0.00E+00	0.00E+00	1.53E+00	6.28E-04	1.86E-02	

1 QDC CRDA, CR & LPZ, ALL REL GLAND: SIEMENS 60 GWD/MTU: 0 - 30 d

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO  
SPRAYED VOL

AT 720.000 HOURS: X/Q(SITE)= .00E+00 SEC/M3 PRIMARY LEAK RATE= .000 PERCENT/DAY CONTROL ROOM  
INTAKE=2460.0 CFM

X/Q CONT ROOM= .00E+00 SEC/M3 SEC RELEASE RATE= .00E+00 VOL/DAY PCT PRI LKG TO ATM =  
00.00

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM			SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA	
ELEMENTAL												
I-131	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.56E-06	1.65E-11	2.26E-10	
I-132	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.45E-11	7.44E-14	4.14E-13	
I-133	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.85E-07	2.25E-11	4.10E-10	
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.21E-16	5.06E-19	2.66E-18	
I-135	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.72E-08	6.84E-12	4.48E-11	
PARTICULATE												
I-131	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.41E-07	9.07E-13	1.24E-11	
I-132	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.09E-12	4.09E-15	2.27E-14	
I-133	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.22E-08	1.24E-12	2.25E-11	
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.21E-17	2.78E-20	1.46E-19	
I-135	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.49E-09	3.76E-13	2.46E-12	
ORGANIC												
I-131	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.13E-07	7.25E-13	9.93E-12	
I-132	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.27E-12	3.27E-15	1.82E-14	
I-133	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.57E-08	9.89E-13	1.80E-11	
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.70E-18	2.22E-20	1.17E-19	
I-135	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.20E-09	3.01E-13	1.97E-12	
NOBLE GASES												
XE-131M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.10E-12	1.48E-10	
XE-133M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.22E-12	6.79E-10		
XE-133	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.95E-10	3.14E-08		
XE-135M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.39E-38	2.53E-37		
XE-135	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.63E-11	2.91E-09		
XE-138	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.01E-34	8.14E-33		
KR-83M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.73E-15	1.98E-14		
KR-85M	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.95E-12	1.05E-10		
KR-85	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.83E-13	7.57E-10	
KR-87	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.40E-15	5.53E-14	
KR-88	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.70E-12	4.52E-11	
									0.00E+00	0.00E+00	3.49E-06	9.54E-10
									0.00E+00	0.00E+00	3.68E-08	
TOTAL DOSES 0-30 DAYS									5.17E+01	9.82E+00	3.26E+00	1.09E+03
									1.65E+00	3.40E+01		

1

QDC CRDA, CR & LPZ, ALL REL GLAND: SIEMENS 60 GWD/MTU: 0 - 30 d

ISOTOPE	ACTIVITY RELEASED (CURIES)			
	2. HRS	8. HRS	24. HRS	720. HRS
<b>ELEMENTAL</b>				
I-131	1.69E+03	1.21E-35	0.00E+00	0.00E+00
I-132	2.36E+03	9.24E-36	0.00E+00	0.00E+00
I-133	3.00E+03	2.02E-35	0.00E+00	0.00E+00
I-134	3.35E+03	4.80E-36	0.00E+00	0.00E+00
I-135	2.64E+03	1.54E-35	0.00E+00	0.00E+00
<b>PARTICULATE</b>				
I-131	9.29E+01	6.62E-37	0.00E+00	0.00E+00
I-132	1.30E+02	5.08E-37	0.00E+00	0.00E+00
I-133	1.65E+02	1.11E-36	0.00E+00	0.00E+00
I-134	1.84E+02	2.64E-37	0.00E+00	0.00E+00
I-135	1.45E+02	8.45E-37	0.00E+00	0.00E+00
<b>ORGANIC</b>				
I-131	7.43E+01	5.30E-37	0.00E+00	0.00E+00
I-132	1.04E+02	4.06E-37	0.00E+00	0.00E+00

I-133	1.32E+02	8.87E-37	0.00E+00	0.00E+00	1.32E+02
I-134	1.47E+02	2.11E-37	0.00E+00	0.00E+00	1.47E+02
I-135	1.16E+02	6.76E-37	0.00E+00	0.00E+00	1.16E+02
NOBLE GASES					
XE-131M	1.57E+03	1.12E-35	0.00E+00	0.00E+00	1.57E+03
XE-133M	8.14E+03	5.70E-35	0.00E+00	0.00E+00	8.14E+03
XE-133	3.33E+05	2.37E-33	0.00E+00	0.00E+00	3.33E+05
XE-135M	8.74E+04	2.92E-36	0.00E+00	0.00E+00	8.74E+04
XE-135	8.25E+04	5.08E-34	0.00E+00	0.00E+00	8.25E+04
XE-138	3.12E+05	1.86E-35	0.00E+00	0.00E+00	3.12E+05
KR-83M	8.37E+03	2.85E-35	0.00E+00	0.00E+00	8.37E+03
KR-85M	3.21E+04	1.68E-34	0.00E+00	0.00E+00	3.21E+04
KR-85	4.57E+03	3.28E-35	0.00E+00	0.00E+00	4.57E+03
KR-87	6.01E+04	1.43E-34	0.00E+00	0.00E+00	6.01E+04
KR-88	8.92E+04	3.89E-34	0.00E+00	0.00E+00	8.92E+04

END EXECUTION DATE: 11/18/1999  
END EXECUTION TIME: 17:45:33.98

AXIDENT VER 2 MOD 4  
 PRODUCTION DATE 02/18/92  
 BEGIN EXECUTION DATE: 11/18/1999  
 BEGIN EXECUTION TIME: 17:45:42.39

1 QDC CRDA, EAB, ALL REL MVP: SIEMENS 60 GWD/MTU: 0 - 6 s  
 2 1 1. 1.  
 3 -2561 2.60+6 1.845+5 5.83+4  
 4 0. 0. 0. 1. 1. 2.78+5 0.  
 5 6 7200  
 6 0.2402 0.  
 7 9.058E-4 0.  
 8 2\*1.  
 9 2\*0.  
 10 2.9E-4 0.  
 11 2\*0.  
 12 2\*0.  
 13 2\*0.  
 14 2\*0.  
 15 2\*0.  
 16 2\*0.  
 17 2\*0.  
 18 2\*0.  
 19 2\*0.  
 20 2\*0.  
 21 6\*1.  
 22 3\*1.  
 23 7.43E+3 1.04E+4 1.32E+4 1.48E+4 1.16E+4 1.57E+3 8.14E+3 3.33E+5  
 24 8.89E+4 8.25E+4 3.17E+5 8.39E+3 3.21E+4 4.57E+3 6.03E+4 8.93E+4

1

QDC CRDA, EAB, ALL REL MVP: SIEMENS 60 GWD/MTU: 0 - 6 s

## INITIAL CONTAINMENT INVENTORY

## ISOTOPE ACTIVITY (CURIES)

I-131	7.430E+03
I-132	1.040E+04
I-133	1.320E+04
I-134	1.480E+04
I-135	1.160E+04
XE-131M	1.570E+03
XE-133M	8.140E+03
XE-133	3.330E+05
XE-135M	8.890E+04
XE-135	8.250E+04
XE-138	3.170E+05
KR-83M	8.390E+03
KR-85M	3.210E+04
KR-85	4.570E+03
KR-87	6.030E+04
KR-88	8.930E+04

1

QDC CRDA, EAB, ALL REL MVP: SIEMENS 60 GWD/MTU: 0 - 6 s

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL,	1. CFM MIXING, 00.00 PCT REL TO
SPRAYED VOL	

AT .002 HOURS: X/Q(SITE)= .29E-03 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM INTAKE=
.0 CFM		
X/Q CONT ROOM= .00E+00 SEC/M3	SEC RELEASE RATE= .78E+02 VOL/DAY	PCT PRI LKG TO ATM =
00.00		

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM		SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA
ELEMENTAL											
I-131	4.00E+02	1.29E+03	4.31E+00	0.00E+00	0.00E+00	6.42E-01	1.16E-04	5.67E-05	0.00E+00	0.00E+00	0.00E+00
I-132	5.60E+02	1.80E+03	6.03E+00	0.00E+00	0.00E+00	3.25E-02	1.05E-03	1.80E-04	0.00E+00	0.00E+00	0.00E+00
I-133	7.11E+02	2.28E+03	7.66E+00	0.00E+00	0.00E+00	3.08E-01	2.65E-04	2.16E-04	0.00E+00	0.00E+00	0.00E+00
I-134	7.96E+02	2.56E+03	8.58E+00	0.00E+00	0.00E+00	2.16E-02	1.21E-03	2.60E-04	0.00E+00	0.00E+00	0.00E+00

I-135	6.24E+02	2.01E+03	6.73E+00	0.00E+00	0.00E+00	8.40E-02	8.68E-04	1.38E-04	0.00E+00	0.00E+00	0.00E+00
<b>PARTICULATE</b>											
I-131	2.20E+01	7.07E+01	2.37E-01	0.00E+00	0.00E+00	3.53E-02	6.37E-06	3.11E-06	0.00E+00	0.00E+00	0.00E+00
I-132	3.07E+01	9.89E+01	3.32E-01	0.00E+00	0.00E+00	1.78E-03	5.77E-05	9.91E-06	0.00E+00	0.00E+00	0.00E+00
I-133	3.90E+01	1.26E+02	4.21E-01	0.00E+00	0.00E+00	1.69E-02	1.46E-05	1.19E-05	0.00E+00	0.00E+00	0.00E+00
I-134	4.37E+01	1.41E+02	4.72E-01	0.00E+00	0.00E+00	1.19E-03	6.63E-05	1.43E-05	0.00E+00	0.00E+00	0.00E+00
I-135	3.43E+01	1.10E+02	3.70E-01	0.00E+00	0.00E+00	4.62E-03	4.77E-05	7.60E-06	0.00E+00	0.00E+00	0.00E+00
<b>ORGANIC</b>											
I-131	1.76E+01	5.65E+01	1.90E-01	0.00E+00	0.00E+00	2.82E-02	5.10E-06	2.49E-06	0.00E+00	0.00E+00	0.00E+00
I-132	2.46E+01	7.91E+01	2.65E-01	0.00E+00	0.00E+00	1.43E-03	4.61E-05	7.93E-06	0.00E+00	0.00E+00	0.00E+00
I-133	3.12E+01	1.00E+02	3.37E-01	0.00E+00	0.00E+00	1.36E-02	1.16E-02	9.50E-06	0.00E+00	0.00E+00	0.00E+00
I-134	3.50E+01	1.12E+02	3.77E-01	0.00E+00	0.00E+00	9.49E-04	5.30E-05	1.14E-05	0.00E+00	0.00E+00	0.00E+00
I-135	2.74E+01	8.82E+01	2.96E-01	0.00E+00	0.00E+00	3.69E-03	3.82E-05	6.08E-06	0.00E+00	0.00E+00	0.00E+00
<b>NOBLE GASES</b>											
XE-131M	3.72E+02	1.19E+03	4.01E+00	0.00E+00	0.00E+00	0.00E+00	6.39E-06	3.61E-05	0.00E+00	0.00E+00	0.00E+00
XE-133M	1.93E+03	6.19E+03	2.08E+01	0.00E+00	0.00E+00	0.00E+00	4.97E-05	2.15E-04	0.00E+00	0.00E+00	0.00E+00
XE-133	7.88E+04	2.53E+05	8.49E+02	0.00E+00	0.00E+00	0.00E+00	1.85E-03	8.27E-03	0.00E+00	0.00E+00	0.00E+00
XE-135M	2.09E+04	6.73E+04	2.26E+02	0.00E+00	0.00E+00	0.00E+00	6.92E-03	1.46E-03	0.00E+00	0.00E+00	0.00E+00
XE-135	1.95E+04	6.28E+04	2.10E+02	0.00E+00	0.00E+00	0.00E+00	3.75E-03	4.52E-03	0.00E+00	0.00E+00	0.00E+00
XE-138	7.47E+04	2.40E+05	8.07E+02	0.00E+00	0.00E+00	0.00E+00	1.68E-01	4.30E-02	0.00E+00	0.00E+00	0.00E+00
KR-83M	9.98E+03	6.38E+03	2.14E+01	0.00E+00	0.00E+00	0.00E+00	7.76E-06	4.85E-05	0.00E+00	0.00E+00	0.00E+00
KR-85M	7.59E+03	2.44E+04	8.19E+01	0.00E+00	0.00E+00	0.00E+00	9.26E-04	1.27E-03	0.00E+00	0.00E+00	0.00E+00
KR-85	1.08E+03	3.48E+03	1.17E+01	0.00E+00	0.00E+00	0.00E+00	1.77E-06	1.73E-04	0.00E+00	0.00E+00	0.00E+00
KR-87	1.43E+04	4.58E+04	1.54E+02	0.00E+00	0.00E+00	0.00E+00	1.53E-02	1.08E-02	0.00E+00	0.00E+00	0.00E+00
KR-88	2.11E+04	6.79E+04	2.28E+02	0.00E+00	0.00E+00	0.00E+00	2.88E-02	5.18E-03	0.00E+00	0.00E+00	0.00E+00
							1.20E+00	2.29E-01	7.59E-02	0.00E+00	0.00E+00
											0.00E+00

1 QDC CRDA, EAB, ALL REL MVP: SIEMENS 60 GWD/MTU: 0 - 6 s

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO SPRAYED VOL

AT	2.000 HOURS:	X/Q(SITE)= .00E+00 SEC/M3	PRIMARY LEAK RATE= .000 PERCENT/DAY	CONTROL ROOM INTAKE=
.0 CFM				
00.00		X/Q CONT ROOM= .00E+00 SEC/M3	SEC RELEASE RATE= .00E+00 VOL/DAY	PCT PRI LKG TO ATM =

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	1.000	1.000

ACTIVITY (CURIES)		CONTROL ROOM (CURIES)		SITE BOUNDARY DOSES (REM)	
	PRIMARY	SECONDARY	THYROID WH BODY BETA	THYROID WH BODY BETA	
<b>ELEMENTAL</b>					
I-131	3.97E+02	1.28E+03	0.00E+00	0.00E+00 0.00E+00 0.00E+00	
I-132	3.06E+02	9.85E+02	0.00E+00	0.00E+00 0.00E+00 0.00E+00	
I-133	6.65E+02	2.14E+03	0.00E+00	0.00E+00 0.00E+00 0.00E+00	
I-134	1.61E+02	5.18E+02	0.00E+00	0.00E+00 0.00E+00 0.00E+00	
I-135	5.08E+02	1.63E+03	0.00E+00	0.00E+00 0.00E+00 0.00E+00	
<b>PARTICULATE</b>					
I-131	2.18E+01	7.02E+01	0.00E+00	0.00E+00 0.00E+00 0.00E+00	
I-132	1.68E+01	5.41E+01	0.00E+00	0.00E+00 0.00E+00 0.00E+00	
I-133	3.66E+01	1.18E+02	0.00E+00	0.00E+00 0.00E+00 0.00E+00	
I-134	8.85E+00	2.85E+01	0.00E+00	0.00E+00 0.00E+00 0.00E+00	
I-135	2.79E+01	8.97E+01	0.00E+00	0.00E+00 0.00E+00 0.00E+00	
<b>ORGANIC</b>					
I-131	1.75E+01	5.61E+01	0.00E+00	0.00E+00 0.00E+00 0.00E+00	
I-132	1.35E+01	4.33E+01	0.00E+00	0.00E+00 0.00E+00 0.00E+00	
I-133	2.92E+01	9.40E+01	0.00E+00	0.00E+00 0.00E+00 0.00E+00	
I-134	7.08E+00	2.28E+01	0.00E+00	0.00E+00 0.00E+00 0.00E+00	
I-135	2.23E+01	7.18E+01	0.00E+00	0.00E+00 0.00E+00 0.00E+00	
<b>NOBLE GASES</b>					
XE-131M	3.70E+02	1.19E+03	0.00E+00	0.00E+00 0.00E+00 0.00E+00	
XE-133M	1.88E+03	6.04E+03	0.00E+00	0.00E+00 0.00E+00 0.00E+00	
XE-133	7.79E+04	2.51E+05	0.00E+00	0.00E+00 0.00E+00 0.00E+00	
XE-135M	1.02E+02	3.28E+02	0.00E+00	0.00E+00 0.00E+00 0.00E+00	
XE-135	1.68E+04	5.39E+04	0.00E+00	0.00E+00 0.00E+00 0.00E+00	
XE-138	6.48E+02	2.08E+03	0.00E+00	0.00E+00 0.00E+00 0.00E+00	
KR-83M	9.46E+02	3.04E+03	0.00E+00	0.00E+00 0.00E+00 0.00E+00	
KR-85M	5.54E+03	1.78E+04	0.00E+00	0.00E+00 0.00E+00 0.00E+00	
KR-85	1.08E+03	3.48E+03	0.00E+00	0.00E+00 0.00E+00 0.00E+00	
KR-87	4.78E+03	1.54E+04	0.00E+00	0.00E+00 0.00E+00 0.00E+00	
KR-88	1.29E+04	4.14E+04	0.00E+00	0.00E+00 0.00E+00 0.00E+00	
			0.00E+00	0.00E+00 0.00E+00 0.00E+00	

1

===== ===== ===== ===== ===== =====  
TOTAL DOSES 0-30 DAYS 1.20E+00 2.29E-01 7.59E-02 0.00E+00 0.00E+00 0.00E+00

QDC CRDA, EAB, ALL REL MVP: SIEMENS 60 GWD/MTU: 0 - 6 s

ISOTOPE	2. HRS	ACTIVITY RELEASED (CURIES)
ELEMENTAL		
I-131	4.31E+00	4.31E+00
I-132	6.03E+00	6.03E+00
I-133	7.66E+00	7.66E+00
I-134	8.58E+00	8.58E+00
I-135	6.73E+00	6.73E+00
PARTICULATE		
I-131	2.37E-01	2.37E-01
I-132	3.32E-01	3.32E-01
I-133	4.21E-01	4.21E-01
I-134	4.72E-01	4.72E-01
I-135	3.70E-01	3.70E-01
ORGANIC		
I-131	1.90E-01	1.90E-01
I-132	2.65E-01	2.65E-01
I-133	3.37E-01	3.37E-01
I-134	3.77E-01	3.77E-01
I-135	2.96E-01	2.96E-01
NOBLE GASES		
XE-131M	4.01E+00	4.01E+00
XE-133M	2.08E+01	2.08E+01
XE-133	8.49E+02	8.49E+02
XE-135M	2.26E+02	2.26E+02
XE-135	2.10E+02	2.10E+02
XE-138	8.07E+02	8.07E+02
KR-83M	2.14E+01	2.14E+01
KR-85M	8.19E+01	8.19E+01
KR-85	1.17E+01	1.17E+01
KR-87	1.54E+02	1.54E+02
KR-88	2.28E+02	2.28E+02

END EXECUTION DATE: 11/18/1999  
END EXECUTION TIME: 17:45:42.39

AXIDENT VER 2 MOD 4  
PRODUCTION DATE 02/18/92  
BEGIN EXECUTION DATE: 11/18/1999  
BEGIN EXECUTION TIME: 17:45:50.52

```

1 QDC CRDA, EAB, ALL REL AOG: SIEMENS 60 GWD/MTU: 6 s - 2 h
2 3 1 1. 1.
3 -2561 2.60+6 1.845+5 5.83+4
4 0. 0. 0. 1. 1. 2.78+5 0.
5 6 1800 7200
6 0.2402 2*1.201E-2
7 9.058E-4 2*1.157E-5
8 3*1.
9 3*0.
10 0. 2.9e-4 2.3E-5
11 3*0.
12 3*0.
13 3*0.
14 3*0.
15 3*0.
16 3*0.
17 3*0.
18 3*0.
19 3*0.
20 3*0.
21 3*0. 3*1.
22 3*1.
23 7.43E+3      1.04E+4    1.32E+4    1.48E+4    1.16E+4    1.57E+3    8.14E+3    3.33E+5
24 8.89E+4      8.25E+4    3.17E+5    8.39E+3    3.21E+4    4.57E+3    6.03E+4    8.93E+4

```

3

ODC CRDA, EAB, ALL REL AOG: SIEMENS 60 GWD/MTU: 6 s - 2 h

## INITIAL CONTAINMENT INVENTORY

**ISOTOPE ACTIVITY (CURIES)**

I-131	7.430E+03
I-132	1.040E+04
I-133	1.320E+04
I-134	1.480E+04
I-135	1.160E+04
XE-131M	1.570E+03
XE-133M	8.140E+03
XE-133	3.330E+05
XE-135M	8.890E+04
XE-135	8.250E+04
XE-138	3.170E+05
KR-83M	8.390E+03
KR-85M	3.210E+04
KR-85	4.570E+03
KR-87	6.030E+04
KR-88	8.930E+04

1

ODC CRDA, EAB, ALL REL AOG: SIEMENS 60 GWD/MTU: 6 s - 2 h

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO  
SPRAYED VOL.

AT .002 HOURS: X/Q(SITE)= .00E+00 SEC/M3 PRIMARY LEAK RATE=\*\*\*\*\* PERCENT/DAY CONTROL ROOM INTAKE=.  
 .0 CFM  
 X/Q CONT ROOM= .00E+00 SEC/M3 SEC RELEASE RATE= .78E+02 VOL/DAY PCT PRI LKG TO ATM =  
 0.00

1 QDC CRDA, EAB, ALL REL AOG: SIEMENS 60 GWD/MTU: 6 s - 2 h

ANALYSIS BASED ON: 2561 MWT, 184500- FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL. 278000. FT3 UNSPRAYED VOL. 1. CPM MIXING, 00.00 PCT REL TO

SPRAYED VOL

AT .500 HOURS: X/Q(SITE)= .29E-03 SEC/M3 PRIMARY LEAK RATE=\*\*\*\*\* PERCENT/DAY CONTROL ROOM INTAKE=.0 CFM  
 00.00 X/Q CONT ROOM= .00E+00 SEC/M3 SEC RELEASE RATE= .10E+01 VOL/DAY PCT PRI LKG TO ATM =

1

QDC CRDA, EAB, ALL REL AOG: SIEMENS 60 GWD/MTU: 6 s - 2 h

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
 1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO  
 SPRAYED VOL

AT .0 CFM	2.000 HOURS:	X/Q(SITE)= .23E-04 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM INTAKE=
		X/Q CONT ROOM= .00E+00 SEC/M3	SEC RELEASE RATE= .10E+01 VOL/DAY	PCT PRI LKG TO ATM =
		00.00		

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM			SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)					
	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA	CLEANUP RATES (HR-1)	FILTER NON-REMOVAL FACTORS		
												SPRAY	RELEASE	CONT CENTER	CONT CENTER
ELEMENTAL	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	1.000			
PARTICULATE	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	1.000			
ORGANIC	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	1.000			
I-131	1.19E-35	1.54E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00			
I-132	9.19E-36	1.19E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00			
I-133	2.00E-35	2.58E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00			
I-134	4.83E-36	6.25E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00			
I-135	1.52E-35	1.97E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00			
PARTICULATE															
I-131	6.54E-37	8.46E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00			
I-132	5.05E-37	6.53E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00			
I-133	1.10E-36	1.42E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00			
I-134	2.66E-37	3.43E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00			
I-135	8.37E-37	1.08E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00			
ORGANIC															
I-131	5.24E-37	6.77E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00			
I-132	4.04E-37	5.23E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00			
I-133	8.77E-37	1.13E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00			
I-134	2.12E-37	2.75E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00			
I-135	6.70E-37	8.66E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00			
NOBLE GASES															
XE-131M	1.11E-35	1.43E+03	9.26E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.17E-05	6.62E-05	0.00E+00	0.00E+00	0.00E+00		
XE-133M	5.63E-35	7.28E+03	4.74E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.00E-05	3.89E-04	0.00E+00	0.00E+00	0.00E+00		
XE-133	2.34E-33	3.02E+05	1.96E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.38E-03	1.51E-02	0.00E+00	0.00E+00	0.00E+00		
XE-135M	3.06E-36	3.96E+02	3.47E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.42E-04	1.78E-04	0.00E+00	0.00E+00	0.00E+00		
XE-135	5.03E-34	6.51E+04	4.45E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.29E-03	7.57E-03	0.00E+00	0.00E+00	0.00E+00		
XE-138	1.94E-35	2.51E+03	1.58E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.61E-02	6.70E-03	0.00E+00	0.00E+00	0.00E+00		
KR-83M	2.84E-35	3.67E+03	3.17E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.12E-06	5.71E-05	0.00E+00	0.00E+00	0.00E+00		
KR-85M	1.66E-34	2.15E+04	1.57E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.40E-03	1.93E-03	0.00E+00	0.00E+00	0.00E+00		
KR-85	3.24E-35	4.20E+03	2.70E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.27E-06	3.19E-04	0.00E+00	0.00E+00	0.00E+00		
KR-87	1.43E-34	1.85E+04	1.86E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.47E-02	1.03E-02	0.00E+00	0.00E+00	0.00E+00		
KR-88	3.86E-34	5.00E+04	3.91E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.92E-02	7.05E-03	0.00E+00	0.00E+00	0.00E+00		
									0.00E+00	9.20E-02	4.97E-02	0.00E+00	0.00E+00	0.00E+00	
TOTAL DOSES 0-30 DAYS									0.00E+00	1.27E+00	4.83E-01	0.00E+00	0.00E+00	0.00E+00	

1

QDC CRDA, EAB, ALL REL AOG: SIEMENS 60 GWD/MTU: 6 s - 2 h

ISOTOPE	ACTIVITY RELEASED (CURIES)	
	2. HRS	
<b>ELEMENTAL</b>		
I-131	0.00E+00	0.00E+00
I-132	0.00E+00	0.00E+00
I-133	0.00E+00	0.00E+00
I-134	0.00E+00	0.00E+00
I-135	0.00E+00	0.00E+00
<b>PARTICULATE</b>		
I-131	0.00E+00	0.00E+00
I-132	0.00E+00	0.00E+00
I-133	0.00E+00	0.00E+00
I-134	0.00E+00	0.00E+00
I-135	0.00E+00	0.00E+00
<b>ORGANIC</b>		
I-131	0.00E+00	0.00E+00
I-132	0.00E+00	0.00E+00
I-133	0.00E+00	0.00E+00
I-134	0.00E+00	0.00E+00
I-135	0.00E+00	0.00E+00
<b>NOBLE GASES</b>		
XE-131M	1.28E+02	1.28E+02

XE-133M	6.59E+02	6.59E+02
XE-133	2.72E+04	2.72E+04
XE-135M	1.56E+03	1.56E+03
XE-135	6.30E+03	6.30E+03
XE-138	6.12E+03	6.12E+03
KR-83M	4.94E+02	4.94E+02
KR-85M	2.27E+03	2.27E+03
KR-85	3.75E+02	3.75E+02
KR-87	3.08E+03	3.08E+03
KR-88	5.84E+03	5.84E+03

END EXECUTION DATE: 11/18/1999  
END EXECUTION TIME: 17:45:50.52

AXIDENT VER 2 MOD 4  
 PRODUCTION DATE 02/18/92  
 BEGIN EXECUTION DATE: 11/18/1999  
 BEGIN EXECUTION TIME: 17:46:00.57

1 QDC CRDA, EAB, ALL REL GLAND: SIEMENS 60 GWD/MTU: 0 - 2 h  
 2 3 2 1. 1.  
 3 -2561 2.60+6 1.845+5 5.83+4  
 4 0. 0. 0. 1. 1. 2.78+5 0.  
 5 6 1800 7200  
 6 0.2402 2\*1.201E-2  
 7 3\*1.  
 8 3\*1.  
 9 3\*0.  
 10 2\*2.9e-4 2.3E-5  
 11 3\*0.  
 12 3\*0.  
 13 3\*0.  
 14 3\*0.  
 15 3\*0.  
 16 3\*0.  
 17 3\*0.  
 18 3\*0.  
 19 3\*0.  
 20 3\*0.  
 21 6\*1.  
 22 3\*1.  
 23 7.43E+3 1.04E+4 1.32E+4 1.48E+4 1.16E+4 1.57E+3 8.14E+3 3.33E+5  
 24 8.89E+4 8.25E+4 3.17E+5 8.39E+3 3.21E+4 4.57E+3 6.03E+4 8.93E+4

1

QDC CRDA, EAB, ALL REL GLAND: SIEMENS 60 GWD/MTU: 0 - 2 h

## INITIAL CONTAINMENT INVENTORY

## ISOTOPE ACTIVITY (CURIES)

I-131	7.430E+03
I-132	1.040E+04
I-133	1.320E+04
I-134	1.480E+04
I-135	1.160E+04
XE-131M	1.570E+03
XE-133M	8.140E+03
XE-133	3.330E+05
XE-135M	8.890E+04
XE-135	8.250E+04
XE-138	3.170E+05
KR-83M	8.390E+03
KR-85M	3.210E+04
KR-85	4.570E+03
KR-87	6.030E+04
KR-88	8.930E+04

1

QDC CRDA, EAB, ALL REL GLAND: SIEMENS 60 GWD/MTU: 0 - 2 h

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
 SPRAYED VOL 1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO

AT .002 HOURS:	X/Q(SITE)= .29E-03 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM INTAKE=
.0 CFM			
00.00	X/Q CONT ROOM= .00E+00 SEC/M3	SEC RELEASE RATE= .86E+05 VOL/DAY	PCT PRI LKG TO ATM =

	CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS			
	SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER		
						ELEMENTAL	PARTICULATE	ORGANIC
		.000	.000	.000	.000	1.000	1.000	
		.000	.000	.000	.000	1.000	1.000	
		.000	.000	.000	.000	1.000	1.000	
ISOTOPE	ACTIVITY (CURIES)	CONTROL ROOM (CURIES)	SITE BOUNDARY DOSES (REM)		CONTROL ROOM DOSES (REM)			
	ISOTOPE	PRIMARY SECONDARY RELEASE	(UCI/CM3)	THYROID WH BODY BETA	THYROID WH BODY	BETA		
ELEMENTAL	I-131	4.00E+02 1.25E+02 1.17E+03	0.00E+00 0.00E+00	1.74E+02 3.13E-02	1.53E-02 0.00E+00	0.00E+00 0.00E+00	0.00E+00	
	I-132	5.60E+02 1.75E+02 1.63E+03	0.00E+00 0.00E+00	8.78E+00 2.84E-01	4.87E-02 0.00E+00	0.00E+00 0.00E+00	0.00E+00	
	I-133	7.11E+02 2.22E+02 2.07E+03	0.00E+00 0.00E+00	8.33E+01 7.16E-02	5.84E-02 0.00E+00	0.00E+00 0.00E+00	0.00E+00	
	I-134	7.96E+02 2.49E+02 2.32E+03	0.00E+00 0.00E+00	5.84E+00 3.26E-01	7.04E-02 0.00E+00	0.00E+00 0.00E+00	0.00E+00	

I-135	6.24E+02	1.95E+02	1.82E+03	0.00E+00	0.00E+00	2.27E+01	2.35E-01	3.74E-02	0.00E+00	0.00E+00	0.00E+00
<b>PARTICULATE</b>											
I-131	2.20E+01	6.88E+00	6.40E+01	0.00E+00	0.00E+00	9.53E+00	1.72E-03	8.41E-04	0.00E+00	0.00E+00	0.00E+00
I-132	3.07E+01	9.62E+00	8.96E+01	0.00E+00	0.00E+00	4.82E-01	1.56E-02	2.68E-03	0.00E+00	0.00E+00	0.00E+00
I-133	3.90E+01	1.22E+01	1.14E+02	0.00E+00	0.00E+00	4.58E+00	3.93E-03	3.21E-03	0.00E+00	0.00E+00	0.00E+00
I-134	4.37E+01	1.37E+01	1.27E+02	0.00E+00	0.00E+00	3.21E-01	1.79E-02	3.87E-03	0.00E+00	0.00E+00	0.00E+00
I-135	3.43E+01	1.07E+01	9.99E+01	0.00E+00	0.00E+00	1.25E+00	1.29E-02	2.05E-03	0.00E+00	0.00E+00	0.00E+00
<b>ORGANIC</b>											
I-131	1.76E+01	5.50E+00	5.12E+01	0.00E+00	0.00E+00	7.63E+00	1.38E-03	6.73E-04	0.00E+00	0.00E+00	0.00E+00
I-132	2.46E+01	7.70E+00	7.17E+01	0.00E+00	0.00E+00	3.85E-01	1.25E-02	2.14E-03	0.00E+00	0.00E+00	0.00E+00
I-133	3.12E+01	9.77E+00	9.10E+01	0.00E+00	0.00E+00	3.66E+00	3.15E-03	2.57E-03	0.00E+00	0.00E+00	0.00E+00
I-134	3.50E+01	1.09E+01	1.02E+02	0.00E+00	0.00E+00	2.56E-01	1.43E-02	3.09E-03	0.00E+00	0.00E+00	0.00E+00
I-135	2.74E+01	8.59E+00	8.00E+01	0.00E+00	0.00E+00	9.98E-01	1.03E-02	1.64E-03	0.00E+00	0.00E+00	0.00E+00
<b>NOBLE GASES</b>											
XE-131M	3.72E+02	1.16E+02	1.08E+03	0.00E+00	0.00E+00	0.00E+00	1.73E-03	9.75E-03	0.00E+00	0.00E+00	0.00E+00
XE-133M	1.93E+03	6.03E+02	5.61E+03	0.00E+00	0.00E+00	0.00E+00	1.34E-02	5.80E-02	0.00E+00	0.00E+00	0.00E+00
XE-133	7.88E+04	2.47E+04	2.30E+05	0.00E+00	0.00E+00	0.00E+00	4.99E-01	2.24E+00	0.00E+00	0.00E+00	0.00E+00
XE-135M	2.09E+04	6.55E+03	6.11E+04	0.00E+00	0.00E+00	0.00E+00	1.87E+00	3.96E-01	0.00E+00	0.00E+00	0.00E+00
XE-135	1.95E+04	6.11E+03	5.69E+04	0.00E+00	0.00E+00	0.00E+00	1.01E+00	1.22E+00	0.00E+00	0.00E+00	0.00E+00
XE-138	7.47E+04	2.34E+04	2.18E+05	0.00E+00	0.00E+00	0.00E+00	4.54E+01	1.16E+01	0.00E+00	0.00E+00	0.00E+00
KR-83M	1.98E+03	6.21E+02	5.78E+03	0.00E+00	0.00E+00	0.00E+00	2.10E-03	1.31E-02	0.00E+00	0.00E+00	0.00E+00
KR-85M	7.59E+03	2.38E+03	2.21E+04	0.00E+00	0.00E+00	0.00E+00	2.50E-01	3.44E-01	0.00E+00	0.00E+00	0.00E+00
KR-85	1.08E+03	3.38E+02	3.15E+03	0.00E+00	0.00E+00	0.00E+00	4.80E-04	4.69E-02	0.00E+00	0.00E+00	0.00E+00
KR-87	1.43E+04	4.46E+03	4.15E+04	0.00E+00	0.00E+00	0.00E+00	4.14E+00	2.91E+00	0.00E+00	0.00E+00	0.00E+00
KR-88	2.11E+04	6.61E+03	6.15E+04	0.00E+00	0.00E+00	0.00E+00	7.78E+00	1.40E+00	0.00E+00	0.00E+00	0.00E+00
							3.23E+02	6.20E+01	2.05E+01	0.00E+00	0.00E+00

1 QDC CRDA, EAB, ALL REL GLAND: SIEMENS 60 GWD/MTU: 0 - 2 h

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS

1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL,		1. CFM MIXING, 00.00 PCT REL TO SPRAYED VOL	
AT .500 HOURS:	X/Q(SITE) = .29E-03 SEC/M3	PRIMARY LEAK RATE=***** PERCENT/DAY	CONTROL ROOM INTAKE=
.0 CFM			
	X/Q CONT ROOM= .00E+00 SEC/M3	SEC RELEASE RATE= .86E+05 VOL/DAY	PCT PRI LKG TO ATM =
00.00			

CLEANUP RATES (HR-1)				FILTER NON-REMOVAL FACTORS	
SPRAY	PRIMARY	SECONDARY	CONT CENTER	RELEASE	CONT CENTER
ELEMENTAL	.000	.000	.000	1.000	1.000
PARTICULATE	.000	.000	.000	1.000	1.000
ORGANIC	.000	.000	.000	1.000	1.000

ISOTOPE	ACTIVITY (CURIES)	CONTROL ROOM (CURIES)	SITE BOUNDARY DOSES (REM)	CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE	THYROID WH BODY BETA	THYROID WH BODY BETA	
ELEMENTAL						
I-131	1.75E-07	2.13E-09	5.25E+02	0.00E+00 0.00E+00	7.82E+01 1.41E-02 6.90E-03	0.00E+00 0.00E+00 0.00E+00
I-132	2.12E-07	2.57E-09	7.31E+02	0.00E+00 0.00E+00	3.93E+00 1.27E-01 2.18E-02	0.00E+00 0.00E+00 0.00E+00
I-133	3.07E-07	3.73E-09	9.32E+02	0.00E+00 0.00E+00	3.75E+01 3.22E-02 2.63E-02	0.00E+00 0.00E+00 0.00E+00
I-134	2.35E-07	2.85E-09	1.03E+03	0.00E+00 0.00E+00	2.59E+00 1.45E-01 3.13E-02	0.00E+00 0.00E+00 0.00E+00
I-135	2.61E-07	3.17E-09	8.18E+02	0.00E+00 0.00E+00	1.02E+01 1.06E-01 1.68E-02	0.00E+00 0.00E+00 0.00E+00
PARTICULATE						
I-131	9.64E-09	1.17E-10	2.89E+01	0.00E+00 0.00E+00	4.30E+00 7.76E-04	3.79E-04 0.00E+00 0.00E+00
I-132	1.16E-08	1.41E-10	4.02E+01	0.00E+00 0.00E+00	2.16E-01 6.99E-03	1.20E-03 0.00E+00 0.00E+00
I-133	1.69E-08	2.05E-10	5.12E+01	0.00E+00 0.00E+00	2.06E+00 1.77E-03	1.45E-03 0.00E+00 0.00E+00
I-134	1.29E-08	1.57E-10	5.66E+01	0.00E+00 0.00E+00	1.42E-01 7.96E-03	1.72E-03 0.00E+00 0.00E+00
I-135	1.43E-08	1.74E-10	4.50E+01	0.00E+00 0.00E+00	5.61E-01 5.80E-03	9.24E-04 0.00E+00 0.00E+00
ORGANIC						
I-131	7.71E-09	9.37E-11	2.31E+01	0.00E+00 0.00E+00	3.44E+00 6.21E-04	3.03E-04 0.00E+00 0.00E+00
I-132	9.30E-09	1.13E-10	3.21E+01	0.00E+00 0.00E+00	1.73E-01 5.59E-03	9.60E-04 0.00E+00 0.00E+00
I-133	1.35E-08	1.64E-10	4.10E+01	0.00E+00 0.00E+00	1.65E+00 1.42E-03	1.16E-03 0.00E+00 0.00E+00
I-134	1.03E-08	1.25E-10	4.53E+01	0.00E+00 0.00E+00	1.14E-01 6.36E-03	1.37E-03 0.00E+00 0.00E+00
I-135	1.15E-08	1.39E-10	3.60E+01	0.00E+00 0.00E+00	4.49E-01 4.64E-03	7.39E-04 0.00E+00 0.00E+00
NOBLE GASES						
XE-131M	1.63E-07	1.98E-09	4.88E+02	0.00E+00 0.00E+00	0.00E+00 7.78E-04	4.39E-03 0.00E+00 0.00E+00
XE-133M	8.41E-07	1.02E-08	2.53E+03	0.00E+00 0.00E+00	0.00E+00 6.05E-03	2.61E-02 0.00E+00 0.00E+00
XE-133	3.45E-05	4.20E-07	1.03E+05	0.00E+00 0.00E+00	0.00E+00 2.25E-01	1.01E+00 0.00E+00 0.00E+00
XE-135M	2.44E-06	2.96E-08	2.63E+04	0.00E+00 0.00E+00	0.00E+00 8.03E-01	1.70E-01 0.00E+00 0.00E+00
XE-135	8.26E-06	1.00E-07	2.56E+04	0.00E+00 0.00E+00	0.00E+00 4.56E-01	5.50E-01 0.00E+00 0.00E+00
XE-138	1.00E-05	1.22E-07	9.41E+04	0.00E+00 0.00E+00	0.00E+00 1.96E+01	5.02E+00 0.00E+00 0.00E+00
KR-83M	7.25E-07	8.81E-09	2.59E+03	0.00E+00 0.00E+00	0.00E+00 9.38E-04	5.87E-03 0.00E+00 0.00E+00
KR-85M	3.08E-06	3.75E-08	9.94E+03	0.00E+00 0.00E+00	0.00E+00 1.12E-01	1.55E-01 0.00E+00 0.00E+00
KR-85	4.75E-07	5.77E-09	1.42E+03	0.00E+00 0.00E+00	0.00E+00 2.16E-04	2.11E-02 0.00E+00 0.00E+00
KR-87	4.77E-06	5.80E-08	1.85E+04	0.00E+00 0.00E+00	0.00E+00 1.85E+00	1.30E+00 0.00E+00 0.00E+00
KR-88	8.20E-06	9.97E-08	2.76E+04	0.00E+00 0.00E+00	0.00E+00 3.49E+00	6.28E-01 0.00E+00 0.00E+00

1.46E+02 2.70E+01 9.00E+00 0.00E+00 0.00E+00 0.00E+00

1 QDC CRDA, EAB, ALL REL GLAND: SIEMENS 60 GWD/MTU: 0 - 2 h

ANALYSIS BASED ON: 2561 MWT, 184500. FT3 CONT CENTER VOLUME, 58300. FT3 CONTROL ROOM VOLUME, 30.31 FT EFF RADIUS  
 1. FT3 SPRAYED VOL, 278000. FT3 UNSPRAYED VOL, 1. CFM MIXING, 00.00 PCT REL TO  
 SPRAYED VOL

AT 2.000 HOURS: X/Q(SITE)= .23E-04 SEC/M3 PRIMARY LEAK RATE=\*\*\*\*\* PERCENT/DAY CONTROL ROOM INTAKE=  
 .0 CFM X/Q CONT ROOM= .00E+00 SEC/M3 SEC RELEASE RATE= .86E+05 VOL/DAY PCT PRI LKG TO ATM =  
 00.00

ISOTOPE	ACTIVITY (CURIES)			CONTROL ROOM			SITE BOUNDARY DOSES (REM)			CONTROL ROOM DOSES (REM)		
	PRIMARY	SECONDARY	RELEASE	(CURIES)	(UCI/CM3)	THYROID	WH BODY	BETA	THYROID	WH BODY	BETA	
ELEMENTAL												
I-131	1.19E-35	1.45E-37	1.78E-07	0.00E+00	0.00E+00	2.10E-09	3.79E-13	1.85E-13	0.00E+00	0.00E+00	0.00E+00	
I-132	9.19E-36	1.12E-37	2.13E-07	0.00E+00	0.00E+00	9.08E-11	2.93E-12	5.04E-13	0.00E+00	0.00E+00	0.00E+00	
I-133	2.00E-35	2.43E-37	3.11E-07	0.00E+00	0.00E+00	9.91E-10	8.52E-13	6.95E-13	0.00E+00	0.00E+00	0.00E+00	
I-134	4.83E-36	5.87E-38	2.33E-07	0.00E+00	0.00E+00	4.65E-11	2.60E-12	5.61E-13	0.00E+00	0.00E+00	0.00E+00	
I-135	1.52E-35	1.85E-37	2.63E-07	0.00E+00	0.00E+00	2.60E-10	2.69E-12	4.29E-13	0.00E+00	0.00E+00	0.00E+00	
PARTICULATE												
I-131	6.54E-37	7.96E-39	9.75E-09	0.00E+00	0.00E+00	1.15E-10	2.08E-14	1.02E-14	0.00E+00	0.00E+00	0.00E+00	
I-132	5.05E-37	6.14E-39	1.17E-08	0.00E+00	0.00E+00	4.99E-12	1.61E-13	2.77E-14	0.00E+00	0.00E+00	0.00E+00	
I-133	1.10E-36	1.33E-38	1.71E-08	0.00E+00	0.00E+00	5.45E-11	4.68E-14	3.82E-14	0.00E+00	0.00E+00	0.00E+00	
I-134	2.66E-37	3.23E-39	1.28E-08	0.00E+00	0.00E+00	2.56E-12	1.43E-13	3.08E-14	0.00E+00	0.00E+00	0.00E+00	
I-135	8.37E-37	1.02E-38	1.45E-08	0.00E+00	0.00E+00	1.43E-11	1.48E-13	2.35E-14	0.00E+00	0.00E+00	0.00E+00	
ORGANIC												
I-131	5.24E-37	6.36E-39	7.80E-09	0.00E+00	0.00E+00	9.22E-11	1.66E-14	8.13E-15	0.00E+00	0.00E+00	0.00E+00	
I-132	4.04E-37	4.91E-39	9.35E-09	0.00E+00	0.00E+00	3.99E-12	1.29E-13	2.22E-14	0.00E+00	0.00E+00	0.00E+00	
I-133	8.77E-37	1.07E-38	1.37E-08	0.00E+00	0.00E+00	4.36E-11	3.74E-14	3.05E-14	0.00E+00	0.00E+00	0.00E+00	
I-134	2.12E-37	2.58E-39	1.03E-08	0.00E+00	0.00E+00	2.05E-12	1.14E-13	2.47E-14	0.00E+00	0.00E+00	0.00E+00	
I-135	6.70E-37	8.14E-39	1.16E-08	0.00E+00	0.00E+00	1.14E-11	1.18E-13	1.88E-14	0.00E+00	0.00E+00	0.00E+00	
NOBLE GASES												
XE-131M	1.11E-35	1.35E-37	1.65E-07	0.00E+00	0.00E+00	0.00E+00	2.09E-14	1.18E-13	0.00E+00	0.00E+00	0.00E+00	
XE-133M	5.63E-35	6.85E-37	8.51E-07	0.00E+00	0.00E+00	0.00E+00	1.61E-13	6.98E-13	0.00E+00	0.00E+00	0.00E+00	
XE-133	2.34E-33	2.84E-35	3.49E-05	0.00E+00	0.00E+00	0.00E+00	6.03E-10	2.70E-11	0.00E+00	0.00E+00	0.00E+00	
XE-135M	3.06E-36	3.72E-38	2.33E-06	0.00E+00	0.00E+00	0.00E+00	5.64E-12	1.19E-12	0.00E+00	0.00E+00	0.00E+00	
XE-135	5.03E-34	6.11E-36	8.34E-06	0.00E+00	0.00E+00	0.00E+00	1.18E-11	1.42E-11	0.00E+00	0.00E+00	0.00E+00	
XE-138	1.94E-35	2.36E-37	9.64E-06	0.00E+00	0.00E+00	0.00E+00	1.59E-10	4.08E-11	0.00E+00	0.00E+00	0.00E+00	
KR-83M	2.84E-35	3.45E-37	7.27E-07	0.00E+00	0.00E+00	0.00E+00	2.09E-14	1.31E-13	0.00E+00	0.00E+00	0.00E+00	
KR-85M	1.66E-34	2.02E-36	3.11E-06	0.00E+00	0.00E+00	0.00E+00	2.79E-12	3.83E-12	0.00E+00	0.00E+00	0.00E+00	
KR-85	3.24E-35	3.94E-37	4.81E-07	0.00E+00	0.00E+00	0.00E+00	5.81E-15	5.67E-13	0.00E+00	0.00E+00	0.00E+00	
KR-87	1.43E-34	1.74E-36	4.77E-06	0.00E+00	0.00E+00	0.00E+00	3.77E-11	2.65E-11	0.00E+00	0.00E+00	0.00E+00	
KR-88	3.86E-34	4.69E-36	8.25E-06	0.00E+00	0.00E+00	0.00E+00	8.27E-11	1.49E-11	0.00E+00	0.00E+00	0.00E+00	
							3.83E-09	3.16E-10	1.32E-10	0.00E+00	0.00E+00	0.00E+00
TOTAL DOSES 0-30 DAYS							4.69E+02	8.90E+01	2.95E+01	0.00E+00	0.00E+00	0.00E+00

1

QDC CRDA, EAB, ALL REL GLAND: SIEMENS 60 GWD/MTU: 0 - 2 h

ISOTOPE	ACTIVITY RELEASED (CURIES)	
	2. HRS	
ELEMENTAL		
I-131	1.69E+03	1.69E+03
I-132	2.36E+03	2.36E+03
I-133	3.00E+03	3.00E+03
I-134	3.35E+03	3.35E+03
I-135	2.64E+03	2.64E+03
PARTICULATE		
I-131	9.29E+01	9.29E+01
I-132	1.30E+02	1.30E+02
I-133	1.65E+02	1.65E+02
I-134	1.84E+02	1.84E+02
I-135	1.45E+02	1.45E+02
ORGANIC		
I-131	7.43E+01	7.43E+01
I-132	1.04E+02	1.04E+02
I-133	1.32E+02	1.32E+02
I-134	1.47E+02	1.47E+02
I-135	1.16E+02	1.16E+02
NOBLE GASES		
XE-131M	1.57E+03	1.57E+03

XE-133M	8.14E+03	8.14E+03
XE-133	3.33E+05	3.33E+05
XE-135M	8.74E+04	8.74E+04
XE-135	8.25E+04	8.25E+04
XE-138	3.12E+05	3.12E+05
KR-83M	8.37E+03	8.37E+03
KR-85M	3.21E+04	3.21E+04
KR-85	4.57E+03	4.57E+03
KR-87	6.01E+04	6.01E+04
KR-88	8.92E+04	8.92E+04

END EXECUTION DATE: 11/18/1999  
END EXECUTION TIME: 17:46:00.68