

ELECTRICAL POWER SYSTEMS

SURVEILLANCE REQUIREMENTS

4.8.1.1.1 Each of the above required independent circuits between the offsite transmission network and the Onsite Class 1E Distribution System shall be:

- a. Determined OPERABLE at least once per 7 days by verifying correct breaker alignments, indicated power availability, and
- b. Demonstrated OPERABLE at least once per 18 months during shutdown by transferring the unit power supply from the normal circuit to each of the alternate circuits.

4.8.1.1.2 \ Each standby diesel generator shall be demonstrated OPERABLE:⁽²⁾⁽¹¹⁾ |

- a. In accordance with the frequency specified in Table 4.8-1 on a STAGGERED TEST BASIS by:
 - 1) Verifying the fuel level in its associated fuel tank,
 - 2) Verifying the diesel starts from standby condition and accelerates to 600 rpm (nominal) in less than or equal to 10 seconds.⁽³⁾ The generator voltage and frequency shall be 4160 ± 416 volts and 60 ± 1.2 Hz within 10 seconds⁽³⁾ after the start signal. The diesel generator shall be started for this test by using one of the following signals:
 - a) Manual, or
 - b) Simulated loss-of-offsite power by itself, or
 - c) Simulated loss-of-offsite power in conjunction with a Safety Injection test signal, or
 - d) A Safety Injection test signal by itself.
 - 3) Verifying the generator is synchronized, loaded to 5000 to 5500 kW, and operates with a load of 5000 to 5500 kW for at least 60 minutes,⁽⁴⁾⁽⁶⁾ and
 - 4) Verifying the standby diesel generator is aligned to provide standby power to the associated emergency busses.
- b. At least once per 31 days and after each operation of the diesel where the period of operation was greater than or equal to 1 hour by checking for and removing accumulated water from its associated fuel tank;
- c. Maintain properties of new and stored fuel oil in accordance with the Fuel Oil Monitoring Program.

ELECTRICAL POWER SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

- d. Deleted
- e. At least once per 18 months, during shutdown, by:
 - 1) Deleted
 - 2) Verifying the generator capability to reject a load of greater than or equal to 785.3 kW while maintaining voltage at 4160 ± 416 volts and frequency at 60 ± 4.5 Hz; ⁽⁴⁾⁽⁵⁾
 - 3) Verifying the generator capability to reject a load of 5500 kW without tripping. The generator voltage shall not exceed 5262 volts during and following the load rejection; ⁽⁴⁾⁽⁵⁾
 - 4) Simulating a loss-of-offsite power by itself, and:
 - a) Verifying deenergization of the ESF busses and load shedding from the ESF busses, and
 - b) Verifying the diesel starts on the auto-start signal within 10 seconds, energizes the auto-connected shutdown loads through the load sequencer and operates for greater than or equal to 5 minutes while its generator is loaded with the shutdown loads. After energization, the steady-state voltage and frequency of the ESF busses shall be maintained at 4160 ± 416 volts and 60 ± 1.2 Hz during this test.
 - 5) Verifying that on a Safety Injection test signal, without loss-of-offsite power, the diesel generator starts on the auto-start signal and operates on standby for greater than or equal to 5 minutes. The generator voltage and frequency shall be 4160 ± 416 volts and 60 ± 1.2 Hz within 10 seconds after the auto-start signal; the steady-state generator voltage and frequency shall be maintained within these limits during this test;
 - 6) Simulating a loss-of-offsite power in conjunction with a Safety Injection test signal, and:
 - a) Verifying deenergization of the ESF busses and load shedding from the ESF busses;
 - b) Verifying the diesel starts on the auto-start signal within 10 seconds, energizes the auto-connected ESF (accident) loads through the load sequencer and operates for greater than or equal to 5 minutes while its generator

ELECTRICAL POWER SYSTEMS

BASES

A.C. SOURCES, D.C. SOURCES, and ONSITE POWER DISTRIBUTION (Continued)

For purposes of this testing, the DGs are started from standby conditions. Standby condition for a DG mean that the diesel engine coolant and oil are being continuously circulated and temperature is being maintained consistent with manufacturer recommendations.

In order to reduce stress and wear on diesel engines, some manufacturers recommend a modified start in which the starting speed of DGs is limited, warmup is limited to this lower speed, and the DGs are gradually accelerated to synchronous speed prior to loading. In addition, the modified start may involve reduced fuel (load limit). These start procedures are the intent of Note 3, which is only applicable when such modified start procedures are recommended by the manufacturer.

Once per 184 days the DG starts from standby conditions and achieves required voltage and frequency within 10 seconds. The 10 second start requirement supports the assumptions of the design basis LOCA analysis in the FSAR.

The 10 second start requirement is not applicable (see Note 3) when a modified start procedure as described above is used.

The normal 31 day Frequency for SR 3.8.1.2 (see Table 4.8-1, "Diesel Generator Test Schedule," in the accompanying LCO) is consistent with Regulatory Guide 1.108. The 184 day Frequency in Note 3 is a reduction in cold testing consistent with Generic Letter 84-15. These Frequencies provide adequate assurance of DG OPERABILITY, while minimizing degradation resulting from testing.

SR 4.8.1.1.2.a.3

This Surveillance verifies that the DGs are capable of synchronizing with the offsite electrical system and accepting loads greater than or equal to the equivalent of the maximum expected accident loads. A minimum run time of 60 minutes is required to stabilize engine temperature, while minimizing the time that the DG is connected to the offsite source.

The load band is provided to avoid routine overloading of the DG. Routine overloading may result in more frequent teardown inspections in accordance with vendor recommendations in order to maintain DG OPERABILITY.

This SR is modified by two Notes. Note 4 indicates that diesel engine runs for this Surveillance may include gradual loading, as recommended by the manufacturer, so that mechanical stress and wear on the diesel engine are minimized. Note 6 states that momentary transients, because of changing bus loads, do not invalidate this test.

A successful DG start under SR 4.8.1.1.2.a.2 must precede this test to credit satisfactory performance.

SOUTH TEXAS - UNITS 1 & 2

B 3/4 8-7

Unit 1 - Amendment No. 68

Unit 2 - Amendment No. 57

ELECTRICAL POWER SYSTEMS

BASES

A.C. SOURCES, D.C. SOURCES, and ONSITE POWER DISTRIBUTION (Continued)

SR 4.8.1.1.2.b

Microbiological fouling is a major cause of fuel oil degradation. There are numerous bacteria that can grow in fuel oil and cause fouling, but all must have a water environment in order to survive. Removal of water from the fuel oil tanks once every 31 days eliminates the necessary environment for bacterial survival. This is the most effective means of controlling microbiological fouling. In addition, it eliminates the potential for water entrainment in the fuel oil during DG operation. Water may come from any of several sources, including condensation, ground water, rain water, contaminated fuel oil, and breakdown of the fuel oil by bacteria. Frequent checking for and removal of accumulated water minimizes fouling and provides data regarding the watertight integrity of the fuel oil system. The Surveillance Frequencies are established by Regulatory Guide 1.137. This SR is for preventative maintenance. The presence of water does not necessarily represent failure of the SR, provided the accumulated water is removed during the performance of this Surveillance.

SR 4.8.1.1.2.c

The requirements will be controlled and administered by the Diesel Fuel Oil Testing Program located in section 6.8.3 of Administrative Controls.

SR 4.8.1.1.2.e.1

Deleted

SR 4.8.1.1.2.e.2

Each DG is provided with an engine overspeed trip to prevent damage to the engine. Recovery from the transient caused by the loss of a large load could cause diesel engine overspeed, which, if excessive, might result in a trip of the engine. This Surveillance demonstrates the DG load response characteristics and capability to reject the largest single load (785.3 kW) without exceeding predetermined voltage and frequency. The 18 month Frequency is consistent with the recommendation of Regulatory Guide 1.108.

This SR is modified by two Notes. Note 4 indicates that diesel engine runs for this Surveillance may include gradual loading, as recommended by the manufacturer, so that mechanical stress and wear on the diesel engine are minimized. Note 5 allows the diesel start for this surveillance to be a modified start as stated in SR 4.8.1.1.2.a.2.