



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

PP&L, INC.

ALLEGHENY ELECTRIC COOPERATIVE, INC.

DOCKET NO. 50-387

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 186
License No. NPF-14

1. The Nuclear Regulatory Commission (the Commission or the NRC) having found that:
 - A. The application for the amendment filed by PP&L, Inc., dated March 12, 1999, as supplemented by letter dated November 1, 1999, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of the Facility Operating License No. NPF-14 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 186 and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. PP&L shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance and shall be implemented upon startup from the Unit 1 eleventh refueling and inspection outage currently scheduled for spring 2000.

FOR THE NUCLEAR REGULATORY COMMISSION



Marsha Gamberoni , Acting Chief, Section 1
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical
Specifications

Date of Issuance: December 30, 1999

ATTACHMENT TO LICENSE AMENDMENT NO. 186

FACILITY OPERATING LICENSE NO. NPF-14

DOCKET NO. 50-387

Replace the following pages of the Appendix A Technical Specifications with the attached revised pages. The revised pages are identified by amendment number and contain marginal lines indicating the areas of change.

REMOVE

2.0-1
2.0-2
2.0-3
5.0-21
5.0-22
5.0-23
5.0-24
5.0-25
B 2.0-2
B 2.0-3
B 2.0-4
B 2.0-5
B 2.0-6
B 3.2-2
B 3.2-4
B 3.2-5
B 3.2-6
B 3.2-9
B 3.2-11
B 3.2-13
B 3.2-16
B 3.2-19

INSERT

2.0-1
2.0-2
2.0-3
5.0-21
5.0-22
5.0-23
5.0-24
5.0-25
B 2.0-2
B 2.0-3
B 2.0-4
B 2.0-5
B 2.0-6
B 3.2-2
B 3.2-4
B 3.2-5
B 3.2-6
B 3.2-9
B 3.2-11
B 3.2-13
B 3.2-16
B 3.2-19

2.0 SAFETY LIMITS (SLs)

2.1 SLs

2.1.1 Reactor Core SLs

2.1.1.1 With the reactor steam dome pressure < 785 psig or core flow < 10 million lbm/hr:

THERMAL POWER shall be \leq 25% RTP.

2.1.1.2 With the reactor steam dome pressure \geq 785 psig and core flow \geq 10 million lbm/hr:

MCPR shall be \geq 1.11 for two recirculation loop operation or \geq 1.13 for single recirculation loop operation.

2.1.1.3 Reactor vessel water level shall be greater than the top of active irradiated fuel.

2.1.2 Reactor Coolant System Pressure SL

Reactor steam dome pressure shall be \leq 1325 psig.

2.2 SL Violations

With any SL violation, the following actions shall be completed within 2 hours:

2.2.1 Restore compliance with all SLs; and

2.2.2 Insert all insertable control rods.

THIS PAGE INTENTIONALLY LEFT BLANK

Figure 2.1.1.2-1

THIS PAGE INTENTIONALLY LEFT BLANK

Figure 2.1.1.2-2

5.6 Reporting Requirements (continued)

5.6.4 Monthly Operating Reports

Routine reports of operating statistics and shutdown experience, including documentation of all challenges to the main steam safety/relief valves, shall be submitted on a monthly basis no later than the 15th of each month following the calendar month covered by the report.

5.6.5 CORE OPERATING LIMITS REPORT (COLR)

- a. Core operating limits shall be established prior to each reload cycle, or prior to any remaining portion of a reload cycle, and shall be documented in the COLR for the following:
1. The Average Planar Linear Heat Generation Rate for Specification 3.2.1;
 2. The Minimum Critical Power Ratio for Specification 3.2.2;
 3. The Linear Heat Generation Rate for Specification 3.2.3;
 4. The Average Power Range Monitor (APRM) Gain and Setpoints for Specification 3.2.4; and
 5. The Shutdown Margin for Specification 3.1.1.
- b. The analytical methods used to determine the core operating limits shall be those previously reviewed and approved by the NRC, specifically those described in the following documents:
1. PL-NF-90-001-A, "Application of Reactor Analysis Methods for BWR Design and Analysis," July, 1992.

(continued)

5.6 Reporting Requirements

5.6.5 COLR (continued)

2. XN-NF-80-19(P)(A), Volume 4, Revision 1. "Exxon Nuclear Methodology for Boiling Water Reactors: Application of the ENC Methodology to BWR Reloads." Exxon Nuclear Company, Inc. June 1986.
3. XN-NF-85-67(P)(A), Revision 1. "Generic Mechanical Design for Exxon Nuclear Jet Pump BWR Reload Fuel." Exxon Nuclear Company, Inc., September 1986.
4. XN-NF-80-19(A), Volume 1, and Volume 1 Supplements 1 and 2 (March 1983), and Volume 1 Supplement 3 (November 1990), "Exxon Nuclear Methodology for Boiling Water Reactors: Neutronic Methods for Design and Analysis," Exxon Nuclear Company, Inc.
5. ANF-524(P)(A), Revision 2 and Supplement 1, Revision 2. "Advanced Nuclear Fuels Corporation Critical Power Methodology for Boiling Water Reactors", November 1990.
6. ANF-1125(P)(A) and ANF-1125(P)(A), Supplement 1, "ANFB Critical Power Correlation", April 1990.
7. NEDC-32071P, "SAFER/GESTR-LOCA Loss of Coolant Accident Analysis," GE Nuclear Energy, May 1992.
8. NE-092-001A, Revision 1, "Licensing Topical Report for Power Uprate With Increased Core Flow," Pennsylvania Power & Light Company, December 1992 and NRC SER (November 30, 1993).
9. PL-NF-90-001, Supplement 1-A, "Application of Reactor Analysis Methods for BWR Design and Analysis: Loss of Feedwater Heating Changes and Use of RETRAN MOD 5.1," August 1995.
10. PL-NF-94-005-P-A, "Technical Basis for SPC 9x9-2 Extended Fuel Exposure at Susquehanna SES", January, 1995.

(continued)

5.6 Reporting Requirements

5.6.5 COLR (continued)

11. PL-NF-90-001, Supplement 2-A, "Application of Reactor Analysis Methods for BWR Design and Analysis: CASMO-3G Code and ANFB Critical Power Correlation", July 1996.
 12. ANF-89-98(P)(A) Revision 1 and Revision 1 Supplement 1, "Generic Mechanical Design Criteria for BWR Fuel Designs," Advanced Nuclear Fuels Corporation, May 1995.
 13. ANF-91-048(P)(A), "Advanced Nuclear Fuels Corporation Methodology for Boiling Water Reactors EXEM BWR Evaluation Model," January 1993.
 14. XN-NF-80-19(P)(A), Volumes 2, 2A, 2B, and 2C "Exxon Nuclear Methodology for Boiling Water Reactors: EXEM BWR ECCS Evaluation Model," September 1982.
 15. XN-NF-80-19(P)(A), Volumes 3 Revision 2 "Exxon Nuclear Methodology for Boiling Water Reactors Thermex: Thermal Limits Methodology Summary Description," January 1987.
 16. XN-NF-79-71(P)(A) Revision 2, Supplements 1, 2, and 3, "Exxon Nuclear Plant Transient Methodology for Boiling Water Reactors," March 1986.
 17. EMF-1997(P)(A) Revision 0, "ANFB-10 Critical Power Correlation," July 1998, and EMF-1997(P)(A) Supplement 1 Revision 0, "ANFB-10 Critical Power Correlation : High Local Peaking Results," July 1998.
- c. The core operating limits shall be determined such that all applicable limits (e.g., fuel thermal mechanical limits, core thermal hydraulic limits, Emergency Core Cooling Systems (ECCS) limits, nuclear limits such as SDM, transient analysis limits, and accident analysis limits) of the safety analysis are met.
- d. The COLR, including any midcycle revisions or supplements, shall be provided upon issuance for each reload cycle to the NRC.

(continued)

5.6 Reporting Requirements

THIS PAGE INTENTIONALLY LEFT BLANK

(continued)

5.6 Reporting Requirements

THIS PAGE INTENTIONALLY LEFT BLANK

(continued)

BASES

BACKGROUND
(continued)

Operation above the boundary of the nucleate boiling regime could result in excessive cladding temperature because of the onset of transition boiling and the resultant sharp reduction in heat transfer coefficient. Inside the steam film, high cladding temperatures are reached, and a cladding water (zirconium water) reaction may take place. This chemical reaction results in oxidation of the fuel cladding to a structurally weaker form. This weaker form may lose its integrity, resulting in an uncontrolled release of activity to the reactor coolant.

APPLICABLE
SAFETY ANALYSES

The fuel cladding must not sustain damage as a result of normal operation and AOOs. The reactor core SLs are established to preclude violation of the fuel design criterion that an MCPR limit is to be established, such that at least 99.9% of the fuel rods in the core would not be expected to experience the onset of transition boiling.

The Reactor Protection System setpoints (LCO 3.3.1.1, "Reactor Protection System (RPS) Instrumentation"), in combination with the other LCOs, are designed to prevent any anticipated combination of transient conditions for Reactor Coolant System water level, pressure, and THERMAL POWER level that would result in reaching the MCPR limit.

2.1.1.1 Fuel Cladding Integrity

The use of the ANFB (Reference 2) and ANFB-10 (Reference 4) correlations is valid for critical power calculations at pressures > 600 psia for ANFB and > 571 psia for ANFB-10 and bundle mass fluxes > 0.1×10^6 lb/hr-ft² for ANFB and > 0.115×10^6 lb/hr-ft² for ANFB-10. For operation at low pressures or low flows, the fuel cladding integrity SL is established by a limiting condition on core THERMAL POWER, with the following basis:

Provided that the water level in the vessel downcomer is maintained above the top of the active fuel, natural circulation is sufficient to ensure a minimum bundle flow for all fuel assemblies that have a relatively high power and potentially can approach a critical heat flux condition. For the SPC 9x9 fuel design, the

(continued)

BASES

APPLICABLE
SAFETY ANALYSES

2.1.1.1 Fuel Cladding Integrity (continued)

minimum bundle flow is approximately 30×10^3 lb/hr. For the SPC ATRIUM-10 design, the minimum bundle flow is $> 28 \times 10^3$ lb/hr. For both the SPC 9x9-2 and ATRIUM-10 fuel designs, the coolant minimum bundle flow and maximum area are such that the mass flux is always $> .25 \times 10^6$ lb/hr-ft². Full scale critical power test data taken from various SPC and GE fuel designs at pressures from 14.7 psia to 1400 psia indicate the fuel assembly critical power at 0.25×10^6 lb/hr-ft² is approximately 3.35 Mwt. At 25% RTP, a bundle power of approximately 3.35 Mwt corresponds to a bundle radial peaking factor of approximately 3.0, which is significantly higher than the expected peaking factor. Thus, a THERMAL POWER limit of 25% RTP for reactor pressures < 785 psig is conservative.

2.1.1.2 MCPR

The MCPR SL ensures sufficient conservatism in the operating MCPR limit that, in the event of an AOO from the limiting condition of operation, at least 99.9% of the fuel rods in the core would be expected to avoid boiling transition. The margin between calculated boiling transition (i.e., MCPR = 1.00) and the MCPR SL is based on a detailed statistical procedure that considers the uncertainties in monitoring the core operating state. One specific uncertainty included in the SL is the uncertainty in the ANFB critical power correlation. Reference 2 describes the methodology used in determining the MCPR SL.

The ANFB and ANFB-10 critical power correlations are based on a significant body of practical test data. As long as the core pressure and flow are within the range of validity of the correlations (refer to Section B.2.1.1.1), the assumed reactor conditions used in defining the SL introduce conservatism into the limit because bounding high radial power factors and bounding flat local peaking distributions are used to estimate the number of rods in boiling transition. These conservatisms and the inherent accuracy of the ANFB and ANFB-10 correlations provide a reasonable degree of assurance that during sustained operation at the MCPR SL there would be no transition boiling in the core.

APPLICABLE

2.1.1.2 MCPR (continued)

(continued)

BASES

SAFETY ANALYSES

If boiling transition were to occur, there is reason to believe that the integrity of the fuel would not be compromised.

Significant test data accumulated by the NRC and private organizations indicate that the use of a boiling transition limitation to protect against cladding failure is a very conservative approach. Much of the data indicate that BWR fuel can survive for an extended period of time in an environment of boiling transition.

SPC 9x9-2 fuel is monitored using the ANFB Critical Power Correlation, and the SPC Atrium -10 fuel is monitored using the ANFB-10 Critical Power Correlation. The effects of channel bow on MCPR are explicitly included in the calculation of the MCPR SL. Explicit treatment of channel bow in the MCPR SL addresses the concerns of NRC Bulletin No. 90-02 entitled "Loss of Thermal Margin Caused by Channel Box Bow."

Monitoring required for compliance with the MCPR SL is specified in LCO 3.2.2, Minimum Critical Power Ratio.

2.1.1.3 Reactor Vessel Water Level

During MODES 1 and 2 the reactor vessel water level is required to be above the top of the active fuel to provide core cooling capability. With fuel in the reactor vessel during periods when the reactor is shut down, consideration must be given to water level requirements due to the effect of decay heat. If the water level should drop below the top of the active irradiated fuel during this period, the ability to remove decay heat is reduced. This reduction in cooling capability could lead to elevated cladding temperatures and clad perforation in the event that the water level becomes $< 2/3$ of the core height. The reactor vessel water level SL has been established at the top of the active irradiated fuel to provide a point that can be

APPLICABLE 2.1.1.3 Reactor Vessel Water Level (continued)

(continued)

BASES

SAFETY ANALYSES

monitored and to also provide adequate margin for effective action.

SAFETY LIMITS

The reactor core SLs are established to protect the integrity of the fuel clad barrier to the release of radioactive materials to the environs. SL 2.1.1.1 and SL 2.1.1.2 ensure that the core operates within the fuel design criteria. SL 2.1.1.3 ensures that the reactor vessel water level is greater than the top of the active irradiated fuel in order to prevent elevated clad temperatures and resultant clad perforations.

APPLICABILITY

SLs 2.1.1.1, 2.1.1.2, and 2.1.1.3 are applicable in all MODES.

SAFETY LIMIT VIOLATIONS

Exceeding an SL may cause fuel damage and create a potential for radioactive releases in excess of 10 CFR 100, "Reactor Site Criteria," limits (Ref. 3). Therefore, it is required to insert all insertable control rods and restore compliance with the SLs within 2 hours. The 2 hour Completion Time ensures that the operators take prompt remedial action and also ensures that the probability of an accident occurring during this period is minimal.

REFERENCES

1. 10 CFR 50, Appendix A, GDC 10.
2. ANF 524 (P)(A), Revision 2, "Critical Power Methodology for Boiling Water Reactors," Supplement 1 Revision 2 and Supplement 2, November 1990.
3. 10 CFR 100.
4. EMF-1997 (P)(A) Revision 0, "ANFB-10 Critical Power Correlation," July 1998 and EMF-1997 (P)(A) Supplement 1 Revision 0, "ANFB-10 Critical Power Correlation : High Local Peaking Results," July 1998.

(continued)

BASES

THIS PAGE INTENTIONALLY LEFT BLANK

BASES

APPLICABLE
SAFETY ANALYSES
(continued)

Suppression Pool Cooling Mode, and Single Loop Operation (SLO)). LOCA analyses were performed for the regions of the power/flow map bounded by the 100% rod line and the APRM rod block line (i.e., the ELLA region). The ELLA region is analyzed to determine whether an APLHGR multiplier as a function of core flow is required. The results of the analysis demonstrate the PCTs are within the 10 CFR 50.46 limit, and that APLHGR multipliers as a function of core flow are not required.

The GE and SPC LOCA analyses consider the delay in Low Pressure Coolant Injection (LPCI) availability when the unit is operating in the Suppression Pool Cooling Mode. The delay in LPCI availability is due to the time required to realign valves from the Suppression Pool Cooling Mode to the LPCI mode. The results of the analyses demonstrate that the PCTs are within the 10 CFR 50.46 limit.

Finally, the GE and SPC LOCA analyses were performed for Single-Loop Operation. The results of the SPC analysis for ATRIUM™-10 fuel shows that an APLHGR limit which is 0.8 times the two-loop APLHGR limit meets the 10 CFR 50.46 acceptance criteria, and that the PCT is less than the limiting two-loop PCT. The results of the GE analysis shows that the two loop APLHGR limit for 9x9-2 fuel is acceptable in SLO.

The APLHGR satisfies Criterion 2 of the NRC Policy Statement (Ref. 10).

LCO

The APLHGR limits specified in the COLR are the result of the DBA analyses.

APPLICABILITY

The APLHGR limits are primarily derived from LOCA analyses that are assumed to occur at high power levels. Design calculations and operating experience have shown that as power is reduced, the margin to the required APLHGR limits

(continued)

BASES

SURVEILLANCE
REQUIREMENTS

SR 3.2.1.1 (continued)

given the large inherent margin to operating limits at low power levels and because the APLHGRs must be calculated prior to exceeding 50% RTP.

REFERENCES

1. NEDC-32071 (P), "Susquehanna Steam Electric Station Units 1 and 2: SAFER/GESTR Loss of Coolant Accident Analysis," May 1992.
 2. Letter from C. O. Thomas (NRC) to J. F. Quirk (GE), "Acceptance for referencing of Licensing Topical Report NEDE-23785, Revision 1, Volume III(P)," 'The GESTR-LOCA and SAFER Models for the Evaluation of Loss of Coolant Accident,' June 1984.
 3. ANF-91-048(P)(A), "Advanced Nuclear Fuels Corporation Methodology for Boiling Water Reactors EXEM BWR Evaluation Model," January 1993.
 4. ANF-CC-33(P)(A) Supplement 2, "HUXY: A Generalized Multirod Heatup Code with 10CFR50 Appendix K Heatup Option," January 1991.
 5. XN-CC-33(P)(A) Revision 1, "HUXY: A Generalized Multirod Heatup Code with 10CFR50 Appendix K Heatup Option Users Manual," November 1975.
 6. XN-NF-80-19(P)(A), Volumes 2, 2A, 2B, and 2C "Exxon Nuclear Methodology for Boiling Water Reactors: EXEM BWR ECCS Evaluation Model," September 1982.
 7. FSAR, Chapter 4.
 8. FSAR, Chapter 6.
 9. FSAR, Chapter 15.
 10. Final Policy Statement on Technical Specifications Improvements, July 22, 1993 (58 FR 39132).
-

B 3.2 POWER DISTRIBUTION LIMITS

B 3.2.2 MINIMUM CRITICAL POWER RATIO (MCPR)

BASES

BACKGROUND

MCPR is a ratio of the fuel assembly power that would result in the onset of boiling transition to the actual fuel assembly power. The MCPR Safety Limit (SL) is set such that 99.9% of the fuel rods avoid boiling transition if the limit is not violated (refer to the Bases for SL 2.1.1.2). The operating limit MCPR is established to ensure that no fuel damage results during anticipated operational occurrences (AOOs). Although fuel damage does not necessarily occur if a fuel rod actually experienced boiling transition (Ref. 1), the critical power at which boiling transition is calculated to occur has been adopted as a fuel design criterion.

The onset of transition boiling is a phenomenon that is readily detected during the testing of various fuel bundle designs. Based on these experimental data, correlations have been developed to predict critical bundle power (i.e., the bundle power level at the onset of transition boiling) for a given set of plant parameters (e.g., reactor vessel pressure, flow, and subcooling). Because plant operating conditions and bundle power levels are monitored and determined relatively easily, monitoring the MCPR is a convenient way of ensuring that fuel failures due to inadequate cooling do not occur.

APPLICABLE
SAFETY ANALYSES

The analytical methods and assumptions used in evaluating the AOOs to establish the operating limit MCPR are presented in References 2 through 9. To ensure that the MCPR SL is not exceeded during any transient event that occurs with moderate frequency, limiting transients have been analyzed to determine the largest reduction in critical power ratio (CPR). The types of transients evaluated are loss of flow, increase in pressure and power, positive reactivity insertion, and coolant temperature decrease. The limiting transient yields the largest change in CPR (Δ CPR). When the largest Δ CPR is added to the MCPR SL, the required operating limit MCPR is obtained.

The MCPR operating limits derived from the transient analysis are dependent on the operating core flow and power

(continued)

BASES

APPLICABLE
SAFETY ANALYSES
(continued)

state to ensure adherence to fuel design limits during the worst transient that occurs with moderate frequency. These analyses may also consider other combinations of plant conditions (i.e., control rod scram speed, bypass valve performance, EOC-RPT, cycle exposure, etc.). Flow dependent MCPR limits are determined by analysis of slow flow runout transients using the methodology of Reference 2.

The MCPR satisfies Criterion 2 of the NRC Policy Statement (Ref. 10).

LCO

The MCPR operating limits specified in the COLR are the result of the Design Basis Accident (DBA) and transient analysis. The operating limit MCPR is determined by the larger of the flow dependent MCPR and power dependent MCPR limits.

APPLICABILITY

The MCPR operating limits are primarily derived from transient analyses that are assumed to occur at high power levels. Below 25% RTP, the reactor is operating at a minimum recirculation pump speed and the moderator void ratio is small. Surveillance of thermal limits below 25% RTP is unnecessary due to the large inherent margin that ensures that the MCPR SL is not exceeded even if a limiting transient occurs. Studies of the variation of limiting transient behavior have been performed over the range of power and flow conditions. These studies encompass the range of key actual plant parameter values important to typically limiting transients. The results of these studies demonstrate that a margin is expected between performance and the MCPR requirements, and that margins increase as power is reduced to 25% RTP. This trend is expected to

(continued)

BASES

REFERENCES
(continued)

3. PL-NF-87-001-A, "Qualification of Steady State core Physics Methods for BWR Design and Analysis." April 28, 1988.
 4. PL-NF-89-005-A, "Qualification of Transient Analysis Methods for BWR Design and Analysis." July 1992, including Supplements 1 and 2.
 5. XN-NF-80-19 (P)(A), Volume 4, Revision 1, "Exxon Nuclear Methodology for Boiling Water Reactors: Application of the ENC Methodology to BWR Reloads," Exxon Nuclear Company, June 1986.
 6. NE-092-001, Revision 1, "Susquehanna Steam Electric Station Units 1 & 2: Licensing Topical Report for Power Uprate with Increased Core flow," December 1992, and NRC Approval Letter: Letter from T. E. Murley (NRC) to R. G. Byram (PP&L), "Licensing Topical Report for Power Uprate With Increased Core Flow, Revision 0, Susquehanna Steam Electric Station, Units 1 and 2 (PLA-3788) (TAC Nos. M83426 and M83427)." November 30, 1993.
 7. EMF-1997 (P)(A) Revision 0, ANFB-10 Critical Power Correlation," July 1998, and EMF-1997 (P)(A) Supplement 1 Revision 0, "ANFB-10 Critical Power Correlation : High Local Peaking Results," July 1998.
 8. XN-NF-79-71(P)(A) Revision 2, Supplements 1, 2, and 3, "Exxon Nuclear Plant Transient Methodology for Boiling Water Reactors," March 1986.
 9. XN-NF-84-105(P)(A), Volume 1 and Volume 1 Supplements 1 and 2, "XCOBRA-T: A Computer Code for BWR Transient Thermal-Hydraulic Core Analysis," February 1987.
 10. Final Policy Statement on Technical Specifications Improvements, July 22, 1993 (58 FR 39132).
-

BASES

APPLICABLE
SAFETY ANALYSES
(continued)

Protection Against Power Transients (PAPT), defined in references 5 and 6, provides the acceptance criteria for LHGRs calculated in evaluation of the AOOs.

For SPC 9x9-2 fuel, there is a LHGR multiplier defined in the Core Operating Limits Report (COLR) for single recirculation loop operation. This multiplier ensures that the DBA LOCA will be less severe in single loop operation than in two loop operation.

The LHGR satisfies Criterion 2 of the NRC Policy Statement (Ref. 7).

LCO

The LHGR is a basic assumption in the fuel design analysis. The fuel has been designed to operate at rated core power with sufficient design margin to the LHGR calculated to cause a 1% fuel cladding plastic strain. The operating limit to accomplish this objective is specified in the COLR.

APPLICABILITY

The LHGR limits are derived from fuel design analysis that is limiting at high power level conditions. At core thermal power levels < 25% RTP, the reactor is operating with a substantial margin to the LHGR limits and, therefore, the Specification is only required when the reactor is operating at \geq 25% RTP.

ACTIONS

A.1

If any LHGR exceeds its required limit, an assumption regarding an initial condition of the fuel design analysis is not met. Therefore, prompt action should be taken to

(continued)

BASES

REFERENCES
(continued)

4. XN-NF 85-67(P)(A), Revision 1, "Generic Mechanical Design for Exxon Nuclear Jet Pump BWR Reload Fuel," Exxon Nuclear Company, Inc., September 1986.
 5. PL-NF-94-005-P-A, "Technical Basis for 9X9-2 Extended Fuel Exposure at Susquehanna SES," January 1995
 6. ANF-89-98(P)(A) Revision 1 and Revision 1 Supplement 1, "Generic Mechanical Design Criteria for BWR Fuel Designs," Advanced Nuclear Fuels Corporation, May 1995.
 7. Final Policy Statement on Technical Specifications Improvements, July 22, 1993 (58 FR 39132).
-
-

BASES

APPLICABLE
SAFETY ANALYSES
(continued)

(MCPR)." and LCO 3.2.3, "LINEAR HEAT GENERATION RATE (LHGR)." limit the initial margins to these operating limits at rated conditions so that specified acceptable fuel design limits are met during transients initiated from rated conditions. At initial power levels less than rated levels, the margin degradation of either the LHGR or the MCPR during a transient can be greater than at the rated condition event. This greater margin degradation during the transient is primarily offset by the larger initial margin to limits at the lower than rated power levels. However, power distributions can be hypothesized that would result in reduced margins to the pre-transient operating limit. When combined with the increased severity of certain transients at other than rated conditions, the SLs could be approached. At substantially reduced power levels, highly peaked power distributions could be obtained that could reduce thermal margins to the minimum levels required for transient events. To prevent or mitigate such situations, the MCPR margin degradation at reduced power and flow is factored into the power and flow dependent MCPR limits (LCO 3.2.2). For LHGR (Ref. 4 and 5), either the APRM gain is adjusted upward by the ratio of the core limiting MFLPD to the F RTP, or the flow biased APRM scram level is reduced by the ratio of F RTP to the core limiting MFLPD. The adjustment in the APRM gain can be performed provided it is during power ascension up to 90% of RATED THERMAL POWER, that the adjusted APRM reading does not exceed 100% of RATED THERMAL POWER, the required gain adjustment increment does not exceed 10% of RATED THERMAL POWER, and a notice of the adjustment is posted on the reactor control panel. Either of these adjustments effectively counters the increased severity of some events at other than rated conditions by proportionally increasing the APRM gain or proportionally lowering the flow biased APRM scram setpoints, dependent on the increased peaking that may be encountered.

The APRM gain and setpoints satisfy Criteria 2 and 3 of the NRC Policy Statement (Ref. 6).

(continued)

BASES

SURVEILLANCE
REQUIREMENTS

SR 3.2.4.1 and SR 3.2.4.2 (continued)

is operating within the assumptions of the safety analysis. These SRs are only required to determine the MFLPD and, assuming MFLPD is greater than FRTP, the appropriate gain or setpoint, and is not intended to be a CHANNEL FUNCTIONAL TEST for the APRM gain or flow biased neutron flux scram circuitry. The 24 hour Frequency of SR 3.2.4.1 is chosen to coincide with the determination of other thermal limits, specifically those for the APLHGR (LCO 3.2.1). The 24 hour Frequency is based on both engineering judgment and recognition of the slowness of changes in power distribution during normal operation. The 24 hour allowance after THERMAL POWER \geq 25% RTP is achieved is acceptable given the large inherent margin to operating limits at low power levels and because the MFLPD must be calculated prior to exceeding 50% RTP unless performed in the previous 24 hours. When MFLPD is greater than FRTP, SR 3.2.4.2 must be performed. The 12 hour Frequency of SR 3.2.4.2 requires a more frequent verification when MFLPD is greater than the fraction of rated thermal power (FRTP) because more rapid changes in power distribution are typically expected.

REFERENCES

1. 10 CFR 50, Appendix A, GDC 10, GDC 13, GDC 20, and GDC 23.
 2. FSAR, Section 4.
 3. FSAR, Section 15.
 4. PL-NF-94-005-P-A, "Technical Basis for 9X9-2 Extended Fuel Exposure at Susquehanna SES," January 1995.
 5. ANF-89-98(P)(A) Revision 1 and Revision 1 Supplement 1, "Generic Mechanical Design Criteria for BWR Fuel Designs," Advanced Nuclear Fuels Corporation, May 1995.
 6. Final Policy Statement on Technical Specifications Improvements, July 22, 1993 (58 FR 39132).
-
-