

January 13, 2000

Mr. J. A. Scalice
Chief Nuclear Officer and
Executive Vice President
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, Tennessee 37402-2801

SUBJECT: SEQUOYAH NUCLEAR PLANT, UNITS 1 AND 2 - CLOSURE OF GENERIC LETTER 97-01, "DEGRADATION OF CRDM/CEDM NOZZLE AND OTHER VESSEL CLOSURE HEAD PENETRATIONS" (TAC NOS. M98596 AND M98597)

Dear Mr. Scalice:

This letter provides the U.S. Nuclear Regulatory Commission (NRC) staff's assessment of your letters of April 30 and July 30, 1997, which provided your 30-day and 120-day responses to Generic Letter (GL) 97-01, "Degradation of CRDM/CEDM Nozzle and Other Vessel Closure Head Penetrations," and your letter of February 11, 1999, which provided your response to the staff's request for additional information (RAI) dated December 29, 1999, relative to the issuance of the GL. Your responses provided your proposed program and efforts to address the potential for primary water stress corrosion cracking (PWSCC) to occur in the control rod drive mechanism (CRDM) nozzles at the Sequoyah Nuclear Plant, Units 1 and 2.

The NRC staff issued GL 97-01 to the industry on April 1, 1997, requesting that addressees provide a description of the plans to inspect the vessel head penetrations (VHPs) at their respective pressurized water reactor (PWR) designed plants. In the discussion section of the GL, the staff indicated that it did not object to individual PWR licensees basing their inspection activities on an integrated, industry-wide inspection program.

The Westinghouse Owners Group (WOG), in coordination with the efforts of the Nuclear Energy Institute (NEI) and the other PWR Owners Groups (i.e., the Babcock and Wilcox (B&W) Owners Group and Combustion Engineering (CE) Owners Group), determined that it was appropriate for its members to develop a cooperative integrated inspection program in response to GL 97-01. On July 25, 1997, the WOG submitted two Topical Reports, WCAP-14901, Revision 0, and WCAP-14902, Revision 0, on behalf of the member utilities in the WOG. In these reports, the WOG provided descriptions of the two models, the Electric Power Research Institute (EPRI)/Dominion Engineering crack initiation and growth susceptibility model and the Westinghouse model, that were being used to rank the VHPs at the participating plants in the owners group. You provided your 30-day and 120-day responses for Sequoyah Nuclear Plant, Units 1 and 2, on April 30 and July 30, 1997. In these responses, you indicated that you were a participant in the WOG's integrated program for evaluating the potential for PWSCC to occur in the VHPs of Westinghouse designed PWRs, and that you were endorsing the probabilistic susceptibility model in WCAP-14901 as being applicable to the assessment of VHPs at Sequoyah.

The staff performed a review of your responses of April 30 and July 30, 1997, and the applicable WCAP topical report for your facility and determined that some additional information was needed for completion of the review. The staff issued an RAI on December 29, 1998, requesting: (1) a description of the probabilistic susceptibility ranking for a plant's VHPs to undergo PWSCC relative to the rankings for the rest of the industry; (2) a description of how the respective susceptibility models were benchmarked; (3) a description of how the variability in the product forms, material specifications, and heat treatments used to fabricate a plant's VHPs were addressed in the susceptibility models; and (4) a description of how the models would be refined in the future to include plant-specific inspection results. As was the case for the earlier responses to the GL, the staff encouraged a coordinated, generic response to the requests in the RAI.

On December 11, 1998, NEI submitted a generic, integrated response to the RAIs on GL 97-01 on behalf of the PWR industry and the utility members in the owners groups. In the generic submittal, NEI informed the staff that it had normalized the susceptibility rankings for the industry. The generic response to the RAIs also provided sufficient information to answer the information requests in the RAIs, and emphasized that the integrated program is an ongoing program that will be implemented in conjunction with EPRI, the PWR Owners Groups, the participating utilities, and the Material Reliability Projects' Subcommittee on Alloy 600. By letter dated March 21, 1999, the staff informed NEI that the integrated program was an acceptable approach for addressing the potential for PWSCC to occur in the VHPs of PWR-designed nuclear plants, and that licensees responding to the GL could refer to the integrated program as a basis for assessing the postulated occurrence of PWSCC in PWR-design VHPs.

To date, all utilities have implemented VT-2 type visual examinations of their VHPs in compliance with the American Society of Mechanical Engineers requirements specified in Table IWB-2500 for Category B-P components. Most utilities, if not all, have also performed visual examinations as part of plant-specific boric acid wastage surveillance programs. In addition, the following plants have completed voluntary, comprehensive augmented volumetric inspections (eddy current examinations or ultrasonic testing examinations) of their CRDM nozzles:

- 1994 - Point Beach Unit 1 (Westinghouse design)
- 1994 - Oconee Unit 2 (B&W design)
- 1994 - D.C. Cook Unit 2 (Westinghouse design)
- 1996 - North Anna Unit 1 (Westinghouse design)
- 1998 - Millstone Unit 2 (a CE design)
- 1999 - Ginna (a Westinghouse design)

In addition, the following plants have completed voluntary, limited augmented volumetric inspections of their VHPs as well:

- 1995 - Palisades - eight instrument nozzles (CE design)
- 1996 - Oconee Unit 2 - reinspection of two CRDM nozzles (B&W design)
- 1997 - Calvert Cliffs Unit 2 - vessel head vent pipe (CE design)

The majority of these plants have been ranked as having the more susceptible VHPs in the industry. Of these inspections, only the inspections at D.C. Cook Unit 2 have resulted in the identification of any domestic PWSCC type flaw indications. The current program includes additional commitments to perform further volumetric inspections of the CRDM nozzles at Oconee Unit 2 (a reinspection of 2-12 nozzles in 1999), Crystal River 3 (in 2001, a B&W design), Diablo Canyon Unit 2 (in 2001, a Westinghouse design), Farley Unit 2 (in 2002, a Westinghouse design), and San Onofre Unit 3 (in 2002-2008, a CE design). These plants are currently ranked in either the high or moderate susceptibility categories.

On February 11, 1999, you provided your response to the staff's RAI of September 25, 1998. In your letter of February 11, 1999, you endorsed the NEI submittal of December 11, 1998, and indicated that you were a participant in the NEI/WOG integrated program. Since the additional voluntary volumetric inspections performed to date have confirmed that PWSCC is not an immediate safety concern with respect to the structural integrity of VHPs in domestic PWRs, and since we have approved the integrated program for implementation, we conclude that the integrated program provides an acceptable basis for evaluating your VHPs. You may refer to the integrated program when submitting VHP-related licensing action submittals for the remainder of the current 40-year licensing period. However, if you are considering applying for license renewal of your facilities, your application will need to address the following items: (1) an assessment of the susceptibility of your VHPs to develop PWSCC during the extended license terms for the facilities; (2) a confirmation that the VHPs at your facilities are included under the scope of your boric acid corrosion inspection program, and (3) a summary of the results of any inspections that have been completed on your VHPs prior to the license renewal application, as appropriate.

This completes the staff's efforts relative to your responses to GL 97-01. Thank you for your consideration and efforts in addressing this issue.

Sincerely,

\RAI

Ronald W. Hernan, Senior Project Manager, Section 2
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-327 and 50-328

cc: See next page

The majority of these plants have been ranked as having the more susceptible VHPs in the industry. Of these inspections, only the inspections at D.C. Cook Unit 2 have resulted in the identification of any domestic PWSCC type flaw indications. The current program includes additional commitments to perform further volumetric inspections of the CRDM nozzles at Oconee Unit 2 (a reinspection of 2-12 nozzles in 1999), Crystal River 3 (in 2001, a B&W design), Diablo Canyon Unit 2 (in 2001, a Westinghouse design), Farley Unit 2 (in 2002, a Westinghouse design), and San Onofre Unit 3 (in 2002-2008, a CE design). These plants are currently ranked in either the high or moderate susceptibility categories.

On February 11, 1999, you provided your response to the staff's RAI of September 25, 1998. In your letter of February 11, 1999, you endorsed the NEI submittal of December 11, 1998, and indicated that you were a participant in the NEI/WOG integrated program. Since the additional voluntary volumetric inspections performed to date have confirmed that PWSCC is not an immediate safety concern with respect to the structural integrity of VHPs in domestic PWRs, and since we have approved the integrated program for implementation, we conclude that the integrated program provides an acceptable basis for evaluating your VHPs. You may refer to the integrated program when submitting VHP-related licensing action submittals for the remainder of the current 40-year licensing period. However, if you are considering applying for license renewal of your facilities, your application will need to address the following items: (1) an assessment of the susceptibility of your VHPs to develop PWSCC during the extended license terms for the facilities; (2) a confirmation that the VHPs at your facilities are included under the scope of your boric acid corrosion inspection program, and (3) a summary of the results of any inspections that have been completed on your VHPs prior to the license renewal application, as appropriate.

This completes the staff's efforts relative to your responses to GL 97-01. Thank you for your consideration and efforts in addressing this issue.

Sincerely,
/RA/
 Ronald W. Hernan, Senior Project Manager, Section 2
 Project Directorate II
 Division of Licensing Project Management
 Office of Nuclear Reactor Regulation

Docket No. 50-390

cc: See next page

DISTRIBUTION:

File Center	OGC	B. Clayton
PUBLIC	ACRS	J. Medoff
SQN R/F	P. Fredrickson, RII	W. Bateman
R. Corriea	R. Hernan	

DOCUMENT NAME: C:\LTRM98596.wpd

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PDII-2\PM		PDII-2\LA		PDII-2\SC				
NAME	RHernan		BClayton		RCorreia				
DATE	12/30/99		12/30/99		01/03/00				01/ /0

OFFICIAL RECORD COPY

Accession #ML003672952
 Template #NRR-056

Mr. J. A. Scalice
Tennessee Valley Authority

SEQUOYAH NUCLEAR PLANT

cc:

Mr. Karl W. Singer, Senior Vice President
Nuclear Operations
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

Mr. D. L. Koehl, Plant Manager
Sequoyah Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Soddy Daisy, TN 37379

Mr. Jack A. Bailey
Vice President
Engineering & Technical Services
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

Mr. Russell A. Gibbs
Senior Resident Inspector
Sequoyah Nuclear Plant
U.S. Nuclear Regulatory Commission
2600 Igou Ferry Road
Soddy Daisy, TN 37379

Mr. Masoud Bajestani
Site Vice President
Sequoyah Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Soddy Daisy, TN 37379

Mr. Michael H. Mobley, Director
TN Dept. of Environment & Conservation
Division of Radiological Health
3rd Floor, L and C Annex
401 Church Street
Nashville, TN 37243-1532

General Counsel
Tennessee Valley Authority
ET 10H
400 West Summit Hill Drive
Knoxville, TN 37902

County Executive
Hamilton County Courthouse
Chattanooga, TN 37402-2801

Mr. N. C. Kazanas, General Manager
Nuclear Assurance
Tennessee Valley Authority
5M Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

Mr. Mark J. Burzynski, Manager
Nuclear Licensing
Tennessee Valley Authority
4X Blue Ridge
1101 Market Street
Chattanooga, TN 37402-2801

Mr. Pedro Salas, Manager
Licensing and Industry Affairs
Sequoyah Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Soddy Daisy, TN 37379