

12/27/55

NOTE TO: NRC DOCUMENT CONTROL DESK
MAIL STOP 0-5-D-24

FROM: Virgil Curley, LICENSING ASSISTANT
OPERATING LICENSING BRANCH _ REGION I

SUBJECT: OPERATOR LICENSING EXAMINATION ADMINISTERED ON
Feb. 26 & Mar. 1-5, 1955, AT Salem Units 1 & 2
DOCKET NOS 272 & 311

ON Feb. 26 & Mar. 1-5, 1955 OPERATOR LICENSING EXAMINATIONS WERE ADMINISTERED AT THE REFERENCED FACILITY. ATTACHED YOU WILL FIND THE FOLLOWING INFORMATION FOR PROCESSING THROUGH NUDOCS AND DISTRIBUTION TO THE NRC STAFF, INCLUDING THE NRC PDR.

- Item #1 (a) FACILITY SUBMITTED OUTLINE AND INITIAL EXAM SUBMITTAL DESIGNATED FOR DISTRIBUTION UNDER RIDS CODE A070.
(Proposed Exam & outline)
- b) AS GIVEN OPERATING EXAMINATION, DESIGNATED FOR DISTRIBUTION UNDER RIDS CODE A070.

Item #2 EXAMINATION REPORT WITH THE AS GIVEN WRITTEN EXAMINATION ATTACHED, DESIGNATED FOR DISTRIBUTION UNDER RIDS CODE IE42.

A070

PDR A DOC 05000272

Proposed outlines

Facility		Salem		Date of Exam: 02/22/99				Exam Level: RO					
Tier	Group	K/A Category Points											Point Total
		K1	K2	K3	K4	K5	K6	A1	A2	A3	A4	G	
1. Emergency & Abnormal Plant Evolutions	1	1	2	6				4	3				16
	2	2	2	4				3	4			2	17
	3							1	2				3
	Tier Totals	3	4	10				8	9			2	36
2. Plant Systems	1	4			5	1	1	4	2	2	3	1	23
	2	2	1	1	5		1	1	3	1	5		20
	3	2		1	2				2	1			8
	Tier Totals	8	1	2	12	1	2	5	7	4	8	1	51
3. Generic Knowledge and Abilities					Cat 1		Cat 2		Cat 3		Cat 4		13
					6		2		2		3		
<p>Note:</p> <ul style="list-style-type: none"> • Attempt to distribute topics among all K/A Categories: select at least one topic from every K/A category within each tier. • Actual point totals must match those specified in the table. • Select topics from many systems: avoid selecting more than two or three K/A topics from a given system unless they relate to plant-specific priorities. • Systems/evolutions within each group are identified on the associated outline. • The shaded areas are not applicable to the category/tier. 													

AC 40

ES-401		PWR RO Examination Outline							ES-401-4	
Emergency and Abnormal Plant Evolutions - Tier 1/Group 1										
Number#	Name	K1	K2	K3	A1	A2	G	K/A Topic(s)	Imp.	Pts.
005	Inoperable/Stuck Control Rod									
015	Reactor Coolant Pump Malfunctions	X						AK1.02 Consequences of an RCPs failure	3.7	1
017	Reactor Coolant Pump Malfunctions (Loss of RC Flow)									
024	Emergency Boration					X		AA2.01 Whether boron flow and/or MOVs are malfunctioning, from plant conditions	3.8*	1
026	Loss of Component Cooling Water				X			AA1.05 The CCWS surge tank, including level control and level alarms, and radiation alarm	3.1	1
027	Pressurizer Pressure Control Malfunction			X				AK3.04 Why, if PZR level is lost and then restored, that pressure recovers much more slowly	2.8	1
040	Steam Line Rupture				X			AA1.02 Feedwater isolation	4.5	1
051	Loss of Condenser Vacuum			X				AK3.01 Loss of steam dump capability upon loss of condenser vacuum	2.8*	1
055	Station Blackout			X				EK3.02 Actions contained in EOP for loss of offsite and onsite power	4.3	1
057	Loss of Vital AC Instrument Bus				X			AA1.01 Manual inverter swapping	3.7*	1
062	Loss of Nuclear Service Water				X			AA1.02 Loads on the SWS in the control room	3.2	1
067	Plant Fire on Site					X		AA2.06 Need for pressurizing control room (recirculation mode)	3.3	1
068	Control Room Evacuation		X					AK2.03 Controllers and Positioners	2.9	1
069	Loss of Containment Integrity									
074	Inadequate Core Cooling		X					EK2.01 RCP	3.6	1
076	High Reactor Coolant Activity					X		AA2.02 Corrective actions required for high fission product activity in RCS	2.8	1
E06	Degraded Core Cooling									
E07	Saturated Core Cooling									
E08	Pressurized Thermal Shock			X				EK3.1 Facility operating characteristics during transient conditions, including coolant chemistry and the effects of temperature, pressure, and reactivity changes and operating limitations and reasons for these operating characteristics.	3.4	1
E09	Natural Circulation Operations			X				EK3.2 Normal, abnormal and emergency operating procedures associated with (Natural Circulation Operations).	3.2	1
E10	Natural Circulation with Steam Void in Vessel with/without RVLIS									
E12	Uncontrolled Depressurization of all Steam Generators									

ES-401		PWR RO Examination Outline							ES-401-4	
Emergency and Abnormal Plant Evolutions - Tier 1/Group 1										
Number#	Name	K1	K2	K3	A1	A2	G	K/A Topic(s)	Imp.	Pts.
E14	High Containment Pressure			X				EK3.1 Facility operating characteristics during transient conditions, including coolant chemistry and the effects of temperature, pressure, and reactivity changes and operating limitations and reasons for these operating characteristics.	3.2	1
K/A Category Point Totals:		1	2	6	4	3	0	Group Point Total:	16	

ES-401		PWR RO Examination Outline							ES-401-4	
Emergency and Abnormal Plant Evolutions - Tier 1/Group 2										
Number#	Name	K1	K2	K3	A1	A2	G	K/A Topic(s)	Imp.	Pts.
001	Continuous Rod Withdrawal					X		AA2.04 Reactor power and its trend	4.2	1
003	Dropped Control Rod			X				AK3.04 Actions contained in EOP for dropped control rod	3.8*	1
007	Reactor Trip				X			EA1.03 RCS pressure and temperature	4.2	1
008	Pressurizer Vapor Space Accident									
009	Small Break LOCA			X				EK3.21 Actions contained in EOP for small break LOCA/leak	4.2	1
011	Large Break LOCA				X			EA1.09 Core flood tank initiation	4.3	1
011	Large Break LOCA			X				EK3.14 RCP tripping requirement	4.1	1
022	Loss of Reactor Coolant Makeup				X			AA1.08 VCT level	3.4	1
025	Loss of Residual Heat Removal System	X						AK1.01 Loss of RHRS during all modes of operation	3.9	1
029	Anticipated Transient Without Scram									
032	Loss of Source Range Nuclear Instrumentation						X	2.4.31 Knowledge of annunciators alarms and indications, and use of the response instructions.	3.3	1
033	Loss of Intermediate Range Nuclear Instrumentation					X		AA2.04 Satisfactory overlap between source-range, intermediate-range and power-range instrumentation	3.2	1
037	Steam Generator Tube Leak					X		AA2.01 Unusual readings of the monitors; steps needed to verify readings	3.0	1
038	Steam Generator Tube Rupture			X				EK3.06 Actions contained in EOP for RCS water inventory balance, S/G tube rupture, and plant shutdown procedures	4.2	1
054	Loss of Main Feedwater	X						AK1.01 MFW line break depressurizes the S/G (similar to a steam line break)	4.1	1
058	Loss of DC Power						X	2.1.32 Ability to explain and apply all system limits and precautions.	3.4	1
059	Accidental Liquid Radwaste Release					X		AA2.02 The permit for liquid radioactive-waste release	2.9	1
060	Accidental Gaseous Radwaste Release									
061	Area Radiation Monitoring System Alarms									
E02	SI Termination		X					EK2.1 Components, and functions of control and safety systems, including instrumentation, signals, interlocks, failure modes, and automatic and manual features.	3.4	1
E03	LOCA Cooldown and Depressurization									
E04	LOCA Outside Containment									
E05	Loss of Secondary Heat Sink									
E11	Loss of Emergency Coolant Recirculation									
E16	High Containment Radiation		X					EK2.2 Facility's heat removal systems, including primary coolant, emergency coolant, the decay heat removal systems, and relations between the proper operation of these systems to the operation of the facility.	2.6	1
K/A Category Point Totals:		2	2	4	3	4	2	Group Point Total:		17

ES-401		PWR RO Examination Outline							ES-401-4	
Emergency and Abnormal Plant Evolutions - Tier 1/Group 3										
Number#	Name	K1	K2	K3	A1	A2	G	K/A Topic(s)	Imp.	Pts.
028	Pressurizer Level Control Malfunction				X			AA1.02 CVCS	3.4	1
036	Fuel Handling Incidents									
056	Loss of Off-Site Power					X		AA2.46 That the ED/Gs have started automatically and that the bus tie breakers are closed	4.2	1
065	Loss of Instrument Air					X		AA2.08 Failure modes of air-operated equipment	2.9*	1
E13	Steam Generator Overpressure									
E15	Containment Flooding									
K/A Category Point Totals:		0	0	0	1	2	0	Group Point Total:	3	

ES-401		PWR RO Examination Outline Plant Systems - Tier 2/Group 1											ES-401-4		
Number#	Name	K1	K2	K3	K4	K5	K6	A1	A2	A3	A4	G	K/A Topic(s)	Imp.	Pts.
001	Control Rod Drive System				X								K4.02 Control rod mode select control (movement control)	3.8	1
001	Control Rod Drive System					X							K5.05 Interpretation of rod worth curves, including proper curve to use: all rods in (ARI), all rods out (ARO), hot zero power (HZZP), hot full power (HFP)	3.5	1
001	Control Rod Drive System							X					A1.02 T-ref	3.1	1
003	Reactor Coolant Pump System							X					A1.07 RCS temperature and pressure	3.4*	1
003	Reactor Coolant Pump System	X											K1.03 RCP seal system	3.3	1
003	Reactor Coolant Pump System				X								K4.04 Adequate cooling of RCP motor and seals	2.8	1
004	Chemical and Volume Control System							X					A1.06 VCT level	3.0	1
004	Chemical and Volume Control System									X			A3.14 Letdown and charging flows	3.4	1
004	Chemical and Volume Control System	X											K1.18 CCWS	2.9	1
013	Engineered Safety Features Actuation System	X											K1.01 Initiation signals for ESF circuit logic	4.2	1
013	Engineered Safety Features Actuation System							X					A1.05 Main steam pressure	3.4	1
013	Engineered Safety Features Actuation System								X				A2.06 Inadvertent ESFAS actuation	3.7*	1
015	Nuclear Instrumentation System						X						K6.04 Bistables and logic circuits	3.1	1
015	Nuclear Instrumentation System				X								K4.05 Reactor trip	4.3	1
017	In-Core Temperature Monitor System										X		A4.01 Actual in-core temperatures	3.8	1
022	Containment Cooling System									X			A3.01 Initiation of safeguards mode of operation	4.1	1
025	Ice Condenser System														
056	Condensate System														
059	Main Feedwater System	X											K1.04 S/GS water level control system	3.4	1
059	Main Feedwater System				X								K4.19 Automatic feedwater isolation of MFW	3.2	1
061	Auxiliary / Emergency Feedwater System				X								K4.02 AFW automatic start upon loss of MFW pump, S/G level, blackout, or safety injection	4.5	1
061	Auxiliary / Emergency Feedwater System								X				A2.03 Loss of dc power	3.1	1
068	Liquid Radwaste System										X		A4.04 Automatic isolation	3.8	1
071	Waste Gas Disposal System										X		A4.27 Opening and closing of the decay tank discharge control valve	3.0*	1

ES-401		PWR RO Examination Outline Plant Systems - Tier 2/Group 1											ES-401-4		
Number#	Name	K1	K2	K3	K4	K5	K6	A1	A2	A3	A4	G	K/A Topic(s)	Imp.	Pts.
072	Area Radiation Monitoring System											X	2.1.27 Knowledge of system purpose and or function.	2.8	1
K/A Category Point Totals:		4	0	0	5	1	1	4	2	2	3	1	Group Point Total:	23	

ES-401		PWR RO Examination Outline											ES-401-4		
Plant Systems - Tier 2/Group 2															
Number#	Name	K1	K2	K3	K4	K5	K6	A1	A2	A3	A4	G	K/A Topic(s)	Imp.	Pts.
002	Reactor Coolant System				X								K4.10 Overpressure protection	4.2	1
002	Reactor Coolant System	X											K1.07 Reactor vessel level indication system	3.5*	1
006	Emergency Core Cooling System									X			A3.03 ESFAS-operated valves	4.1	1
006	Emergency Core Cooling System				X								K4.05 Autostart of HPI/LPI/SIP.	4.3	1
010	Pressurizer Pressure Control System							X					A1.07 RCS pressure	3.7	1
011	Pressurizer Level Control System						X						K6.03 Relationship between PZR level and PZR heater control circuit	2.9	1
012	Reactor Protection System														
014	Rod Position Indication System														
018	Non-Nuclear Instrumentation System										X		A4.01 NNI channel select controls	2.9*	1
028	Containment Spray System										X		A4.01 CSS controls	4.5	1
026	Containment Spray System				X								K4.01 Source of water for CSS, including recirculation phase after LOCA	4.2	1
029	Containment Purge System	X											K1.01 Gaseous radiation release monitors	3.4	1
033	Spent Fuel Pool Cooling System								X				A2.03 Abnormal spent fuel pool water level or loss of water level	3.1	1
035	Steam Generator System										X		A4.01 Shift of S/G controls between manual and automatic control, by bumpless transfer	3.7	1
039	Main and Reheat Steam System								X				A2.05 Increasing steam demand, its relationship to increases in reactor power	3.3	1
055	Condenser Air Removal System														
062	A.C. Electrical Distribution		X										K2.01 Major system loads	3.3	1
062	A.C. Electrical Distribution								X				A2.01 Types of loads that, if de-energized, would degrade or hinder plant operation	3.4	1
063	D.C. Electrical Distribution			X									K3.02 Components using dc control power	3.5	1
064	Emergency Diesel Generators										X		A4.05 Transfer of ED/G control between manual and automatic	3.1	1
064	Emergency Diesel Generators				X								K4.02 Trips for ED/G while operating (normal or emergency)	3.9	1
073	Process Radiation Monitoring System										X		A4.01 Effluent release	3.9	1
075	Circulating Water System														
079	Station Air System														
086	Fire Protection System				X								K4.02 Maintenance of fire header pressure	3.0	1
K/A Category Point Totals:		2	1	1	5	0	1	1	3	1	5	0	Group Point Total:	20	

ES-401		PWR RO Examination Outline Plant Systems - Tier 2/Group 3											ES-401-4		
Number#	Name	K1	K2	K3	K4	K5	K6	A1	A2	A3	A4	G	K/A Topic(s)	Imp.	Pts.
005	Residual Heat Removal System								X				A2.03 RHR pump/motor malfunction	2.9	1
007	Pressurizer Relief Tank/Quench Tank System	X											K1.01 Containment system	2.9	1
008	Component Cooling Water System									X			A3.05 Control of the electrically operated, automatic isolation valves in the CCWS	3.0	1
027	Containment Iodine Removal System	X											K1.01 CSS	3.4*	1
028	Hydrogen Recombiner and Purge Control System														
034	Fuel Handling Equipment System														
041	Steam Dump System and Turbine Bypass Control				X								K4.17 Reactor trip	3.7	1
045	Main Turbine Generator System								X				A2.17 Malfunction of electrohydraulic control	2.7*	1
076	Service Water System				X								K4.03 Automatic opening features associated with SWS isolation valves to CCW heat exchangers	2.9*	1
078	Instrument Air System			X									K3.02 Systems having pneumatic valves and controls	3.4	1
103	Containment System														
K/A Category Point Totals:		2	0	1	2	0	0	0	2	1	0	0	Group Point Total:		8

Facility	Date:		Exam Level:	RO
Salem	February 22, 1999			
Category	KA #	KA Topic	Imp.	Points
Conduct of Operations	2.1.18	Ability to make accurate, clear and concise logs, records, status boards, and reports.	2.9	1
	2.1.20	Ability to execute procedure steps.	4.3	1
	2.1.28	Knowledge of the purpose and function of major system components and controls.	3.2	1
	2.1.3	Knowledge of shift turnover practices.	3.0	1
	2.1.32	Ability to explain and apply all system limits and precautions.	3.4	1
	2.1.9	Ability to direct personnel activities inside the control room.	2.5	1
	Total			
Equipment Control	2.2.2	Ability to manipulate the console controls as required to operate the facility between shutdown and designated power levels.	4.0	1
	2.2.13	Knowledge of tagging and clearance procedures.	3.6	1
Total				2
Radiation Control	2.3.1	Knowledge of 10 CFR: 20 and related facility radiation control requirements.	2.6	1
	2.3.10	Ability to perform procedures to reduce excessive levels of radiation and guard against personnel exposure.	2.9	1
Total				2
Emergency Procedures and Plan	2.4.1	Knowledge of EOP entry conditions and immediate action steps.	4.3	1
	2.4.12	Knowledge of general operating crew responsibilities during emergency operations.	3.4	1
	2.4.39	Knowledge of the RO's responsibilities in emergency plan implementation.	3.3	1
Total				3
Tier 3 Target Point Total (RO/SRO)				13

Facility	Salem	Date of Exam: 02/22/99					Exam Level: SRO						
Tier	Group	K/A Category Points										Point Total	
		K1	K2	K3	K4	K5	K6	A1	A2	A3	A4		G
1. Emergency & Abnormal Plant Evolutions	1	3	3	7				4	5			2	24
	2	3	2	3				2	2			4	16
	3		1					1	1				3
	Tier Totals	6	6	10				7	8			6	43
2. Plant Systems	1	4		1	1	1	1	2	3	2	4		19
	2	2	1		4		1	1	3	1	3	1	17
	3	1			1					1		1	4
	Tier Totals	7	1	1	6	1	2	3	6	4	7	2	40
3. Generic Knowledge and Abilities					Cat 1		Cat 2		Cat 3		Cat 4		
					5		4		3		5		17
<p>Note:</p> <ul style="list-style-type: none"> • Attempt to distribute topics among all K/A Categories: select at least one topic from every K/A category within each tier. • Actual point totals must match those specified in the table. • Select topics from many systems: avoid selecting more than two or three K/A topics from a given system unless they relate to plant-specific priorities. • Systems/evolutions within each group are identified on the associated outline. • The shaded areas are not applicable to the category/tier. 													

ES-401		PWR SRO Examination Outline							ES-401-3	
Emergency and Abnormal Plant Evolutions - Tier 1/Group 1										
Number#	Name	K1	K2	K3	A1	A2	G	K/A Topic(s)	Imp.	Pts.
001	Continuous Rod Withdrawal					X		AA2.04 Reactor power and its trend	4.3	1
003	Dropped Control Rod			X				AK3.04 Actions contained in EOP for dropped control rod	4.1*	1
005	Inoperable/Stuck Control Rod						X	2.1.12 Ability to apply technical specifications for a system.	4.0	1
011	Large Break LOCA					X		EA2.04 Significance of PZR readings	3.9	1
011	Large Break LOCA			X				EK3.14 RCP tripping requirement	4.2	1
015	Reactor Coolant Pump Malfunctions	X						AK1.02 Consequences of an RCPs failure	4.1	1
017	Reactor Coolant Pump Malfunctions (Loss of RC Flow)									
024	Emergency Boration					X		AA2.01 Whether boron flow and/or MOVs are malfunctioning, from plant conditions	4.1	1
026	Loss of Component Cooling Water				X			AA1.05 The CCWS surge tank, including level control and level alarms, and radiation alarm	3.1	1
029	Anticipated Transient Without Scram			X				AK3.12 Actions contained in EOP for ATWS	4.7	1
040	Steam Line Rupture				X			AA1.02 Feedwater isolation	4.5	1
051	Loss of Condenser Vacuum			X				AK3.01 Loss of steam dump capability upon loss of condenser vacuum	3.1*	1
055	Station Blackout			X				EK3.02 Actions contained in EOP for loss of offsite and onsite power	4.6	1
057	Loss of Vital AC Instrument Bus				X			AA1.01 Manual inverter swapping	3.7	1
059	Accidental Liquid Radwaste Release					X		AA2.02 The permit for liquid radioactive-waste release	3.9	1
062	Loss of Nuclear Service Water				X			AA1.02 Loads on the SWS in the control room	3.3	1
067	Plant Fire on Site						X	2.4.25 Knowledge of fire protection procedures.	3.4	1
068	Control Room Evacuation		X					AK2.03 Controllers and Positioners	3.1	1
069	Loss of Containment Integrity									
074	Inadequate Core Cooling		X					EK2.01 RCP	3.8	1
076	High Reactor Coolant Activity					X		AA2.02 Corrective actions required for high fission product activity in RCS	3.4	1
E02	SI Termination		X					EK2.1 Components, and functions of control and safety systems, including instrumentation, signals, interlocks, failure modes, and automatic and manual features.	3.9	1
E04	LOCA Outside Containment	X						EK1.2 Normal, abnormal and emergency operating procedures associated with (LOCA Outside Containment).	4.2	1
E06	Degraded Core Cooling									
E07	Saturated Core Cooling									
E08	Pressurized Thermal Shock			X				EK3.1 Facility operating characteristics during transient conditions, including coolant chemistry and the effects of temperature, pressure, and reactivity changes and operating limitations and reasons for these operating characteristics.	3.9	1

ES-401		PWR SRO Examination Outline							ES-401-3	
Emergency and Abnormal Plant Evolutions - Tier 1/Group 1										
Number#	Name	K1	K2	K3	A1	A2	G	K/A Topic(s)	Imp.	Pts.
E09	Natural Circulation Operations									
E10	Natural Circulation with Steam Void in Vessel with/without RVLIS	X						EK1.2 Normal, abnormal and emergency operating procedures associated with (Natural Circulation with Steam Void in Vessel with/without RVLIS).	3.6	1
E12	Uncontrolled Depressurization of all Steam Generators									
E14	High Containment Pressure			X				EK3.1 Facility operating characteristics during transient conditions, including coolant chemistry and the effects of temperature, pressure, and reactivity changes and operating limitations and reasons for these operating characteristics.	3.6	1
K/A Category Point Totals:		3	3	7	4	5	2	Group Point Total:		24

ES-401		PWR SRO Examination Outline							ES-401-3	
Emergency and Abnormal Plant Evolutions - Tier 1/Group 2										
Number#	Name	K1	K2	K3	A1	A2	G	K/A Topic(s)	Imp.	Pts.
007	Reactor Trip				X			EA1.03 RCS pressure and temperature	4.1	1
008	Pressurizer Vapor Space Accident						X	2.1.12 Ability to apply technical specifications for a system.	4.0	1
009	Small Break LOCA			X				EK3.21 Actions contained in EOP for small break LOCA/leak	4.5	1
022	Loss of Reactor Coolant Makeup				X			AA1.08 VCT level	3.3	1
025	Loss of Residual Heat Removal System	X						AK1.01 Loss of RHRS during all modes of operation	4.3	1
027	Pressurizer Pressure Control Malfunction			X				AK3.04 Why, if PZR level is lost and then restored, that pressure recovers much more slowly	3.3	1
032	Loss of Source Range Nuclear Instrumentation						X	2.4.31 Knowledge of annunciators alarms and indications, and use of the response instructions.	3.4	1
033	Loss of Intermediate Range Nuclear Instrumentation						X	2.1.1 Knowledge of conduct of operations requirements.	3.8	1
037	Steam Generator Tube Leak					X		AA2.01 Unusual readings of the monitors; steps needed to verify readings	3.4	1
038	Steam Generator Tube Rupture			X				EK3.08 Criteria for securing RCP	4.2	1
054	Loss of Main Feedwater	X						AK1.01 MFW line break depressurizes the S/G (similar to a steam line break)	4.3	1
058	Loss of DC Power						X	2.1.32 Ability to explain and apply all system limits and precautions.	3.8	1
060	Accidental Gaseous Radwaste Release									
061	Area Radiation Monitoring System Alarms									
065	Loss of Instrument Air									
E03	LOCA Cooldown and Depressurization	X						EK1.2 Normal, abnormal and emergency operating procedures associated with (LOCA Cooldown and Depressurization).	4.1	1
E05	Loss of Secondary Heat Sink		X					EK2.2 Facility's heat removal systems, including primary coolant, emergency coolant, the decay heat removal systems, and relations between the proper operation of these systems to the operation of the facility.	4.2	1
E11	Loss of Emergency Coolant Recirculation					X		EA2.1 Facility conditions and selection of appropriate procedures during abnormal and emergency operations.	4.2	1
E16	High Containment Radiation		X					EK2.2 Facility's heat removal systems, including primary coolant, emergency coolant, the decay heat removal systems, and relations between the proper operation of these systems to the operation of the facility.	3.0	1
K/A Category Point Totals:		3	2	3	2	2	4	Group Point Total:		16

ES-401		PWR SRO Examination Outline							ES-401-3	
Emergency and Abnormal Plant Evolutions - Tier 1/Group 3										
Number#	Name	K1	K2	K3	A1	A2	G	K/A Topic(s)	Imp.	Pts.
028	Pressurizer Level Control Malfunction				X			AA1.02 CVCS	3.4	1
036	Fuel Handling Incidents		X					AK2.01 Fuel handling equipment	3.5	1
056	Loss of Off-Site Power					X		AA2.46 That the ED/Gs have started automatically and that the bus tie breakers are closed	4.4	1
E13	Steam Generator Overpressure									
E15	Containment Flooding									
K/A Category Point Totals:		0	1	0	1	1	0	Group Point Total:		3

ES-401		PWR SRO Examination Outline											ES-401-3		
Plant Systems - Tier 2/Group 1															
Number#	Name	K1	K2	K3	K4	K5	K6	A1	A2	A3	A4	G	K/A Topic(s)	Imp.	Pts.
001	Control Rod Drive System								X				A2.06 Effects of transient xenon on reactivity	3.7	1
001	Control Rod Drive System	X											K1.05 NIS and RPS	4.4	1
001	Control Rod Drive System					X							K5.05 Interpretation of rod worth curves, including proper curve to use: all rods in (ARI), all rods out (ARO), hot zero power (HZZP), hot full power (HFP)	3.9	1
003	Reactor Coolant Pump System							X					A1.07 RCS temperature and pressure	3.4	1
003	Reactor Coolant Pump System	X											K1.03 RCP seal system	3.6	1
004	Chemical and Volume Control System									X			A3.14 Letdown and charging flows	3.1	1
004	Chemical and Volume Control System	X											K1.18 CCWS	3.2	1
013	Engineered Safety Features Actuation System							X					A1.05 Main steam pressure	3.6	1
013	Engineered Safety Features Actuation System								X				A2.06 Inadvertent ESFAS actuation	4.0	1
014	Rod Position Indication System														
015	Nuclear Instrumentation System						X						K6.04 Bistables and logic circuits	3.2	1
017	In-Core Temperature Monitor System														
022	Containment Cooling System									X			A3.01 Initiation of safeguards mode of operation	4.3	1
025	Ice Condenser System														
026	Containment Spray System										X		A4.01 CSS controls	4.3	1
056	Condensate System														
059	Main Feedwater System	X											K1.04 S/GS water level control system	3.4	1
059	Main Feedwater System				X								K4.19 Automatic feedwater isolation of MFW	3.4	1
061	Auxiliary / Emergency Feedwater System								X				A2.03 Loss of dc power	3.4	1
063	D.C. Electrical Distribution			X									K3.02 Components using dc control power	3.7	1
063	D.C. Electrical Distribution										X		A4.03 Battery discharge rate	3.1	1
068	Liquid Radwaste System														
071	Waste Gas Disposal System											X	A4.27 Opening and closing of the decay tank discharge control valve	2.7*	1
072	Area Radiation Monitoring System											X	A4.01 Alarm and interlock setpoint checks and adjustments	3.3	1
	K/A Category Point Totals:	4	0	1	1	1	1	2	3	2	4	0	Group Point Total:		19

ES-401		PWR SRO Examination Outline Plant Systems - Tier 2/Group 2											ES-401-3		
Number#	Name	K1	K2	K3	K4	K5	K6	A1	A2	A3	A4	G	K/A Topic(s)	Imp.	Pts.
002	Reactor Coolant System				X								K4.10 Overpressure protection	4.4	1
002	Reactor Coolant System	X											K1.07 Reactor vessel level indication system	3.7*	1
006	Emergency Core Cooling System									X			A3.03 ESFAS-operated valves	4.1	1
006	Emergency Core Cooling System				X								K4.05 Autostart of HPI/LPI/SIP.	4.4	1
010	Pressurizer Pressure Control System							X					A1.07 RCS pressure	3.7	1
011	Pressurizer Level Control System						X						K6.03 Relationship between PZR level and PZR heater control circuit	3.3	1
012	Reactor Protection System														
016	Non-Nuclear Instrumentation System										X		A4.01 NNI channel select controls	2.8*	1
027	Containment Iodine Removal System														
028	Hydrogen Recombiner and Purge Control System														
029	Containment Purge System	X											K1.01 Gaseous radiation release monitors	3.7	1
033	Spent Fuel Pool Cooling System								X				A2.03 Abnormal spent fuel pool water level or loss of water level	3.5	1
034	Fuel Handling Equipment System														
035	Steam Generator System										X		A4.01 Shift of S/G controls between manual and automatic control, by bumpless transfer	3.6	1
039	Main and Reheat Steam System								X				A2.05 Increasing steam demand, its relationship to increases in reactor power	3.6	1
055	Condenser Air Removal System														
062	A.C. Electrical Distribution		X										K2.01 Major system loads	3.4	1
062	A.C. Electrical Distribution								X				A2.01 Types of loads that, if de-energized, would degrade or hinder plant operation	3.9	1
064	Emergency Diesel Generators											X	2.1.12 Ability to apply technical specifications for a system.	4.0	1
064	Emergency Diesel Generators				X								K4.02 Trips for ED/G while operating (normal or emergency)	4.2	1
073	Process Radiation Monitoring System										X		A4.01 Effluent release	3.9	1
075	Circulating Water System														
079	Station Air System														
086	Fire Protection System				X								K4.02 Maintenance of fire header pressure	3.4	1
103	Containment System														
K/A Category Point Totals:		2	1	0	4	0	1	1	3	1	3	1	Group Point Total:		17

ES-401		PWR SRO Examination Outline Plant Systems - Tier 2/Group 3											ES-401-3		
Number#	Name	K1	K2	K3	K4	K5	K6	A1	A2	A3	A4	G	K/A Topic(s)	Imp.	Pts.
005	Residual Heat Removal System											X	2.2.24 Ability to analyze the affect of maintenance activities on LCO status.	3.8	1
007	Pressurizer Relief Tank/Quench Tank System	X											K1.01 Containment system	3.1	1
008	Component Cooling Water System									X			A3.05 Control of the electrically operated, automatic isolation valves in the CCWS	3.1	1
041	Steam Dump System and Turbine Bypass Control				X								K4.17 Reactor trip	3.9	1
045	Main Turbine Generator System														
076	Service Water System														
078	Instrument Air System														
K/A Category Point Totals:		1	0	0	1	0	0	0	0	1	0	1	Group Point Total:		4

Facility	Salem	Date: February 22, 1999	Exam Level:	SRO
Category	KA #	KA Topic	Imp.	Points
Conduct of Operations	2.1.9	Ability to direct personnel activities inside the control room.	4.0	1
	2.1.14	Knowledge of system status criteria which require the notification of plant personnel.	3.3	1
	2.1.18	Ability to make accurate, clear and concise logs, records, status boards, and reports.	3.0	1
	2.1.20	Ability to execute procedure steps.	4.2	1
	2.1.32	Ability to explain and apply all system limits and precautions.	3.8	1
	Total			5
Equipment Control	2.2.12	Knowledge of surveillance procedures.	3.4	1
	2.2.13	Knowledge of tagging and clearance procedures.	3.8	1
	2.2.18	Knowledge of the process for managing maintenance activities during shutdown operations.	3.6	1
	2.2.29	Knowledge of SRO fuel handling responsibilities.	3.8	1
	Total			4
Radiation Control	2.3.1	Knowledge of 10 CFR: 20 and related facility radiation control requirements.	3.0	1
	2.3.4	Knowledge of radiation exposure limits and contamination control, including permissible levels in excess of those authorized.	3.1	1
	2.3.10	Ability to perform procedures to reduce excessive levels of radiation and guard against personnel exposure.	3.3	1
	Total			3
Emergency Procedures and Plan	2.4.1	Knowledge of EOP entry conditions and immediate action steps.	4.6	1
	2.4.11	Knowledge of abnormal condition procedures.	3.6	1
	2.4.13	Knowledge of crew roles and responsibilities during EOP flowchart use.	3.9	1
	2.4.21	Knowledge of the parameters and logic used to assess the status of safety functions including: 1. Reactivity control 2. Core cooling and heat removal 3. Reactor coolant system integrity 4. Containment conditions 5. Radioactivity release control.	4.3	1
	2.4.30	Knowledge of which events related to system operations/status should be reported to outside agencies.	3.6	1
	Total			5
Tier 3 Target Point Total (RO/SRO)				17

Facility: Salem		Date of Examination: 02/22/99
Examination Level: RO		Operating Test Number:
Administrative Topic/Subject Description		Describe method of evaluation: 1. ONE Administrative JPM, OR 2. TWO Administrative Questions
A1	QPTR JPM	2.1.7 3.7 - Ability to evaluate plant performance and make operational judgments based on operating characteristics, reactor behavior, and instrument interpretation. Perform a Quadrant Power Tilt Ratio Calculation
	Temporary Modification of Procedures JPM	2.2.11 2.5 - Knowledge of the process for controlling temporary changes Prepare a Temporary Modification to a procedure.
A.2	Action Requests JPM	2.2.24 2.5 - Ability to analyze the affect of maintenance activities on LCO status Maintenance activities and affects on Tech Specs
A.3	Radiation Protection	2.3.4 2.5 - Knowledge of radiation exposure limits and contamination control, including permissible levels in excess of those authorized Given an emergency situation, determine the allowable stay time.
		2.3.10 2.9 - Ability to perform procedures to reduce excessive levels of radiation and guard against personnel exposure. Special requirements for containment entry during Mode 1.
A.4	Emergency Procedures/Plan	2.4.27 3.0 - Knowledge of fire in the plant procedure. Control Room response to a fire in the plant.

Facility: Salem		Date of Examination: 2/22/99
Examination Level: SRO		Operating Test Number:
Administrative Topic/Subject Description		Describe method of evaluation: 1. ONE Administrative JPM, OR 2. TWO Administrative Questions
A.1	Valve Lineup JPM	2.1.29 3.3 - Knowledge of how to conduct and verify valve lineups. Perform a valve alignment verification surveillance.
	Perform a QPTR Surveillance JPM	2.1.7 4.4 - Ability to evaluate plant performance and make operational judgments based on operating characteristics, reactor behavior, and instrument interpretation. Perform a QPTR surveillance.
A.2	Surveillance Test Review JPM (FAULTED)	2.2.12 3.4 - Knowledge of surveillance procedures. Review a completed surveillance test on a Containment Spray Pump.
A.3	Radiation Protection	2.3.4 3.1 - Knowledge of radiation exposure limits and contamination control, including permissible levels in excess of those authorized. Determine Emergency Exposure Limits during a plant emergency.
		2.3.10 3.3 - Ability to perform procedures to reduce excessive levels of radiation and guard against personnel exposure. Special requirements necessary for personnel to enter a locked High Radiation Area.
A.4	Emergency Plan JPM	2.4.44 4.0 - Knowledge of Emergency Plan Protective Action Recommendations Determine PARs during a site emergency.

Facility: Salem 1 & 2 Examination Level: Inplant 1 – Simulator 1		Date of Examination: 2/22/99 Operating Test Number: 1
System / JPM Title / Type Codes*	Safety Function	Planned Followup Questions: K/A/G – Importance - Description
1. CVCS/RWST Makeup Using Blender (S2.OP-SO.CVC-0006(Q) section 5.7) N S	I	a. 004 K1.23 //3.4/3.7// Flow path for procedure (If power is decreasing, where can the boron be entering CVCS?) b. 2.2.22 //3.4/4.1// Technical Specifications for loss of a charging pump.
2. ECCS/ Fill an accumulator using an SI pump. (JPM 33) M S	II	a. 011 EK3.07 //3.5/3.6// Reason for SI Pump Mini-Flow Isolation during Recirculation Phase b. 011 EK3.12 //4.4/4.6// Negative effects if an accumulator is not isolated when required by LOCA-1
3. RHR / Swapping RHR Loops (JPM 28) D S L	IV	a. 005 K4.01 //3.0/3.2// Overpressurization protection for shutdown cooling piping on increasing RCS pressure b. 005 A2.04 //2.9/2.9// Effect a loss of air would have on RHR flow with SDC in service (Repeated on Set 2)
4. PRT/Purging the PRT (S2.OP-SO.PZR-0001) N S	V	a. 2.1.32 //3.4/3.8// Difference between venting to IRU and to the containment atmosphere. b. 007 K4.01 //2.6/2.9// How will a feed and bleed operation on the PRT be affected by an SI signal?
5. NI / Respond to failure of a Source Range Instrument (JPM 44) D S L	VII	a. 2.2.22 //3.4/4.1// Technical Specifications for Source Range b. 015 A2.01 //3.5/3.9// Effect of a control power fuse blowing during startup.
6. Containment / Containment Pressure Relief with R-12A Out of Service (JPM 48) D S	VIII	a. 029 K3.01 //2.9/3.1// What are the negative effects if the pressure relief was not performed when required? (Repeated on Set 2) b. 2.3.11 //2.7/3.2// Limits on times that VC-5 and VC-6 can be open. (Repeated on set 2)
7. Pressure Control / Depressurize in accordance with LOCA-2 using Auxiliary Spray (2-EOP-LOCA-2 Steps 13-15.2) N S A	III	a. 010 A1.08 //3.2/3.3// Factors affecting the delta T on the spray nozzle. b. 010 A1.09 //3.4/3.7// Validate temperature indication for a leaking PORV.
8. Pressurizer / Transfer Pressurizer heaters to Emergency Power Supply (JPM PZHTEP) D P	III	a. 2.1.30 //3.9/3.4// Local operation of pressurizer heaters during shutdown outside the control room b. 010 K4.02 //3.0/3.4// Automatic control/protective features available during operation outside the control room.
9. Diesel Generator/Perform Attachment 4 for Shutdown Outside the Control room. N P R	VI	a. 064 K1.04 //3.6/3.9// What will prevent the diesel from starting on loss of DC? b. 063 K2.01 //2.9/3.1// Effect of loss of DC power will have on Diesel Room Ventilation and required actions
10. Main Steam / Align Main Steam following a Control Room Evacuation (JPM 83 & 108) M P	IV	a. 068 AK3.18 //4.2/4.5// Why removing power to the solenoids is not used when closing and MSIV outside the control room? b. 068 AA2.08 //3.9/4.1// When locally operating MS10's why is it important to coordinate with the CRS at HSD?
Type Codes: (D) Direct from bank, (M)odified from bank, (N)ew, (A)lternate Path, (C)ontrol Room, (S)imulator, (P)lant, (L)ow Power, (R)CA # Questions or JPM are similar or the same as Questions or JPMs used on a recent NRC exam.		

Facility: Salem 1 & 2		Date of Examination: 2/22/99
Examination Level: In-Plant 1 – Simulator 2		Operating Test Number: 2
System / JPM Title / Type Codes*	Safety Function	Planned Followup Questions: K/A/G – Importance – Description
1. Rod Cont./Recover a Dropped rod (JPM – DROPROD) D S	I	a. 001 K4.01 //3.5/3.8// Effects of incorrectly setting the P to A converter during realigning a control rod.
		b. 001 A3.02 //3.5/3.6// Rod Insertion Limit determination
2. CVCS/Establish Excess Letdown (JPM 21) D S	II	a. 004 A2.12 //4.1/4.3// Effect of a Phase A Isolation on excess letdown
		b. 004 A1.04 //3.9/4.1// What will be the expected Pzr level trend with excess letdown in service?
3. LOCA / Respond to a Shutdown LOCA – Start Centrifugal Charging Pump and Realign flow through the BIT (S2.OP-AB.LOCA-0001) N S A L	III	a. 009 EA2.34 //3.6/4.2// Based on plant conditions determine if a SI pump can be secured.
		b. 009 EK1.01 //4.2/4.7// Based on plant conditions determine if Natural Circulation has been established.
4. RHR/Place RHR in service with RCS depressurized (JPM – inirhr) D S L	IV	a. 2.2.22 //3.4/4.1// RHR Technical Specifications
		b. 005 A2.04 //2.9/2.9// Effect a loss of air would have on RHR flow {Repeated on Set 1}
5. Containment / Perform a containment purge (JPM 69) D S A	VIII	a. 029 K3.01 //2.9/3.1// What are the negative effects if the pressure relief was not performed when required? {Repeated on Set 1}
		b. 2.3.11 //2.7/3.2// Limits on times that VC-5 and VC-6 can be open. {Repeated on Set 1}
6. NI / Respond to failure of a Source Range Instrument (JPM 44) D S L	VII	a. 2.1.12 //2.9/4.0// Apply AFD limits
		b. 015 K1.02 //3.4/3.6 // Effect on NIS of removing Deans line from service during a Unit 1 startup
7. Hydrogen Recombiner/Place the Hydrogen Recombiner in Service (JPM 49) D S	V	a. 028 A1.02 //3.4/3.7// Effect of recombinder operation on containment pressure
		b. 028 K6.01 //2.6/3.1// Effect of not achieving required temperature. {Repeated on Set 3}
8. Pressurizer / Transfer Pressurizer heaters to Emergency Power Supply (JPM PZHTEP) D P	III	a. 2.1.30 //3.9/3.4// Local operation of pressurizer heaters during shutdown outside the control room
		b. 010 K4.02 //3.0/3.4// Automatic control/protective features available during operation outside the control room.
9. Diesel Generator/Perform Attachment 4 for Shutdown Outside the Control room. N P R	VI	a. 064 K1.04 //3.6/3.9// What will prevent the diesel from starting on loss of DC?
		b. 063 K2.01 //2.9/3.1// Effect of loss of DC power will have on Diesel Room Ventilation and required actions
10. Main Steam / Align Main Steam following a Control Room Evacuation (JPM 83 & 108) M P	IV	a. 068 AK3.18 //4.2/4.5// Why removing power to the solenoids is not used when closing an MSIV outside the control room?
		b. 068 AA2.08 //3.9/4.1// When locally operating MS10's why is it important to coordinate with the CRS at HSD?
Type Codes: (D) Direct from bank, (M)odified from bank, (N)ew, (A)lternate Path, (C)ontrol Room, (S)imulator, (P)lant, (L)ow Power, (R)CA # Questions or JPM are similar or the same as Questions or JPMs used on a recent NRC exam.		

Facility: Salem 1 & 2 Examination Level: In-Plant 1 – Simulator 3		Date of Examination: 2/22/99 Operating Test Number: 3	
System / JPM Title / Type Codes*	Safety Function	Planned Followup Questions: K/A/G – Importance – Description	
1. CVCS/Increasing RHR Loop Boron Concentration (S2.OP-SO.CVC-0006 Att. 1) N S L	I	a. 004 K1.24 //3.4/3.9// Using the P&IDs trace how the Boron Concentration is changed.	b. 004 A2.06 //4.2/4.3// Why is boron a concern when placing SDC in service and the temperature change not a concern?
2. ECCS&ESFAS / Terminate SI (JPM – Terminate SI) D S	II	a. 013 K4.01 //3.9/4.3// Failure of P-4 on SI reset	b. 013 K4.06 //4.0/4.3// Status of SI signal input to Semi Automatic Switchover system following SI reset.
3. Pressure Control/ Respond to a failed open spray valve (JPM ABPZRPS3) D S A	III	a. 010 K1.03 //3.6/3.7// Why are the actions different if PS-1 sticks open instead of PS-3?	b. 027 AK3.03 //3.7/4.1// Explain how selecting "IMP OUT" prevents an RCS cooldown when stopping an RCP for a stuck open spray valve?
4. Feedwater/Establish feed with SGFP (S2.OP-SO.CN-002 section 5.4) N S	IV	a. 059 A2.01 //3.4/3.6// AFW pump response to a SGFP trip.	b. 059 K4.05 //2.5/2.8// Function of the "Bias" control on 22 SGFP.
5. Hydrogen Recombiner / Place the Hydrogen Recombiner in Service (JPM 49) D S	V	a. 028 A1.01 // 3.4/3.8// When are the hydrogen recombiners required to be placed in service?	b. 028 K6.01 //2.6/3/1// Effect of not achieving required temperature. {Repeated on Set 2}
6. NI / Respond to a failed Intermediate Range Instrument (JPM 45) D S	VII	a. 015 A2.02 //3.1/3.5// Undercompensation Effects on Intermediate Range	b. 015 A3.03 //3.9/3.9// Indication at NIS rack when at power
7. CCW / Start a CCW Pump IAW APX-1 D S A	VIII	a. 2.2.3 // 3.1/3.3 // CCW response during a LOCA (Unit Differences) (#)	b. 2.2.22 //3.4/4.1// Required TS actions for one CCW pump being inoperable.
8. Pressurizer / Transfer Pressurizer heaters to Emergency Power Supply (JPM PZHTEP) D P	III	a. 2.1.30 //3.9/3.4// Local operation of pressurizer heaters during shutdown outside the control room	b. 010 K4.02 //3.0/3.4// Automatic control/protective features available during operation outside the control room.
9. Diesel Generator/Perform Attachment 4 for Shutdown Outside the Control room. N P R	VI	a. 064 K1.04 //3.6/3.9// What will prevent the diesel from starting on loss of DC?	b. 063 K2.01 //2.9/3.1// Effect of loss of DC power will have on Diesel Room Ventilation and required actions
10. Main Steam / Align Main Steam following a Control Room Evacuation (JPM 83 & 108) M P	IV	a. 068 AK3.18 //4.2/4.5// Why removing power to the solenoids is not used when closing an MSIV outside the control room?	b. 068 AA2.08 //3.9/4.1// When locally operating MS10's why is it important to coordinate with the CRS at HSD?
Type Codes: (D) Direct from bank, (M)odified from bank, (N)ew, (A)lternate Path, (C)ontrol Room, (S)imulator, (P)lant, (L)ow Power, (R)CA # Questions or JPM are similar or the same as Questions or JPMs used on a recent NRC exam.			

Facility: Salem 1 & 2

Date of Examination: 2/22/99

Examination Level:

Operating Test Number: 1

Inplant 2 – Simulator 1

System / JPM Title / Type Codes*	Safety Function	Planned Followup Questions: K/A/G – Importance - Description
1. CVCS/RWST Makeup Using Blender (S2.OP-SO.CVC-0006(Q) section 5.7) N S	I	a. 004 K1.23 //3.4/3.7// Flow path for procedure (If power is decreasing, where can the boron be entering CVCS?) b. 2.2.22 //3.4/4.1// Technical Specifications for loss of a charging pump.
2. ECCS/ Fill an accumulator using an SI pump. (JPM 33) M S	II	a. 011 EK3.07 //3.5/3.6// Reason for SI Pump Mini-Flow Isolation during Recirculation Phase b. 011 EK3.12 //4.4/4.6// Negative effects if an accumulator is not isolated when required by LOCA-1
3. RHR / Swapping RHR Loops (JPM 28) D S L	IV	a. 005 K4.01 //3.0/3.2// Overpressurization protection for shutdown cooling piping on increasing RCS pressure b. 005 A2.04 //2.9/2.9// Effect a loss of air would have on RHR flow with SDC in service {Repeated on Set 2}
4. PRT/Purging the PRT (S2.OP-SO.PZR-0001) N S	V	a. 2.1.32//3.4/3.8// Difference between venting to the IRU and to the containment atmosphere b. 007 K4.01//2.6/2.9//How will feed and bleed operation on the PRT be affected by a SI signal?
5. NI / Respond to failure of a Source Range Instrument (JPM 44) D S L	VII	a. 2.2.22 //3.4/4.1// Technical Specifications for Source Range b. 015 A2.01 //3.5/3.9// Effect of a control power fuse blowing during startup.
6. Containment / Containment Pressure Relief with R-12A Out of Service (JPM 48) D S	VIII	a. 029 K3.01 //2.9/3.1// What are the negative effects if the pressure relief was not performed when required? {Repeated on Set 2} b. 2.3.11 //2.7/3.2// Limits on times that VC-5 and VC-6 can be open. {Repeated on set 2}
7. Pressure Control / Depressurize in accordance with LOCA-2 using Auxiliary Spray (2-EOP-LOCA-2 Steps 13-15.2) N S A	III	a. 010 A1.08 //3.2/3.3// Factors affecting the delta T on the spray nozzle. b. 010 A1.09 //3.4/3.7// Validate temperature indication for a leaking PORV.
8. AFW/Reset an AFW turbine trip valve (MS52) (JPM Reset MS52) D P R	V	a. 061 A2.07 //3.4/3.5// Operation of AFW valves with PRESS OVRD lights illuminated b. 061 A2.02 //3.2/3.6// Effect of a loss of control air
9. AC Elect/Startup Vital Instrument Inverter – Alternate Source Startup and Return the Inverter to Normal (JPM 112) D P	VI	a. 062 K3.01 //3.5/3.9// Effect of a loss 115 VAC on SI b. 062 K4.10 //3.1/3.5// Status of Inverter if Manual Bypass Switch is in the Isolate (Preferred) Position.
10. ECCS / Align Charging suction to the RWST during CR Evacuation (S1OP-AB.CR-0001 Att. 3 step 19-21) N P R	II	a. 2.2.22 //3.4/4.1// ECCS flow path Technical Specifications b. 006 K4.09 //3.9/4.2// How an inadvertent SI is prevented during shutdown outside the control room.
Type Codes: (D) Direct from bank, (M)odified from bank, (N)ew, (A)lternate Path, (C)ontrol Room, (S)imulator, (P)lant, (L)ow Power, (R)CA # Questions or JPM are similar or the same as Questions or JPMs used on a recent NRC exam.		

System / JPM Title / Type Codes*		Safety Function	Planned Followup Questions: K/A/G – Importance – Description
Facility: Salem 1 & 2 Examination Level: In-Plant 2 – Simulator 2 Date of Examination: 2/22/99 Operating Test Number: 2			
1.	Rod Cont./Recover a Dropped rod (JPM – DROPROD) D S	I	a. 001 K4.01 //3.5/3.8// Effects of incorrectly setting the P to A converter during realigning a control rod. b. 001 A3.02 //3.5/3.6// Rod Insertion Limit determination
2.	CVCS/Establish Excess Letdown (JPM 21) D S	II	a. 004 A2.12 //4.1/4.3// Effect of a Phase A Isolation on excess letdown b. 004 A1.04 //3.9/4.1// What will be the expected Pzr level trend with excess letdown in service?
3.	LOCA / Respond to a Shutdown LOCA – Start Centrifugal Charging Pump and Realign flow through the BIT (S2.OP-AB.LOCA-0001) N S A L	III	a. 009 EA2.34 //3.6/4.2// Based on plant conditions determine if a SI pump can be secured. b. 009 EK1.01 //4.2/4.7// Based on plant conditions determine if Natural Circulation has been established.
4.	RHR/Place RHR in service with RCS depressurized (JPM – inrhr) D S L	IV	a. 2.2.22 //3.4/4.1// RHR Technical Specifications b. 005 A2.04 //2.9/2.9// Effect a loss of air would have on RHR flow (Repeated on Set 1)
5.	Containment / Perform a containment purge (JPM 69) D S A	VIII	a. 029 K3.01 //2.9/3.1// What are the negative effects if the pressure relief was not performed when required? (Repeated on Set 1) b. 2.3.11 //2.7/3.2// Limits on times that VC-5 and VC-6 can be open. (Repeated on Set 1)
6.	NI / Respond to failure of a Source Range Instrument (JPM 44) D S L	VII	a. 2.1.12 //2.9/4.0// Apply AFD limits b. 015 K1.02 //3.4/3.6 // Effect on NIS of removing Deans line from service during a Unit 1 startup
7.	Hydrogen Recombiner/Place the Hydrogen Recombiner in Service (JPM 49) D S	V	a. 028 A1.02 //3.4/3.7// Effect of recombining operation on containment pressure b. 028 K6.01 //2.6/3.1// Effect of not achieving required temperature. (Repeated on Set 3)
8.	AFW/Reset an AFW turbine trip valve (MS52) (JPM Reset MS52) D P R	V	a. 061 A2.07 //3.4/3.5// Operation of AFW valves with PRESS OVRD lights illuminated b. 061 A2.02 //3.2/3.6// Effect of a loss of control air
9.	AC Elect/Startup Vital Instrument Inverter – Alternate Source Startup and Return the Inverter to Normal (JPM 112) D P	VI	a. 062 K3.01 //3.5/3.9// Effect of a loss 115 VAC on SI b. 062 K4.10 //3.1/3.5// Status of Inverter if Manual Bypass Switch is in the Isolate (Preferred) Position.
10.	ECCS / Align Charging suction to the RWST during CR Evacuation (S1OP-AB.CR-0001 Att. 3 step 19-21) N P R	II	a. 2.2.22 //3.4/4.1// ECCS flow path Technical Specifications b. 006 K4.09 //3.9/4.2// How an inadvertent SI is prevented during shutdown outside the control room.
Type Codes: (D) Direct from bank, (M)odified from bank, (N)ew, (A)lternate Path, (C)ontrol Room, (S)imulator, (P)lant, (L)ow Power, (R)CA # Questions or JPM are similar or the same as Questions or JPMs used on a recent NRC exam.			

System / JPM Title / Type Codes*		Safety Function	Planned Followup Questions: K/A/G – Importance – Description
Facility: Salem 1 & 2 Examination Level: In-Plant 2 – Simulator 3		Date of Examination: 2/22/99 Operating Test Number: 3	
1.	CVCS/Increasing RHR Loop Boron Concentration (S2.OP-SO.CVC-0006 Att. 1) N S L	I	a. 004 K1.24 //3.4/3.9// Using the P&IDs trace how the Boron Concentration is changed. b. 004 A2.06 //4.2/4.3// Why is boron a concern when placing SDC in service and the temperature change not a concern?
2.	ECCS&ESFAS / Terminate SI (JPM – Terminate SI) D S	II	a. 013 K4.01 //3.9/4.3// Failure of P-4 on SI reset b. 013 K4.06 //4.0/4.3// Status of SI signal input to Semi Automatic Switchover system *following SI reset.
3.	Pressure Control/ Respond to a failed open spray valve (JPM ABPZRPS3) D S A	III	a. 010 K1.03 //3.6/3.7// Why are the actions different if PS-1 sticks open instead of PS-3? b. 027 AK3.03 //3.7/4.1// Explain how selecting "IMP OUT" prevents an RCS cooldown when stopping an RCP for a stuck open spray valve?
4.	Feedwater/Establish feed with SGFP (S2.OP-SO.CN-002 section 5.4) N S	IV	a. 059 A2.01 //3.4/3.6// AFW pump response to a SGFP trip. b. 059 K4.05 //2.5/2.8// Function of the "Bias" control on 22 SGFP.
5.	Hydrogen Recombiner / Place the Hydrogen Recombiner in Service (JPM 49) D S	V	a. 028 A1.01 // 3.4/3.8// When are the hydrogen recombiners required to be placed in service? b. 028 K6.01 //2.6/3/1// Effect of not achieving required temperature. (Repeated on Set 2)
6.	NI / Respond to a failed Intermediate Range Instrument (JPM 45) D S	VII	a. 015 A2.02 //3.1/3.5// Undercompensation Effects on Intermediate Range b. 015 A3.03 //3.9/3.9// Indication at NIS rack when at power
7.	CCW / Start a CCW Pump IAW APX-1 D S A	VIII	a. 2.2.3 // 3.1/3.3 // CCW response during a LOCA (Unit Differences) (#) b. 2.2.22 //3.4/4.1// Required TS actions for one CCW pump being inoperable.
8.	AFW/Reset an AFW turbine trip valve (MS52) (JPM Reset MS52) D P R	V	a. 061 A2.07 //3.4/3.5// Operation of AFW valves with PRESS OVRD lights illuminated b. 061 A2.02 //3.2/3.6// Effect of a loss of control air
9.	AC Elect/Startup Vital Instrument Inverter – Alternate Source Startup and Return the Inverter to Normal (JPM 112) D P	VI	a. 062 K3.01 //3.5/3.9// Effect of a loss 115 VAC on SI b. 062 K4.10 //3.1/3.5// Status of Inverter if Manual Bypass Switch is in the Isolate (Preferred) Position.
10.	ECCS / Align Charging suction to the RWST during CR Evacuation (S1OP-AB.CR-0001 Att. 3 step 19-21) N P R	II	a. 2.2.22 //3.4/4.1// ECCS flow path Technical Specifications b. 006 K4.09 //3.9/4.2// How an inadvertent SI is prevented during shutdown outside the control room.
Type Codes: (D) Direct from bank, (M)odified from bank, (N)ew, (A)lternate Path, (C)ontrol Room, (S)imulator, (P)lant, (L)ow Power, (R)CA # Questions or JPM are similar or the same as Questions or JPMs used on a recent NRC exam.			

Facility: Salem Generating Station

Scenario No.: 1

Op Test No.: D1

Examiners: _____

Candidates: _____ CRS

_____ RO

_____ PO

Objectives: Evaluate the ability of the Crew to perform a normal power reduction. Evaluate the response of the crew to the failure of PT-505 during the power reduction. Evaluate the ability of the Crew to recognize and respond to the failure of VCT level instrument LT-112. Evaluate the response of the Crew to the RCS leak. Evaluate the ability of the Crew to recognize and respond to the Main Steam Isolation Valve drifting closed. Evaluate the response of the Crew to the rising leak rate and eventual entry into the EOPs. The crew should recognize the failure of 22 SI Pump to start. Evaluate the response of the Crew to the loss of offsite power and their ability to recognize the need to manually align Safety Injection components.

Initial Conditions: IC-2, MOL at 100% power. 21 Service water Pump and Strainer C/T. N41 removed from service. 24 S/G narrow range level LT-518 is removed from service for I&C testing. 21 SI pump is C/T to repair a leaking drain valve.

Turnover: The plant is in Mode 1 at 100% power. Last shift, 21 Heater Drain Pump developed an abnormal vibration and is to be removed from service. 21 Service Water Pump and Strainer are C/T for strainer maintenance. N41 is out of service for replacement of a failed amplifier card. 24 S/G narrow range level LT-518 is removed from service for I&C testing. 21 SI pump is C/T to repair a leaking drain valve. All other equipment is operating normally with all controls in automatic. Orders for the shift are to perform a power reduction to 90% within the next 30 minutes and remove 21 Heater Drain Pump from service.

Event No.	Malf. No.	Event Type*	Event Description
1		N CRS R PO R RO	Perform a normal power reduction to permit removal of 21 Heater Drain Pump
2	TU0055	I CRS PO RO	Turbine First Stage Pressure transmitter, PT-505 fails low
3	CV0037	I CRS RO	VCT Level transmitter, LT-112 fails high
4	RC0002	C ALL	RCS Leak – Ramp from 0 – 50 gpm over 5 min
5	New	C CRS PO	Main Steam Isolation Valve, 23MS167 drifts closed
6	RC0002	M ALL	Small Break LOCA – 1000 gpm
7	CV	C CRS RO	22 SI Pump Fails to start on SI signal
8	EL0134	M ALL	Loss of Offsite Power (After the SI is reset)

* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor

SCENARIO SUMMARY

The scenario begins with a normal power reduction to remove 21 Heater Drain Pump from service. During the power reduction, the turbine first stage pressure transmitter PT505 fails low. This will change T-ref to the no load value of 547°F resulting in continuous rod motion in the inward direction. The RO should verify that no turbine load change is in progress and that Tave and reactor power are consistent and then take Rod Control to manual to stop rod motion. Actions should then be performed IAW AB.ROD-0003, Continuous Rod Motion.

When VCT level transmitter LT112 fails high, CV35 will divert to the Holdup Tanks causing VCT level to lower. Since the VCT auto makeup function is controlled by LT112 between 14-24%, no auto makeup will occur. The operator must manually divert CV35 back to the VCT and/or initiate a manual makeup to terminate the VCT level drop. The operators will be alerted to the failure by a VCT HI/LO Level console alarm.

An RCS leak of 50 gpm inside containment is initiated causing pressurizer level to drop and containment pressure and temperature to rise. Charging flow should rise to maintain pressurizer level on program. Operator actions should include monitoring VCT level and initiating a manual VCT makeup to prevent Charging Pump cavitation since the auto swap to the RWST will not occur with LT112 failed high.

When the Main Steam Line isolation valve drifts closed, the PO should respond IAW the Annunciator Response procedure and re-open the valve.

The major event is a small break LOCA caused by degradation of the existing leak to a 1000 gpm break. The crew should recognize the inability to maintain pressurizer level and manually trip the Reactor, initiate a manual Safety Injection and initiate the EOPs by entering EOP-TRIP-0001. The crew should notice the failure of the 22 SI Pump to start and perform appropriate steps of TRIP-1 to start it.

The crew should perform TRIP-1 and transition to EOP-LOCA-1 at Step 28.

When desired by the examination team but after the SECs are reset, a Loss of Off-site power will occur. Since the SECs will have been reset and will not restart loads automatically, the crew should respond IAW the "BLACKOUT" continuous action step (Step 5) and manually start ECCS pumps. The scenario may be terminated when the plant is stable with the proper ECCS pumps in service and with the concurrence of the examination team.

Facility: Salem Units 1 & 2

Scenario No.: 2

Op Test No.: D2

Examiners: _____

Candidates: _____ CRS

_____ RO

_____ PO

Objectives: Evaluate the ability of the Crew to perform a normal power ascension using the Integrated Operating Procedures. The crew should recognize and respond to the S/G level instrument failure and manually control S/G level. Evaluate the ability of the Crew to recognize and respond to the SGFP trip and stabilize the plant without a plant trip. The crew should recognize and respond to the failure of the Pressurizer Master Pressure Controller and take action to stabilize plant pressure. Evaluate the ability of the Crew to respond to the Steam Line break and enter the EOPs. Evaluate the response of the Crew to the trip of 22 AFW Pump. Evaluate the ability of the Crew to recognize the trip of 21 AFW Pump and properly transition to EOP-FRHS-1, Response to Loss of Secondary Heat Sink.

Initial Conditions: IC-3 at 70% power with the following conditions:

- 23 S/G NR Level transmitter LT-518 is failed and is out of service.
- 23 AFW Pump C/T for repair of a steam leak on MS132.
- Pre-insert AF0181B for 22 AFW Pump
- Pre-insert CS0171 for the failure of 'B' Containment Spray Logic to automatically actuate.

Turnover: The plant is in Mode 1 at 70% power with a power ascension in progress. 23 S/G NR Level transmitter, LT-518 is out of service for repairs. 23 AFW Pump is C/T for repair of a steam leak on MS132. All other equipment is operating normally with all controls in automatic. Orders for the shift are to continue the ascension to 100% power at 10% /hr.

Event No.	Malf. No.	Event Type*	Event Description
1		N CRS R PO R RO	Perform a power ascension to 100 % power.
2	SG0095C	I CRS PO	LT-519, 23 S/G Narrow Range Level fails low
3	BF0104A	C All	21 SGFP trip
4	PR0016E	I CRS RO	Pressurizer Master Pressure Controller fails high
5	MS0090C	M All	Main Steam Line Break in Containment on 23 S/G
6	AF0181B	C CRS PO	22 Aux Feedwater Pump trip
7	AF0181A	C CRS PO	21 Aux Feedwater Pump trip (when 24 S/G NR Level gets on scale)

* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor

The scenario begins with a power ascension to 100%. After the power ascension has progressed to the satisfaction of the examination team, 23 S/G Level transmitter LT-519 will fail low. This will cause the 23 S/G Feedwater Reg Valves BF19 and BF40 to shift to manual. The crew should terminate the power ascension and investigate. After a delay, the 21 SGFP will develop thrust bearing problems, which cause the pump to trip. The PO should control 23 S/G level with manual control of 23BF19/40.

When the plant is stable, the Pressurizer Master Pressure Controller will fail high. This will cause pressurizer heaters to turn off, both spray valves to open and actual pressurizer pressure to lower. The RO should respond by placing the Master pressure controller in manual and close the spray valves. The crew should enter and perform the actions of S2.OP-AB.PZR-0001.

The major event is a Main Steam Line Break on 23 S/G inside Containment. The crew will respond by entering and performing the actions of EOP-TRIP-1, Reactor Trip or Safety Injection. During the initial transient, 22 AFW Pump will trip on overcurrent. The PO is expected to establish and maintain feed flow to 23 & 24 S/Gs using the remaining AFW Pump.

The crew should perform EOP-TRIP-1 and transition to EOP-LOSC-1, Loss of Secondary Coolant at Step 26.

When 24 S/G NR Level gets on scale, the 21 AFW Pump will trip resulting in a Loss of Secondary Heat Sink. The Crew is expected to respond by transitioning to EOP-FRHS-1, Response to Loss of Secondary Heat Sink at Step 26 of EOP-TRIP-1 or when the 21 AFW pump trips if already beyond Step 26.

The crew will perform the actions of EOP-FRHS-1. The success path will be the restoration of feed by depressurizing the S/Gs and feeding with the Condensate System. The scenario may be terminated when level in at least one S/G is rising and with the concurrence of the Examination Team.

Facility: Salem Units 1 & 2

Scenario No.: 3

Op Test No.: D3

Examiners: _____

Candidates: _____ CRS

_____ RO

_____ PO

Objectives: Evaluate the ability of the crew to perform a normal power ascension. The RO should recognize and respond to the Rod Speed failure during the power ascension. Evaluate the response of the crew to the failure of 22 S/G Pressure transmitter, PT-517A. Evaluate the ability of the crew to recognize and respond to a Fuel Element Failure. Evaluate the ability of the crew to respond to a S/G tube failure and their ability to implement the EOPs. Evaluate the ability of the crew to recognize and respond to the trip of 22 Aux Feedwater Pump. The PO should recognize the loss of the Steam Dumps and control S/G pressure with manual operation of the MS10.

Initial Conditions: IC-4 at 90% power. 23 S/G Feed Flow transmitter, FT-510 out of service for I & C testing.

Turnover: The plant is in Mode 1 with power at 90%. All equipment is operating normally with all controls in automatic. Orders for the shift are to continue the power ascension to 100% at 10% per hour.

Event No.	Malf. No.	Event Type*	Event Description
1		N CRS R PO R RO	Perform a normal power ascension.
2	RD0061	I CRS RO	Rod Speed Control Program fails to Maximum (72 spm)
3	MS0129	I CRS PO	22 S/G Pressure transmitter, PT-517A fails high (Only transfers MS10 to man)
4	CV0040	C CRS RO	Fuel Element failure
5	SG0078	M All	22 SG Tube Leak/Rupture
6	AF0181B	C CRS PO	22 Aux Feedwater Pump trip
7	MS0093	I CRS PO	Loss of Steam Dump Vacuum permissive

* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor

SCENARIO SUMMARY

This scenario begins with an ascension to 100% power. When the power ascension has progressed to the satisfaction of the Examination Team, the Rod Speed controller will fail high at 72 spm. The RO should recognize the failure, take Rod Control to Manual and stabilize Tave. The crew should enter and take the actions of S2.OP-AB.ROD-0003.

After the investigation of the rod speed failure has been initiated, 22 S/G Pressure Transmitter, PT-517 will fail high causing 22 S/G Atmospheric Dump Valve, 22MS10 to shift to manual. The PO should identify the failure and discuss the implications with the crew. After a short time for the PT-517 failure discussion, a fuel element failure will occur as a small leak at first and then degrade over time. The crew should recognize the Fuel Failure, enter and take the actions of S2.OP-AB.RC-0002, High Activity in the Reactor Coolant and S2.OP-AB.RAD-0001, Abnormal Radiation.

The major event is a Steam Generator Tube Leak. The crew will enter and perform the actions of S2.OP-AB.SG-0001, Steam Generator Tube Leak. The leak will eventually degrade requiring a manual Reactor Trip and Safety Injection and implementation of the EOPs. While performing actions of EOP-TRIP-1, Reactor Trip or Safety Injection, 22 Aux Feedwater Pump will trip. The PO should respond by maintaining S/G levels using 23 Aux Feedwater Pump. The crew should progress through the EOPs as follows:

1. Perform EOP-TRIP-1 and transition to EOP-SGTR-1, Steam Generator Tube Rupture at Step 27.
2. After transitioning to EOP-SGTR-1, the Steam Dump Vacuum Permissive will be lost causing all Steam Dump Valves to close. The PO should control S/G pressures with the Atmospheric Relief Valves controlling 22MS10 in manual.
3. When the steps for SI termination (Step 25) have been initiated and with the concurrence of the Examination Team, the scenario may be terminated.

Facility: Salem Units 1 & 2

Scenario No.: 4

Op Test No.: D4

Examiners: _____

Candidates: _____ CRS

_____ RO

_____ PO

Objectives: Evaluate the ability of the crew to perform a normal power reduction to 75% power. The crew should recognize and respond to the failure of control bank rod D3 to insert during the power reduction. Evaluate the response of the crew to the failure of 21 S/G Feed Flow Transmitter, FT-511 and the automatic transfer of Feedwater Reg Valves 21BF19 & 40 to manual. The crew should recognize and respond to the failure of the LT-461, Pressurizer Level failing high. Evaluate the ability of the crew to recognize and respond to the Main Turbine Lube Oil leak and failure of the Main Turbine Aux Oil Pump to auto start and subsequent abnormal vibrations on the Main Turbine. Evaluate the ability of the crew to recognize and respond to the failure of the Reactor and Main Turbine to trip and to implement the EOPs. Evaluate the ability of the crew to recognize the loss of all AC and to properly transition to the LOPA series EOPs.

Initial Conditions: IC-2 at 100% power with 21 S/G Feed Flow transmitter FT-510 out of service for circuit board replacement.

Turnover: The plant is in Mode 1 with power at 100%. 21 S/G Feed Flow transmitter FT-510 out of service for circuit board replacement. All other equipment is operating normally with all controls in automatic. Orders for the shift are to reduce power to 75% to remove 22 Condensate Pump from service for seal replacement.

Event No.	Malf. No.	Event Type*	Event Description
1		N CRS R PO R RO	Perform a normal power reduction
2	RD0065	C CRS RO	Control Bank Rod D3 fails to insert
3	SG0096	I CRS PO	21 S/G Feed Flow transmitter FT-511 fails low.
4	PR017A	I CRS RO	LT-461, Pressurizer Level fails high
5	TU0075 New TU0083	C CRS PO	MTLO Leak - Ramped from 0-90% over a 10 minute period Main Turbine high vibration Main Turbine Aux Bearing Oil Pump fails to auto start
6	RP0069 RP0058 RP0059	M ALL	Main Turbine failure to trip (Interface Valve Failure) Reactor Failure to Trip (Auto & Manual)
7	EL0134 EL0162 EL0146 EL0273 XXXXX	M ALL	Loss of All AC Power 2B DG Trip 2C 4KV Bus Differential 2A DG Bkr fail to Auto Close 2A DG Bkr Trip upon Closure

* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor

SCENARIO SUMMARY

The scenario begins with a normal power reduction to remove 22 Condensate Pump from service for shaft seal replacement. During the power reduction, Control Bank Rod D3 will fail to insert. The crew should terminate the power reduction, enter and take the actions of AB.ROD-0001.

21 S/G Feed Flow Transmitter, FT-511 will fail low causing 21 S/G Feedwater Reg Valves 21BF19 and 21BF 40 to shift to manual. After a short delay to allow conditions to stabilize, Pressurizer Level Transmitter FT-461 will fail high. This will cause charging flow to be reduced actual Pressurizer level to lower. The RO should take the Master Level Controller to manual and stabilize pressurizer level. The crew should take the actions of Annunciator Response Procedure AR.ZZ-0005 for OHA E-4, PZR LVL HI.

When Pressurizer level has been stabilized, a leak will occur in the Main Turbine Lube Oil System at the discharge of the shaft driven pump. All oil will be retained in the system by the guard pipe. The PO should recognize the failure of the Aux Bearing Oil Pump to auto start and respond by manually starting the pump to terminate the low oil pressure problem. When the lube oil leak is initiated, a Main Turbine high vibration will also be initiated that will gradually degrade to the point where a manual trip is required.

The major event will be a failure of the Reactor and Main Turbine to trip. The crew should implement the EOPs, enter and take the actions of EOP-TRIP-1, Reactor Trip or Safety Injection.

The crew should perform EOP-TRIP-1 and transition to EOP-FRSM-1, Response to Nuclear Power Generation at Step 2.2

The crew will perform the actions of EOP-FRSM-1. When Rapid Boration actions of Step 3 are complete, a Loss of All AC Power will occur, terminating the ATWS. The crew will complete the actions of EOP-FRSM-1 and transition to EOP-LOPA-1, Loss of All AC Power at Step 17.

The crew will perform actions of EOP-LOPA-1. When SI Actuation and Reset actions of Steps 21-23 have been initiated, a Diesel Generator will become available. The crew should respond IAW Continuous Action Step 14 and restore power to the 4kV bus. When power is restored and with the concurrence of the Examination Team, the scenario may be terminated.

Facility: Salem Units 1 & 2	Scenario No.: 5	Op Test No.: SP
Examiners: _____	Candidates: _____	CRS
_____	_____	RO
_____	_____	PO

Objectives: Evaluate the ability of the Crew to perform a normal power ascension. Evaluate the response of the crew to the RCS temperature instrument failure. The crew should recognize and respond to the trip of 22 Vacuum Pump. Evaluate the response of the crew to the Hotwell Level Transmitter failure. Evaluate the response of the crew to the high vibration on 22 RCP. Evaluate the ability of the Crew to trip the 22 RCP with resultant Reactor Trip failure requiring entry into the EOPs. Evaluate the response of the crew to the ensuing Large Break LOCA and their ability to properly transition to the LOCA series procedures. Evaluate the ability of the crew to respond to failures of an RHR pump and suction valve during transfer to Cold Leg Recirc requiring transition to EOP-LOCA-5, Loss of Emergency Recirculation.

Initial Conditions: IC-4 at 90% power with 21B waterbox C/T for cleaning.

Turnover: The plant is in Mode 1 at 90% power. Power ascension is in progress following recovery of 21 SGFP, which tripped last shift while changing COPU Unit oil filters. 21B waterbox is out of service for cleaning and is expected to be completed this shift. All other equipment is operating normally with all controls in automatic. Orders for the shift are to continue the power ascension to 100% power at 10% /hr.

Event No.	Malf. No.	Event Type*	Event Description
1		N CRS R PO R RO	Perform a normal power ascension to 100% power.
2	RC0014	I CRS RO	22 Loop T _{hot} fails High
3	VC0087	C CRS PO	22 Vacuum Pump Trip
4	CN0112	I CRS PO	Hotwell Level Transmitter fails low
5	RC0012 RC0004	C CRS RO	22 RCP High Vibration 22 RCP Trip (If RCP is not manually tripped)
6	RP0058 & RP0059	M ALL	Failure of the Reactor to Trip-Auto and Manual (Rods in when breakers opened manually)
7	RC0001	M ALL	LBLOCA on 22 RC Loop (Short delay after the trip)
8	RH0026 RH0128	C ALL	21 RHR Pump Trip (Trip when near placing Recirc in service) 22 RH4 Fails Open (Breaker is open, but can be closed)

* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor

Facility: Salem Examination Level: RO		Date of Examination: 02/22/98 Operating Test Number:
Administrative Topic/Subject Description		Describe method of evaluation: 1. ONE Administrative JPM, OR 2. TWO Administrative Questions
A1	QPTR JPM	2.1.7 3.7 - Ability to evaluate plant performance and make operational judgments based on operating characteristics, reactor behavior, and instrument interpretation. Perform a Quadrant Power Tilt Ratio Calculation
	Temporary Modification of Procedures JPM	2.1.1 3.7 - Knowledge of conduct of operations requirements Prepare a Temporary Modification to a procedure.
A.2	Action Requests JPM	2.2.24 2.6 - Ability to analyze the effect of maintenance activities on LCO status. Maintenance activities and effects on Tech Specs
A.3	Radiation Protection	2.3.4 2.5 - Knowledge of radiation exposure limits and contamination control, including permissible levels in excess of those authorized Given an emergency situation, determine the allowable stay time.
		2.3.10 2.9 - Ability to perform procedures to reduce excessive levels of radiation and guard against personnel exposure. Special requirements for containment entry during Mode 1.
A.4	Emergency Plan JPM	2.4.39 3.3 - Knowledge of RO's responsibilities in Emergency Plan implementation. Activate the ERDS as Secondary Communicator

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

STATION: SALEM
SYSTEM: Administrative
TASK: Calculate a Quadrant Power Tilt Ratio
TASK NUMBER: 114 503 03 01
JPM NUMBER: WD-ROA1.1
APPLICABILITY:

EO RO SRO

K/A NUMBER: 2.1.7
IMPORTANCE FACTOR: 3.7 / 4.4
RO SRO

EVALUATION SETTING/METHOD: CLASSROOM
REFERENCES: S2.OP-ST.NIS-0002
TOOLS AND EQUIPMENT:
VALIDATED JPM COMPLETION TIME: 15 minutes
TIME PERIOD FOR TIME CRITICAL STEPS: N/A
APPROVED: _____

PRINCIPAL TRAINING SUPERVISOR

OPERATIONS MANAGER

CAUTION: No plant equipment shall be operated during the performance of a JPM without the following:

1. Permission from the SNSS or Unit NSS;
2. Direct oversight by a qualified individual (determined by the individual granting permission based on plant conditions);
3. Verification of the "as left" condition by a qualified individual.

ACTUAL TIME TO COMPLETE JPM:

JPM PERFORMED BY:

GRADE: SAT UNSAT

REASON, IF UNSATISFACTORY:

EVALUATOR'S SIGNATURE:

DATE:

JOB PERFORMANCE MEASURE

NAME: _____

DATE: _____

SYSTEM: Administrative

TASK: Calculate A Quadrant Power Tilt Ratio

TASK NUMBER: 114 503 03,01

INITIAL CONDITIONS: Reactor Power has been maintained at 100% for the last 180 days

INITIATING CUE: The following detector voltages have been recorded from the Power Range NI Detectors:

	N41	N42	N43	N44
UPPER	245	256	246	237
LOWER	259	281	249	235

You have been directed to calculate the existing Quadrant Power Tilt Ratio.

Successful Completion Criteria:

1. All critical steps completed
2. All sequential steps completed in order
3. All time-critical steps completed within allotted time
4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made (and NRC concurrence is obtained).

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

Name: _____
Date: _____

System: ADMINISTRATIVE

Task: CALCULATE A QUADRANT POWER TILT RATIO

# *	STEP NO.	STEP (* Denotes a Critical Step) (# Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT evaluation)
NOTE: Refer to the completed Attachments 1 & 2 for the standard.					
		Obtains procedure S2.OP-ST.NIS-0002(Q)	Obtains correct procedure. <i>NOTE: This is a Category I procedure. Work Standards require that the operator refer to the procedure at each step of the task. Individual step documentation shall be complete prior to preceding to the next step</i>		
	5.1.1	If one Power Range Channel is inoperable and reactor thermal power is >75%, ...	Determines all 4 Power Range Channels operable.		
	5.1.2	Record the following data on Attachment 2: A. Date B. Time C. Reactor Power D. Reason for performing QPTR Calculation	Records data on Attachment.		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

Name: _____
Date: _____

System: ADMINISTRATIVE

Task: CALCULATE A QUADRANT POWER TILT RATIO

# *	STEP NO.	STEP (* Denotes a Critical Step) (# Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT evaluation)
	5.1.3	<p>RECORD the following:</p> <p>NI Channels N-41, N-42, N-43 and N-44 <u>Upper</u> Detector current readings, (Power Range B, Detector A, 0-500 milli-amperes scale)</p> <p>NI Channels N-41, N-42, N-43 and N-44 <u>Lower</u> Detector current readings, (Power Range B, Detector B, 0-500 milli-amperes scale)</p> <p>The respective 100% NI Current Values for Channels N-41, N-42, N-43 and N-44 Detectors from S2.RE-RA.ZZ-0011, (RE Manual), Table 2</p>	<p>Transfers Upper Detector currents to Attachment 1</p> <p>Transfers Lower Detector currents to Attachment 1</p> <p>Locates and records 100% currents from S2.RE-RA.ZZ-0011, (RE Manual), Table 2</p>		
	5.1.4	Complete calculations	Completes calculations within accuracy of <u>+0.01</u>		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

Name: _____
Date: _____

System: ADMINISTRATIVE

Task: CALCULATE A QUADRANT POWER TILT RATIO

# *	STEP NO.	STEP (* Denotes a Critical Step) (# Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT evaluation)
*	5.1.5	Record the following on Attachment 2: Power Tilt for each Detector Maximum Power Tilt and applicable detector identification information Test results by initializing the SAT or UNSAT column IAW the stated Acceptance Criteria	Transfers Power Tilt data to Attachment 2 Correctly identifies maximum upper and maximum power tilts and records data. Determines N43 upper has a tilt of 1.022 (1.02-1.024)* and initials UNSAT*		

Terminating Cue: Initials Attachment Test Results.

INTENTIONALLY
BLANK

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE
(To be provided to the candidate)**

INITIAL CONDITIONS:

Reactor Power has been maintained at 100% for the last 180 days

INITIATING CUE:

The following detector voltages have been recorded from the Power Range NI Detectors:

	N41	N42	N43	N44
UPPER	245	256	246	237
LOWER	259	281	249	235

You have been directed to calculate the existing Quadrant Power Tilt Ratio.

**ATTACHMENT 1
(Page 1 of 1)**

QPTR CALCULATION DATA

1.0 UPPER DETECTORS

Detector Current) 100% NI Value	= Detector Ratio) Average Upper Detector Ratio	= Power Tilt (1)
N41T= 245	246.9	0.992305	1.000958	0.991
N42T= 256	257.3	0.994946		0.994
N43T= 246	240.5	1.022869		1.022
N44T=237	238.5	0.993711		0.993
Sum of Detector Ratios		= 4.003831		
# of Operable Detectors) 4		
Average Upper Detector Ratio		= 1.000958		
Independent Verification of calculation performed by:				

2.0 LOWER DETECTORS

Detector Current) 100% NI Value	= Detector Ratio) Average Lower Detector Ratio	= Power Tilt (1)
N41B= 259	261.1	0.991957	0.999558	0.992
N42B= 281	283.6	0.99832		0.991
N43B= 249	244.6	1.017989		1.018
N44B= 235	235.6	0.997453		0.998
Sum of Detector Ratios		= 3.998231		
# of Operable Detectors		= 4		
Average Lower Detector Ratio		=0.999558		
Independent Verification of calculation performed by:				

(1) Record Power Tilt to three (3) significant digits to the right of the decimal.

**ATTACHMENT 2
(Page 1 of 1)**

QPTR TEST DATA

Date:	Time:	Reactor Power:	%
-------	-------	----------------	---

REASON FOR PERFORMING QPTR: (Check as applicable)

- Unit in Mode 1 operating at > 50% thermal power.
- Unit in Mode 1 operating at # 50% thermal power and verification that QPTR is within limits prior to exceeding 50% thermal power.
- OHA E-38 or E-46 annunciated or is inoperable and thermal power is > 50%.
- IAW LCO 3.3.1.1 Action 2c, One Power Range Channel is inoperable AND Trip setpoints are > 85% or thermal power is > 75%.

Upper Detector	Power Tilt (1)	Lower Detector	Power Tilt (1)
N41T	0.991	N41B	0.992
N42T	0.994	N42B	0.991
N43T	1.022	N43B	1.018
N44T	0.993	N44B	0.998

Maximum Power Tilt (1)	Detector	Acceptance Criteria	Test Results	
			SAT	UNSAT
1.022	N43 Upper	# 1.02 and (2)		X
1.018	N43 Lower		X	

- (1) Carry forward the Power Tilt value on Attachment 1 with three significant digits to the right of the decimal.
- (2) IAW Tech. Spec. 3.3.1.1, Action 2c and d, when applicable, the 3 channel QPTR is verified consistent with Reactor Engineering Flux Map to satisfy surveillance requirement 4.2.4.2.

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

STATION: SALEM
SYSTEM: Administrative
TASK: Prepare a Temporary Modification to a Procedure
TASK NUMBER:
JPM NUMBER: WD-ROA1.2
APPLICABILITY:

EO RO SRO

K/A NUMBER: 2.1.1
IMPORTANCE FACTOR: 3.7 / 3.8
RO SRO

EVALUATION SETTING/METHOD: CLASSROOM
REFERENCES: NC.NA-AP.ZZ0001(Q)

TOOLS AND EQUIPMENT:

VALIDATED JPM COMPLETION TIME: 15 minutes
TIME PERIOD FOR TIME CRITICAL STEPS: N/A

APPROVED:

PRINCIPAL TRAINING SUPERVISOR

OPERATIONS MANAGER

CAUTION: No plant equipment shall be operated during the performance of a JPM without the following:

1. Permission from the SNSS or Unit NSS;
2. Direct oversight by a qualified individual (determined by the individual granting permission based on plant conditions);
3. Verification of the "as left" condition by a qualified individual.

ACTUAL TIME TO COMPLETE JPM:

JPM PERFORMED BY:

GRADE: SAT UNSAT

REASON, IF UNSATISFACTORY:

EVALUATOR'S SIGNATURE:

DATE:

JOB PERFORMANCE MEASURE

NAME: _____

DATE: _____

SYSTEM: Administrative

TASK: Prepare a Temporary Modification to a Procedure

TASK NUMBER:

INITIAL CONDITIONS: During the performance of S2.OP-ST.CS-0001, In-service Testing-21 Containment Spray Pump, 21CS11 was determined to be stuck in the full open position. Management has made the decision to make an OTSC to the procedure to allow the Test to be completed.

INITIATING CUE: The CRS directs you to initiate an OTSC to change S2.OP-ST.CS-0001:

- Step 5.1.21 to "Verify 22CS11 is CLOSED".
- Attachment 4 verification of 21CS11 to 22CS11

Following the performance of the test, a Tagout will be hung to affect repairs to 21CS11.

Successful Completion Criteria:

1. All critical steps completed
2. All sequential steps completed in order
3. All time-critical steps completed within allotted time
4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made (and NRC concurrence is obtained).

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

Name: _____
Date: _____

System: ADMINISTRATIVE

Task: PREPARE A TEMPORARY MODIFICATION TO A PROCEDURE

# *	TEP NO.	STEP (* Denotes a Critical Step) (# Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT evaluation)
		Obtain NC.NA-AP.ZZ-0001(Q)	Procedure and/or applicable sections may be provided by the Evaluator		
	A	Discuss the proposed OTSC with the Job Supervisor. If there is a change of intent involved, an OTSC shall not be used.	CUE: As Job Supervisor, inform candidate that no intent change is involved and no TSAS will apply to the change.		
	B	Obtain the latest revision of the procedure to serve as the "OTSC-Original" including copies of any outstanding OTSCs impacting the proposed change.	CUE: Provide candidate with a copy of the procedure.		
*	C	Assign a OTSC #. <ul style="list-style-type: none"> • Use current revision number followed by a sequential letter. • If a temporary OTSC, complete the OTSC# with T and identify the expected duration. List procedure pages changed on Page 1 of Form-4 • Complete Page 1 up to and including Initiator signature. • Attach the entire Form-4 to the "OTSC- Original" 	CUE: Inform candidate that the change is temporary and will only be applicable this test. <ul style="list-style-type: none"> • The candidate assigns the number OTSC# 9A-T. • The candidate lists procedure pages 7 & 26 as changed pages. • The candidate completes and signs Form 4. 		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

Name: _____

Date: _____

System: ADMINISTRATIVE

Task: PREPARE A TEMPORARY MODIFICATION TO A PROCEDURE

# *	TEP NO.	STEP (* Denotes a Critical Step) (# Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT evaluation)
*	D	<p>Mark-up the "OTSC-Original" with the required changes.</p> <p>Identify changes by placing revision bars and OTSC change number in the right margin.</p> <p>Ensure previously approved OTSCs for the current revision are not adversely affected.</p>	<p>The candidate changes Step 5.1.21 to read:</p> <ul style="list-style-type: none"> • "VERIFY CLOSED 22CS11, 22 CS Pump Flow Test Stop Valve.. • Places a rev bar and the OTSC # in the right hand margin adjacent to Step 5.1.21. • The candidate changes the Attachment 4 verification of 21CS11 to read: • "22CS11, 22 CS Pump Flow Test Stop Valve, X". • Places a rev bar and the OTSC # in the right hand margin adjacent to the 22CS11 verification line. 		
	E	Submit the OTSC and Form 4 to the CRS.	The candidate submits the OTSC and Form 4 to the CRS.		

Terminating Cue: The CRS acknowledges receipt of the OTSC. The JPM is Terminated.

TEAR OFF SHEET FOR CANDIDATE

INITIAL CONDITIONS: During the performance of S2.OP-ST.CS-0001, In-service Testing-21 Containment Spray Pump, 21CS11 was determined to be stuck in the full open position. Management has made the decision to make an OTSC to the procedure to allow the test to be completed.

INITIATING CUE: The CRS directs you to initiate an OTSC to change S2.OP-ST.CS-0001:

- Step 5.1.21 to "Verify 22CS11 is CLOSED".
- Attachment 4, verification of 21CS11 to 22CS11

Following the performance of the test, a Tagout will be hung to affect repairs to 21CS11.

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

STATION: Salem 1 & 2
SYSTEM: Administrative
TASK: Initiate a manual Action Request (Form 1)
TASK NUMBER: 1145340104

JPM NUMBER: Admin 2 RO

APPLICABILITY: EO RO SRO K/A NUMBER: 2.1.14
IMPORTANCE FACTOR:

2.5	3.3
RO	SRO

EVALUATION SETTING/METHOD: Control Room/Simulator; Simulate

REFERENCES: NC.NA-AP.ZZ-0000(Q) Action Request Process

TOOLS AND EQUIPMENT:

VALIDATED JPM COMPLETION TIME: 15 MINUTES

TIME PERIOD IDENTIFIED FOR TIME CRITICAL STEPS: _____

APPROVED: _____
PRINCIPAL TRAINING SUPERVISOR OPERATIONS MANAGER

CAUTION: No plant equipment shall be operated during the performance of a JPM without the following:

1. Permission for the SNSS Or Unit NSS;
2. Direct oversight by a qualified individual (determined by the individual granting permission based on plant conditions).
3. Verification of the "as left" condition by a qualified individual.

ACTUAL JPM COMPLETION TIME: _____
ACTUAL TIME CRITICAL COMPLETION TIME: _____
JPM PERFORMED BY: _____ GRADE: SAT UNSAT
REASON, IF UNSATISFACTORY:
EVALUATOR'S SIGNATURE: _____ DATE: _____

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

SYSTEM: Administrative

TASK: Initiate a manual Action Request

TASK NUMBER:

INITIAL CONDITIONS:

1. Both Units are operating at 100% power.
2. You are an Extra Operator assigned to perform Administrative Tasks for the Shift.
3. The Unit 2 Reactor Operator had been adjusting the Master Flow Controller to restore Pressurizer Level to program following the transfer to 21 Charging Pump. The Operator reports that the Flow Demand Indication, FI-459B has stopped responding at 38%.
4. It has been determined only the controller demand indication is affected. System flow and 2CV55 position have been verified to be responding appropriately.

INITIATING CUE:

The CRS has directed you to initiate a manual Action Request, Form 1 for the Master Flow Controller. The computer is UNavailable.

Successful Completion Criteria:

1. All critical steps completed.
2. All sequential steps completed in order.
3. All time-critical steps completed within allotted time.
4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made (and NRC concurrence is obtained).

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: Administrative

TASK: Initiate a manual Action Request

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
		Obtain FORM 1	Locates blank FORM 1 sheet. and procedure NC.NA-AP.ZZ-0000(Q).		
*	5.3.5	Determine Action Request type	Determines AR is CM (Corrective Maintenance) type and marks on FORM 1		
<p>NOTE: Since there is no space for a response to the following step on the manual form, the candidate may state a CR is not required in the description block or may skip this step.</p>					
*	5.3.6	Indicate a CR is required using the CR REQUIRED (Y/N) field when...	Determine CR is not required for Significance Level 3 CM type and indicates Not Required on FORM 1.		
	5.3.7	Document an Action Request Code	Determines MMIS code and enters _____ OR leaves blank (optional) on FORM 1.		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

SYSTEM: Administrative

TASK: Initiate a manual Action Request

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
*	5.3.8	Describe the condition in sufficient detail and clarity such that additional explanation beyond the text of the AR is not required for review or approval	Describes condition on FORM 1, to include (at least) <ul style="list-style-type: none"> Unit, component identification number, noun name and system – Unit 2, Master Flow Controller List symptoms and the effect the condition has on plant operations - Failure of the controller flow demand indication to respond (Appears stuck at 38%) Initiating alarm/indication (control room and local) and any indications that were unusual or abnormal for the plant conditions - Operator noted Charging System Flow changing but controller flow demand indication was not. 2CV55 was verified to be responding locally. 		
*	5.3.9	Recommend a significance level.	Refers to Attachment 3 and determines Significance Level is Level 3 and records on FORM 1		
	5.3.15	When a Condition Resolution is required, a Department Verification (CRDV) may be created in accordance with NAP-6.	Indicates that CRDV should be initiated. CUE: AR Review will ensure CRDV is completed.		

Terminating CUE: When the Operator indicates AR is ready for Reviewer, the JPM may be terminated.

JOB PERFORMANCE MEASURE

ACTION REQUEST FORM

Part A. To be completed by the Initiator		
(1) Department identifying concern: Salem Operations	(2) Unit Designator: HC <input type="checkbox"/> S2 <input checked="" type="checkbox"/> SC <input type="checkbox"/> S1 <input type="checkbox"/> S3 <input type="checkbox"/> CA <input type="checkbox"/>	
(3) Describe the actual condition or event (add additional pages as needed): The Flow Demand indication for the Master Flow Controller FI-459B does not respond to demand changes greater than 38%. The controller output and the Charging System components have been verified to be responding appropriately. - Operator noted Charging System Flow changing but controller flow demand indication was not. - 2CV55 was verified locally to be responding properly. Step 5.3.6 - CR Not required.		
(4) EMIS Tag Hung? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> If Yes, what is the location of the EMIS tag? _____ EMIS Tag No. _____	(5) Component Description. Master Flow Controller Demand indication FI-459B (6) Component Location: CC2	
(7) Initiator: _____ NAME _____	(8) Date: ___X___	(9) Time: ___X___

Part B. To be completed by the Reviewer			
(1) Action Request Type: CM <input checked="" type="checkbox"/> CR <input type="checkbox"/> BP <input type="checkbox"/> <i>Corrective Maintenance</i> <i>Condition Resolution</i> <i>Business Process (Sig. Lvl. "X" only)</i>	(2) Significance Level: 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input checked="" type="checkbox"/> X <input type="checkbox"/> NOTE: Immediately present Significance Level 1 or 2 conditions to the SRO Approver.		
(3) AR Code: _____	(4) System ID: ___Charging___	(5) Comp. ID: ___FI-459B___	(6) Action Request No: _____
(7) Reviewer: _____	(8) Date: _____	(9) Time: _____	

PROVIDE THIS SHEET TO THE CANDIDATE

INITIAL CONDITIONS:

- Both Units are operating at 100% power.
- You are an Extra Operator assigned to perform Administrative Tasks for the Shift.
- The Unit 2 Reactor Operator had been adjusting the Master Flow Controller to restore Pressurizer Level to program following the transfer to 21 Charging Pump. The Operator reports that the Flow Demand Indication, FI-459B has stopped responding at 38%.
- It has been determined only the controller demand indication is affected. System flow and 2CV55 position have been verified to be responding appropriately.

INITIATING CUE

The CRS has directed you to initiate a manual Action Request, Form 1 for the Master Flow Controller. The computer is UNavailable.

SALEM ADMIN QUESTIONS

RO

A3

PAGE 1 OF 1

CANDIDATE: _____ DOCKET: _____ DATE: _____

QUESTION: A leak has developed in the VCT Room and must be isolated. You have been assigned to perform the valve manipulations. Your annual dose is currently 122 mr. The general area dose rate where the valves are located is 1.3 R/hr. What is the longest time you can take manipulating the valves without exceeding the Salem administrative dose limit? (Do NOT consider access and egress time.)

ANSWER: The Administrative Annual dose limit is 2000 mr. Allowable Dose = 2000-122 = 1878 mr.
Max Time = $(1878/1300 \text{ mr/hr}) \times 60 \text{ min/hr} = \underline{1 \text{ hr. and } 27 \text{ min}}$ (1hr. and 22 mins. to 1 hr. and 27 minutes is acceptable band)

RESPONSE:

SAT _____ UNSAT _____ K/A NUMBER: 2.3.4 – 2.5/3.1

REFERENCES: NC.NA-AP.ZZ-0024, Radiation Protection Program, Rev. 8

QUESTION: A task must be performed that requires entry into a Locked Very High Radiation Area.

What specific requirements must be met prior to entry into this area?

- ANSWER:**
1. A Special RWP is required.
 2. Rad. Protection coverage is required.
 3. Must be an Operational or Safety reason for entry.
 4. Radiation Protection Manager and OS must be notified prior to entry.
 5. A brief on the radiological conditions in the area and the procedures to be followed in case area evacuation is required.
 6. Other requirements may be addressed.

RESPONSE:

SAT _____ UNSAT _____ K/A NUMBER: 2.3.10 – 2.9/3.3

REFERENCES: LP Radcon-00, Section X. Control of Access.
NC.NA-AP.ZZ-0024, Radiation Protection Program, Rev.8, Sections 5.7-5.9

SALEM ADMIN QUESTIONS

QUESTION:

A leak has developed in the VCT Room and must be isolated. You have been assigned to perform the valve manipulations. Your annual dose is currently 122 mr. The general area dose rate where the valves are located is 1.3 R/hr.

What is the longest time you can take manipulating the valves without exceeding the Salem administrative dose limit? (Do NOT consider access and egress time.)

SALEM ADMIN QUESTIONS

QUESTION: A task must be performed that requires entry into a Locked Very High Radiation Area.

What specific requirements must be met prior to entry into this area?

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

STATION: Salem 1 & 2
SYSTEM: Administrative
TASK: Activate ERDS as Secondary Communicator

TASK NUMBER: 1240100501

JPM NUMBER: Admin 4.1 RO

APPLICABILITY: EO RO SRO

K/A NUMBER: 2.4.27
IMPORTANCE FACTOR:

3.0	3.5
RO	SRO

EVALUATION SETTING/METHOD: Simulator

REFERENCES: ECG Attachment 8 Secondary Communicator Log

TOOLS AND EQUIPMENT:

VALIDATED JPM COMPLETION TIME: 5 mins (ERDS); 10 mins. (MEES)

TIME PERIOD IDENTIFIED FOR TIME CRITICAL STEPS: _____

APPROVED: _____
PRINCIPAL TRAINING SUPERVISOR OPERATIONS MANAGER

CAUTION: No plant equipment shall be operated during the performance of a JPM without the following:

1. Permission for the SNSS Or Unit NSS;
2. Direct oversight by a qualified individual (determined by the individual granting permission based on plant conditions).
3. Verification of the "as left" condition by a qualified individual.

ACTUAL JPM COMPLETION TIME: _____
ACTUAL TIME CRITICAL COMPLETION TIME: _____
JPM PERFORMED BY: _____ GRADE: SAT UNSAT
REASON, IF UNSATISFACTORY: _____
EVALUATOR'S SIGNATURE: _____ DATE: _____

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

SYSTEM: Administrative

TASK: Activate ERDS as Secondary Communicator

TASK NUMBER:

INITIAL CONDITIONS: Setup the Simulator with normal plant conditions for Shutdown Cooling using IC-??? and establish the following additional conditions:

- 21 & 22 RHR Pumps stopped
- Allow RCS Temperature to rise to 200°F and then snap the IC.

1. Unit 2 is in Mode 5.
2. Core cooling was being provided by the RHR System
3. An unplanned loss of all systems providing decay heat removal functions has occurred.
4. RCS temperature has exceeded 200°F.
5. The Emergency Plan has been implemented and an Alert declared.
6. You are assigned the responsibilities of Secondary Communicator.

INITIATING CUE:

The Operations Superintendent directs you to activate the Emergency Response Data System (ERDS) in accordance with Attachment 8 of the Emergency Classification Guide and complete the Major Equipment and Electrical Status Form.

Successful Completion Criteria:

1. All critical steps completed.
2. All sequential steps completed in order.
3. All time-critical steps completed within allotted time.
4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made (and NRC concurrence is obtained).

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

SYSTEM: Administrative

TASK: Activate ERDS as Secondary Communicator

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
NOTE: Obtain an up-to-date copy of ECG Attachment 8 prior to the start of the JPM.					
*	1	Locate Unit 2 ECG and obtain a copy of Attachment 8	The operator locates the Unit 2 ECG and obtains a copy of Attachment 8.		
CUE: When Attachment 8 of the ECG is located, provide the candidate with a copy.					
*	2	At a Unit 2 SPDS Terminal: PRESS "UNIT MASTER MENU" Key	The Operator presses the "UNIT MASTER MENU" key		
*	3	PRESS "ERDS" key	The Operator presses the "ERDS" key		
*	4	PRESS "SHIFT" and "1" keys	The Operator presses the "SHIFT" and "1" keys		
*	5	PRESS "Y" key to confirm	The Operator presses the "Y" key to confirm the selection		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

SYSTEM: Administrative

TASK: Activate ERDS as Secondary Communicator

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
*	6	PRESS "RETURN" key to execute	The Operator presses the "RETURN" key to execute and observes the following message displayed on the SPDS terminal: "ERDS Activation Accepted"		
*	7	Obtain a copy of the Major Equipment and Electrical Status Form	The Operator locates a copy of the Major Equipment and Electrical Status Form from ECG Attachment 8.		
		Determine and record the status of each component on the Major Equipment and Electrical Status Form	The Operator correctly determines and records the status of each component on the Major Equipment and Electrical Status Form.		

NOTE: Use the completed Major Equipment and Electrical Status Form, attached, as the standard.

Terminating Cue: When the Major Equipment and Electrical Status Form has been completed, the JPM may be terminated.

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: Administrative

TASK: Activate ERDS as Secondary Communicator

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
*	6	PRESS "RETURN" key to execute	The Operator presses the "RETURN" key to execute and observes the following message displayed on the SPDS terminal: "ERDS Activation Accepted"		
*	7	Obtain a copy of the Major Equipment and Electrical Status Form	The Operator locates a copy of the Major Equipment and Electrical Status Form from ECG Attachment 8.		
	8	Determine and record the status of each component on the Major Equipment and Electrical Status Form	<i>CUE:</i> For the purposes of this examination, log the equipment status as it is today The Operator correctly determines and records the status of each component on the Major Equipment and Electrical Status Form.		

NOTE: Use the completed Major Equipment and Electrical Status Form, attached, as the standard.

Terminating Cue: When the Major Equipment and Electrical Status Form has been completed, the JPM may be terminated.

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE
(To be provided to the candidate)**

INITIAL CONDITIONS:

1. Unit 2 is in Mode 5.
2. Core cooling was being provided by the RHR System.
3. An unplanned loss of all systems providing decay heat removal functions has occurred .
4. RCS temperature has exceeded 200°F.
5. The Emergency Plan has been implemented and an Alert declared.
6. You are assigned the responsibilities of Secondary Communicator.

INITIATING CUE:

The Operations Superintendent directs you to activate the Emergency Response Data System (ERDS) in accordance with Attachment 8 of the Emergency Classification Guide and complete the Major Equipment and Electrical Status Form.

Facility: Salem		Date of Examination: 2/22/98
Examination Level: SRO		Operating Test Number:
Administrative Topic/Subject Description		Describe method of evaluation: 1. ONE Administrative JPM, OR 2. TWO Administrative Questions
A.1	Valve Lineup JPM	2.1.29 3.3 - Knowledge of how to conduct and verify valve lineups. Perform a valve alignment verification surveillance.
	Perform a QPTR Surveillance JPM	2.1.7 4.4 - Ability to evaluate plant performance and make operational judgments based on operating characteristics, reactor behavior, and instrument interpretation. Perform a QPTR surveillance.
A.2	Surveillance Test Review JPM (FAULTED)	2.2.12 3.4 - Knowledge of surveillance procedures. Review a completed surveillance test on a Containment Spray Pump.
A.3	Radiation Protection	2.3.4 3.1 - Knowledge of radiation exposure limits and contamination control, including permissible levels in excess of those authorized. Determine Emergency Exposure Limits during a plant emergency.
		2.3.10 3.3 - Ability to perform procedures to reduce excessive levels of radiation and guard against personnel exposure. Special requirements necessary for personnel to enter a locked High Radiation Area.
A.4	Emergency Plan JPM	2.4.44 4.0 - Knowledge of Emergency Plan Protective Action Recommendations Determine PARs during a General Emergency.

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

STATION: SALEM
SYSTEM: Administrative
TASK: Perform a Valve Alignment Check of AFW Valves
TASK NUMBER: 0610100201
JPM NUMBER: WD-SROA.1.1
APPLICABILITY:

EO RO SRO

K/A NUMBER: 2.1.29
IMPORTANCE FACTOR: 3.4 / 3.3
RO SRO

EVALUATION PLANT
SETTING/METHOD:
REFERENCES: S2.OP-ST.AF-0008(Q)

TOOLS AND EQUIPMENT:

VALIDATED JPM COMPLETION TIME: 10 mins

TIME PERIOD FOR TIME CRITICAL STEPS: N/A

APPROVED: _____
PRINCIPAL TRAINING SUPERVISOR OPERATIONS MANAGER

CAUTION: No plant equipment shall be operated during the performance of a JPM without the following:

1. Permission from the OS or Unit CRS;
2. Direct oversight by a qualified individual (determined by the individual granting permission based on plant conditions);
3. Verification of the "as left" condition by a qualified individual.

ACTUAL TIME TO COMPLETE JPM: _____
JPM PERFORMED BY: _____ GRADE: SAT UNSAT
REASON, IF UNSATISFACTORY: _____
EVALUATOR'S SIGNATURE: _____ DATE: _____

JOB PERFORMANCE MEASURE

NAME: _____

DATE: _____

SYSTEM: Administrative

TASK: Perform a Valve Alignment Check of AFW Valves

TASK NUMBER:

INITIAL CONDITIONS: S2.OP-ST.AF-0008, Auxiliary Feedwater Valve Verification Modes 1-3 is in progress.

INITIATING CUE: You are to perform 2LCK SURV 002 for the Inner Penetration Area, Elevation 100 IAW S2.OP-ST.AF-0008, Auxiliary Feedwater Valve Verification Modes 1-3.

Successful Completion Criteria:

1. All critical steps completed
2. All sequential steps completed in order
3. All time-critical steps completed within allotted time
4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made (and NRC concurrence is obtained).

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

Name: _____
Date: _____

System: ADMINISTRATIVE

Task: Perform a Valve Alignment Check of AFW Valves

# *	STEP NO.	STEP (* Denotes a Critical Step) (# Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT evaluation)
	1	Obtain Auxiliary Feedwater Valve Verification Modes 1-3 procedure, S2.OP-ST.AF-0008.	<i>CUE:</i> Provide the candidate with a copy of S2.OP-ST.AF-0008, Auxiliary Feedwater Valve Verification Modes 1-3 and a copy of 2LCK SURV 002 for the Inner Penetration Area, Elevation 100'.		
	2	Read the Lineup Sheet and locate the Unit, System and Components to be verified.	The operator reads the lineup sheet and locates the Unit, System and Components to be verified.		
*	3	Perform the following for each valve:	The operator performs the following for each		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

Name: _____

Date: _____

System: **ADMINISTRATIVE**

Task: **Perform a Valve Alignment Check of AFW Valves**

# *	STEP NO.	STEP (* Denotes a Critical Step) (# Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT evaluation)
		<ul style="list-style-type: none"> - Locate the valve - Verify the valve ID - Verify the valve is properly locked - Verify the valve is in the correct position. Record the As-Found position of the valve and initial for the verification. 	valve: <ul style="list-style-type: none"> - Locates the valve in the plant. - Verifies the valve ID by comparing the ID Tag with the Lineup Sheet - Verifies the valve is properly locked by observing the locking device is intact and positioned such that the valve operator cannot be positioned to move the valve stem. - Verifies the valve is in the correct position by observing the local position indicator and/or valve stem position. - Records the As-Found position of the valve and initials for the verification. 		
	4	When all valves have been verified, sign and date the bottom of each Lineup Sheet.	When all valves have been verified, the candidate signs and dates the bottom of each Lineup Sheet.		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

Name: _____

Date: _____

System: **ADMINISTRATIVE**

Task: **Perform a Valve Alignment Check of AFW Valves**

# *	STEP NO.	STEP (* Denotes a Critical Step) (# Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT evaluation)
	5	Inform the Control Room Supervisor when the lineup is complete.	The candidate informs the Control Room Supervisor of task completion.		

Terminating Cue: **CRS notified**

THIS SHEET SHOULD BE PROVIDED TO THE CANDIDATE

INITIAL CONDITIONS: S2.OP-ST.AF-0008, Auxiliary Feedwater Valve Verification Modes 1-3 is in progress.

INITIATING CUE: You are to perform 2LCK SURV 002 for the Inner Penetration Area, Elevation 100, IAW S2.OP-ST.AF-0008, Auxiliary Feedwater Valve Verification Modes 1-3.

SALEM 2 Unit: S2 Opmode: 1 Printer: TSR1 01/20/99 13:44
Blocking Point Lineup Completion BROWS

Command ==>

Unit: S2 + System : 2LCK + Type: SURV + ID: 002 +
Area: 13 Elevation: 100 Opmode: 1 Verification Nbr: 1

Blocking Pt#	Norm Pos	Tris Pos	Remarks	Current Status
21AF23	LO	LO		NORMAL
21MS45	LO	LO		NORMAL
23AF23	LO	LO		NORMAL
23MS45	LO	LO		NORMAL

F3 Cancel F4 Commit F6 Edit F7 Back F8 Forward F9 Help F11 Prompt

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

STATION: SALEM
SYSTEM: Administrative
TASK: Calculate a Quadrant Power Tilt Ratio
TASK NUMBER: 0150020201
JPM NUMBER: WD-SROA1.2
APPLICABILITY:

EO RO SRO

K/A NUMBER: 2.1.7
IMPORTANCE FACTOR: 3.7 / 4.4
RO SRO

EVALUATION SETTING/METHOD: CLASSROOM

REFERENCES:

TOOLS AND EQUIPMENT:

VALIDATED JPM COMPLETION TIME: 18 minutes

TIME PERIOD FOR TIME CRITICAL STEPS: N/A

APPROVED:

PRINCIPAL TRAINING SUPERVISOR

OPERATIONS MANAGER

CAUTION: No plant equipment shall be operated during the performance of a JPM without the following:

1. Permission from the SNSS or Unit NSS;
2. Direct oversight by a qualified individual (determined by the individual granting permission based on plant conditions);
3. Verification of the "as left" condition by a qualified individual.

ACTUAL TIME TO COMPLETE JPM: _____
JPM PERFORMED BY: _____ GRADE: SAT UNSAT
REASON, IF UNSATISFACTORY:
EVALUATOR'S SIGNATURE: _____ DATE: _____

JOB PERFORMANCE MEASURE

JOB PERFORMANCE MEASURE _____

NAME: _____

DATE:

SYSTEM: Administrative

TASK: Calculate A Quadrant Power Tilt Ratio

TASK NUMBER: 114 503 03 01

INITIAL CONDITIONS: Reactor Power has been maintained at 100% for the last 180 days

INITIATING CUE: The following detector voltages have been recorded from the Power Range NI Detectors:

	N41	N42	N43	N44
UPPER	245	256	246	237
LOWER	259	281	249	235

You have been directed to calculate the existing Quadrant Power Tilt Ratio.

Successful Completion Criteria:

1. All critical steps completed
2. All sequential steps completed in order
3. All time-critical steps completed within allotted time
4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made (and NRC concurrence is obtained).

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

System: ADMINISTRATIVE

Task: CALCULATE A QUADRANT POWER TILT RATIO

# *	STEP NO.	STEP (* Denotes a Critical Step) (# Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT evaluation)
NOTE: Refer to the completed Attachments 1 & 2 for the standard.					
		Obtains procedure S2.OP-ST.NIS-0002(Q)	Obtains correct procedure. <i>NOTE: This is a Category I procedure. Work Standards require that the operator refer to the procedure at each step of the task. Individual step documentation shall be complete prior to preceding to the next step</i>		
	5.1.1	If one Power Range Channel is inoperable and reactor thermal power is >75%,	Determines all 4 Power Range Channels operable.		
	5.1.2	Record the following data on Attachment 2: Date Time Reactor Power Reason for performing QPTR	Records data on Attachment.		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

System: ADMINISTRATIVE

Task: CALCULATE A QUADRANT POWER TILT RATIO

# *	STEP NO.	STEP (* Denotes a Critical Step) (# Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT evaluation)
	5.1.3	<p>RECORD the following:</p> <p>NI Channels N-41, N-42, N-43 and N-44 <u>Upper</u> Detector current readings, (Power Range B, Detector A, 0-500 milli-amperes scale)</p> <p>NI Channels N-41, N-42, N-43 and N-44 <u>Lower</u> Detector current readings, (Power Range B, Detector B, 0-500 milli-amperes scale)</p> <p>The respective 100% NI Current Values for Channels N-41, N-42, N-43 and N-44 Detectors from S2.RE-RA.ZZ-0011, (RE Manual), Table 2</p>	<p>Transfers Upper Detector currents to Attachment 1</p> <p>Transfers Lower Detector currents to Attachment 1</p> <p>Locates and records 100% currents from S2.RE-RA.ZZ-0011, (RE Manual), Table 2</p>		
	5.1.4	Complete calculations	Completes calculations within accuracy of <u>+0.01</u>		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

System: **ADMINISTRATIVE**

Task: **CALCULATE A QUADRANT POWER TILT RATIO**

# *	STEP NO.	STEP (* Denotes a Critical Step) (# Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT evaluation)
*	5.1.5	Record the following on Attachment 2: <ul style="list-style-type: none"> • Power Tilt for each Detector • Maximum Power Tilt and applicable detector identification information • Test results by initializing the SAT or UNSAT column IAW the stated Acceptance Criteria 	<ul style="list-style-type: none"> • Transfers Power Tilt data to Attachment 2 • Correctly identifies maximum upper and maximum power tilts and records data. • Determines N43 upper has a tilt of 1.022 (1.02-1.024)* and initials UNSAT* 		
	5.1.6	DIRECT a second Operator to perform Independent Verification of calculations in Attachment 1.	<p>The candidate requests second operator to perform Independent Verification of calculations in Attachment 1.</p> <p>CUE: The calculations of Attachment 1 have been verified to be correct.</p>		
*	5.1.7	IF the Maximum Power Tilt for <u>any</u> detector exceeds 1.02, THEN REFER to Technical Specifications 3.2.4 for corrective actions	The Operator refers to Technical Specifications 3.2.4 and determines Action a. is applicable.		

Terminating Cue: When the Tech Spec Action has been identified, the JPM may be terminated.

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE
(To be provided to the candidate)**

INITIAL CONDITIONS:

Reactor Power has been maintained at 100% for the last 180 days

INITIATING CUE:

The following detector voltages have been recorded from the Power Range NI Detectors:

	N41	N42	N43	N44
UPPER	245	256	246	237
LOWER	259	281	249	235

You have been directed to calculate the existing Quadrant Power Tilt Ratio.

ATTACHMENT 1

(QPTR CALCULATION DATA

1.0 UPPER DETECTORS

Detector Current) 100% NI Value	= Detector Ratio) Average Upper Detector Ratio	= Power Tilt (1)
N41T= 245	246.9	0.992305	1.000958	0.991
N42T= 256	257.3	0.994946		0.994
N43T= 246	240.5	1.022869		1.022
N44T=237	238.5	0.993711		0.993
Sum of Detector Ratios		= 4.003831		
# of Operable Detectors) 4		
Average Upper Detector Ratio		= 1.000958		
Independent Verification of calculation performed by:				

2.0 LOWER DETECTORS

Detector Current) 100% NI Value	= Detector Ratio) Average Lower Detector Ratio	= Power Tilt (1)
N41B= 259	261.1	0.991957	0.999558	0.992
N42B= 281	283.6	0.99832		0.991
N43B= 249	244.6	1.017989		1.018
N44B= 235	235.6	0.997453		0.998
Sum of Detector Ratios		= 3.998231		
# of Operable Detectors		= 4		
Average Lower Detector Ratio		=0.999558		
Independent Verification of calculation performed by:				

(1) Record Power Tilt to three (3) significant digits to the right of the decimal.

**ATTACHMENT 2
(Page 1 of 1)**

QPTR TEST DATA

Date:	Time:	Reactor Power:	%
-------	-------	----------------	---

REASON FOR PERFORMING QPTR: (Check as applicable)

- Unit in Mode 1 operating at > 50% thermal power.
- Unit in Mode 1 operating at # 50% thermal power and verification that QPTR is within limits prior to exceeding 50% thermal power.
- OHA E-38 or E-46 annunciated or is inoperable and thermal power is > 50%.
- IAW LCO 3.3.1.1 Action 2c, One Power Range Channel is inoperable AND Trip setpoints are > 85% or thermal power is > 75%.

Upper Detector	Power Tilt (1)	Lower Detector	Power Tilt (1)
N41T	0.991	N41B	0.992
N42T	0.994	N42B	0.991
N43T	1.022	N43B	1.018
N44T	0.993	N44B	0.998

Maximum Power Tilt (1)	Detector	Acceptance Criteria	Test Results	
			SAT	UNSAT
1.022	N43 Upper	# 1.02 and (2)		X
1.018	N43 Lower		X	

- (1) Carry forward the Power Tilt value on Attachment 1 with three significant digits to the right of the decimal.
- (2) IAW Tech. Spec. 3.3.1.1, Action 2c and d, when applicable, the 3 channel QPTR is verified consistent with Reactor Engineering Flux Map to satisfy surveillance requirement 4.2.4.2.

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

STATION: SALEM
SYSTEM: Administrative
TASK: Review a completed surveillance test
TASK NUMBER: 1230300302
JPM NUMBER: WD-SROA.2
APPLICABILITY:

EO RO SRO

K/A NUMBER: 2.2.12

IMPORTANCE FACTOR: 3.0 / 3.4
RO SRO

EVALUATION SETTING/METHOD: CLASSROOM

REFERENCES: S1.OP-ST.CS-0001(Q) ; S1.RA-ST.CS-0001(Q)

TOOLS AND EQUIPMENT:

VALIDATED JPM COMPLETION TIME: 20 min

TIME PERIOD FOR TIME CRITICAL STEPS: N/A

APPROVED:

PRINCIPAL TRAINING SUPERVISOR

OPERATIONS MANAGER

CAUTION: No plant equipment shall be operated during the performance of a JPM without the following:

1. Permission from the SNSS or Unit NSS;
2. Direct oversight by a qualified individual (determined by the individual granting permission based on plant conditions);
3. Verification of the "as left" condition by a qualified individual.

ACTUAL TIME TO COMPLETE JPM: _____

JPM PERFORMED BY: _____ GRADE: SAT UNSAT

REASON, IF UNSATISFACTORY:

EVALUATOR'S SIGNATURE:

DATE:

JOB PERFORMANCE MEASURE

NAME: _____

DATE: _____

SYSTEM: Administrative

TASK: Review a completed surveillance test

TASK NUMBER:

INITIAL CONDITIONS: The unit is in Mode 1. A regularly scheduled surveillance test is in progress on the 11 Containment Spray Pump. The procedure has been completed through step 5.2.21.

INITIATING CUE: You are the CRS. Beginning at Step 5.2.22, complete the procedure and initiate action, as necessary.

Successful Completion Criteria:

1. All critical steps completed
2. All sequential steps completed in order
3. All time-critical steps completed within allotted time
4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made (and NRC concurrence is obtained).

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

System: ADMINISTRATIVE

Task: REVIEW A COMPLETED SURVEILLANCE TEST

# *	STEP NO.	STEP (* Denotes a Critical Step) (# Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT evaluation)
		Provide the candidate with the completed surveillance test S1.OP-ST.CS-0001(Q), Inservice Testing - 11 Containment Spray Pump and S1.RA-ST.CS-0001, Inservice Testing - 11 Containment Spray Pump Acceptance Criteria.	Candidate reviews procedures		
*	5.2.22	Record the Test Results by initialing the SAT or UNSAT column using the Acceptance Criteria in Attachment 2. Section 3.0 and 4.0	<p>The candidate reviews the data of sections 3.0 & 4.0 of Attachment 2.</p> <p>Compares the data with the acceptance criteria in S1.RA-ST.CS-0001, Inservice Testing - 11 Containment Spray Pump Acceptance Criteria.</p> <p>Determines the vibration data point status and initials the appropriate column as follows:</p> <ul style="list-style-type: none"> ▪ Pt. 126 - Alert Range, SAT ▪ Pt. 127 - Alert Range, SAT ▪ Pt. 128 - Required Action, UNSAT ▪ Pt. 129 - Alert Range, SAT <p>Determines Pump flow rate to be SAT and initials the SAT column.</p> <p align="center">(cont'd on next page)</p>		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

System: ADMINISTRATIVE

Task: REVIEW A COMPLETED SURVEILLANCE TEST

# *	STEP NO.	STEP (* Denotes a Critical Step) (# Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT evaluation)
			Determines Pump Differential Pressure to be UNSAT and initials the UNSAT column.		
	5.2.23	IF this surveillance is being performed to establish new baseline data THEN IST Program Manager PERFORM the following:	CUE: Initial Conditions stated that the surveillance was regularly scheduled. Candidate marks this step N/A.		
	5.3.1	If surveillance is satisfactory...	Candidate marks this step N/A		
*	5.3.2	If surveillance is unsatisfactory	The candidate indicates an AR should be prepared to correct the situation. CUE: After the candidate states that an AR should be prepared, inform him that the AR # 99-XXX has been completed. The Candidate records the AR # for the UNSAT (Low DP) in Attachment 6.		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

System: ADMINISTRATIVE

Task: REVIEW A COMPLETED SURVEILLANCE TEST

# *	STEP NO.	STEP (* Denotes a Critical Step) # Denotes a Sequential Step	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT evaluation)
<p>NOTE: If the Candidate indicates the Test could be re-run to verify data, then:</p> <p>CUE: The surveillance will not be run prior to repairs to the pump.</p>					
	5.4.1	IF testing is complete, THEN Direct Maintenance Controls to REMOVE temporary test equipment and INITIAL and DATE the Removal in Attachment 1, Section 3.0	The Candidate informs I&C to remove the temporary test equipment and INITIAL and DATE the removal in Attachment 1, Section 3.0 and initials the step. CUE: I&C acknowledges.		
	5.4.2	COMPLETE Attachment 6, Sections 1.0 and 2.0, AND FORWARD this procedure to the CRS for review.			
*	5.4.3	CRS review the procedure.	Candidate reviews the procedure and initials Step A. Candidate recognizes that the test is unsatisfactory IAW Part D and marks Steps B & C N/A. *Candidate declares the pump Inoperable and initials Step D.		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

System: ADMINISTRATIVE

Task: REVIEW A COMPLETED SURVEILLANCE TEST

# *	STEP NO.	STEP (* Denotes a Critical Step) (# Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT evaluation)
*		Evaluate Technical Specifications	Candidate refers to Technical Specifications and enters AS for 3.6.2.1		

Terminating Cue: After Technical Specifications are interpreted the JPM is complete.

PROVIDE THIS SHEET TO THE CANDIDATE

INITIAL CONDITIONS: The unit is in Mode 1. A regularly scheduled surveillance test is in progress on the 11 Containment Spray Pump. The procedure has been completed through step 5.2.21.

INITIATING CUE: You are the CRS. Beginning at Step 5.2.22, complete the procedure and initiate action, as necessary.

SALEM ADMIN QUESTIONS

SRO

A3

PAGE 1 OF 2

CANDIDATE: _____ DOCKET: _____ DATE: _____

QUESTION: During a reactor shutdown, a leak occurred in the CVCS charging line outside containment. 2CV68 & 2CV69 cannot be closed remotely. An ALERT has been declared. Radio contact was lost with an Equipment Operator who was in the process of closing the valves manually. A RadPro Tech. reports that the NEO can be seen lying unconscious across some pipes in the area of the valves and is bleeding. Radiation Protection has determined radiation levels in the vicinity of 2CV68 & 2CV69 to be 6.3 R/hr.

Given the following information, determine the allowable dose two individuals may receive while rescuing the Equipment Operator:

- Neither person is declared pregnant
- Accumulated dose for the individuals this year is 1.6 rem and 1.87 rem.

ANSWER: The limit to save a life is 75 rem. This dose is in addition to current annual accumulated dose. Therefore, the total dose either individual may receive for this task is 75 rem.

RESPONSE:

SAT _____ UNSAT _____

K/A NUMBER: 2.3.4 – 2.5/3.1

SALEM ADMIN QUESTIONS

QUESTION: During a reactor shutdown, a leak occurred in the CVCS charging line outside containment. 2CV68 & 2CV69 cannot be closed remotely. An ALERT has been declared. Radio contact was lost with an Equipment Operator who was in the process of closing the valves manually. A RadPro Tech. reports that the NEO can be seen lying unconscious across some pipes in the area of the valves and is bleeding. Radiation Protection has determined radiation levels in the vicinity of 2CV68 & 2CV69 to be 6.3 R/hr.

Given the following information, determine the allowable dose two individuals may receive while rescuing the Equipment Operator:

- Neither person is declared pregnant
- Accumulated dose for the individuals this year is 1.6 rem and 1.87 rem.

SALEM ADMIN QUESTIONS

REFERENCES: NC.NA-AP.ZZ-0024, Radiation Protection Program, Rev. 8

SRO

A3

PAGE 2 OF 2

CANDIDATE: _____ DOCKET: _____ DATE: _____

QUESTION: A task must be performed that requires entry into a Locked Very High Radiation Area.

What specific entry requirements must be met prior to entry into this area?

- ANSWER:**
1. A Special RWP is required.
 2. Rad. Protection coverage is required.
 3. Must be an Operational or Safety reason for entry.
 4. Radiation Protection Manager and OS must be notified prior to entry.
 5. A brief on the radiological conditions in the area and the procedures to be followed in case area evacuation is required.
 6. Other requirements maybe addressed.

RESPONSE:

SAT _____ UNSAT _____

K/A NUMBER: 2.3.10 – 2.9/3.3

REFERENCES: LP Radcon-00, Section X. Control of Access.
NC.NA-AP.ZZ-0024, Radiation Protection Program, Rev.8, Sections 5.7-5.9

SALEM ADMIN QUESTIONS

QUESTION:

A task must be performed that requires entry into a Locked Very High Radiation Area.

What specific entry requirements must be met prior to entry into this area?

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

STATION: SALEM
SYSTEM: Administrative
TASK: Determine PARs during a General Emergency
TASK NUMBER:
JPM NUMBER: WD-SROA.4
APPLICABILITY:

EO RO SRO

K/A NUMBER: 2.4.44
IMPORTANCE FACTOR: 2.1 / 4.0
RO SRO

EVALUATION SETTING/METHOD: CLASSROOM
REFERENCES: EPIP 104S; ECG ATT. 4

TOOLS AND EQUIPMENT:

VALIDATED JPM COMPLETION TIME: 20 min

TIME PERIOD FOR TIME CRITICAL STEPS: N/A

APPROVED: _____
PRINCIPAL TRAINING SUPERVISOR OPERATIONS MANAGER

CAUTION: No plant equipment shall be operated during the performance of a JPM without the following:

1. Permission from the SNSS or Unit NSS;
2. Direct oversight by a qualified individual (determined by the individual granting permission based on plant conditions);
3. Verification of the "as left" condition by a qualified individual.

ACTUAL TIME TO COMPLETE JPM: _____
JPM PERFORMED BY: _____ GRADE: SAT UNSAT
REASON, IF UNSATISFACTORY:
EVALUATOR'S SIGNATURE: _____ DATE: _____

JOB PERFORMANCE MEASURE

NAME: _____
DATE: _____

SYSTEM: Administrative

TASK: Determine PARs for a General Emergency

TASK NUMBER:

INITIAL CONDITIONS: A major tube rupture occurred in 21 S/G while recovering from a Loss of Secondary Heat Sink. One safety valve on 21 S/G has been verified stuck open. RCS pressure has stabilized at 1240 psig following SI actuation. The following conditions exist:

- No feed is available to the S/Gs
- 22,23 & 24 S/G WR Level is 23%, 19%, & 25% respectively
- 21 S/G WR Level is 18% and rising
- 21 S/G pressure is 248 psig
- RVLIS Full Range indicates 83%
- The highest Core Exit TC indicates 585° F
- Containment Pressure is 1.5 psia
- Wind direction is from 327 degrees
- Wind speed is 25 mph
- A General Emergency has been declared.

INITIATING CUE:

You are the Emergency Coordinator. Prepare the ICMF.

Successful Completion Criteria:

1. All critical steps completed
2. All sequential steps completed in order
3. All time-critical steps completed within allotted time
4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made (and NRC concurrence is obtained).

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE
ADMINISTRATIVE**

NAME: _____
DATE: _____

System:

Task: **DETERMNE PARs FOR A PLANT EMERGENCY**

# *	STEP NO.	STEP (* Denotes a Critical Step) (# Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT evaluation)
		Obtain the proper Attachment to the EPIPs	CUE: When Attachment 4 to the ECG is located, provide the candidate with a copy.		
		Complete ECG Attachment 4			
	1	CALL communicators to the control room	CUE: Communicators are on the way to the control room		
	2	MAKE a PAR by the following steps:			
*	2a	Refer to Pre-determined PAR Flow chart on Pg. 5 and CHOOSE the appropriate PAR.	Refers to flowchart, using CFSTs and Table 3. <ul style="list-style-type: none"> - Determines that 9 points are made up on the barrier table. - Answers YES and evacuates all sectors 0-5 miles - Downwind +/- 1 sector 5-10 miles and shelters all remaining sectors 5-10 miles. 		
*	2b.	REFER to Recommended Protective Actions	Refers to Pg. 6 worksheet. Determines that		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE
ADMINISTRATIVE**

NAME: _____
DATE: _____

System:

Task: **DETERMINE PARs FOR A PLANT EMERGENCY**

# *	STEP NO.	STEP (* Denotes a Critical Step) (# Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT evaluation)
		Worksheet on Pg. 6 to DETERMINE the compass designations for the downwind sectors affected.	the compass directions for the affected sectors are S, SSE & SE. Since the wind direction is within $\pm 3^\circ$ of the sector dividing line, Sector ESE should also be included.		
	2c	IF a Radiologically based PAR is IMMEDIATELY available, THEN compare the two PARs and choose the most appropriate for inclusion on the ICMF.	CUE: A radiologically based PAR is NOT available at this time.		
	3	COMPLETE the ICMF	Completes the ICMF		
	4	Provide ICMF to the Communicator	Communicator acknowledges receipt of the ICMF		

Terminating Cue: The Communicator has received your information.

THIS SHEET SHOULD BE PROVIDED TO THE CANDIDATE

INITIAL CONDITIONS: A major tube rupture occurred in 21 S/G while recovering from a Loss of Secondary Heat Sink. One safety valve on 21 S/G has been verified stuck open. RCS pressure has stabilized at 1240 psig following SI actuation. The following conditions exist:

- No feed is available to the S/Gs
- 22,23 & 24 S/G WR Level is 23%, 19%, & 25% respectively
- 21 S/G WR Level is 18% and rising
- 21 S/G pressure is 248 psig
- RVLIS Full Range indicates 83%
- The highest Core Exit TC indicates 585° F
- Containment Pressure is 1.5 psia
- Wind direction is from 327 degrees
- Wind speed is 25 mph
- A GENERAL EMERGENCY has been declared.

INITIATING CUE: You are the Emergency Coordinator. Prepare the ICMF.

JPM INDEX

00 – Revised JPM Outline (ES-301-2)

SIMULATOR

- 01 – Makeup to RWST ✓
- 02 – Raise Accumulator Level ✓
- 03 – Swap RHR Loops ✓
- 04 – Containment Spray Failure ✓
- 05 – Source Range NIS Failure ✓
- 06 – Containment Pressure Relief ✓
- 07 – Depressurize RCS in LOCA-2 (Auxiliary Spray) ✓
- 08 – Recover a Dropped Rod ✓
- 09 – Place Excess Letdown in service ✓
- 10 – Shutdown LOCA ✓
- 11 – Remove IR NIS Channel from service ✓
- 12 – Start a Hydrogen Recombiner ✓
- 13 – Manual operation of CVCS Makeup Controls ✓
- 14 – Terminate SI ✓
- 15 – PZR Spray Valve fails open ✓
- 16 – Prompt recovery from SGFP Trip (FRHS) ✓
- 17 – Start a CCW Pump (EOP-APPX-1)

IN-PLANT

- 18 – Trip Turbine, Open Generator Exciter Field Brkr, Trip both SGFP's (Control Rm. Evac.)
- 19 – Local EDG Operation during Control Rm. Evac.
- 20 – Close MSLI Valve (MS167) and operate the associated SG Atmospheric Relief (MS10)
- 21 – Reset SDAFW Pp Trip Valve (MS52)
- 22 – Startup 115 VAC Vital Instrument Inverter
- 23 – Align Charging Pp suction source to RWST during Control Rm. Evac.

Facility: Salem 1 & 2		Date of Examination: 2/22/99
Examination Level: Inplant 1 - Simulator 1		Operating Test Number: 1
System / JPM Title / Type Codes*	Safety Function	Planned Followup Questions: K/A/G - Importance - Description
1. CVCS/RWST Makeup Using Blender (S2.OP-SO.CVC-0006(Q) section 5.7) N S	I	a. 004 K1.23 //3.4/3.7// Flow path for procedure (If power is decreasing, where can the boron be entering CVCS?)
		b. 2.2.22 //3.4/4.1// Technical Specifications for loss of a charging pump.
2. ECCS/Fill an accumulator using an SI pump. (JPM 33) M S	II	a. 011 EK3.07 //3.5/3.6// Reason for SI Pump Mini-Flow Isolation during Recirculation Phase
		b. 011 EK3.12 //4.4/4.6// Negative effects if an accumulator is not isolated when required by LOCA-1
3. RHR / Swapping RHR Loops (JPM 28) D S L	IV	a. 005 K4.01 //3.0/3.2// Overpressurization protection for shutdown cooling piping on increasing RCS pressure
		b. 005 A2.04 //2.9/2.9// Effect a loss of air would have on RHR flow with SDC in service (Repeated on Set 2)
4. PRT/Purging the PRT (S2.OP-SO.PZR-0001) N S	V	a. 2.1.32 //3.4/3.8// Difference between venting to IRU and to the containment atmosphere.
		b. 007 K4.01 //2.6/2.9// How will a feed and bleed operation on the PRT be affected by an SI signal?
5. NI / Respond to failure of a Source Range Instrument (JPM 44) D S L	VII	a. 2.2.22 //3.4/4.1// Technical Specifications for Source Range
		b. 015 A2.01 //3.5/3.9// Effect of a control power fuse blowing during startup.
6. Containment / Containment Pressure Relief with R-12A Out of Service (JPM 48) D S	VIII	a. 029 K3.01 //2.9/3.1// What are the negative effects if the pressure relief was not performed when required? {Repeated on Set 2}
		b. 2.3.11 //2.7/3.2// Limits on times that VC-5 and VC-6 can be open. {Repeated on set 2}
7. Pressure Control / Depressurize in accordance with LOCA-2 using Auxiliary Spray (2-EOP-LOCA-2 Steps 13-15.2) N S A	III	a. 010 A1.08 //3.2/3.3// Factors affecting the delta T on the spray nozzle.
		b. 010 A1.09 //3.4/3.7// Validate temperature indication for a leaking PORV.
8. Pressurizer / Transfer Pressurizer heaters to Emergency Power Supply (JPM PZHTEP) D P	III	a. 2.1.30 //3.9/3.4// Local operation of pressurizer heaters during shutdown outside the control room
		b. 010 K4.02 //3.0/3.4// Automatic control/protective features available during operation outside the control room.
9. Diesel Generator/Perform Attachment 4 for Shutdown Outside the Control room. N P R	VI	a. 064 K1.04 //3.6/3.9// What will prevent the diesel from starting on loss of DC?
		b. 063 K2.01 //2.9/3.1// Effect of loss of DC power will have on Diesel Room Ventilation and required actions
10. Main Steam / Align Main Steam following a Control Room Evacuation (JPM 83 & 108) M P	IV	a. 068 AK3.18 //4.2/4.5// Why removing power to the solenoids is not used when closing and MSIV outside the control room?
		b. 068 AA2.08 //3.9/4.1// When locally operating MS10's why is it important to coordinate with the CRS at HSD?
Type Codes: (D) Direct from bank, (M)odified from bank, (N)ew, (A)lternate Path, (C)ontrol Room, (S)imulator, (P)lant, (L)ow Power, (R)CA # Questions or JPM are similar or the same as Questions or JPMs used on a recent NRC exam.		

Facility: Salem 1 & 2		Date of Examination: 2/22/99	
Examination Level: In-Plant 1 – Simulator 2		Operating Test Number: 2	
System / JPM Title / Type Codes*	Safety Function	Planned Followup Questions: K/A/G – Importance – Description	
1. Rod Cont./Recover a Dropped rod (JPM – DROPROD) D S	I	a.	001 K4.01 //3.5/3.8// Effects of incorrectly setting the P to A converter during realigning a control rod.
		b.	001 A3.02 //3.5/3.6// Rod Insertion Limit determination
2. CVCS/Establish Excess Letdown (JPM 21) D S	II	a.	004 A2.12 //4.1/4.3// Effect of a Phase A Isolation on excess letdown
		b.	004 A1.04 //3.9/4.1// What will be the expected Pzr level trend with excess letdown in service?
3. LOCA / Respond to a Shutdown LOCA – Start Centrifugal Charging Pump and Realign flow through the BIT (S2.OP-AB.LOCA-0001) N S A L	III	a.	009 EA2.34 //3.6/4.2// Based on plant conditions determine if a SI pump can be secured.
		b.	009 EK1.01 //4.2/4.7// Based on plant conditions determine if Natural Circulation has been established.
4. RHR/Place RHR in service with RCS depressurized (JPM – inirhr) D S L	IV	a.	2.2.22 //3.4/4.1// RHR Technical Specifications
		b.	005 A2.04 //2.9/2.9// Effect a loss of air would have on RHR flow {Repeated on Set 1}
5. Containment / Perform a containment purge (JPM 69) D S A	VIII	a.	029 K3.01 //2.9/3.1// What are the negative effects if the pressure relief was not performed when required? {Repeated on Set 1}
		b.	2.3.11 //2.7/3.2// Limits on times that VC-5 and VC-6 can be open. {Repeated on Set 1}
6. NI / Respond to failure of a Source Range Instrument (JPM 44) D S L	VII	a.	2.1.12 //2.9/4.0// Apply AFD limits
		b.	015 K1.02 //3.4/3.6 // Effect on NIS of removing Deans line from service during a Unit 1 startup
7. Hydrogen Recombiner/Place the Hydrogen Recombiner in Service (JPM 49) D S	V	a.	028 A1.02 //3.4/3.7// Effect of recombinder operation on containment pressure
		b.	028 K6.01 //2.6/3.1// Effect of not achieving required temperature. {Repeated on Set 3}
8. Pressurizer / Transfer Pressurizer heaters to Emergency Power Supply (JPM PZHTEP) D P	III	a.	2.1.30 //3.9/3.4// Local operation of pressurizer heaters during shutdown outside the control room
		b.	010 K4.02 //3.0/3.4// Automatic control/protective features available during operation outside the control room.
9. Diesel Generator/Perform Attachment 4 for Shutdown Outside the Control room. N P R	VI	a.	064 K1.04 //3.6/3.9// What will prevent the diesel from starting on loss of DC?
		b.	063 K2.01 //2.9/3.1// Effect of loss of DC power will have on Diesel Room Ventilation and required actions
10. Main Steam / Align Main Steam following a Control Room Evacuation (JPM 83 & 108) M P	IV	a.	068 AK3.18 //4.2/4.5// Why removing power to the solenoids is not used when closing an MSIV outside the control room?
		b.	068 AA2.08 //3.9/4.1// When locally operating MS10's why is it important to coordinate with the CRS at HSD?
Type Codes: (D) Direct from bank, (M)odified from bank, (N)ew, (A)lternate Path, (C)ontrol Room, (S)imulator, (P)lant, (L)ow Power, (R)CA # Questions or JPM are similar or the same as Questions or JPMs used on a recent NRC exam.			

System / JPM Title / Type Codes*		Safety Function	Planned Followup Questions: K/A/G - Importance - Description
Facility: Salem 1 & 2 Examination Level: In-Plant 1 - Simulator 3 Date of Examination: 2/22/99 Operating Test Number: 3			
1.	CVCS/Increasing RHR Loop Boron Concentration (S2.OP-SO.CVC-0006 Att. 1) N S L	I	a. 004 K1.24 //3.4/3.9// Using the P&IDs trace how the Boron Concentration is changed. b. 004 A2.06 //4.2/4.3// Why is boron a concern when placing SDC in service and the temperature change not a concern?
2.	ECCS&ESFAS / Terminate SI (JPM - Terminate SI) D S	II	a. 013 K4.01 //3.9/4.3// Failure of P-4 on SI reset b. 013 K4.06 //4.0/4.3// Status of SI signal input to Semi Automatic Switchover system following SI reset.
3.	Pressure Control/ Respond to a failed open spray valve (JPM ABZRPS3) D S A	III	a. 010 K1.03 //3.6/3.7// Why are the actions different if PS-1 sticks open instead of PS-3? b. 027 AK3.03 //3.7/4.1// Explain how selecting "IMP OUT" prevents an RCS cooldown when stopping an RCP for a stuck open spray valve?
4.	Feedwater/Establish feed with SGFP (S2.OP-SO.CN-002 section 5.4) N S	IV	a. 059 A2.01 //3.4/3.6// AFW pump response to a SGFP trip. b. 059 K4.05 //2.5/2.8// Function of the "Bias" control on 22 SGFP.
5.	Hydrogen Recombiner / Place the Hydrogen Recombiner in Service (JPM 49) D S	V	a. 028 A1.01 // 3.4/3.8// When are the hydrogen recombiners required to be placed in service? b. 028 K6.01 //2.6/3.1// Effect of not achieving required temperature. {Repeated on Set 2}
6.	NI / Respond to a failed Intermediate Range Instrument (JPM 45) D S	VII	a. 015 A2.02 //3.1/3.5// Undercompensation Effects on Intermediate Range b. 015 A3.03 //3.9/3.9// Indication at NIS rack when at power
7.	CCW / Start a CCW Pump IAW APX-1 D S A	VIII	a. 2.2.3 // 3.1/3.3 // CCW response during a LOCA (Unit Differences) (#) b. 2.2.22 //3.4/4.1// Required TS actions for one CCW pump being inoperable.
8.	Pressurizer / Transfer Pressurizer heaters to Emergency Power Supply (JPM PZHTEP) D P	III	a. 2.1.30 //3.9/3.4// Local operation of pressurizer heaters during shutdown outside the control room b. 010 K4.02 //3.0/3.4// Automatic control/protective features available during operation outside the control room.
9.	Diesel Generator/Perform Attachment 4 for Shutdown Outside the Control room. N P R	VI	a. 064 K1.04 //3.6/3.9// What will prevent the diesel from starting on loss of DC? b. 063 K2.01 //2.9/3.1// Effect of loss of DC power will have on Diesel Room Ventilation and required actions
10.	Main Steam / Align Main Steam following a Control Room Evacuation (JPM 83 & 108) M P	IV	a. 068 AK3.18 //4.2/4.5// Why removing power to the solenoids is not used when closing an MSIV outside the control room? b. 068 AA2.08 //3.9/4.1// When locally operating MS10's why is it important to coordinate with the CRS at HSD?
Type Codes: (D) Direct from bank, (M)odified from bank, (N)ew, (A)lternate Path, (C)ontrol Room, (S)imulator, (P)lant, (L)ow Power, (R)CA # Questions or JPM are similar or the same as Questions or JPMs used on a recent NRC exam.			

Facility: Salem 1 & 2
 Examination Level:
 Inplant 2 – Simulator 1

Date of Examination: 2/22/99
 Operating Test Number: 1

System / JPM Title / Type Codes*	Safety Function	Planned Followup Questions: K/A/G – Importance - Description
1. CVCS/RWST Makeup Using Blender (S2.OP-SO.CVC-0006(Q) section 5.7) N S	I	a. 004 K1.23 //3.4/3.7// Flow path for procedure (If power is decreasing, where can the boron be entering CVCS?) b. 2.2.22 //3.4/4.1//Technical Specifications for loss of a charging pump.
2. ECCS/Fill an accumulator using an SI pump. (JPM 33) M S	II	a. 011 EK3.07 //3.5/3.6// Reason for SI Pump Mini-Flow Isolation during Recirculation Phase b. 011 EK3.12 //4.4/4.6// Negative effects if an accumulator is not isolated when required by LOCA-1
3. RHR / Swapping RHR Loops (JPM 28) D S L	IV	a. 005 K4.01 //3.0/3.2// Overpressurization protection for shutdown cooling piping on increasing RCS pressure b. 005 A2.04 //2.9/2.9// Effect a loss of air would have on RHR flow with SDC in service (Repeated on Set 2)
4. PRT/Purging the PRT (S2.OP-SO.PZR-0001) N S	V	a. 2.1.32//3.4/3.8// Difference between venting to the IRU and to the containment atmosphere b. 007 K4.01//2.6/2.9//How will feed and bleed operation on the PRT be affected by a SI signal?
5. NI / Respond to failure of a Source Range Instrument (JPM 44) D S L	VII	a. 2.2.22 //3.4/4.1// Technical Specifications for Source Range b. 015 A2.01 //3.5/3.9// Effect of a control power fuse blowing during startup.
6. Containment / Containment Pressure Relief with R-12A Out of Service (JPM 48) D S	VIII	a. 029 K3.01 //2.9/3.1// What are the negative effects if the pressure relief was not performed when required? (Repeated on Set 2) b. 2.3.11 //2.7/3.2// Limits on times that VC-5 and VC-6 can be open. (Repeated on set 2)
7. Pressure Control / Depressurize in accordance with LOCA-2 using Auxiliary Spray (2-EOP-LOCA-2 Steps 13-15.2) N S A	III	a. 010 A1.08 //3.2/3.3// Factors affecting the delta T on the spray nozzle. b. 010 A1.09 //3.4/3.7// Validate temperature indication for a leaking PORV.
8. AFW/Reset an AFW turbine trip valve (MS52) (JPM Reset MS52) D P R	V	a. 061 A2.07 //3.4/3.5// Operation of AFW valves with PRESS OVRD lights illuminated b. 061 A2.02 //3.2/3.6// Effect of a loss of control air
9. AC Elect/Startup Vital Instrument Inverter – Alternate Source Startup and Return the Inverter to Normal (JPM 112) D P	VI	a. 062 K3.01 //3.5/3.9// Effect of a loss 115 VAC on SI b. 062 K4.10 //3.1/3.5// Status of Inverter if Manual Bypass Switch is in the Isolate (Preferred) Position.
10. ECCS / Align Charging suction to the RWST during CR Evacuation (S1OP-AB.CR-0001 Att. 3 step 19-21) N P R	II	a. 2.2.22 //3.4/4.1// ECCS flow path Technical Specifications b. 006 K4.09 //3.9/4.2// How an inadvertent SI is prevented during shutdown outside the control room.

Type Codes: (D) Direct from bank, (M)odified from bank, (N)ew, (A)lternate Path, (C)ontrol Room, (S)imulator, (P)lant, (L)ow Power, (R)CA # Questions or JPM are similar or the same as Questions or JPMs used on a recent NRC exam.

Facility: Salem 1 & 2

Date of Examination: 2/22/99

Examination Level:

Operating Test Number: 2

In-Plant 2 – Simulator 2

System / JPM Title / Type Codes*	Safety Function	Planned Followup Questions: K/A/G – Importance – Description
1. Rod Cont./Recover a Dropped rod (JPM – DROPROD) D S	I	a. 001 K4.01 //3.5/3.8// Effects of incorrectly setting the P to A converter during realigning a control rod. b. 001 A3.02 //3.5/3.6// Rod Insertion Limit determination
2. CVCS/Establish Excess Letdown (JPM 21) D S	II	a. 004 A2.12 //4.1/4.3// Effect of a Phase A Isolation on excess letdown b. 004 A1.04 //3.9/4.1// What will be the expected Pzr level trend with excess letdown in service?
3. LOCA / Respond to a Shutdown LOCA – Start Centrifugal Charging Pump and Realign flow through the BIT (S2.OP-AB.LOCA-0001) N S A L	III	a. 009 EA2.34 //3.6/4.2// Based on plant conditions determine if a SI pump can be secured. b. 009 EK1.01 //4.2/4.7// Based on plant conditions determine if Natural Circulation has been established.
4. RHR/Place RHR in service with RCS depressurized (JPM – inirhr) D S L	IV	a. 2.2.22 //3.4/4.1// RHR Technical Specifications b. 005 A2.04 //2.9/2.9// Effect a loss of air would have on RHR flow {Repeated on Set 1}
5. Containment / Perform a containment purge (JPM 69) D S A	VIII	a. 029 K3.01 //2.9/3.1// What are the negative effects if the pressure relief was not performed when required? {Repeated on Set 1} b. 2.3.11 //2.7/3.2// Limits on times that VC-5 and VC-6 can be open. {Repeated on Set 1}
6. NI / Respond to failure of a Source Range Instrument (JPM 44) D S L	VII	a. 2.1.12 //2.9/4.0// Apply AFD limits b. 015 K1.02 //3.4/3.6 // Effect on NIS of removing Deans line from service during a Unit 1 startup
7. Hydrogen Recombiner/Place the Hydrogen Recombiner in Service (JPM 49) D S	V	a. 028 A1.02 //3.4/3.7// Effect of recombinder operation on containment pressure b. 028 K6.01 //2.6/3.1// Effect of not achieving required temperature. {Repeated on Set 3}
8. AFW/Reset an AFW turbine trip valve (MS52) (JPM Reset MS52) D P R	V	a. 061 A2.07 //3.4/3.5// Operation of AFW valves with PRESS OVRD lights illuminated b. 061 A2.02 //3.2/3.6// Effect of a loss of control air
9. AC Elect/Startup Vital Instrument Inverter – Alternate Source Startup and Return the Inverter to Normal (JPM 112) D P	VI	a. 062 K3.01 //3.5/3.9// Effect of a loss 115 VAC on SI b. 062 K4.10 //3.1/3.5// Status of Inverter if Manual Bypass Switch is in the Isolate (Preferred) Position.
10. ECCS / Align Charging suction to the RWST during CR Evacuation (S1OP-AB.CR-0001 Att. 3 step 19-21) N P R	II	a. 2.2.22 //3.4/4.1// ECCS flow path Technical Specifications b. 006 K4.09 //3.9/4.2// How an inadvertent SI is prevented during shutdown outside the control room.

Type Codes: (D) Direct from bank, (M)odified from bank, (N)ew, (A)lternate Path, (C)ontrol Room, (S)imulator, (P)lant, (L)ow Power, (R)CA # Questions or JPM are similar or the same as Questions or JPMs used on a recent NRC exam.

Facility: Salem 1 & 2

Date of Examination: 2/22/99

Examination Level:

Operating Test Number: 3

In-Plant 2 – Simulator 3

System / JPM Title / Type Codes*	Safety Function	Planned Followup Questions: K/A/G – Importance – Description
1. CVCS/Increasing RHR Loop Boron Concentration (S2.OP-SO.CVC-0006 Att. 1) N S L	I	a. 004 K1.24 //3.4/3.9// Using the P&IDs trace how the Boron Concentration is changed. b. 004 A2.06 //4.2/4.3// Why is boron a concern when placing SDC in service and the temperature change not a concern?
2. ECCS&ESFAS / Terminate SI (JPM – Terminate SI) D S	II	a. 013 K4.01 //3.9/4.3// Failure of P-4 on SI reset b. 013 K4.06 //4.0/4.3// Status of SI signal input to Semi Automatic Switchover system following SI reset.
3. Pressure Control/ Respond to a failed open spray valve (JPM ABZRPS3) D S A	III	a. 010 K1.03 //3.6/3.7// Why are the actions different if PS-1 sticks open instead of PS-3? b. 027 AK3.03 //3.7/4.1// Explain how selecting "IMP OUT" prevents an RCS cooldown when stopping an RCP for a stuck open spray valve?
4. Feedwater/Establish feed with SGFP (S2.OP-SO.CN-002 section 5.4) N S	IV	a. 059 A2.01 //3.4/3.6// AFW pump response to a SGFP trip. b. 059 K4.05 //2.5/2.8// Function of the "Bias" control on 22 SGFP.
5. Hydrogen Recombiner / Place the Hydrogen Recombiner in Service (JPM 49) D S	V	a. 028 A1.01 // 3.4/3.8// When are the hydrogen recombiners required to be placed in service? b. 028 K6.01 //2.6/3.1// Effect of not achieving required temperature. (Repeated on Set 2)
6. NI / Respond to a failed Intermediate Range Instrument (JPM 45) D S	VII	a. 015 A2.02 //3.1/3.5// Undercompensation Effects on Intermediate Range b. 015 A3.03 //3.9/3.9// Indication at NIS rack when at power
7. CCW / Start a CCW Pump IAW APX-1 D S A	VIII	a. 2.2.3 // 3.1/3.3 // CCW response during a LOCA (Unit Differences) (#) b. 2.2.22 //3.4/4.1// Required TS actions for one CCW pump being inoperable.
8. AFW/Reset an AFW turbine trip valve (MS52) (JPM Reset MS52) D P R	V	a. 061 A2.07 //3.4/3.5// Operation of AFW valves with PRESS OVRD lights illuminated b. 061 A2.02 //3.2/3.6// Effect of a loss of control air
9. AC Elect/Startup Vital Instrument Inverter – Alternate Source Startup and Return the Inverter to Normal (JPM 112) D P	VI	a. 062 K3.01 //3.5/3.9// Effect of a loss 115 VAC on SI b. 062 K4.10 //3.1/3.5// Status of Inverter if Manual Bypass Switch is in the Isolate (Preferred) Position.
10. ECCS / Align Charging suction to the RWST during CR Evacuation (S1OP-AB.CR-0001 Att. 3 step 19-21) N P R	II	a. 2.2.22 //3.4/4.1// ECCS flow path Technical Specifications b. 006 K4.09 //3.9/4.2// How an inadvertent SI is prevented during shutdown outside the control room.

Type Codes: (D) Direct from bank, (M)odified from bank, (N)ew, (A)lternate Path, (C)ontrol Room, (S)imulator, (P)lant, (L)ow Power, (R)CA # Questions or JPM are similar or the same as Questions or JPMs used on a recent NRC exam.

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

1

STATION: Salem 1 & 2
SYSTEM: CVCS
TASK: Makeup to the RWST using CVCS Makeup System
TASK NUMBER: 0040170101

JPM NUMBER:

K/A NUMBER: 004 A4.12

APPLICABILITY:

IMPORTANCE FACTOR:

EO RO SRO

3.8	3.3
RO	SRO

EVALUATION SETTING/METHOD: Simulator

REFERENCES: S2.OP-SO.CVC-0006 section 5.7
S2.RE-RA.ZZ-0012, Figure 110B

TOOLS AND EQUIPMENT:

VALIDATED JPM COMPLETION TIME: 15 mins.

TIME PERIOD IDENTIFIED FOR TIME CRITICAL STEPS: N/A

APPROVED: _____
PRINCIPAL TRAINING SUPERVISOR OPERATIONS MANAGER

CAUTION: No plant equipment shall be operated during the performance of a JPM without the following:

1. Permission for the OS Or Unit CRS;
2. Direct oversight by a qualified individual (determined by the individual granting permission based on plant conditions).
3. Verification of the "as left" condition by a qualified individual.

ACTUAL JPM COMPLETION TIME: _____
ACTUAL TIME CRITICAL COMPLETION TIME: _____
JPM PERFORMED BY: _____ GRADE: SAT UNSAT
REASON, IF UNSATISFACTORY: _____
EVALUATOR'S SIGNATURE: _____ DATE: _____

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

SIMULATOR SETUP INSTRUCTIONS

SYSTEM: CVCS

TASK: Makeup to the RWST using CVCS Makeup System

TASK NUMBER: 0040170101

SIMULATOR IC: IC-2 with REMOTE EC01A to 40.5

**MALFUNCTIONS
REQUIRED:**

**OVERRIDES
REQUIRED:**

**SPECIAL
INSTRUCTIONS:** Reduce RWST level to Technical Specification entry level.

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

SYSTEM: CVCS

TASK: Makeup to the RWST using CVCS Makeup System

TASK NUMBER: 0040170101

INITIAL CONDITIONS:

1. RWST level has decreased to 40.5 ft.
2. Reactor Makeup is not required at this time.
3. Boric Acid Storage Tank Concentration is 6800 ppm.
4. RCS Boron concentration is 680 ppm.
5. RWST Boron Concentration is 2350 ppm.
6. Technical Specifications have been reviewed by the CRS.
7. The RWST Heater Pump is in service.

INITIATING CUE:

The CRS has directed that a 1000 gallons be added to RWST to raise level using the normal blender. Inform the CRS when makeup has been initiated to the RWST.

Successful Completion Criteria:

1. All critical steps completed.
2. All sequential steps completed in order.
3. All time-critical steps completed within allotted time.
4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made (and NRC concurrence is obtained).

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

SYSTEM: CVCS

TASK: Makeup to the RWST using CVCS Makeup System

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
	1	Provide a properly marked up copy of S2.OP-SO.CVC-0006. Inform candidate that all prerequisites have been met and Off-Normal has been reviewed.	Candidate reviews procedure <i>NOTE:</i> The procedure should be implemented IAW Work Standards Handbook guidance for Category II procedures.		
	2	Verifies RWST Heater Pump is in service	Given as an initial condition. <i>Cue: The RWST heater pump is in service.</i>		
	3.	Ensure VCT level adequate	Verifies VCT level is adequate using <u>LT112</u> or LT114.	✓	
	4.	Obtain Boric Acid Flow setpoint from S2.RE-RA.ZZ-0012(Q).	Determines boric acid flow rate is to be 25 gpm or greater. <i>NOTE:</i> Using the graph the closest value is 30 gpm. Calculating the value using the formula is 27.8 gpm. Allowing for error the tolerance was determined to be 25 gpm. <u>30 vs 27.8 ± 25</u> ? ✓		
*	5.	DEPRESS Makeup Control Mode Selector Stop Pushbutton.	Depresses MODE SELECT STOP PB and verifies PB is illuminated.		
	6.	Reset COUNT A on the Makeup flow register.	On each Make Flow Register select COUNT A then select RESET.		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

SYSTEM: CVCS

TASK: Makeup to the RWST using CVCS Makeup System

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
	7.	Place 2CV179, PRI WTR FLOW CONTROL VALVE, in MANUAL	Depresses the 2CV179 MANUAL PB and verifies PB is illuminated.		
	8.	Place 2CV172, BA FLOW CONTROL VALVE, in MANUAL	Depresses the 2CV172 MANUAL PB and verifies PB is illuminated.		
	9.	Ensure closed 2BR170, BA BLENDER TO CVCS HUT VALVE.	Direct local operator to verify 2BR170 is closed. <i>CUE: 2BR170 is closed.</i>		
	10.	OPEN 2CV182, BA BLENDER TO RWST AND HUT VALVE and 2CV184, BA BLENDER TO RWST	Direct an operator TO OPEN 2CV182 & 2CV184 <i>CUE: Simulator Operator open both 2CV182 (REMOTE CV20A to 100%) and 2CV184(REMOTE CV21A to 100%) on 1 minute ramp. Inform Control Room by radio as soon as the valves begin to ramp.</i>		
*	11.	Start Primary Water Pump.	Depresses either the 21 or 22 PRIMARY WATER PUMP START PB and verifies PB is illuminated.		
*	12..	Place Boric Acid Pump in FAST Speed.	Depresses either the 21 or 22 FAST PB and verifies PB is illuminated.		
*	13..	Manually adjust CV172, BA FLOW CONTROL VALVE.	Using 2CV172 OPEN (INC FLOW) and CLOSE (DEC FLOW) PB to obtain >25 gpm on FI110A.		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: CVCS

TASK: Makeup to the RWST using CVCS Makeup System

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
	14.	If required BA Flow is not achieved, then close 21 and 22CV160 (Recirculation Valves).	Determine that required BA Flow Rate is achieved.		
*	15.	Manually adjust 2CV179 for 50 gpm.	Depress 2CV179 OPEN (INC FLOW) PB until FI111A indicates 50 gpm		

TERMINATING CUE: Inform the CRS that makeup flow has be initiated to the RWST.

**JOB PERFORMANCE MEASURE
FOLLOW-UP QUESTION DOCUMENTATION:**

NAME: _____

DATE: _____

SYSTEM: CVCS

TASK: Makeup to the RWST using CVCS Makeup System

TASK NUMBER: 0040170101

QUESTION: _____

RESPONSE: _____

RESULT: -SAT -UNSAT

QUESTION: _____

RESPONSE: _____

RESULT: -SAT -UNSAT

JOB PERFORMANCE MEASURE

JPM QUESTION #1

skit?

INITIAL CONDITIONS:

1. RWST level has decreased to 40.5 ft.
2. Reactor Makeup is not required at this time.
3. Boric Acid Storage Tank Concentration is 6800 ppm.
4. RCS Boron concentration is 680 ppm.
5. RWST Boron Concentration is 2350 ppm.
6. Technical Specifications have been reviewed by the CRS.
7. The RWST Heater Pump is in service

INITIATING CUE:

The CRS has directed that a 1000 gallons be added to RWST to raise level using the normal blender. Inform the CRS when makeup has been initiated to the RWST.

JPM QUESTION #1

Utilizing the P&ID, trace the flow path from the Boric Acid Tank to the RWST. Identify how boration of the RCS is prevented while performing this procedure.

OPEN REFERENCE

ANSWER:

On 205328 Sh 1 Starting at No 21 or No. 22 BAT (grid G2 or G4) trace to 21 or 22 Boric Acid pump. From the discharge of the pump trace to where it transitions to 205334 (Grid E-7). On 205334 Sh 1 (Grid F-2) trace to the RWST.

CV181, VCT Make-Up Stop Valve, and CV185, Charging Pump Suction Valve, are closed.

KA #: 004 K1.23 //3.4/3.7//

Objective: 0300-000.00S-CVCS00-00 Obj. 3

Reference: 205328 Sh1 and 205334 Sh 1

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #1

Utilizing the P&ID, trace the flow path from the Boric Acid Tank to the RWST. Identify how boration of the RCS is prevented while performing this procedure. *during a...*

OPEN REFERENCE

JPM QUESTION #2

Reactor power is 85%. 2A EDG was removed from service for maintenance at 1600 on 2/24/99. All required Technical Specification Action Statements (TSAS's) were entered. 22 Charging pump has been declared inoperable at 0800, 2/25/99, and 2A EDG remains inoperable.

Identify all TSAS's that must be entered when the 22 Charging Pump is declared inoperable.

SRO ONLY – To prevent having to perform a reactor shutdown, when would 2A EDG and 22 charging pump be required to be returned to service?

OPEN REFERENCE

ANSWER:

The following LCOs have to be entered: 3.1.2.2, 3.1.2.4, and 3.5.2

SRO Only:

2A EDG must be returned to service NLT 1600, 2/27/99

AND

22 Charging pump must be returned to service NLT 0800, 2/28/99

KA #: 2.2.22 //3.4/4.1//

Objective: 0300-000.00S-CVCS00-00 Obj. 10

Reference: TS 3.1.2.2, 3.1.2.4, 3.5.2

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #2

Reactor power is 85%. 2A EDG was removed from service for maintenance at 1600 on 2/24/99. All required TS LCOs were entered. 22 Charging pump was declared inoperable at 0800 on 2/25/99.

Identify all required Technical Specification LCOs that must be entered when the 22 Charging pump is declared inoperable.

SRO ONLY – To prevent having to perform a reactor shutdown when would 2A EDG and 22 charging pump be required to be returned to service?

OPEN REFERENCE

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

3

STATION: Salem
SYSTEM: Emergency Core Cooling Systems
TASK: Increase Accumulator Level with a Safety Injection Pump
TASK NUMBER: 006 501 01 01

JPM NUMBER: _____ K/A NUMBER: 006 A4.07
APPLICABILITY: EO RO SRO IMPORTANCE FACTOR:

4.4	4.4
RO	SRO

EVALUATION SETTING/METHOD: Simulator
REFERENCES: S2.OP-SO.SJ-0002, Accumulator Operations
TOOLS AND EQUIPMENT: None

VALIDATED JPM COMPLETION TIME: 15 minutes
TIME PERIOD IDENTIFIED FOR TIME CRITICAL STEPS: _____

APPROVED: _____
PRINCIPAL TRAINING SUPERVISOR OPERATIONS MANAGER

CAUTION: No plant equipment shall be operated during the performance of a JPM without the following:
1. Permission for the OS Or Unit CRS;
2. Direct oversight by a qualified individual (determined by the individual granting permission based on plant conditions).
3. Verification of the "as left" condition by a qualified individual.

ACTUAL JPM COMPLETION TIME: _____
ACTUAL TIME CRITICAL COMPLETION TIME: _____
JPM PERFORMED BY: _____ GRADE: SAT UNSAT
REASON, IF UNSATISFACTORY: _____
EVALUATOR'S SIGNATURE: _____ DATE: _____

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

SIMULATOR SETUP INSTRUCTIONS

SYSTEM: Emergency Core Cooling Systems

TASK: Increase Accumulator Level with a Safety Injection Pump

TASK NUMBER: 006 501 01 01

SIMULATOR IC: IC-95 for 2/99 NRC Exam (Any Steady State 100% IC, lower accum. lev. < TS)

**MALFUNCTIONS
REQUIRED:** None

**OVERRIDES
REQUIRED:** None

**SPECIAL
INSTRUCTIONS:** Lower 21 Accumulator level to 56%.

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

SYSTEM: Emergency Core Cooling Systems

TASK: Increase Accumulator Level with a Safety Injection Pump

TASK NUMBER: 006 501 01 01

INITIAL CONDITIONS:

1. The plant is at 100% power with all systems in their normal alignment with control systems in automatic.
2. 21 Accumulator is at 56% level.

INITIATING CUE:

Fill 21 ECCS Accumulator to 60% using 21 SI pump.

Successful Completion Criteria:

1. All critical steps completed.
2. All sequential steps completed in order.
3. All time-critical steps completed within allotted time.
4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made (and NRC concurrence is obtained).

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

SYSTEM: Emergency Core Cooling Systems

TASK: Increase Accumulator Level with a Safety Injection Pump

#	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
*		Obtains the current revision of the S2.OP-SO.SJ-0002(Q), Accumulator Operations, and selects <u>Accumulator Make-up with 21 Safety Injection Pump</u> section.	Obtains correct procedure, selects appropriate section. <i>NOTE: This is a Category I procedure. Work Standards require that the operator refer to the procedure at each step of the task. Individual step documentation shall be complete prior to proceeding to the next step.</i>		
	1	<u>IF</u> RCS Pressure is less than 2000 psig, <u>THEN</u> ensure closed 21SJ134, COLD LEG DISCHARGE.	Operator verifies RCS pressure > 2000 psig and leaves 21SJ134 OPEN.		
*	2	Start 21 Safety Injection Pump.	Operator depresses START PB, notes change in light status, and observes stabilization of running current.		
*	3.	Open SJ53, 21 SI PUMP DISCHARGE TEST LINE VALVE.	Operator depresses 2J53 OPEN PB and notes change in light status.		
*	4	Open SJ123, TEST LINE TO CVCS HUT.	Operator depresses 21SJ123 OPEN PB and notes change in light status.		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: Emergency Core Cooling Systems

TASK: Increase Accumulator Level with a Safety Injection Pump

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
*	5	OPEN associated Accumulator fill valve: ♦ 21SJ20, 21 ACCUMULATOR FILL ♦ 22SJ20, 22 ACCUMULATOR FILL ♦ 23SJ20, 23 ACCUMULATOR FILL ♦ 24SJ20, 24 ACCUMULATOR FILL	Operator depresses 21SJ20 OPEN PB; notes change in light status and monitor 21 Accumulator level on LI934 and LI935.		
*	6	When desired level is reached, close the Accumulator fill valve: ♦ 21SJ20, 21 ACCUMULATOR FILL ♦ 22SJ20, 22 ACCUMULATOR FILL ♦ 23SJ20, 23 ACCUMULATOR FILL ♦ 24SJ20, 24 ACCUMULATOR FILL	When level reaches 60% (+/-2%), operator depresses 21SJ20 CLOSE PB and notes change in light status		
	7	Close 2SJ53, 21 SI PUMP DISCHARGE TEST LINE VALVE	Operator depresses 2SJ53 CLOSE PB and notes change in light status.		
	8	Close 2SJ123, TEST LINE TO CVCS HUT.	Operator depresses 2SJ123 CLOSE PB and notes change in light status.		
*	9	Stop 21 Safety Injection Pump	Operator depresses 21 SI Pump STOP PB and notes change in light status.		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: Emergency Core Cooling Systems

TASK: Increase Accumulator Level with a Safety Injection Pump

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
	10	IF Accumulator level has increased \geq 1% of tank volume, THEN perform S2.OP-ST.SJ-0008(Q), Emergency Core Cooling Accumulators, within 6 hours.	Identifies the need to perform S2.OP-ST.SJ-0008(Q) within 6 hours.		

What about any pressure increase?

**JOB PERFORMANCE MEASURE
FOLLOW-UP QUESTION DOCUMENTATION:**

NAME: _____

DATE: _____

SYSTEM: Emergency Core Cooling Systems

TASK: Increase Accumulator Level with a Safety Injection Pump

TASK NUMBER: 006 501 01 01

QUESTION: _____

RESPONSE: _____

RESULT: -SAT -UNSAT

QUESTION: _____

RESPONSE: _____

RESULT: -SAT -UNSAT

JOB PERFORMANCE MEASURE

INITIAL CONDITIONS:

1. The plant is at 100% power with all systems in their normal alignment with control systems in automatic.
2. 21 Accumulator is at 56% level.

INITIATING CUE:

Fill 21 ECCS Accumulator to 60% using 21 SI pump.

JPM QUESTION #1

Transfer to Cold Leg Recirculation is being performed. SJ67 (SI PUMP MINIFLOW) valve cannot be shut. If the Transfer to Cold Leg Recirculation procedure were to continue from this point, determine the following:

1. Would the RWST be contaminated from the containment sump? Explain.
2. Will the interlock allowing 21 SJ45 and 22 SJ45 RHR Discharge to SI/Charging Pumps valves to be opened be satisfied? Explain.

OPEN REFERENCE

ANSWER:

1. The RWST will not be contaminated because SJ68 is in series with SJ67 and it will be closed.
2. The interlock will be satisfied because either SJ67 or SJ68 will be closed.

KA #: 011 EK3.07 //3.5/3.6//

Objective: 0300-000.00S-LOCA03-02 Obj. 3

Reference: 0300-000.00S-LOCA03-02, Transfer to Cold Leg Recirculation, Section 3.2.5
0300-000.00S-ECCS00-00, Emergency Core Cooling System, Section IV.D.3.a.2)
P&ID 205334.
2-EOP-LOCA-3 Basis Document, Transfer to Cold Leg Recirculation, page 26.
2-EOP-LOCA-3 Step 11.3.

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #1

Transfer to Cold Leg Recirculation is being performed. SJ67 (SI PUMP MINIFLOW) valve cannot be shut. If the Transfer to Cold Leg Recirculation procedure were to continue from this point, determine the following:

1. Would the RWST be contaminated from the containment sump? Explain.
2. Will the interlock allowing 21 SJ45 and 22 SJ45 RHR Discharge to SI/Charging Pumps valves to be opened be satisfied? Explain.

OPEN REFERENCE

JPM QUESTION #2

A LOCA has occurred. The accumulators are not isolated until RCS That temperatures are 250 °F. What is the potential impact on further LOCA Recovery?

OPEN REFERENCE

ANSWER:

Nitrogen may have been injected into the RCS, which would impede further RCS depressurization.

KA #: 011 EK3.12 //4.4/4.6//

Objective: 0300-000.00S-LOCA01-00, Obj. 6, 9, 10.

Reference: 0300-000.00S-LOCA01-00, Section 5.3.19
2-EOP-LOCA-1, Loss of Reactor Coolant Basis Document, page 40.

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #2

A LOCA has occurred. The accumulators are not isolated until RCS That temperatures are 250 °F. What is the potential impact on further LOCA Recovery?

OPEN REFERENCE

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

3

STATION: Salem 1 & 2
SYSTEM: Residual Heat Removal
TASK: Swapping RHR Loops in Shutdown Cooling
TASK NUMBER: 0050050101

JPM NUMBER:

K/A NUMBER: 2.1.23

APPLICABILITY: EO RO SRO

IMPORTANCE FACTOR:

3.9	4.0
RO	SRO

EVALUATION SETTING/METHOD: Simulator

REFERENCES: S2.OP-SO.RHR-001(Q) Initiating RHR

TOOLS AND EQUIPMENT:

VALIDATED JPM COMPLETION TIME: 10 min.

TIME PERIOD IDENTIFIED FOR TIME CRITICAL STEPS:

APPROVED: _____
PRINCIPAL TRAINING SUPERVISOR OPERATIONS MANAGER

CAUTION: No plant equipment shall be operated during the performance of a JPM without the following:

1. Permission for the OS Or Unit CRS;
2. Direct oversight by a qualified individual (determined by the individual granting permission based on plant conditions).
3. Verification of the "as left" condition by a qualified individual.

ACTUAL JPM COMPLETION TIME: _____
ACTUAL TIME CRITICAL COMPLETION TIME: _____
JPM PERFORMED BY: _____ GRADE: SAT UNSAT
REASON, IF UNSATISFACTORY: _____
EVALUATOR'S SIGNATURE: _____ DATE: _____

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

SYSTEM: Residual Heat Removal

TASK: Swapping RHR Loops in Shutdown Cooling

TASK NUMBER: 0050050101

INITIAL CONDITIONS: IC-172 for 2/99 NRC EXAM

1. The unit is in Mode 5 with RHR in service maintaining RCS temperature.

INITIATING CUE:

You have been directed to remove 21 RHR from service and place 22 RHR in service.

Successful Completion Criteria:

1. All critical steps completed.
2. All sequential steps completed in order.
3. All time-critical steps completed within allotted time.
4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made (and NRC concurrence is obtained).

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: Residual Heat Removal

TASK: Swapping RHR Loops in Shutdown Cooling

#	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
		Provide operator with properly marked up copy of S2.OP-SO.RHR-0001(Q), <u>Initiating RHR, Swapping RHR Loops In Shutdown Cooling</u>	Obtains S2.OP-SO.RHR-0001(Q), selects correct procedure section. <i>NOTE: This is a Category I procedure. Work Standards require that the operator refer to the procedure at each step of the task. Individual step documentation shall be complete prior to preceding to the next step.</i>		
#	1	IF starting 22 RHR Loop and stopping 21RHR Loop, THEN perform the following: Ensure 22RH29 in AUTO.	Verifies 22RH29 in AUTO.		
* #	2.	IF placing 22 RHR Heat Exchanger in service, THEN: 1. Open 22CC16, ² RHR HX OUTLET. 2. Throttle 22CC15, RHR HX CC FLOW CONT VALVE, as required for Component Cooling flow to control RCS temperature.	Opens 22CC16. Directs Primary NEO to throttle 22CC15 as required to control RCS temperature at current value ± 10°F. CUE: Primary NEO is throttling 22CC15		
* #	3.	Start 22 RHR Pump	Starts 22 RHR pump		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: Residual Heat Removal

TASK: Swapping RHR Loops in Shutdown Cooling

#	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
#	4.	Throttle either or both RH18s to maintain stable RHR flow to the Reactor Coolant System.	Transfers flow from 21 RHR loop to 22 RHR loop using 21&22RH18's such that stable RHR flow is maintained to the RCS		
*	5.	Stop 21 RHR Pump.	Stops 21 RHR Pump.		
#	6.	Monitor 22 RHR Loop until parameters are stabilized.	Monitors 22 RHR loop flow, system temperatures, and pump motor amps.		
	7.	IF removing 21 RHR Heat Exchanger from service, THEN close 21CC16, 22 RHR HX OUTLET.	Closes 21CC16		
	8.	Record actual valve positions in Attachment 2, Section 6.0.	Records current valve positions in appropriate attachment section.		
	9.	Direct a second Operator to Complete Attachment 2, Section 6.0	Requests CRS direct a second operator to complete verification of valve positions in appropriate attachment section.		

Terminating Cue: When CRS is requested to direct second operator complete Attachment 2, Section 6.0.

**JOB PERFORMANCE MEASURE
FOLLOW-UP QUESTION DOCUMENTATION:**

NAME: _____
DATE: _____

SYSTEM: Residual Heat Removal

TASK: Swapping RHR Loops in Shutdown Cooling

TASK NUMBER: 0050050101

QUESTION: _____

RESPONSE: _____

RESULT: -SAT -UNSAT

QUESTION: _____

RESPONSE: _____

RESULT: -SAT -UNSAT

JOB PERFORMANCE MEASURE

INITIAL CONDITIONS:

1. The unit is in Mode 5 with RHR in service maintaining RCS temperature.

INITIATING CUE:

You have been directed to remove 21 RHR loop from service and place 22 RHR loop in service.

JPM QUESTION #1

A loss of RHR cooling has occurred causing an increase in RCS pressure to occur.

List all equipment that will operate to prevent overpressurizing RHR piping on increasing reactor pressure.

OPEN REFERENCE

ANSWER:

1. Pressurizer Over pressure Protection (POPs) will open at 375 psig.
2. (Alarm "1(2) RHR1 (or 1(2) RH2) NOT FULL CLS & RX PRESS HIGH" will alarm at ≥ 400 psig.) Not required for full credit.
3. RCS to RHR Inlet Relief Valve RH3 will open at 375 psig.
4. RHR to RCS Hot Leg Relief Valve RH25 will lift at 600 psig.

KA #: 005 K4.01 //3.0/3.2//

Objective: 0300-000.00S-PZRPRT-00, LO 6
0300-000.00S-RHR000-00, LO 4
Reference: 0300-000.00S-PZRPRT-00, IV.B.5.d
0300-000.00S-RHR000-00, IV.D.1.c, IV.B.6.a
P&ID 205332

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #1

A loss of RHR cooling has occurred causing an increase in RCS pressure to occur.

List all equipment that will operate to prevent overpressurizing RHR piping on increasing reactor pressure.

~~CLOSED REFERENCE~~

JPM QUESTION #2

Given the following conditions:

- 21 RHR pump and 21 HX are in service for Shutdown Cooling Mode.
- 21RH18 RHR Heat Exchanger Discharge valve is throttled.
- 21SJ49 Flow is 3000 GPM.
- 2RH20 RHR Heat Exchanger Bypass valve is fully closed.

What will be the effect on RHR flow if control air to RHR components is lost?

OPEN REFERENCE *and explain WHY?*

ANSWER:

RHR flow will increase (to maximum due to a loss of air causing:)

- RHR Heat Exchanger Discharge valves (21,22) RH 18 to fail open.
- RHR Heat Exchanger Bypass valve (RH20) to fail open.

) = not necessary to answer.

KA #: 005 A2.04 //2.9/2.9//

Objective: 0300-000.00S-ABCA01-00, LO 4
Reference: 0300-000.00S-RHR0001, IV.B.5.
0300-000.00S-CCW0001, IV.B.1.b)
P&ID 205331 Sheet 1.
S2.OP-AB.CA-0001, pg 18.

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #2

Given the following conditions:

- 21 RHR pump and 21 HX are inservice for Shutdown Cooling Mode.
- 21RH18 RHR Heat Exchanger Discharge valve is throttled.
- 21SJ49 Flow is 3000 GPM.
- 2RH20 RHR Heat Exchanger Bypass valve is fully closed.

What will be the effect on RHR flow if control air to RHR components is lost?

OPEN REFERENCE

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

4

STATION: SALEM
SYSTEM: CONTAINMENT SPRAY
TASK: CONTAINMENT SPRAY FAILURE DURING LBLOCA

TASK NUMBER: 115 036 05 01

JPM NUMBER:

APPLICABILITY:

EO RO SRO

K/A NUMBER: E14 EA1.1
IMPORTANCE FACTOR: RO 3.7/SRO 3.7

EVALUATION SETTING/METHOD: Simulator

REFERENCES: EOP TRIP-1 Step 11

TOOLS AND EQUIPMENT: N/A

VALIDATED JPM COMPLETION TIME: 5 min

TIME PERIOD IDENTIFIED FOR TIME CRITICAL STEPS: N/A

APPROVED: _____
PRINCIPAL TRAINING SUPERVISOR OPERATIONS MANAGER

CAUTION: No plant equipment shall be operated during the performance of a JPM without the following:
1. Permission from the OS Or Unit CRS;
2. Direct oversight by a qualified individual (determined by the individual granting permission based on plant conditions).
3. Verification of the "as left" condition by a qualified individual.

ACTUAL JPM COMPLETION TIME: _____

ACTUAL TIME CRITICAL COMPLETION TIME: N/A

JPM PERFORMED BY: _____

GRADE:

- SAT - UNSAT

EVALUATOR'S SIGNATURE: _____

DATE: _____

JOB PERFORMANCE MEASURE

SIMULATOR SETUP INSTRUCTIONS

SYSTEM: Containment Spray

TASK: Containment Spray failure during LBLOCA

TASK NUMBER: 115 036 05 01

SIMULATOR IC: Saved IC-171 for 2/99 NRC EXAM (21 CS Pp Control Power OFF; 21 CS Pp breaker tagged; Run simulator with 10000 gpm leak; reset 2C SEC; then insert rupture of 21 RCS loop)

**MALFUNCTIONS
REQUIRED:** NONE

**OVERRIDES
REQUIRED:** NONE

**SPECIAL
INSTRUCTIONS:** Complete EOP TRIP-1 to Step 11

NOTE:

JOB PERFORMANCE MEASURE

NAME: _____
DATE: _____

SYSTEM: Containment Spray

TASK: Containment Spray failure during LBLOCA

TASK NUMBER: 115 036 05 01

INITIAL CONDITIONS: SI has actuated. The Crew has completed steps 1 through 10 of TRIP-1, Reactor Trip or Safety Injection. 21 CS Pp is tagged OOS. 2C SEC was reset while attempting to start 22 Charging Pump.

INITIATING CUE: Beginning at Step 11, continue with the procedure. Respond only to alarms associated with your task.

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

Name: _____
Date: _____

System: Containment Spray

Task: Containment Spray failure during LBLOCA

# *	STEP NO.	STEP (*Denotes a Critical Step) (# Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT evaluation)
		TRIP-1 marked through Step 10	EOP TRIP-1 provided		
	1	CNMT pressure less than 15 psig?	Recognizes CNMT pressure is greater than 15 psig		
	2	Initiate Phase B and Spray Actuation	Verifies Phase B and Spray Actuation		
*	4	Start 21 and 22 CS pump	Starts 22 CS pump (21 is tagged OOS)		
	5	Initiate Loop 21 through 24 Main Steam Isolation	Verifies or initiates Main Steam Isolation NOTE: If MSLI must be initiated then it becomes a critical task.		
	6	Stop 21 through 24 RCPs	Verifies all RCP's stopped		
	7	Are valve groups in Table D in Safeguards position?	Verifies 2CC117, 118, 131, 190, 136 and 187 closed Verifies 21&22CS2 and 2CS14, 16, 17 open		

Terminating Cue: Step 11 completed

INITIAL CONDITIONS: SI has actuated. The Crew has completed steps 1 through 10 of TRIP-1, Reactor Trip or Safety Injection. 21 CS Pp is tagged OOS. 2C SEC was reset while attempting to start 22 Charging Pump.

INITIATING CUE: Beginning at Step 11, continue with the procedure. Respond only to alarms associated with your task.

JPM QUESTION #1

Unit 2 is at 98% power. 21 Containment Spray pump and 24 Containment Fan Coil Unit have both been declared inoperable within the past hour. What will happen to containment pressure if a DBA LOCA occurs before either component is returned to service?

OPEN REFERENCE

ANSWER:

Containment Pressure will be maintained within design limits by one CS pump and the remaining CFCUs. (If a vital bus is lost then containment pressure response is bus dependent) () not required for full credit.

KA #: 026 K4.04 //3.7/4.1//

Objective: 0300-000.00S-CSPRAY-00, Obj. 2
Reference: 0300-000.00S-CSPRAY-00, Section III.D
UFSAR, Section 6.2.2
Technical Specifications Basis, 3/4.6.2.1 & 3/4.6.2.3, page B 3/4 6-3.

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #1

Unit 2 is at 98% power. 21 Containment Spray pump and 24 Containment Fan Coil Unit have both been declared inoperable within the past hour. What will happen to containment pressure if a DBA LOCA occurs before either component is returned to service?

OPEN REFERENCE

JPM QUESTION #2

A LOCA has occurred. Control Room Operators are responding per the EOP's. The SI signal and the SEC's have been reset. Containment pressure has steadily risen and has just reached the HI-HI setpoint.

How will the CS pumps and valves respond to these conditions?

FOLLOWUP QUESTION

Using logic prints show how the starting of the CS pumps is prevented.

OPEN REFERENCE

ANSWER:

The CS pumps will not start but the valves will reposition.

FOLLOWUP ANSWER

Using Logic Diagrams demonstrate how resetting the SEC will prevent the CS pumps from starting.

KA #: 026 A3.01 //4.3/4.5//

Objective: 0300-000.00S-CSPRAY-00, Obj. 8 & 9
Reference: 0300-000.00S-CSPRAY-00, Section IV.A.4.a
Logic Diagrams 239949 and 239952

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #2

A LOCA has occurred. Control Room Operators are responding per the EOP's. The SI signal and the SEC's have been reset. Containment pressure has steadily risen and has just reached the HI-HI setpoint.

How will the CS pumps and valves respond to these conditions?

OPEN REFERENCE

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

5

STATION: Salem 1 & 2
SYSTEM: Nuclear Instrumentation System
TASK: Take Corrective Action for a Source Range Instrument Malfunction
TASK NUMBER: 015 527 04 01
JPM NUMBER: 2-6 (44)

APPLICABILITY: EO RO SRO
K/A NUMBER: 032 AA205
IMPORTANCE FACTOR:

2.9*	3.2*
RO	SRO

EVALUATION SETTING/METHOD: Simulator

REFERENCES: S2.OP-AR.ZZ-0005 Overhead Annunciators Window E
S2.OP-AB.NIS-0001(Q) Nuclear Instrumentation System Malfunction

TOOLS AND EQUIPMENT:

VALIDATED JPM COMPLETION TIME: 10 min.

TIME PERIOD IDENTIFIED FOR TIME CRITICAL STEPS:

APPROVED: _____
PRINCIPAL TRAINING SUPERVISOR OPERATIONS MANAGER

CAUTION: No plant equipment shall be operated during the performance of a JPM without the following:

1. Permission for the OS Or Unit CRS;
2. Direct oversight by a qualified individual (determined by the individual granting permission based on plant conditions).
3. Verification of the "as left" condition by a qualified individual.

ACTUAL JPM COMPLETION TIME: _____
ACTUAL TIME CRITICAL COMPLETION TIME: _____
JPM PERFORMED BY: _____ GRADE: SAT UNSAT
REASON, IF UNSATISFACTORY:
EVALUATOR'S SIGNATURE: _____ DATE: _____

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

SIMULATOR SETUP INSTRUCTIONS

SYSTEM: Nuclear Instrumentation System

TASK: Take Corrective Action for a Source Range Instrument Malfunction

TASK NUMBER: 015 527 04 01

SIMULATOR IC: Shutdown IC-12

**MALFUNCTIONS
REQUIRED:** NI0190A, N31 fails to 100%

**OVERRIDES
REQUIRED:**

**SPECIAL
INSTRUCTIONS:**

- Select the Audio CR and Scaler/Timer to the channel that will be failed.
- After the first NIS alarm, inform the candidate that the PO will tend to any non-related alarms.

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

SYSTEM: Nuclear Instrumentation

TASK: Take Corrective Action for a Source Range Instrument Malfunction

TASK NUMBER: 015 527 04 01

INITIAL CONDITIONS:

1. The Unit is in Mode 3 with the rod control system de-energized.

INITIATING CUE:

You are the reactor operator

Successful Completion Criteria:

1. All critical steps completed.
2. All sequential steps completed in order.
3. All time-critical steps completed within allotted time.
4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made (and NRC concurrence is obtained).

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: Nuclear Instrumentation

TASK: Take Corrective Action for a Source Range Instrument Malfunction

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
		Operator acknowledges OHA E-13 and F-25. Refers to S2.OP-AR.ZZ-0005(Q) for actions	<p>Acknowledges annunciator</p> <p><i>NOTE: After the first SR NIS alarm, inform the candidate that the PO will tend to any alarms not related to the NIS problem.</i></p> <p>Pulls S2.OP-AR.ZZ-0005(Q) or immediately enters AB.NIS-1.</p> <p><i>CUE: Alarm Response Procedures for SR NIS do not direct the operator into AB.NIS and could direct entry into EOP-TRIP-1. If necessary (as CRS), direct the candidate to implement AB.NIS-0001.</i></p>		
2		Go to S2.OP-AB.NIS-0001(Q), Nuclear Instrument System Malfunctions.	<p>Refers to S2.OP-AB.NIS-0001(Q).</p> <p><i>NOTE: This is a Category I procedure. Work Standards require that the operator refer to the procedure at each step of the task. Individual step documentation shall be complete prior to proceeding to the next step.</i></p>		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: Nuclear Instrumentation

TASK: Take Corrective Action for a Source Range Instrument Malfunction

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
	3	<u>IF</u> a Power Range NI ¹² failed, <u>THEN</u> place the ROD BANK SELECTOR SWITCH in MAN.	Operator confirms Source Range instrument failure.		
	4	STOP any Turbine load change.	Operator determines that no action required since the plant is in Mode 3.		
	5	Has a Power Range channel failure occurred as indicated by one or more of the following symptoms? ...	Operator determines that NO Power Range instrument has failed by listed indication, proceeds to appropriate step.		
	6	Has an Intermediate Range Channel failure occurred as indicated by one or more of the following symptoms?	Operator determines that NO Intermediate Range instrument has failed by listed indication, proceeds to appropriate step.		
	7	Has Scaler/Timer or Audio Count Rate channel failure occurred as indicated by one or more of the following symptoms?	Determines if Scaler/Timer or Audio Count Rate channel has been affected by SR instrument malfunction, proceeds to appropriate step. <i>NOTE: Malfunction may/may not affect indications; dependent on malfunctioning channel.</i>		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: Nuclear Instrumentation

TASK: Take Corrective Action for a Source Range Instrument Malfunction

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
	8	Has a Source Range Channel failed as indicated by one or more of the following symptoms? ◆ Erratic or failed indication ◆ OHA E-5, SR DET VOLT TRBL, in alarm ◆ OHA-E-13, SR HI FLUX AT S/D unsubstantiated by other indications	Operator determines that a Source Range channel has failed, proceeds to appropriate step.		
*	9	Select alternate Source Range Channel for input to Audio Count Rate Circuit.	Operator determines which channel has failed and selects the alternate channel as input to the Audio Count Rate circuit on Rack #81, N34 drawer. <i>NOTE:</i> This switch must be pulled out to reposition. If the candidate is unaware and calls for an I&C Tech. then provide <i>CUE:</i> Try pulling switch outward and rotate.		
	10.	IF refueling operations are in progress, ...	Determines refueling operations are NOT in progress.		
	11.	IF Source Range Channel has failed, THEN go to step ...	Recognizes failure, proceeds to appropriate step.		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

SYSTEM: Nuclear Instrumentation

TASK: Take Corrective Action for a Source Range Instrument Malfunction

#	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
*	12	REMOVE affected Source Range Channel from service as follows: Place the LEVEL TRIP switch in the BYPASS position (Source Range drawer).	Operator determines the failed channel and at its associated NIS drawer: Rotates Level Trip switch to BYPASS		
	13.	Ensure OHA E-29, SR & IR TRIP BYP is in alarm	Determines OHA E-29 lit.		
*	14.	Place HIGH FLUX AT SHUTDOWN switch in BLOCK position (Source Range drawer).	Rotates High Flux at Shutdown switch to BLOCK.		
	15.	Ensure OHA E-21, SR HI FLUX AT S/D BLOCK.	Determines OHA E-21 is lit.		
*	16.	Remove INSTRUMENT POWER fuses (Source Range drawer).	Rotates and removes BOTH Instrument Power fuses.		
	17.	Ensure OHA E-5, SR DET VOLT TROUBLE is in alarm.	Determines OHA E-5 is lit.		
	18.	IF conditons warrant, THEN place ROD BANK SELECTOR SWITCH in AUTO.	Verifies selector switch in MANUAL.		
	19.	NOTIFY the CRS/OS to refer to Technical Specifications.	Operator informs the CRS/OS to refer to Tech Spec's		

Terminating Cue: CRS/OS notified
D:\DGroup\JPMs\Simulator\srnisJPM.doc

**JOB PERFORMANCE MEASURE
FOLLOW-UP QUESTION DOCUMENTATION:**

NAME: _____
DATE: _____

SYSTEM: Nuclear Instrumentation

TASK: Take Corrective Action for a Source Range Instrument Malfunction

TASK NUMBER: 015 527 04 01

QUESTION: _____

RESPONSE: _____

RESULT: -SAT -UNSAT

QUESTION: _____

RESPONSE: _____

RESULT: -SAT -UNSAT

JOB PERFORMANCE MEASURE

INITIAL CONDITIONS:

1. The unit is in Mode 3 with the rod control system de-energized.

INITIATING CUE:

You are the Reactor Operator.

JPM QUESTION #1

Core re-load is in progress following a RCP seal maintenance outage. The control room staff realizes they have not heard the audio count rate signal for a several minutes but both source range instruments are indicating properly on the control console.

What actions are required?

OPEN REFERENCE

ANSWER:

Immediately suspend all operations involving core alterations or positive reactivity changes.

NOTE: The operator may state that the range switch may need to be adjusted. May have to state that the audio signal does not return when the count rate is adjusted.

KA #: 2.2.22 //3.4/4.1//

Objective: 0300-000.00S-EXCORE-00, Obj. 11

Reference: TS 3.9.2
S2.OP-AB.NIS-0001

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #1

Core re-load is in progress following a RCP seal maintenance outage. The control room staff realizes they have not heard the audio count rate signal for a several minutes but both source range instruments are indicating properly on the control console.

What actions are required?

OPEN REFERENCE

JPM QUESTION #2

A reactor startup is in progress. Power is currently at 5×10^3 cps. A control power fuse for one Source Range instrument blows.

What will be the response and why?

OPEN REFERENCE

ANSWER:

A loss of control power will deenergize the RPS relay and cause a reactor trip.

KA #: 015 A2.01 //3.5/3.9//

Objective: 0300-000.00S-EXCORE-00, Obj. 8
Reference: 0300-000.00S-EXCORE-00, Section V.A.1.b.2)
S2.OP-AB.NIS-0001
Logic Diagram 221052

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #2

A reactor startup is in progress. Power is currently at 5×10^3 cps. A control power fuse for one Source Range instrument blows.

What will be the response and why?

OPEN REFERENCE

JPM QUESTION #1 (Day 3)

At 1323 on 2/22/99 reactor power is 99%. Cycle burnup is 10,000 MWD/MTU. Delta I is determined to be -15. A rod control failure prevents adjusting control rods to return delta I to the required band. A power decrease is initiated and power is reduced below 50% at 1351 on 2/22/99. AFD is returned to the target band at 1533.

When can power be returned to above 50% power, provided AFD remains within the target band?

OPEN REFERENCE

ANSWER:

1343 on 2/23/99

Note: TS 3.2.1 Action 2 requires that if power is outside the limits (doghouse) then the Power Range Neutron Flux-High Trip setpoints are required to be reduced. The applicant may state that power cannot be returned until the setpoints are reset. Cue that the setpoints have been reset.

KA #: 2.1.12 //2.9/4.0//

Objective: 0300-000.00S-POWER0-00, LO 5

Reference: Technical Specifications 3.2.1

		Penalty Minutes
Initial Time	2/22/99 13:23	
Time at 50%	2/22/99 13:51	0:28:00 Penalty @ 1
Time within Limits	2/22/99 15:33	0:51:00 Penalty @ 50%
Time back above 50%	2/23/99 13:43	1:19:00 Total Penalty

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #1

At 1323 on 2/22/99 reactor power is 99%. Cycle burnup is 10,000 MWD/MTU. Delta I is determined to be -15 . A rod control failure prevents adjusting control rods to return delta I to the required band. A power decrease is initiated and power is reduced below 50% at 1351 on 2/22/99. AFD is returned to the target band at 1533.

When can power be returned to above 50% power, provided AFD remains within the target band?

OPEN REFERENCE

JPM QUESTION #2 (Day 3)

Unit 1 is performing a reactor startup with power at 150 cps. Unit 2 is at 100% power. A tagging request to clear the U1 generator output breakers (1-5 and 5-6 500 KV breakers) to restore the drops (main power transfer leads).

What effect can this have on the current startup?

OPEN REFERENCE

ANSWER:

Induced AC noise from [welding machines and] 500 KV switching evolutions can cause Source Range counts to increase significantly.

[] not required for full credit

KA #: 015 K1.02 //3.4/3/6//

Objective: 0300-000.00S-EXCORE-00, Obj. 13

Reference: S2.OP-IO.ZZ-0003, Step 3.12

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #2

Unit 1 is performing a reactor startup with power at 150 cps. Unit 2 is at 100% power. A tagging request to clear the U1 generator output breakers (1-5 and 5-6 500 KV breakers) to restore the drops (main power transfer leads).

What effect can this have on the current startup?

OPEN REFERENCE

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

4

STATION: Salem 1 & 2
SYSTEM: Containment System
TASK: Perform a Containment Pressure Relief with R-12A in service
TASK NUMBER: 0225130101
JPM NUMBER: 48

APPLICABILITY: EO RO SRO

K/A NUMBER: 2.1.23
IMPORTANCE FACTOR:

3.9	4.0
RO	SRO

EVALUATION SETTING/METHOD: Simulator

REFERENCES: S2.OP-SO.CBV-0002(Q) Containment Pressure-Vacuum Relief System Operation

TOOLS AND EQUIPMENT: None

VALIDATED JPM COMPLETION TIME: 15 mins.

TIME PERIOD IDENTIFIED FOR TIME CRITICAL STEPS: N/A

APPROVED: _____
PRINCIPAL TRAINING SUPERVISOR OPERATIONS MANAGER

CAUTION: No plant equipment shall be operated during the performance of a JPM without the following:

1. Permission for the OS Or Unit CRS;
2. Direct oversight by a qualified individual (determined by the individual granting permission based on plant conditions).
3. Verification of the "as left" condition by a qualified individual.

ACTUAL JPM COMPLETION TIME: _____
ACTUAL TIME CRITICAL COMPLETION TIME: _____
JPM PERFORMED BY: _____ GRADE: SAT UNSAT
REASON, IF UNSATISFACTORY: _____
EVALUATOR'S SIGNATURE: _____ DATE: _____

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

SIMULATOR SETUP INSTRUCTIONS

SYSTEM: Containment System

TASK: Perform a Containment Pressure Relief with R-12A in service

TASK NUMBER: 0225130101

SIMULATOR IC: IC-161 for 2/99 NRC Exam

**MALFUNCTIONS
REQUIRED:**

**OVERRIDES
REQUIRED:**

**SPECIAL
INSTRUCTIONS:** Mark up procedure to Step 5.1. Ensure 2R16 steps are marked as complete

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

SYSTEM: Containment Systems

TASK: Perform a Containment Pressure Relief with 2R41 Out of Service

TASK NUMBER: 022 513 01 01

INITIAL CONDITIONS:

1. The plant is at 100% power with all systems aligned normally and control systems in automatic. Containment differential pressure is 0.23 psig.

INITIATING CUE:

You have been directed to perform a containment pressure relief with R-12A in service

IAW S2.OP-SO.CBV-0002. 2R41 is not available *or R14 U/A*

Successful Completion Criteria:

1. All critical steps completed.
2. All sequential steps completed in order.
3. All time-critical steps completed within allotted time.
4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made (and NRC concurrence is obtained).

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: Containment Systems

TASK: Perform a Containment Pressure Relief with R-12A in service

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
		Evaluator should provide a properly marked up copy of the procedure S2.OP-SO.CBV-0002, Containment Pressure-Vacuum Relief System Operation	Correct procedure obtained <i>NOTE: This is a Category I procedure. Work Standards require that the operator refer to the procedure at each step of the task. Individual step documentation shall be complete prior to proceeding to the next step.</i>		
		<u>Containment Pressure – Vacuum Relief Preparations</u>	N/A		
	1	<u>IF</u> Containment pressure is greater than +0.3 psig... <u>THEN</u> ...	Determines pressure is < 0.3 psig (from initiating cue) and continues with next step. 23		
	2	Ensure Two Auxiliary Building Exhaust Fans are in service.	Determines 2 ABV Exhaust fans are in service		
	3	Ensure Auxiliary Building Exhaust flow is <125,000 CFM	Verifies AB flow <125,000 CFM <i>CUE: Flow is 110,000 cfm (not modeled on simulator).</i>		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: Containment Systems

TASK: Perform a Containment Pressure Relief with R-12A in service

#	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
*	4	Ensure at least one of the following operable RMS channels is in service (ref: Tech Spec Table 3.3-13, Item 2a): Channel 2R41 (preferred) [2R41A, B & D] Channel 2R12A (alternate)	CUE: R41 channels are not available. Use R12A		
	5	If in Mode 6, then ...	Marks step N/A after determining currently in Mode 1.		
	6	IF 2R41A is operable, THEN perform a source check as follows:	R41 not operable per prior cue		
	7	IF 2R41B is operable, THEN perform a source check as follows:	R41 not operable per prior cue		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: Containment Systems

TASK: Perform a Containment Pressure Relief with R-12A in service

#	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
*	8	IF 2R12A is operable, <u>THEN</u> perform a source check.	<p>R12A operable per initiating cue</p> <ul style="list-style-type: none"> • Press 2R12A pushbutton on Radiation Monitor Front Panel • Press C/S Pushbutton • Ensure the following: (1) C/S backlight illuminates (should remain illuminated for approximately one minute), (2) Monitor remains in NORMAL after C/S backlight extinguishes • Ensure Containment APD Flow is 2.0-5.0 SCFM <p>CUE: NEO reports APD flow is 4.0 SCFM</p> <ul style="list-style-type: none"> • Perform Channel Check • Record R12A Source and Channel Check Test Results by initialing the SAT or UNSAT column using the Acceptance Criteria in Attachment 1, Sections 1.0 and 2.0 		
	9	IF in Mode 6 <u>THEN</u> ...	Marks step N/A after determining currently in Mode 1		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: Containment Systems

TASK: Perform a Containment Pressure Relief with R-12A in service

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
	10	IF 2R16 is operable, THEN ...	CUE: R16 source check is complete. Use Channel 2R12A only Marks step N/A		
	11	IF a Containment Isolation Actuation signal is present THEN perform the following:	Determines a CVIA signal is not present and marks step N/A		
		Performing a Containment Pressure Relief	N/A		
	12	ENSURE Source and Channel Check Test Results are Satisfactory IAW applicable attachment.	Reviews and/or recalls Acceptance Criteria of Attachment 1, Sections 1.0 & 2.0 is satisfied for monitor 2R12A		
	13	RECORD the following on required attachment: <ul style="list-style-type: none"> • Pressure Relief start • Initial Containment Pressure • Initial reading of monitor 2R12A 	Records the required information on Attachment 2 <ul style="list-style-type: none"> • Time/Date • Cnmt pressure psig • 2R12A reading 		
	14	INITIATE Containment Relief as follows:			
	15	Monitor available radiation monitors 2R41D, 2R16 & 2R12A.	Monitors 2R12A indications		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

SYSTEM: Containment Systems

TASK: Perform a Containment Pressure Relief with R-12A in service

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
	16	If Containment pressure <0.5 psig , then OPEN:.....	Determines containment pressure <0.5 psig		
*	17	Open 2VC6, ISOL VLV	Opens 2CV6		
*	18	Open 2VC5, ISOL VLV	Opens 2VC5		
*	19	Open PRESSURE RELIEF DAMPER	Opens Pressure Relief Damper		
*	20	RECORD time that 2VC5 and 2VC6 are OPENED in the Control Room Narrative log for the Cyclic Data Monitoring Program IAW required procedure.	Indicates logging time of opening 2VC5 & 2VC6 <i>CUE:</i> Opening time is recorded		
*	21	When Containment Pressure decreases to required value, CLOSE <ul style="list-style-type: none"> • PRESSURE RELIEF DAMPER • 2VC6 • 2VC5 	<i>CUE:</i> Containment differential pressure indicates 0.0 psig Determines containment pressure at required value and closes Press Relief Damper. Closes Pressure Relief Damper Closes 2VC5 Closes 2VC6		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: Containment Systems

TASK: Perform a Containment Pressure Relief with R-12A in service

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
	22	RECORD the following on applicable attachment: <ul style="list-style-type: none"> • Final Containment Pressure • Pressure Relief stop • Highest reading on available radiation monitors 2R41D, 2R16, and 2R12A 	Records the required information on Attachment 2 <ul style="list-style-type: none"> • Time/Date <i>CUE:</i> <ul style="list-style-type: none"> • Cnmt Pressure 0.0 psig • Highest 2R12A reading 550 CPM 		
*	23	RECORD time that 2VC5 and 2VC6 are CLOSED in the Control Room Narrative Log for the Cyclic Data Monitoring Program.	Indicates logging time of closing 2VC5 & 2VC6 <i>CUE:</i> Closing time is recorded		

Terminating Cue: Closing time recorded

**JOB PERFORMANCE MEASURE
FOLLOW-UP QUESTION DOCUMENTATION:**

NAME: _____
DATE: _____

SYSTEM: Containment Systems

TASK: Perform a Containment Pressure Relief with R-12A in service

TASK NUMBER: 022 513 01 01

QUESTION: _____

RESPONSE: _____

RESULT: -SAT -UNSAT

QUESTION: _____

RESPONSE: _____

RESULT: -SAT -UNSAT

JOB PERFORMANCE MEASURE

INITIAL CONDITIONS:

1. The plant is at 100% power with all systems aligned normally and control systems in automatic. Containment pressure is 0.23 psig.

INITIATING CUE:

You have been directed to perform a containment pressure relief with R-12A in service IAW S2.OP-SO.CBV-0002. 2R41 is not available.

JPM QUESTION #1

What would be the potential negative effects if Containment Internal pressure was allowed to increase to 1.0 psig before performing a pressure relief?

OPEN REFERENCE

ANSWER:

The design pressure may be challenged if one of the design basis accidents occurs.

NOTE: The procedure would also require a visual inspection of the duct work following the releases. The operator may also provide this correct information but it is not directly elicited by the question.

KA #: 029 K3.01 //2.9/3.3//

Objective: 0300-000.00S-CONTMT-00, 2.b)

**Reference: Technical Specification Basis 3/4.6.1.4, page B 3/4 6-2
S2.OP-SO.CBV-0002, Section 5.1.**

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #1

What would be the potential negative effects if Containment Internal pressure was allowed to increase to 1.0 psig before performing a pressure relief?

OPEN REFERENCE

JPM QUESTION #2

Why is it necessary to log the time that the Containment Pressure – Vacuum Relief Isolation valves (VC-5 and VC-6) are open?

OPEN REFERENCE

ANSWER:

Salem is committed to maintaining the time the valves are open to less than 1000 hours/year. This is to limit the potential for off-site releases during a LOCA.

KA #: 2.3.11 //2.7/3.2//

Objective: 0300-000.00S-CONTMT-00, LO 12
Reference: SC.OP-AP.ZZ-0004, Attachment 1 and 2.
0300-000.00S-CONTMT-00, Section VIII.H.f.1)

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #2

Why is it necessary to log the time that the Containment Pressure – Vacuum Relief Isolation valves (VC-5 and VC-6) are open?

OPEN REFERENCE

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE



STATION: Salem 1 & 2

SYSTEM: Pressure Control

TASK: Depressurize in accordance with LOCA-2 using Auxiliary Spray

TASK NUMBER: 1150090501

JPM NUMBER:

K/A NUMBER: 009 EA1.09

APPLICABILITY: EO RO SRO

IMPORTANCE FACTOR:

4.4	4.3
RO	SRO

EVALUATION SETTING/METHOD: Simulator

REFERENCES: 2-EOP-LOCA-2, Post LOCA Cooldown and Depressurization

TOOLS AND EQUIPMENT: None

VALIDATED JPM COMPLETION TIME: 15 mins.

TIME PERIOD IDENTIFIED FOR TIME CRITICAL STEPS: N/A

APPROVED: _____
PRINCIPAL TRAINING SUPERVISOR OPERATIONS MANAGER

CAUTION: No plant equipment shall be operated during the performance of a JPM without the following:

1. Permission for the OS Or Unit CRS;
2. Direct oversight by a qualified individual (determined by the individual granting permission based on plant conditions).
3. Verification of the "as left" condition by a qualified individual.

ACTUAL JPM COMPLETION TIME: _____
ACTUAL TIME CRITICAL COMPLETION TIME: _____
JPM PERFORMED BY: _____ GRADE: SAT UNSAT
REASON, IF UNSATISFACTORY: _____
EVALUATOR'S SIGNATURE: _____ DATE: _____

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

SYSTEM: Pressure Control

TASK: Depressurize in accordance with LOCA-2 using Auxiliary Spray

TASK NUMBER: 1150090501

INITIAL CONDITIONS:

1. A LOCA has occurred.
2. Plant conditions are stable.
3. Safeguards Actuations have been reset.
4. AC Buses are energized from offsite power.
5. Actions of 2-EOP-LOCA-2, Post LOCA Cooldown and Depressurization have been completed through step 11.
6. All equipment has functioned normally to this point.
7. A cooldown has been initiated.
8. 2PR6 is closed and tagged

INITIATING CUE:

The CRS directs you to depressurize the RCS to fill the PZR to Greater than 25% (33% if adverse condition exist),
Starting w/ Step 12 ?

Successful Completion Criteria:

1. All critical steps completed.
2. All sequential steps completed in order.
3. All time-critical steps completed within allotted time.
4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made (and NRC concurrence is obtained).

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

**JOB PERFORMANCE MEASURE
SIMULATOR SETUP INSTRUCTIONS**

SYSTEM: Pressure Control

TASK: Depressurize in accordance with LOCA-2 using Auxiliary Spray

TASK NUMBER: 1150090501

SIMULATOR IC:

**MALFUNCTIONS
REQUIRED:** IC-81 for 2/99 NRC Exam (Any IC with a LOCA sized to obtain the conditions below)

**OVERRIDES
REQUIRED:** Override second PZR PORV to fail closed.
Override Spray valves to fail closed.

**SPECIAL
INSTRUCTIONS:** The following conditions must be established:

- Break flow equal to injection flow with at least two charging pumps running and MSIVs open.
- RCS pressure approximately 1500 psig (or as appropriate for the cooldown)
- PZR level approximately 10% to 20%.
- PR6 PZR PORV Block valve closed and tagged.
- SI Reset

Ensure major steps of LOCA-1 and LOCA-2 are completed up through step 11

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: Pressure Control

TASK: Depressurize in accordance with LOCA-2 using Auxiliary Spray

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
	1	Place ALL PZR Heaters in MANUAL and OFF	Verifies 21 BACKUP MANUAL PB illuminated. Verifies 22 BACKUP MANUAL PB illuminated. Verifies 21 BACKUP OFF PB is illuminated. Verifies 22 BACKUP OFF PB is illuminated. Verifies CNTRL GRP HEATERS OFF PB is illuminated.		
	2.	Attempts to open PS1 and PS3, PRZ SPRAY VLVs.	Depress the Master Pressure Controller MANUAL PB and verifies it illuminates. Depress the Master Pressure Controller DECREASE PRESSURE PB and verifies DEMAND indication increases. When DEMAND signal is in the SPRAY range recognize the spray valves have not opened. Depresses the 2PS1 MANUAL PB and verifies PB illuminates. Depress 2PS1 OPEN (INC FLOW) PB. Recognizes 2PS1 demand signal is not increasing. Depresses the 2PS3 MANUAL PB and verifies PB illuminates. Depress 2PS3 OPEN (INC FLOW) PB. Recognizes 2PS3 demand signal is not increasing.		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: Pressure Control

TASK: Depressurize in accordance with LOCA-2 using Auxiliary Spray

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
	3.	Attempts to open PR2 PRZ PORV.	Depress the 2PR2 MANUAL PB and verifies PB illuminates. Depresses the 2PR2 OPEN PB. Determine that the valve does not open.		
	4.	Determines a SI pump is running.	Verifies 21 START PB OR 22 START PB are illuminated. OR Verifies flow on FI922 for 21 SI PUMP OR FI918 for 22 SI PUMP.		
	5.	Determines 21 or 22 Charging Pump is running.	Verifies 21 START PB OR 22 START PB are illuminated. OR Verifies BORON INJ TANK flow on FI917.		
*	6.	Opens Charging Pump Minimum Flow Valves.	Depresses the 2CV139 CHARGING MINI FLOW OPEN PB and verifies the PB illuminates. Depresses 2CV140 CHARGING MINIFLOW OPEN PB and verifies the PB illuminates.		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

SYSTEM: Pressure Control

TASK: Depressurize in accordance with LOCA-2 using Auxiliary Spray

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
*	7.	<p>Close BIT Isolation Valves</p> <p><i>NOTE: When the BIT is isolated then a loss of subcooling will occur.</i></p> <p><i>CUE: If the operator states that ECCS is required to be reinitiated or if the operator begins to reinitiate ECCS then state "From the CRS - Continue the depressurization, EOPs will reestablish subcooling after depressurization is complete."</i></p>	<p>Depresses the PB for each of the following and verifies the PB illuminates for each:</p> <ul style="list-style-type: none"> • 2SJ4 BIT INLET CLOSE • 2SJ5 BIT INLET CLOSE • 2SJ12 BIT OUTLET CLOSE • 2SJ13 BIT OUTLET CLOSE <p>NOTE: Closing either both of the inlet valves or both of the outlet valves will isolate BIT flow.</p>		
	8.	Close the Charging Flow Control Valve	<p>Depresses the CV55 MANUAL PB and verifies it illuminates OR verifies it is illuminated.</p> <p>Depresses the 2CV55 CLOSE (DEC FLOW) PB until the valve is closed (PB illuminates).</p>		
*	9.	Open Charging Discharge Valves	<p>Depresses the 2CV68 CHG OPEN PB and verifies the PB illuminates.</p> <p>Depresses the 2CV69 CHG OPEN PB and verifies the PB illuminates.</p>		
*	10.	Adjust Charging Flow Control Valve to raise charging flow	Depresses the 2CV55 OPEN (INC FLOW) PB until a charging flow rate is established		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

SYSTEM: Pressure Control

TASK: Depressurize in accordance with LOCA-2 using Auxiliary Spray

#	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
	11.	Adjust RCP Seal Injection flow as necessary	Verifies proper RCP seal injection flow.		
*	12.	Open the RCS Aux Spray Valve.	Depress the 2CV75 RCS AUX SPRAY OPEN PB and verifies the PB illuminates.		
*	13.	Close Charging flow to RCS Loops 23 and 24.	Depress the PB and verifies the PB illuminates for the following valves: <ul style="list-style-type: none"> • 2CV77 CHARGING TO LOOP 23 CLOSE • 2CV79 CHARGING TO LOOP 24 CLOSE 		
	14.	Monitor Pressurizer Level	Monitor the following indicators: <ul style="list-style-type: none"> • LI-459A CHANNEL I LEVEL • LI-460A CHANNEL II LEVEL • LI-461 CHANNEL III LEVEL <i>CUE:</i> If candidate wants or begins to continue the procedure while depressurization is in progress then, as CRS, direct him to wait until depressurization has been accomplished.		
	15.	When PZR level is greater than 25% (33% Adverse) then stop depressurization.	When PZR level is >25% (33% Adverse) depress RCS AUX SPRAY CLOSE PB and verifies PB illuminates.		

TERMINATING CUE: Auxiliary Spray is secured.

**JOB PERFORMANCE MEASURE
FOLLOW-UP QUESTION DOCUMENTATION:**

NAME: _____

DATE: _____

SYSTEM: Pressure Control

TASK: Depressurize in accordance with LOCA-2 using Auxiliary Spray

TASK NUMBER: 1150090501

QUESTION: _____

RESPONSE: _____

RESULT: -SAT -UNSAT

QUESTION: _____

RESPONSE: _____

RESULT: -SAT -UNSAT

JOB PERFORMANCE MEASURE

INITIAL CONDITIONS:

1. A LOCA has occurred.
2. Plant conditions are stable.
3. Safeguards Actuations have been reset.
4. AC Buses are energized from offsite power.
5. Actions of 2-EOP-LOCA-2, Post LOCA Cooldown and Depressurization have been completed through step 11.
6. All equipment has functioned normally to this point.
7. A cooldown has been initiated.
8. 2PR6 is closed and tagged

INITIATING CUE:

The CRS directs you to depressurize the RCS to fill the PZR to greater than 25% (33% if adverse condition exist),

Starting with step 12 of LOCA-2

JPM QUESTION #1

A procedure note indicates that the limit for spray head delta temperature may be exceeded during this evolution. Why ~~would~~ this limit be exceeded?

~~could~~ might

CLOSED REFERENCE

ANSWER:

The Auxiliary spray flow is coming from the RWST and is only being heated by the Regenerative Heat Exchanger, which probably will not be in service. The spray nozzle will be at saturation temperature for the current pressurizer pressure.

KA #: 010 A1.08 //3.2/3.3/

Objective: 0300-000.00S-CVCS00-00, Obj. 3. {The objective is draw the system and this question is based on the flow path}

Reference: P&ID 205328, Sh 2.

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #1

A procedure note indicates that the limit for spray head delta temperature may be exceeded during this evolution. Why would this limit be exceeded?

CLOSED REFERENCE

JPM QUESTION #2

During a plant heatup with the pressurizer at 1000 psig a PORV begins to leak. How can the location of the leak be determined?

FOLLOWUP QUESTION:

If PRT pressure is 3 psig, what would the expected value for tail pipe temperature?

OPEN REFERENCE

ANSWER:

The temperature downstream of the PORVs on the combined header can be read on CC2. Using the temperature it can be determined that the leak is from a PORV but the PORVs would have to be isolated one at a time to determine which one is leaking.

FOLLOWUP ANSWER:

The expected temperature for the leaking PORV would be 330 °F (Accept 310 to 350 °F).

KA #: 010 A1.09 // 3.4/3.7//

Objective: 0300-000.00S-ABRC01-00, Obj. 3

Reference: P&ID 205301, Sheet 1,
Steam Tables

S2.OP-AB.RC-0001, Reactor Coolant System Leak, Att. 2, pg 10.

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #2

During a plant heatup with the pressurizer at 1000 psig a PORV begins to leak. How can the location of the leak be determined?

OPEN REFERENCE

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE



STATION: Salem 1 & 2
SYSTEM: Rod Control
TASK: Recover a Dropped Rod
TASK NUMBER: 114 033 0401
JPM NUMBER: DROPROD

K/A NUMBER: APE 003 AA1.02
IMPORTANCE FACTOR:

3.6	3.3
RO	SRO

APPLICABILITY: EO RO SRO

EVALUATION SETTING/METHOD: Simulator

REFERENCES: S2.OP-AB.ROD-0002 Dropped Rod

TOOLS AND EQUIPMENT:

VALIDATED JPM COMPLETION TIME: 20 min.

TIME PERIOD IDENTIFIED FOR TIME CRITICAL STEPS:

APPROVED: _____
PRINCIPAL TRAINING SUPERVISOR OPERATIONS MANAGER

CAUTION: No plant equipment shall be operated during the performance of a JPM without the following:

1. Permission for the OS Or Unit CRS;
2. Direct oversight by a qualified individual (determined by the individual granting permission based on plant conditions).
3. Verification of the "as left" condition by a qualified individual.

ACTUAL JPM COMPLETION TIME: _____
ACTUAL TIME CRITICAL COMPLETION TIME: _____
JPM PERFORMED BY: _____ GRADE: SAT UNSAT
REASON, IF UNSATISFACTORY:
EVALUATOR'S SIGNATURE: _____ DATE: _____

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

SIMULATOR SETUP INSTRUCTIONS

SYSTEM: Rod Control

TASK: Recover a Dropped Rod

TASK NUMBER: 114 033 0401

SIMULATOR IC: IC6, IC96 ESG disk

**MALFUNCTIONS
REQUIRED:**

**OVERRIDES
REQUIRED:**

**SPECIAL
INSTRUCTIONS:**

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

NAME: _____

DATE: _____

SYSTEM: Rod Control

TASK: Recover a Dropped Rod

TASK NUMBER: 114 033 04 01

INITIAL CONDITIONS:

1. You are the Unit RO.
2. Control Rod 1SA2 dropped approximately 45 minutes ago.
3. AB.ROD-0002 has been performed through Step 3.25.
4. Eng has granted permission to recover rod at present power level.
5. All Technical Specification actions have been addressed.
6. Cause for dropped rod has been repaired.
7. Rod recovery is ready to begin.

INITIATING CUE:

You have been directed to recover the dropped rod beginning at Step 3.26 of S2.OP-AB.ROD-0002. The rod is to be recovered over a 10 minute period. (NOTE: The withdrawal time has been designated specifically to expedite performance of this JPM and is not intended to be an indicator for the time that would be allotted if the event were to occur at the plant.)

Successful Completion Criteria:

1. All critical steps completed.
2. All sequential steps completed in order.
3. All time-critical steps completed within allotted time.
4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made (and NRC concurrence is obtained).

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

SYSTEM: Rod Control

TASK: Recover a Dropped Rod

#	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
	1	Operator reviews the marked up S2.OP-AB.CR-0002.	Evaluator provides copy of S2.OP-AB.CR-0002, marked up through Step 3.25. <i>NOTE:</i> AB's should be implemented IAW the Work Standards requirements for Cat. 1 procedures.		
	2	Record the Group Step Counter reading associated with the affected group.	Records 228 steps on the procedure.		
	3	Is the dropped rod a Group 1 rod in a Control Bank?	Determines rod is in a Shutdown Bank (Answers NO) and proceeds to Step 3.29.		
*	4	Set the applicable Group Step Counter to zero steps.	Sets correct Step Counter by depressing ZERO button for SD BANK A Group 1.		
* #	5	Place the Lift Coil Disconnect Switches for all rods in the affected bank, except the dropped rod, in the OFF position.	Using STAR principles, sets all Lift Coil Disconnects except 1SA2 in Shutdown Bank A to OFF.		
	6	Independently verify the Lift Coil Disconnect Switches for all rods in the affected bank, except the dropped rod, are in the OFF position.	(Evaluator can serve as the verifier but should make no corrections.) The operator requests independent verification of Disconnect Switch positions.		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

SYSTEM: Rod Control

TASK: Recover a Dropped Rod

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
	7	Monitor Tav _g for necessary adjustments until the rod has been aligned.	<i>CUE: An individual is available as PO, taking direction from the RO.</i> Directs PR to monitor Tav _g and maintain within required range of Tref.		
*	8	Select the affected bank with the Rod Bank Selector Switch.	Selects Shutdown Bank A.		
*	9	Withdraw the dropped rod over the duration specified by Reactor Engineering, until the Group Step Counter is returned to the value recorded in Step 3.26.	Withdraws the specified rod to 228 steps on the Step Counter, over a 10 mins. period.		
	10	Was the dropped rod in Shutdown Bank C or D?	Determines rod was not in SDB or SDC (Answers NO) and proceeds to Step 3.41.		
	11	Are Group 1 and Group 2 Group Step Counters equal?	Verifies and answers YES		
	12	Was the dropped rod in Group 2?	Answers NO		
	13	Perform the following to ensure proper group sequencing logic is maintained: <ul style="list-style-type: none"> • Withdraw the dropped rod one step • Insert the dropped rod one step 	Withdraws and inserts dropped rod one step and verifies proper operation		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

SYSTEM: Rod Control

TASK: Recover a Dropped Rod

#	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
*	14	Place all Lift Coil Disconnect Switches in the ON position.	Returns all Lift Coil Disconnect Switches in the affected bank to ON		
	15	Independently verify all Lift Coil Disconnect Switches are in the ON position.	(Evaluator can serve as the verifier but should make no corrections.) The operator requests independent verification of Disconnect Switch positions.		
*	15	Place the Rod Bank Selector Switch in MANUAL	Selects MANUAL on the RBSS		
	15	Do indications (IRPI, Rod Bottom Light OFF, rising Tav _g during rod motion) confirm the dropped rod is recovered?	Determines that indications are proper for recovered rod (Answers YES) and proceeds to next step.		
	16	If a PR Flux Rate Trip has occurred on any channel, then reset the trip bistable on the NIS Cabinet.	Determines NO Rate Trips present on 2RP 4.		
	17	Depress the ALARM RESET PB to clear the Rod Bank Urgent Failure Alarm (OHA E-40).	Depresses ALARM RESET PB and observes E-40 clears or indicates step does not apply.		

TERMINATING CUE: OHA E-40 cleared.

**JOB PERFORMANCE MEASURE
FOLLOW-UP QUESTION DOCUMENTATION:**

NAME: _____

DATE: _____

SYSTEM: Rod Control

TASK: Recover a Dropped Rod

TASK NUMBER: 114 033 0401

QUESTION: _____

RESPONSE: _____

RESULT: -SAT

-UNSAT

QUESTION: _____

RESPONSE: _____

RESULT: -SAT

-UNSAT

JOB PERFORMANCE MEASURE

INITIAL CONDITIONS:

1. You are the Unit RO.
2. Control Rod 1SA2 dropped approximately 45 minutes ago.
3. AB.ROD-0002 has been performed through Step 3.25.
4. Eng has granted permission to recover rod at present power level.
5. All Technical Specification actions have been addressed.
6. Cause for dropped rod has been repaired.
7. Rod recovery is ready to begin.

INITIATING CUE:

You have been directed to recover the dropped rod beginning at Step 3.26 of S2.OP-AB.ROD-0002. ~~The rod is to be recovered over a 10 minute period.~~

~~NOTE: The withdrawal time has been designated specifically to expedite performance of this JPM and is not intended to be an indicator for the time that would be allotted if the event were to occur at the plant.)~~

JPM QUESTION #1

A control rod in Group 1 of Control Bank D is misaligned 20 steps below all other rods in the group. During the realignment, the P/A converter is mistakenly adjusted by 10 steps instead of 20 steps. What would be the effect on Rod Control Interlocks if continued operation were permitted with rods in this configuration?

OPEN REFERENCE

ANSWER:

The P/A converter would be 10 steps higher than what it should be therefore:

1. The Bank D withdrawal limit will occur 10 steps sooner than expected.
2. The RIL alarms will not occur until 10 steps after when they should have.
3. (The Rod Bottom Bistable ~~will~~ input will be incorrect by 10 steps.)
() Not required for full credit.

KA #: 001 K4.01 //3.5/3.8//

Objective: 0300-000.00S-RODS00-00, 6.k
Reference: 0300-000.00S-RODS00-00, Section IV.B.13
S1.OP-AB.ROD-0002, Technical Basis Section 2.4

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #1

A control rod in Group 1 of Control Bank D is misaligned 20 steps below all other rods in the group. During the realignment, the P/A converter is mistakenly adjusted by 10 steps instead of 20 steps. What would be the effect on Rod Control Interlocks if continued operation were permitted with rods in this configuration?

OPEN REFERENCE

JPM QUESTION #2

Given the following conditions for Unit 2:

- Startup is underway following refueling (Cycle 10)
- Reactor power is stable at 75%
- Tavg is on program
- RCS boron concentration is 1375 ppm
- All Pre-conditioning limits have been met.

What are the restrictions on control rod position?

SRO Only: And what actions are required per TS if control rods are not in compliance with this restriction?

OPEN REFERENCE

ANSWER:

Group D control rods must be above 110 steps.

SRO Only:

Control rods must be restored to above the limit within 2 hours.

KA #: 001 A3.02 //3.5/3.6//

Objective: 0300-000.00S-RODS00-00, Obj. 13

Reference: Technical Specifications 3.1.3.5

S2.RE-RA.ZZ-0012, Figure 14.

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #2

Given the following conditions for Unit 2:

- Startup is underway following refueling (Cycle 10)
- Reactor power is stable at 75%
- Tavg is on program
- RCS boron concentration is 1375 ppm
- All Pre-conditioning limits have been met.

What are the restrictions on control rod position?

SRO Only: And what actions are required per TS if control rods are not in compliance with this restriction?

OPEN REFERENCE

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

9

STATION: Salem 1 & 2
SYSTEM: Chemical and Volume Control System
TASK: Place Excess Letdown in Service
TASK NUMBER: 004 510 01 01
JPM NUMBER: 21

K/A NUMBER: 004 A4.06
IMPORTANCE FACTOR:

3.6	3.1
RO	SRO

APPLICABILITY: EO RO SRO

EVALUATION SETTING/METHOD: Simulator

REFERENCES: S2.OP-SO.CVC-0003(Q) Excess Letdown Flow

TOOLS AND EQUIPMENT:

VALIDATED JPM COMPLETION TIME: 10 min.

TIME PERIOD IDENTIFIED FOR TIME CRITICAL STEPS:

APPROVED: _____
PRINCIPAL TRAINING SUPERVISOR OPERATIONS MANAGER

CAUTION: No plant equipment shall be operated during the performance of a JPM without the following:
1. Permission for the OS Or Unit CRSS;
2. Direct oversight by a qualified individual (determined by the individual granting permission based on plant conditions).
3. Verification of the "as left" condition by a qualified individual.

ACTUAL JPM COMPLETION TIME: _____
ACTUAL TIME CRITICAL COMPLETION TIME: _____
JPM PERFORMED BY: _____ GRADE: SAT UNSAT
REASON, IF UNSATISFACTORY:
EVALUATOR'S SIGNATURE: _____ DATE: _____

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

NAME: _____

DATE: _____

SYSTEM: Chemical and Volume Control System

TASK: Place Excess Letdown in Service

TASK NUMBER: 004 510 01 01

INITIAL CONDITIONS: IC-97

1. The plant is at 100% power with charging at minimum. A leak has been identified in the Letdown Heat Exchanger.

INITIATING CUE:

The CRS/OS has directed you to place excess letdown in service, directed to the VCT

Successful Completion Criteria:

1. All critical steps completed.
2. All sequential steps completed in order.
3. All time-critical steps completed within allotted time.
4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made (and NRC concurrence is obtained).

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

NAME: _____

DATE: _____

SYSTEM: Chemical and Volume Control System

TASK: Place Excess Letdown in Service

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
		Obtains S2.OP-SO.CVC-0003(Q), Excess Letdown Flow.	Obtains procedure. <i>NOTE: This is a Category II procedure. Work Standards require that the procedure should be at the jobsite. The operator should refer to the procedure at the beginning and end of the job and as frequently as necessary (based on the task, experience of the operator, familiarization with the task, etc) to complete the job in accordance with the procedure.</i>		
	1	ENSURE OPEN 2CC215, EXC LHX INLET.	Verifies open or opens 2CC215.		
	2	OPEN 2CC113, EXC LHX OUTLET.	Opens 2CC113.		
	3	CHECK CLOSED 2CV132.	Verifies closed or closes 2CV132.		
	4	IF flow will be directed to the RCDT, THEN SELECT 2CV134 to FLOW TO RCDT.	Operator determines step is NA, flow is to be directed to the VCT.		
*	5	IF flow will be directed to the VCT, THEN SELECT 2CV134 to FLOW TO VCT.	Places 2CV134 in the FLOW TO VCT position.		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

SYSTEM: Chemical and Volume Control System

TASK: Place Excess Letdown in Service

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
*	6	OPEN 2CV278.	Opens 2CV278.		
*	7	OPEN 2CV131.	Opens 2CV131.		
*	8	SLOWLY OPEN 2CV132 to allow gradual warming of the Excess Letdown Heat Exchanger.	Opens 2CV132 in increments maintaining temperature < 195 degrees F on TI122 and pressure < 150 psig on PI121.		
	9	ADJUST 2CV132	<i>CUE: Direct operator to fully open 2CV132.</i> Fully opens 2CV132.		

Terminating Cue: Operator adjusts 2CV132 to maximum flowrate flowrate.

**JOB PERFORMANCE MEASURE
FOLLOW-UP QUESTION DOCUMENTATION:**

NAME: _____

DATE: _____

SYSTEM: Chemical and Volume Control System

TASK: Place Excess Letdown in Service

TASK NUMBER: 004 510 01 01

QUESTION: _____

RESPONSE: _____

RESULT: -SAT

-UNSAT

QUESTION: _____

RESPONSE: _____

RESULT: -SAT

-UNSAT

INITIAL CONDITIONS:

1. The plant is at 100% power with charging at minimum.. A leak has been identified in the Letdown Heat Exchanger.

INITIATING CUE:

The CRS/OS has directed you to place excess letdown in service, directed to the VCT

JPM QUESTION #1

Given the following conditions:

- Unit 2 is in Mode 3 with preparations in progress for a Reactor Startup.
- Excess Letdown to the VCT is in service with normal letdown isolated.

What effect would a SI signal have on the Excess Letdown system and any other components using that flowpath? Using prints, show the sequence and affects of valve operations with no operator action.

OPEN REFERENCE

ANSWER:

The SI signal also generates a Containment Phase A Isolation. On Phase A, CNMT Isolation valves CV284 and CV116 close, isolating the excess letdown (and seal return) line. At 150 psig, the relief valve inside CNMT ~~will open~~ ^{to the PACT} will open allowing flow. (In the long run, Instrument Air to CNMT Isolation valves close, and without air, control valves in excess letdown line (CV132, CV278 & CV131) will fail closed stopping excess letdown flow.) Note: () not solicited by the question.

X

KA #: 004 A2.12 //4.1/4.3//

Objective: 0300-000.00S-CVCS00-00, Obj. 4
Reference: P&ID 205328, Sh 2,
0300-000.00S-CVCS00-00, section III.A.2, IV.A.4.c&d

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #1

Given the following conditions:

- Unit 2 is in Mode 3 with preparations in progress for a Reactor Startup.
- Excess Letdown to the VCT is in service with normal letdown isolated.

What effect would a SI signal have on the Excess Letdown system and any other components using that flowpath? Using prints, show the sequence and affects of valve operations with no operator action.

OPEN REFERENCE

JPM QUESTION #2

What action is necessary if Excess Letdown must be placed in service for one or more shifts? Explain.

OPEN REFERENCE

ANSWER:

Minimum charging minus seal return and excess letdown would result in a continuously rising PZR level. The minimum stop on CV55 must be bypassed or the PDP linkage adjusted.

KA #: 004 A1.04 //3.9/4.1//

Objective: 0300-000.00S-CVCS00-00, Obj. 2, 3
Reference: 0300-000.00S-CVCS00-00, IV.A.3.c
S2.OP-SO.CVC-0001, Section 5.3.2

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #2

What action is necessary if Excess Letdown must be placed in service for one or more shifts? Explain.

OPEN REFERENCE

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

13

STATION: Salem 1 & 2
SYSTEM: ECCS
TASK: Respond to a Shutdown LOCA

TASK NUMBER: 1140260401

JPM NUMBER:

K/A NUMBER: 2.1.23

APPLICABILITY:

IMPORTANCE FACTOR:

EO RO SRO

3.9	4.0
RO	SRO

EVALUATION SETTING/METHOD: Simulator

REFERENCES: S2.OP-AB.LOCA-0001, Shutdown LOCA

TOOLS AND EQUIPMENT: None

VALIDATED JPM COMPLETION TIME: 10 mins.

TIME PERIOD IDENTIFIED FOR TIME CRITICAL STEPS: N/A

APPROVED: _____
PRINCIPAL TRAINING SUPERVISOR OPERATIONS MANAGER

CAUTION: No plant equipment shall be operated during the performance of a JPM without the following:

1. Permission for the OS Or Unit CRS;
2. Direct oversight by a qualified individual (determined by the individual granting permission based on plant conditions).
3. Verification of the "as left" condition by a qualified individual. -

ACTUAL JPM COMPLETION TIME: _____
ACTUAL TIME CRITICAL COMPLETION TIME: _____
JPM PERFORMED BY: _____ GRADE: SAT UNSAT
REASON, IF UNSATISFACTORY: _____
EVALUATOR'S SIGNATURE: _____ DATE: _____

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

JOB PERFORMANCE MEASURE

SIMULATOR SETUP INSTRUCTIONS

SYSTEM: ECCS

TASK: Shutdown LOCA

TASK NUMBER: 1140260401

SIMULATOR IC: IC-82 for 2/99 NRC Exam (Shutdown IC with SI pumps, Accumulators, and one centrifugal charging pump removed from service)

**MALFUNCTIONS
REQUIRED:** LOCA - Size to exceed the capabilities of a centrifugal charging pump through the normal charging line but level can be maintained with the centrifugal charging pump through the BIT.

**OVERRIDES
REQUIRED:** NONE

**SPECIAL
INSTRUCTIONS:**

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

NAME: _____

DATE: _____

SYSTEM: ECCS

TASK: Respond to a Shutdown LOCA

TASK NUMBER: 1140260401

INITIAL CONDITIONS:

1. Reactor is shutdown and cooldown to 275 °F and 325 psig.
2. The 22 Charging pump and both SI pumps are removed from service.
3. The accumulators have been isolated.

NOTE TO THE EXAMINER: The simulator has been frozen after level has decreased from 34% to 30%. Notify the Simulator Operator when the operator is ready to begin and the simulator should be taken out of freeze.

INITIATING CUE:

Respond to a decreasing pressurizer level. Notify CRS when pressurizer level is rising.

Successful Completion Criteria:

1. All critical steps completed.
2. All sequential steps completed in order.
3. All time-critical steps completed within allotted time.
4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made (and NRC concurrence is obtained).

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

SYSTEM: ECCS

TASK: Respond to a Shutdown LOCA

#	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
*		Obtains the current revision of the S2.OP-AB.LOCA-0001, Shutdown LOCA.	Obtains correct procedure. <i>NOTE: This is a Category I procedure. Work Standards require that the operator refer to the procedure at each step of the task. Individual step documentation shall be complete prior to proceeding to the next step.</i>		
	1.	Initiate Attachment 1, Continuous Action Summary.	Indicates that Attachment 1 is to be monitored. <i>CUE: The CRS will monitor Attachment 1, Continuous Action Summary</i>		
*	2.	Closes 2CV2, Letdown Control.	Depresses 2CV2 MANUAL PB and verifies PB illuminates. Depresses 2CV2 CLOSE PB and verifies PB illuminates.		
	3.	Closes 2CV7, Letdown Line Containment Isolation	Depresses 2CV7 CLOSED PB and verifies PB illuminates.		
	4.	Closes 2CV277, Letdown Control	Depresses 2CV277 MANUAL PB and verifies PB illuminates. Depresses 2CV277 CLOSED PB and verifies PB illuminates.		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: ECCS

TASK: Respond to a Shutdown LOCA

#	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
*	5.	Closes 2CV8, Letdown ISO for RHR	Depresses 2CV8 CLOSE (DEC FLOW) PB and verifies 2CV8 VALVE DEMAND on FI133 indicates 0% and the PB light is illuminated.		
	6.	Verifies 2CV278, Excess Letdown, is closed.	Verifies 2CV278 CLOSE PB is illuminated.		
	7.	Verifies 2CV131, Excess Letdown, is closed.	Verifies 2CV131 CLOSED PB is illuminated.		
	8.	Checks to determine if Pressurizer Level can be maintained stable or rising.	Determines that pressurizer level is lowering on COLD CAL LEVEL LI462.		
	9.	Determine if a Centrifugal Charging Pump is in service.	Determines that the Centrifugal Charging Pump is in service.		
*	10.	Adjusts 2CV55 to maximize charging flow.	Depresses the 2CV55 OPEN (INCR FLOW) PB until the valve is full open.		
	11.	Determines that Pressurizer level is not stable or rising.	Determines that Pressurizer level is continuing to lower.		
	12.	Open 2SJ1 or 2SJ2, RWST TO CHG PUMP	Depress 2SJ1 OR 2SJ2 MANUAL PB and verifies PB illuminates. Depress 2SJ1 OR 2SJ2 RWST TO CHG PUMP OPEN PB and verifies PB illuminates. NOTE: This may automatically occur on low VCT level.		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: ECCS

TASK: Respond to a Shutdown LOCA

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
	13.	Close 2CV40 or 2CV41, VCT DISCH STOP VALVE	Depress 2CV40 OR 2CV41 MANUAL PB and verifies PB illuminates. Depress 2CV40 OR 2CV41 DISCH STOP VALVE CLOSE PB verifies PB illuminates.		
	14.	Stops all but one Centrifugal Charging Pump	Identifies that only one Centrifugal Charging Pump is running.		
*	15.	Open BIT isolation valves.	Depresses the PB and verifies PB illuminates for the following valves: <ul style="list-style-type: none"> • 2SJ4 BIT INLET OPEN • 2SJ5 BIT INLET OPEN • 2SJ12 BIT OUTLET OPEN • 2SJ13 BIT OUTLET OPEN <p>NOTE: 2SJ4 and 2SJ5 are normally open so it is not critical to operate those valves.</p>		
	16.	Close the Charging isolation valves.	Depresses the PB and verifies the PB illuminates for the following valves: <ul style="list-style-type: none"> • 2CV68 CHG DISCH CLOSE • 2CV69 CHG DISCH CLOSE 		
	17.	Fully open 2CV55, Charging Flow	Notes that 2CV55 was previously fully open to obtain maximum charging flow.		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

SYSTEM: ECCS

TASK: Respond to a Shutdown LOCA

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
	18.	Close the Charging Miniflow valves	Depresses the PB and verifies the PB illuminates for the following valves: <ul style="list-style-type: none"> • 2CV139 CHARGING MINIFLOW CLOSE • 2CV140 CHARGING MINIFLOW CLOSE 		

TERMINATING CUE: Pressurizer level is increasing.

**JOB PERFORMANCE MEASURE
FOLLOW-UP QUESTION DOCUMENTATION:**

NAME: _____

DATE: _____

SYSTEM: ECCS

TASK: Respond to a Shutdown LOCA

TASK NUMBER: 1140260401

QUESTION: _____

RESPONSE: _____

RESULT: -SAT -UNSAT

QUESTION: _____

RESPONSE: _____

RESULT: -SAT -UNSAT

JOB PERFORMANCE MEASURE

INITIAL CONDITIONS:

1. Reactor is shutdown and cooldown to 275 °F and 325 psig.
2. The 22 Charging pump and both SI pumps are removed from service.
3. The accumulators have been isolated.

INITIATING CUE:

Respond to a decreasing pressurizer level. Notify the CRS when level is rising.

*Do we need to tell candidate
this. Why can't he just take
the watch & go from there?*

JPM QUESTION #1

Unit 2 is in Mode 3 during a plant shutdown to cold shutdown when a LOCA occurred. AB.LOCA-0001 step 3.76 is being performed. Given the following conditions, determine if the 22 SI Pump can be secured. Justify your answer.

- No RCPs are running
- 21 Charging Pump is running
- 22 SI Pump is running
- 22 RHR pump is running in the S/D Cooling Mode.
- WRTC = 338°
- WRTH = 345°
- PT403 = 360 psig
- PT405 = 350 psig
- Pressurizer level is 42%

OPEN REFERENCE

ANSWER:

Per step 3.76, 90° subcooling is required.
From Att. 5, T_{sat} at 350 psi=436°.
Subcool=436°-345°=91°.

The pump can be secured.

Note: Attachment 5 provides saturation temperatures.

KA #: 009 EA2.34 //3.6/4.2//

Objective: 0300-000.00S-ABLOCA-02, Obj. 7

Reference: S2.OP-AB.LOCA0001

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #1

Unit 2 is in Mode 3 during a plant shutdown to cold shutdown when a LOCA occurred. AB.LOCA-0001 step 3.76 is being performed. Given the following conditions, determine if the 22 SI Pump can be secured. Justify your answer.

- No RCPs are running
- 21 Charging Pump is running
- 22 SI Pump is running
- 22 RHR pump is running in the S/D Cooling Mode.
- WRTC = 338°
- WRTH = 345°
- PT403 = 360 psig
- PT405 = 350 psig
- Pressurizer level is 42%

OPEN REFERENCE

JPM QUESTION #2

Unit 2 was in Mode 3 with shutdown cooling in service when a LOCA occurred. Given the following parameters, determine if natural circulation cooling has been established.

Parameter	T=0	T=+15min
PT403	360 psi	360 psi
WRTH	345°	341°
WRTC	338°	336°
S/G Press	100 psi	99 psi

OPEN REFERENCE

ANSWER:

Yes.

RCS subcooling is >0
Steam Generator Pressures are stable
RCS Wide Range Hot Leg temperatures are dropping
RCS Wide Range Cold Leg temperatures are at saturation temperature for Steam Generator pressure.

necessary

KA #: 009 EK1.01 //4.2/4.7//

Objective: 0300-000.00S-ABLOCA-02, Obj. 7

Reference: AB.LOCA-0001, Att. 7

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #2

Unit 2 was in Mode 3 with shutdown cooling in service when a LOCA occurred. Given the following parameters, determine if natural circulation cooling has been established.

Parameter	T=0	T=+15min
PT403	360 psi	360 psi
WRTH	345°	341°
WRTC	338°	336°
S/G Press	100 psi	99 psi

OPEN REFERENCE

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

11

STATION: Salem 1 & 2
SYSTEM: Nuclear Instrumentation System
TASK: Take Corrective Action for an Intermediate Range Instrument Malfunction

TASK NUMBER: 015 529 04 01

JPM NUMBER: 45

APPLICABILITY:

EO RO SRO

K/A NUMBER: 2.4.50
IMPORTANCE FACTOR:

3.3	3.3
RO	SRO

EVALUATION SETTING/METHOD: Simulator

REFERENCES: S2.OP-AR.ZZ-0005(Q) Overhead Annunciators Window E
S2.OP-AB.NIS-0001(Q) Nuclear Instrumentation System Malfunctions
S2.OP-SO.RPS-0001(Q) Nuclear Instrumentation Channel Trip /Restoration

TOOLS AND EQUIPMENT:

VALIDATED JPM COMPLETION TIME: 10 mins.

TIME PERIOD IDENTIFIED FOR TIME CRITICAL STEPS: N/A

APPROVED: _____
PRINCIPAL TRAINING SUPERVISOR OPERATIONS MANAGER

CAUTION: No plant equipment shall be operated during the performance of a JPM without the following:

1. Permission for the OS Or Unit CRS;
2. Direct oversight by a qualified individual (determined by the individual granting permission based on plant conditions).
3. Verification of the "as left" condition by a qualified individual.

ACTUAL JPM COMPLETION TIME: _____
ACTUAL TIME CRITICAL COMPLETION TIME: _____
JPM PERFORMED BY: _____ GRADE: SAT UNSAT
REASON, IF UNSATISFACTORY:
EVALUATOR'S SIGNATURE: _____ DATE: _____

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

NAME: _____

DATE: _____

SYSTEM: Nuclear Instrumentation System

TASK: Take Corrective Action for an Intermediate Range Instrument Malfunction

TASK NUMBER: 015 529 04 01

INITIAL CONDITIONS: IC-8, 25% power; Malfunction NI0197A

1. The Unit is at-power.
2. A reactor shutdown is required due to other equipment being out of service.
3. Excessive noise has been observed on N-35 Intermediate Range NI.

INITIATING CUE:

You have been directed to remove N-35 from service.

Successful Completion Criteria:

1. All critical steps completed.
2. All sequential steps completed in order.
3. All time-critical steps completed within allotted time.
4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made (and NRC concurrence is obtained).

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: Nuclear Instrumentation System

TASK: Take Corrective Action for an Intermediate Range Instrument Malfunction

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
	1	REMOVE the failed Intermediate Range channel from service IAW S2.OP-SO.RPS-0001(Q), Nuclear Instrumentation Channel Trip/Restoration.	Obtains current copy of procedure S2.OP-SO.RPS-0001 and proceeds to <u>Placing N-35 Intermediate Range NI in Tripped Condition</u> section of procedure. <i>NOTE: This is a Category I procedure. Work Standards require that the operator refer to the procedure at each step of the task. Individual step documentation shall be complete prior to proceeding to the next step</i>		
	2	Verify the tripping of associated bistable(s) will not result in an RPS or ESF actuation.	Determines tripping bistable will NOT result in a coincidence that will cause RPS or ESF actuation.		
	3	Ensure 2N35 Channel is not selected on NIS Recorder 2NR45.	Selects 2N36 Channel to NIS Recorder 2NR45 if required.		
	4	Record time, channel number, and Action Statement in SC.OP-DL.ZZ-0001(Q), Control Room Operator/Supervisor Logs.	Notes the required data is to be recorded in Control Room Operator/Supervisor Logs.		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

SYSTEM: Nuclear Instrumentation System

TASK: Take Corrective Action for an Intermediate Range Instrument Malfunction

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
*	5	At NI Rack No. 78, INTERMEDIATE RANGE 2N35 Drawer, place LEVEL TRIP switch in BYPASS and verify LEVEL TRIP BYPASS light is illuminated.	Place N35 Trip Switch in BYPASS and verify bistable light illuminated. <i>CUE: If the operator calls for an I&C Technician, then inform the operator that I&C is not available and the operator is to perform all actions. A second operator will monitor the Control Room Panels.</i>		
	6	VERIFY OHA E-29, SR & IR TRIP BYP, is illuminated.	Checks status and acknowledges OHA E-29.		
	7	VERIFY Reactor Panel Status light, NIS INTERMEDIATE RANGE, CH I, TRIP BLOCKED is illuminated.	Checks status of Panel light lit.		
*	8	At NI Rack No. 78, REMOVE both INSTRUMENT POWER fuses from the INTERMEDIATE RANGE 2N35 Drawer and verify INSTRUMENT POWER ON light is off.	Remove BOTH Instrument Power fuses from N35 drawer and verify Instrument Power On bistable light is extinguished.		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: Nuclear Instrumentation System

TASK: Take Corrective Action for an Intermediate Range Instrument Malfunction

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
	9	<u>IF</u> (power level)....	Determines reactor power is Greater Than 5% and power operation can continue.		

Terminating Cue: N35 channel OOS and determined power operations can continue.

**JOB PERFORMANCE MEASURE
FOLLOW-UP QUESTION DOCUMENTATION:**

NAME: _____

DATE: _____

SYSTEM: Nuclear Instrumentation System

TASK: Take Corrective Action for an Intermediate Range Instrument Malfunction

TASK NUMBER: 015 529 04 01

QUESTION: _____

RESPONSE: _____

RESULT: -SAT -UNSAT

QUESTION: _____

RESPONSE: _____

RESULT: -SAT -UNSAT

JOB PERFORMANCE MEASURE

INITIAL CONDITIONS:

1. The Unit is at-power.
2. A reactor shutdown is required due to other equipment being out of service.
3. Excessive noise has been observed on N-35 Intermediate Range NI.

INITIATING CUE:

You have been directed to remove N-35 from service.

JPM QUESTION #1

A reactor startup is in progress. The compensating voltage on one intermediate range channel is set too low.

1. How will this affect when the source range can be blocked as power is increased?
2. What will be the effect on indicated SUR during the startup?

CLOSED REFERENCE

ANSWER:

1. The source range instruments could be blocked at a lower power level.
2. Indicated startup rate will be less than actual startup rate [but the effect of the undercompensation will dissipate as power (neutron population) rises].

[] not required for full credit

KA #: 015 A2.02 //3.1/3.5//

Objective: 0300-000.00S-EXCORE-00, Obj. 5

Reference: 0300-000.00S-EXCORE-00, Section IV.D.2.h.4) b)

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #1

A reactor startup is in progress. The compensating voltage on one intermediate range channel is set too low.

1. How will this affect when the source range can be blocked as power is increased?
2. What will be the effect on indicated SUR during the startup?

CLOSED REFERENCE

JPM QUESTION #2

At 80% what will be the expected status of the "HIGH LEVEL TRIP" light on the Intermediate Range drawer?

OPEN REFERENCE

FOLLOWUP QUESTION

What prevents a reactor trip from occurring?

ANSWER:

The bistable in the NI drawer will be tripped as indicated by the illuminated light.

FOLLOWUP ANSWER:

The bypass circuit (P-10) blocks the output to RPS.

KA #: 015 A3.03 //3.9/3.9//

Objective: 0300-000.00S-EXCORE-00, Obj. 10
Reference: 0300-000.00S-EXCORE-00, IV.D.3.e.3)
Logic diagram 221052

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #2

At 80% what will be the expected status of the "HIGH LEVEL TRIP" light on the Intermediate Range drawer?

OPEN REFERENCE

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

12

STATION: Salem 1 & 2
SYSTEM: Containment System
TASK: Start a Hydrogen Recombiner
TASK NUMBER: 022 526 05 01
JPM NUMBER: 49

K/A NUMBER: 028 A4.01
IMPORTANCE FACTOR:

4.0*	4.0*
RO	SRO

APPLICABILITY: EO RO SRO

EVALUATION SETTING/METHOD: Walk-thru in Simulator or Control Room

REFERENCES: S2.OP-SO.CAN-0001(Q) Hydrogen Recombiner Operation

TOOLS AND EQUIPMENT:

VALIDATED JPM COMPLETION TIME: 8 mins.

TIME PERIOD IDENTIFIED FOR TIME CRITICAL STEPS:

APPROVED: _____
PRINCIPAL TRAINING SUPERVISOR OPERATIONS MANAGER

CAUTION: No plant equipment shall be operated during the performance of a JPM without the following:
1. Permission for the OS Or Unit CRS;
2. Direct oversight by a qualified individual (determined by the individual granting permission based on plant conditions).
3. Verification of the "as left" condition by a qualified individual.

ACTUAL JPM COMPLETION TIME: _____
ACTUAL TIME CRITICAL COMPLETION TIME: _____
JPM PERFORMED BY: _____ GRADE: SAT UNSAT
REASON, IF UNSATISFACTORY:
EVALUATOR'S SIGNATURE: _____ DATE: _____

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

SYSTEM: Containment System

TASK: Start a Hydrogen Recombiner

TASK NUMBER: 022 526 05 01

INITIAL CONDITIONS:

1. A LOCA has occurred on the Unit.
2. Pre-LOCA conditons: Reactor Power - 100%; Pzr Pressure - 2235 psig; Containment Pressure - 0.1 psig; Containment Temperature - 90 degrees F
3. Current pertinent conditions: Pzr Pressure - 1050 psig; Containment Pressure - 4.0 psig; Containment Temperature - 225 degrees F; Containment Hydrogen Concentration - 2.1%

INITIATING CUE:

The CRS directs you to place the 21 Hydrogen Recombiner in service IAW S2.OP-SO.CAN-0001(Q)

Successful Completion Criteria:

1. All critical steps completed.
2. All sequential steps completed in order.
3. All time-critical steps completed within allotted time.
4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made (and NRC concurrence is obtained).

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

SYSTEM: Containment System

TASK: Start a Hydrogen Recombiner

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
		Obtains procedure S2.OP-SO.CAN-0001(Q).	Correct procedure obtained or provided <i>NOTE: This is a Category II procedure. Work Standards require that the procedure should be at the jobsite. The operator should refer to the procedure at the beginning and end of the job and as frequently as necessary. (Based on the task, experience of the operator, familiarization with the task, etc.) to complete the job in accordance with the procedure.</i>		
	1	Perform Attachment 1 to determine Recombiner Power Setting.	Obtains Attachment 1		
	2	Determine the Pre-LOCA Temperature from SC.OP-DL.ZZ-0003(Q), Control Room Readings Mode 1-4	Determines Pre-LOCA Containment Temperature is 90°F (from initial conditions).		
	3	Determine the Containment Pressure as indicated on 2PI-948A, 2PI-948B, 2PI-948C or 2PI-948D.	Determines containment pressure is 4 psig (from initial conditions) OR by checking PI-948A-D or recorder PR948A/B.		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: Containment System

TASK: Start a Hydrogen Recombiner

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
	4	Using the PRE-LOCA Containment Temperature and Containment Pressure, determine the Power Correction Factor (Cp), IAW Attachment 2.	Determines the Power Correction Factor to be 1.21 (1.20-1.22).		
*	5	Perform the calculation to determine the Recombiner Power Setting:	Using Att. 1, determines power setting to be 53 to 54 KW (52.8-53.7 KW by calculation).		
*	6	Place both Recombiner Control Switches on 2RP5 in the ON position	<i>Cue: Operate only 21 H2 Recombiner.</i> Places 21 H2 Recombiner control switch to ON		
	7	Ensure the white power available lights are illuminated at each Recombiner Control Panels	Verifies power available lights are lit. <i>Cue: White power available light is ON.</i>		
	8	Perform the following for the Recombiner to be operated: Ensure the power adjust Potentiometer is set at zero.	For 21 H2 Recombiner, verifies Power Adjust Pot is at zero.		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: Containment System

TASK: Start a Hydrogen Recombiner

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
*	9	Turn the power out switch to the ON position <u>and</u> ensure the red light is illuminated.	Turns Power Out Switch to ON and verifies red light is lit. <i>Cue: Red light is ON.</i>		
*	10	Turn the power adjust Potentiometer in the clockwise direction until the correct power setting is obtained on the Power Out Wattmeter.	Adjusts Power Out Pot to read 53-54 KW on Wattmeter NOTE: Potentiometer setting of 530-540 corresponds to 53-54KW.		

Terminating Cue: Operator indicates the H2 Recombiner is set IAW calculation.

**JOB PERFORMANCE MEASURE
FOLLOW-UP QUESTION DOCUMENTATION:**

NAME: _____

DATE: _____

SYSTEM: Containment System

TASK: Start a Hydrogen Recombiner

TASK NUMBER: 022 526 05 01

QUESTION: _____

RESPONSE: _____

RESULT: -SAT -UNSAT

QUESTION: _____

RESPONSE: _____

RESULT: -SAT -UNSAT

JOB PERFORMANCE MEASURE

INITIAL CONDITIONS:

1. A LOCA has occurred on the Unit.
2. Pre-LOCA conditons: Reactor Power - 100%; Pzr Pressure - 2235 psig; Containment Pressure - 0.1 psig; Containment Temperature - 90 degrees F
3. Current pertinent conditions: Pzr Pressure - 1050 psig; Containment Pressure - 4.0 psig; Containment Temperature - 225 degrees F; Containment Hydrogen Concentration - 2.1%

INITIATING CUE:

The CRS directs you to place the 21 Hydrogen Recombiner in service IAW S2.OP-SO.CAN-0001(Q)

JPM QUESTION (Day 2&3)

A large break LOCA occurred, a H2 Recombiner was placed in service and the setting is now 73 KW. In the past 24 hours, containment hydrogen concentration has risen steadily from 2.8% to 3.3%.

What action can be taken by the shift relative to recombiner operation?

OPEN REFERENCE

ANSWER:

Raise heater output to 75 KW (maximum allowed) and [inform the TSC]

[] not required for full credit

KA #: 028 A2.01 //3.4/3.6//

Objective: 0300-000.00S-CONTMT-00, Obj. 12.

Reference: S2.OP-SO.CAN-0001, Step 5.1.7.

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION

A large break LOCA occurred, a H₂ Recombiner was placed in service and the setting is now 73 KW. In the past 24 hours, containment hydrogen concentration has risen steadily from 2.8% to 3.3%.

What action can be taken by the shift relative to recombiner operation?

OPEN REFERENCE

JPM QUESTION #1 (Day 2)

What are the two most significant sources of hydrogen in containment following a LOCA and what is the purpose of maintaining control over hydrogen concentration?

OPEN REFERENCE

ANSWER:

1. Zirconium-water reaction
2. Radiolytic decomposition of reactor coolant and of post-LOCA injection cooling (containment sump) water

Maintaining control of hydrogen concentration prevents a hydrogen burn that could lead to a pressure spike and thereby challenge containment integrity.

KA #: 028 K5.03 //2.9/3.6//

Objective: 0300-000.00S LOCA01, Obj. 9
Reference: 0300-000.00S-CONTMT-00, Section IX.D
EOP-LOCA-1 Basis
UFSAR

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION

What are the two most significant sources of hydrogen in containment following a LOCA and what is the purpose of maintaining control over hydrogen concentration?

OPEN REFERENCE

JPM QUESTION #1(Day 3)

List three situations that require placing the Hydrogen Recombiners in service. Include the minimum and maximum hydrogen concentrations, if appropriate.

OPEN REFERENCE

ANSWER:

- When directed by various EOPs (min .5%, maximum 4%)
- When recommended by the TSC
- When chemistry sample indicates containment hydrogen concentration increasing to 2% (maximum of 4.0%)

NOTE: The evaluator may have to prompt that that EOPs is only considered as one of the three situations.

KA #: 028 A1.01 //3.4/3.8//

Objective: 0300-000.00S-LOCA01-01, Obj. 11

Reference: 2-EOP-LOCA-1, Step 24
S2.OP-SO.CAN-0001, Step 2.3

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #1

List three situations that require placing the Hydrogen Recombiners in service. Include the minimum and maximum hydrogen concentrations, if appropriate.

OPEN REFERENCE

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

12

STATION: Salem

SYSTEM: CVCS

TASK: Place CVCS make-up control in the MANUAL Mode.

TASK NUMBER: 004 013 01 01

JPM NUMBER:

K/A NUMBER: A4.07

APPLICABILITY:

IMPORTANCE FACTOR:

EO RO SRO

3.9	3.7
RO	SRO

EVALUATION SETTING/METHOD: Simulator

REFERENCES: S2.OP-SO.CVC-0006, Rev. 6

TOOLS AND EQUIPMENT: None

VALIDATED JPM COMPLETION TIME: 10 mins.

TIME PERIOD IDENTIFIED FOR TIME CRITICAL STEPS: N/A

APPROVED: _____
PRINCIPAL TRAINING SUPERVISOR OPERATIONS MANAGER

CAUTION: No plant equipment shall be operated during the performance of a JPM without the following:

1. Permission for the OS Or Unit CRS;
2. Direct oversight by a qualified individual (determined by the individual granting permission based on plant conditions).
3. Verification of the "as left" condition by a qualified individual.

ACTUAL JPM COMPLETION TIME: _____

ACTUAL TIME CRITICAL COMPLETION TIME: _____

JPM PERFORMED BY: _____ GRADE: SAT UNSAT

REASON, IF UNSATISFACTORY: _____

EVALUATOR'S SIGNATURE: _____ DATE: _____

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

NAME: _____

DATE: _____

SYSTEM: CVCS

TASK: Place the CVCS make-up control in the MANUAL mode.

TASK NUMBER: 004 013 01 01

INITIAL CONDITIONS: VCT level transmitter LT-112 has failed. RCS boron concentration is 550 ppm.

SIMULATOR SETUP:

- Any @ power IC.
- Lower VCT level to the AUTO M/U setpoint.
- Fail VCT LT-112 HIGH

INITIATING CUE:

You are the Reactor Operator. The CVCS AUTO M/U function is inoperable due to the failure of LT-112. Perform a makeup with the control system in MANUAL.

Successful Completion Criteria:

1. All critical steps completed.
2. All sequential steps completed in order.
3. All time-critical steps completed within allotted time.
4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made (and NRC concurrence is obtained).

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

SYSTEM: CVCS

TASK: Place the CVCS make-up control in the MANUAL Mode.

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
	1	Operator obtains current revision of S2.OP-SO.CVC-0006.	<i>NOTE:</i> As of the development of this JPM the procedure was designated as Category III, a classification no longer in use. The procedure should be implemented IAW Work Standards Handbook guidance for Category II procedures.		
	2	Obtain Boric Acid Flow Setpoint using existing RCS boron concentration from S2.RE-RA.ZZ-0012(Q), Reactor Eng'g Manual, Figure 100A.	<i>CUE:</i> RCS boron concentration is 550 ppm.		
*	3	Depress Makeup Control Mode Select STOP PB.	STOP PB illuminated.		
	4	Place 2CV179, PRI WTR FLOW CONTROL VALVE, in MANUAL	2CV179 MANUAL PB illuminated.		
	5	Place 2CV172, BA FLOW CONTROL VALVE, in MANUAL	2CV172 MANUAL PB illuminated.		
*	6	Align outlet of Boric Acid Blender to one of the following: A. Open 2CV185, MAKEUP FROM BLENDER TO CHG PUMP SUCTION, OR, B. Open 2CV181, MAKEUP FROM BLENDER TO VCT.	Either 2CV185 or 2CV181 PB illuminated. Preferred path is through 2CV185.		
	7	Start Primary Water Pump.	START PB on either PW Pump illuminated.		
	8	Place Boric Acid Pump in FAST Speed.	FAST PB on either BA Pump illuminated.		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

SYSTEM: CVCS

TASK: Place the CVCS make-up control in the MANUAL Mode.

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
*	9	Manually adjust 2CV172 setpoint to REM Figure 100A value. If required BA Flow is not achieved, then close 21 and 22CV160 (Recirculation Valves).	Using INC/DEC PB's, adjusts BA Flow to 5.5- 6.2 gpm. 6.5		
*	10	Manually adjust 2CV179 Setpoint to 62 gpm.	Using INC/DEC PB's, adjusts PW Flow to 62 +/- 2gpm. <i>CUE: If makeup is in progress then inform operator the AUTO STOP setpoint has been reached and the makeup can be terminated.</i>		
	11	When desired to terminate makeup, perform the following: <ul style="list-style-type: none"> • Close 2CV179 • Close 2CV172 • Close CV185 • Close CV181 • Stop PW Makeup Pump • Place BA Pump selected in SLOW Speed • Return CVCS M/U Control System to AUTO IAW Section 5.1 of this procedure 	<ul style="list-style-type: none"> • CV179 CLOSE PB illuminated • CV172 CLOSE PB illuminated • CV185 CLOSE PB illuminated • CV181 CLOSE PB illuminated • PW Pump STOP PB illuminated • Correct BA Pump SLOW PB illuminated <i>NOTE: The JPM is complete when the BA Pump is in SLOW.</i>		

Initial conditions, slow map.

**JOB PERFORMANCE MEASURE
FOLLOW-UP QUESTION DOCUMENTATION:**

NAME: _____

DATE: _____

SYSTEM: CVCS

TASK: Place the CVCS makeup control in the MANUAL Mode.

TASK NUMBER: 004 013 01 01

QUESTION: _____

RESPONSE: _____

RESULT: -SAT -UNSAT

QUESTION: _____

RESPONSE: _____

RESULT: -SAT -UNSAT

INITIAL CONDITIONS:

1. VCT level transmitter LT-112 has failed. RCS boron concentration is 550 ppm.

INITIATING CUE:

You are the Reactor Operator. The CVCS AUTO M/U function is inoperable due to the failure of LT-112. Perform a makeup with the control system in MANUAL.

JPM QUESTION #1

A reactor trip has occurred but three control rods fail to fully insert. An SI has not occurred. 2CV175, Rapid Borate Stop Valve cannot be opened. What method of boration is required and how long is this method required to be performed?

OPEN REFERENCE

ANSWER:

The charging pumps suction would have to be aligned to the RWST and the boration would have to occur for 360 minutes.

KA #: 024 AA2.05 //3.3/3.5//

Objective: 0300-000.00S-TRP002-01, LO. 8

Reference: 2-EOP-TRIP-2, Sheet 1 of 4.

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #1

A reactor trip has occurred but three control rods fail to fully insert. An SI has not occurred. 2CV175, Rapid Borate Stop Valve cannot be opened. What method of boration is required and how long is this method required to be performed?

OPEN REFERENCE

JPM QUESTION #2

Reactor power is 85%. 2A EDG was removed from service for maintenance at 1600 on 2/24/99. All required Technical Specification Action Statements (TSAS's) were entered. 22 Charging pump has been declared inoperable at 0800, 2/25/99, and 2A EDG remains inoperable.

Identify all TSAS's that must be entered when the 22 Charging Pump is declared inoperable.

SRO ONLY – To prevent having to perform a reactor shutdown, when would 2A EDG and 22 charging pump be required to be returned to service?

OPEN REFERENCE

ANSWER:

The following LCOs have to be entered: 3.1.2.2, 3.1.2.4, and 3.5.2

SRO Only:

2A EDG must be returned to service NLT 1600, 2/27/99

AND

22 Charging pump must be returned to service NLT 0800, 2/28/99

KA #: 2.2.22 //3.4/4.1//

Objective: 0300-000.00S-CVCS00-00 Obj. 10

Reference: TS 3.1.2.2, 3.1.2.4, 3.5.2

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #2

Reactor power is 85%. 2A EDG was removed from service for maintenance at 1600 on 2/24/99. All required Technical Specification Action Statements (TSAS's) were entered. 22 Charging pump has been declared inoperable at 0800, 2/25/99, and 2A EDG remains inoperable.

Identify all TSAS's that must be entered when the 22 Charging Pump is declared inoperable.

SRO ONLY – To prevent having to perform a reactor shutdown, when would 2A EDG and 22 charging pump be required to be returned to service?

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

14

STATION: Salem
SYSTEM: Emergency Operating Procedures
TASK: Terminate SI
TASK NUMBER: 1150040501

JPM NUMBER:

K/A NUMBER: E02 EA1.1

APPLICABILITY: EO RO SRO

IMPORTANCE FACTOR:

4.0	3.9
RO	SRO

EVALUATION SETTING/METHOD: Simulator

REFERENCES: EOP-TRIP-3

TOOLS AND EQUIPMENT: None

VALIDATED JPM COMPLETION TIME: 7 minutes

TIME PERIOD IDENTIFIED FOR TIME CRITICAL STEPS: N/A

APPROVED: G. Blinde
PRINCIPAL TRAINING SUPERVISOR

J. Konovalchick
OPERATIONS MANAGER

CAUTION: No plant equipment shall be operated during the performance of a JPM without the following:

1. Permission for the OS Or Unit CRS;
2. Direct oversight by a qualified individual (determined by the individual granting permission based on plant conditions).
3. Verification of the "as left" condition by a qualified individual.

ACTUAL JPM COMPLETION TIME: _____
ACTUAL TIME CRITICAL COMPLETION TIME: _____
JPM PERFORMED BY: _____ GRADE: SAT UNSAT
REASON, IF UNSATISFACTORY: _____
EVALUATOR'S SIGNATURE: _____ DATE: _____

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

NAME: _____

DATE: _____

SYSTEM: Emergency Operating Procedures

TASK: Terminate SI

TASK NUMBER: 1150040501

INITIAL CONDITIONS: An inadvertent SI occurred due to a technician error. The crew has transitioned from TRIP-1 to TRIP-3.

1. IC-98 for 2/99 NRC Exam - Initiate a MANUAL SI
2. Carry out the steps of EOP-TRIP-1, through the transition to TRIP-3 and snap.

INITIATING CUE:

An inadvertent SI has occurred due to a technician error. The crew just transitioned to 2-EOP-TRIP-3. You are the board operator. Starting at Step 1, carry out the actions of TRIP-3.

Successful Completion Criteria:

1. All critical steps completed.
2. All sequential steps completed in order.
3. All time-critical steps completed within allotted time.
4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made (and NRC concurrence is obtained).

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: Emergency Operating Procedures

TASK: Terminate SI

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
*	2	Reset SI	Depresses Train A and Train B SI RESET PB's		
		Reset Phase A Isolation	Depresses Train A and Train B PHASE A ISOLATION RESET PB's		
		Reset Phase B Isolation	Depresses Train A and Train B PHASE B ISOLATION RESET PB's		
		Open 21 and 22CA330	Open indication on 21 and 22CA330 <i>Note:</i> PZR Spray may initiate, lowering RCS pressure		
*		Reset each SEC	Depresses RESET PB's for 2A, 2B, and 2C SEC		
	3	Are all SEC's Reset	Verifies all SEC's are reset		
		Reset all 230V Control Centers	Depresses RESET on 2A, 2B, and 2C 230V Control Centers		
*	4	Stop all but 21 or 22 Charging Pump	Stops 21 <u>OR</u> 22 Charging Pump <i>and 23</i>		
	5	Is RCS Pressure stable or rising?	Yes		

TERMINATION: Verifies RCS Pressure is stable or rising.

**JOB PERFORMANCE MEASURE
FOLLOW-UP QUESTION DOCUMENTATION:**

NAME: _____

DATE: _____

SYSTEM: Emergency Operating Procedures

TASK: Terminate SI

TASK NUMBER: 1150040501

QUESTION: _____

RESPONSE: _____

RESULT: -SAT -UNSAT

QUESTION: _____

RESPONSE: _____

RESULT: -SAT -UNSAT

JOB PERFORMANCE MEASURE

INITIAL CONDITIONS:

1. An inadvertent SI occurred due to a technician error. The crew has transitioned from TRIP-1 to TRIP-3.

INITIATING CUE:

An inadvertent SI has occurred due to a technician error. The crew just transitioned to 2-EOP-TRIP-3. You are the board operator. Starting at Step 1, carry out the actions of TRIP-3.

JPM QUESTION #1

inside ctmt

A steam break has occurred causing a SI on high containment pressure. The MSIV's are closed. Reactor Trip Breaker "A" did not open and remains closed. All steps through 29.1 of EOP-TRIP-1 were completed and the crew transitioned to EOP-TRIP-3.

What will be the status of both trains of SI after the operator depresses SI RESET IAW TRIP-3? *and why is this so?*

OPEN REFERENCE

ANSWER:

Both trains will reset because a P-4 jumper was installed in EOP-TRIP-1.

KA #: 013 K4.01 //3.9/4.3//

Objective: 300-000.00S-TRIP-1, Obj. 22
Reference: 221057, Reactor Protection System Sheet 8
EOP-TRIP-1 and Basis Document

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #1

A steam break has occurred causing a SI on high containment pressure. The MSIV's are closed. Reactor Trip Breaker "A" did not open and remains closed. All steps through 29.1 of EOP-TRIP-1 were completed and the crew transitioned to EOP-TRIP-3.

What will be the status of both trains of SI after the operator depresses SI RESET IAW TRIP-3?

OPEN REFERENCE

JPM QUESTION #2

A LOCA has occurred on Unit 2. Per direction in the EOPs, the SI signal may have been reset before LOCA-3 is entered.

How is the functionality of the Semi-Automatic Swapover to Cold Leg Recirculation feature affected if the SI actuation signal has been manually reset prior to entering LOCA-3?

OPEN REFERENCE

ANSWER:

The Semi-Automatic Swapover to Cold Leg Recirculation will still function because there is a latching relay that locks in the SI signal. [The locked in signal is reset using the RESET "S" SIGNAL pushbutton on each Safeguards Bezel.]

[] not required for full credit

KA #: 013 K4.06 //4.0/4.3//

Objective: 0300-000.00S-ECCS00-00, Obj. 9
Reference: 0300-000.00S-ECCS00-00, Section IV.F.5.b.2)
S2-OP-SO.SJ-0004, Post SI Systems Re-alignment

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #2

A LOCA has occurred on Unit 2. Per direction in the EOPs, the SI signal may have been reset before LOCA-3 is entered.

How is the functionality of the Semi-Automatic Swapover to Cold Leg Recirculation feature affected if the SI actuation signal has been manually reset prior to entering LOCA-3?

OPEN REFERENCE

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

15

STATION: Salem 1 & 2
SYSTEM: Pressurizer Pressure Control
TASK: Take Corrective Action for a Failed Open Pressurizer Spray Valve (PS3)

TASK NUMBER: 114 024 04 01

JPM NUMBER: ABPZRPS3

APPLICABILITY:

EO RO SRO

K/A NUMBER: 027 AA1.01

IMPORTANCE FACTOR:

4.0	3.9
RO	SRO

EVALUATION SETTING/METHOD: Simulator

REFERENCES: S2.OP-AB.PZR-0001(Q) Pressurizer Pressure Malfunction

TOOLS AND EQUIPMENT:

VALIDATED JPM COMPLETION TIME: 5 min.

TIME PERIOD IDENTIFIED FOR TIME CRITICAL STEPS:

APPROVED: _____
PRINCIPAL TRAINING SUPERVISOR OPERATIONS MANAGER

CAUTION: No plant equipment shall be operated during the performance of a JPM without the following:

1. Permission for the OS Or Unit CRS;
2. Direct oversight by a qualified individual (determined by the individual granting permission based on plant conditions).
3. Verification of the "as left" condition by a qualified individual.

ACTUAL JPM COMPLETION TIME: _____
ACTUAL TIME CRITICAL COMPLETION TIME: _____
JPM PERFORMED BY: _____ GRADE: SAT UNSAT
REASON, IF UNSATISFACTORY:
EVALUATOR'S SIGNATURE: _____ DATE: _____

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

NAME: _____

DATE: _____

SYSTEM: Pressurizer Pressure Control

TASK: Take Corrective Action fo a Failed Open Pressurizer Spray Valve (2PS3)

TASK NUMBER: 114 024 04 01

INITIAL CONDITIONS:

1. Plant conditions are stable. You are the Reactor Operator.

INITIATING CUE:

Respond to changing plant conditions as the Reactor Operator.

Successful Completion Criteria:

1. All critical steps completed.
2. All sequential steps completed in order.
3. All time-critical steps completed within allotted time.
4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made (and NRC concurrence is obtained).

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

SYSTEM: Pressurizer Pressure Control

TASK: Take Corrective Action for a Failed Open Pressurizer Spray Valve (PS3)

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
	1	Operator responds to PZR Pressure dropping and/or alarm and/or change in 2PS3 position.	Enters S2.OP-AB.PZR-0001 directly or via an ARP. <i>NOTE:</i> It is acceptable for the operator to attempt closing PS3 prior to entering AB.PZR.		
	2	Is POPS in service?	Determines POPS NOT in service. (NO)		
	3	Is the controlling PZR Pressure Control Channel (I or III) failed?	Checks PZR pressure channels PI455 and PI457 and determines NEITHER failed. (NO)		
	4	Is the Master Pressure Controller controlling pressure consistent with actual pressure as shown on Attachment 1?	Checks PZR Master Pressure Controller output demand and determines "normal" for plant conditions. (YES) <i>NOTE:</i> May not refer to Att. 1 if 2PS3 has been noted open with pressure below closing setpoint.		
	5	Are the Spray Valves controlling pressure consistent with Att. 1?	Identifies 2PS3 is open. (NO)		
*	6	Place the Spray Valve(s) in MANUAL	Selects MANUAL on at least 2PS3.		
*	7	Operate the Spray Valves to control pressure consistent with Att. 1.	Attempts to close 2PS3 using valve pushbuttons Identifies failure of valve to close.		
	8	Has pressure control been regained?	Determines PZR pressure decreasing. (NO)		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

SYSTEM: Pressurizer Pressure Control

TASK: Take Corrective Action for a Failed Open Pressurizer Spray Valve (PS3)

#	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
	9	Is RCS pressure dropping rapidly?	Determines PZR pressure drop is rapid. (YES)		
*	10	Trip the Reactor	Initiates a Reactor Trip using either MANUAL TRIP handle.		
	11	Is Reactor Trip confirmed?	Determines reactor is tripped : <ul style="list-style-type: none"> • Rx trip breakers open • Rod Bottom lights lit • Decreasing PR NIS Power and negative IR SUR. (YES) <i>NOTE:</i> It may be necessary for evaluator to tell candidate that IA's for the reactor trip will be performed by another individual. Complete AB.PZR.		
*	12	Stop 23 RCP	Depresses STOP PB on 23 RCP and verifies breakers opened.		

Terminating Cue: Operator determines further actions are addressed in EOP-TRIP-1.

**JOB PERFORMANCE MEASURE
FOLLOW-UP QUESTION DOCUMENTATION:**

NAME: _____

DATE: _____

SYSTEM: Pressurizer Pressure Control

TASK: Take Corrective Action fo a Failed Open Pressurizer Spray Valve (2PS3)

TASK NUMBER: 114 024 04 01

QUESTION: _____

RESPONSE: _____

RESULT: -SAT -UNSAT

QUESTION: _____

RESPONSE: _____

RESULT: -SAT -UNSAT

JOB PERFORMANCE MEASURE

INITIAL CONDITIONS:

1. Plant conditions are stable. You are the Reactor Operator.

INITIATING CUE: Respond to changing plant conditions as the Reactor Operator.

JPM QUESTION #1

If PS1 is suspected to be leaking, both 21 and 23 RCPs are stopped. If PS3 is suspected to be leaking only 23 RCP is stopped. Why is there a difference in the actions?

CLOSED REFERENCE

ANSWER:

Most spray flow is provided by 23 RCP through either PS3 or PS1. An alternative correct answer is that 21RCP produces a negligible amount of flow through PS3

KA #: 010 K1.03 //3.6/3.7//

Objective: 0300-000-00S-ABPZR1-01, Obj. 1
Reference: 0300-000-00S-ABPZR1-01, Explanation for the note prior to Step 3.20.
Technical Basis for S2.OP-AB.PZR-0001, Explanation for Steps 3.16 through 3.41.

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #1

If PS1 is suspected to be leaking, both 21 and 23 RCPs are stopped. If PS3 is suspected to be leaking only 23 RCP is stopped. Why is there a difference in the actions?

CLOSED REFERENCE

JPM QUESTION #2

Prior to stopping a RCP in AB.PZR-1 the operator is directed to select the turbine controls to "IMP OUT" or "TURBINE MANUAL" to prevent a RCS cooldown. How does this action prevent a RCS cooldown?

OPEN REFERENCE

ANSWER:

[In "IMP IN" the turbine is controlled via a first stage pressure signal. If a RCP is tripped steam pressure will lower, causing the turbine governor valves to open to maintain load. The increased steam flow will cause a drop in T_{avg} .] In "IMP OUT" or "TURBINE MANUAL" the turbine has fixed inputs for valve position therefore it does not respond to steam header pressure changes.

[] not necessary to answer question.

KA #: 027 AK3.03 //3.7/4.1//

Objective: 0300-000-00S-ABPZR1-01, Obj. 2

Reference: Technical Basis for S2.OP-AB.PZR-0001, Explanation for Steps 3.16 through 3.41.

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #2

Prior to stopping a RCP in AB.PZR-1 the operator is directed to select the turbine controls to "IMP OUT" or "TURBINE MANUAL" to prevent a RCS cooldown. How does this action prevent a RCS cooldown?

OPEN REFERENCE

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

16

STATION: Salem
SYSTEM: Feedwater
TASK: Prompt Recovery from a SGFP Trip
TASK NUMBER: 1150290501

JPM NUMBER:

K/A NUMBER: 2.1.23

APPLICABILITY: EO RO SRO

IMPORTANCE FACTOR:

3.9	4.0
RO	SRO

EVALUATION SETTING/METHOD:

REFERENCES: S2.OP-SO.CN-0007, Prompt Recovery from SGFP Trip

TOOLS AND EQUIPMENT: None

VALIDATED JPM COMPLETION TIME: 15 mins.

TIME PERIOD IDENTIFIED FOR TIME CRITICAL STEPS: N/A

APPROVED: _____
PRINCIPAL TRAINING SUPERVISOR OPERATIONS MANAGER

CAUTION: No plant equipment shall be operated during the performance of a JPM without the following:

1. Permission for the OS Or Unit CRS;
2. Direct oversight by a qualified individual (determined by the individual granting permission based on plant conditions).
3. Verification of the "as left" condition by a qualified individual.

ACTUAL JPM COMPLETION TIME: _____
ACTUAL TIME CRITICAL COMPLETION TIME: _____
JPM PERFORMED BY: _____ GRADE: SAT UNSAT
REASON, IF UNSATISFACTORY:
EVALUATOR'S SIGNATURE: _____ DATE: _____

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

SIMULATOR SETUP INSTRUCTIONS

SYSTEM: Feedwater

TASK: Prompt Recovery from a SGFP Trip

TASK NUMBER: 1150290501

SIMULATOR IC: IC-85 for 2/99 NRC Exam (Start from a power IC where only one SGFP would be in service)

MALFUNCTIONS REQUIRED:

- Malfunctions to prevent any AFW pumps from starting.
- Malfunction to trip the running SGFP

OVERRIDES REQUIRED:

SPECIAL INSTRUCTIONS: Trip the running SGFP. Then complete actions of 2-EOP-FRHS-1 up to step 13.
Ensure the Simulator Operator has a copy of S2.OP-SO.CN-0007.

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

NAME: _____

DATE: _____

SYSTEM: Feedwater

TASK: Prompt Recovery from a SGFP Trip

TASK NUMBER: 1150290501

INITIAL CONDITIONS:

1. The reactor was operating at 38% power.
2. 22 SGFP was running and spuriously tripped during instrumentation testing.
3. During the reactor trip no AFW pumps started.
4. All actions for 2-EOP-TRIP 1 and 2-EOP-FRHS-1 have been completed to step 13 of FRHS-1.
5. An SI has NOT occurred.
6. 21 SGFP is available for starting.

INITIATING CUE:

The CRS has directed that 21 SGFP be promptly ~~restarted~~.

Successful Completion Criteria:

1. All critical steps completed.
2. All sequential steps completed in order.
3. All time-critical steps completed within allotted time.
4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made (and NRC concurrence is obtained).

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: Feedwater

TASK: Prompt Recovery from SGFP Trip

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
		Obtains S2.OP-SO.CN-0007(Q), Prompt Recovery from SGFP Trip	Correct procedure obtained. <i>NOTE: This is a Category II procedure. Work Standards require that the procedure should be at the job site. The operator should refer to the procedure at the beginning and end of the job and as frequently as necessary (based on the task, experience of the operator, familiarization with the task, etc.) to complete the job in accordance with the procedure.</i>		
	1.	Review prerequisites and precautions and limitations.	<i>CUE: The CRS has verified all prerequisites have been met and has reviewed the precautions</i>		
	2.	Ensure all SGFP trips are clear.	<i>CUE: A Local Equipment Operator has verified that all trips are clear.</i>		
	3.	Ensure SGFP suction pressure is greater than 350 psig.	Verifies SGFP suction pressure on PI-509 PUMP SUCT PRESS		
	4.	Verify 21 SGFP is tripped.	Verifies TURBINE TRIP light illuminated or HP and LP Stop valves close indication illuminated.		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: Feedwater

TASK: Prompt Recovery from SGFP Trip

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
	5	Direct a local operator to place 21 SGFP Turbine Enable/disable switch 2ND17482, in Panel 362-2, in the DISABLE position.	Local operator directed to perform the action. <i>CUE: Local operator reports that the 21 SGFP Turbine Enable/Disable is in the DISABLE position.</i>		
	6.	Direct an operator to locally at 2SA2805, Woodward governor controller keypad, to depress the CLR key and verify the LCD displays "CONTROLLING PARAM PUSH RUN OR PROGRAM".	Local operator directed to perform the action. <i>CUE: Local operator reports the CLR key has been depressed and the LCD displays "CONTROLLING PARAM PUSH RUN OR PROGRAM".</i>		
	7.	Select 21TD24, TURBINE DRAINS, OPEN.	Verifies 21TD24 opens		
	8.	Ensure 21CN36, WARM-UP is OPEN.	Ensures 21CN36 WARM-UP OPEN is illuminated.		
	9.	Verify Pump Casing delta T is ≤ 40 °F.	Verifies pump casing delta T is ≤ 40 °F using the process computer.		
	10.	Depress MODULATE RECIRC VALVE pushbutton and ensure 21BF32 RECIRC OPEN indication.	Depresses 21BF32 MODULATE RECIRC VALVE PB. Verifies 21BF32 RECIRC OPEN indication illuminates.		
	11.	Verify 21CN32 PUMP SUCTION VALVE is open.	Verifies 21CN32 PUMP SUCTION VALVE OPEN light is illuminated.		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

SYSTEM: Feedwater

TASK: Prompt Recovery from SGFP Trip

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
	12.	Verify 21BF32 RECIRC is open.	Verifies 21BF32 RECIRC OPEN light is illuminated.		
	13.	Verify 21MS43 HP STOP VALVE is closed.	Verifies 21MS43 HP STOP-CLS light is illuminated.		
	14.	Verify 21RS15 LP STOP VALVE is closed.	Verifies 21RS15 LP STOP-CLS light is illuminated.		
	15.	Verify SGFP suction pressure is greater than 215 psig.	Verifies suction pressure is greater than 215 psig on PI-509.		
	16.	Verify speed demand is at minimum.	Operate SPEED DEC PB until speed demand does not decrease further (approx. 1100 rpm) <i>NOTE:</i> This can also be accomplished by adjusting the master demand to minimum		
*	17.	Depress TURBINE LATCH pushbutton	Depresses TURBINE LATCH pushbutton.		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: Feedwater

TASK: Prompt Recovery from SGFP Trip

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
	18.	Verify indications for turbine latching.	Verifies the following indications: <ul style="list-style-type: none"> • 21MS43 OPEN light is illuminated. • 21RS15 OPEN light is illuminated. • 21CN36 CLOSED light is illuminated. • 21BF32 OPEN light is illuminated. • 21 SGFP speed on SA5086 is slowly increasing. • 21 SGFP TRIP AFP AUTO ARMED light is extinguished. 		
	19.	Direct a local operator to check if the Woodward Governor Controller (2SA2805) displays "TURBINE TURNING/PUSH RUN OR CLR" and to depress the RUN key and ensure LCD momentarily displays "CONTROLLING PARM/SEMI AUTO START".	Local operator directed to perform the action. <i>CUE: "The RUN key was NOT depressed because TURBINE TURNING/PUSH RUN OR CLR was NOT displayed."</i>		
	20.	Direct the local operator to monitor during warmup for rubbing, vibration and unusual noises.	Directs the local operator to monitor the SGFP. <i>CUE: No unusual rubbing, vibration or noises were observed.</i>		
	21.	Direct a local operator to place 21 SGFP Turbine Enable/Disable switch 2ND17482, in Panel 362-2, in the ENABLE position.	Local operator directed to perform the action. <i>CUE: Local operator reports that the 21 SGFP Turbine Enable/Disable is in the ENABLE position.</i>		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: Feedwater

TASK: Prompt Recovery from SGFP Trip

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
		Transition to section 5.2			
	22.	Ensure the 21CN48 and 22CN48 Pump Bypass valves are closed.	Verifies the following indications: <ul style="list-style-type: none"> • 21CN48 CLOSE light is illuminated. • 22CN48 CLOSE light is illuminated. 		
	23.	Ensure 22 SGFP DEMAND BIAS set at 0%.	Verifies 22SGFP DEMAND BIAS is at 0% on SA8393.		
*	24.	Adjust 21 SGFP PUMP SPEED CONTROL to establish differential pressure on Exhibit 1.	Depress 21 SGFP INCREASE SPEED PB to increase speed until PA 14932 indicates ≥ 50 psid.		
	25.	Ensure SGFPs MASTER SPEED CONTROLLER SPEED DEMAND is tracking 21 SGFP PUMP SPEED.	Verifies that MASTER SPEED CONTROLLER SPEED DEMAND FI1500P is tracking 21 SGFP PUMP SPEED SA5086.		
	26.	Place 21 SGFP PUMP SPEED CONTROL in AUTO	Depress 21 SGFP SPEED CONTROL AUTO pushbutton and verifies the PB illuminates.		
	27.	ENSURE MASTER SPEED CONTROLLER SPEED DEMAND is maintaining DP from Exhibit 1	Verifies ENSURE MASTER SPEED CONTROLLER SPEED DEMAND is maintaining ≥ 50 psid on PA 14932.		
	28.	SELECT 21TD24, TURBINE DRAINS, closed.	Depresses 21TD24 TURBINE DRAINS CLOSE PB and verifies PB illuminates.		

TERMINATING CUE: The operator reports 21 SGFP is available to feed the SGs.
D:\DGroup\JPMs\Simulator\sgfpJPM.doc

**JOB PERFORMANCE MEASURE
FOLLOW-UP QUESTION DOCUMENTATION:**

NAME: _____
DATE: _____

SYSTEM: Feedwater

TASK: Prompt Recovery from a SGFP Trip

TASK NUMBER: 1150290501

QUESTION: _____

RESPONSE: _____

RESULT: -SAT -UNSAT

QUESTION: _____

RESPONSE: _____

RESULT: -SAT -UNSAT

JOB PERFORMANCE MEASURE

INITIAL CONDITIONS:

1. The reactor was operating at 38% power.
2. 22 SGFP was running and spuriously tripped during instrumentation testing.
3. During the reactor trip no AFW pumps started.
4. All actions for 2-EOP-TRIP 1 and 2-EOP-FRHS-1 have been completed to step 13 of FRHS-1.
5. A SI has NOT occurred.
6. 21 SGFP is available for starting.

INITIATING CUE:

The CRS has directed that 21 SGFP be promptly restarted.

JPM QUESTION #1

A SGFP is tripped from the control room, even when it is being removed from service IAW the normal operating procedure. What is the consequence of NOT tripping the SGFP during the procedure?

OPEN REFERENCE

ANSWER: One of the signals required for auto start of the MDAFW Pumps on a trip of both SGFP's will not be present.

KA #: 059 A2.01 //3.4/3.6//

Objective: 0300-000.00S-AFW000-01, Obj. 6

Reference: S2.OP-SO.CN-0002(Q), Precautions and Limitations

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #1

A SGFP is tripped from the control room, even when it is being removed from service IAW the normal operating procedure. What is the consequence of NOT tripping the SGFP during the procedure?

OPEN REFERENCE

JPM QUESTION #2

Reactor power is 100%. 22 SGFP bias is set at 0. Due to instrument failure, the bias signal is going in the negative direction.

What will be the effect on both SGFPs?

CLOSED REFERENCE

ANSWER:

The speed of 22 SGFP will be slowing but 21 SGFP will raise due to the differential pressure controller.

KA #: 059 K4.05 //2.5/2.8//

Objective: 0300-000.00S-CN&FDW-00, Obj. 8

Reference: 0300-000.00S-CN&FDW-00

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #2

Reactor power is 100%. 22 SGFP bias is set at 0. Due to instrument failure, the bias signal is going in the negative direction.

What will be the effect on both SGFPs?

CLOSED REFERENCE

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

17

STATION: Salem
SYSTEM: Emergency Procedures
TASK: Start a CCW Pump IAW APPX-1

TASK NUMBER: 1150420501

JPM NUMBER:

APPLICABILITY:

EO RO SRO

K/A NUMBER: 007 EA1.04
IMPORTANCE FACTOR:

3.6	3.7
RO	SRO

EVALUATION SETTING/METHOD: Simulator

REFERENCES: 2-EOP-TRIP-1 Rev 22
2-EOP-APPX-1 Rev 21

TOOLS AND EQUIPMENT:

VALIDATED JPM COMPLETION TIME: 10 mins.

TIME PERIOD IDENTIFIED FOR TIME CRITICAL STEPS: N/A

APPROVED: _____
PRINCIPAL TRAINING SUPERVISOR OPERATIONS MANAGER

CAUTION: No plant equipment shall be operated during the performance of a JPM without the following:

1. Permission for the OS Or Unit CRS;
2. Direct oversight by a qualified individual (determined by the individual granting permission based on plant conditions).
3. Verification of the "as left" condition by a qualified individual.

ACTUAL JPM COMPLETION TIME: _____
ACTUAL TIME CRITICAL COMPLETION TIME: _____
JPM PERFORMED BY: _____ GRADE: SAT UNSAT
REASON, IF UNSATISFACTORY:
EVALUATOR'S SIGNATURE: _____ DATE: _____

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

NAME: _____

DATE: _____

SYSTEM: Emergency Procedures

TASK: Start a CCW Pump IAW APPX-1

TASK NUMBER: 1150420501

INITIAL CONDITIONS:

1. Place Simulator in a full power IC (IC-99 for 2/99 NRC EXAM)
2. Prevent 22 CCW Pp from starting manually; MALF's MS:090A and EL:0134 TD 35 secs
3. Perform actions of TRIP-1 up to step 17
4. Freeze Simulator and snap to a temporary IC

INITIATING CUE:

A loss of off-site power has occurred with a steam break in containment. The crew has performed the EOPs to step 17 of TRIP-1. The CRS has directed you to perform EOP-APPX-1 and place a CCW Pump in service.

Successful Completion Criteria:

1. All critical steps completed.
2. All sequential steps completed in order.
3. All time-critical steps completed within allotted time.
4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made (and NRC concurrence is obtained).

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: Emergency Procedures

TASK: Start a CCW Pump IAW APPX-1

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
#	1	Check 4Kv Bus Status	Determines all vital busses powered from D/Gs		
#	2	Check ECCS and AFW Pump Status	Determines all ECCS and AFW Pumps running		
#	3	Select Strategy for starting a CCW Pump	Operators selects Step 4		
#	4	Check 22 CCW Pump available	Determines 22 CCW pump available		
# *	5	Block 2B and 2C SEC	Blocks 2B and 2C SEC on 2RP1		
# *	6	Reset 2B and 2C SEC	Resets 2B and 2C SEC @ EDG Bezels		
#	7	Stop 22 and 24 CFCU Stop 22 SWGR Room Supply Fan Stop 22 ABV Supply Fan Start 23 SWGR Supply Fan	Stops 22 and 24 CFCU Stops 22 SWGR Room Supply Fan Stops 22 ABV Supply Fan Starts 23 SWGR Supply Fan		
#	8	Start 22 CCW Pump	Determines 22 CW Pump tripped		
*	9	Start 22 or 24 CFCU	Starts 22 or 24 CFCU		
# *	10	Start 21 CCW Pump: Block 2A and 2B SEC	[Blocks 2A SEC]*, 2B SEC already blocked and reset		
# *	11	Reset 2A and 2B SEC	Resets 2A, 2B already reset		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: Emergency Procedures

TASK: Start a CCW Pump IAW APPX-1

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
#	12	Send and Operator to lockout 21 Chiller	<i>CUE</i> : Operator is dispatched		
# *	13	Start 22 SWGR Supply Fan Stop 21 SWGR Supply Fan	Starts 22 SWGR Supply Fan Stops 21 SWGR Supply Fan		
#	14	Start 22 or 24 CFCUs	22 or 24 CFCU already running (This step is critical if not performed earlier)		
# *	15	Stop 21 CFCU	Stops 21 CFCU		
# *	16	Start 22 FHB Exhaust Fan Stop 21 ABV Exhaust Fan	Start 22 FHB Exhaust Fan Stops 21 ABV Supply Fan		
# *	17	Start 21 CCW Pump	Starts 21 CCW Pump		

Terminating Cue: One CCW Pump in service

**JOB PERFORMANCE MEASURE
FOLLOW-UP QUESTION DOCUMENTATION:**

NAME: _____

DATE: _____

SYSTEM: Emergency Procedures

TASK: Start a CCW Pump IAW APPX-1

TASK NUMBER: 1150420501

QUESTION: _____

RESPONSE: _____

RESULT: -SAT

-UNSAT

QUESTION: _____

RESPONSE: _____

RESULT: -SAT

-UNSAT

JOB PERFORMANCE MEASURE

INITIAL CONDITIONS:

1. A loss of off-site power has occurred with a steam break in containment. EOP-TRIP-1 has been completed through Step 16.

INITIATING CUE:

~~The crew has performed the EOPs to step 17 of TRIP-1.~~ The CRS has directed you to perform EOP-APPX-1 and place a CCW Pump in service.

JPM QUESTION #1

Following a Reactor trip and Safety Injection on Unit 2, the crew is in EOP TRIP-1. The NCO is performing APPX-1 for CCW restoration and reports to the CRS that both 21 and 22CC16, RHR HX Outlet Isolation Valves, have not opened from the Safety injection actuation signal. What conditions must be met for 21 and 22 CC16 to open and is it any different for 11 and 12CC16?

OPEN REFERENCE

ANSWER:

For 21 and 22CC16 Valves to open, both a SI signal and a LO RWST signal must be present. Together, these signals open the CC16 valves on Unit 2. On Unit 1, there is no automatic function. The NCO must open 11 and 12CC16.

manually

KA #: 2.2.3 //3.1/3.5//

- Objective: 0300-000.00S-CCW000-01, 6 and 11.
- Reference: 0300-000.00S-CCW000-01, Section IV.B.4.b.1.a)(2)
Logic Diagram 224403
CCW P&ID 205331
Unit 1 and/or 2EOP-LOCA-3 and Basis Documents

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #1

Following a Reactor trip and Safety Injection on Unit 2, the crew is in EOP TRIP-1. The NCO is performing APPX-1 for CCW restoration and reports to the CRS that both 21 and 22CC16, RHR HX Outlet Isolation Valves, have not opened from the Safety injection actuation signal. What conditions must be met for 21 and 22 CC16 to open and is it any different for 11 and 12CC16?

OPEN REFERENCE

JPM QUESTION #2

The unit is in MODE 1. 22 CCW pump has just been declared inoperable. What action is required?

OPEN REFERENCE

ANSWER:

Restore the pump to service within 72 hours.

NOTE: Technical Specifications states two loops are required to be operable, but the precautions and limitations for S2.OP-SO.CC-0001 states three CCW pumps are required to be operable in order to consider two loops operable.

KA #: 2.2.22 //3.4/4.1//

Objective: 0300-000.00S-CCW000-01, Obj. 10.
Reference: S2.OP-SO.CC-0001, Step 3.4.
Technical Specifications 3.7.3 and basis.

Work on this

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #2

The unit is in MODE 1. 22 CCW pump has just been declared inoperable. What action is required?

OPEN REFERENCE

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

STATION: SALEM
SYSTEM: ABNORMAL PROCEDURES
TASK: TCAF Control Room Evacuation (Trip Turbine, Open Exciter Field Breaker, Trip SGFP's)
TASK NUMBER: 114 013 04 01

JPM NUMBER:

K/A NUMBER: APE 068 AA1.04, EA1.23,
AA1.27

APPLICABILITY:

EO RO SRO

IMPORTANCE FACTOR:

All >3.0	All >3.0
RO	SRO

EVALUATION SETTING/METHOD: In-Plant Simulate

REFERENCES: S2.OP-AB.CR-0001, Att. 8,
Rev. 6

TOOLS AND EQUIPMENT: None

VALIDATED JPM COMPLETION TIME: 10 mins.

TIME PERIOD IDENTIFIED FOR TIME CRITICAL STEPS: N/A

APPROVED:

PRINCIPAL TRAINING SUPERVISOR

OPERATIONS MANAGER

CAUTION:

No plant equipment shall be operated during the performance of a JPM without the following:

1. Permission for the OS Or Unit CRS;
2. Direct oversight by a qualified individual (determined by the individual granting permission based on plant conditions).
3. Verification of the "as left" condition by a qualified individual.

ACTUAL JPM COMPLETION TIME: _____

ACTUAL TIME CRITICAL COMPLETION TIME: _____

JPM PERFORMED BY: _____

GRADE: SAT UNSAT

REASON, IF UNSATISFACTORY:

EVALUATOR'S SIGNATURE: _____

DATE: _____

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

SYSTEM: ABNORMAL PROCEDURES

TASK: TCAF Control Room Evacuation (Trip Turbine, Open Exciter Field Breaker, Trip SGFP's)

TASK NUMBER: 114 013 04 01

INITIAL CONDITIONS:

1. The control room has been evacuated due to a bomb threat.

INITIATING CUE:

The control room has been evacuated IAW S2.OP-AB.CR-0001. You are assigned to carry out the actions of Attachment 8, Steps 3.0-5.0: Trip the Mn. Turbine, Open the Exciter Field Breaker, Trip the SGFP's.

Successful Completion Criteria:

1. All critical steps completed.
2. All sequential steps completed in order.
3. All time-critical steps completed within allotted time.
4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made (and NRC concurrence is obtained).

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: ABNORMAL PROCEDURES

TASK: TCAF Control Room Evacuation: Trip MT, Open Exciter Field Breaker, Trip SGFP's

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
		Operator reviews procedure.	Evaluator provides copy of AB.CR-0001, Att. 8. <i>NOTE:</i> Work Standards Handbook guidance for use of Cat. I procedures applies.		
*	3.0	Proceed to Turbine Front Standard, and place the Reset-Normal-Trip Lever in the TRIP position.	Proceed to front standard, locates Lever and points out TRIP position.		
*	4.0	Proceed to Excitation System Control Cubicle and open Generator Exciter Field Breaker.	Proceeds to Turb. Bldg., El. 120, locates breaker and discusses opening.		
*	5.0	Locally, trip the following: • 21 SGFP • 22 SGFP	Proceeds to Turb. Bldg., El. 100, locates each local trip PB and discusses operation of at least one. <i>CUE:</i> Report your actions IAW the procedure.		
	16.0	Notify STA and HSD Panel Operator.	Locates page or discusses use of radio.		

Terminating Cue: Report completed

**JOB PERFORMANCE MEASURE
FOLLOW-UP QUESTION DOCUMENTATION:**

NAME: _____

DATE: _____

SYSTEM: ABNORMAL PROCEDURES

TASK: TCAF Control Room Evacuation: Trip MT, Open Exciter Field Breaker, Trip SGFP's.

TASK NUMBER: 114 013 04 01

QUESTION: _____

RESPONSE: _____

RESULT: -SAT -UNSAT

QUESTION: _____

RESPONSE: _____

RESULT: -SAT -UNSAT

JOB PERFORMANCE MEASURE

INITIAL CONDITIONS:

1. The control room has been evacuated due to a bomb threat.

INITIATING CUE: The control room has been evacuated IAW S2.OP-AB.CR-0001. You are assigned to carry out the actions of Attachment 8, Steps 3.0-5.0: Trip the Mn. Turbine, Open the Exciter Field Breaker, Trip the SGFP's.

JPM QUESTION #1

Assume that only a manual reactor trip was accomplished before the control room was evacuated. What would be the expected status of each piece of equipment operated during the task you just performed? Explain why it would be in that condition.

FOLLOWUP QUESTION

Why is it necessary to perform these actions?

CLOSED REFERENCE

ANSWER:

1. The turbine should have tripped from P-4 interlock when the manual reactor trip was initiated.
2. The field breaker would trip following the turbine trip and generator breakers opening.
3. The SGFP would not be tripped automatically [but a feedwater isolation should have occurred]. [] not required

FOLLOWUP ANSWER (References can be used for the followup question)

Ensure the heat loads are removed from the Steam Generators to allow temperature control of the reactor.

KA #: 068 AK3.18 //4.2/4.5//

Objective: 0300-000.00S-ABCR01-00, Obj. 2

Reference: S2.OP-AB.CR-0001, Technical Bases for Attachment #8, Immediate Actions

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #1

Assume that only a manual reactor trip was accomplished before the control room was evacuated. What would be the expected status of each piece of equipment operated during the task you just performed? Explain why it would be in that condition.

CLOSED REFERENCE

JPM QUESTION #2

During shutdown outside the control room how can AFST level be determined?

FOLLOWUP QUESTION

What would be the minimum allowable AFW pump suction pressure?

OPEN REFERENCE

ANSWER:

The suction pressure of the AFW pump is compared to a table in AB.CR-0001 that converts suction pressure to AFST level.

FOLLOWUP ANSWER

Minimum pressure would be 23.9 psig. Required to maintain above TS minimum of 94%. 95% is the closest on the chart.

KA #: 2.4.35 //3.3/3.5//

Objective: 0300-000.00S-ABCR01-00, Obj. 2
Reference: S2.OP-AB.CR-0001, Attachment 14

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #2

During shutdown outside the control room how can AFST level be determined?

OPEN REFERENCE

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

STATION: Salem

SYSTEM: Diesel Generators

TASK: Complete actions for Diesel Generator for Shutdown Outside the Control Room

TASK NUMBER: 1140130401

JPM NUMBER:

K/A NUMBER: 068 AA1.31

APPLICABILITY:

EO RO SRO

IMPORTANCE FACTOR:

3.9	4.0
RO	SRO

EVALUATION SETTING/METHOD: In-plant

REFERENCES: S2.OP-AB.CR-0002, Control Room Evacuation Due To Fire In Control Room, Relay Room, Or Ceiling Of The 460/230v Switchgear Room

TOOLS AND EQUIPMENT: None

VALIDATED JPM COMPLETION TIME: _____

TIME PERIOD IDENTIFIED FOR TIME CRITICAL STEPS: 15 mins. _____

APPROVED: _____
PRINCIPAL TRAINING SUPERVISOR

OPERATIONS MANAGER

CAUTION: No plant equipment shall be operated during the performance of a JPM without the following:

1. Permission for the OS Or Unit CRS;
2. Direct oversight by a qualified individual (determined by the individual granting permission based on plant conditions).
3. Verification of the "as left" condition by a qualified individual. -

ACTUAL JPM COMPLETION TIME: _____

ACTUAL TIME CRITICAL COMPLETION TIME: _____

JPM PERFORMED BY: _____ GRADE: SAT UNSAT

REASON, IF UNSATISFACTORY:

EVALUATOR'S SIGNATURE: _____ DATE: _____

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

NAME: _____

DATE: _____

SYSTEM: Diesel Generators

TASK: Complete actions for Diesel Generator for Shutdown Outside the Control Room

TASK NUMBER:

INITIAL CONDITIONS:

1. A fire has occurred in the control room requiring evacuation.
2. You are the Reactor Operator.
3. The 2C 4KV bus is being supplied from off-site power.
4. The 2C D/G is not running.

INITIATING CUE:

You have been directed to perform the actions of Attachment 4 to S2.OP-AB.CR-0002. Start 2C D/G so that 2C 4KV bus can be transferred from off-site to 2C D/G. Inform the CRS when actions have been completed for 2C D/G.

Successful Completion Criteria:

1. All critical steps completed.
2. All sequential steps completed in order.
3. All time-critical steps completed within allotted time.
4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made (and NRC concurrence is obtained).

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: Diesel Generator

TASK: Complete actions for Diesel Generator for Shutdown Outside the Control Room

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
		Provide a copy of Attachment 4 of S2.OP-AB.CR-0002.	Operator obtains copy of procedure. NOTE: Category 1 procedure use requirements apply		
	1.	Obtains the required equipment.	CUE: Assume that you have all equipment required to do Attachment 4		
	2.	Establishes communication with CRS via radio.	Indicates that communications are established with the CRS.		
	3.	Proceed to 21SW21 and 22SW21, Diesel Generator Cooling Water, and report valve positions to CRS.	Determines that both 21SW21 and 22SW21 are open. <i>CUE: Valve stem position indicates that the valve is open.</i>		
	4.	Proceed to 2C DG			

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: Diesel Generator

TASK: Complete actions for Diesel Generator for Shutdown Outside the Control Room

#	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
*	5.	Places Fire Emergency Keylock switches to bypass.	<ul style="list-style-type: none"> • Places 69/1, FIRE EMERGENCY BY-PASS (Generator Control Panel) to BYPASS. • Places 69/2, FIRE EMERGENCY BY-PASS (Engine Control Panel) to BYPASS. • Places 69/3, FIRE EMERGENCY BY-PASS (Engine Control Panel) to BYPASS. 		
	6.	Contacts operator at 2C 4KV bus to determine the availability of off-site power.	<p>Contacts operator at 2C 4KV bus.</p> <p><i>CUE: The operator at the 2C 4KV bus reports that off-site power is supplying the 2C 4KV bus.</i></p>		
	7.	Determine 2C D/G is not operating.	<p>Verifies 2C D/G is not operating.</p> <p><i>CUE: Provide appropriate cues that the diesel generator is not operating.</i></p>		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: Diesel Generator

TASK: Complete actions for Diesel Generator for Shutdown Outside the Control Room

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
*	8.	At Panel 2CDC1DA, 2C Diesel Generator Alternate DC Starter Terminal Box, place breakers to OFF.	<ul style="list-style-type: none"> Places 2CDC1DA1, Normal DC to 2C D/G Engine Controls from 2CCDC-34 to OFF. Places 2CDC1DA2, Normal DC to 2C D/G Engine Controls from 2CCDC-36 to OFF. Places 2CDCDA5, Normal DC to 2C D/G Exciter from 2CCDC-32 to OFF. 		
*	9.	At Panel 2CDC1DA, 2C Diesel Generator Alternate DC Starter Terminal Box, place breakers to ON.	<ul style="list-style-type: none"> Places 2CDC1DA3, Standby DC to 2C D/G Engine Controls from 2CDCDG-10 to ON. Places 2CDC1DA4, Standby DC to D/G Engine Controls from 2CDCDG-7 to ON. Places 2CDC1DA6, Standby DC to 2C D/G Exciter from 2CDCDG-9 to ON. 		
*	10.	At No 2A, 2B, & 2C 125 VDC Distribution Cabinet place breakers on 2CDC2DA to ON.	<ul style="list-style-type: none"> Places 2CDC2DA7, 2C D/G Control & Alarm to ON. Places 2CDC2DA9, 2C D/G Control & Excitation to ON. Places 2CDC2DA10, 2C D/G Trip & Breaker Failure Protection to ON. Places 2CDC2DAX1/2CDC2DA1 (mechanically interlocked) 2CDCDG 125 VDC Distribution Panel Main Breaker to ON. 		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: Diesel Generator

TASK: Complete actions for Diesel Generator for Shutdown Outside the Control Room

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
	11.	Verify the white 2C Diesel Generator Loading switch AUTO (ISOOCR) indicating light is illuminated at 2PNL11832 2C Generator Control Panel.	Verifies AUTO (ISOOCR) indicating light is illuminated. <i>CUE: The Auto (ISOOCR) indicating light is illuminated.</i>		
	12.	Verify the green Exciter Regulator Remote Manual-Automatic Switch AUTO indicating light is illuminated at 2PNL11833 2C Diesel Generator Eng.	Verifies Auto indicating light is illuminated. <i>CUE: The AUTO indicating light is illuminated.</i>		
	13.	Determine if it is necessary to start 2C D/G.	Initial conditions indicated that the 2C D/G was to be started. <i>CUE: If the operator asks if the DG is to be started indicate that the CRS has requested that the 2C D/G be started.</i>		
	14.	Ensure the DUTR is RESET.	Verify DUTR indicates Reset. (2C-DF-GCP-2) <i>CUE: The flag for the DUTR is Green. {Verify the correct cue to give during validation}.</i>		
*	15.	Start 2C D/G by placing the local diesel switch to start position.	Places the local diesel switch to START position (2C-DF-SS). <i>CUE: Provide indications for engine starting.</i>		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

SYSTEM: Diesel Generator

TASK: Complete actions for Diesel Generator for Shutdown Outside the Control Room

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
	16.	Verify EDG Voltage and Speed lights are illuminated.	Verifies the following lights are illuminated: <ul style="list-style-type: none"> • 2DAE38-LT2 EDG Voltage • 2DAE38-LT3 EDG Speed <p><i>CUE: EDG Voltage and EDG Speed lights are illuminated.</i></p>	•	
	17.	Notify operators at 4KV Switchgear and CRS that 2C diesel is operating.	Notifies operators at 4KV switchgear and CRS the 2C D/G is operating. <i>CUE: The operator at the 4KV switchgear and the CRS acknowledge the 2C D/G is operating.</i>		

TERMINATING CUE: The 4KV Operator and the CRS are notified 2C D/G is available for further loads.

**JOB PERFORMANCE MEASURE
FOLLOW-UP QUESTION DOCUMENTATION:**

NAME: _____

DATE: _____

SYSTEM: Diesel Generators

TASK: Complete actions for Diesel Generator for Shutdown Outside the Control Room

TASK NUMBER:

QUESTION: _____

RESPONSE: _____

RESULT: -SAT

-UNSAT

QUESTION: _____

RESPONSE: _____

RESULT: -SAT

-UNSAT

JOB PERFORMANCE MEASURE

INITIAL CONDITIONS:

1. A fire has occurred in the control room requiring evacuation.
2. You are the Reactor Operator.
3. The 2C 4KV bus is being supplied from off-site power.
4. The 2C D/G is not running.

INITIATING CUE:

You have been directed to perform the actions of Attachment 4 to S2.OP-AB.CR-0002. Start 2C D/G so that 2C 4KV bus can be transferred from off-site to 2C D/G. Inform the CRS when actions have been completed for 2C D/G.

EDG JPM QUESTION #1

What is the effect on the Diesel Generator Area Ventilation if DC power is not available to a DG Control Panel?

OPEN REFERENCE

ANSWER:

If the 125 VDC to any Diesel Control Panel is unavailable, the associated fans and dampers will not be automatically locked out by a Fire Suppression Actuation.

KA #: 063 K2.01 //2.9/3.1//

Objective: 0300-000.00S-EDG000-00, 12

Reference: S2.OP-SO.DGV-0001, Page 3

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #1

What is the effect on the Diesel Generator Area Ventilation if DC power is not available to a DG Control Panel?

OPEN REFERENCE

EDG JPM QUESTION #2

What, if any, is the difference in the purpose of the FIRE EMERGENCY BYPASS switches on the EDG control panel as compared to the Diesel Generator Supply Fans EMERGENCY BYPASS OF CO2 SHUTDOWN switches on the RP-5 Panel in the Control Room?

OPEN REFERENCE

ANSWER: The FIRE EMERGENCY BYPASS switches allow local control of the EDG, bypassing wiring and controls that could be damaged in a fire. The EMERGENCY BYPASS OF CO2 SHUTDOWN switches allow operation of the DGV equipment in the event that EDG operation is necessary and the DGV equipment is locked out by actual CO2 actuation or equipment failure (earthquake induced).

LESSON: 300-000.00S-EDG000, Obj. 7.b & 8.b

K/A: 064 K4.02 – 3.9/4.2

REFERENCE: S2.OP-AB.CR-0002

S.2.OP-SO.DGV-0001

THIS SHEET TO BE GIVEN TO CANDIDATE *

JPM QUESTION #2

What, if any, is the difference in the purpose of the FIRE EMERGENCY BYPASS switches on the EDG control panel as compared to the Diesel Generator Supply Fans EMERGENCY BYPASS OF CO2 SHUTDOWN switches on the RP-5 Panel in the Control Room?

OPEN REFERENCE

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

STATION: Salem 1 & 2

SYSTEM: Main Steam System

TASK: Locally close a Main Steamline Isolation Valve (MS167) and operate the associated Atmospheric Steam Relief Valve (MS10)

TASK NUMBER: 1140130401

JPM NUMBER:

K/A NUMBER: APE 068 AA1.01

APPLICABILITY:

IMPORTANCE FACTOR:

4.3	4.5
RO	SRO

EO RO SRO

EVALUATION SETTING/METHOD: Unit Inner Penetration Area

REFERENCES: S2.OP-AB.CR-0002, Control Room Evacuation
S2.OP-SO.HSD-0001, Attachment 8

TOOLS AND EQUIPMENT: Adjustable Wrench

VALIDATED JPM COMPLETION TIME: _____

TIME PERIOD IDENTIFIED FOR TIME CRITICAL STEPS: N/A

APPROVED: _____
PRINCIPAL TRAINING SUPERVISOR OPERATIONS MANAGER

CAUTION: No plant equipment shall be operated during the performance of a JPM without the following:

1. Permission for the OS or Unit CRS;
2. Direct oversight by a qualified individual (determined by the individual granting permission based on plant conditions).
3. Verification of the "as left" condition by a qualified individual.

ACTUAL JPM COMPLETION TIME: _____

ACTUAL TIME CRITICAL COMPLETION TIME: _____

JPM PERFORMED BY: _____ GRADE: SAT UNSAT

REASON, IF UNSATISFACTORY:

EVALUATOR'S SIGNATURE: _____ DATE: _____

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

SYSTEM: Main Steam

TASK: Locally close a Main Steamline Isolation Valve (MS167) and operate the associated Atmospheric Steam Relief Valve (MS10)

TASK NUMBER: 1140130401

INITIAL CONDITIONS:

1. A Control Room Evacuation has taken place due to a fire in the Relay Room.
2. A manual trip was initiated from 100% power.
3. S2-OP-AB.CR-0002 and S2.OP-SO.HSD-0001 are being utilized to control the plant.

INITIATING CUE:

The CRS has directed you to close both 21MS18 and 21MS167 and place 21MS10 in LOCAL. Then make the report to the HSD Panel Operator and standby to operate 21MS10. These operations are to be accomplished IAW the appropriate sections of Attachment 8, S2.OP-SO.HSD-0001.

Successful Completion Criteria:

1. **All critical steps completed.**
2. **All sequential steps completed in order.**
3. **All time-critical steps completed within allotted time.**
4. **JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made (and NRC concurrence is obtained).**

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

N _____
D _____

SYSTEM: Locally close a Main Steamline Isolation Valve (MS167) and operate the associated Atmospheric Steam Relief Valve (MS10)
TASK: 1140130401

#	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
		Evaluator may elect to provide a copy of the applicable sections of S2.OP-SO.HSD-0001 Obtains a copy of correct procedure and verifies correct revision.	Obtains a copy of the procedure [and verifies correct revision]. <input type="checkbox"/> Evaluator option <i>NOTE: This is a Category I procedure. Work Standards require that the operator refer to the procedure at each step of the task. Individual step documentation shall be complete prior to proceeding to the next step.</i>		
*	1	<u>Attachment 8.5</u> Proceed to No. 21 Mn. Stm Gen Cont Pnl 683-2A. Close 21MS18 A/S Manual Air Supply Isolation Valve in air line 5465R-C	Closes 21MS18 A/S Isolation Valve		
*	2	At 21MS18, OPEN the drain cock on either pressure regulator.	Either drain cock opened. <i>CUE: 21MS18 is closed</i>		
	3	<u>Attachment 8.11</u> Ensure 21MS10 is closed	<i>CUE: 21MS10 is closed</i>		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

N _____
D _____

SYSTEM: Locally close a Main Steamline Isolation Valve (MS167) and operate the associated Atmospheric Steam Relief Valve (MS10)
TASK: 1140130401

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
	4	Isolate 21MS167, MS ISOL. VL: by failing open 21MS171 or 21MS169.			
*	4.a	Fail open 21MS171, MS ISOL VLV; at No. 2 Unit Main Steam Vent VLV Control Panel 688-2A by: Closing 21MS171 A/S, Air Line Manual Isolation to SV-275 Open pressure regulator drain-cock (in line between A/S valve and SV-275) Verify 21MS171 failed open	Closes A/S to SV-275 Opens draincock for pressure regulator <i>CUE:</i> 21MS171 is mechanically-bound and closed		
*	4.b	Fail open 21MS169, MS ISOL VLV; at No. 2 Unit Main Steam Vent VLV Control Panel 689-2A by: Closing 21MS169 A/S, Air Line Manual Isolation to SV-274 Open pressure regulator drain-cock (in line between A/S valve and SV-274) Verify 21MS169 failed open	Closes A/S to SV-274 Opens draincock for pressure regulator <i>CUE:</i> 21MS169 failed open		
	5	Verify 21MS167, No. 21 MS Stop Valve, has failed closed	<i>CUE:</i> 21MS167 is closed		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

N _____
D _____

SYSTEM: Locally close a Main Steamline Isolation Valve (MS167) and operate the associated Atmospheric Steam Relief Valve (MS10)
TASK: 1140130401

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
*	6	<u>Attachment 8.1</u> Proceed to 21 Mn Stm & Trb Bypass Stm Gen Press Cont Pnl 684-2A: PLACE local E/P bypass Line Selector Valve in LOCAL position OPERATE hand sender in E/P line to increase pressure indicated on PL-8907	21MS10 selector valve to LOCAL and makes report to HSD Panel Operator <i>CUE:</i> Open 21 MS10 to approx. 50% [Operates hand sender to raise pressure]* to approx. 8-12 psig on PL-8907		

TERMINATING CUE: Reports 21MS10 open to approx. 50%

**JOB PERFORMANCE MEASURE
FOLLOW-UP QUESTION DOCUMENTATION:**

NAME: _____

DATE: _____

SYSTEM: Main Steam

TASK: Locally close a Main Steamline Isolation Valve (MS167) and operate the associated Atmospheric Steam Relief Valve (MS10)

TASK NUMBER: 120 504 04 01 and 117 502 04 01

QUESTION: _____

RESPONSE: _____

RESULT: -SAT -UNSAT

QUESTION: _____

RESPONSE: _____

RESULT: -SAT -UNSAT

JOB PERFORMANCE MEASURE

INITIAL CONDITIONS:

- A Control Room Evacuation has taken place due to a fire in the Relay Room.
- A manual trip was initiated from 100% power.
- S2-OP-AB.CR-0002 and S2.OP-SO.HSD-0001 are being utilized to control the plant.

INITIATING CUE:

The CRS has directed you to close both 21MS18 and 21MS167 and place 21MS10 in LOCAL. Then make the report to the HSD Panel Operator and standby to operate 21MS10. These operations are to be accomplished IAW the appropriate sections of Attachment 8, S2.OP-SO.HSD-0001.

MS10-167 JPM QUESTION #1

Due to steam being present in the vicinity of the MSIVs, the NEO has suggested closing the MSIVs by opening 125 VDC breakers for the MSIV solenoids. What will be the effect of performing this action?


OPEN REFERENCE

ANSWER:

The MSIVs will remain open because those solenoids are normally de-energized and must energize to vent.

KA #: 068 AK3.18 //4.2/4.5//

Objective: 0300-000.00S-ABCR01-00, Obj. 2
0300-000.00S-MSTEAM-00, Obj. 4f.
Reference: Logic Diagram 239916 and others

Comments: _____

THIS SHEET TO BE GIVEN TO CANDIDATE

JPM QUESTION #1

Due to steam being present in the vicinity of the MSIVs, the NEO has suggested closing the MSIVs by opening 125 VDC breakers for the MSIV solenoids. What will be the effect of performing this action?

OPEN REFERENCE

MS10-167 JPM QUESTION #2

When locally operating MS10's, why is it important to coordinate with the CRS at the HSD panel?

CLOSED REFERENCE

ANSWER:

If a 100# differential pressure develops between steam generators a SI signal will be generated. [Candidate may also discuss staying within cooldown limits]

KA #: 068 AA2.08 //3.9/4.1//

Objective: 0300-000.00S-AB.CR-0001, Obj. 3.b

Reference: S2.OP-AB.CR-0001, Attachment 3

Comments: _____

THIS SHEET TO BE GIVEN TO CANDIDATE

JPM QUESTION #2

When locally operating MS10's, why is it important to coordinate with the CRS at the HSD panel?

OPEN REFERENCE

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

STATION: Salem 1 & 2

SYSTEM: Auxiliary Feedwater System

TASK: Reset Auxiliary Feedwater Turbine Trip Valve (MS-52)

TASK NUMBER: 113 004 05 01

JPM NUMBER: Reset MS-52

K/A NUMBER: 2.1.30

APPLICABILITY:

IMPORTANCE FACTOR:

EO RO SRO

3.9	3.4
RO	SRO

EVALUATION SETTING/METHOD: Simulate / Aux Bldg Elev 84

REFERENCES: S2.OP-SO.AF-001(Q) Auxiliary Feedwater System Operation

TOOLS AND EQUIPMENT: JA Master key

VALIDATED JPM COMPLETION TIME: 7 min.

TIME PERIOD IDENTIFIED FOR TIME CRITICAL STEPS:

APPROVED: _____
PRINCIPAL TRAINING SUPERVISOR OPERATIONS MANAGER

CAUTION: No plant equipment shall be operated during the performance of a JPM without the following:

1. Permission for the OS Or Unit CRS;
2. Direct oversight by a qualified individual (determined by the individual granting permission based on plant conditions).
3. Verification of the "as left" condition by a qualified individual.

ACTUAL JPM COMPLETION TIME: _____
ACTUAL TIME CRITICAL COMPLETION TIME: _____
JPM PERFORMED BY: _____ GRADE: SAT UNSAT
REASON, IF UNSATISFACTORY:
EVALUATOR'S SIGNATURE: _____ DATE: _____

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

NAME: _____

DATE: _____

SYSTEM: Auxiliary Feedwater System

TASK: Reset Auxiliary Feedwater Turbine Trip Valve (MS-52)

TASK NUMBER: 113 004 05 01

INITIAL CONDITIONS:

1. Unit 2 has just experienced a reactor trip. The 23 AFW Pump has tripped on overspeed.

INITIATING CUE:

You have been directed to reset 23 AFW Pump Turbine Trip Valve (2MS52) in accordance with S2.OP-SO.AF-0001, Attachment 2, Turbine-Driven AFW Pump Restoration

Successful Completion Criteria:

1. All critical steps completed.
2. All sequential steps completed in order.
3. All time-critical steps completed within allotted time.
4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made (and NRC concurrence is obtained).

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: Auxiliary Feedwater System

TASK: Reset Auxiliary Feedwater Turbine Trip Valve (MS-52)

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
		Operator obtains or is provided with the correct procedure. <i>NOTE: Evaluator should verify that the Operator has a JA Master Key before entering the controlled area.</i>	Obtains the correct procedure, S2.OP-SO.AF-0001(Q), Attachment 2. <i>NOTE: This is a Category II procedure. Work standards require that the procedure be at the job site. The Operator should refer to the procedure at the beginning and end of the task and as frequently as necessary during performance of the task.</i>		
# *	1	<u>RESETTING 2MS52</u> SEAT tappet nut by slightly pulling Head Lever away from trip linkage <u>AND</u> VERIFY that the Emergency Trip Lever is in its RESET position (horizontal).	Verifies tappet nut seated and EMERGENCY TRIP LEVER in reset position. <i>CUE: Tappet nut seated and EMERGENCY TRIP LEVER is reset.</i>		
# *	2	ROTATE 2MS52 Handwheel in the closed direction (clockwise). This will cause the Latch-Up Lever to move up toward the Trip Hook.	Rotates MS52 Handwheel clockwise and verifies Latch-Up Lever moving toward Trip Hook.		
# *	3	VERIFY that as the Latch-Up Lever moves up into position, it moves to and engages the Trip Hook.	Verifies Trip Hook engages. <i>CUE: Trip Hook is engaged.</i>		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: Auxiliary Feedwater System

TASK: Reset Auxiliary Feedwater Turbine Trip Valve (MS-52)

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
#	4	IF necessary to assist the Trip Hook in engaging the Latch-Up Lever, THEN PULL UP on the Hand Trip Lever until engaged.	Trip Hook engaged in previous step.		
# *	5	ROTATE 2MS52 Handwheel in the open direction (counter-clockwise) until the Split Coupling raises and makes contact with the bottom of the Sliding Nut.	Rotates Handwheel counter-clockwise and verifies Split Coupling makes contact with Sliding Nut. <i>CUE: Split Coupling contacting Sliding Nut.</i>		
# *	6	ROTATE 2MS52 Handwheel clockwise approximately one turn until Handwheel moves freely. This prevents the valve from binding.	Rotates Handwheel clockwise one turn and verifies Handwheel moves freely.		

TERMINATING CUE: Operator reports 2MS52 are reset.

**JOB PERFORMANCE MEASURE
FOLLOW-UP QUESTION DOCUMENTATION:**

NAME: _____

DATE: _____

SYSTEM: Auxiliary Feedwater System

TASK: Reset Auxiliary Feedwater Turbine Trip Valve (MS-52)

TASK NUMBER: 113 004 05 01

QUESTION: _____

RESPONSE: _____

RESULT: -SAT

-UNSAT

QUESTION: _____

RESPONSE: _____

RESULT: -SAT

-UNSAT

JOB PERFORMANCE MEASURE

INITIAL CONDITIONS:

1. Unit 2 has just experienced a reactor trip. The 23 AFW Pump has tripped on overspeed.

INITIATING CUE:

You have been directed to reset 23 AFW Pump Turbine Trip Valve (2MS52) in accordance with SO.AF-0001, Attachment 2, Turbine-Driven AFW Pump Restoration

S2.OP-

JPM QUESTION #1

OPEN REFERENCE

A Unit 2 shutdown is in progress with reactor power at 10%, lowering at 15%/hour. 23 AFW Pump is OOS due to a steam leak on 2MS132. 21AF3, AFWST to 21AFW Pump Suction Valve, is closed due to back-leakage through 21AF4 (check valve). 21 AFW Pump is tagged OOS because AF3 is closed. Directions are that 21 AFW Pump should only be used in an emergency. .

three
What actions are necessary to feed all four SG's using 22 AFW Pump?

ANSWER:

- Open discharge x-connect valves, 21&22AF923
- Restore 125 VDC control power to 21 AFW Pump
- Select PRESS OVERRIDE DEFEAT on the bezel for 21 AFW Pump

KA #: 061 A2.04 //3.4/3.8

Objective: 0300-000.00S-AFW000-00, Obj. 4.h

Reference: S2.OP-SO.AF-0001, pg. 7

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #1

A Unit 2 shutdown is in progress with reactor power at 10%, lowering at 15%/hour. 23 AFW Pump is OOS due to a steam leak on 2MS132. 21AF3, AFWST to 21AFW Pump Suction Valve, is closed due to back-leakage through 21AF4 (check valve). 21 AFW Pump is tagged OOS because AF3 is closed. Directions are that 21 AFW Pump should only be used in an emergency.

What actions are necessary to feed all four SG's using 22 AFW Pump?

OPEN REFERENCE

JPM QUESTION #2

During power operations the control air line supplying air to the AFW System components ruptures. How will this failure affect the immediate capability of the AFW System to perform its' design function?

OPEN REFERENCE

ANSWER:

The system is still fully capable of performing its' design function. Loss of air does not impact the availability of the MDAFW pumps and the TDAFW pump would start due to loss of air to the steam stop, MS132. All AFW flow control valves (AF11's and AF21's) fail open, resulting in full flow capability to all four SG's.

KA #: 061 A2.02 //3.2/3.6//

Objective: 0300-000.00S-AFW000-00, Obj 4.

Reference: P & ID 205336
S2.OP-AB.CA-0001

Comments: _____

*** THIS SHEET TO BE GIVEN TO CANDIDATE ***

JPM QUESTION #2

During power operations the control air supply line to the AFW System components ruptures. How will this failure affect the capability of the AFW System to perform its' design function?

OPEN REFERENCE

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

STATION: Salem 1 & 2
SYSTEM: 115 VAC Vital Instrumentation
TASK: Startup Vital Instrument Inverter - Alternate Source Startup and Return the Inverter to Normal
TASK NUMBER: 0625040104
JPM NUMBER: 2-9 (112)

APPLICABILITY: EO RO SRO
K/A NUMBER: 062 A407
IMPORTANCE FACTOR:

3.1*	3.1*
RO	SRO

EVALUATION SETTING/METHOD: Auxiliary Building, Simulate

REFERENCES: S2.OP-SO.115-0011 (-0015) Vital Instrument Bus UPS System Operation

TOOLS AND EQUIPMENT:

VALIDATED JPM COMPLETION TIME: 10 min.

TIME PERIOD IDENTIFIED FOR TIME CRITICAL STEPS:

APPROVED: _____
PRINCIPAL TRAINING SUPERVISOR OPERATIONS MANAGER

CAUTION: No plant equipment shall be operated during the performance of a JPM without the following:

1. Permission from the OS Or Unit CRS;
2. Direct oversight by a qualified individual (determined by the individual granting permission based on plant conditions).
3. Verification of the "as left" condition by a qualified individual.

ACTUAL JPM COMPLETION TIME: _____

ACTUAL TIME CRITICAL COMPLETION TIME: _____

JPM PERFORMED BY: _____ GRADE: SAT UNSAT

REASON, IF UNSATISFACTORY:

EVALUATOR'S SIGNATURE: _____ DATE: _____

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

SYSTEM: 115 VAC Vital Instrumentation

TASK: Startup Vital Instrument Inverter - Alternate Source Startup and Return the Inverter to Normal

TASK NUMBER: 0625040104

INITIAL CONDITIONS:

1. Selected Vital Instrument Bus Inverter _____ is powering its associated bus with Regulator AC INPUT breaker CB301 open.

INITIATING CUE:

The CRS directs you to energize the AC Line Regulator with the Inverter supplying its bus.

Successful Completion Criteria:

1. All critical steps completed.
2. All sequential steps completed in order.
3. All time-critical steps completed within allotted time.
4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made (and NRC concurrence is obtained).

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: 115 VAC Vital Instrumentation

TASK: Startup Vital Instrument Inverter – Alternate Source Startup and Return the Inverter to Normal

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
		<p>Operator locates is provided with the correct procedure and Section 5.9: <u>Energizing the AC line Regulator with Inverter Supplying 2A 115 V Vital Instrument Bus</u></p> <p>NOTE: This JPM is written using the 2A inverter. It may be conducted on <u>ANY</u> Vital Instrument Bus Inverter. The other Vital Bus #'s will be provided in parentheses following the 2A #'s. The evaluator should insure the inverter specific breakers are located.</p>	<p>Operator obtains copy of S2.OP-SO.115-0011 (0012, 0013, 0014)</p> <p>NOTE: This is a Category I procedure. Work Standards require that the operator refer to the procedure at each step of the task. Individual step documentation shall be complete prior to preceding to the next step.</p>		
	1.A	<p>ENSURE the following:</p> <ul style="list-style-type: none"> 2AY1AX9Y (2BY1AX6Y/2CY1AX7Y/2BY1AX6Y), 2A (B&D/C/B&D) VITAL INSTRUMENT BUS POWER SUPPLY (ALTERNATE), is CLOSED (2A (B/C/B) 230V Vital Bus, Elev.,84' Swgr Rm). 	<p>At 2A (B/C/B) 230 V Vital Bus verifies 2AY1AX9A (2BY1AX6Y/2CY1AX7Y/2BY1AX6Y) is closed.</p>		
	.B	<ul style="list-style-type: none"> MAN. BYPASS switch is set to BYP TO PREF (*2A (B/C/D) Vital Instrument Bus Reg & Static SW Panel). 	<p>At Static Switch panel verifies Man Bypass switch is in BYP TO PREF position.</p>		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: 115 VAC Vital Instrumentation

TASK: Startup Vital Instrument Inverter – Alternate Source Startup and Return the Inverter to Normal

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
	.C	<ul style="list-style-type: none"> TEST TRANSFER toggle switch is set to N 	At Static Switch panel verifies Toggle switch set to N position.		
	2	PLACE MAN. BYPASS switch in preferred ISOLATE.	Indicates taking Man Bypass switch to ISOLATE position.		
	3	CLOSE 2AVII2A3 (2BVII2B3/2CVII2C3/2DVII2D3), NO. 2A (B/C/D) VITAL INSTR BUS INVERTER ALT AC INPUT BREAKER (CB301).	At inverter, indicates taking CB301 to ON.		
	4	PLACE MAN. BYPASS switch in BYP TO PREF.	Indicates taking Man Bypass switch to BYP TO PREF position.		
	5	IF STATIC SWITCH ON ALTERNATE (white) lamp is illuminated, THEN PRESS THE RESET pushbutton.	If light is lit, depresses RESET pushbutton.		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: 115 VAC Vital Instrumentation

TASK: Startup Vital Instrument Inverter – Alternate Source Startup and Return the Inverter to Normal

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
	6	PRESS ALARM CONTACT RESET pushbutton, <u>AND ...</u>	<p>Presses Alarm Contact Reset button. AND Verifies the following light status:</p> <p><i>It may be necessary for the Evaluator to provide necessary CUES</i></p> <p><u>At 2A (B/C/D) Instrument Bus Rectifier Panel</u></p> <ul style="list-style-type: none"> • REG AC OUTPUT AVAILABLE - lit (RED) • REG AC OUTPUT LOW/FAIL - NOT lit (WHITE) <p><u>At Vital Instr Bus Reg & Static SW panel</u></p> <ul style="list-style-type: none"> • LOW AIR FLOW - NOT lit • SYNCHRONIZED - lit (RED) • SYNC MONITOR - NOT lit (CLEAR) • REG AC INPUT AVAILABLE - lit (RED) • STATIC SWITCH ON INVERTER -lit (RED) • STATIC SWITCH ON ALTERNATE - NOT lit (WHITE) <ul style="list-style-type: none"> • Aux Alarm Typewriter Point 0147 (0155/0134/0159), 2A (B/C/D) VITAL INSTR BUS INV TROUBLE - clear 		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: 115 VAC Vital Instrumentation

TASK: Startup Vital Instrument Inverter – Alternate Source Startup and Return the Inverter to Normal

#	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
*	7	ROTATE the SOURCE SELECTOR switch to LINE <u>AND</u> ...	Rotates Source Selector switch to LINE position, AND ENSURES: • AC OUTPUT VOLTS: 115 - 130 VAC <i>CUE:</i> Per existing reading or 125 VAC • AC OUTPUT FREQ: 59.5 - 60.5 Hz <i>CUE:</i> Per existing reading or 60 Hz		
	8	ROTATE the SOURCE SELECTOR switch to OUTPUT.	Rotates Source Selector switch to OUPUT position.		
*	9	PLACE the MAN. BYPASS switch in NORMAL	Indicates taking Man Bypass switch to NORMAL position.		
	10	ENSURE 2A Vital Instrument Bus UPS System status is IAW conditions specified in Attachment 1, STATUS ON NORMAL SOURCE column.	Verifies indications agree with STATUS ON NORMAL SOURCE positions IAW Attachment 1 (Attachment 2 for C/D), Sections 1.0, 2.0 & 3.0.		
	11	Notify the NCO that 2A (B/C/D)Vital Instrument Bus AC Line Regulator is available to the 2A (B/C/D) Vital Instrument Bus.	Notifies NCO of Inverter/Regulator status.		

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

NAME: _____
DATE: _____

SYSTEM: 115 VAC Vital Instrumentation

TASK: Startup Vital Instrument Inverter – Alternate Source Startup and Return the Inverter to Normal

Terminating Cue: Candidate notifies the NCO that 2A (2B, 2C, 2D) Vital Instrument Bus AC Line Regulator is available to the 2A (2B, 2C, 2D) Vital Instrument Bus.

JOB PERFORMANCE MEASURE
FOLLOW-UP QUESTION DOCUMENTATION:

NAME: _____

DATE: _____

SYSTEM: Vital 115 VAC

TASK: Startup Vital Instrument Inverter - Alternate Source Startup and Return the Inverter to Normal

TASK NUMBER: 0625040104

QUESTION: _____

RESPONSE: _____

RESULT: -SAT

-UNSAT

QUESTION: _____

RESPONSE: _____

RESULT: -SAT

-UNSAT

JOB PERFORMANCE MEASURE

INITIAL CONDITIONS:

1. Vital Instrument Bus Inverter 2A is powering its associated bus with Regulator AC INPUT breaker CB301 open.

INITIATING CUE:

The CRS directs you to energize the AC Line Regulator with the Inverter supplying its bus.

JPM QUESTION #1

The 2A Instrument Inverter Manual Bypass Switch is in the ISOLATE (Preferred) position. Describe how this position differs from the NORMAL and BYP TO PREF positions.

OPEN REFERENCE

ANSWER:

In the NORMAL position the inverter will automatically transfer to the AC Line Regulator. The BYP TO PREF position and the ISOLATE (Preferred) position both prevent transfer from the Inverter to the AC Line Regulator. The ISOLATE (Preferred) position will isolate power from both power sources to the static switch.

KA #: 062 K4.10 //3.1/3.5//

Objective: 0300-000.00S-115VAC-00, Obj. 6

Reference: S2.OP-SO.115-0011, Exhibit 1.

Comments: _____

THIS SHEET TO BE GIVEN TO CANDIDATE

JPM QUESTION #1

The 2A Instrument Inverter Manual Bypass Switch is in the ISOLATE (Preferred) position. Describe how this position differs from the NORMAL and BYP TO PREF positions.

OPEN REFERENCE

Inverter JPM QUESTION #2

Precaution and Limitation 3.5 of S2.OP-SO.115-0014 states the following:
2RH20, RHR HX BYPASS VALVE, may open when transferring 2D Vital Instrument Bus from Inverter to the AC Line Regulator or when transferring from AC Line Regulator to Inverter.

Assume the RCS is being cooled by RHR and 2RH20 is being used to control temperature. What is the alternative means of controlling RCS temperature if 2RH20 fails open during one of the evolutions described in the precaution?

OPEN REFERENCE

ANSWER: Control RHR HX CCW flow utilizing CC15.

OBJECTIVE: 300-000.00S-115VAC, Obj. 13.b.(i)

K/A: 062A2.10 – 3.0/3.3

REFERENCE: S2.OP-AB.115-0004, Attachment and/or P&ID 205332
(RHR)/205331(CCW)

THIS SHEET TO BE GIVEN TO CANDIDATE

JPM FOLLOWUP QUESTION

Precaution and Limitation 3.5 of S2.OP-SO.115-0014 states the following:
2RH20, RHR HX BYPASS VALVE, may open when transferring 2D Vital Instrument Bus from Inverter to the AC Line Regulator or when transferring from AC Line Regulator to Inverter.

Assume the RCS is being cooled by RHR and 2RH20 is being used to control temperature. What is the alternative means of controlling RCS temperature if 2RH20 fails open during one of the evolutions described in the precaution?

OPEN REFERENCE

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

STATION: Salem
SYSTEM: Emergency Core Cooling System
TASK: Align charging suction to the RWST during CR evacuation

TASK NUMBER: 1140130401

JPM NUMBER:

APPLICABILITY: EO RO SRO
K/A NUMBER: 2.1.30
IMPORTANCE FACTOR:

3.9	3.4
RO	SRO

EVALUATION SETTING/METHOD:

REFERENCES: S1.OP-AB.CR-0001, Control Room Evacuation

TOOLS AND EQUIPMENT:

VALIDATED JPM COMPLETION TIME: 5 mins.

TIME PERIOD IDENTIFIED FOR TIME CRITICAL STEPS: _____

APPROVED: _____
PRINCIPAL TRAINING SUPERVISOR OPERATIONS MANAGER

*Replaced
due to Ops.
not wanting
to open cabinets*

CAUTION: No plant equipment shall be operated during the performance of a JPM without the following:
1. Permission for the OS Or Unit CRS;
2. Direct oversight by a qualified individual (determined by the individual granting permission based on plant conditions).
3. Verification of the "as left" condition by a qualified individual.

ACTUAL JPM COMPLETION TIME: _____
ACTUAL TIME CRITICAL COMPLETION TIME: _____
JPM PERFORMED BY: _____ GRADE: SAT UNSAT
REASON, IF UNSATISFACTORY:
EVALUATOR'S SIGNATURE: _____ DATE: _____

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

NAME: _____

DATE: _____

SYSTEM: Emergency Core Cooling System

TASK: Align charging suction to the RWST during CR evacuation

TASK NUMBER: 1140130401

INITIAL CONDITIONS:

1. The control room has been evacuated due to toxic gas.
2. The actions of Attachment 3 are being directed by the CRS.

INITIATING CUE:

You have been directed to align charging to the RWST per steps 20 and 21 of Attachment 3, SI.OP-AB.CR-0001.

Successful Completion Criteria:

1. All critical steps completed.
2. All sequential steps completed in order.
3. All time-critical steps completed within allotted time.
4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made (and NRC concurrence is obtained).

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: Emergency Core Cooling System

TASK: Align charging suction to the RWST during CR evacuation

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
		Provide candidate with Attachment 3 of S2.OP-AB.CR-0001	Candidate locates and reviews proper steps Category I procedure use requirements apply		
*	1.	Defeat the door interlock and open the breaker door for 1SJ1-RWST to Charging Pump Stop Valve.	Simulates inserting screwdriver to defeat door interlock and opens the door.	?	Simulate?
*	2.	Place key operated NORMAL/EMER switch, 1CY2AX2A-T1 to EMER	Simulates placing 1CY2AX2A-T1 to EMER	?	
	3.	Verify breaker is CLOSED	Identifies mechanical indication indicates closed.	?	
	4	Verify the thermal overloads are reset.	Verifies that the button on the thermal overloads is not protruding.	?	
*	5	Place key operated EMER OPEN/NORM/EMER CLOSE switch, 1CY2AX5H-T2, in EMER OPEN.	Simulates placing 1CY2AX5H-T2 to EMER OPEN.	?	
*	6	Defeat the door interlock and open the breaker door for 1CV40-Volume Control Tank Outlet Isolation Valve.	Simulates inserts screwdriver to defeat door interlock and opens the door.		
*	7	Place key operated NORMAL/EMER switch, 1CY2AX4A-T1 to EMER	Simulates placing 1CY2AX2A-T1 to EMER		
	8	Verify breaker is CLOSED	Identifies mechanical indication indicates closed.		
	9	Verify the thermal overloads are reset.	Verifies that the button on the thermal overloads is not protruding.		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____
DATE: _____

SYSTEM: Emergency Core Cooling System

TASK: Align charging suction to the RWST during CR evacuation

# *	STEP NO.	STEP (*Denotes a Critical Step) (#Denotes a Sequential Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT Evaluation)
*	10	Place key operated EMER OPEN/NORM/EMER CLOSE switch 1CY2AX4A-T2 in EMER CLOSED.	1CY2AX4A-T2 is placed to EMER CLOSED.		

TERMINATING CUE: Operator reports that charging has been aligned to the RWST.

**JOB PERFORMANCE MEASURE
FOLLOW-UP QUESTION DOCUMENTATION:**

NAME: _____

DATE: _____

SYSTEM: Emergency Core Cooling System

TASK: Align charging suction to the RWST during CR evacuation

TASK NUMBER: 1140130401

QUESTION: _____

RESPONSE: _____

RESULT: -SAT

-UNSAT

QUESTION: _____

RESPONSE: _____

RESULT: -SAT

-UNSAT

INITIAL CONDITIONS:

The control room has been evacuated due to toxic gas.

The actions of Attachment 3 are being directed by the CRS.

INITIATING CUE:

You have been directed to align charging to the RWST per steps 20 and 21 of Attachment 3, S1.OP-AB.CR-0001.

RWST SUCT JPM QUESTION #1

How is an automatic SI avoided during the RCS cooldown and depressurization initiated per Attachment 3 of S1.OP-SO.AB-CR0001, Control Room Evacuation?

OPEN REFERENCE

ANSWER:

Both trains of SSPS and all SEC's are de-energized per Attachment 7.

KA #: 006 K4.09 //3.9/4.2//

Objective: 0300-000.00S-ABCR01-00, Obj. 2

Reference: S1.OP-AB.CR-00001 and Technical Bases for Attachment 7

Comments: _____

THIS SHEET TO BE GIVEN TO CANDIDATE

JPM QUESTION #1

How is an automatic SI avoided during the RCS cooldown and depressurization initiated per Attachment 3 of S1.OP-SO.AB-CR0001, Control Room Evacuation?

OPEN REFERENCE

RWST SUCT JPM QUESTION #2

Unit 2 is in the midst of a 55 day run at 100% power. As part of a VCT level control troubleshooting procedure, 2CV40 and 2CV41 (VCT to CHARGING PUMP SUCTION VALVES) and SJ1 and SJ2 (RWST to CHARGING PUMP SUCTION VALVES), are all in MANUAL. 2CV40 and 2CV41 are open. 2SJ1 and 2SJ2 are closed. With the valves aligned as such, an automatic SI and loss of off-site power occurs. While 2B 4KV Vital Bus is loading the in-feed breaker opens due to relay actuation on BUS DIFF. 2A and 2C 4KV Vital Buses energize per design.

What will be the alignment of 2CV40, 2CV41, 2SJ1 and 2SJ2 after the SI?

OPEN REFERENCE

Answer: 2CV40 is closed; 2CV41 is open; 2SJ1 is open; 2SJ2 is closed

Objective: 300-ECCS, Obj. 6.a

REFERENCE: Valve Logic Diagrams and TRIS Power Feed Manual (SJ1 & CV40 off C Bus, SJ2 & CV41 off B Bus. The valves re-position whether in AUTO or MANUAL)

K/A: 006 K2.04 – 3.8/4.2

THIS SHEET SHOULD BE GIVEN TO THE CANDIDATE

JPM QUESTION #2

Unit 2 is in the midst of a 55 day run at 100% power. As part of a VCT level control troubleshooting procedure, 2CV40 and 2CV41 (VCT to CHARGING PUMP SUCTION VALVES) and SJ1 and SJ2 (RWST to CHARGING PUMP SUCTION VALVES), are all in MANUAL. 2CV40 and 2CV41 are open. 2SJ1 and 2SJ2 are closed. With the valves aligned as such, an automatic SI and loss of off-site power occurs. While 2B 4KV Vital Bus is loading the in-feed breaker opens due to relay actuation on BUS DIFF. 2A and 2C 4KV Vital Buses energize per design.

What will be the alignment of 2CV40, 2CV41, 2SJ1 and 2SJ2 after the SI?

OPEN REFERENCE

Competencies	Applicant-RO1 RO/SRO-I/SRO-U				Applicant-RO2 RO/SRO-I/SRO-U				Applicant-SRO1 RO/SRO-I/SRO-U			
	SCENARIO				SCENARIO				SCENARIO			
	R 1	P 2	3	4	P 1	2	R 3	4	1	R 2	C 3	4
Understand and Interpret Annunciators and Alarms	2,3,4,6	2,3,5,6,8			2,4,5,6		2,4,5			3,4,5,7	2,3,4,5,6	
Diagnose Events and Conditions	2,3,4,6,7,8	2,3,5,6,8			2,4,5,6,8		2,4,5			3,4,5,7	2,3,4,5,6,7	
Understand Plant and System Response	1,2,3,4,6,7	1,2,3,5,6,8			1,2,4,5,6,8		1,2,4,5			1,3,4,5,7	1,2,3,4,5,6,7	
Comply With and Use Procedures (1)	1,2,3,4,6,7,8	1,2,3,5,6,8			1,2,4,5,6,8		1,2,4,5			1,3,4,5,7	1,2,3,4,5,6,7	
Operate Control Boards (2)	1,2,3,4,6,7,8	1,2,3,5,6,8			1,2,4,5,6,8		1,2,4,5			1,3,4,5,7	—	
Communicate and Interact With the Crew	1,2,3,4,5,6,7,8	1,2,3,5,6,8			1,2,4,5,6,8		1,2,4,5			1,3,4,5,7	1,2,3,4,5,6,7	
Demonstrate Supervisory Ability (3)	—	—			—		—			—	1,2,3,4,5,6,7	
Comply With and Use Tech. Specs. (3)	—	—			—		—			—	4,5	
Notes:												
(1) Includes Technical Specification compliance for an RO.												
(2) Optional for an SRO-U.												
(3) Only applicable to SROs.												

INSTRUCTIONS:

Circle the applicant's license type and enter the event numbers that test the competency for each scenario in the set.

Author:

Chief Examiner:

M. Anderson
D. G. Smith

Competencies	Applicant-RO3 RO/SRO-I/SRO-U				Applicant-SRO2 RO/SRO-I/SRO-U				Applicant-SRO3 RO/SRO-I/SRO-U				
	SCENARIO				SCENARIO				SCENARIO				
	R 1	2	P 3	4	1	C 2	R 3	4	C 1	R 2	3	4	
Understand and Interpret Annunciators and Alarms	2,3,4,6		2,3,4,5,6			2,3,4,5,6,7,8	2,4,5			2,3,4,5,6	3,4,5,7		
Diagnose Events and Conditions	2,3,4,6,7,8		2,3,4,5,6,7			2,3,4,5,6,7,8	2,4,5			2,3,4,5,6,7,8	3,4,5,7		
Understand Plant and System Response	1,2,3,4,6,7		1,2,3,4,5,6,7			1,2,3,4,5,6,7,8	1,2,4,5			1,2,3,4,5,6,7,8	1,3,4,5,7		
Comply With and Use Procedures (1)	1,2,3,4,6,7,8		1,2,3,5,6,7			1,2,3,4,5,6,7,8	1,2,4,5			1,2,3,4,5,6,7,8	1,3,4,5,7		
Operate Control Boards (2)	1,2,3,4,6,7,8		1,2,3,5,6,7			—	1,2,4,5			—	1,3,4,5,7		
Communicate and Interact With the Crew	1,2,3,4,5,6,7,8		1,2,3,4,5,6,7			1,2,3,4,5,6,7,8	1,2,4,5			1,2,3,4,5,6,7,8	1,3,4,5,7		
Demonstrate Supervisory Ability (3)	—		—			1,2,3,4,5,6,7,8	—			1,2,3,4,5,6,7,8	—		
Comply With and Use Tech. Specs. (3)	—		—			4	—			4	—		
Notes:													
(1) Includes Technical Specification compliance for an RO.													
(2) Optional for an SRO-U.													
(3) Only applicable to SROs.													

INSTRUCTIONS:

Circle the applicant's license type and enter the event numbers that test the competency for each scenario in the set.

Author:

Chief Examiner:

M. S. ...
D. H. ...



Competencies	Applicant-RO4 RO/SRO-I/SRO-U				Applicant-RO5 RO/SRO-I/SRO-U				Applicant-SRO4 RO/SRO-I/SRO-U			
	SCENARIO				SCENARIO				SCENARIO			
	R 1	P 2	3	4	P 1	2	R 3	4	1	R 2	C 3	4
Understand and Interpret Annunciators and Alarms	2,3,4,6	2,3,5,6,8			2,4,5,6		2,4,5			3,4,5,7	2,3,4,5,6	
Diagnose Events and Conditions	2,3,4,6,7,8	2,3,5,6,8			2,4,5,6,8		2,4,5			3,4,5,7	2,3,4,5,6,7	
Understand Plant and System Response	1,2,3,4,6,7	1,2,3,5,6,8			1,2,4,5,6,8		1,2,4,5			1,3,4,5,7	1,2,3,4,5,6,7	
Comply With and Use Procedures (1)	1,2,3,4,6,7,8	1,2,3,5,6,8			1,2,4,5,6,8		1,2,4,5			1,3,4,5,7	1,2,3,4,5,6,7	
Operate Control Boards (2)	1,2,3,4,6,7,8	1,2,3,5,6,8			1,2,4,5,6,8		1,2,4,5			1,3,4,5,7	—	
Communicate and Interact With the Crew	1,2,3,4,5,6,7,8	1,2,3,5,6,8			1,2,4,5,6,8		1,2,4,5			1,3,4,5,7	1,2,3,4,5,6,7	
Demonstrate Supervisory Ability (3)	—	—			—		—			—	1,2,3,4,5,6,7	
Comply With and Use Tech. Specs. (3)	—	—			—		—			—	4,5	
Notes:												
(1) Includes Technical Specification compliance for an RO.												
(2) Optional for an SRO-U.												
(3) Only applicable to SROs.												

INSTRUCTIONS:

Circle the applicant's license type and enter the event numbers that test the competency for each scenario in the set.

Author:

Chief Examiner:


Competencies	Applicant-SRO5 RO/SRO-I/SRO-U				Applicant- RO/SRO-I/SRO-U				Applicant- RO/SRO-I/SRO-U			
	SCENARIO				SCENARIO				SCENARIO			
	1	C 2	P 3	4	1	2	3	4	1	2	3	4
Understand and Interpret Annunciators and Alarms		2,3,4, 5,6,7, 8	3,4,5, 6,7									
Diagnose Events and Conditions		2,3,4, 5,6,7, 8	3,5,6, 7									
Understand Plant and System Response		1,2,3, 4,5,6, 7,8	1,3,5, 6,7									
Comply With and Use Procedures (1)		1,2,3, 4,5,6, 7,8	1,3,5, 6,7									
Operate Control Boards (2)		—	1,3,5, 6,7									
Communicate and Interact With the Crew		1,2,3, 4,5,6, 7,8	1,3,4, 5,6,7									
Demonstrate Supervisory Ability (3)		1,2,3, 4,5,6, 7,8	—									
Comply With and Use Tech. Specs. (3)		4	—									
Notes:												
(1) Includes Technical Specification compliance for an RO.												
(2) Optional for an SRO-U.												
(3) Only applicable to SROs.												

INSTRUCTIONS:

Circle the applicant's license type and enter the event numbers that test the competency for each scenario in the set.

Author:

Chief Examiner:




Competencies	Applicant-RO6 RO/SRO-I/SRO-U				Applicant-RO7 RO/SRO-I/SRO-U				Applicant-SRO6 RO/SRO-I/SRO-U			
	SCENARIO				SCENARIO				SCENARIO			
	R 1	P 2	3	4	P 1	2	3	R 4	1	R 2	3	C 4
Understand and Interpret Annunciators and Alarms	2,3,4,6	2,3,5,6,8			2,4,5,6			2,3,5,7,8		3,4,5,7		2,3,4,5,6,7,8
Diagnose Events and Conditions	2,3,4,6,7,8	2,3,5,6,8			2,4,5,6,8			2,3,5,7,8		3,4,5,7		3,4,5,6,7,8
Understand Plant and System Response	1,2,3,4,6,7	1,2,3,5,6,8			1,2,4,5,6,8			1,2,3,5,7,8		1,3,4,5,7		1,2,3,4,5,6,7,8
Comply With and Use Procedures (1)	1,2,3,4,6,7,8	1,2,3,5,6,8			1,2,4,5,6,8			1,2,3,5,7,8		1,3,4,5,7		1,2,3,5,6,7,8
Operate Control Boards (2)	1,2,3,4,6,7,8	1,2,3,5,6,8			1,2,4,5,6,8			1,2,3,5,7,8		1,3,4,5,7		—
Communicate and Interact With the Crew	1,2,3,4,5,6,7,8	1,2,3,5,6,8			1,2,4,5,6,8			1,2,3,5,7,8		1,3,4,5,7		1,2,3,4,5,6,7,8
Demonstrate Supervisory Ability (3)	—	—			—			—		—		1,2,3,4,5,6,7,8
Comply With and Use Tech. Specs. (3)	—	—			—			—		—		3,5
Notes:												
(1) Includes Technical Specification compliance for an RO.												
(2) Optional for an SRO-U.												
(3) Only applicable to SROs.												

INSTRUCTIONS:

Circle the applicant's license type and enter the event numbers that test the competency for each scenario in the set.

Author:

Chief Examiner:



 5/17/2008

Competencies	Applicant-RO8 RO/SRO-I/SRO-U				Applicant-SRO7 RO/SRO-I/SRO-U				Applicant-SRO8 RO/SRO-I/SRO-U			
	SCENARIO				SCENARIO				SCENARIO			
	R 1	2	3	P 4	C 1	2	R 3	4	1	2	C 3	R 4
Understand and Interpret Annunciators and Alarms	2,3,4,6			2,4,6,7,8	2,3,4,5,6		2,4,5				2,3,4,5,6	2,3,5,7,8
Diagnose Events and Conditions	2,3,4,6,7,8			4,6,7,8	2,3,4,5,6,7,8		2,4,5				2,3,4,5,6,7	2,3,5,7,8
Understand Plant and System Response	1,2,3,4,6,7			1,2,4,6,7,8	1,2,3,4,5,6,7,8		1,2,4,5				1,2,3,4,5,6,7	1,2,3,5,7,8
Comply With and Use Procedures (1)	1,2,3,4,6,7,8			1,2,4,6,7,8	1,2,3,4,5,6,7,8		1,2,4,5				1,2,3,4,5,6,7	1,2,3,5,7,8
Operate Control Boards (2)	1,2,3,4,6,7,8			1,2,4,6,7,8	—		1,2,4,5				—	1,2,3,5,7,8
Communicate and Interact With the Crew	1,2,3,4,5,6,7,8			1,2,4,6,7,8	1,2,3,4,5,6,7,8		1,2,4,5				1,2,3,4,5,6,7	1,2,3,5,7,8
Demonstrate Supervisory Ability (3)	—			—	1,2,3,4,5,6,7,8		—				1,2,3,4,5,6,7	—
Comply With and Use Tech. Specs. (3)	—			—	4		—				4,5	—
Notes:												
(1) Includes Technical Specification compliance for an RO.												
(2) Optional for an SRO-U.												
(3) Only applicable to SROs.												

INSTRUCTIONS:

Circle the applicant's license type and enter the event numbers that test the competency for each scenario in the set.

Author:

Chief Examiner:

M. Sankar
D. J. Swartz



Competencies	Applicant-RO9 RO/SRO-I/SRO-U				Applicant-RO10 RO/SRO-I/SRO-U				Applicant-SRO9 RO/SRO-I/SRO-U			
	SCENARIO				SCENARIO				SCENARIO			
	1	R 2	P 3	4	1	P 2	3	R 4	1	2	R 3	C 4
Understand and Interpret Annunciators and Alarms		3,4, 5,7	2,3,4, 5,6			2,3,5, 6,8		2,3,5, 7,8			2,4,5	2,3,4, 5,6,7, 8
Diagnose Events and Conditions		3,4,5, 7	2,3,4, 5,6,7			2,3,5, 6,8		2,3,5, 7,8			2,4,5	3,4,5, 6,7,8
Understand Plant and System Response		1,3,4, 5,7	1,2,3, 4,5,6, 7			1,2,3, 5,6,8		1,2,3, 5,7,8			1,2,4, 5	1,2,3, 4,5,6, 7,8
Comply With and Use Procedures (1)		1,3,4, 5,7	1,2,3, 5,6,7			1,2,3, 5,6,8		1,2,3, 5,7,8			1,2,4, 5	1,2,3, 5,6,7, 8
Operate Control Boards (2)		1,3,4, 5,7	1,2,3, 5,6,7			1,2,3, 5,6,8		1,2,3, 5,7,8			1,2,4, 5	—
Communicate and Interact With the Crew		1,3,4, 5,7	1,2,3, 4,5,6, 7			1,2,3, 5,6,8		1,2,3, 5,7,8			1,2,4, 5	1,2,3, 4,5,6, 7,8
Demonstrate Supervisory Ability (3)		—	—			—		—			—	1,2,3, 4,5,6, 7,8
Comply With and Use Tech. Specs. (3)		—	—			—		—			—	3,5
Notes:												
(1) Includes Technical Specification compliance for an RO.												
(2) Optional for an SRO-U.												
(3) Only applicable to SROs.												

INSTRUCTIONS:

Circle the applicant's license type and enter the event numbers that test the competency for each scenario in the set.

Author:

Chief Examiner:

Facility: Salem Generating Station	Scenario No.: 1	Op Test No.: D1
Examiners: _____	Candidates: _____	CRS
_____	_____	RO
_____	_____	PO

Objectives: Evaluate the ability of the Crew to perform a normal power reduction. Evaluate the response of the crew to the failure of PT-505 during the power reduction. Evaluate the ability of the Crew to recognize and respond to the failure of VCT level instrument LT-112. Evaluate the response of the Crew to the RCS leak. Evaluate the ability of the Crew to recognize and respond to the Main Steam Isolation Valve drifting closed. Evaluate the response of the Crew to the rising leak rate and eventual entry into the EOPs. The crew should recognize the failure of 22 SI Pump to start. Evaluate the response of the Crew to the loss of offsite power and their ability to recognize the need to manually align Safety Injection components.

Initial Conditions: IC-2, MOL at 100% power. 21 Service water Pump and Strainer C/T. N41 removed from service. 24 S/G narrow range level LT-549 is removed from service for I&C testing. 21 SI pump is C/T to repair a leaking drain valve.

Turnover: The plant is in Mode 1 at 100% power. Last shift, 21 Heater Drain Pump developed an abnormal vibration and is to be removed from service. 21 Service Water Pump and Strainer are C/T for strainer maintenance. N41 is out of service for replacement of a failed amplifier card. 24 S/G narrow range level LT-549 is removed from service for I&C testing. 21 SI pump is C/T to repair a leaking drain valve. All other equipment is operating normally with all controls in automatic. Orders for the shift are to perform a power reduction to 90% within the next 30 minutes and remove 21 Heater Drain Pump from service.

Event No.	Malf. No.	Event Type*	Event Description
1		N CRS R PO R RO	Perform a normal power reduction to permit removal of 21 Heater Drain Pump
2	TU0055	I CRS PO RO	Turbine First Stage Pressure transmitter, PT-505 fails low
3	CV0037	I CRS RO	VCT Level transmitter, LT-112 fails high
4	RC0002	C ALL	RCS Leak – Ramp from 0 – 35 gpm over 5 min
5	VL0422	C CRS PO	Main Steam Isolation Valve, 23MS167 drifts closed
6	RC0002	M ALL	Small Break LOCA – 1000 gpm
7	SJ0184B	C CRS RO	22 SI Pump Fails to start on SI signal
8	EL0134	M ALL	Loss of Offsite Power (After the SI is reset)

* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor

SCENARIO SUMMARY

The scenario begins with a normal power reduction to remove 21 Heater Drain Pump from service. During the power reduction, the turbine first stage pressure transmitter PT505 fails low. This will change T-ref to the no load value of 547°F resulting in continuous rod motion in the inward direction. The RO should verify that no turbine load change is in progress and that Tave and reactor power are consistent and then take Rod Control to manual to stop rod motion. Actions should then be performed IAW AB.ROD-0003, Continuous Rod Motion.

When VCT level transmitter LT112 fails high, CV35 will divert to the Holdup Tanks causing VCT level to lower. Since the VCT auto makeup function is controlled by LT112 between 14-24%, no auto makeup will occur. The operator must manually divert CV35 back to the VCT and/or initiate a manual makeup to terminate the VCT level drop. The operators will be alerted to the failure by a VCT HI/LO Level console alarm.

An RCS leak of 35 gpm inside containment is initiated causing pressurizer level to drop and containment pressure and temperature to rise. Charging flow should rise to maintain pressurizer level on program. Operator actions should include monitoring VCT level and initiating a manual VCT makeup to prevent Charging Pump cavitation since the auto swap to the RWST will not occur with LT112 failed high.

When the Main Steam Line isolation valve drifts closed, the PO should respond IAW the Annunciator Response procedure and re-open the valve.

The major event is a small break LOCA caused by degradation of the existing leak to a 1000 gpm break. The crew should recognize the inability to maintain pressurizer level and manually trip the Reactor, initiate a manual Safety Injection and initiate the EOPs by entering EOP-TRIP-0001. The crew should notice the failure of the 22 SI Pump to start and perform appropriate steps of TRIP-1 to start it.

The crew should perform TRIP-1 and transition to EOP-LOCA-1 at Step 28.

When desired by the examination team but after the SECs are reset, a Loss of Off-site power will occur. Since the SECs will have been reset and will not restart loads automatically, the crew should respond IAW the "BLACKOUT" continuous action step (Step 5) and manually start ECCS pumps. The scenario may be terminated when the plant is stable with the proper ECCS pumps in service and with the concurrence of the examination team.

SIMULATOR EXAM SCENARIO

SCENARIO TITLE: Small Break LOCA

SCENARIO NUMBER: 1-D1

EFFECTIVE DATE: 2/22/99

EXPECTED DURATION: 1.5 Hours

REVISION NUMBER: 0


PROGRAM:



LO REQUAL



INITIAL LICENSE



STA



OTHER _____

Revision Summary: Rev 0

PREPARED BY: *M. Mansour*
(WD ASSOCIATES)

1/21/99
(DATE)

APPROVED BY: _____
(TRAINING SUPERVISOR)

(DATE)

APPROVED BY: _____
(TRAINING SUPERVISOR)

(DATE)

I. OBJECTIVES

- A. Evaluate the ability of the crew to implement normal plant procedures to reduce plant power for the removal of the 21 Heater Drain Pump.
- B. Evaluate the ability of the crew to recognize and respond to PT-505 failing low during the power reduction.
- C. Evaluate the ability of the crew to recognize and respond to the failure high of VCT level instrument, LT-112.
- D. Evaluate the ability of the crew to recognize and to respond to the RCS leak by implementing the appropriate plant procedures.
- E. Evaluate the ability of the crew to recognize and respond to the Main Steam Isolation Valve drifting closed.
- F. Evaluate the ability of the crew to recognize and respond to the rising RCS leak rate and to implement the EOPs when plant conditions degrade.
- G. Evaluate the ability of the crew to recognize the failure of the 22 Safety Injection Pump to start upon receipt of a Safety Injection signal.
- H. Evaluate the ability of the crew to recognize the loss of offsite power and the resultant need to manually align Safety Injection components.

II. MAJOR EVENTS

- A. Perform a normal power reduction to permit removal of 21A Heater Drain Pump.
- B. Turbine First Stage Pressure transmitter, PT-505 fails low during the power reduction.
- C. VCT Level transmitter, LT-112 fails high.
- D. An RCS leak develops and ramps from 0 – 35 gpm over a 5 minute period.
- E. Main Steam Isolation Valve, 23MS167 drifts closed
- F. The RCS leak degrades into a Small Break LOCA at approximately 1000 gpm.
- G. 22 Safety Injection Pump fails to start upon receipt of a Safety Injection signal.
- H. Loss of Offsite Power

III. SCENARIO SUMMARY

- A. The crew will assume the watch at 100% power with directions to initiate a power reduction to 90% for the removal of the 21 Heater Drain Pump from service to correct shaft vibrations. All controls are in automatic. The following additional plant conditions exist:
- 21 Service Water Pump and Strainer are C/T for strainer maintenance. The Maintenance Supervisor anticipates the work to be completed in approximately six (6) hours.
 - N41 is out of service due to a failed amplifier card and is expected to be returned by the end of shift.
 - 24 S/G narrow range level LT-549 is removed from service for I&C testing.
 - 21 SI pump is C/T to repair a leaking drain valve.
- B. During the power reduction, PT-505 will fail low. When the crew identifies the failure, they should respond by taking Rod Control to manual to stop rod motion.
- C. While waiting for the failure of PT-505 to be resolved, VCT Level transmitter, LT-112 will fail high. The crew should respond IAW the appropriate Alarm Response Procedure and by manually diverting CV-35 back to the VCT.
- D. When VCT level is stable, a small RCS leak is initiated and ramped from 0-35 gpm over a 5 minute time period.
- E. After the initial actions for the RCS leak have been initiated, Main Steam Line Isolation Valve 23MS167 will drift closed.
- F. Approximately two minutes after the crew has reopened the Main Steam Line Isolation Valve, the RCS leak will degrade to a Small Break LOCA of approximately 1000 gpm requiring initiation of Safety Injection and entry into the EOPs.
- G. When the Safety Injection is initiated, 22 Safety Injection Pump will fail to start but will start manually.
- H. When steps to reduce injection flow have been initiated and at the discretion of the examination team, a Loss of Offsite power is initiated. The scenario may be terminated when the crew recognizes that ECCS systems must be manually restored and initiates action to restore proper SI flow or as directed by the examination team.

III. INITIAL CONDITIONS

IC-2 (or IC-88 from the ESG disk), MOL at 100% power with the following conditions:

- a. 21 Service Water Pump and Strainer C/T for strainer maintenance.
- b. N41 removed from service due to a failed amplifier card.
- c. 24 S/G narrow range level LT-549 is removed from service for I&C testing.
- d. 21 SI pump is C/T to repair a leaking drain valve.

MALFUNCTIONS					
	Malfunction	Severity	Delay	Ramp	Description
___1.	SG095D	0	0	0	24 S/G Lvl Transmitter LT549 failed low
___2.	SJ0184B	Fail	0	0	22 SI Pump Fail to start
___3.	TU0055	0	0	0	PT-505 fails low (ET-1)
___4.	CV0037	100	0	0	LT-112 Fails High (ET-2)
___5.	RC0002	35 gpm	0	5 min	RCS Leak into Cont. (ET-3)
___6.	VL0422	93%	0	0	23MS167 Drifts Closed (Fails to 93% open) (ET-4)
___7.	EL0134	Fail	0	0	Loss of all 500 KV Offsite Power (ET-5)

I/O OVERRIDES						
	Override/Type	SER Pt.	DI	DO	Condition	Description

- ___1. None

REMOTES			
	Remote/Type	Condition	Description
___1.	SW23D	OFF	21 SW Pump control power
___2.	SW24D	Tagged	21 SW Pump breaker racked out
___3.	SJ13D	OFF	21 SI Pump control power
___4.	SJ14D	Tagged	21 SI Pump breaker racked out
___5.	RC01D	Trip	OTDT Trip CH I BS (411C)
___6.	RC05D	Trip	OTDT R/BCK CH I BS (411D)
___7.	S401D	Trip	24 S/G Lvl Hi-Hi BS

TAGGED EQUIPMENT	
	Description
___1.	21 Service Water Pump and Strainer for strainer maintenance.
___2.	N41 removed from service due to a failed amplifier card.
___3.	21 SI pump is C/T to repair a leaking drain valve.
___4.	Red Stripe LT-549

IV. SEQUENCE OF EVENTS

- A. Designate shift positions.
- B. Conduct a shift briefing outlining the shift instructions to the crew. (Provide each crew member with a copy of the Shift Turnover Sheet)
- C. Inform the crew " The simulator is running and that board walk-downs should be performed. CRS please inform me when your Crew is ready to assume the shift."
- D. Allow sufficient time for panel walk-downs. When informed by the CRS that the Crew is ready to assume the shift, ensure the simulator is cleared of unauthorized personnel.

EVALUATOR/INSTRUCTOR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
<p>. Power reduction using normal plant procedures.</p> <div style="border: 1px solid black; padding: 5px;"> <p>No malfunctions other than those already inserted to start the scenario. The crew will reduce load at 30% per hr until either 90% power is reached or PT-505 fails.</p> </div>	<ul style="list-style-type: none"> ● The CREW commences a power reduction IAW Step 5.3 of S2.OP-IO.ZZ-0004, Power Operation. <ul style="list-style-type: none"> - Notify the Systems Operator and the Condensate Polishing Operator of the upcoming load reduction. ● The CRS establishes a rate of power reduction. ● The PO INITIATES a Turbine load reduction with IAW S2.OP-SO.TRB-0002, Turbine Generator Shutdown Operations. <ul style="list-style-type: none"> - INITIATES monitoring the Main Turbine Data display points on the Plant Computer. - Uses the REF ? and GO pushbuttons to attain desired load. ● The RO MAINTAINS T_{AVG}/T_{REF} mismatch at minimum value with Auto Rod motion and Boration. ● The RO adjusts RCS Boron concentration to maintain AFD in target band and Rods above Rod Insertion Limits using OP-SO.CVC-0006, Boron Concentration Control. <ul style="list-style-type: none"> - DEPRESS Makeup Control Mode Select STOP Pushbutton. - ADJUST 2CV172 Setpoint to the desired value. - SET Boric Acid Flow Register to the number of gallons desired. - DEPRESS Makeup Control Mode Select BORATE Pushbutton. - DEPRESS Makeup Control Mode Select START Pushbutton. 	

EVALUATOR/INSTRUCTOR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
	<ul style="list-style-type: none"> - When Boration is complete, depress makeup Control Mode Select STOP Pushbutton. - ADJUST 2CV172 Setpoint to the pre-boration value. - DEPRESS Makeup Control Mode Select AUTO Pushbutton. - DEPRESS Makeup Control Mode Select START Pushbutton. <ul style="list-style-type: none"> • The PO verifies that SG Feed Pump suction pressure is being maintained ≥ 300 psig. • The PO monitors Condenser temperatures using the Plant Computer. 	
<p>2. PT-505 fails low.</p> <div style="border: 1px solid black; padding: 5px;"> <p>After the power reduction has progressed sufficiently, and with the concurrence of the Examination team, initiate the failure of PT-505 failure, ET-1, Malf. TU0055.</p> </div>	<p>The failure of PT-505 causes the following plant response:</p> <ul style="list-style-type: none"> - Control Rods continuously insert at 72 steps per min. - RC Tave-Tref DEVIATION console alarm - 21-24 S/G HI STM FLOW console alarms - OHA E-5, SR DET VOLT TRBL - OHA E-21, SR HI FLUX AT S/D BLOC - OHA G-15, ADFCS TRBL - OHA A-36, AMSAC BYPASSED (240 Sec Time Delay) <ul style="list-style-type: none"> • The CREW responds to the control rod motion and alarms. • The RO determines the rod motion to be unwarranted and places Rod Control in Manual <ul style="list-style-type: none"> - Verifies no turbine runback in progress or required - Verifies turbine load is not changing - Verifies Tave on program - Places Rod Control in MANUAL • The CRS enters and performs actions of S2.OP-AB.ROD-0003, Continuous Rod Motion. 	

EVALUATOR/INSTRUCTOR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
	<ul style="list-style-type: none"> • The CREW identifies the failure of PT-505 as the cause of the transient. • The PO places Steam Dumps in Main Steam Pressure Control Mode. • The CREW notifies I&C to investigate the failure of PT-505. • The CREW reviews the OHAs in alarm • The CRS initiates the actions of S2.OP-SO.RPS-0006, Main Turbine Channel Trip/Restoration 	
<p>3. VCT Level transmitter, LT-112 fails high.</p> <div style="border: 1px solid black; padding: 5px; margin-top: 10px;"> <p>When the plant is stable and actions of AB.ROD-0003 have been completed, initiate the failure of LT-112, ET-2, Malf CV0037.</p> </div>	<p>Failure of LT-112 high will cause the following plant response:</p> <ul style="list-style-type: none"> - CV35 will full divert to the HUT if in Auto. - Actual VCT level will begin to lower. - No auto makeup will occur with LT-112 failed high. - With no operator action, level will continue to drop until charging pumps cavitate. - Auto swap to RWST will not occur with LT-112 failed high. - VCT HI/LO LEVEL console alarm will actuate due to LT-112 failed high. - Console level indication for the VCT is fed from LT-112 and will indicate upscale. Indication is available via the plant computer from LT-114. <ul style="list-style-type: none"> • The RO responds to HI/LO LEVEL alarm: <ul style="list-style-type: none"> - Compares console level with computer indications and determines LT-112 is failed. - Manually aligns CV35 to the VCT. - Initiates a manual makeup as necessary to restore and maintain VCT level IAW S2.OP-SO.CV-0006. 	

EVALUATOR/INSTRUCTOR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
----------------------------------	------------------------------------	----------

4. RCS Leak inside Containment

When VCT Level is stable, insert the RCS Leak at 35 gpm ramped over a 5 min period, ET-3, malfunction RC0002.

- The **CREW** responds IAW the CC2 Console Alarm response Procedure, S2.OP-AR.ZZ-0012.
- The **CREW** identifies the leak by one or more of the following indications:
 - The Warning alarm on R-11A
 - Rising rad levels on R-11A
 - A rise in Containment temp and pressure
 - CFCU Leak Detection OHAs
 - Lowering Pressurizer Level
 - Charging flow rising to compensate for the Pressurizer level drop.
- The **CRS** should enter and direct actions IAW S2.OP-AB.RC-0001, RCS Leak.
- The **RO** should place a Centrifugal Charging Pump in service
 - Ensure Master Flow Controller in AUTO.
 - Close 2CV55, charging flow control valve.
 - Start either 21 OR 22 Charging Pump.
 - Place 23 Charging Pump Speed Controller in MANUAL.
 - While lowering 23 Charging Pump, adjust 2CV55 to maintain desired flow.
 - When 23 Charging Pump is at minimum flow, STOP 23 Charging Pump.
 - Adjust 2CV55 to obtain desired flow.
 - Place 2CV55 in AUTO
- The **RO/PO** should reduce letdown flow
 - Manually control 2CV18 and maintain letdown pressure approximately 300 psig.
 - Open 2CV3, 45 gpm orifice
 - Close 2CV4 and 2CV5, 75 gpm orifice
 - Return 2CV18 to Auto
- The **RO/PO** places two CFCUs in Low speed and two CFCUs in High speed.

EVALUATOR/INSTRUCTOR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
----------------------------------	------------------------------------	----------

- The **CRS** refers to Tech Specs.
 - Operational Leakage (3.4.7.2)
 - Containment Pressure (3.6.1.4)
- The **CREW** may initiate a manual makeup due to failed VCT Level.
- The **CREW** determines the leak rate to be > TS limits and begins a plant shutdown.
- The **PO** responds to OHA G-34, 21-24MS167 VALVES NOT FULL OPEN and takes action IAW S2.OP-AR.ZZ-0007.
 - Identifies the drifting valve as 23MS167.
 - Opens the valve using the open pushbutton.

5. Main Steam Line Isolation Valve, 23MS167 drifts closed.

When the decision to shutdown the plant has been made, insert the malfunction to drift 23MS167 closed: ET-4, Malf VL0422. **AS SOON AS** the alarms are received, delete the Malf from the summary page to allow the MSIV to be opened.

6. Small Break LOCA

When 23MS167 is returned to the full open position, modify Malf RC0002 to 1000 gpm.

- The **CREW** recognizes the degraded condition by observing:
 - Pressurizer level lowering rapidly.
 - Pressurizer pressure lowering
- The **RO** manually trips the Reactor and confirms the trip:
 - At least three PR channels indicate < 5%
 - IR indications lowering with negative SUR
- The **RO** Manually initiates SI.
- The **CRS** enters EOP-TRIP-1, Reactor Trip or Safety Injection

Critical Task # 1: Sat _____
 Unsat _____

EVALUATOR/INSTRUCTOR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
----------------------------------	------------------------------------	----------

- The **RO** performs the immediate actions of EOP-TRIP-1:

- Trip the reactor
- Verify the Reactor is tripped by observing at least three PR channels indicate < 5% and IR indications lowering with negative SUR
- Trip the Turbine and verify TSV CLOSED and AST OIL PRESS LOW lights illuminated on RP4
- Verify Vital 4KV Bus status by observing bus voltage > 3900 volts
- Manually initiate SI

Critical Task #2: Sat _____
Unsat _____

- The **CREW** should notice the failure of 22 SI Pump to start and manually start the pump IAW the appropriate steps of EOP-TRIP-1.

- The **PO** blocks and resets the 'C' SEC.
- The **RO** starts 22 SI pump.

The **CREW** closes CV139 & CV140, Charging Pump Miniflow valves IAW EOP-TRIP-1 CAS when RCS pressure lowers below 1500 psig and BIT flow is established.

Critical Task #3: Sat _____
Unsat _____

The **CREW** stops all RCPs IAW EOP-TRIP-1 CAS when RCS pressure lowers to 1350 psig and ECCS flow is established.

- The **RO** closes 21 & 22CA330, Containment Control Air Isolation Valves.
- The **PO** throttles AFW flow to > 22E4 lbm/hr, then maintains S/G levels 15-33%.
- The **RO** initiates Loop 21-24 MSL Isolation.

EVALUATOR/INSTRUCTOR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
----------------------------------	------------------------------------	----------

- The **CREW** transitions to EOP-LOCA-1, Loss of Reactor Coolant at Step 28 when the following Containment Rad Monitors are observed in Warning, Alarm or Rising:
 - 2R2
 - 2R7
 - 2R10A,B
- The **CREW** implements the CFSTs
- The **RO** performs Safeguards Reset Actions:
 - Resets SI
 - Resets Phase A
 - Resets Phase B
 - Opens 21 & 22CA330, Containment Control Air Isolation Valves.
 - Resets A & B SEC

The Crew may not stop RHR Pumps if pressure is slowly lowering.

- If pressure is stable, then the **RO** stops 21 & 22 RHR Pumps.

7. Loss of Off-site Power

After the SI has been reset, initiate the Loss of Off-site Power by inserting ET-5, malfunction EL0134.

- The **CREW** recognizes the Loss of Off-site power by observing 500KV breaker indication on CC3 Mimic.
- The **CRS** directs the actions of the blackout continuous action step (Step 5).
- The **PO** verifies loading is complete by observing the LOADING COMPLETE light is illuminated for each D/G.
- The **PO** Resets each SEC and monitors D/G loading as loads are started.
- The **RO** verifies 21 & 22 Charging Pumps running

EVALUATOR/INSTRUCTOR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
----------------------------------	------------------------------------	----------

Critical Task #4: Sat _____
Unsat _____

- The RO starts 22 SI Pump

The Crew may elect to start RHR pumps if they were not previously removed from service.

- The PO verifies 21 & 22 AFW Pumps running
- The RO starts 21 & 22 RHR Pumps

The scenario may be terminated after required ECCS Pumps have been restarted and with the concurrence of the examination team.

After the scenario has been terminated, the CRS should refer to the ECG to Classify the event.

- The CRS refers to the ECG and classifies the event:
 - Alert - 3.2.2.B or 3.2.2.a depending on the value of subcooling.

V. SCENARIO REFERENCES

- A. ES-301, Preparing Initial Operating Tests
- B. K/A Catalog
- C. JTA Listing
- D. Technical Specifications
- E. S2.OP-IO.ZZ-0004
- F. S2.OP-SO.TRB-0002
- G. Various Alarm Response Procedures
- H. S2.OP-AB.ROD-0003
- I. S2.OP-SO.RPS-0006
- J. S2.OP-SO.CVC-0006
- K. S2.OP-AB.RC-0001
- L. 2-EOP-TRIP-1
- M. 2-EOP-LOCA-1

ATTACHMENT 1 UNIT TWO PLANT STATUS TODAY

MODE: 1	POWER: 100%	RCS BORON: 680 ppm	Mwe: 1150
---------	-------------	--------------------	-----------

SHUTDOWN SAFETY SYSTEM STATUS (5, 6 & DEFUELED): N/A

REACTIVITY PARAMETERS: Core Burnup 8000 MWD/MTU

MOST LIMITING LCO AND DATE/TIME OF EXPIRATION:

3.3.3.1 N41 out of service. Action requirements are complete. QPTR due at 1700 this evening.

3.3.3.1 24LT-549 out of service for I&C testing. Testing is expected to be complete in 4 hrs.

3.5.2 21 SI Pump out of service. 72 hour Action expires at 2200 tomorrow.

EVOLUTIONS/PROCEDURES/SURVEILLANCES IN PROGRESS:

21 SI O/S to repair a leaking drain valve

21 Service Water Strainer out of service for basket repairs

24 S/G Level transmitter LT-549 OOS for I&C Testing

PLANT TURNOVER IS AS FOLLOWS:

Last shift, 21 Heater drain Pump developed an excessive vibration and is to be removed from service for investigation and repair.

The orders for the shift are to reduce power to 90% at 30%/hr and remove 21 Heater Drain Pump from service.

ABNORMAL PLANT CONFIGURATIONS: NONE

CONTROL ROOM:

Unit 1 and Hope Creek at 80% power.

No penalty minutes in the last 24 hrs.

PRIMARY: NONE

SECONDARY: Heating Steam is aligned to unit 1.

RADWASTE: No discharges in progress

CIRCULATING WATER/SERVICE WATER: 21 SW Strainer C/T for strainer repairs.

ATTACHMENT 2 SIMULATOR READY FOR TRAINING CHECKLIST
--

- ___ 1. Verify simulator is in correct load for training
- ___ 2. All required computer terminals in operation
- ___ 3. Simulator clocks synchronized
- ___ 4. Required chart recorders advanced and ON (proper paper installed)
- ___ 5. Rod step counters correct (channel check)
- ___ 6. All tagged equipment properly secured and documented (TSAS Log filled out)
- ___ 7. DL-10 log up-to-date
- ___ 8. Required procedures clean
- ___ 9. All OHA lamps operating (OHA Test)
- ___ 10. All printers have adequate paper AND functional ribbon
- ___ 11. Procedure pens available
- ___ 12. Procedures in progress open and signed-off to proper step
- ___ 13. Shift manning sheet available
- ___ 14. SPDS reset
- ___ 15. Reference verification performed with required documents available
- ___ 16. Ensure a current RCS Leak Rate Worksheet is placed by Aux Alarm Typewriter with Baseline Data filled out
- ___ 17. Required keys available
- ___ 18. Video Tape (if applicable)
- ___ 19. Ensure ECG Classification is correct – 960502140 CRCA-03
- ___ 20. Reset P-250 Rod Counters

ATTACHMENT 3

CRITICAL TASK METHODOLOGY

In reviewing each proposed CT, the examination team assesses the task to ensure, that it is essential to safety. A task is essential to safety if, in the judgement of the examination team, the improper performance or omission of this task by a licensee will result in direct adverse consequences or in significant degradation in the mitigative capability of the plant.

The examination team determines if an automatically actuated plant system would have been required to mitigate the consequences of an individual's incorrect performance. If incorrect performance of a task by an individual necessitates the crew taking compensatory action that would complicate the event mitigation strategy, the task is safety significant.

1. Examples of CTs involving essential safety actions include those for which operation or correct performance prevents...
 - degradation of any barrier to fission product release
 - degraded emergency core cooling system (ECCS) or emergency power capacity
 - a violation of a safety limit
 - a violation of the facility license condition
 - incorrect reactivity control (such as failure to initiate Emergency Boration or Standby Liquid Control, or manually insert control rods)
 - a significant reduction of safety margin beyond that irreparably introduced by the scenario

2. Examples of CTs involving essential safety actions include those for which a crew demonstrates the ability to...
 - effectively direct or manipulate engineered safety feature (ESF) controls that would prevent any condition described in the previous paragraph.
 - recognize a failure or an incorrect automatic actuation of an ESF system or component.
 - take one or more actions that would prevent a challenge to plant safety.
 - prevent inappropriate actions that create a challenge to plant safety (such as an unintentional Reactor Protection System (RPS) OR ESF actuation.

ATTACHMENT 4 SCENARIO REVIEW CHECKLIST

Note: Attach a separate copy of this form to each scenario reviewed. This form is used as guidance for the examination team as they conduct their review for the proposed scenarios.

SCENARIO IDENTIFIER:	REVIEWER:
-----------------------------	------------------

Initials Qualitative Attributes

- ___ 1. The scenario has clearly stated objectives in the scenario.
- ___ 2. The initial conditions are realistic, in that some equipment and/or instrumentation may be out of service, but it does not cue crew into expected events.
- ___ 3. The scenario consists mostly of related events.
- ___ 4. Each event description consists of--
 - the point in the scenario when it is to be initiated
 - the malfunction(s) that are entered to initiate the event
 - the symptoms/cues that will be visible to the crew
 - the expected operator actions (by shift position)
 - the event termination point
- ___ 5. No more than one non-mechanistic failure (e.g., pipe break) is incorporated into the scenario without a credible preceding incident such as a seismic event.
- ___ 6. The events are valid with regard to physics and thermodynamics.
- ___ 7. Sequencing/timing of events is reasonable, and allows for the examination team to obtain complete evaluation results commensurate with the scenario objectives.
- ___ 8. The simulator modeling is not altered.
- ___ 9. All crew competencies can be evaluated.
- ___ 10. The scenario has been validated.
- ___ 11. If the sampling plan indicates that the scenario was used for training during the Requalification cycle, evaluate the need to modify or replace the scenario.

<p style="text-align: center;">ATTACHMENT 5 ESG – CRITICAL TASKS</p>
--

CT#1 – CRS orders MANUAL Rx Trip then SI when Pressurizer level cannot be maintained. (E-0--A)

CT#2 – Crew stops all RCPs when RCS pressure lowers below 1350 psig & ECCS flow is established (E-1--C)

CT#3 – Crew manually starts 22 SI Pump following SEC start failure. (E-0--J)

CT#4 – Crew manually starts 22 SI Pump following the Loss of Off-site Power. (E-0--J)

Facility: Salem Units 1 & 2	Scenario No.: 2	Op Test No.: D2
Examiners: _____	Candidates: _____	CRS
_____	_____	RO
_____	_____	PO

Objectives: Evaluate the ability of the Crew to perform a normal power ascension using the Integrated Operating Procedures. The crew should recognize and respond to the shift of 23BF19/40 to manual. Evaluate the ability of the Crew to recognize and respond to the SGFP trip and stabilize the plant without a plant trip. The crew should recognize and respond to the failure of the Pressurizer Pressure Channel I and take action to stabilize plant pressure. Evaluate the ability of the Crew to respond to the Steam Line break and enter the EOPs. Evaluate the response of the Crew to the trip of 22 AFW Pump. Evaluate the ability of the crew to recognize and respond to the failure of 22 Charging Pump to auto start. Evaluate the ability of the Crew to recognize the trip of 21 AFW Pump and properly transition to EOP-FRHS-1, Response to Loss of Secondary Heat Sink.

Initial Conditions: IC-3 at 70% power with the following conditions:

- 23 S/G Narrow Range Level transmitter, LT-539 failed and has been removed from service.
- 23 AFW Pump C/T for repair of a steam leak on MS132.

Turnover: The plant is in Mode 1 at 70% power with a power ascension in progress. 23 S/G NR Level transmitter, LT-539 is out of service for repairs. 23 AFW Pump is C/T due to a steam leak on. All other equipment is operating normally with all controls in automatic. Orders for the shift are to continue the ascension to 100% power at 10% /hr.

Event No.	Malf. No.	Event Type*	Event Description
1		N CRS R PO R RO	Perform a power ascension to 100 % power
2	I/O BM06 & CL06	I CRS PO	23BF19 & 23 BF40 shift to manual
3	BF0105A	C All	21 SGFP trip
4	PR0016A	I CRS RO	Pressurizer Pressure Channel I fails high
5	MS0247C MS0090C	M All	Main Steam Line Leak/Break in Containment on 23 S/G
6	AF0181B	C CRS PO	22 Aux Feedwater Pump trip
7	CV0185B	C CRS RO	22 Charging Pump fails to start on SEC
8	AF0181A	C CRS PO	21 Aux Feedwater Pump trip

* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor

SCENARIO SUMMARY

After the power ascension has progressed to the satisfaction of the examination team, 23 S/G Feedwater Reg Valves BF19 and BF40 will shift to manual. The crew should terminate the power ascension and investigate. After a delay, the 21 SGFP will develop thrust bearing problems, which cause the pump to trip. The PO should control 23 S/G level with manual control of 23BF19/40.

When the plant is stable, the Pressurizer Pressure Channel I will fail high. This will cause pressurizer heaters to turn off, both spray valves to open and actual pressurizer pressure to lower. The RO should respond by placing the Master pressure controller in manual and close the spray valves. The crew should enter and perform the actions of S2.OP-AB.PZR-0001.

The major event is a Main Steam Leak on 23 S/G inside Containment. The crew will respond by entering and performing the actions of S2.OP-AB.STM-0001, Excessive Steam Flow. When the crew decides to manually trip the Reactor and enter into EOP-TRIP-1, Reactor Trip or Safety Injection, the leak will degrade into a rupture.

During the initial transient, 22 AFW Pump will trip on overcurrent and 22 Charging Pump will fail to auto start. The PO is expected to establish and maintain feed flow to 23 & 24 S/Gs using the remaining AFW Pump and the RO is expected to manually start 22 Charging Pump after the SEC is reset.

When flow is established to 24 S/G, 21 AFW Pump will trip resulting in a Loss of Secondary Heat Sink. The Crew is expected to respond by transitioning to EOP-FRHS-1, Response to Loss of Secondary Heat Sink at Step 20 of EOP-TRIP-1 or when the 21 AFW pump trips if past Step 26.

The crew will perform the actions of EOP-FRHS-1. The success path will be the restoration of feed by depressurizing the S/Gs and feeding with the Condensate System. The scenario may be terminated when level in at least one S/G is rising and with the concurrence of the Examination Team.

SIMULATOR EXAM SCENARIO

SCENARIO TITLE: Loss of Secondary Heat Sink

SCENARIO NUMBER: 2-D2

EFFECTIVE DATE: 2/22/99

EXPECTED DURATION: 1.5 Hours

REVISION NUMBER: 0

PROGRAM:

LO REQUAL

INITIAL LICENSE

STA

OTHER _____

Revision Summary: Rev 0

PREPARED BY: M. Hanchuruck sm 1/23/99
(WD ASSOCIATES) (DATE)

APPROVED BY: _____ (TRAINING SUPERVISOR) _____ (DATE)

APPROVED BY: _____ (TRAINING SUPERVISOR) _____ (DATE)

I. OBJECTIVES

- A. Evaluate the ability of the crew to implement normal plant procedures to raise plant power to 100% of Rated Thermal Power.
- B. Evaluate the ability of the crew to recognize and respond to 2BF19 & 23BF40 shifting to manual during the power reduction.
- C. Evaluate the ability of the crew to recognize and respond to the trip of 21 SGFP and stabilize the plant without a reactor trip. The PO should control 23 S/G Level with manual control of 23BF19.
- D. Evaluate the ability of the crew to recognize and respond to the Pressurizer Pressure Channel I failing high.
- E. Evaluate the ability of the crew to recognize and respond to the Main Steam Line Break inside containment and to implement the EOPs.
- F. Evaluate the ability of the crew to recognize and respond to the trip of 22 Aux Feedwater pump and control 23 & 24 S/G levels with the remaining AFW Pump.
- G. Evaluate the ability of the crew to recognize and respond to the failure of 22 Charging Pump to auto start.
- H. Evaluate the ability of the crew to recognize the trip of 21 AFW Pump as a Loss of Heat Sink and to properly transition to EOP-FRHS-1, Response to Loss of Secondary Heat Sink.

II. MAJOR EVENTS

- A. Perform power ascension to 100 % power
- B. 23BF19 and 23BF40 shift to MANUAL
- C. 21 SGFP trip
- D. Pressurizer Pressure Channel I fails high
- E. Main Steam Line Break in Containment on 23 S/G
- F. 22 Aux Feedwater Pump trip
- G. 22 Charging Pump fails to auto start
- H. 21 Aux Feedwater Pump trip resulting in a Loss of Heat Sink

III. SCENARIO SUMMARY

- A. The crew will assume the watch with the plant in Mode 1 at 70% power. Directions to the shift are to continue the power ascension to 100%. All controls are in automatic and all equipment is operating normally with the following exceptions:
- 23Aux Feedwater Pump is C/T to repair a steam leak on MS132. The Maintenance Supervisor anticipates the work to be completed in approximately nine (9) hours.
 - 23 S/G Narrow Range Level transmitter, LT-539 failed and has been removed from service. Work is expected to be complete and the transmitter returned to service by the end of shift.
- B. After the power ascension has progressed to the satisfaction of the examination team, 23 S/G Feedwater Reg Valves BF19 and BF40 will shift to manual. The crew should terminate the power ascension and investigate.
- C. While waiting for the shift to manual of BF19 and BF40 to be resolved, the 21 SGFP will develop thrust bearing problems, which cause the pump to trip. The PO should control 23 S/G level during the transient with manual operation of 23BF19/40. The crew should enter and perform the actions of S2.OP-AB.CN-0001.
- D. When the plant is stable, the Pressurizer Pressure Channel I will fail high. This will cause pressurizer heaters to turn off, both spray valves to open and actual pressurizer pressure to lower. The RO should respond by placing the Master pressure controller in manual and close the spray valves. The crew should enter and perform the actions of S2.OP-AB.PZR-0001, Pressurizer Pressure Malfunction.
- E. The major event is a Main Steam Leak on 23 S/G inside Containment. The crew will respond by entering and performing the actions of S2.OP-AB.STM-0001, Excessive Steam Flow. When the crew decides to manually trip the Reactor and enter into EOP-TRIP-1, Reactor Trip or Safety Injection, the leak will degrade into a rupture.
- F. During the initial transient, 22 AFW Pump will trip on overcurrent and 22 Charging Pump will fail to auto start. The PO is expected to establish and maintain feed flow to 23 & 24 S/Gs using with 21 AFW Pump and the RO is expected to manually start 22 Charging Pump after the SEC is reset.
- F. When flow is established to 24 S/G, 21 AFW Pump will trip resulting in a Loss of Secondary Heat Sink. The Crew is expected to respond by transitioning to EOP-FRHS-1, Response to Loss of Secondary Heat Sink at Step 20 of EOP-TRIP-1 or when the 21 AFW pump trips if past Step 26.
- G. The crew will perform the actions of EOP-FRHS-1. The success path will be the restoration of feed by depressurizing the S/Gs and feeding with the Condensate System. The scenario may be terminated when level in at least one S/G is rising and with concurrence of the Examination Team.

IV. INITIAL CONDITIONS

IC-5 or IC-89 on ESG Disk, MOL at 70% power with the following conditions:

- a. 23 S/G NR Level transmitter LT-539 is failed and is out of service.
- b. 23 AFW Pump C/T for repair of a steam leak on MS132.

MALFUNCTIONS

	Malfunction	Severity	Delay	Ramp	Description	
___1.	SG0095C	0	0	0	23 S/G NR Level LT-539 fails low	
___2.	AF0181B	Trip	0	0	22 AFW Pump trip	
___3.	AN0363	2			G07 ADFCS Switch to manual	(ET-1)
___4.	AN0360	2			G15 ADFCS Trouble	(ET-1)
___5.	BF0105A	2	0	0	21 SGFP Trip, Thrust Bearing Press Hi	(ET-2)
___6.	PR0016A	100	0	0	Pzr Pressure Channel I fails high	(ET-3)
___7.	MS0247C	850k lb/hr	0	10 min	Main Steam Leak in Containment	(ET-4)
___8.	MS0090C	N/A	0	0	23 Main Steam Line Break in Containment	(ET-5)
___9.	CV0185B	N/A	N/A	N/A	22 Charging Pump fail to start on SEC	(ET-5)
___10.	AF0181A	Trip	0	0	21 AFW Pump trip	(ET-6)

I/O OVERRIDES

	Override/Type	SER Pt.	DI	DO	Condition	Description
___ 1.	BM06		X		ON	23BF19 MANUAL switch (ET-1)
___ 2.	CL07		X		ON	23BF40 MANUAL switch (ET-1)
___ 3.	B201		X		ON	2PR6 CLOSE PB Switch

REMOTES			
	Remote/Type	Condition	Description
___ 1.	S301D	Trip	23 S/G Level HI-HI CH I (LC539A)
___ 2.	S304D	Trip	23 S/G Level LO-LO CH I (LC539B)

TAGGED EQUIPMENT	
	Description
___ 1.	Red Stripe 23 S/G NR Level transmitter LT-539
___ 2.	23 AFW Pump C/T for repair of a steam leak on MS132 - Open the Trip valve and C/T.

IV. SEQUENCE OF EVENTS

- A. Designate shift positions.
- B. Conduct a shift briefing outlining the shift instructions to the crew. (Provide each crew member with a copy of the Shift Turnover Sheet)
- C. Inform the crew " The simulator is running and that board walk-downs should be performed. CRS please inform me when your Crew is ready to assume the shift."
- D. Allow sufficient time for panel walk-downs. When informed by the CRS that the Crew is ready to assume the shift, ensure the simulator is cleared of unauthorized personnel.

EVALUATOR/INSTRUCTOR OR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
<p>Power ascension using normal plant procedures.</p> <div style="border: 1px solid black; padding: 5px;"> <p>No malfunctions other than those already inserted to start the scenario. The crew will raise load at 10% per hr until either 100% power is reached 23BF19/40 shift to manual.</p> </div>	<ul style="list-style-type: none"> • The CREW commences a power ascension IAW Step 5.2 of S2.OP-IO.ZZ-0004, Power Operation. <ul style="list-style-type: none"> - Notify the Systems Operator and the Condensate Polishing Operator of the upcoming power ascension. • The PO Initiates a Turbine load increase with IAW S2.OP-SO.TRB-0001, Turbine Generator Startup Operations. <ul style="list-style-type: none"> - INITIATES monitoring the Main Turbine Data display points on the Plant Computer. - Monitor Turbine parameters IAW S2.OP-SO.TRB-0001, Attachment 2. - Uses the REF ▲ and GO pushbuttons to attain desired load. - Monitor condenser ΔT Limits • The RO maintains AFD within the target band using Auto Rod motion and Dilution. • The RO MAINTAINS T_{AVG}/T_{REF} mismatch at minimum value with Auto Rod motion and Dilution. • The RO adjusts RCS Boron concentration to maintain Tavg and AFD using Boron Concentration Control, S2.OP-SO.CVC-0006. <ul style="list-style-type: none"> - DEPRESS Makeup Control Mode Select STOP Pushbutton. - SET Primary Water Flow Register to the number of gallons desired. - DEPRESS Makeup Control Mode Select DILUTE Pushbutton. - DEPRESS Makeup Control Mode Select START Pushbutton. 	

EVALUATOR/INSTRUCTOR OR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
-------------------------------------	------------------------------------	----------

- When dilution is complete, depress Makeup Control Mode Select STOP Pushbutton.
- DEPRESS Makeup Control Mode Select AUTO Pushbutton.
- DEPRESS Makeup Control Mode Select START Pushbutton.

2. 23BF19 & 23BF40 shift to MANUAL.

The shift of 23BF19 & 23BF40 to manual causes the following plant response:

After the power ascension has progressed sufficiently and with the concurrence of the examination team: insert ET-1, malfunctions AN0360 and AN0363 and overrides BM06 and CL07 to shift 23BF19 & 23BF40 MANUAL.

- 23 S/G Feed Reg Valves, 23BF19 & 23BF40 shift to manual.
- OHA G-7, ADFCS SWITCH TO MANUAL
- OHA G15, ADFCS TROUBLE

- The **CREW** responds to the alarms IAW the appropriate Alarm Response Procedures.
- The **PO** identifies the problem to be associated with the 23BF19 & 23BF40, 23 S/G Feed Reg Valves by observing the blue MANUAL lights illuminated.
 - Manually adjusts the position of 23BF19 & 23BF40 as necessary to control 23 S/G level at the program value of 44%.
- The **CREW** notifies I&C to investigate the failure shift of 23BF19/40 to manual.

3. 21 SGFP trip

The Crew will be alerted to the SGFP problem by the following plant response:

When the plant is stable and actions of S2.OP-SO.RPS-0004 have been initiated: insert ET-2, MALF BF0105A to trip 21 SGFP.

- OHA G-6, 21 SGFP TRBL
- TURB THRUST BEARING OIL PRESSURE HI console alarm

EVALUATOR/INSTRUCTOR OR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
<p>Approximately 2 minutes after the Equipment Operator is dispatched, report that there is a significant amount of oil on the floor adjacent to the 21 SGFP.</p>	<ul style="list-style-type: none"> • The CREW responds to the plant alarms IAW the appropriate Alarm Response Procedures. - Dispatch an Equipment Operator to investigate the SGFP alarms. 	
<p>The CREW may decide to initiate a power reduction in anticipation of a Feed Pump failure.</p>	<ul style="list-style-type: none"> • The CRS enters and performs the actions of S2.OP-AB.CN-0001, Main Feedwater/ Condensate System Abnormality. • The CREW responds to the SGFP trip IAW S2.OP-AB.CN-0001, Main Feedwater/ Condensate System Abnormality. • The PO responds to the SGFP trip. <ul style="list-style-type: none"> - Maintains 23 S/G level by manually controlling 23BF19 & 23BF40. - Verifies the Turbine Runback is in progress - Ensures the Polisher Bypass valves, 21-23CN108s open. - Ensures the 2CN47, Heater string Bypass Valve opens. • The RO maintains Tavg, AFD and RIL within limits using Control Rod motion and Boration. 	
<p>4. Pressurizer Pressure Channel I fails high.</p>	<p>The Crew will be alerted to the malfunction by the following plant response:</p>	
<p>When the plant is stable, initiate the failure of Pressurizer Pressure Channel I failure, ET-3, malfunction PR0016A at 100%.</p>	<ul style="list-style-type: none"> - RC PRESSURE DEVIATION HI console alarm on CC2. - Both Pzr Spray valves, PS-1 & 2 full open - Actual Pressurizer pressure lowering - OHA E-28, PZR HTR ON PRESS LO 	

EVALUATOR/INSTRUCTOR OR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
-------------------------------------	------------------------------------	----------

NOTE: If pressure control is not regained in a timely manner, a reactor trip will occur at 1865 psig and a Safety Injection at 1765 psig

- The RO responds to the transient by:
 - Comparing pressurizer pressure indications with Pressure Controller output and determining the Pressure Channel I has failed.
 - Place the Master Pressure Controller in Manual.
 - Close both Spray Valves by depressing the Pressure Increase pushbutton.
 - Energize all Pressurizer heaters.

NOTE: If pressure falls below 2205 psig, the LCO for DNB (3.2.5) is applicable.

- The CRS enters and initiates actions IAW S2.OP-AB.PZR-0001, Pressurizer Pressure Malfunction.
- The CRS reviews Tech Specs.
 - 3.3.1.1, Action 6
 - 3.3.2.1, Action 19
 - 3.4.5, Action a

If requested to open the breaker for 2PR6, insert Overrides #3 & #4 (B201-ON) for 2PR6 switch and lamp.

- The CREW notifies I&C of the failure and requests they investigate.

5. Main Steam Leak Inside Containment on 23 S/G.

The Crew will be alerted to the failure by the following initial plant response:

When Pressurizer pressure is stable and the Tech Spec review is sufficient, initiate the Main Steam Line Break at 850K lbm/hr, ramped over 10 min, ET-4, malfunction MS0247C.

- 23 S/G console alarm, FLOW HI
- OHA C38, CFCU LEAK DETECTOR HI
- CC1 console alarm, CONT PRESSURE HI
- Reactor power rising
- Steam flows in all S/Gs rising
- Containment Temperatures & Pressures rising.

EVALUATOR/INSTRUCTOR OR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
-------------------------------------	------------------------------------	----------

When the Crew initiates a MSL Isolation and SI, initiate the Steam Line Rupture by inserting ET-5, malfunction MS0090C.

Critical Task #1: Sat _____
Unsat _____

- The **CREW** should identify the transient as a steam leak inside containment and respond IAW S2.OP-AB.STM-0001, Excessive Steam Flow.

- The **CRS** should direct the plant to be tripped manually IAW S2.OP-AB.STM-0001, Excessive Steam Flow, Attachment 1.

- The **RO** should perform the actions of the Continuous Action Summary as follows:

- Manually trip the Reactor
- Verify the Reactor is tripped by observing at least three PR channels indicate < 5% and IR indications lowering with negative SUR
- Manually initiate Loop 21-24 Main Steam Isolation.
- Manually initiate Safety Injection

- The **CREW** should enter EOP-TRIP-1, Reactor Trip or Safety Injection.
- The **RO** performs the immediate actions of EOP-TRIP-1:
 - Trip the reactor
 - Verify the Reactor is tripped by observing at least three PR channels indicate < 5% and IR indications lowering with negative SUR
 - Trip the Turbine and verify TSV CLOSED and AST OIL PRESS LOW lights illuminated on RP4
 - Verify Vital 4KV Bus status by observing bus voltage > 3900 volts
 - Manually initiate SI

EVALUATOR/INSTRUCTOR OR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
----------------------------------	---------------------------------	----------

(Critical Task # 2: Sat _____
Unsat _____

NOTE: Closing 23AF11 is not critical since 23 AFW Pump is tagged.

- The **PO** should identify 23S/G as Faulted and isolate feed by closing 23AF21 & 23AF11.

- The **CREW** should recognize the failure of 22 Charging Pump to auto start.
- The **PO** should block and reset the C SEC.
- The **RO** should manually start 22 Charging Pump.
- The **PO** should respond to 22 AFW trip by establishing feed to 24 S/G \geq 22E4 lbm/hr using 23 AFW Pump.
- The **CREW** should respond to the trip of 22 AFW Pump IAW the applicable steps of EOP-TRIP-1.

(J. 21 Aux Feedwater Pump trip.

AS SOON AS the minimum flow is established to 24 S/G, initiate the trip of 21 AFW Pump by inserting ET-6, malfunction AF0181A. If 21 AFW pump trip is delayed, S/G level may rise above 15% negating the need for FRHS.

- The **CREW** should recognize the loss of all feed and transition to EOP-FRHS-1, Response to Loss of Secondary Heat Sink at step 20 of EOP-TRIP-1.
- The **CREW** should close Charging Pump mini flow valves 2CV139 & 2CV140 when RCS pressure falls below 1500 psig IAW TRIP-1 CAS.
- The **CREW** should trip all RCPs when RCS pressure falls below 1350 psig IAW TRIP-1 CAS.

EVALUATOR/INSTRUCTOR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
<p>if requested to close the breaker for 2PR6, remove Override #3 (B201-ON) for 2PR6 switch and lamp.</p>	<ul style="list-style-type: none"> • The RO stops all RCPs if Running. • The RO/PO performs valve alignments per EOP-APPX-3, SI Verification. • The RO/PO Reset Safeguards actuations <ul style="list-style-type: none"> - Reset SI - Reset Phase A Isolation - Reset Phase B isolation - Open 21&22CA330 - Reset each SEC - Stop 21 & 22 RHR Pumps - Stop both SI Pumps - Run only 21 or 22 Charging Pump • The CREW selects the S/G with the lowest level for depressurization. • The RO/PO opens the selected MS10, S/G Atmospheric relief, and depressurizes the S/G to below 575 psig. • The RO/PO maintains selected S/G pressure below 575 psig using the MS10. 	
<p>Approximately 4 minutes after the EO is dispatched, report that you are standing by at the selected BF19 & BF40.</p>	<ul style="list-style-type: none"> • The CREW sends an Equipment Operator to locally open Feedwater Reg Valve, BF19 or BF40 for the selected S/G. 	

EVALUATOR/INSTRUCTOR OR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
<p>Critical Task #3: Sat _____ Unsat _____</p>	<ul style="list-style-type: none"> • The CREW coordinates with the Equipment Operator to throttle open the selected BF19 & BF40. 	
<p>NOTE: The critical task is to establish feed to the S/G and encompasses several steps but is placed here for convenience.</p>		
	<ul style="list-style-type: none"> • The RO/PO opens the FW Inlet Stop Valve, BF13 for the selected S/G. • The RO/PO releases the selected S/G BF22 FW Stop-Check Valve. • The RO/PO opens the 21&22CN48, SGFP Bypass Valves. 	
<p>When flow is established to the selected S/G and level is rising, with the concurrence of the Examination team the scenario may be terminated.</p>	<ul style="list-style-type: none"> • The RO/PO closes the 21 & 22BF32, SGFP Suction Valves. 	
<p>After the scenario has been terminated, the CRS should refer to the ECG to Classify the event.</p>	<ul style="list-style-type: none"> • The CRS refers to the ECG and classifies the event: <ul style="list-style-type: none"> – SAE - 3.1.1.B & 3.2.1.B OR 8.1.3.C 	

V. SCENARIO REFERENCES

- A. ES-301, Preparing Initial Operating Tests
- B. K/A Catalog
- C. JTA Listing
- D. Technical Specifications
- E. S2.OP-IO.ZZ-0004
- F. S2.OP-SO.TRB-0001
- G. S2.OP-SO.CVC-0006
- H. S2.OP-SO.RPS-0004
- F. Various Alarm Response Procedures
- G. S2.OP-AB.CN-0001
- I. S2.OP-AB.PZR-0001
- J. S2.OP-AB.STM-0001
- K. 2-EOP-TRIP-1
- L. 2-EOP-FRHS-1

ATTACHMENT 1
UNIT TWO PLANT STATUS TODAY

MODE: 1	POWER: 70%	RCS BORON: 680 ppm	Mwe: 800
---------	------------	--------------------	----------

SHUTDOWN SAFETY SYSTEM STATUS (5, 6 & DEFUELED): N/A

REACTIVITY PARAMETERS: Core Burnup 8000 MWD/MTU

MOST LIMITING LCO AND DATE/TIME OF EXPIRATION:

3.3.3.1 23LT-539 is failed and is out of service for repair.

3.7.1.2 23 AFW Pump is out of service to repair a steam leak on MS132. The 72 hour action expires at 2200 tomorrow.

EVOLUTIONS/PROCEDURES/SURVEILLANCES IN PROGRESS:

Power ascension in progress IAW S2.OP-IO.ZZ-0004.

23 AFW Pump is out of service to repair a steam leak on MS132.

23 S/G Level transmitter LT-539 OOS for repairs.

PLANT TURNOVER IS AS FOLLOWS:

Yesterday, and leak developed on the oil cooler transfer valve for 22 SGFP. The pump was removed from service, the leak repaired and the pump placed back in service.

The orders for the shift are to raise power to 100% at 10%/hr.

ABNORMAL PLANT CONFIGURATIONS: NONE

CONTROL ROOM:

Unit 1 and Hope Creek at 80% power.
No penalty minutes in the last 24 hrs.

PRIMARY: NONE

SECONDARY: Heating Steam is aligned to unit 1.

RADWASTE: No discharges in progress

CIRCULATING WATER/SERVICE WATER:

ATTACHMENT 2 SIMULATOR READY FOR TRAINING CHECKLIST
--

- ___ 1. Verify simulator is in correct load for training
- ___ 2. All required computer terminals in operation
- ___ 3. Simulator clocks synchronized
- ___ 4. Required chart recorders advanced and ON (proper paper installed)
- ___ 5. Rod step counters correct (channel check)
- ___ 6. All tagged equipment properly secured and documented (TSAS Log filled out)
- ___ 7. DL-10 log up-to-date
- ___ 8. Required procedures clean
- ___ 9. All OHA lamps operating (OHA Test)
- ___ 10. All printers have adequate paper AND functional ribbon
- ___ 11. Procedure pens available
- ___ 12. Procedures in progress open and signed-off to proper step
- ___ 13. Shift manning sheet available
- ___ 14. SPDS reset
- ___ 15. Reference verification performed with required documents available
- ___ 16. Ensure a current RCS Leak Rate Worksheet is placed by Aux Alarm Typewriter with Baseline Data filled out
- ___ 17. Required keys available
- ___ 18. Video Tape (if applicable)
- ___ 19. Ensure ECG Classification is correct – 960502140 CRCA-03
- ___ 20. Reset P-250 Rod Counters

ATTACHMENT 3 CRITICAL TASK METHODOLOGY

In reviewing each proposed CT, the examination team assesses the task to ensure, that it is essential to safety. A task is essential to safety if, in the judgement of the examination team, the improper performance or omission of this task by a licensee will result in direct adverse consequences or in significant degradation in the mitigative capability of the plant.

The examination team determines if an automatically actuated plant system would have been required to mitigate the consequences of an individual's incorrect performance. If incorrect performance of a task by an individual necessitates the crew taking compensatory action that would complicate the event mitigation strategy, the task is safety significant.

1. Examples of CTs involving essential safety actions include those for which operation or correct performance prevents...
 - degradation of any barrier to fission product release
 - degraded emergency core cooling system (ECCS) or emergency power capacity
 - a violation of a safety limit
 - a violation of the facility license condition
 - incorrect reactivity control (such as failure to initiate Emergency Boration or Standby Liquid Control, or manually insert control rods)
 - a significant reduction of safety margin beyond that irreparably introduced by the scenario
2. Examples of CTs involving essential safety actions include those for which a crew demonstrates the ability to...
 - effectively direct or manipulate engineered safety feature (ESF) controls that would prevent any condition described in the previous paragraph.
 - recognize a failure or an incorrect automatic actuation of an ESF system or component.
 - take one or more actions that would prevent a challenge to plant safety.
 - prevent inappropriate actions that create a challenge to plant safety (such as an unintentional Reactor Protection System (RPS) OR ESF actuation.

ATTACHMENT 4
SCENARIO REVIEW CHECKLIST

Note: Attach a separate copy of this form to each scenario reviewed. This form is used as guidance for the examination team as they conduct their review for the proposed scenarios.

SCENARIO IDENTIFIER:

REVIEWER:

Initials

Qualitative Attributes

- | | |
|---|---|
| <p>_____ 1.</p> <p>_____ 2.</p> <p>_____ 3.</p> <p>_____ 4.</p> <p>_____ 5.</p> <p>_____ 6.</p> <p>_____ 7.</p> <p>_____ 8.</p> <p>_____ 9.</p> <p>_____ 10.</p> <p>_____ 11.</p> | <p>The scenario has clearly stated objectives in the scenario.</p> <p>The initial conditions are realistic, in that some equipment and/or instrumentation may be out of service, but it does not cue crew into expected events.</p> <p>The scenario consists mostly of related events.</p> <p>Each event description consists of--</p> <ul style="list-style-type: none"> • the point in the scenario when it is to be initiated • the malfunction(s) that are entered to initiate the event • the symptoms/cues that will be visible to the crew • the expected operator actions (by shift position) • the event termination point <p>No more than one non-mechanistic failure (e.g., pipe break) is incorporated into the scenario without a credible preceding incident such as a seismic event.</p> <p>The events are valid with regard to physics and thermodynamics.</p> <p>Sequencing/timing of events is reasonable, and allows for the examination team to obtain complete evaluation results commensurate with the scenario objectives.</p> <p>The simulator modeling is not altered.</p> <p>All crew competencies can be evaluated.</p> <p>The scenario has been validated.</p> <p>If the sampling plan indicates that the scenario was used for training during the Initial Training Program, evaluate the need to modify or replace the scenario.</p> |
|---|---|

ATTACHMENT 5
ESG – CRITICAL TASKS

CT#1 – CRS orders MANUAL Rx Trip, Main Steam Line isolation and SI in response to the Main Steam Line rupture IAW S2.OP-AB.STM-0001, Attachment 1, Continuous Action Summary. (E-0--A)

CT#2 – Isolate feed to the Faulted S/G. (E-2--A)

CT#3 – Establish feed flow to at least one S/G using the Condensate System. (E-0--F)

Facility: Salem Units 1 & 2

Scenario No.: 3

Op Test No.: D3

Examiners: _____

Candidates: _____ CRS

_____ RO

_____ PO

Objectives: Evaluate the ability of the crew to perform a normal power ascension. The RO should recognize and respond to the inappropriate rod motion caused by PT-505 output failure during the power ascension. Evaluate the response of the crew to the failure of 22 S/G Pressure transmitter, PT-526A. Evaluate the ability of the crew to recognize and respond to a Fuel Element Failure. Evaluate the ability of the crew to respond to a S/G tube failure and their ability to implement the EOPs. Evaluate the ability of the crew to recognize and respond to the trip of 22 Aux Feedwater Pump. The PO should recognize the loss of the Steam Dumps and control S/G pressure with manual operation of the MS10.

Initial Conditions: IC-4 at 90% power. 23 S/G Feed Flow transmitter, FT-510 out of service for I & C testing.

Turnover: The plant is in Mode 1 with power at 90%. All equipment is operating normally with all controls in automatic. Orders for the shift are to continue the power ascension to 100% at 10% per hour.

Event No.	Malf. No.	Event Type*	Event Description
1		N CRS R PO R RO	Perform a normal power ascension.
2	RD0045	I CRS RO	The Output of PT505 fails causing rods to insert at maximum speed (72 spm)
3	SG0129B	I CRS PO	22 S/G Pressure transmitter, PT-526A fails high
4	CV0040	C CRS RO	Fuel Element failure
5	SG0078B	M All	22 SG Tube Leak/Rupture
6	AF0181B	C CRS PO	22 Aux Feedwater Pump trip
7	MS0093	I CRS PO	Loss of Steam Dump Vacuum permissive

* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor

SCENARIO SUMMARY

This scenario begins with an ascension to 100% power. When the power ascension has progressed to the satisfaction of the Examination Team, the output of PT-505 will fail causing control rods to be inserted at the maximum speed of 72 spm. The RO should recognize the failure, take Rod Control to Manual and stabilize Tave. The crew should enter and take the actions of S2.OP-AB.ROD-0003.

After the investigation of the rod speed failure has been initiated, 22 S/G Pressure Transmitter, PT-526A will fail high causing 22 S/G Atmospheric Dump Valve, 22MS10 to shift to manual. The PO should identify the failure and discuss the implications with the crew. After a short time for the PT-526A failure discussion, a fuel element failure will occur as a small leak at first and then degrade over time. The crew should recognize the Fuel Failure, enter and take the actions of S2.OP-AB.RC-0002, High Activity in the Reactor Coolant and S2.OP-AB.RAD-0001, Abnormal Radiation.

The major event is a Steam Generator Tube Leak. The crew will enter and perform the actions of S2.OP-AB.SG-0001, Steam Generator Tube Leak. The leak will eventually degrade requiring a manual Reactor Trip and Safety Injection and implementation of the EOPs. While performing actions of EOP-TRIP-1, Reactor Trip or Safety Injection, 22 Aux Feedwater Pump will trip. The PO should respond by maintaining S/G levels using 23 Aux Feedwater Pump. The crew should progress through the EOPs as follows:

1. Perform EOP-TRIP-1 and transition to EOP-SGTR-1, Steam Generator Tube Rupture at Step 27.
2. After transitioning to EOP-SGTR-1, the Steam Dump Vacuum Permissive will be lost causing all Steam Dump Valves to close. The PO should control S/G pressures with the Atmospheric Relief Valves controlling 22MS10 in manual.
3. When the steps for SI termination (Step 25) have been initiated and with the concurrence of the Examination Team, the scenario may be terminated.

SIMULATOR EXAM SCENARIO

SCENARIO TITLE: SGTR
SCENARIO NUMBER: 3-D3
EFFECTIVE DATE: 2/22/99
EXPECTED DURATION: 1.5 Hours
REVISION NUMBER: 0


PROGRAM:



LO REQUAL



INITIAL LICENSE



STA



OTHER _____

Revision Summary: Rev 0

PREPARED BY: _____
M. Sanchuan
(WD ASSOCIATES)

1/21/99
(DATE)

APPROVED BY: _____
(TRAINING SUPERVISOR)

(DATE)

APPROVED BY: _____
(TRAINING SUPERVISOR)

(DATE)

I. OBJECTIVES

- A. Evaluate the ability of the crew to implement normal plant procedures to raise plant power to 100% of Rated Thermal Power.
- B. The crew should recognize and respond to the inappropriate rod motion caused by PT-505 output failure during the power ascension.
- C. Evaluate the response of the crew to the failure of 22 S/G Pressure transmitter, PT-526A.
- D. Evaluate the ability of the crew to recognize and respond to a Fuel Element Failure.
- E. Evaluate the ability of the crew to respond to a S/G tube failure and their ability to implement the EOPs.
- F. Evaluate the ability of the crew to recognize and respond to the failure of 22 Aux Feedwater Pump.
- G. The PO should recognize the loss of the Steam Dumps and control S/G pressure and cooldown rate with manual operation of the MS10.

II. MAJOR EVENTS

- A. Perform a power ascension to 100 % power.
- B. The output of PT-505 fails high causing rods to insert at maximum rod speed (72 spm)
- C. 22 S/G Pressure transmitter, PT-526A fails high
- D. Fuel Element failure
- E. 22 SG Tube Leak/Rupture
- F. 22 Aux Feedwater Pump trip
- G. Loss of Steam Dump Vacuum permissive

III. SCENARIO SUMMARY

- A. The crew will assume the watch with the plant in Mode 1 at 90% power. Directions to the shift are to continue the power ascension to 100% at 10% per hour. All controls are in automatic and all equipment is operating normally with the following exceptions:
- 23 S/G Feed Flow transmitter, FT-531A is out of service for I&C testing.
- B. When the power ascension has progressed to the satisfaction of the Examination Team, the output of PT-505 will fail causing control rods to be inserted at the maximum speed of 72 spm. The RO should recognize the failure, take Rod Control to Manual and stabilize Tave. The crew should enter and take the actions of S2.OP-AB.ROD-0003.
- C. After the investigation of the inappropriate rod motion has been initiated, 22 S/G Pressure Transmitter, PT-526A will fail high causing 22 S/G Atmospheric Dump Valve, 22MS10 to shift to manual. The PO should identify the failure and discuss the implications with the crew.
- D. After a short delay for the PT-526A failure discussion, a fuel element failure will occur as a small leak at first and then degrade over time. The crew should recognize the Fuel Failure, enter and take the actions of IAW S2.OP-AB.RC-0002, High Activity in the Reactor Coolant and S2.OP-AB.RAD-0001, Abnormal Radiation.
- E. The major event is a Steam Generator Tube Leak. The crew will enter and perform the actions of S2.OP-AB.SG-0001, Steam Generator Tube Leak. The leak will eventually degrade requiring a manual Reactor Trip and Safety Injection and implementation of the EOPs.
- F. While performing actions EOP-TRIP-1, Reactor Trip or Safety Injection, 22 Aux Feedwater Pump will trip. The crew should respond by controlling S/G levels with 23 Aux Feedwater Pump.
- G. The crew should progress through TRIP-1, Reactor Trip or Safety Injection and transition to EOP-SGTR-1, Steam Generator Tube Rupture at Step 27.
- H. After transitioning to EOP-SGTR-1, Steam Generator Tube Rupture the Steam Dump Vacuum Permissive will be lost causing all Steam Dump Valves to close. The PO should control S/G pressures with the Atmospheric Relief Valves, controlling 22MS10 in manual.
- I. When the actions for SI termination (Step 25) have been initiated and with the concurrence of the Examination Team, the scenario may be terminated.

IV. INITIAL CONDITIONS

IC-2 or IC-90 from the ESG disk, MOL at 90% power with the following conditions:

- a. 23 S/G Feed Flow transmitter, FT-531 is out of service for I&C testing.

MALFUNCTIONS					
	Malfunction	Severity	Delay	Ramp	Description
___1.	SG097C	0	0	0	23 S/G FF xmtr (FT531) CH II fail low
___2.	RD0045	N/A	N/A	N/A	Uncontrolled Rod Insertion in AUTO (ET-1)
___3.	SG0129B	100	0	0	22 S/G Pressure, PT-526A fails high (ET-2)
___4.	CV0040	25 pins	0	0	Fuel Element failure (ET-3)
___5.	SG0078B	60 gpm	0	5 min	22 S/G tube Leak (ET-4)
___6.	AF0181B	0	0	0	22 Aux Feedwater Pump trip (ET-5)
___7.	MS0093	0	0	0	Loss of steam Dump vacuum permissive (ET-6)

I/O OVERRIDES						
	Override/Type	SER Pt.	DI	DO	Condition	Description
___1.	None					

REMOTES			
	Remote/Type	Condition	Description
___1.	AF25D	OFF	22 AFW Pump control power OFF

TAGGED EQUIPMENT	
	Description

___1. Red Stripe FT-531

IV. SEQUENCE OF EVENTS

- A. Designate shift positions.
- B. Conduct a shift briefing outlining the shift instructions to the crew. (Provide each crew member with a copy of the Shift Turnover Sheet)
- C. Inform the crew " The simulator is running and that board walk-downs should be performed. CRS please inform me when your Crew is ready to assume the shift.".
- D. Allow sufficient time for panel walk-downs. When informed by the CRS that the Crew is ready to assume the shift, ensure the simulator is cleared of unauthorized personnel.

EVALUATOR/INSTRUCTOR OR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
<p>Power ascension using normal plant procedures.</p> <div style="border: 1px solid black; padding: 5px; width: fit-content;"> <p>No malfunctions other than those already inserted to start the scenario. The crew will raise load at 10% per hr until 100% power or the output of PT-505 fails.</p> </div>	<ul style="list-style-type: none"> • The CREW commences a power ascension IAW Step 5.2 of S2.OP-IO.ZZ-0004, Power Operations. <ul style="list-style-type: none"> - Notify the Systems Operator and the Condensate Polishing Operator of the upcoming power ascension. • The PO raises Turbine load IAW S2.OP-SO.TRB-0001, Turbine Generator Startup Operations. <ul style="list-style-type: none"> - Initiates monitoring the Main Turbine Data display points on the Plant Computer. - Monitor Turbine parameters IAW S2.OP-SO.TRB-0001, Attachment 2. - Uses the REF and GO pushbuttons to attain desired load. - Monitor condenser ΔT Limits • The RO maintains AFD within the target band using Auto Rod motion and Dilution. • The RO Maintains T_{AVG}/T_{REF} mismatch at minimum value with Auto Rod motion and dilution. • The RO adjusts RCS Boron concentration to maintain Tavg and AFD using S2.OP-SO.CVC-0006, Boron Concentration Control. <ul style="list-style-type: none"> - DEPRESS Makeup Control Mode Select STOP Pushbutton. - SET Primary Water Flow Register to the number of gallons desired. - DEPRESS Makeup Control Mode Select DILUTE Pushbutton. - DEPRESS Makeup Control Mode Select START Pushbutton. 	

EVALUATOR/INSTRUCTOR OR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
	<ul style="list-style-type: none"> - When dilution is complete, depress Makeup Control Mode Select STOP Pushbutton. - DEPRESS Makeup Control Mode Select AUTO Pushbutton. - DEPRESS Makeup Control Mode Select START Pushbutton. 	
<p>2. Output of PT-505 fails (Blown Fuse).</p>	<ul style="list-style-type: none"> • The RO should recognize the inappropriate rod motion and place Rod Control in manual. 	
<p>When the power ascension has progressed to the satisfaction of the examination team, insert ET-1, malfunction RD0045 to cause continuous rod insertion at 72 spm.</p>	<ul style="list-style-type: none"> • The CREW should terminate the power ascension and stabilize the plant. • The CRS should enter and take the actions of S2.OP-AB.ROD-0003, Continuous Rod Motion. 	
	<ul style="list-style-type: none"> • The RO should adjust Tavg to within 1.5°F of program using manual rod motion. 	
<p>NOTE: This malfunction does not affect PT505 indication on CC3. The crew may recognize the failed input to Steam Dumps and place the dumps in MS Pressure Control Mode IAW S2.OP-AB.ROD-0003.</p>	<ul style="list-style-type: none"> • The CREW should investigate the cause and identify the following affects of the transient and request I&C to investigate: <ul style="list-style-type: none"> - RC LOOP TAVE-TREF DEVIATION CC2 console alarm. - TAVE-TREF Recorder indicates full upscale - Full demand on steam Dump Controller 	

EVALUATOR/INSTRUCTOR OR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
<p>PT-526A, 22 S/G Pressure transmitter fails high.</p>	<p>The Crew will be alerted to the failure by the following plant response:</p>	
<p>When I&C has been requested to investigate inappropriate rod motion, initiate the failure of PT-526A by inserting ET-2, malfunction SG129B.</p>	<ul style="list-style-type: none"> - OHA G7, ADFCS SWAP TO MANUAL - OHA G15, ADFCS TROUBLE • The CREW should respond to the alarms IAW appropriate Alarm Response Procedures. 	
<p>SIM OP NOTE: One (1) min after Event 3 has been initiated, initiate the fuel failure by inserting ET-3, malfunction CV0040 at 25 pins to allow activity to build up for the next event.</p>	<ul style="list-style-type: none"> • The PO should scan the boards and determine PT-526A, 22 S/G Pressure transmitter has failed and 22MS10, 22 S/G Atmospheric Relief Valve shifted to manual by the blue manual light illuminated. 	
<p>4. Fuel Element Failure</p>	<p>The Crew will be alerted to the failure by the following plant response:</p>	
<p>The first alarm will be a WARNING on 2R31 and will occur approximately 14 min after inserting ET-3, malfunction CV0040.</p>	<ul style="list-style-type: none"> - OHA A-6, RMS TROUBLE - Radiation levels will begin to increase on the following monitors: 	
	<ul style="list-style-type: none"> ○ Letdown line monitor, 2R31 ○ Reactor Coolant Filter, 2R26 ○ Seal Water Injection Filter, 2R24A(B) ○ Seal Water Return Filter, 2R25 ○ Containment, 2R2 	
	<ul style="list-style-type: none"> • The CREW should respond to the alarms IAW the appropriate Alarm Response Procedures. 	
	<ul style="list-style-type: none"> • The CRS should enter and take the actions of S2.OP-AB.RAD-0001, Abnormal Radiation. 	
	<ul style="list-style-type: none"> - Direct an announcement be made to warn personnel of the abnormal radiation condition. 	

EVALUATOR/INSTRUCTOR OR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
<p>When directed to take samples, request primary sample valves to be opened .</p>	<ul style="list-style-type: none"> • The CRS should initiate Attachment 1, of S2.OP-AB.RAD-0001, when it is determined that R31 rad level is rising or is in alarm. • The CRS should enter and take the actions of S2.OP-AB.RC-0002, High Activity in the Reactor Coolant. <ul style="list-style-type: none"> - Request chemistry to sample the RCS for activity. - Request Radiation Protection to initiate surveys of the plant. - Review Tech Specs. 	
<p>Five minutes after primary sample valves are opened, report as Chemistry Technician that the results of the sample will take about an hour but sample sink radiation levels were ten (10) times normal indicating a significant fuel failure and Maximum Letdown Flow is recommended.</p>	<ul style="list-style-type: none"> • The RO places a Centrifugal Charging Pump in service: <ul style="list-style-type: none"> - Ensure Charging Master Flow Controller in AUTO - Close 2CV55, Charging Flow Control Valve - Place 23 Charging Pump Speed Controller in MANUAL - While lowering 23 Charging Pump speed to minimum, Adjust 2CV55 to maintain desired flow. - WHEN 23 Charging Pump is at minimum flow, Stop 23 Charging Pump. - Adjust 2CV55 to obtain desired flow - Place 2CV55 in AUTO. • The RO raises Letdown flow to maximum: <ul style="list-style-type: none"> - Control Letdown pressure at 300 psig using manual control of 2CV18, Non-Regen Hx Outlet Valve. - Open 2CV3, 45 gpm orifice. - Return 2CV18 to auto. 	

EVALUATOR/INSTRUCTOR OR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
<p>7. 22 S/G Tube Leak</p> <p>When Letdown flow has been maximized, initiate: 22 S/G tube leak by inserting ET-4, MALF SG0078B at 60 gpm, ramped over 5 min.</p>	<p>The Crew will be alerted to the failure by the following plant response:</p> <ul style="list-style-type: none"> - OHA E-28 PRZ HTR ON PRESS LOW - OHA A06 RMS TROUBLE - Rising level, Warning or Alarm on the following Rad Monitors: <ul style="list-style-type: none"> ▪ R19B, S/G Blowdown ▪ R46A-E, Main Stm Line ▪ R53A-D, Main Stm Line N16 ▪ R15, Cond Air Ejector Monitor ▪ R40, Cond Polishing Filter - Pressurizer low level console alarm - SER point 222, Pressurizer Heater On Pressure Low - Actual Pzr level will lower - Charging flow will rise <ul style="list-style-type: none"> • The CREW should respond to the alarms IAW the appropriate Alarm Response Procedures. • The CRS should enter and take the actions of S2.OP-AB.SG-0001, S/G Tube Leak. • The CRS should enter and take the actions of S2.OP-AB.RAD-0001, Abnormal radiation. • The CREW should identify 22 S/G as the affected S/G by: <ul style="list-style-type: none"> - Rising level on 2R19B - Rising level on 2R53 B • The CREW should notify Chemistry: • The CREW should notify Radiation Protection to survey the main Steam lines. • The CRS should notify the operations Manager and commence a Reactor Shutdown IAW AB-LOAD. 	

EVALUATOR/INSTRUCTOR OR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
----------------------------------	---------------------------------	----------

3. S/G Tube Rupture

When the decision to shut down the plant has been made, raise the tube leak to maximum by changing SG0078B to 600 gpm.

The crew will be alerted to the increased leak rate by the following plant response:

- Pressurizer level lowering rapidly
- OHA E-28 PRZ HTR ON PRESS LOW
- Pressurizer low level console alarm
- SER point 222, Pressurizer Heater On
- Pressure Low
- Charging flow will rise

- The **CREW** should recognize the change in leak rate and perform the following actions IAW S2.OP-AB.SG-0001, Steam Generator Tube Leak, Attachment 1, Continuous Action Summary.

Critical Step # 1: Sat _____
Unsat _____

- Initiate a Manual Reactor trip.
- Verify the Reactor is tripped by observing at least three PR channels indicate < 5% and IR indications lowering with negative SUR
- Initiate a Manual Safety Injection

- The **CREW** should enter and perform the actions of EOP-TRIP-1, Reactor Trip or Safety Injection Response.

- The **RO** performs the immediate actions of EOP-TRIP-1:

- Trip the reactor
- Verify the Reactor is tripped by observing at least three PR channels indicate < 5% and IR indications lowering with negative SUR
- Trip the Turbine and verify TSV CLOSED and AST OIL PRESS LOW lights illuminated on RP4
- Verify Vital 4KV Bus status by observing bus voltage > 3900 volts
- Manually initiate SI

EVALUATOR/INSTRUCTOR OR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
----------------------------------	---------------------------------	----------

Critical Step #2: Sat _____
 (Part 1 of 2) **Unsat** _____

- The **PO** should isolate Aux Feed Flow to 22 S/G by closing 22AF11 and 22AF21.
- The **PO** should reduce total Aux Feed Flow to $\geq 22E4$ lbm/hr.

7. 22 Aux Feed Pump Trip

The Crew will be alerted to the failure by the following plant response:

Five minutes after minimum AFW flow is established, initiate 22AFW Pump trip by inserting ET-5, malfunction AF0181B.

- Console alarm on 2CC2
- Flashing STOP indication for 22 AFW Pump
- Flow indication to 21 & 22 S/G falls to zero

If the Control Room requests control power removed from 22 AFW Pump, insert Remote AF25D to OFF.

Critical Step # 3: Sat _____
Unsat _____

- The **PO** should respond by feeding 21 S/G with 23 AFW Pump:
 - Raise 23 AFW Pump speed
 - Throttle the AF11s to maintain total AFW Flow $\geq 22E4$ lbm/hr and then maintain S/G levels 9-33%.

- The **CREW** performs EOP-TRIP-1 actions and transitions to EOP-SGTR-1, Steam Generator Tube Rupture at Step 27 when level in 22 S/G is observed rising in an uncontrolled manner.

Since Auto mode is failed, 22MS10 setpoint adjustment may not be performed.

- The **PO** should control pressure below 1045 psig to prevent opening the S/G Safeties by manual operation of 22MS10.

Critical Step #2: Sat _____
 (Part 2 of 2) **Unsat** _____

- The **PO** closes the following valves:
 - 22MS167, Main Steam Isolation Valve
 - 22MS18, Main Steam Line Warmup Vlv
 - 22MS7, MSL Drain Isolation Valve
 - 22GB4, S/G Blowdown Isolation Valve

EVALUATOR/INSTRUCTOR OR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
----------------------------------	---------------------------------	----------

- The **CREW** dispatches an Equipment Operator to align Secondary valves.
- The **RO/PO** performs Safeguards Reset actions:
 - Reset SI
 - Reset Phase A Isolation
 - Reset Phase B isolation
 - Open 21&22CA330
 - Reset each SEC
 - Stop 21 & 22 RHR Pumps
 - Stop both SI Pumps
 - Run only 21 or 22 Charging Pump
- The **RO** stops 21 & 22 RHR Pumps.
- The **CRS** determines the Required RCS Cooldown Temperature IAW Table D. C/D Temp_____
- The **PO** initiates an RCS Cooldown:
 - Place Steam Dumps in Manual
 - Adjusts Stm Pressure Demand to 0%
 - Selects MS Press Control
 - Adjusts Stm Press Valve Demand to 25%

8. Loss of Steam Dump Vacuum Permissive.

The Crew will be alerted to the failure by the following plant response:

When the cooldown has been initiated, insert ET-6, malfunction MS0093 to cause a loss of Steam Dump Vacuum Permissive.

- The closure of all Steam Dump valves
- The CNDSR VAC permissive light on RP4 extinguishes.

EVALUATOR/INSTRUCTOR OR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
----------------------------------	---------------------------------	----------

Critical Step #4: Sat _____
 Unsat _____

- The CREW responds IAW appropriate steps of EOP-SGTR-1, cooling down using the S/G Atmospheric Relief Valves, 21, 23 & 24MS10s
- The PO places 21, 23 & 24MS10 in manual and fully opens the valves.
- The PO maintains RCS temperature no more than 5°F above the Target Temperature of _____ °F by throttling the MS10s.

When the desired RCS temperature is reached and with the concurrence of the Examination Team, the scenario may be terminated.

After the scenario has been terminated, the CRS should refer to the ECG to Classify the event.

- The CRS refers to the ECG and classifies the event:
 - Alert - 3.2.3.A

V. SCENARIO REFERENCES

- A. ES-301, Preparing Initial Operating Tests
- B. K/A Catalog
- C. JTA Listing
- D. Technical Specifications
- E. S2.OP-IO.ZZ-0004
- F. S2.OP-SO.TRB-0001
- G. S2.OP-SO.CVC-0006
- H. Various Alarm Response Procedures
- I. S2.OP-AB.ROD-0003
- J. S2.OP-SO.RPS-0006
- K. S2.OP-AB.RAD-0001
- L. S2.OP-AB.RC-0002
- M. S2.OP-AB.SG-0001
- N. 2-EOP-TRIP-1
- O. 2-EOP-SGTR-1

ATTACHMENT 1
UNIT TWO PLANT STATUS TODAY

MODE: 1	POWER: 90%	RCS BORON: 105 ppm	Mwe: 1000
---------	------------	--------------------	-----------

SHUTDOWN SAFETY SYSTEM STATUS (5, 6 & DEFUELED): N/A

REACTIVITY PARAMETERS: Core Burnup 8000 MWD/MTU

MOST LIMITING LCO AND DATE/TIME OF EXPIRATION:

EVOLUTIONS/PROCEDURES/SURVEILLANCES IN PROGRESS:

I&C functional testing of 23 S/G Feed Flow transmitter, FT-531A.

PLANT TURNOVER IS AS FOLLOWS:

The orders for the shift are to raise power to 100% at 10%/hr.

ABNORMAL PLANT CONFIGURATIONS: NONE

CONTROL ROOM:

Unit 1 and Hope Creek at 80% power.
No penalty minutes in the last 24 hrs.

PRIMARY: NONE

SECONDARY: Heating Steam is aligned to unit 1.

RADWASTE: No discharges in progress

CIRCULATING WATER/SERVICE WATER:

ATTACHMENT 2 SIMULATOR READY FOR TRAINING CHECKLIST
--

- ___ 1. Verify simulator is in correct load for training
- ___ 2. All required computer terminals in operation
- ___ 3. Simulator clocks synchronized
- ___ 4. Required chart recorders advanced and ON (proper paper installed)
- ___ 5. Rod step counters correct (channel check)
- ___ 6. All tagged equipment properly secured and documented (TSAS Log filled out)
- ___ 7. DL-10 log up-to-date
- ___ 8. Required procedures clean
- ___ 9. All OHA lamps operating (OHA Test)
- ___ 10. All printers have adequate paper AND functional ribbon
- ___ 11. Procedure pens available
- ___ 12. Procedures in progress open and signed-off to proper step
- ___ 13. Shift manning sheet available
- ___ 14. SPDS reset
- ___ 15. Reference verification performed with required documents available
- ___ 16. Ensure a current RCS Leak Rate Worksheet is placed by Aux Alarm Typewriter with Baseline Data filled out
- ___ 17. Required keys available
- ___ 18. Video Tape (if applicable)
- ___ 19. Ensure ECG Classification is correct – 960502140 CRCA-03
- ___ 20. Reset P-250 Rod Counters

ATTACHMENT 3 CRITICAL TASK METHODOLOGY

In reviewing each proposed CT, the examination team assesses the task to ensure, that it is essential to safety. A task is essential to safety if, in the judgement of the examination team, the improper performance or omission of this task by a licensee will result in direct adverse consequences or in significant degradation in the mitigative capability of the plant.

The examination team determines if an automatically actuated plant system would have been required to mitigate the consequences of an individual's incorrect performance. If incorrect performance of a task by an individual necessitates the crew taking compensatory action that would complicate the event mitigation strategy, the task is safety significant.

1. Examples of CTs involving essential safety actions include those for which operation or correct performance prevents...
 - degradation of any barrier to fission product release
 - degraded emergency core cooling system (ECCS) or emergency power capacity
 - a violation of a safety limit
 - a violation of the facility license condition
 - incorrect reactivity control (such as failure to initiate Emergency Boration or Standby Liquid Control, or manually insert control rods)
 - a significant reduction of safety margin beyond that irreparably introduced by the scenario
2. Examples of CTs involving essential safety actions include those for which a crew demonstrates the ability to...
 - effectively direct or manipulate engineered safety feature (ESF) controls that would prevent any condition described in the previous paragraph.
 - recognize a failure or an incorrect automatic actuation of an ESF system or component.
 - take one or more actions that would prevent a challenge to plant safety.
 - prevent inappropriate actions that create a challenge to plant safety (such as an unintentional Reactor Protection System (RPS) OR ESF actuation.

ATTACHMENT 4 SCENARIO REVIEW CHECKLIST

Note: Attach a separate copy of this form to each scenario reviewed. This form is used as guidance for the examination team as they conduct their review for the proposed scenarios.

SCENARIO IDENTIFIER:	REVIEWER:
-----------------------------	------------------

Initials

Qualitative Attributes

- | | |
|--|--|
| _____

_____ | 1. The scenario has clearly stated objectives in the scenario.
2. The initial conditions are realistic, in that some equipment and/or instrumentation may be out of service, but it does not cue crew into expected events.
3. The scenario consists mostly of related events.
4. Each event description consists of-- <ul style="list-style-type: none"> • the point in the scenario when it is to be initiated • the malfunction(s) that are entered to initiate the event • the symptoms/cues that will be visible to the crew • the expected operator actions (by shift position) • the event termination point 5. No more than one non-mechanistic failure (e.g., pipe break) is incorporated into the scenario without a credible preceding incident such as a seismic event.
6. The events are valid with regard to physics and thermodynamics.
7. Sequencing/timing of events is reasonable, and allows for the examination team to obtain complete evaluation results commensurate with the scenario objectives.
8. The simulator modeling is not altered.
9. All crew competencies can be evaluated.
10. The scenario has been validated.
11. If the sampling plan indicates that the scenario was used for training during the Initial training Program, evaluate the need to modify or replace the scenario. |
|--|--|

ATTACHMENT 5 ESG – CRITICAL TASKS
--

CT#1 – Manually trip the Reactor and initiate Safety Injection (E-0--D)

CT#2 – Isolate feed to and steam from the Ruptured S/G (E-3--A)

CT#3 – Establish the min required Aux Feed Flow prior to transition out of EOP-TRIP-1. (E-0--F)

CT#4 – Cooldown the RCS and maintain temperature (E-3--B)

Facility: Salem Units 1 & 2

Scenario No.: 4

Op Test No.: D4

Examiners: _____

Candidates: _____ CRS

RO

PO

Objectives: Evaluate the ability of the crew to perform a normal power reduction to 75% power. Evaluate the ability of the crew to perform a rapid power reduction. The crew should recognize and respond to the failure of control bank rod D3 to insert during the power reduction. Evaluate the response of the crew to the failure of 21 S/G Feed Flow Transmitter, FT-511 and the automatic transfer of Feedwater Reg Valves 21BF19 & 40 to manual. The crew should recognize and respond to the failure of the LT-459, Pressurizer Level failing low. Evaluate the ability of the crew to recognize and respond to the Main Turbine Lube Oil leak, failure of the Main Turbine Aux Oil Pump to auto start and subsequent abnormal vibrations on the Main Turbine. Evaluate the ability of the crew to recognize and respond to the failure of the Reactor and to implement the EOPs. Evaluate the ability of the crew to recognize the loss of all AC and to properly transition to the LOPA series EOPs.

Initial Conditions: IC-2 at 100% power with 21 S/G Feed Flow transmitter FT-510 out of service for circuit board replacement.

Turnover: The plant is in Mode 1 with power at 100%. 21 S/G Feed Flow transmitter FT-510 out of service for circuit board replacement. All other equipment is operating normally with all controls in automatic. Orders for the shift are to reduce power to 75% to remove 22 Condensate Pump from service for seal replacement.

Event No.	Malf. No.	Event Type*	Event Description
1		N CRS N PO N RO	Perform a normal power reduction
2		R ALL	Rapid power reduction
3	RD0065	C CRS RO	Control Bank Rod D3 fails to insert
4	SG0097A	I CRS PO	21 S/G Feed Flow transmitter FT-511 fails low.
5	PR017A	I CRS RO	LT-459, Pressurizer Level fails low
6	TU0075 TU0083A /B TA0306A	C CRS PO	MTLO Leak - Ramped from 0-90% over a 10 minute period Main Turbine high vibration Main Turbine Aux Bearing Oil Pump fails to auto start
7	RP0058 RP0059A	M ALL	Failure of the Reactor to Trip (Auto & Manual)
8	EL0134 EL0162 EL0146 EL0273A IO2ADD	M ALL	Loss of All AC Power 2B DG Trip 2C 4KV Bus Differential 2A DG Bkr fail to Auto Close 2A DG Bkr Trip upon Closure

* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor

Salem299_O_Scen-4

Modified: 1/20/99

Last printed 01/23/99 6:14 PM

Page 1 of 2

SCENARIO SUMMARY

The scenario begins with a normal power reduction to remove 22 Condensate Pump from service for shaft seal replacement. When the normal power reduction has progressed sufficiently, a report from the systems operator will require a rapid power reduction IAW S2.OP-AB.GRID-0001, Grid Disturbance. During the power reduction, Control Bank Rod D3 will fail to insert. The crew should enter and take the actions of S2.OP-AB.ROD-0001, Misaligned/Immovable Rod and continue the power reduction IAW S2.OP-AB.GRID-0001.

21 S/G Feed Flow Transmitter, FT-511 will fail low causing 21 S/G Feedwater Reg Valves 21BF19 and 21BF 40 to shift to manual. After a short delay to allow conditions to stabilize, Pressurizer Level Transmitter FT-459 will fail low. This will raise charging flow and cause actual Pressurizer level to rise. The RO should take the Master Level Controller to manual and stabilize pressurizer level. The crew should take the actions of Annunciator Response Procedure S2.OP-AR.ZZ-0005 for OHA E-36, PZR HTR OFF LVL LO.

When Pressurizer level has been stabilized, a leak will occur in the Main Turbine Lube Oil System at the discharge of the shaft driven pump. All oil will be retained in the system by the guard pipe. The PO should recognize the failure of the Aux Bearing Oil Pump to auto start and respond by manually starting the pump to terminate the low oil pressure problem. When the lube oil leak is initiated, a Main Turbine high vibration will also be initiated that will gradually degrade to the point where a manual trip is required.

The major event will be a failure of the Reactor to trip. The crew should implement the EOPs, enter and take the actions of EOP-TRIP-1, Reactor Trip or Safety Injection.

The crew should perform EOP-TRIP-1 and transition to EOP-FRSM-1, Response to Nuclear Power Generation at Step 2.2

The crew will perform the actions of EOP-FRSM-1. When Rapid Boration actions of Step 3 are complete, a Loss of All AC Power will occur, terminating the ATWS. The crew will complete the actions of EOP-FRSM-1 and transition to EOP-LOPA-1, Loss of All AC Power at Step 17.

The crew will perform actions of EOP-LOPA-1. When SI Actuation and Reset actions of Steps 21-23 have been initiated, a Diesel Generator will become available. The crew should respond IAW Continuous Action Step 14 and restore power to the 4kV bus. When power is restored and with the concurrence of the Examination Team, the scenario may be terminated.

SIMULATOR EXAM SCENARIO

SCENARIO TITLE: ATWS
SCENARIO NUMBER: 4-D4
EFFECTIVE DATE: 2/22/99
EXPECTED DURATION: 1.5 Hours
REVISION NUMBER: 0

PROGRAM:



LO REQUAL



INITIAL LICENSE



STA



OTHER _____

Revision Summary: Rev 0

PREPARED BY: *M. Hancock*
(WD ASSOCIATES)

1/21/99
(DATE)

APPROVED BY: _____
(TRAINING SUPERVISOR)

(DATE)

APPROVED BY: _____
(TRAINING SUPERVISOR)

(DATE)

I. OBJECTIVES

- A. Evaluate the ability of the crew to implement normal plant procedures to reduce plant power to 75%.
- B. Evaluate the ability of the crew to perform a rapid power reduction IAW S2.OP-AB.GRID-0001, Grid Disturbance. The crew should recognize and respond to the failure of Control Bank rod D3 to insert during the power reduction.
- C. Evaluate the response of the crew to the failure of 21 S/G Feed Flow Transmitter, FT-511 and the automatic transfer of Feedwater Reg Valves 21BF19 & 40 to manual.
- D. The crew should recognize and respond to the failure of the LT-459, Pressurizer Level failing low.
- E. Evaluate the ability of the crew to recognize and respond to the Main Turbine Lube Oil leak, failure of the Main Turbine Aux Oil Pump to auto start and subsequent abnormal vibrations on the Main Turbine.
- F. Evaluate the ability of the crew to recognize and respond to the failure of the Reactor to trip and to implement the EOPs.
- H. Evaluate the ability of the crew to recognize the loss of all AC and to properly transition to the LOPA series EOPs.

II. MAJOR EVENTS

- A. Perform a normal power reduction
- B. Control Bank Rod D3 fails to insert
- C. 21 S/G Feed Flow transmitter FT-511 fails low
- D. LT-459, Pressurizer Level fails low
- E. MTLO Leak with Main Turbine high vibration and a failure of the Main Turbine Aux Bearing Oil Pump to auto start.
- F. Failure of the Reactor to Trip (Auto & Manual)
- G. Loss of All AC Power

III. SCENARIO SUMMARY

- A. The crew will assume the watch at 100% power with directions to perform a power reduction to 75% for the removal of the 22 Condensate Pump from service for shaft seal replacement. All controls are in automatic and all equipment is operating normally with the following exceptions:
- 21 S/G Feed Flow transmitter FT-510 out of service for circuit board replacement.
- B. When the normal power reduction has progressed sufficiently, a report from the systems operator will require a rapid power reduction IAW S2.OP-AB.GRID-0001, Grid Disturbance. During the power reduction, Control Bank Rod D3 will fail to insert. The crew should enter and take the actions of S2.OP-AB.ROD-0001, Misaligned/Immovable Rod and continue the power reduction IAW S2.OP-AB.GRID-0001.
- C. 21 S/G Feed Flow Transmitter, FT-511 will fail low causing 21 S/G Feedwater Reg Valves 21BF19 and 21BF 40 to shift to manual.
- D. After a short delay to allow conditions to stabilize, Pressurizer Level Transmitter FT-459 will fail low. This will raise charging flow and cause actual Pressurizer level to rise. The RO should take the Master Level Controller to manual and stabilize pressurizer level. The crew should take the actions of Annunciator Response Procedure S2.OP-AR.ZZ-0005 for OHA E-36, PZR HTR OFF LVL LO.
- E. When Pressurizer level has been stabilized, a leak will occur in the Main Turbine Lube Oil System at the discharge of the shaft driven pump. All oil will be retained in the system by the guard pipe. As oil pressure lowers, the Aux Bearing Oil Pump will fail to auto start. The PO should recognize the failure of the Aux Bearing Oil Pump to auto start and respond by manually starting the pump to terminate the low oil pressure problem.
- F. When the lube oil leak is initiated, a Main Turbine high vibration will also be initiated that will gradually degrade to the point where a manual trip is required.
- G. The major event will be a failure of the Reactor to trip. The crew should implement the EOPs, enter and take the actions of EOP-TRIP-1, Reactor Trip or Safety Injection.
- H. The crew should perform EOP-TRIP-1, Reactor Trip or Safety Injection and transition to EOP-FRSM-1, Response to Nuclear Power Generation at Step 2.2
- I. The crew will perform the actions of EOP-FRSM-1, Response to Nuclear Power Generation. When Rapid Boration actions of Step 3 are complete, a Loss of All AC Power will occur, terminating the ATWS. The crew will transition to EOP-LOPA-1, Loss of All AC Power.
- J. The crew will perform actions of EOP-LOPA-1, Loss of All AC Power. When SI Actuation and Reset actions of Steps 21-23 have been initiated, a Diesel Generator will become available. The crew should respond IAW Continuous Action Step 14 and restore power to the 4kV bus. When power is restored and with the concurrence of the Examination Team, the scenario may be terminated.

IV. INITIAL CONDITIONS

IC-2 or IC-91 from the ESG disk, MOL at 100% power with the following conditions:

- a. 21 S/G Feed Flow transmitter FT-510 out of service for circuit board replacement.
- b. Pressurizer Level Channel I selected for control

MALFUNCTIONS					
	Malfunction	Severity	Delay	Ramp	Description
___1.	TA0306A	N/A	N/A	N/A	2 Aux Brg Oil PP Auto Start Failure
___2.	RD0065	47	0	0	Control Bank Rod D3 fails to insert
___3.	RP0058	N/A	0	0	Failure of the Reactor to auto trip
___4.	RP0059A	N/A	0	0	Failure of the Reactor to manually trip
___5.	SG0096A	0	0	0	FT-510,21 S/G Feed Flow Fails Low
___6.	SG0097A	0	0	0	FT-511, 21 S/G Feed Flow fails low (ET-1)
___7.	PR0017A	0	0	0	LT-459, Pzr Level fails low (ET-2)
___8.	TU0075	90	0	2 min	Main Turbine Lube Oil leak (ET-3)
___9.	TU0083A	20 mils	0	10 min	Main Turbine high vibration (ET-3)
___10.	TU0083B	20 mils	0	10 min	Main Turbine high vibration (ET-3)
___11.	EL0134	0	0	0	Loss of all AC Power (ET-4)
___12.	EL0162	Trip	0	0	2B DG Trip (ET-4)
___13.	EL0146	0	0	0	2C 4KV Bus Differential (ET-4)
___14.	EL0273A	0	0	0	2A DG Bkr fail to Auto Close (ET-4)

I/O OVERRIDES						
	Override/Type	SER Pt.	DI	DO	Condition	Description

___1.	CB05 (2ADD)		X		OFF	2A DIESEL GEN/BKR CLOSE
___2.	B440 (RTB A)		X		OFF	2A Rx Trip Bkr Open Switch off
___3.	B441 (RTB B)		X		OFF	2B Rx Trip Bkr Open Switch off
___4.	C310 (2E6D)		X		OFF	2E6D Bkr Open Switch off
___5.	C510 (2G6D)		X		OFF	2G6D Bkr Open Switch off

REMOTES			
	Remote/Type	Condition	Description

___1.	DG01D	OFF	A SEC POWER (When Requested)
___2.	DG02D	OFF	B SEC POWER (When Requested)
___3.	DG03D	YES	C SEC POWER (When Requested)
___4.	AF20D	YES	21 AFW pp control power off (When Requested)
___5.	AF25D	YES	22 AFW pp control power off (When Requested)

TAGGED EQUIPMENT	
	Description

___1.	Red Stripe FT-510
-------	-------------------

IV. SEQUENCE OF EVENTS

- A. Designate shift positions.
- B. Conduct a shift briefing outlining the shift instructions to the crew. (Provide each crew member with a copy of the Shift Turnover Sheet)
- C. Inform the crew " The simulator is running and that board walk-downs should be performed. CRS please inform me when your Crew is ready to assume the shift.".
- D. Allow sufficient time for panel walk-downs. When informed by the CRS that the Crew is ready to assume the shift, ensure the simulator is cleared of unauthorized personnel.

EVALUATOR/INSTRUCTOR OR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
<p>1. Power reduction using normal plant procedures.</p> <div style="border: 1px solid black; padding: 5px; width: fit-content;"> <p>No malfunctions other than those already inserted to start the scenario. The crew will reduce load at 30% per hr until notified by the Systems Operator to rapidly reduce load.</p> </div>	<ul style="list-style-type: none"> • The CREW commences a power reduction IAW Step 5.3 of S2.OP-IO.ZZ-0004, Power Operations. <ul style="list-style-type: none"> - Notify the Systems Operator and the Condensate Polishing Operator of the upcoming load reduction. • The PO INITIATES a Turbine load reduction with IAW S2.OP-SO.TRB-0002, Turbine Generator Shutdown Operations. <ul style="list-style-type: none"> - INITIATES monitoring the Main Turbine Data display points on the Plant Computer. - Uses the REF ? and GO pushbuttons to attain desired load. • The RO MAINTAINS T_{AVG}/T_{REF} mismatch at minimum value with Auto Rod motion and Boration. • The RO adjusts RCS Boron concentration to maintain AFD in target band and Rods above Rod Insertion Limits using OP-SO.CVC-0006, Boron Concentration Control. <ul style="list-style-type: none"> - DEPRESS Makeup Control Mode Select STOP Pushbutton. - ADJUST 2CV172 Setpoint to the desired value. - SET Boric Acid Flow Register to the number of gallons desired. - DEPRESS Makeup Control Mode Select BORATE Pushbutton. - DEPRESS Makeup Control Mode Select START Pushbutton. 	

EVALUATOR/INSTRUCTOR OR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
----------------------------------	---------------------------------	----------

- When Boration is complete, depress makeup Control Mode Select STOP Pushbutton.
- ADJUST 2CV172 Setpoint to the pre-boration value.
- DEPRESS Makeup Control Mode Select AUTO Pushbutton.
- DEPRESS Makeup Control Mode Select START Pushbutton.
- The **PO** verifies that SG Feed Pump suction pressure is being maintained \approx 300 psig.
- The **PO** monitors Condenser temperatures using the Plant Computer.

2. Rapid load reduction IAW AB-GRID and failure of Control Bank Rod D3 to insert.

AT the discretion of the examination team, Call as the Systems Operator and inform the crew that a K-6 Solar Disturbance is in affect and an EXCESS MVAR alarm has been received. The malfunction for rod D3 is Pre-inserted.

The crew will respond by entering and taking the actions IAW S2.OP-AB.GRID-0001, Grid Disturbance.

- The **PO** should initiate a Turbine load reduction at 15%/min to 80% or less.
- The **RO** should initiate a Boration at 25 gpm or more.

After rods begin to move, the Crew will be alerted to the failure of Control Bank Rod to insert by the following plant response:

- OHA E-24, ROD DEV OR SEQ
- Individual Rod Position Indication on CC2.
- Individual Rod Position Indication on the Process Computer.
- The **CREW** should respond by continuing the power reduction IAW AB-GRID and taking action IAW the appropriate Alarm Response Procedures.

EVALUATOR/INSTRUCTOR OR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
----------------------------------	---------------------------------	----------

- The **RO** should identify the faulted rod and respond by placing Rod Control in MANUAL IAW S2.OP-AB.ROD-0001, Immovable/Misaligned Rods.
- The **CRS** should enter and take the actions of S2.OP-AB.ROD-0001, Immovable/Misaligned Rods
- The **RO** should stop any boron concentration changes in progress.

The crew may decide to continue the boration to restore Tave to program IAW AB-GRID.

This action is specified by AB.ROD-1 but should NOT perform because raising turbine load is not permitted by AB.GRID.

- The **RO/PO** adjust Tavg to within 1.5 °F of program by adjusting Turbine load.
- The **CREW** should dispatch an Equipment Operator to investigate indications at the Rod Control cabinets.

Five (3) min after told to investigate, report as the I&C Supervisor that the fuse for the moveable coil for rod D3 is blown and a replacement is being obtained.

- The **CREW** should request:
 - I&C investigate Rod Control.
 - Reactor Engineering confirm misaligned rod.
- The **CREW** should monitor QPTR and AFD.
- The **CRS** should review Tech Specs.

3. FT-511, 21 S/G Feed Flow transmitter fails low.

The Crew will be alerted to the failure by the following plant response:

When the Tech Spec review has been initiated, initiate the failure of FT-511 low by inserting ET-1, SG0097A at 0%.

- OHA G15, ADFCS TRBL
- OHA G7, ADFCS SHIFT TO MAN
- 21BF19 & 21BF40 shift to manual.
- The **CREW** responds to the alarms IAW the appropriate Alarm Response Procedures.

EVALUATOR/INSTRUCTOR OR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
<p>Both Feed Flow indicators on CC2 for 21 S/G have failed. The PO should adjust 21BF19 by matching S/G levels and BF19 positions</p>	<ul style="list-style-type: none"> • The PO identifies the problem to be associated with 21 S/G Feed reg Valves, 21BF19 & 21BF40 by observing the blue MANUAL lights illuminated. - Manually adjusts the position of 21BF19 & 21BF40 as necessary to control 21 S/G level at the program value of 44%. 	
<p>4. LT-459, Pressurizer Level fails low.</p>	<ul style="list-style-type: none"> • The CREW identifies the failure of FT-511 as the cause of the transient. • The CREW notifies I&C to investigate the failure of FT-511. 	
<p>When the plant is stable and I&C have been notified, initiate the failure if LT-459 by inserting ET-2, PR0017A at 0%.</p>	<p>The failure of LT-459 low causes the following plant response:</p> <ul style="list-style-type: none"> - Indicated level will fail low causing charging flow to rise to compensate. - Actual Pressurizer level will begin to rise. - OHA E-36, PZR HTR OFF LVL LO - All Pressurizer Heaters de-energize - Letdown isolates <ul style="list-style-type: none"> • The CREW responds to the alarms IAW the appropriate Alarm Response Procedures. • The RO compares pressurizer level channels and determines Channel I to be failed. • The RO places the Pressurizer Master Flow Controller in Manual and minimizes Charging Flow. • The RO selects Pressurizer Level Channel III for Control. • The RO restores Pressurizer heaters. 	

EVALUATOR/INSTRUCTOR OR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
----------------------------------	---------------------------------	----------

- The **RO/PO** Restores Letdown IAW S2.OP-SO.CVC-0001, Charging, Letdown and Seal Injection.
 - Open 2CV2, LTDWN LINE ISOL V.
 - Open 2CV277, LTDWN LINE ISOL V
 - Place 2CV2, LTDWN LINE ISOL V in AUTO.
 - Place 2CV2, LTDWN LINE ISOL V in AUTO.
 - Place 2CV277, LTDWN LINE ISOL V in AUTO.
 - Open 2CV7, LTDWN HX INLET V.
 - Place 2CV18 in MANUAL CLOSE.
 - Open 2CV18 until CLOSE (INC PRESS) pushbutton extinguishes.
 - Ensure Charging flow is 85-90 gpm.
 - Adjust 2CV71, to maintain 6-12 gpm
 - Open 2CV4, 75 GPM ORIFICE.
 - Adjust 2CV18, to maintain Letdown pressure approximately 300 psig
 - Ensure Master Flow Controller in AUTO.
 - Place 2CV55 in AUTO.
 - Adjust 2CV18, to maintain letdown pressure approximately 300 psig and place in AUTO.

- The **CRS** reviews Tech Specs and enters LCO 3.3.1.1 action 6.

- The **CRS** initiates the actions of S2.OP-SO.RPS-0003, Placing Pressurizer Channel I in the tripped condition.

- The **RO** restores Pressurizer Level to the program band IAW S2.OP-AR.ZZ-0005, Overhead Annunciators Window E-36.

EVALUATOR/INSTRUCTOR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
<p>5. Main Turbine Lube Oil Leak and High Turbine Vibration.</p>	<p>The leak at the discharge of the Main Turbine Shaft Driven Lube Oil Pump will cause the following plant response:</p>	
<p>When letdown is restored and pressurizer level is stable, initiate the MT Lube Oil leak and High Vibs by inserting ET-3, for malfunctions TU0075 at 90% with a 2 min ramp and TU0083A&B at 100% with a 10 min ramp.</p>	<ul style="list-style-type: none"> - Bearing Oil Header Pressure will lower. - The HP Seal Oil Backup Pump starts at 12 psig. - CC3 Console Alarm when the HP Seal Oil Backup Pump starts - Turbine vibration will rise resulting in a Turbine trip. - OHA G-35, TSI TROUBLE (Delayed) - SER point 268, TSI Trouble (Delayed) <ul style="list-style-type: none"> • The PO should recognize the failure of the Aux Bearing Oil Pump to start and manually start the pump. • The CRS should enter and take the actions of S2.OP-AB.TL-0001, Loss of Main Turbine Lube Oil. • The PO should monitor Turbine parameters per S2.OP-AB.TL-0001, Attachment 2. • The CRS should direct a load reduction at < 5%/min to reduce Turbine vibration and remove the Turbine from service. 	
<p>6. Failure of the Reactor to trip.</p>	<ul style="list-style-type: none"> • The CREW should respond to the Hi vibration alarm IAW the Alarm Response procedure. • The RO/PO should trip the Reactor and then trip the turbine at or before bearing vibration reaches 9 mils and then enter EOP-TRIP-1. • The CREW should recognize the failure of the Reactor to trip and respond IAW EOP-TRIP-1. • The CRS enters and directs the actions of EOP-TRIP-1. 	
<p>NOTE: The malfunctions for this event (RP0058 & RP0059A) were pre-inserted at the beginning of the scenario.</p>		

EVALUATOR/INSTRUCTOR OR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
----------------------------------	---------------------------------	----------

- The **RO** should perform immediate actions of EOP-TRIP-1 and transition to EOP-FRSM-1.

- Trip the reactor using:
 - Both Trip Switches
 - Trip Breaker Bezels
 - 460V Breakers 2E6D & 2G6D
- Verify the Reactor is tripped by observing at least three PR channels indicate < 5% and IR indications lowering with negative SUR
- Trip the Turbine
- Initiate Rod Insertion in Manual

NOTE: Auto rod motion should be used if it will result in a higher rod speed.

- The **CRS** enters and directs the actions of EOP-FRSM-1, Response to Nuclear Power Generation.
- The **RO** starts the second Centrifugal Charging Pump and adjusts CV71 to maintain total RCP Seal Injection flow ≤ 40 gpm.

- The **RO/PO** initiates Rapid Boration as follows:

- Starts 21 & 22 Boric Acid transfer Pumps in fast speed.
- Opens CV175, Rapid Borate Stop Valve
- Close 21 & 22 CV160, BAT Pump Recirc Valves

Critical Step # 1: Sat _____
Unsat _____

- The **CREW** should send Equipment Operators to:
 - Open the Reactor Trip Breakers
 - Trip the Main Turbine.
 - Close Primary water Valves

EVALUATOR/INSTRUCTOR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
-------------------------------	---------------------------------	----------

7. Loss of All AC Power

After Rapid Boration Steps are complete, initiate the Loss of All AC Power by inserting ET-4 for the following malfunctions:

- EL0134, Loss of All AC Power
- EL0162, 2B DG Trip
- EL0146, 2C 4KV Bus Differential
- EL0273A, 2A DG Bkr fail to Auto Close

Override 2ADD, 2A DG Bkr Trip CLOSE PB OFF

When requested to de-energize the SECs, insert the following remote functions **AFTER** a four (4) min delay:

- DG01D, A SEC
- DG02D, B SEC
- DG03D, C SEC

The loss of power will cause all control rods to fully insert and allow the Crew to transition out of EOP-FRSM-1.

- The **CREW** should recognize Loss of All AC Power and transition to EOP-LOPA-1.

- The **CREW** should send an Equipment Operator to de-energize all SECs.

- The **PO** should initiate Blackout Coping Actions IAW S2.OP-AB.LOOP-0001, Loss of Off-site Power, Attachment 1, Part A.

- The **CREW** should recognize the 2A DG Breaker did not auto close and attempt to close the breaker manually.

- The **RO/PO** Closes the 2A DG Bkr 2ADD:

- Press the Mimic Bus 2A DG BKR 2ADD pushbutton.
- Verify 2A MIMIC BUS INTERLOCK CLOSE SELECTION light is illuminated.
- Press 2A BREAKER CLOSE pushbutton

EVALUATOR/INSTRUCTOR OR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
----------------------------------	---------------------------------	----------

Critical Step # 2: Sat ____
 Unsat ____

- The **CREW** should recognize when the 2A DG Breaker will not close and two DGs are running without Service Water

- The **PO** stops the 2A & 2C EDG IAW EOP-LOPA-1 CAS

- The **CREW** should send Equipment Operators to:
 - Open 2SJ1 & 2SJ2, RWST to Charging Pump Valves.
 - Close 2SW26, Service Water to Turbine Building Isolation.

Simulator Operator: When SI Actuation and Reset actions have been initiated: clear the Override on 2A D/G Bkr to allow breaker closure.

THEN:

As NEO, make report to the Control Room: 2A EDG Breaker was not racked in properly. The breaker has been racked in and electricians at the breaker recommend a re-closure attempt.

- The **RO/PO** initiates Safety Injection
- The **RO/PO** closes:
 - Phase A Isolation valves (Table D)
 - Containment Isolation valves (Table E)

- The **PO** starts 2A EDG
- The **PO** closes 2A EDG Bkr 2ADD:
 - Press the Mimic Bus 2A DG BKR 2ADD pushbutton.
 - Verify 2A MIMIC BUS INTERLOCK CLOSE SELECTION light is illuminated.
 - Press 2A BREAKER CLOSE pushbutton and verify bus voltage is > 3900 volts.
- The **CRS** should return to Continuous Action Step 14.1 when the 2A 4KV Bus is energized.

The Mimic Bus Pushbutton may have been previously been selected.

EVALUATOR/INSTRUCTOR OR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
----------------------------------	---------------------------------	----------

Critical Step # 3: Sat _____
 Unsat _____

- The RO/PO should:
 - Start either 21 or 22 Service Water Pump.
 - Close 21SW20, Turbine Area SW Stop Valve.

When the 2A 4 KV Bus has been energized, Service Water is restored and with the concurrence of the Examination Team, the scenario may be terminated.

After the scenario has been terminated, the CRS should refer to the ECG to Classify the event.

- The CRS refers to the ECG and classifies the event:
 - SAE - 5.1.3
 - SAE - 7.1.3 After 15 min.

V. SCENARIO REFERENCES

- A. ES-301, Preparing Initial Operating Tests
- B. K/A Catalog
- C. JTA Listing
- D. Technical Specifications
- E. S2.OP-IO.ZZ-0004
- F. S2.OP-SO.TRB-0002
- G. S2.OP-SO.CVC-0001
- H. S2.OP-SO.CVC-0006
- I. Various Alarm Response Procedures
- J. S2.OP-AB.ROD-0001
- K. S2.OP-AB.GRID-0001
- L. S2.OP-SO.RPS-0003
- M. S2.OP-AB.LOOP-0001
- N. S2.OP-AB.TL-0001
- O. 2-EOP-TRIP-1
- P. 2-EOP-FRSM-1
- Q. 2-EOP-LOPA-1

ATTACHMENT 1
UNIT TWO PLANT STATUS TODAY

MODE: 1	POWER: 100%	RCS BORON: 680 ppm	Mwe: 1140
---------	-------------	--------------------	-----------

SHUTDOWN SAFETY SYSTEM STATUS (5, 6 & DEFUELED): N/A

REACTIVITY PARAMETERS: Core Burnup 8000 MWD/MTU

MOST LIMITING LCO AND DATE/TIME OF EXPIRATION:

EVOLUTIONS/PROCEDURES/SURVEILLANCES IN PROGRESS:

21 S/G Feed Flow transmitter FT-510 out of service for circuit board replacement.

PLANT TURNOVER IS AS FOLLOWS:

The orders for the shift are to reduce power to 75% at 30%/hr and remove 22 Condensate Pump from service for shaft seal replacement.

ABNORMAL PLANT CONFIGURATIONS: NONE

CONTROL ROOM:

Unit 1 and Hope Creek at 80% power.
No penalty minutes in the last 24 hrs.

PRIMARY: NONE

SECONDARY: Heating Steam is aligned to unit 1.

RADWASTE: No discharges in progress

CIRCULATING WATER/SERVICE WATER:

ATTACHMENT 2 SIMULATOR READY FOR TRAINING CHECKLIST
--

- ___ 1. Verify simulator is in correct load for training
- ___ 2. All required computer terminals in operation
- ___ 3. Simulator clocks synchronized
- ___ 4. Required chart recorders advanced and ON (proper paper installed)
- ___ 5. Rod step counters correct (channel check)
- ___ 6. All tagged equipment properly secured and documented (TSAS Log filled out)
- ___ 7. DL-10 log up-to-date
- ___ 8. Required procedures clean
- ___ 9. All OHA lamps operating (OHA Test)
- ___ 10. All printers have adequate paper AND functional ribbon
- ___ 11. Procedure pens available
- ___ 12. Procedures in progress open and signed-off to proper step
- ___ 13. Shift manning sheet available
- ___ 14. SPDS reset
- ___ 15. Reference verification performed with required documents available
- ___ 16. Ensure a current RCS Leak Rate Worksheet is placed by Aux Alarm Typewriter with Baseline Data filled out
- ___ 17. Required keys available
- ___ 18. Video Tape (if applicable)
- ___ 19. Ensure ECG Classification is correct – 960502140 CRCA-03
- ___ 20. Reset P-250 Rod Counters

ATTACHMENT 3 CRITICAL TASK METHODOLOGY

In reviewing each proposed CT, the examination team assesses the task to ensure, that it is essential to safety. A task is essential to safety if, in the judgement of the examination team, the improper performance or omission of this task by a licensee will result in direct adverse consequences or in significant degradation in the mitigative capability of the plant.

The examination team determines if an automatically actuated plant system would have been required to mitigate the consequences of an individual's incorrect performance. If incorrect performance of a task by an individual necessitates the crew taking compensatory action that would complicate the event mitigation strategy, the task is safety significant.

1. Examples of CTs involving essential safety actions include those for which operation or correct performance prevents...
 - degradation of any barrier to fission product release
 - degraded emergency core cooling system (ECCS) or emergency power capacity
 - a violation of a safety limit
 - a violation of the facility license condition
 - incorrect reactivity control (such as failure to initiate Emergency Boration or Standby Liquid Control, or manually insert control rods)
 - a significant reduction of safety margin beyond that irreparably introduced by the scenario
2. Examples of CTs involving essential safety actions include those for which a crew demonstrates the ability to...
 - effectively direct or manipulate engineered safety feature (ESF) controls that would prevent any condition described in the previous paragraph.
 - recognize a failure or an incorrect automatic actuation of an ESF system or component.
 - take one or more actions that would prevent a challenge to plant safety.
 - prevent inappropriate actions that create a challenge to plant safety (such as an unintentional Reactor Protection System (RPS) OR ESF actuation.

ATTACHMENT 4 SCENARIO REVIEW CHECKLIST

Note: Attach a separate copy of this form to each scenario reviewed. This form is used as guidance for the examination team as they conduct their review for the proposed scenarios.

SCENARIO IDENTIFIER:	REVIEWER:
-----------------------------	------------------

Initials

Qualitative Attributes

- | | |
|---|--|
| _____

_____ | 1. The scenario has clearly stated objectives in the scenario.
2. The initial conditions are realistic, in that some equipment and/or instrumentation may be out of service, but it does not cue crew into expected events.
3. The scenario consists mostly of related events.
4. Each event description consists of-- <ul style="list-style-type: none"> • the point in the scenario when it is to be initiated • the malfunction(s) that are entered to initiate the event • the symptoms/cues that will be visible to the crew • the expected operator actions (by shift position) • the event termination point 5. No more than one non-mechanistic failure (e.g., pipe break) is incorporated into the scenario without a credible preceding incident such as a seismic event.
6. The events are valid with regard to physics and thermodynamics.
7. Sequencing/timing of events is reasonable, and allows for the examination team to obtain complete evaluation results commensurate with the scenario objectives.
8. The simulator modeling is not altered.
9. All crew competencies can be evaluated.
10. The scenario has been validated.
11. If the sampling plan indicates that the scenario was used for training during the Initial training Program, evaluate the need to modify or replace the scenario. |
|---|--|

ATTACHMENT 5
ESG – CRITICAL TASKS

CT#1 – Initiate a Rapid Boration (FR-S.1--C)

CT#2 – Stop any Diesel Generators running without Service Water (CAS)

CT#3 – Energize a bus and start a Service Water pump to prevent damage to running DGs
(ECA-0.0--F)

SPARE - UK

Facility: Salem Units 1 & 2

Scenario No.: 5

Op Test No.: SP

Examiners: _____

Candidates: _____ CRS
 _____ RO
 _____ PO

Objectives: Evaluate the ability of the crew to perform a normal power ascension to 100 % power. Evaluate the ability of the crew to recognize and respond to Power Range Channel N43 failing high during the power ascension. The crew should recognize and respond to the 22 Vacuum Pump trip. The crew should recognize and respond to the leaking PORV. Evaluate the ability of the crew to respond to the FW Line Break inside containment on 21 S/G and implement the EOPs. The crew should recognize and respond to the trip of 23 Aux Feedwater Pump. The crew should recognize and respond to the Loss of Off-site Power. The crew should recognize and respond to the loss of the 2B 4kV Bus transition to EOP-FRHS-1, Response to Loss of Secondary Heat Sink, and eventually initiate RCS Bleed and Feed.

Initial Conditions: IC-4 at 90% power with 21 AFW Pump C/T for bearing replacement.

Turnover: The plant is in Mode 1 with power at 90%. 21 AFW Pump C/T for bearing replacement with work expected to be complete in approximately 14 hours. All other equipment is operating normally with controls in automatic. Orders for the shift are to perform a normal ascension to 100% power at 10% per hour.

Event No.	Malf. No.	Event Type*	Event Description
1		N CRS R PO R RO	Perform a power ascension to 100 % power.
2	NI0193C	I CRS RO	Power Range Channel N43 fails high
3	VC0087A	C CRS PO	22 Vacuum Pump trips
4	PR0018A	C CRS RO	PZR PORV 2PR1 develops a leak
5	BF0111A	M ALL	21 S/G FW Line Break inside containment
6	AF0183	C CRS PO	23 Aux Feedwater Pump overspeed trip
7	EL0134	M ALL	Loss of Off-site Power
8	EL0145	C ALL	Loss of 2B 4160V Vital Bus

* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor

SCENARIO SUMMARY

The scenario begins with a normal power ascension to 100%. When the power ascension has progressed to the satisfaction of the Examination Team, Power Range Channel N43 will fail causing the associated bisables to trip. The crew will enter and take the actions of S2.OP-AB.ROD-0003, Continuous Rod Motion, and S2.OP-AB.NIS-0001, Nuclear Instrumentation System Malfunction.

When the TSAS for N43 have been entered, 22 Vacuum Pump will trip causing condenser vacuum to degrade. The crew should respond by entering and performing the actions of S2.OP-AB.COND-0001, Loss of Condenser Vacuum, and start the out-of-service Vacuum Pumps.

After the crew has stabilized condenser vacuum, 2PR1 will develop a leak causing Pressurizer pressure to lower. The crew is expected to respond IAW S2.OP-AB.PZR-0001, Pressurizer Pressure Abnormality.

After the Tech Spec review is complete, a Feed Line Break will occur inside containment on 21 S/G. The crew should respond by entering S2.OP-AB.STM-0001, Excessive Steam Flow. The crew is expected to determine SG Levels are lowering, Trip the Reactor and enter EOP-TRIP-1, Reactor Trip or Safety Injection. When the reactor Trip is initiated, a Loss of Off-site Power will occur. The crew should respond IAW EOP-TRIP-1.

During the Reactor Trip, 23 Aux Feedwater Pump will trip on overspeed leaving only 22 Aux Feedwater Pump available to feed the Steam Generators. The crew should continue performing the actions of EOP-TRIP-1.

A loss of the 2B 4KV Vital Bus will occur resulting in the loss of the 22 Aux Feedwater Pump. The Crew is expected to recognize the loss of all Aux Feed and transition to EOP-FRHS-1, Response to Loss of Secondary Heat Sink.

When required by FRHS-1, the crew will initiate Bleed & Feed and continue with the actions of FRHS-1. When Containment Spray has been terminated, and with the concurrence of the examination team, the scenario may be terminated.

SIMULATOR EXAM SCENARIO

SCENARIO TITLE: FRHS-Feed & Bleed
SCENARIO NUMBER: 5-SP
EFFECTIVE DATE: 2/22/99
EXPECTED DURATION: 1:5 Hours
REVISION NUMBER: 0
PROGRAM: LO REQUAL
 INITIAL LICENSE
 STA
 OTHER _____

Revision Summary: Rev 0

PREPARED BY: _____ (WD ASSOCIATES) _____ (DATE)
APPROVED BY: _____ (TRAINING SUPERVISOR) _____ (DATE)
APPROVED BY: _____ (TRAINING SUPERVISOR) _____ (DATE)

I. OBJECTIVES

- A. Evaluate the ability of the crew to perform a normal ascension to 100 % power.
- B. Evaluate the ability of the crew to recognize and respond to the failure of a Power Range Nuclear Instrument.
- C. The crew should recognize and respond to the trip of 22 Vacuum Pump.
- D. The crew should recognize and respond to the leaking PORV.
- E. Evaluate the ability of the crew to respond to a FW Line Break on 21 S/G inside containment and eventual implementation of the EOPs.
- F. Evaluate the ability of the crew to recognize and respond to the trip of 23 Aux Feedwater Pump during the Reactor Trip transient.
- G. The crew should recognize and respond to the Loss of Off-site Power.
- H. Evaluate the ability of the crew to recognize and respond to the loss of the 2B 4kV Bus and resultant loss of the 21 AFW Pump and transition to FRHS-1.

II. MAJOR EVENTS

- A. Perform a normal ascension to 100 % power
- B. Failure of Power Range Nuclear Instrument N43
- C. 22 Vacuum Pump trips
- D. 2PR1 develops a small leak
- E. FW Line Break on 21 S/G inside containment
- F. Overspeed trip of 23 Aux Feedwater Pump during the Reactor Trip transient
- G. Loss of Off-site Power
- H. Loss of the 2B 4kV Bus resulting in a Loss of Secondary Heat Sink

III. SCENARIO SUMMARY

- A. The crew will assume the watch at 90% power with directions to perform an ascension to 100% power. All controls are in automatic and all systems are operating normally EXCEPT:
- 21 Aux Feedwater Pump C/T for bearing replacement. The Maintenance Supervisor anticipates the work to be completed in approximately fourteen (14) hours.
- B. When the power ascension has progressed to the satisfaction of the Examination Team, Power Range Channel N43 will fail causing the associated bistables to trip. The Crew will enter and take the actions of S2.OP-AB.NIS-0001, Nuclear Instrumentation System Malfunction.
- C. After the T/S have been evaluated for the PRNIS failure, 22 Vacuum Pump will trip causing condenser vacuum to degrade. The Crew should respond by entering and performing the actions of S2.OP-AB.COND-0001, Loss of Condenser Vacuum, including starting the out-of-service Vacuum Pumps.
- D. After the Crew has stabilized condenser vacuum, 2PR1 will develop a leak causing Pressurizer pressure to lower. The crew is expected to respond IAW S2.OP-AB.PZR-0001, Pressurizer Pressure Abnormality.
- E. After the Tech Spec review is complete, a Feed Line Break will occur on 21 S/G inside containment. The Crew should respond by entering S2.OP-AB.STM-0001, Excessive Steam Flow. The crew is expected to determine SG Levels are lowering, Trip the Reactor and enter EOP-TRIP-1, Reactor Trip or Safety Injection. When the reactor Trip is initiated, a Loss of Off-site Power will occur. The crew should respond IAW EOP-TRIP-1.
- F. During the Reactor Trip, 23 Aux Feedwater Pump will trip on overspeed leaving only 22 Aux Feedwater Pump available to feed the Steam Generators. The crew should continue performing the actions of EOP-TRIP-1.
- G. A loss of the 2B 4KV Vital Bus will occur resulting in the loss of 22 Aux Feedwater Pump. The Crew is expected to recognize the loss of all Aux Feed and will transition to EOP-FRHS-1, Response to Loss of Secondary Heat Sink, at Step 20 of EOP-TRIP-1.
- H. When required by FRHS-1, the crew will initiate Feed & Bleed and continue with the actions of FRHS-1. When Containment Spray has been terminated, and with the concurrence of the examination team, the scenario may be terminated.

IV. INITIAL CONDITIONS

IC-2 or IC-94 from the ESG disk, MOL at 90% power with the following conditions:

- a. 21 Aux Feedwater Pump C/T for bearing replacement.
- b. Remove ALL BUT 22 and 23 Vacuum Pumps from service.

MALFUNCTIONS

	Malfunction	Severity	Delay	Ramp	Description
--	-------------	----------	-------	------	-------------

___ 1.	AF0183	0	0	0	23 Aux Feedwater Pump overspeed trip
___ 2.	NI0193C	200	0	0	Power Range Channel N43 fails high (ET-1)
___ 3.	VC0087A	0	0	0	22 Condenser Vacuum Pump Trip (ET-2)
___ 4.	PR0018A	20k	0	2 min	PZR PORV 2PR1 develops leak (ET-3)
___ 5.	BF0111A	10K gpm	0	8 min	21 S/G FW Line Break inside Containment (ET-4)
___ 6.	EL0134	N/A	0	0	Loss of Off-site Power (ET-5)
___ 7.	EL0145	0	5 min	0	Loss of 2B 4160V Vital Bus (ET-5)

I/O OVERRIDES

	Override/Type	SER Pt.	DI	DO	Condition	Description
--	---------------	---------	----	----	-----------	-------------

- 1. None

REMOTES

	Remote/Type	Condition	Description
--	-------------	-----------	-------------

___ 1.	AF20D	OFF	21 AFW pp Control Power off
___ 2.	AF21D	OFF	22 AFW pp Control Power off

TAGGED EQUIPMENT	
------------------	--

	Description
--	-------------

___ 1. 21 Aux Feedwater Pump C/T for bearing replacement

OTHER:

Provide marked up copy of S2.OP-IO.ZZ-0004

V. SEQUENCE OF EVENTS

- A. Designate shift positions.
- B. Conduct a shift briefing outlining the shift instructions to the crew. (Provide each crew member with a copy of the Shift Turnover Sheet)
- C. Inform the crew " The simulator is running and that board walk-downs should be performed. CRS please inform me when your Crew is ready to assume the shift."
- D. Allow sufficient time for panel walk-downs. When informed by the CRS that the Crew is ready to assume the shift, ensure the simulator is cleared of unauthorized personnel.

EVALUATOR/INSTRUCTOR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
<p>1. Power ascension using normal plant procedures.</p> <p>No malfunctions other than those already inserted to start the scenario. The crew will raise load at a maximum of 10% per hr until either 100% power is reached or PR N43 fails.</p>	<ul style="list-style-type: none"> • The CREW commences a power ascension IAW Step 5.1 of S2.OP-IO.ZZ-0004, Power Operation. <ul style="list-style-type: none"> - Notify the Systems Operator and the Condensate Polishing Operator of the upcoming power ascension. • The PO raises Turbine load IAW S2.OP-SO.TRB-0001, Turbine Generator Startup Operations. <ul style="list-style-type: none"> - Initiates monitoring the Main Turbine Data display points on the Plant Computer. - Monitor Turbine parameters IAW S2.OP-SO.TRB-0001, Attachment 2. - Uses the REF ▲ and GO pushbuttons to attain desired load. - Monitor condenser ΔT Limits • The RO maintains AFD within the target band using Auto Rod motion and Dilution. • The RO Maintains T_{AVG}/T_{REF} mismatch at minimum value with Rod motion and dilution. • The RO adjusts RCS Boron concentration to maintain Tavg and AFD using Boron Concentration Control, S2.OP-SO.CVC-0006. <ul style="list-style-type: none"> - DEPRESS Makeup Control Mode Select STOP Pushbutton. - SET Primary Water Flow Register to the number of gallons desired. - DEPRESS Makeup Control Mode Select DILUTE Pushbutton. - DEPRESS Makeup Control Mode Select START Pushbutton. - When dilution is complete, depress Makeup 	

EVALUATOR/INSTRUCTOR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
<p>2. Power Range Channel N43 Fails High.</p> <p>When the power ascension has progressed to the satisfaction of the examination team, initiate the failure Power Range Channel N43 by inserting ET-1, for malfunction NI0193C.</p> <p>Crew may enter S2.OP-AB.ROD-0003 first</p> <p>RO may place rods in MANUAL when the failure is identified</p>	<p>Control Mode Select STOP Pushbutton.</p> <ul style="list-style-type: none"> - DEPRESS Makeup Control Mode Select AUTO Pushbutton. - DEPRESS Makeup Control Mode Select START Pushbutton. <ul style="list-style-type: none"> • The Crew will be alerted to the failure by the following plant response: <ul style="list-style-type: none"> - OHA E-15, PR HI RNG FLUX HI - OHA E-31, PR OVRPWR ROD STOP - OHA E-47, PR NEUT FLUX RATE HI - OHA E-39, PR CH DEV • The CREW should stop the power ascension and respond to the alarms IAW the appropriate Alarm Response Procedure. • The CRS should enter and take the actions of S2.OP-AB.NIS-0001, Nuclear Instrumentation System Malfunction. • The RO should place Rod Control in MANUAL • The CRS initiates S2.OP-SO.RPS-0001, Nuclear Instrumentation Channel Trip/ Restoration to remove Power Range Channel N43 from service. • The CREW should request I&C assistance in removing Power Range N43 from service. • The CRS enters T/S 3.3.1.1 Actions 2 and 6 	
<p>3. 22 Vacuum Pump trips</p> <p>When the PRNIS TSAS's have been entered and I&C assistance requested, initiate the trip of 22 Vacuum Pump by inserting ET-2, MALF VC0087A</p>	<ul style="list-style-type: none"> • The Crew will be alerted to the failure by the following plant response: <ul style="list-style-type: none"> - CC2 console alarm when the Vacuum Pump Trips. - Condenser vacuum will begin to lower. • The RO/PO should determine that the 22 Vacuum Pump tripped. 	

EVALUATOR/INSTRUCTOR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
<p>Five minutes after the Equipment Operator is dispatched, report that the breaker for 22 Vacuum Pump has tripped on overcurrent. The vacuum pumps just started are running normally.</p>	<ul style="list-style-type: none"> • The CRS should enter and take the actions of S2.OP-AB.COND-0001, Loss of Condenser Vacuum. • The CREW should send an Equipment Operator to check operation of the Vacuum Pumps locally. • The PO should start the standby vacuum pumps. 	
<p>4. PR1 Develops a Leak</p> <p>When condenser vacuum has stabilized, initiate the leak on PR1 by inserting ET-3, malfunction PR0018A at 20000 lbm/hr with a 2 min ramp.</p> <p>Crew may enter S2.OP-AB.RC-0001 and then transition to S2.OP-AB.PZR-0001</p>	<p>The crew will be alerted to the malfunction by the following plant response:</p> <ul style="list-style-type: none"> - Pressurizer pressure lowers - Heaters energize - Spray valves close - Tail Pipe temperature rises - OHA E-28 <ul style="list-style-type: none"> • The RO should place heaters in manual and evaluate pressure control for proper operation. • The CREW should enter and take the actions of S2.OP-AB.PZR-0001, Pressurizer Pressure Abnormality and close PR6 and/or PR7 to attempt to isolate the leaking PORV followed by re-opening PR6 and PR7 sequentially to determine 2PR1 is leaking • The CRS should refer to Tech Specs and declare PR1 inoperable IAW 3.4.5.a. 	
<p>5. 21 S/G Feed Line Break.</p> <p>When the Tech Spec review is complete, initiate the Feed Line Break inside containment by inserting ET-4, malfunction BF0111D at 10k gpm with an 8 min ramp.</p>	<p>The Crew will be alerted to the failure by the following plant response:</p> <ul style="list-style-type: none"> - CC2 Console Alarm for 24 S/G, Program Deviation Setpoint Actual - 24 S/G level will begin to lower - 24BF19, Feed Reg Valve will open to maintain level. - OHA G-15 ADFCS TROUBLE - Contmnt Press HI Bezel Alarm 	

EVALUATOR/INSTRUCTOR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
----------------------------------	------------------------------------	----------

Crew may elect to initiate a MANUAL Rx Trip, SI and MSLI w/o entering S2.OP-AB.STM-0001

- The **CREW** should respond to the Console Alarms LAW the appropriate Alarm response Procedure.
- The **CRS** should enter and take the actions of S2.OP-AB.STM-0001, Excessive Steam Flow.
- The **RO/PO** should identify the lowering level in 24 S/G and initiate a MANUAL Reactor trip, Safety Injection and MSLI
- The **CREW** should enter and take the actions of EOP-TRIP-1, Reactor Trip or Safety Injection.
- The **RO** performs the immediate actions of EOP-TRIP-1:
 - Trip the reactor
 - Verify the Reactor is tripped by observing at least three PR channels indicate < 5% and IR indications lowering with negative SUR
 - Trip the Turbine and verify TSV CLOSED and AST OIL PRESS LOW lights illuminated on RP4
 - Verify Vital 4KV Bus status by observing bus voltage > 3900 volts
 - Initiate a MANUAL SI

Critical Task #1: Sat _____ Unsat _____

- Crew should isolate AFW flow to 21 SG by closing 21AF11 and 21AF21 NLT 10 minutes after the break

EVALUATOR/INSTRUCTOR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
<p>J. Loss of Off-Site Power and Trip of 23 AFW Pump</p> <p>30 seconds after the reactor is tripped, initiate the Loss of Off-site Power by inserting ET-5, malfunction EL0134. The trip of 23 AFW Pump is pre-inserted.</p> <p>Critical Task #2: Sat ____ Unsat ____</p>	<ul style="list-style-type: none"> • The CREW should recognize the Loss of Off-site Power and continue with the actions of EOP-TRIP-1. • Establish and maintain total Aux Feed Flow to 22 S/Gs at $\geq 22E4$ lbm/hr. • PO should recognize and report loss of 23 AFW Pump 	
<p>7. Loss of the 2B 4KV Vital Bus</p> <p>Five minutes after the loss of off-site power, loss of the 2B 4KV Vital Bus will occur (ET-5) on MALF EL0145.</p>	<p>The Crew will be alerted to the failure by the following plant response:</p> <ul style="list-style-type: none"> - The 2B 4KV Bus will de-energize - 2B D/G will remain running - All 4KV load breakers will trip (Not 460V Fds) - OHA J-2, 2B4KV VTL BUS DIFF PROT - OHA J-12, 2B DG URGENT TRBL - OHA J-18, 2B 4KV BUS UNDRVOLT - Loss of 22 AFW Pump <ul style="list-style-type: none"> • CRS directs an operator to start one CCW Pp per EOP-APPX-1 	
<p>When Feed & Bleed criteria is met, the Crew will proceed to Step 23.</p>	<ul style="list-style-type: none"> • The CREW should recognize the loss of 22 Aux Feedwater Pump causing a Loss of Secondary heat Sink and should transition to EOP-FRHS-1, Response to Loss of Secondary Heat Sink, at Step 20, EOP-TRIP-1 • The CREW should send an Equipment Operator to investigate AFW Pump problems. 	

EVALUATOR/INSTRUCTOR ACTIVITY	EXPECTED PLANT/STUDENT RESPONSE	COMMENTS
----------------------------------	------------------------------------	----------

These valves are supplied with power from the 2B Vital Bus and will be de-energized.

Critical Task #3: Sat _____ **Unsat** _____

- The **CREW** should dispatch Equipment Operators to position the following valves:
 - 2CV41, VCT Discharge Stop
 - 2CV68, Charging Discharge
 - 2SJ12,BIT Outlet
- The **RO** opens 2PR6 and opens both Pressurizer PORVs.
- The **CRS** directs EOP-APPX-3, SI Verification be performed.
- The **RO** performs Safeguards Reset Actions:
 - Reset SI
 - Reset Phase A Isolation
 - Reset Phase B Isolation
 - Open 21 & 22CA330, Containment Control Air Isolation Valves
 - Reset each SEC
- If Containment Spray has actuated, the **RO** should terminate Containment Spray:
 - Reset Spray Actuation
 - Stop both CS Pumps
 - Close 21 & 22CS2, CS Pump Discharge Valves

When safeguards have been reset, and with the concurrence of the examination team, the scenario may be terminated.

After the scenario has been terminated, the CRS should refer to the ECG to Classify the event.

- The CRS refers to the ECG and classifies the event:
 - SAE - 3.1.1.b & 3.2.1.b **OR**
 - SAE - 8.1.3.C

VI. SCENARIO REFERENCES

- A. ES-301, Preparing Initial Operating Tests
- B. K/A Catalog
- C. JTA Listing
- D. Technical Specifications
- E. S2.OP-IO.ZZ-0004
- F. S2.OP-SO.TRB-0001
- G. S2.OP-SO.CVC-0006
- H. Various Alarm Response Procedures
- I. S2.OP-AB.COND-0001
- J. S2.OP-AB.NIS-0001
- K. S2.OP-AB.PZR-0001
- L. S2.OP-AB.STM-0001
- M. S2.OP-SO.RPS-0001
- N. 2-EOP-TRIP-1
- O. 2-EOP-FRHS-1
- P. 2-EOP-APPX-3

**ATTACHMENT 1
UNIT TWO PLANT STATUS TODAY**

MODE: 1	POWER: 90%	RCS BORON: 104 ppm	Mwe: 1040
---------	------------	--------------------	-----------

SHUTDOWN SAFETY SYSTEM STATUS (5, 6 & DEFUELED): N/A

REACTIVITY PARAMETERS: Core Burnup 14,000 MWD/MTU

MOST LIMITING LCO AND DATE/TIME OF EXPIRATION:

3.7.2 21 Aux Feedwater Pump out of service for bearing replacement. The 72 hr LCO expires at 2330 tomorrow.

EVOLUTIONS/PROCEDURES/SURVEILLANCES IN PROGRESS:

Power ascension to 100%.

PLANT TURNOVER IS AS FOLLOWS:

- 21 Aux Feedwater Pump out of service for bearing replacement. Maintenance estimates the work will be complete in approximately 14 hours.
- The orders for the shift are to raise power to 100% at a rate not to exceed 10%/hr.

ABNORMAL PLANT CONFIGURATIONS: NONE

CONTROL ROOM:

Unit 1 and Hope Creek at 100% power.
No penalty minutes in the last 24 hrs.

PRIMARY: NONE

SECONDARY: Heating Steam is aligned to unit 1.

RADWASTE: No discharges in progress

CIRCULATING WATER/SERVICE WATER:

ATTACHMENT 2 SIMULATOR READY FOR TRAINING CHECKLIST
--

- ___ 1. Verify simulator is in correct load for training
- ___ 2. All required computer terminals in operation
- ___ 3. Simulator clocks synchronized
- ___ 4. Required chart recorders advanced and ON (proper paper installed)
- ___ 5. Rod step counters correct (channel check)
- ___ 6. All tagged equipment properly secured and documented (TSAS Log filled out)
- ___ 7. DL-10 log up-to-date
- ___ 8. Required procedures clean
- ___ 9. All OHA lamps operating (OHA Test)
- ___ 10. All printers have adequate paper AND functional ribbon
- ___ 11. Procedure pens available
- ___ 12. Procedures in progress open and signed-off to proper step
- ___ 13. Shift manning sheet available
- ___ 14. SPDS reset
- ___ 15. Reference verification performed with required documents available
- ___ 16. Ensure a current RCS Leak Rate Worksheet is placed by Aux Alarm Typewriter with Baseline Data filled out
- ___ 17. Required keys available
- ___ 18. Video Tape (if applicable)
- ___ 19. Ensure ECG Classification is correct – 960502140 CRCA-03
- ___ 20. Reset P-250 Rod Counters

ATTACHMENT 3 CRITICAL TASK METHODOLOGY

In reviewing each proposed CT, the examination team assesses the task to ensure, that it is essential to safety. A task is essential to safety if, in the judgement of the examination team, the improper performance or omission of this task by a licensee will result in direct adverse consequences or in significant degradation in the mitigative capability of the plant.

The examination team determines if an automatically actuated plant system would have been required to mitigate the consequences of an individual's incorrect performance. If incorrect performance of a task by an individual necessitates the crew taking compensatory action that would complicate the event mitigation strategy, the task is safety significant.

1. Examples of CTs involving essential safety actions include those for which operation or correct performance prevents...
 - degradation of any barrier to fission product release
 - degraded emergency core cooling system (ECCS) or emergency power capacity
 - a violation of a safety limit
 - a violation of the facility license condition
 - incorrect reactivity control (such as failure to initiate Emergency Boration or Standby Liquid Control, or manually insert control rods)
 - a significant reduction of safety margin beyond that irreparably introduced by the scenario

2. Examples of CTs involving essential safety actions include those for which a crew demonstrates the ability to...
 - effectively direct or manipulate engineered safety feature (ESF) controls that would prevent any condition described in the previous paragraph.
 - recognize a failure or an incorrect automatic actuation of an ESF system or component.
 - take one or more actions that would prevent a challenge to plant safety.
 - prevent inappropriate actions that create a challenge to plant safety (such as an unintentional Reactor Protection System (RPS) OR ESF actuation.

ATTACHMENT 4 SCENARIO REVIEW CHECKLIST

Note: Attach a separate copy of this form to each scenario reviewed. This form is used as guidance for the examination team as they conduct their review for the proposed scenarios.

SCENARIO IDENTIFIER:

REVIEWER:

Initials

Qualitative Attributes

- ___ 1. The scenario has clearly stated objectives in the scenario.
- ___ 2. The initial conditions are realistic, in that some equipment and/or instrumentation may be out of service, but it does not cue crew into expected events.
- ___ 3. The scenario consists mostly of related events.
- ___ 4. Each event description consists of--
 - the point in the scenario when it is to be initiated
 - the malfunction(s) that are entered to initiate the event
 - the symptoms/cues that will be visible to the crew
 - the expected operator actions (by shift position)
 - the event termination point
- ___ 5. No more than one non-mechanistic failure (e.g., pipe break) is incorporated into the scenario without a credible preceding incident such as a seismic event.
- ___ 6. The events are valid with regard to physics and thermodynamics.
- ___ 7. Sequencing/timing of events is reasonable, and allows for the examination team to obtain complete evaluation results commensurate with the scenario objectives.
- ___ 8. The simulator modeling is not altered.
- ___ 9. All crew competencies can be evaluated.
- ___ 10. The scenario has been validated.
- ___ 11. If the sampling plan indicates that the scenario was used for training during the Initial training Program, evaluate the need to modify or replace the scenario.

ATTACHMENT 5
ESG - CRITICAL TASKS

CT#1 - Isolate AFW flow to 21 SG within 10 mins. (Salem UFSAR Accident Analysis assumption)

CT#2 - Establish minimum Aux Feedwater flow to 22 S/Gs. (E-0--F)

CT#3 - Establish Feed & Bleed before the Pressurizer PORVs auto open. (FR-H.1--B)

Written Exam
Proposed
(Double Sided)

Which one of the choices below correctly completes the following statement concerning the Rod Selector switch?

The Rod Selector Switch should remain in AUTO...

- except as directed by the CRS.
- but may be placed in MANUAL for minor Tave adjustments.
- unless inserting rods during an ATWS, then MANUAL shall be selected.
- but if required to be placed in MANUAL, the CRS must directly observe all rod movement.

GENERIC

2.1 Conduct of Operations

2.1.1 Knowledge of conduct of operations requirements.

3.7 3.8

Exemption: b. Correct. Manual rod motion for Tave adjustments is permitted. a. While the CRS may direct the use of MANUAL Rod Control, the RO may use MANUAL control if necessary without direction from the CRS. c. If AUTO rod insertion will result in a higher rod speed, AUTO is preferred. d. There is no requirement for the CRS to directly observe MANUAL rod motion.

CONDUCT OF OPERATIONS	0300-00.00S-CONDOP-00	III.C.3	15	00	7
OPERATIONS STANDARDS	SH.OP-DD.ZZ-0004			1	

External Reference Application

Question Source: Question Application:

Question Source Comments:

Comment Type:

Caution tagging manually operated MOVs

A motor operated valve (MOV) has been manually operated. IAW NC.NA-AP.ZZ-0005, Station Operating Practices, which one of the following correctly identifies the specific information required to be printed on the White Caution Tag that is installed on the breaker of that MOV?

- The date and time the LCO for the Inoperable MOV expires.
- The Technical Specification LCOs in effect due to the Inoperable MOV.
- Direction for the MOV to be unseated by hand prior to the circuit breaker being closed.
- Direction for the MOV to be electrically cycled as part of the return to Operability Requirements.

c	S	Memory	Salem	2/22/99
2		1		

GENERIC

2.1 Conduct of Operations

2.1.1 Knowledge of conduct of operations requirements.

3.7 3.8

c. - correct answer, must ensure valve will move manually prior to putting power on it a. - not procedurally required d. - caution tags cannot direct component operation b. - LCOs tracked via other means

Station Operating Practices

NC.NA-AP.ZZ-0005(Q)

Attachment 5, 3.4.3

34

8

Actions Required for Examination

New

Given the following conditions:

- The on-coming Day Shift Reactor Operator (RO) is returning to shift after 4 days vacation
- Today is February 22, 1999

Which one of the following correctly identifies the date of the earliest Control Room Narrative Log the RO is required to review prior to participating in the shift turnover today?

February 20, 1999.

February 17, 1999.

February 15, 1999.

February 12, 1999.

a	R	Memory	Salem	2/22/99
Number	3	2		

GENERIC

2.1 Conduct of Operations

2.1.3 Knowledge of shift turnover practices.

3.0 3.4

a. - correct answer, review last 48 hours prior to taking shift b. - 5 days, last time on shift, after turnover complete c. - 7 days, after turnover if vacation longer than 7 days d. - 10 days

Shift Turnover Responsibilities	SC.OP-AP.ZZ-0107(Q)	3.4	3	10	
Shift Turnover And Logkeeping	0300-000.00S-TNOVER			1	2, 4

NRC Exam Bank

Significantly Modified

This is similar to question asked of SRO on last NRC exam 6/98. Changes made include dates, activities and which review conducted (prior to turnover vice following turnover). This question is limited to RO only.

Given the following conditions:

- Unit 1 is performing a startup on Day Shift
- The crew is preparing to synchronize the main generator to the grid
- The PO reports to the Control Room Supervisor (CRS) that the 0730 Technical Specification log readings are not completed
- Current time is 1030

IAW SC.OP-AP.ZZ-0110. Use and Development of Operating Logs, which one of the following correctly identifies the required actions? -

The Log readings...

- should be completed and reviewed before 1130.
- should be completed and reviewed before 1330.
- have been missed. Make an entry in the narrative log that readings have been missed.
- have been missed. Make an entry in the narrative log that readings have been missed and refer to Technical Specifications for any required actions.

Answer	a	Answer	B	Question	Memory	City	Salem	Company	2/22/99
Code Number	4	Question	3	Answer	2				

GENERIC

2.1 Conduct of Operations

2.1.9 Ability to direct personnel activities inside the control room.

2.5 4.0

b, c, and d. - the Tech Spec logs SHALL be completed and reviewed within 4 hours of specified time, no exceptions a. - correct answer

Use And Development Of Operating Logs	SC.OP-AP.ZZ-0110(Q)	5.2.2.E	13	5	
Shift Turnover And Logkeeping	0300-000.00S-TNOVER			01	5.a, 8

Question Source Command

Location New

Question Source Command

Counted Type

The Unit 1 on-shift CRS has noticed an obviously incorrect value logged on the previous shift's Control Room logs.

IAW SH.OP-DD.ZZ-0004, Operations Standards, which one of the following correctly describes the actions you should take to correct the log reading?

- The incorrect value shall be circled in red and the correct value, with an explanation, placed in the comments section.
- The incorrect value shall be circled in red and the correct value logged . These changes will be initialed and dated by the original operator when next on shift.
- A single line shall be drawn through the incorrect value, the correct value logged and the change dated and initialed. The correct value should then be circled in red with an explanation placed in the comments section.
- A single line shall be drawn through the incorrect value, the correct value logged and the change dated and initialed. The log cannot be submitted until the reading is also initialed by the original log taker.

Answer	c	B	Memory	Salem	2/22/99
Record Number	5	4	3		

GENERIC

2.1 Conduct of Operations

2.1.18 Ability to make accurate, clear and concise logs, records, status boards, and reports. 2.9 3.0

Explanations: a. - incorrect value should be lined out with single line d. - correct value should be red circled b. - log changes shall be initialed and dated immediately and by the operator making the changes c. - correct answer

Nuclear Business Unit Operations Standards	SH.OP-DD.ZZ-0004(Z)	5.4.1	36	1	
Shift Turnover And Logkeeping	0300-000.00S-TNOVER			01	8

Material Required for Examination

Question Source: New

Question Source: Comments

Comment Type	Comments

Which one of the choices below correctly completes the following statement concerning control of plant power changes?

For Mode 1 power changes ...

- neither the CRS nor OS is required to be notified in advance of a normal dilution for AFD control.
- the CRS does NOT need to be informed prior to reducing load in response to a Feedwater problem.
- the STA must be present at the controls for a power change of greater than 5%.
- the STA must verify all boration calculations prior to the evolution.

b

B

Memory

Salem

2/22/99

6

5

4

GENERIC

2.1 Conduct of Operations

2.1.20 Ability to execute procedure steps.

4.3 4.2

b. - correct answer, RO may take immediate action to respond to a plant transient without first notifying the CRS. a. - Either the CRS or OS are required to be notified. c. - not required d. - The CRS may review in place of the STA.

Operations Standards	SH.OP-DD.ZZ-0004	4.1.3	14	1	7
Use And Control Of Procedures	0300-000.00S-PROCED			02	6.b

New
 Revision
 Deleted
 Other

Excessive stroking of motor operated valves (MOV's) during surveillance testing has been identified as a reason for premature failure of motor actuators.

Which one of the following correctly identifies the procedural limit for full strokes on a MOV during surveillance testing IAW S1.OP-ST.SJ-0003, Inservice Testing Safety Injection Valves Modes 1-6?

2 per hour

3 per hour

4 per hour

5 per hour

b	B	Memory	Salem	2/22/99
7	6	5		

GENERIC

2.1 Conduct of Operations

2.1.32 Ability to explain and apply all system limits and precautions. 3.4 3.8

Explanation of Answer: INPO OMR-312 has identified that excessive stroking of MOV's during surveillance testing activities can lead to premature motor actuator failures. Salem has committed to limiting the number of Full Stroke MOV cycles to no more than 3 per hour.

SURVEILLANCES AND TESTING	0300-000.00S-SURV00-00	IV.B	27	8	13.b
INSERVICE TESTING SAFETY INJECTION VALVES MODES 1-6	S1.OP-ST.SJ-0003(Q)	3.3	3	5	

Material Required for Examination:

Question Source: Previous 2 NRC Exams **Editorially Modified**

Question Source Comment: Dropped the 1 per hour choice and added a 5 per hour. This also changed position of correct answer.

Comment Type: Comment

Unit 2 has been operating at power for several months. Due to an inadvertent dilution, the following power history occurred:

- 0300 - 100%
- 0315 - 100.1%
- 0320 - 100.3%
- 0325 - 100.5%
- 0330 - 100.8%
- 0335 - 101.2%
- 0340 - 101.8%
- 0345 - 101.5%
- 0350 - 100.9%
- 0355 - 100.2%
- 0400 - 100%

Which one of the following correctly completes the statement concerning Reactor Power?

The Control Room crew should...

- begin a shutdown due to exceeding Rated Thermal Power.
- reduce power to obtain a 24 hour average power of no greater than 100%.
- maintain power less than or equal to 100%. Since the transient is over no further action is required.
- reduce power so the average for the 12 hour shift is no greater than 100% power.

Answer	d	Points	R	Comprehension	0.00	Salem	Examine	2/22/99
Record Number	8	Points	7					

GENERIC

2.2 Equipment Control

2.2.2 Ability to manipulate the console controls as required to operate the facility between shutdown and designated power levels.

4.0 3.5

a. - correct answer, not allowed to intentionally raise power >100%, not possible for operator action to result in a 12-hour shift average of 100% if not there already b., c. & d. - limits for unintentional power excursions

IOP-4, Power Operations	0300-000.S-IOP004	II.C.6	12	01	2

Additional Required for Examinations

Question Source: New

Question Source Comments

Comment Type	Comment

SJ1, RWST to Charging Pump Suction valve has been manually operated and positioned fully open.

Which one of the following correctly describes how the Reactor Operator/Plant Operator know that particular valve has been manually operated?

- The OPEN indication will be illuminated and an Info Tag (sticker) will be affixed to the bezel.
- The OPEN indication will be illuminated and a White Caution Tag (sticker) will be affixed to the bezel.
- The position indication will be extinguished and a Red Blocking Tag (sticker) will be affixed to the bezel.
- The position indication will be extinguished and an Info Tag (sticker) will be affixed to the bezel.

Answer	id	R	Application	Salem	2/22/99
	9		8		

GENERIC

2.2 Equipment Control

2.2.13 Knowledge of tagging and clearance procedures.

3.6 3.8

Explanation of Answers: d. - correct answer, MOV power removed (position lights out) and caution tag hung b. - no position indication available c. - RBT on the power supply, not on switch a. - no position indication available, RBT on the power supply, not on switch

Station Operating Practices	NC.NA-AP.ZZ-0005(Q)	Attachment 5, 3.4.1 & 3.4.3	34	8

Material Required for Examination:

Question Source: New

Question Source Comment:

Comment Type: Common

Given the following conditions:

- A Red Blocking Tag (RBT) is hung on a 480 VAC breaker
- This breaker is tagged in the OPEN position
- The bus associated with this breaker is energized

Which one of the following correctly completes the description of the required tagging actions if this breaker is required to be removed from its cubicle for maintenance?

The RBT shall...

- be removed from the breaker but kept active and maintained in the physical possession of the Supervisor responsible for the job while the breaker is out of the cubicle.
- remain on the breaker. A White Caution Tag is installed on the safety rope/tape placed across the cubicle opening.
- be removed from the breaker. The same RBT is installed on the Foreign Material Exclusion device placed in the cubicle opening.
- remain on the breaker. An additional RBT is installed on the Foreign Material Exclusion device placed in the cubicle opening.

Answer	c	Exam Level	S	Memory	Salem	2/22/99
Record Number	10			6		

GENERIC

2.2 Equipment Control

2.2.13 Knowledge of tagging and clearance procedures.

3.6 3.8

d. - RBT shall be removed from the breaker a. - Tags cannot be kept "active" while removed for their designated equipment, component b. - rope required for energized bus but WCT not placed on it, RBT removed from breaker c. - correct answer

TRIS+ Tagging Operation	SH.OP-AP-ZZ-0015(Q)	Attachment 2, Electrical A	53	3

Question Source: New

Question Source: Comments:

Comment By: [Redacted]

Unit 1 is operating at 100% power. During a scan of control board indications, the RO observed the "VCT LEVEL HI-LO" & "VCT LEVEL LO MAKEUP NOT IN AUTO" console alarms illuminated and determined makeup controls were not restored to AUTO following a recent dilution. Makeup controls were placed in AUTO, VCT level restored and the console alarms cleared. No other audible or visual alarms were received. A check of annunciators indicates the CC2 Group alarm function is not working.

I AW SC.OP-AP.ZZ-0108, Removal/Return of Nuclear Safety Equipment, which one of the following correctly identifies the actions you should take for these conditions?

- Make a One Hour Report for a Loss of Annunciators.
- Initiate a Priority X AR to address the failure of the CC2 Group Console Alarm.
- Initiate a Priority "A" Action Request to address the failure of the CC2 Group Console Alarm.
- Begin a controlled shutdown due to loss of annunciators.

c	S	Memory	Salem	2/22/99
11		7		

GENERIC

2.2 Equipment Control

2.2.20 Knowledge of the process for managing troubleshooting activities. 2.2 3.3

c. - Correct. a. - Group console alarms are not considered "Annunciators" and do not require a one hour report. b. - The "X" designation refers to Significance Level not Priority Level and is used for business Processes or corrective maintenance items that are not adverse to quality. Control Console Alarms are definitely Adverse to Quality. d. - No requirement for a shutdown and certainly not until the problem can be quantified.

Reference	Number	Level	Number	Level
Removal/Return of Nuclear Safety Equipment	SC.OP-AP.ZZ-0108	Att. 7	45	8
Action Request Process	NC.NA-AP.ZZ-0000	Att. 2	20	3
Work Control Process	0300-000.00S-WORK00-00	VIII.A	30,31	00 7

Total Required/Recommended: _____

Position Source:

Position Source Form:

Comment type:

Given the following conditions with Unit 1 operating at 100% power:

- 11 Safety Injection (SI) Pump is out of service for repairs to 1SW169, SW Isolation to 11 SI Pump. Repairs are expected to be completed within the next 24 hours.
- A routine QA Audit of completed surveillance procedures has determined the quarterly surveillance performed on 12 SI Pump (Per S1.OP-ST.SJ-0002) 35 days ago was not properly completed.

IAW Technical Specifications, which one of the following actions is correct for this situation?

- Enter T.S. 3.0.3 but the required actions can be delayed for 24 hours IAW T.S. 4.0.3.
- Per T.S. 4.0.3, re-perform the surveillance on 12 SI Pump within 24 hours or enter T.S. 3.0.3
- Enter T.S. 3.0.3. The 25% allowance of T.S. 4.0.2 has been exceeded.
- Enter T.S. 3.0.3 until the LCO applicable to the SI Pumps is met.

Answer	a	Exam	S	Comprehension	Salem	2/22/99
Record Number	12			8		

GENERIC

2.2 Equipment Control

2.2.22 Knowledge of limiting conditions for operations and safety limits.

3.4 4.1

Explanation: a. Correct answer. 3.0.3 must be entered but the actions may be delayed IAW 4.0.3. b. 3.0.3 must be entered at the time of the discovery. c. 4.0.2 is the wrong specification. d. 3.0.3 may be exited when either SI Pump operability is restored.

Technical Specifications Surveillance Program	NC.NA-AP.ZZ-0012(Q)	4.5.1	8	7	
Surveillances And Testing	0300-000.00S-SRUV00			00	1.d, 2.b

Material Required for Examination:

Question Source: Utility Bank

Question Source Comments: 1997 LOR

Comment type	Comment

Given the following conditions:

- Both Units are operating at 100% power
- Reactor Engineering has determined that a single fuel assembly in the spent fuel pool needs to be moved to a new storage location and has initiated an Action Request for this movement
- This assembly has been in the pool (out of the reactor vessel) for 100 months
- The Operations Superintendent has given permission for this movement
- Radiation Protection has been notified of the movement

Which one of the following correctly completes the statement concerning the operations requirements for this evolution?

A Senior Reactor Operator...

is not required for this evolution.

shall be in the Fuel Handling Building during any fuel movement.

is not required if SFP boron concentration is verified to be >2000 ppm.

shall be on the crane trolley during any fuel movement.

Answer	a	Exam Level	S	Application	Salem	2/22/99
Record Number	13	Question Number		Answer Number	9	

GENERIC

2.2 Equipment Control

2.2.29 Knowledge of SRO fuel handling responsibilities. 1.6 3.8

c. - not a requirement for stationing an SRO b. - not required for non-core alt fuel handling a. - correct answer d. - An SRO is not required for fuel movement in the Fuel Handling Building.

Activity	Code	Element	Frequency	Weight	Priority
Conduct Of Fuel Handling	NC.NA-AP.ZZ-0049(Q)	5.1.2.A	7	1	
Conduct of Operations	0300-000.00S-CONDOP-00	V.A.5	38	00	2

Material Required for Examination

Question Source: New Question Source: Other

Question Source: Comment

Comment	Priority

An Equipment Operator received 450 mrem while visiting a foreign nuclear plant as part of a Technical Exchange Program. The Operator's prior exposure at Salem was 175 mrem for the current year.

If no exposure limit extensions have been authorized, which one of the following correctly lists the MAXIMUM additional non-emergency Total Effective Dose Equivalent (TEDE) that this individual could receive at Salem for the remainder of 1999?

1375 mrem

1825 mrem

3375 mrem

3825 mrem

a	B	Application	Salem	2/22/99
14	9	10		

GENERIC

2.3 Radiation Control

2.3.1 Knowledge of 10 CFR: 20 and related facility radiation control requirements. 2.6 3.0

Examination: a. - Correct 2000 mrem - 450 - 175 = 1375 mrem b. - All occupational is considered c&d 4000 limit is incorrect.

Standard For Protection Against Radiation	10CFR20	10CFR20.3.a(10)	325	1-1-92
Radiation Protection Program	NC.NA-AP.ZZ-0024(Q)	5.2.1, 5.2.2.B & Attachment 1	10, 11 & 32	8
Radiation Protection Program	0300-000.00S-RADCON			01 2.a), b)

Material Required for Examination				
Question Source	New			
Question Source - Company				
Question Type				

During implementation of the Emergency Plan, the Extended Yearly Dose Limit (TEDE) for a fully qualified Radiation Worker with documented lifetime dose is set at 4500 mrem.

Which of the following choices below correctly describes the process that accomplishes this extension?

The extension to 4500 mrem is....

- made upon the authorization of the Radiological Assessment Coordinator (RAC) for an Alert or higher.
- made upon the authorization of the of the Emergency Duty Officer (EDO) for a Site Area Emergency or higher.
- made automatically upon declaration of an Alert or higher.
- made automatically only upon declaration of a General Emergency.

c	S	Memory	Salem	2/22/99
15			11	

GENERIC

2.3 Radiation Control

2.3.4 Knowledge of radiation exposure limits and contamination control, including permissible levels in excess of those authorized. 2.5 3.1

c. Correct answer. a&b No authorization is required to raise the limit. d. Incorrect. Limit is raised at an Alert or higher.

Radiation Protection Program	0300-000.00S-RADCON	IV.E.1.a	15	01	3.a
OSC Radiation Protection Response	EPIP-304S	3.1	2	12	

Material Control Examination

Question Source: New

Question Source Comments:

Comments	Comment

Given the following conditions:

- An independent verification is required on two valves in an area with a 75 mr/hour dose rate
- Only one operator will be performing the independent verification

Which of the following correctly identifies the maximum time allowed for the independent verification before the requirement for the "hands-on" verification may be waived?

5 minutes

8 minutes

10 minutes

12 minutes

b	B	Application	Salem	2/22/99
16	10	12		

GENERIC

2.3 Radiation Control

2.3.10 Ability to perform procedures to reduce excessive levels of radiation and guard against personnel exposure.

2.9 3.3

Rad exposure limit for independent verification is 10 mrem. 75 mrem/hour/60 min/hour 1.25 mrem/minute
10 mrem/1.25 mrem/minute = 8 minutes b. - correct answer

Station Operating Practices	NC.NA-AP.ZZ-0005(Q)	Attachment 6, 1.4	37	8	
Conduct of Operations	0300-000.00S-CONDOP-00	III.J	24	00	10

Material Required for Examination

Condition Source: New

Application Source: []

Comments Type	Comments

Unit 2 is operating at 100% power with all systems operating normally. Intermediate Range (IR) Channel N35 failed several days ago and has been properly removed from service.

Which one of the following correctly identifies an expected crew response if a Reactor Trip were to occur?

- The Reactor Trip can be confirmed with one IR Channel. Completion of 2-EOP-FRSM-1, Response to Nuclear Power Generation, will not be required.
- The Reactor Trip cannot be confirmed with only one IR Channel. Completion of 2-EOP-FRSM-1, Response to Nuclear Power Generation, will be required.
- The Reactor Trip can be confirmed after the crew manually energizes the Source Range detectors. Completion of 2-EOP-FRSM-1, Response to Nuclear Power Generation, will not be required.
- The Reactor Trip cannot be confirmed since jumpers will be required to energize Source Range detectors. Completion of 2-EOP-FRSM-1, Response to Nuclear Power Generation, will be required.

a	B	Comprehension	Salem	2/22/99
Record Number: 17	11	13		

GENERIC

2.4 Emergency Procedures / Plan

2.4.1 Knowledge of EOP entry conditions and immediate action steps.

4.3 4.6

Examination of: a. - correct answer. The Reactor Trip can be confirmed with one IR Channel. b&d - The Reactor Trip can be confirmed. c. - The Reactor Trip can be confirmed with one IR.

Use Of Procedures	SC.OP-AP.ZZ-0102(Q)	5.3.5.D.1	11	5	
Use And Control Of Procedures	0300-000.00S-PROCEED			02	3.c

Material Required for Completion:

Question Source: 1/98 Salem NRC Exam

Question Source Comments:

Comment Type

Document

While directing Unit 2 operation in accordance with an Abnormal Procedure (AB), the Control Room Supervisor (CRS) reaches a step that reads: "SEND an operator to secure turbine gland sealing steam".

Which one of the following correctly completes the description of the actions the CRS should take?

The CRS may progress to the next step in the AB...

- if that next step is prefaced with: "IF AT ANY TIME".
- at any time, since ABs allow step performance in non-sequential order.
- after the Nuclear Equipment Operator has completed the step and has reported back to the Control Room.
- after the Nuclear Equipment Operator has been directed to perform the step and has acknowledged the order.

id	S	Application	Salem	2/22/99
Record Number	18			14

GENERIC

2.4 Emergency Procedures / Plan

2.4.11 Knowledge of abnormal condition procedures. 3.4 3.6

d. - correct answer, requirement here is to "send" an operator, once that is met can move to next step b. - no procedural guidance for this c. - not required, the required action was to "send" a. - continuous action steps are placed in effect once reached the first time.

Use Of Procedures	SC.OP-AP.ZZ-0102(Q)	5.4.2.C	23	5	
Use And Control Of Procedures	0300-000.00S-PROCED			02	2.a & 3.b

Material Required for Examination

Question Source: NRC Exam Bank Concept Used

Question Source Comment: Salem NRC Exam 07/96 - used idea for question, changed stem to different type of "action" verb, different correct answer, two new distracters, modified one distracter

Comment Type	Comment

While Unit 2 was operating at 100% power, a LOCA occurred. The crew has performed the actions of and are ready to transition out of EOP-TRIP-1 at step 28. The following conditions exist:

- All rods are fully inserted
- No RCPs are operating
- Nine (9) CETs are >700 degrees, no CETs are >1200 degrees
- Pressurizer level is 96%
- Containment pressure is 28 psig
- Containment Sump level is 52%
- RWST level is 17 ft.
- All loop Tc's are 300 degrees
- RVLIS indicates 43%
- RCS pressure is 265 psig

Which one of the following statements correctly identifies the next procedure to be implemented?

- EOP-LOCA-5, Loss of Emergency Recirc.
- EOP-FRCC-2, Response to Degraded Core Cooling.
- EOP-FRCI-1, Response to High Pressurizer Level.
- EOP-FRCE-1, Response to Excessive Containment Pressure.

Answer	b	Exam	R	Comprehension	Salem	2/22/99
Record Number	19		12			

GENERIC

2.4 Emergency Procedures / Plan

2.4.12 Knowledge of general operating crew responsibilities during emergency operations. 3.4 3.9

b. - Correct. Purple path exists for FRCC a. CAS requires EmergRecirc to be established and then lost.
c. - Yellow path d. - FRCC is a higher priority.

Use Of Procedures	SC.OP-AP.ZZ-0102(Q)	5.3.12	18	5	
Operator Fluency	0300-000.00S-FLUNCY-01			02	2.J

Material Required for Examination

Direction Source

Question Source Comments

Comment type	Comment

Given the following conditions on Unit 1:

- A trip has occurred from 100% power
- The Control Room Supervisor (CRS) is directing the actions of EOP-TRIP-1, "Reactor Trip Or Safety Injection"
- The Shift Technical Advisor is monitoring the Continuous Action Summaries
- The RCPs are tripped IAW the CAS

Which one of the following correctly describes how the trip of the RCPs should be captured as a permanent record?

- After the event, the Unit 2 CRS updates the narrative log from data recorded on the EOP Flow Charts.
- The CRS should direct the PO to log the event in the Narrative log.
- The CRS logs the event directly on the EOP Flow Charts.
- The STA logs all major plant manipulations during EOP usage.

c	S	Memory	Salem	2/22/99
20		15		

GENERIC

2.4 Emergency Procedures / Plan

2.4.13 Knowledge of crew roles and responsibilities during EOP flowchart use. 3.3 3.9

a. - no procedural requirement for this b. - EOP Flow Charts are used in place of the narrative log c. - Correct d. - The STA is an advisory position only and does not perform shift functions.

Use Of Procedures	SC.OP-AP.ZZ-0102(Q)	5.3.8	12	5	
Use And Control Of Procedures	0300-000.00S-PROCED			02	2.e, 3.b

Link to Question Bank:

Question Source:

Question Status/Comments:

Comment Type	<input type="text"/>

Given the following conditions for Unit 1:

- Reactor trip from 100% power due to steamline break and RCS leak.
- All RCPs have been tripped.
- SI and Steamline Isolation have actuated.

The STA notes the following:

- Intermediate Range NIs – 10E-03 Amps, -0.3 dpm
- RCS Tcold temperatures – 460 degrees F, lowering slowly
- RVLIS Full Range – 95% AND LOWERING
- All SG NR Levels – Off-scale Low
- Aux Feedwater Flow - 23E04lbm/hr to TWO S/Gs
- Containment Pressure - 11 psig, rising
- Pressurizer Level - Off-scale Low

Which one of the following correctly identifies the monitoring frequency required for the Critical Safety Function Status Trees?

- Continuous.
- Every 5 minutes.
- Every 15 minutes.
- Every 30 minutes.

Answer	a	Exam Code	S	Application	Salem	2/22/99
Record Number	21				16	

GENERIC

2.4 Emergency Procedures / Plan

2.4.21 Knowledge of the parameters and logic used to assess the status of safety functions including: 1. Reactivity control 2. Core cooling and heat removal 3. Reactor coolant system integrity 4. Containment conditions 5. Radioactivity release control. 3.7 4.3

Once EOP-CFST-1 has been initiated, the following rules apply to usage of the EOP network: 1) Monitoring should be continuous if any RED or PURPLE condition is found to exist, or 2) Monitoring frequency may be reduced to 10-20 minutes if all CFST indicate YELLOW or GREEN and plant conditions are stable. No PURPLE or RED conditions currently exist but containment pressure is approaching a Purple Path value.

OP-TRIP-1, REACTOR TRIP OR SAFETY INJECTION AND INTRODUCTION TO THE USE OF EOPs	0300-000.00S-TRP001-01	3.3.4	28	7, 10
USE OF PROCEDURES	SC.OP-AP.ZZ-0102(Q)	5.3.12.G	20	5

Previous 2 NRC Exams Significantly Modified

Changed initial conditions. Changed conditions such that only YELLOW conditions at worse exist. This changes correct answer.

Comments	

Plant conditions are such that a deviation from a Technical Specification LCO is "foreseen and required".

IAW NC.NA-AP.ZZ-0005, Station Operating Practices, which one of the following correctly describes the actions required for this entry?

Invoking 10CFR50.54(x) will:

- require immediate commencement of a unit shutdown.
- require notifying the NRC in advance if possible.
- be accompanied by declaring an Alert.
- require a notification of the NRC within 15 minutes .

Unit	b	Event	S	Category	Memory	Plant	Salem	Date	2/22/99
Record Number	22	Event Number		Event Code	17				

GENERIC

2.4 Emergency Procedures / Plan

2.4.30 Knowledge of which events related to system operations/status should be reported to outside agencies. 2.2 3.6

a. - not a requirement for a 50.54(X) invocation although will eventually be required b. - correct answer d. - one hour report must be made if 10CFR50.54(x) is invoked c. - 10CFR50.54(x) requires only a one hour report

Station Operating Practices	NC.NA-AP.ZZ-0005	5.4	7	9	
Event Classification Guide		11.1	1	00	
Tech Spec Lesson Plan	0300-000.00S-TECHSP-01	VII	48	01	26

Material Required for Examination

Question Source: New

Question Source Comments

Comment Type	Comment

Which one of the following correctly completes the statement of requirements for making notifications to the State and Local Agencies?

The Primary Communicator shall complete the notifications within 15 minutes after...

- the NRC Emergency Operations Center is notified.
- the Emergency Action Level condition is met.
- the Operations Superintendent makes the event classification.
- receiving the Initial Contact Message Form from the Emergency Coordinator.

c	R	Memory	Salem	2/22/99
23	13			

GENERIC

2.4 Emergency Procedures / Plan

2.4.39 Knowledge of the RO's responsibilities in emergency plan implementation.

3.3 3.1

a., b. & d. - the 15 time clock for completing notifications begins with the EC classifying the event c. - correct answer

Primary Communicator Log	ECG Attachment 6	A.2 Caution	1	06	

Initial Required: []

Question Source: New

Question Source Comment: []

Comment Type:	Comment:

During normal power increases, as turbine load is increased, which one of the following parameters is utilized to determine the output value of the Variable Gain Unit of the Rod Control Reactor Control Unit ?

Total Steam Flow

Auctioneered Hi Tavg

Turbine impulse pressure

Auctioneered Nuclear Power

c	R	Memory	Salem	2/22/99
Record Number	24	14		

001 Control Rod Drive System

A1. Ability to predict and/or monitor changes in parameters associated with operating the Control Rod Drive System controls including:

A1.02 T-ref 3.1 3.4

c. Correct. b,c,and d incorrect because the Inputs to VGU are Turbine Impulse pressure and Auctioneered Hi NIs.

Rod Control Lesson Plan	0300-000.00S-RODS00-0	IV.4.6.d	27-28		6

Material Contribution Examination

Question Source: NRC Exam Bank Editorially Modified

Question Source: Exam Bank

Comment type	

A SG feed pump trip occurred resulting in a turbine runback on Unit 2. Power was reduced from 100% steady-state conditions using a combination of rods and boration. The following conditions exist for Unit 2 following stabilization:

- Reactor Power - 60%
- Delta-I target value - -2.0%
- Actual Delta-I - -10.5%
- Control Bank D position - 160 steps withdrawn
- Tavg - 562°F

Which one of the following correctly describes actions that will maintain the current power level and maintain Delta-I within its normal operating band over the next FIVE hours?

- Boration and control rod insertion for AFD, followed by dilution for xenon compensation.
- Dilution and control rod insertion for AFD, followed by boration for xenon compensation.
- Boration and control rod withdrawal for AFD, followed by dilution for xenon compensation.
- Dilution and control rod withdrawal for AFD, followed by boration for xenon compensation.

Case	c	Unit	S	Comprehension	Field	Salem	2/22/99
Control Number	25			18			

001 Control Rod Drive System

A2. Ability to (a) predict the impacts of the following on the Control Rod Drive System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operation:

A2.06 Effects of transient xenon on reactivity 3.4 3.7

Xenon will begin to build in the upper portion of the core causing delta-I to become more negative if no action is taken. With delta-I currently near its lower limit, action must be taken to move the flux back toward the top of the core. This is accomplished by rod withdrawal, requiring boration to compensate for the reactivity addition. With control rods at desired location, then as xenon continues to build in, dilution is required to maintain power over the 5 hours. (NOTE: the initial boration also helps to move the flux profile upward due to redistribution associated with boron concentration effects.)
 Boration and control rod insertion will tend to drive delta-I further negative, and will lower Tave. Dilution and insertion will tend to drive delta-I further negative even if Tave is maintained. Dilution and control rod withdrawal will tend to raise Tave, which is NOT acceptable (even though delta-I tends to become more positive).

Reference Title	Reference Number	Section	Page	Version	Other
POWER DISTRIBUTION LIMITS	0300-000.00S-POWER0-00	I.C.2.a	21-22	1	

Material Required for Examination

Question Source: NRC Exam Bank Editorially Modified

Question Source Comments

Comments

Given the following:

- Reactor power at 90%
- Power Range N-41 failed HIGH fifteen (15) minutes ago
- Control rods are in MANUAL control
- An operator bypassed the rod stop, but did not defeat the N-41 input to the power mismatch circuit
- Tav_g is greater than T_{ref} by one (1) degree F

Which one of the following correctly describes the response of the rod control system if the Rod Selector Switch is placed in AUTOMATIC?

- Rods will not move.
- Rods will step in a few steps and stop.
- Rods will step in at 8 steps per minute.
- Rods will step in at 72 steps per minute.

Answer	a	Section	S	Comprehension	Salem	2/22/99
Record Number	26	Page		19		

001 Control Rod Drive System

K1. Knowledge of the physical connections and/or cause-effect relationships between Control Rod Drive System and the following:

K1.05 NIS and RPS 4.5 4.4

Rods will not move because the power mismatch circuit only produces an output when there is a rate of change between Rx and turbine power. Other answers are incorrect for the same reason.

RODS-00-00	IV.6.D.a)	27	5b

Question Source: NRC Exam Bank

Editorially Modified

Question Source / Comment:

Comment type	Count

Given the following:

- Reactor Power is 75%
- A failure of control rods to move in AUTO or MANUAL has occurred

Which one of the following correctly lists the function that is impaired if control bank D rods are moved using the CBD position of the Rod Selector Switch?

- The Pulse-To-Analog display for Control Bank D.
- Bank overlap function when rods are inserted.
- Rod Insertion Limit alarms when inserting control rods.
- Control Rod Stop alarm actuation when C-11 is reached.

Power	b	Assembly	R	Memory	Salem	2/22/99
Record Number	27		15			

001 Control Rod Drive System

K4. Knowledge of Control Rod Drive System design feature(s) and or interlock(s) which provide for the following:

K4.02 Control rod mode select control (movement control) 3.8 3.8

When Individual Bank positions are used, the Bank Overlap Unit is bypassed (GO pulses are not counted). Choices a, c, d, are not affected by operation with Individual Banks selected.

Rod control LP	RODS00-00	IV.B.8.f.7.	39	7d

Items Required for Completion

Question Source: Other Facility Question Update Information: Editorially Modified

Question Source Comment:

Comment type:

During the performance of an Estimated Critical Position for a given RCS boron concentration, the operator uses the BOL HFP Curves instead of the BOL HZP curves for determining rod worth for the current ECP at 58 steps on Control Bank D.

Which one of the following correctly describes the effect of this error when criticality is reached during the reactor startup using rod withdrawal?

- The ECP administrative limits for criticality will be exceeded.
- The critical rod position will be lower than calculated for the ECP.
- The critical rod position will be higher than calculated for the ECP.
- Additional boron must be added to attain the desired control rod position.

Answer	b	Exam	B	Comprehension	Salem	2/22/99
	28		16	20		

001 Control Rod Drive System

K5. Knowledge of the operational implications of the following concepts as they apply to the Control Rod Drive System:

K5.05 Interpretation of rod worth curves, including proper curve to use: all rods in (ARI), all rods out (ARO), hot zero power (HZA), hot full power (HFP) 3.5 3.9

The integral rod worths are BOL HZA - ~ 800 pcm and BOL HFP - ~ 870 pcm. With rod worth at ECP subtracted from critical rod worth in reactivity balance, Then contribution from rod worth in balance becomes more negative. Therefore, the calculated critical boron concentration will be less and criticality will occur sooner than expected (+ 70 pcm added to the BOL rod worth) or at 870 pcm on BOL curve which is at ~ 50 steps on CBD. This is well within the TS limits and minimum admin limits of +/- 300 pcm.

ESTIMATED CRITICAL POSITION	0300-000.00S-ECP000-00	I.C.1; II.B.9; IV.C.1.b	10; 14;20-21	2	
ESTIMATED CRITICAL POSITION	S2.RE-RA.ZZ-0001(Q)	Attachment 1,5.1 & 6	10-11		6
FIGURES	S2.RE-RA.ZZ-00132(Q)	Figure 4	8		33

Material Required for Exam 0006 BOL and EOL rod worth curve - S2.RE-RA.ZZ-0012(Q) Figure 4

Question Source: New

Creation Source Comments:

Comment Type	Comment

A loss of coolant accident has occurred. The RVLIS Summary Display Page is displaying dynamic range. During a cooldown and depressurization, void content indication remains constant at 80%.

Which one of the following correctly describes actual void content response during this cooldown and depressurization?

Actual void content:

- increased due to change in density as pressure and temperature decreased.
- decreased due to change in density as pressure and temperature decreased.
- remained constant; differential pressure alone is an accurate indication of void content.
- remained constant; indicated void content is compensated using pressure and temperature signals.

d	B	Comprehension	Salem	2/22/99
29	17	21		

002 Reactor Coolant System

K1. Knowledge of the physical connections and/or cause-effect relationships between Reactor Coolant System and the following:

K1.07 Reactor vessel level indication system .5* .7*

a&b assume not density compensated. C is incorrect because density compensation is required.

RVLIS LP	0300-000.00S-RVLIS0-00	IV.B.9	23		3,4

Metadata for Example

Question Source: Other Facility Editorially Modified

Question Source Comments:

Common Type:

The following conditions exist:

- Unit 1 is in Mode 4
- RCS temperature is 280 degrees F as indicated by In-core Thermocouples
- Pressurizer level indicates 30%
- RCS pressure is 350 psig
- 11 Residual Heat Removal (RHR) Pump is operating and all RCPs are OFF
- Loops 11 and 12 cold leg temperatures are 285 degrees F
- Steam Generator secondary temperatures are 330 degrees F

Which one of the following correctly describes the anticipated RCS pressure response and the reason for that response if the 12 RCP is started?

- Rises due to heating the RCS fluid as it passes through the Steam Generators.
- Lowers due to higher temperature loop water being cooled as it passes through the core region.
- Lowers because Pressurizer spray is initiated via bypass flow.
- Rises because letdown flow will be reduced.

QID	a	QID	B	Application	Salem	2/22/99
QID	30	QID	18	QID	22	

003 Reactor Coolant Pump System

A1. Ability to predict and/or monitor changes in parameters associated with operating the Reactor Coolant Pump System controls including:

A1.07 RCS temperature and pressure .4* 3.4

a. Correct. RCS pressure will rise during starting due to heat transfer from the secondary side of the S/G since they are hotter than the RCS. b. Water in core region is at the same temperature as the RCS so no pressure change as the RCS water passes through the core. c. While spray bypass flow may, the pressure affect will be negligible. d. Letdown flow is from RHR via CV8 and should not be affected by an RCP start.

RCP Operation	S1.OP-SO.RC-0001(Q)	3.2.7,8	4		15
IOP-2, Cold Shutdown to Hot Standby- LP	0300-000.00S-IOP002-00	II.D.2.b.5)	32	6d	

Question Source: NRC Exam Bank Editorial Source: Editorially Modified

Comment Type	

Unit 1 is in Mode 5, with the following conditions:

- RCS pressure is 120 psig
- Seal inlet temperatures, and #1 seal leakoff temperatures are approaching their alarm setpoints
- 11-14 CV104, #1 seal leakoff valves are open, but leakoff flowrates range from 0.4-0.8 gpm
- Total seal injection flow is 22 gpm

Which one of the following correctly describes a condition that must exist before the combined #1 seal leakoff bypass valve, 1CV114, may be opened per S1.OP-SO.RC-0001(Q), "Reactor Coolant Pump Operation"?

Seal leakoff flow must be raised to > 1 gpm for each pump.

RCS pressure must be reduced below 100 psig.

Seal injection flow must be greater than 6 gpm to each RCP.

CCW must be available to all RCP Thermal Barrier Hxs.

c	B	Memory	Salem	2/22/99
31	19	23		

003 Reactor Coolant Pump System

K1. Knowledge of the physical connections and/or cause-effect relationships between Reactor Coolant Pump System and the following:

K1.03 RCP seal system 3.3 3.6

RCS pressure must be 100-1000 psig to open the seal bypass valve, and seal injection flow must be greater than 6 gpm to each RCP. Seal leakoff flow must be 1 gpm or less to each pump. CCW flow is not a requirement to open the CV114.

RCP Operation	S1.OP-SO.RC-0001(Q)	5.2.1	8		15
RCP LP	0300-000.00S-RCPUMP-01	IV.B.15.c.7).a)	29	3biv	

Material Requirements List

INRC Exam Bank Editorially Modified

A RCP has just been started with RCS pressure at 325 psig.

Which one of the following correctly describes the reason that a minimum of 200 psid across the RCP seals is required for RCP operation?

- Prevents physical contact between the thermal barrier Hx and the seal package.
- Ensures that adequate seal cooling flow from the RCS is available.
- Prevents the #1 RCP seal from swapping from a face rubbing to a film riding seal.
- Prevents the weight of the seal ring from limiting cooling flow through the seal gap.

003 Reactor Coolant Pump System

K4. Knowledge of Reactor Coolant Pump System design feature(s) and or interlock(s) which provide for the following:

K4.04 Adequate cooling of RCP motor and seals 2.8 3.1

d. Correct. 2220 psid will support the seal ring and prevent contact with the runner. a. Contact with the thermal barrier Hx is not a concern. b. The 200 psid is not the driving force for cooling flow. c. Backwards. 200 psid prevents face rubbing operation.

RCP Lesson Plan	0300-000.00S-RCPUMP-01	IV.B.8.f.11).c) & 12).b)	20	12	
RCP Operation	S1.OP-SO.RC-0001(Q)	Prerequisites-2.3.3	2		

Question Source: NRC Exam Bank Direct From Source

Comment:	

Unit 2 is at 100% power with all systems in normal alignment and 21 Charging Pump in service. Due to a failure of the Master Flow Controller, the charging flow control valve, CV-55 has gone to the minimum flow position.

Which one of the following correctly describes the flow into the RCS?

- All pump flow will be through the mini flow valves CV139 and CV140.
- All flow will be to the charging header.
- All flow will be to the RCP seals.
- Reduced flow to the charging header and RCP seals.

004 Chemical and Volume Control System

A3. Ability to monitor automatic operations of the Chemical and Volume Control System including:

A3.14 Letdown and charging flows 3.4 3.1

When CV-55 goes to minimum flow stop, total flow will be 47 gpm. Since no other system changes were made, there will be reduced flow to both the charging header and to the RCP seals.

CVCS Lesson Plan	0300-000.00S-CVCS00-00	B.20.d.10.b)	47	4.a.xxv	
CVCS P&ID	205328				

Other Facility

Editorially Modified

Comment type:

The following plant conditions exist:

- Reactor power: 70%
- Rod control: automatic
- Letdown flow: 40 GPM

2CC71 (letdown heat exchanger temperature control valve) fails to the full closed position due to a temperature sensor failing low.

Which one of the following correctly describes the plant response to this event?

- VCT temperature rises causing a reduction in charging pump NPSH.
- Letdown flow increases due to decreasing backpressure.
- RCS boron concentration will slowly rise with the CVCS demineralizers bypassed.
- Pressurizer level will rise and VCT level will lower when CV7 closes.

ia	B	Application	Salem	2/22/99
34	22	25		

K1. Knowledge of the physical connections and/or cause-effect relationships between Chemical and Volume Control System and the following:

K1.18 CCWS 2.9 3.2

Explanation of Answer: a. Correct. Since cooling to the letdown HX is lost. VCT & charging pump suction temperature will rise causing a reduction in pump NPSH. b. Backpressure is not affected by CC71. c. Demins isolate but no affect on boron concentration will be seen. d. Backwards. CC71 will close if CV7 closes.

CVCS LP	0300-000.00S-CVCS00-00	IV.C.9,12	36	4,6	

Question Source: INRC Exam Bank **Editorially Modified**

Question Source Comment:

Comment type:	Comment:

A Large Break LOCA has occurred on Unit 2. All equipment started normally except the 21 RHR pump which tripped on overcurrent.

Which one of the following correctly describes all the ECCS Pump suction that are supplied from the discharge of the 22 RHR Pump following completion of the transfer to Cold Leg Recirculation?

- The 21 and 22 Charging Pumps.
- The 22 Charging Pump and 22 SI Pump.
- The 21 and 22 Charging Pumps, and the 22 SI Pump.
- The 21 and 22 Charging Pumps, and the 21 and 22 SI Pumps.

005 Residual Heat Removal System

A2. Ability to (a) predict the impacts of the following on the Residual Heat Removal System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operation:

A2.03 RHR pump/motor malfunction 2.9 3.1

During CL recirc, The outlet from the 22 RHR Hx (Discharge of 22 RHR Pump) is aligned to Charging Pumps suction header by opening 22SJ45. The 21 RHR Hx is aligned to SI Pumps suction header by opening 21SJ45. The SI and Charging Pumps suction headers are then crosstied by opening 21SJ113 or 22SJ113. The 22 RHR (or 21 RHR) Pump alone can feed both the Charging Pumps and through the crossover the SI Pumps. Typical alignment is supplying train-related components (such as RHR to CNMT Spray headers - 22 RHR supplies 22 CS spray header only).

RESIDUAL HEAT REMOVAL SYSTEM	0300-000.00S-RHR000-01	IV.C.2.2).f)	34-35		3.b

Additional Required for Examination

NRC Exam Bank Editorially Modified

Byron 98

Given the following conditions on Unit 2:

- Reactor power - 50%
- 21 RHR Pump tagout in progress
- Maintenance has requested that 21RH19, RHR Train Cross-connect Valve, and 21SJ49, Cold Leg Injection Isolation Valve be tagged out to facilitate work

IAW Technical Specifications, which one of the following correctly completes the description of the required response for this request?

The tagout...

- can be approved as long as 22RH19 is open.
- can be approved and covered under the umbrella of the TSAS for the RHR Pump.
- Should NOT be allowed since this would require stationing operators at manual RH12, RHR HX Bypass Valves.
- Should NOT be allowed because an entry into Tech Spec 3.0.3 would be required.

d	S	Comprehension	Salem	2/22/99
36		26		

005 Residual Heat Removal System

2.2 Equipment Control

2.2.24 Ability to analyze the affect of maintenance activities on LCO status.

2.6 3.8

d. Correct. Closure of either RH19 or either SJ49 makes both trains inoperable, IAW Tech Specs since each train is required to inject into all four cold legs. a. Water will still be injected into all four cold legs but not from each train. b. 3.5.2 does not address both trains inoperable. c. RH12 will not change the situation.

RESIDUAL HEAT REMOVAL SYSTEM

0300-000.00S-RHR000-01

X.A.1

59

13

Technical Specifications

3.5.2

183

TS Section 3.5.2

New

Which one of the following correctly describes an AUTOMATIC action that occurs when RWST level is <15 ft after a large break LOCA on Unit 2?

- RHR to SI suction valves (SJ45) OPEN.
- SI pump miniflow valve (SJ67, SJ68) CLOSE.
- SI to Charging Pump Crossover Valves (SJ113s) OPEN.
- RWST to Charging Pump suction valves (SJ1, SJ2) CLOSE.

C

B

Memory

Salem

2/22/99

37

24

27

006 Emergency Core Cooling System

A3. Ability to monitor automatic operations of the Emergency Core Cooling System including:

A3.03 ESFAS-operated valves 4.1 4.1

c. Correct a&b. Valves are not affected by swapover. d. SJ1 & SJ2 open not close.

ECCS LP	0300-000.00S-ECCS00-00	(V.F.5.b.3)	42	11

Material Required

Question Source: NRC Exam Bank Significantly Modified

Question ID

Comment Type	Comment

During a Unit 1 cooldown per S1.OP-IO.ZZ-0006, PS1 malfunctioned. The following temperatures and pressures were observed during a review of P250 trends:

Time	T cold	RCS pressure
0940	510 F	1700 psig
1000	500 F	1750 psig
1020	490 F	1850 psig
1040	483 F	1950 psig
1100	475 F	1850 psig
1120	470 F	1785 psig

Assume NO operator action occurred between 0940-1120 and all appropriate actions were taken per S1.OP-IO.ZZ-0006 prior to 0940.

IAW S1.OP-IO.ZZ-0006, which one of the following correctly describes the appropriate operator action if the current trends continue?

- Continue cooldown, no problem exists.
- Continue cooldown, but reduce cooldown rate.
- Stop the cooldown. Depressurize to 1500 psig to comply with pressure-temperature limits.
- Stop the cooldown and depressurization and block the low pressure SI.

Answer: d Name: B Comprehension Salem 2/22/99
 Record Number: 38 25 28

006 Emergency Core Cooling System

K4. Knowledge of Emergency Core Cooling System design feature(s) and or interlock(s) which provide for the following:

K4.05 Autostart of HPI/LPI/SIP. 4.3 4.4

a. Correct. a-c. During cooldown and depressurization, the low Pressurizer SI is blocked at 1915 psig. As pressure INCREASES above 1915 psig the SI is automatically UNBLOCKED. When pressure again drops below 1765 psig, an SI will occur.

Reference	ESF ID	ESF ID	ESF ID	ESF ID	ESF ID
ESF LP	0300-000.00S-ESF000-00	VII.B.1	50		21

Interlock/Exception

Question Source: New

Question Source: Common

Common Type: Common

Given the following conditions on Unit 2:

- RCS Tavg - 305°F and stable
- PRT parameters
 - Pressure - 3.5 psig
 - Level - 70%
 - Temperature - 98°F

One hour later when PRT PRESS HI (CC2) alarmed, the operator noted the following PRT parameters:

- Pressure - 10.2 psig
- Level - 81%
- Temperature - 126°F

Which one of the following correctly describes the conditions that resulted in the change in parameters?

- CVCS Letdown Relief Valve 2CV6 lifted.
- PRT to Vent Header Isol Valve 2PR15 failed closed.
- NT25, Nitrogen to the PRT was opened.
- PRT Water Supply Isolation Valve 2WR82 opened while filling RCP standpipes.

Answer	a	Exam Code	B	Comprehension	Salem	2/22/99
Record Number	39		26		29	

007 Pressurizer Relief Tank/Quench Tank System

K1. Knowledge of the physical connections and/or cause-effect relationships between Pressurizer Relief Tank/Quench Tank System and the following:

K1.03 RCS 3.0 3.2

d. While filling RCP standpipes, the operator opens 2WR80, PW TO CONTMT STOP Valve. If 2WR82 were to open, PW would begin to fill PRT. This increase in level would also raise PRT pressure but would not raise temperature. Failure of CVCS letdown relief or POPS actuation would result in higher temperature water going to PRT which will raise PRT temperature pressure and level. Closure of the vent valve and opening NT25 may raise pressure by would NOT affect level or temperature.

PRESSURIZER AND PRESSURIZER RELIEF TANK	0300-000.00S-PZRPRT-00	IV.B.8.g	37-39		3, 4
CONTROL CONSOLE 2CC2	S2.OP-AR.ZZ-0012(Q)	Bezel 3-22: G.1.a & b	51-55	10	

Material Required for Exam: RCS P&ID 205301 sh.1

Question source: NRC Exam Bank Revision/Modification: Significantly Modified

Question Source Comment: Vogtle 1993 exam

Comment Type	Comment

Which one of the following correctly describes the operation of the 2CC131, RCP Thermal Barrier Discharge Flow Control Valve?

The valve will close on Phase B Isolation...

- and high flow if in AUTO.
- and high flow if in AUTO or MANUAL.
- if in AUTO, but will close on high flow if in AUTO or MANUAL.
- if in AUTO or MANUAL, but will close on high flow only if in AUTO.

Answer	d	Barrel	B	Memory	Salem	2/22/99
Records	40		27		30	

008 Component Cooling Water System

A3. Ability to monitor automatic operations of the Component Cooling Water System including:

A3.05 Control of the electrically operated, automatic isolation valves in the CCWS

3.0 3.1

Explanation of A3: As given the RCP Thermal Barrier Isol valve CC-131 closes on CNMT Phase B signal regardless of whether it is selected to AUTO or MANUAL. The valve will close on sensed high flow of >= 175 gpm (for at least 4 sec), but is inhibited from automatic closure on high flow if selected to MANUAL.

Component Name	Part Number	Version	Revision	Notes
COMPONENT COOLING WATER	0300-000.00S-CCW000-01	V.A.5.a	38-39	4.d, 6.b

Installation Requirements/Exam/Notes

Description: New

Installation Source Comments

Comment Type: Caution

The following plant conditions exist:

- Steady state operation at 100% power
- The PZR Pressure Master Controller is in AUTO with I&C testing in progress
- Assume Pressurizer pressure control remains in automatic

Which one of the following correctly describes the IMMEDIATE automatic response of the system if a Technician error results in a step change in the Master Pressure Controller setpoint to 2360 psig?

- Spray valves close and Pressurizer heaters energize.
- Spray valves open and Pressurizer heaters energize.
- Power operated relief valves PR1 and PR2 open and spray valves close.
- Power operated relief valve PR1 opens, spray valves open, Pressurizer heaters de-energize.

Answer	a	B	Application	Salem	2/22/99
	41	28	31		

010 Pressurizer Pressure Control System

A1. Ability to predict and/or monitor changes in parameters associated with operating the Pressurizer Pressure Control System controls including:

A1.07 RCS pressure 3.7 3.7

Question: A step increase in the controller setpoint is seen as system pressure being too low. This will cause the spray valves to close and heaters to energize to raise pressure. Other distracters assume pressure is too high and/or controller failure.

Pressurizer Pressure and Level control LP	0300-000.00S-PZRP&L-00	IV.B.h-K	20-24	4a,5a,9

Question Source: NRC Exam Bank **Direct From Source**

Question Source Comment:

Comment Type: Continuation

Unit 1 is in Mode 5 performing steps to draw a bubble in the Pressurizer. The following steps have been completed:

- The Pressurizer is filled as indicated on the cold calibrated level channel
- All Pressurizer heaters have been energized
- Pressure is controlled at approximately 65 psig

The next major action is to manually open PR1 & PR2 for 10-15 minutes when the Pressurizer reaches approximately 300 degrees F.

Which of the following correctly describes the reason for opening PR1 & PR2?

- Required as part of the operability check for PR1 & PR2.
- Verification that the PORV tailpipe temperature device will respond to changes in temperature.
- Establishes flow from the RCS into the Pressurizer to ensure boron concentrations are equalized.
- Provides a flowpath for venting non-condensable gases out of the Pressurizer during bubble formation.

Author	id	Exam Level	R	Comprehension	Salem	2/22/99
Record Number	42	29				

010 Pressurizer Pressure Control System

2.1 Conduct Of Operations

2.1.23 Ability to perform specific system and integrated plant procedures during all modes of plant operation. 3.9 4.0

d. Correct. a. No procedural direction for this. b. Tailpipe temperature response can be verified by means other than fully opening PR1 & PR2. c. The RCS and Pressurizer are filled from the same source so there should be little difference in boron concentration.

Reference	Plant System	Version	Revision	Page	Total Pages
CVCS LP	0300-000.00S-CVCS00-00	V.B.2.v.2)	82-83		8

Micro Board Exam

Question Source: Previous two NRC Exam

Question Source Comment:

Comment Type	Comments

The following plant conditions exist:

- Unit 1 is at 100% power
- Pressurizer Level Channel 1 is selected for control
- Pressurizer Level Channel 2 is selected for alarm
- Pressurizer Level Channel 2 fails LOW

Which one of the following correctly completes the description of the immediate plant response assuming no operator intervention?

Charging flow...

- does NOT change, letdown isolates, and ALL Pressurizer Heaters shut off.
- will rise to maximum, letdown isolates, and ONLY Backup Pressurizer Heaters shut off.
- will rise to maximum, letdown isolation does NOT occur, and ALL Pressurizer Heaters shut off.
- does NOT change, letdown isolation does NOT occur, and ONLY Backup Pressurizer Heaters shut off.

Answer	a	Exam Level	B	Comprehension	Salem	2/22/99
Record Number	43	30	32			

011 Pressurizer Level Control System

K6. Knowledge of the effect of a loss or malfunction on the following will have on the Pressurizer Level Control System:

K6.03 Relationship between PZR level and PZR heater control circuit 2.9 3.3

Shutdown will isolate and all heaters will de-energize. Since channel was selected for alarm, no change in charging flow demand.

Component	Reference	Version	Revision	Count	Order
Pressurizer Pressure and Level control LP	0300-000.00S-PZRP&L-00	IX.B.2.d	43	12	

Material Required for Completion

Question Source: NRC Exam Bank Significantly Modified

Question Source Comments

Comment Type	Comment

Given the following plant conditions:

- Unit 1 is at 100% power
- Containment pressure Channel I indication becomes erratic
- The channel is removed from service IAW S1.OP-SO.RPS-0005.

Which one of the following correctly describes plant response if Containment Pressure Channel IV subsequently fails high?

- No response other than channel related alarms.
- An AUTO SI actuation on 2/3 channel tripped.
- AUTO SI, Containment Spray, Main Steamline Isolation and Phase B Isolation all actuate.
- Main Steamline Isolation and Phase B Isolation. Containment Spray valves reposition but the Containment spray pumps do not start.

a	B	Comprehension	Salem	2/22/99
Record Number	44	31	33	

012 Reactor Protection System

K4. Knowledge of Reactor Protection System design feature(s) and or interlock(s) which provide for the following:

K4.01 Trip logic when one channel OOC or in test 3.7 4.0

Explanation: a. Correct. Channel I does not input to the protection logic so the required coincidence is not satisfied and only the alarms associated with Channel IV will actuate.

System Name	System ID	Version	Revision	Year
REACTOR PROTECTION SYSTEM	0300-000.00S-RXPROT-00	V	34	00 12

Material Required for Examination

Revision Source: New

Revision Source: Contin. Use

Comment Type: Comment

RCS pressure has decreased to 1859 psig during a plant cooldown. Appropriate actions have been taken as required by S2.OP-IO.ZZ-0005, Minimum Load to Hot Standby. Subsequently, a large steamline break occurs downstream of the MSIVs.

Which one of the following correctly describes the ESF response to this break?

- No SI or Main Steamline Isolation will occur.
- BOTH a Main Steamline Isolation and an SI will occur.
- A Main Steamline Isolation will occur, but an SI will NOT occur.
- An SI will occur, but a Main Steamline Isolation will NOT occur.

013 Engineered Safety Features Actuation System

A1. Ability to predict and/or monitor changes in parameters associated with operating the Engineered Safety Features Actuation System controls including:

A1.05 Main steam pressure 3.4 3.6

The SI has been blocked below P-11 so will not occur. The Hi Steam Flow SI was blocked when Tave dropped below 543 degrees so MSI will not occur.

ESF LP	0300-000.00S-ESF000-00	VII.B.1	50-51	21

Material Requirements Examination

Allocation Source: Other Facility Editorially Modified

Question Source Comments

Comment Type

A valid Safety Injection (SI) signal is generated while a Blackout sequence is in progress.

Which one of the following correctly completes the description of SEC operation?

The MODE II sequence will...

- reset, and the MODE I Sequence starts.
- restart, and the MODE I Sequence is blocked.
- terminate and reset, loads started will be stripped and the MODE III sequence will load appropriate ECCS equipment.
- continue to completion, and then the MODE III Sequence will load appropriate ECCS equipment.

Answer	C	RAID	R	Memory	Salem	2/22/99
Question Number	46	33				

013 Engineered Safety Features Actuation System

K1. Knowledge of the physical connections and/or cause-effect relationships between Engineered Safety Features Actuation System and the following:

K1.01 Initiation signals for ESF circuit logic 4.2 4.4

Explanation: If a MODE II signal occurs, followed by a MODE I signal, the SEC will reset to MODE III and go through the proper sequence. The other distracters are possible MODE II actions with other signals.

SEC LP	0300-000.00S-SEC000-00	IV.D.1,5	21-23	8

Material Required for Examination:

Question Source: New

Question Source - command:

Command type: Common

Unit 2 was operating at 100% power when an automatic Safety Injection occurred due to a high steamline flow coincident with LO-LO Tave. The following conditions exist:

- The leak has been isolated
- All SI signals have been cleared
- Reactor Trip Breaker A failed to open and remains closed
- An I&C Technician has completed installing the P-4 jumper for Reactor Trip Breaker A IAW the required procedure
- All SI and RHR Pumps are stopped
- 21 CVC Pump is running and the BIT is isolated IAW EOP-TRIP-3, SI Termination

Which one of the following correctly describes Safety System response if a Pressurizer safety valve fails open and RCS pressure lowers below the automatic SI setpoint?

- SI automatically initiates from Train A.
- SI automatically initiates from Train B.
- SI automatically initiates from both trains.
- MANUAL SI must be initiated or equipment must be started/aligned individually.

Answer:	d	Exam Level:	B	Memory:		Facility:	Salem	Exam Date:	2/22/99
Record Number:	47	Q Number:	34	Q Number:	35				

013 Engineered Safety Features Actuation System

K4. Knowledge of Engineered Safety Features Actuation System design feature(s) and or interlock(s) which provide for the following:

K4.01 SIS reset 3.9 4.3

Explanation/Answer: With ECCS Pumps stopped, the SI must have been reset. Since the RTBs have not been cycled, auto SI will not occur so d. is the only correct answer.

Reference ID	Plant System	System	Part (000-10)	Time	Points
Reactor Protection System	0300-000.00S-RXPROT-00	VII.B.6	49-50	20d	10

Material Required for Examination:

Question Source: INRC Exam Bank **Question Source:** Direct From Source

Question Source/Commentary:

Comments:

Given the following:

- Unit 1 is operating at 30% steady state reactor power.
- I&C technician receives permission to perform a calibration on PR N-41.
- The I&C technician mistakenly pulls the fuses on N-42, realizes the mistake, reinserts the fuses for N-42 and pulls the fuses for the correct channel, N-41.

Which one of the following correctly identifies the actions that occur after the technician pulls the fuses for N41?

- High power rod stop
- PR rate trip
- PR neutron flux high setpoint trip
- Only expected alarms for N41

Issue	b	Form	R	Comprehension	Salem	2/22/99
Record Number	48	35				

015 Nuclear Instrumentation System

K4. Knowledge of Nuclear Instrumentation System design feature(s) and or interlock(s) which provide for the following:

K4.05 Reactor trip

4.3 4.5

Explanation of Answer: Pulling the fuses on the N-42 drawer causes the Power Range circuitry to fail Upscale actuating the rate trip for that channel. When the fuses are reinstalled, the Upscale trip clears but the rate trip requires manual reset. When the fuses are pulled for the second channel the Rate Trip for N41 occurs completing the 2/4 coincidence and the reactor trips.

Reference ID	Reference Title	Version	Revision	Revision
Excure Nuclear Instrument System LP	0300-000300S-EXCORE-00	IV.G.3.h	40	10e

Material Required for Examination

Question Source: NRC Exam Bank Editorially Modified

Question Source Comment

Comment

Intermediate Range (IR) compensating voltage fails LOW on one of the IR detectors. The reactor subsequently trips due to other causes, but the IR current on the failed detector does NOT go below 5.0 E-5 amps.

Which one of the following items correctly describes how the source range instruments will be energized as reactor power DECREASES below 7.0 E-11 amps?

- P-6 will be unblocked and the source range detectors will automatically reenergize.
- The failed IR detector will be bypassed allowing the source range detectors to energize.
- The source range manual reset pushbuttons will be used to manually reenergize the source range detectors.
- One source range detector will automatically reenergize and the other will be manually reenergized using the reset pushbuttons.

QUESTION CODE	c	QUESTION CODE	B	QUESTION CODE	Application	QUESTION CODE	Salem	QUESTION CODE	2/22/99
QUESTION CODE	49	QUESTION CODE	36	QUESTION CODE	36	QUESTION CODE		QUESTION CODE	

015 Nuclear Instrumentation System

K6. Knowledge of the effect of a loss or malfunction on the following will have on the Nuclear Instrumentation System:

K6.04 Bistables and logic circuits 3.1 3.2

Explanation: Both IRs must be below P-6 to reinstate the SRs. Both A&B RESET switches must be pressed.

Reference ID	Reference Description	Version	Page/Section	Other
Excore NIS LP	0300-000.00S-EXCORE-00	(V.D.2.h.4).a)	29	5b

Material Required for Examination

Question Source: NRC Exam Bank Editorially Modified

Question Source Comment

Comment type: Comment

The plant is shutdown in Mode 5 with RCS temperature at 100 degrees F. RCS pressure control is in a normal lineup for the current RCS pressure and temperature.

The following control board indications are noted:

- POPS INITIATED PRESSURE HI Bezel Alarm for Channel I
- CHANNEL I PRESSURE HI Bezel Alarm for Channel I
- PR1 NOT FULL CLSD OHA E-6
- PR1 indicates open

Which one of the following correctly identifies the transmitter that will give the above indications when it fails HIGH?

PT403

PT405

PT456

PT474

Answer	b	Exam Level	B	Memory	Salem	2/22/99
Record Number	50	Q Number	37	37		

K3. Knowledge of the effect that a loss or malfunction of the Non-Nuclear Instrumentation System will have on the following:

K3.01 RCS .4* .6*

Explanation of Question: PT403 only feeds PR2. PT 456 and 474 are alarm channels and are bypassed when POPS is in service.

Component	Reference	Version	Page	Count
Pressurizer Pressure and Level Control LP	0300-000.00S-PZRP&L-00	V.1.3.a	27	18

Material Required for Examination:

Question Source: New

Question Source Comments:

Comment Type	Comment

Unit 2 is operating at 100% power and has experienced a LOCA. The CET Display for the hottest in-core thermocouple reading is 688 degrees F. Temperature in the area of the Reference Junction boxes for the thermocouples is 100 degrees higher than it was prior to the LOCA.

Which one of the following correctly describes how the CET readings are affected by the temperature change in the area of the reference junction boxes?

The thermocouple readings will:

- read lower due to lower voltage differential between metals at the cold junction.
- read higher due to higher voltage differential between metals at the cold junction.
- remain the same because the reference junction boxes are thermally insulated
- remain the same because the temperature change is compensated for by the CET processor.

d	R	Comprehension	Salem	2/22/99
51	38			

017 In-Core Temperature Monitor System

A1. Ability to predict and/or monitor changes in parameters associated with operating the In-Core Temperature Monitor System controls including:

A1.01 Core exit temperature 3.7 3.9

A temperature sensor monitors the temperature at the reference junction boxes and provides an input to the CET processor to allow provide compensation for changes in ambient temperature.

System	Component	Version	Priority	Category	Code
Incore Instrument System - LP	0300-000.00S-INCORE-00	IV.D.2	30	00	7b

Material Required for Exam Prep

Question Source: NRC Exam Bank **Significantly Modified**

Question Source Comment

Comment Type

Given the following:

- Both Units are at 100% power
- All systems are normally aligned
- A loss of off-site power occurs

Which one of the following correctly completes the description of the response of the Containment Fan Cooling Units (CFCUs)?

The CFCUs are tripped and...

- must be manually restarted.
- one CFCU is started on each bus in high speed.
- then sequenced onto the safety-related electrical buses in the slow speed mode.
- then sequenced onto the safety-related electrical buses in normal high speed mode.

Answer	a	Answer	B	Answer	Memory	Answer	Salem	Answer	2/22/99
Record Number	52	Record Number	39	Record Number	38				

022 Containment Cooling System

A3. Ability to monitor automatic operations of the Containment Cooling System including:

A3.01 Initiation of safeguards mode of operation 4.1 4.3

From the 1990s Bkrs 1&2 are tripped by the SEC, an interlock trips bkr 3. There is no restart in MODE II.

Reference ID	Question Number	Question	Reference Number	Location	Page
Containment and Containment Support Systems LP	0300-0000.00S-CONTMT-00	IV.H.1.f.s)	70	5a	4

Facility Question Bank

Question Source: NRC Exam Bank Significantly Modified

Question Source: Common

Comment Type: Common

Which one of the following describes the flowpath through the Containment Fan Coil Units during a LOCA?

- Low speed flow through demister, then HEPA filter, then charcoal filter, then cooling coils.
- Low speed flow through demister, then roughing filter, then HEPA filter, then cooling coils.
- Low speed flow through demister, then HEPA filter, then cooling coils.
- Low speed flow through roughing filter, then demister, then cooling coils, then HEPA filter.

C	B	Comprehension	Salem	2/22/99
53	40	39		

022 Containment Cooling System

K4. Knowledge of Containment Cooling System design feature(s) and or interlock(s) which provide for the following:

K4.02 Correlation of fan speed and flowpath changes with containment pressure .1* .4*

Explanation of answer: c. Correct. a,b&c. CFCUs do not have charcoal Filters or roughing filters.

Reference Title	Activity Reference Number	Location	Reference to	Revision
Containment and Support Systems	0300-000.00S-CONTMT-00	III.	57	00 4

Material Required: 5.000000

Question Source: New

Question Source Comment:

Comment Type: Common

Which one of the following correctly describes the protection specifically designed to prevent a spurious actuation of Containment Spray (CS) as a result of a loss of power or a voltage fluctuation?

- A normally OFF key switch is provided in the CS pump start circuitry.
- The CS bistables energize to trip on Hi-Hi Containment Pressure.
- The CS bistables are powered from 125 VDC battery buses.
- An SI signal must be present for CS to actuate.

026 Containment Spray System

A4. Ability to manually operate and/or monitor in the control room:

A4.01 CSS controls 4.5 4.3

Explanation of Answer: a. The key switch is for manual actuation only. b. Correct. The CS bistables are the only SEC bistables that are energized to actuate. c. The bistables are DC powered but this does not prevent actuation on loss of power. d. An SI will be present but does not relate to a loss of power.

Component	Reference	Code	Frequency	Count	Notes
Containment Spray LP	0300-000.00S-CSPRAY-00	IV.B.15.e	29	4	

Version Control Log Extension

Question Source: New

Question Source: Comments

Revision	Comments

A Large Break LOCA has occurred. The 21 RHR pump has tripped on Overcurrent. The Recirculation phase is being implemented with Containment Spray required. The following conditions are noted:

- RWST level is at the LO LO alarm setpoint
- The second Containment Spray pump has been stopped
- The sump to RHR isolation valve 21SJ44 is CLOSED
- The sump to RHR isolation valve 22SJ44 is OPEN
- The RCS to RHR isolation valve 2RH1 is OPEN
- The RCS to RHR isolation valve 2RH2 is CLOSED

Which one of the following correctly describes the response of the RHR to CS System isolation valves 21CS36 and 22CS36 when their respective Open Pushbutton is depressed?

- Both valves will OPEN.
- Neither valve will OPEN.
- 21CS36 will OPEN and 22CS36 will NOT OPEN.
- 21CS36 will NOT OPEN and 22CS36 will OPEN.

Answer	d	Score	R	Comprehension	Salem	2/22/99
Record Number	55	42				

026 Containment Spray System

K4. Knowledge of Containment Spray System design feature(s) and or interlock(s) which provide for the following:

K4.01 Source of water for CSS, including recirculation phase after LOCA 4.2 4.3

Explanation of Answer: Either RH1 or RH2 must be closed AND the associated train SJ44 valve must be OPEN before the SJ36 valve will open.

Reference	Question Reference	Response	Examination ID	Question	Answer
Containment Spray LP	0300-000.00S-CSPRAY-00	V.B.1.k.	37	8	

Material Required for Examination:

Question Source: New

Question Source Comments:

Comment Type	Comments

Which one of the following correctly identifies the mechanisms for gaseous iodine removal from containment atmosphere?

- Iodine Removal Units both during accident conditions and during normal conditions.
- Containment Spray during accident conditions, and Iodine Removal Units during normal conditions.
- Containment Spray and Iodine Removal Units during accident conditions, and neither during normal conditions.
- Containment Spray and Iodine Removal Units during accident conditions, and Iodine Removal Units during normal conditions.

b	R	Memory	Salem	2/22/99
56	43			

027 Containment Iodine Removal System

K1. Knowledge of the physical connections and/or cause-effect relationships between Containment Iodine Removal System and the following:

K1.01 CSS .4* .7*

Explanation of Answer: Two iodine removal units (IRU) and fans are installed to reduce the airborne radioactivity levels, facilitate access to the containment, and to minimize doses to personnel. These units remove gaseous iodine and particulate radioactivity from the containment atmosphere as required for containment access during normal operation. b. A secondary purpose is to remove iodine from Containment atmosphere. A primary purpose is to maintain containment pressure less than design pressure following a high-energy line break (Main Steam Line Break or Large-Break Loss of Coolant Accident) inside Containment. C and d. incorrect because IRUs are not used during accident conditions.

System Name	Reference ID	Code	Count	Revision	Score
CONTAINMENT SPRAY SYSTEM	0300-000.00S-CSPRAY-00	II.B	14		1, 4.c
CONTAINMENT AND CONTAINMENT SUPPORT SYSTEMS	0300-000.00S-CONTMT-00	IV.A.1	74		1.e

Manual Required for Examination

Question Source: New

Question Source Comments

Comment Type	Comment

Containment Purge operations are in progress during MODE 5 operations. The following conditions are noted:

- 1R41D was determined to be inoperable prior to the start of the purge operation
- 1R12A is being continuously monitored

Which one of the following correctly describes conditions that will require immediate MANUAL termination of the purge operation IAW the Containment Purge to Plant Vent procedure, S1.OP-SO.WG-0006?

- 1R12B becomes inoperable.
- A downscale failure of 1R12A.
- A downscale failure of 1R11A.
- 1R11A becomes inoperable during the purge operation.

b	B	Comprehension	Salem	2/22/99
Record Number	57	44	41	

029 Containment Purge System

K1. Knowledge of the physical connections and/or cause-effect relationships between Containment Purge System and the following:

K1.01 Gaseous radiation release monitors 3.4 3.7

b. Correct. R12A is unique in that it does NOT have a downscale failure function. Continuous monitoring is required and if a downscale failure occurs, any release in progress must be terminated. a&d cause automatic isolation of purge due to Containment Vent Isolation signal. 1R11A is not required to be operable in MODE 5.

Equipment	Part Number	Location	Quantity	Unit	Notes
Containment Purge to Plant vent	S1.OP-SO.WG-0006(Q)	P&R	4		
Aux. Bldg. Vent LP	0300-000.00S-ABVENT-00			12	

Initial Review/Revision Summary

Revision Source: New

Revision Source Summary

Comment Type	Comment

Unit 1 Spent Fuel Cooling System is degraded and requires cross-connecting to Unit 2 Spent Fuel Cooling System.

Which of the following statements correctly describes the flowpaths associated with this evolution?

- Unit 1 Spent Fuel Pit is cooled by Unit 2 Spent Fuel Cooling Pumps and Heat Exchanger.
- Unit 1 Spent Fuel Pit is cooled by Unit 2 Spent Fuel Cooling Pumps using Unit 1 Spent Fuel Cooling Heat Exchanger.
- Unit 2 Spent Fuel Cooling System provides limited cooling to both Unit 1 & Unit 2 Spent Fuel Pits.
- Unit 1 Spent Fuel Pit is cooled by Unit 2 Spent Fuel Cooling System Heat Exchanger using Unit 1 Spent Fuel Cooling Pumps.

Answer	d	Points	100	Category	B	Memory	Salem	2/22/99
Question Number	58	Points	45	Question Number	42			

033 Spent Fuel Pool Cooling System

A2. Ability to (a) predict the impacts of the following on the Spent Fuel Pool Cooling System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operation:

A2.02 Loss of SFPCS 2.7 3.0

Explanation: During crossconnect operation, with Unit 2 SFPC System supplying, Unit 2 Pit receives no cooling flow. Unit 1 pit is cooled by Unit 2 heat exchanger using Unit 1 pumps.

Loss of SFP LP	0300-000.00S-ABSF01-00	18	9	00	2
Spent Fuel Cooling P&ID	205233			24	
SFPC Operation	S2.OP-SO.SF-0002	5.7	13	12	

Question Source: New

Common type: Common

The Unit 2 Advanced Digital Feedwater Control System (ADFWCS) average steam pressure calculation output has failed.

Which one of the following correctly describes the expected response of the Feedwater Control System?

- Only 21-24BF19 valves will switch to manual control mode.
- Only SGFP controllers will switch to manual control mode.
- Only 21-24BF19 and BF40 valves will switch to manual control mode.
- The 21-24BF19s, BF40s and both feed pump controllers will switch to manual control mode.

d	B	Memory	Salem	2/22/99
59	46	43		

The following plant conditions exist:

- Plant is operating at 55 percent power
- One main steam code safety valve inadvertently fully opens
- The plant continues to operate

Which one of the following correctly describes the approximate power level the plant will stabilize at if the valve remains OPEN?

57.5 percent.

60.5 percent.

65 percent.

75 percent.

b	B	Memory	Salem	2/22/99
60	47	44		

039 Main and Reheat Steam System

A2. Ability to (a) predict the impacts of the following on the Main and Reheat Steam System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operation:

A2.05 Increasing steam demand, its relationship to increases in reactor power 3.3 3.6

20 main steam safety valves (5 per loop) rated at 110%. One valve is approx. 5.5%. Other values math error choices.

Component	Reference	Code	Frequency	Priority	Notes
Main Steam LP	0300-000.00S-MSTEAM-00	III.B.4.	16	2	

Editorially Modified

NRC Exam Bank

Editorially Modified

Component	Reference	Code	Frequency	Priority	Notes

Given the following conditions on Unit 2:

- Reactor power was 65% when the turbine tripped and an ATWS occurred
- The reactor tripped 20 seconds later when Train A reactor trip breaker was locally opened
- Train B reactor trip breaker is failed closed
- No controls other than control rods and boration controls have been operated

Which one of the following correctly describes the operation of the steam dumps for these conditions?

Steam Dumps will...

- open immediately following the turbine trip and modulate to stabilize Tavg at its no-load value.
- open when the trip breaker is opened and modulate to stabilize Tavg at its no-load value.
- open immediately following the turbine trip and modulate to stabilize Tavg 5 degrees above its no-load value.
- open when the trip breaker is opened and will be blocked closed when Tavg falls below its low-low value.

Answer:	c	Exam Level:	B	Comprehension	Facility:	Salem	2/22/99
Record Number:	61	48	45				

041 Steam Dump System and Turbine Bypass Control

K4. Knowledge of Steam Dump System and Turbine Bypass Control design feature(s) and or interlock(s) which provide for the following:

K4.17 Reactor trip 3.7 3.9

Explanation: The following signals of concern will energize the arming solenoids: 1) Turbine load rejection as sensed by PT506 (>5% per minute or 10% step decrease); 2) Reactor Trip Breaker Train A open. Since the A breaker initially failed to open on the trip, the arming signal was provided by the loss of load. 1) If TAVG Control is selected and Reactor Trip Breaker, Train B (P-4) is closed (as in this case), the Load Rejection Controller controls Dump valve position based on TAVG error with an initial 5 degree dead band. So 'c' is correct. 'a' Would occur on "normal" trip or if the B Train breaker is open. "b" and "d" assume the steam dump arming signal does NOT occur until the A Train breaker is opened.

System	Reference	Code	Page	Other
STEAM DUMP SYSTEM	0300-000.00S-STDUMP-01	VI.A.1.a, V.A.9.c, IX.B.4	32, 36, 38-39	8, 10

Initial Control Data Explanation

Question Source

Question Source Comments

Comment Type	Comment

The following conditions exist on Unit 2:

- Reactor power 30%
- Turbine EHC Panel settings:
 - Turbine SETTER & REFERENCE - 36
 - IMP IN is selected
- Turbine Valve Position Limiter is set at the 100% power value
- The turbine impulse pressure channel input to EHC slowly fails to zero

Which one of the following correctly describes the response of the EHC controls to these conditions?

Turbine load will...

- remain constant. When the difference between REFERENCE and the input signal exceeds the setpoint, EHC will transfer to MANUAL control.
- increase until the difference between REFERENCE and the input signal exceeds the setpoint, then load will stabilize in IMP OUT control.
- increase until the difference between REFERENCE and the input signal exceeds the setpoint, then an alarm will alert the operator to select IMP OUT control.
- remain constant. When the difference between REFERENCE and the input signal exceeds the setpoint, an alarm will alert the operator to select MANUAL control.

b	R	Comprehension	Salem	2/22/99
62	49			

045 Main Turbine Generator System

A2. Ability to (a) predict the impacts of the following on the Main Turbine Generator System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operation:

A2.17 Malfunction of electrohydraulic control .7* .9*

Explanation: During "IMP IN" mode, if difference between actual 1st stage impulse pressure and the REFERENCE value exceeds the setpoint the following will occur: (1) LOAD CHAN light is illuminated; (2) Turbine automatically shifts to IMP OUT. The light is indicative of a loss of actual turbine impulse pressure signal.

ELECTRIC-HYDRAULIC CONTROL (EHC) SYSTEM	0300-000.00S-EHC000-01	V.B.2.c.2).o)	63		8
CONTROL CONSOLE 2CC3	S2.OP-AR.ZZ-0013(Q)	E.3 (Bezel 6-9)	43	10	

Question Source: NRC Exam Bank Editorially Modified

Question Source: Byron NRC exam 9/98.

Comment type:	Comment:

Unit 2 is at 50% power. 21 SGFP is manually tripped. 22 SGFP subsequently trips on a loss of Lube oil.

Which one of the following correctly describes the status of the Aux Feedwater Pumps?

- The motor driven AFW Pumps immediately start when the 22 SGFP trips.
- The motor driven AFW Pumps will not start until S/G levels drop below 9%.
- All AFW pumps auto start only if the jumpers were installed in the 21 SGFP trip circuit.
- All AFW Pumps immediately start when the 22 SGFP trips.

a	B	Comprehension	Salem	2/22/99
63	50	46		

059 Main Feedwater System

K1. Knowledge of the physical connections and/or cause-effect relationships between Main Feedwater System and the following:

K1.02 AFW System 3.4 .4*

a. Correct. Manual or auto trip of a SGFP is seen the same way by the AFW Pump start ckt so both MDAFW Pumps will start immediately. b. Same as a. c. Jumpers are no longer required due to circuit modifications. d. 23 AFW Pump does not start on SGFP trips.

Component	System	Revision	Order
Operator Fluency	0300-000.00S-FLUNCY-04	04	2

Material Reference to Examination

Question Source: New

Question Source: General

Comment Type	Comment

059 Main Feedwater System

K4. Knowledge of Main Feedwater System design feature(s) and or interlock(s) which provide for the following:

K4.16 Automatic trips for MFW pumps .1* .2*

Explanation of: c. Correct. Containment pressure at 4.4 psig will generate an SI signal which will trip both SGFPs simultaneously. a. SGFP trip is at 0' Hg. b. No direct trip of SGFP s from a MT trip. d. Feedwater interlock signal (P-4 with low Auctioneered Tave) closes the 19 and 40 valves only. A Feedwater isolation closes the 19,13, and 40 valves trips the feed pumps and the main turbine.

Item	Reference	Category	Priority	Impact	Notes
SGFP	0300-000.00S-SGFP00-00				

Material Required for Examination

Question Source: NRC Exam Bank Significantly Modified

Question Source Comments

Comments

The reactor is at full power. Auxiliary Feedwater pump 23 LOCAL/REMOTE switch has been inadvertently left in LOCAL at the Hot Shutdown Panel.

Which one of the following correctly describes the consequences of this error?

The 23 AFW Pump will start...

- if both SGFPs trip.
- when actuated by an AMSAC signal.
- on a loss of 125VDC control power.
- if the START switch in the control room is operated.

65	ic	B	Comprehension	Salem	2/22/99
65		52	48		

061 Auxiliary / Emergency Feedwater System

A2. Ability to (a) predict the impacts of the following on the Auxiliary / Emergency Feedwater System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operation:

A2.03 Loss of dc power 3.1 3.4

Explanation: c. Correct. On a loss of 125VDC control power, the steam inlet valve will fail open starting the pump. a. 23 AFW Pump does not start on SGFP trips. b.&d. Control Room Controls and all AUTO starts are disabled with the LOCAL/REMOTE switch is in LOCAL.

Component	Reference	Version	Count	Code	Order
AFW LP	0300-000.00S-AFW000-01	V.A.3.e	44	01	7

Match to Prod/Oper/Commissioning

Creation Source: New

Creation Source: Comments

Comments	Comments

A failure of the RPS has occurred following the loss of a single feed pump. Steam Generator narrow range levels lowered to a minimum of 3% and have stabilized.

Which one of the following correctly describes the plant response due to AMSAC actuation?

- All AFW pumps start and the main turbine trips 25 seconds after 3 of 4 S/G levels go below 5%.
- All AFW pumps start immediately after 3 of 4 S/G levels go below 5%.
- Main Turbine trips immediately and all AFW Pumps start 25 seconds after 3 of 4 S/G levels go below the reactor trip setpoint.
- All AFW Pumps start and the Main Turbine trips immediately after 3 of 4 S/G levels go below the reactor trip setpoint.

Answer	a	Feedback	R	Memory	Salem	2/22/99
Record Number	66		53			

061 Auxiliary / Emergency Feedwater System

K4. Knowledge of Auxiliary / Emergency Feedwater System design feature(s) and or interlock(s) which provide for the following:

K4.02 AFW automatic start upon loss of MFW pump, S/G level, blackout, or safety injection 4.5 4.6

The time delay is 25 sec. after 3/4 S/Gs is less than 5%.

AMSAC Lesson Plan	0300-000.00S-AMSAC0-00	III.B.1	11	2

Order/Revision/Description

Revision Source: New

Revision Source:

Revision Source:

Given the following conditions:

- Unit 1 is in MODE 3
- Unit 2 reactor power - 18%
- The Main Generator is synchronized to the grid
- Steam Dumps are closed.
- 21A, 22A and 23A Circulators have tripped.

Which one of the following correctly identifies the failure which would cause the simultaneous trip of these Circulators?

- A momentary undervoltage on the 2CW bus section 23.
- 3 SPT Differential Overcurrent.
- Breaker failure on 500 kV BS 9-10 (30X) breaker.
- Phase to Ground fault on the Salem 2CW 4KV bus Section 23.

d	B	Comprehension	Salem	2/22/99
67	54	49		

062 A.C. Electrical Distribution

A2. Ability to (a) predict the impacts of the following on the A.C. Electrical Distribution and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operation:

A2.01 Types of loads that, if de-energized, would degrade or hinder plant operation 3.4 3.9

d. Correct. A phase to ground fault would open the normal feeder breaker(23CW1AD) to 2CW bus sect 23. The crosstie breaker would NOT close and the Circulators would be lost. a. a 0.7 sec time delay should prevent circulator trips on momentary undervoltage conditions allowing the cross-tie to close and maintain voltage on the bus. b. 3 SPT Diff protection will de-energize the normal feed to the CW bus sect 23 but the CW bus cross-tie should close and maintain power to the circulators. c. The 30 X breaker failure opens the other generator output breaker (BS 1-9, 32X) and the BS 2-10 breaker (31X) which isolates the Hope Creek line.

System Name	System ID	Reference	Count	Options
CIRCULATING WATER SYSTEM	0300-000.00S-CW0000-00	IV.B.11.e.11)	33	5
4160 ELECTRICAL SYSTEM	0300-000.00S-4KVAC0-00	V.C.6.c	57	3.a
500KV ELECTRICAL SYSTEM	0300-000.00S-500KVO-00			6, 8

Material Requirements Example

Question Source: NRC Exam Bank Question Modification: Significantly Modified

Question Source Comments: 1992 exam. Modified premise. Selected two different distracters and modified other (except answer).

Comment Type	Comment

Which one of the following correctly describes the normal flowpath for power to the 115 Vital Instrument Bus D on Unit 2?

- DC power from the 2B 125 VDC Bus rectified to 120 VAC.
- AC power from 2C 230 VAC Vital Bus transformed to 120 VAC.
- AC power from the 2B 230 VAC Vital Bus, rectified to 140 VDC inverted to 120 VAC.
- AC power from 2C 230 VAC, stepped down to 140 VAC to the AC Line Regulator and reduced to 120 VAC.

c	B	Memory	Salem	2/22/99
68	55	50		

062 A.C. Electrical Distribution

K2. Knowledge of bus power supplies to the following:

K2.01 Major system loads 3.3 3.4

The D VIB is powered from the D VIB Inverter. Each Inverter receives power from an AC/DC Power Supply. The D AC/DC Power Supply receives power from the B 230 VAC Vital Bus and the B 125 VDC Bus. The normal supply is the AC input (correct answer) and the backup source of power is the B 125 VDC Bus (selection a). Other VIBs are supplied from their respective 230 VAC Vital buses (A-A, B-B, C-C, with D being the "odd" one) (Selection b). The emergency or "alternate" source of power is supplied to the output of each Inverter, supplied from the same associated 230 Vital Bus as above. The alternate power feed enters the AC Line Regulator Cabinet, passes through the Regulator AC Input Circuit Breaker and is stepped down to about 140 VAC. The voltage is the input to the AC Line (Static) Regulator which provides a constant 120 VAC output with a variable input (selection c).

Code	Reference	Answer	Points	Options
115VAC ELECTRICAL SYSTEMS	0300-000.00S-115VAC-00	V.A.b	17	3, 5

Initial Review Date: Examination

Question Source: INRC Exam Bank Significantly Modified

Question Source Comments: Byron 1996 NRC exam. Modified selections to agree with Salem power supplies. Changed premise to require determination of plant status for inputs.

Comment Type	Comment

063 D.C. Electrical Distribution

A4. Ability to manually operate and/or monitor in the control room:

A4.03 Battery discharge rate .0* 3.1

With the 2A1 charger OOS, the 2A2 Charger is a 100% charger and will supply the battery if required. But this charger must be manually aligned. The batteries are designed to last 2 hours at full discharge.

DC Electrical Systems LP	0300-000.00S-DCELEC-00	IV.B.2	16-18	3.b

Location of Control Room

Condition New

Equipment Size

Comment	

125 VDC breaker 2BDC1AX12, 2G 4KV Bus Control Power Supply (Reg) tripped due to a breaker malfunction.

Which one of the following correctly describe the affect this malfunction will have?

- 24 RCP will trip immediately.
- 24 RCP will remain running but will not trip if required.
- Emergency control power from the 2A 125 VDC bus will automatically be provided.
- 24 RCP breaker will trip if required but will not close to start the pump.

b	B	Memory	Salem	2/22/99
70	56	52		

063 D.C. Electrical Distribution

K4. Knowledge of D.C. Electrical Distribution design feature(s) and or interlock(s) which provide for the following:

K4.02 Breaker interlocks, permissives, bypasses and cross-ties.

.9* .2*

b. Correct. Breaker trip coils are energize to function. Without control power, the RCP will not trip. a. Same as b. c. No auto backup is provided. d. Same as b.

DC ELECTRICAL SYSTEMS	0300-000.00S-DCELEC-00		9	0	12
2A 125VDC BUS OPERATION	S2.OP-SO.125-0005(Q)	3	7	12	

Question Source: New

Creation Source Comment:

Scanned by:

Given the following conditions on Unit 2:

- The 2A 4KV Vital bus experienced a loss of bus voltage
- The 2A EDG energized the 2A 4kv bus
- The SEC sequenced loads in accordance with MODE II*
- The normal source to the bus is now available

Which one of the following correctly completes the description of the method for restoration of the normal power supply to the 2A 4KV Vital Bus IAW S2.OP-SO.DG-0001, 2A DIESEL GENERATOR OPERATION?

The EDG is...

- unloaded in Isochronous Mode and removed from the bus before the normal feeder breaker is closed.
- unloaded in Isochronous Mode, placed in parallel with the normal feeder breaker closed and then removed from the bus.
- transferred to Droop Mode, placed in parallel with the normal feeder breaker closed and then removed from the bus.
- transferred to Droop Mode when the SEC is reset, unloaded and removed from the bus before the normal feeder breaker is closed.

Answer	a	Exam Level	R	Memory	Salem	2/22/99
Record Number	71		57			

064 Emergency Diesel Generators

A4. Ability to manually operate and/or monitor in the control room:

A4.09 Establishing power from the ring bus (to relieve ED/G) .2* .3*

When conditions return to normal, Diesel Generator Operation operating procedure S1/2.OP-SO.DG-0001(Q), is used to return the EDGs to Normal-Standby mode. This involves unloading and removing EDG from the bus in current mode. This action is taken from the Control Room, and requires that vital bus be de-energized before a normal feeder breaker is closed. B. &c. require parallel operation.

Item	Reference	Section	Page	Revision
EMERGENCY DIESEL GENERATORS	0300-000.00S-EDG000-00	VII.A.2	87	8, 12
2A DIESEL GENERATOR OPERATION	S2.OP-SO.DG-0001(Q)	5.8	18	22

Normal
 New
 Deleted
 Modified

Given the following conditions on Unit 2:

- Reactor power - 100%
- 2A Emergency Diesel Generator (EDG) was being run to maintain engine oil temperature due to failure of the prelube pump during Preventive Maintenance
- The breaker feeding the jacket water heater on the 2A EDG tripped and CANNOT be re-closed
- Electrical Maintenance determines breaker and circuit wiring will need to be replaced
- Repairs are expected to take 30 hours

IAW Technical Specifications, which one of the following correctly describes the required actions?

- 2B or 2C EDG must be tested within the next 24 hours.
- 2B and 2C EDG must be tested independently within the next 24 hours.
- Periodically run 2A EDG to maintain Lube oil temperature.
- 2B and 2C EDG must be verified operable but neither EDG need be run within the next 24 hours.

QUESTION	b	ANSWER	S	Comprehension	Salem	2/22/99
Record Number	72	Page Number		Page Count	53	

064 Emergency Diesel Generators

2.1 Conduct Of Operations

2.1.12 Ability to apply technical specifications for a system. 2.9 4.0

With both the prelube pump and the jacket water heater inoperable, the EDG is considered inoperable. Per action of Tech Spec, the remaining EDGs must be started and run per surveillance to ensure operability. If the EDG had been made inoperable for preventive maintenance, the Tech Specs do NOT require operation of the remaining two EDGs. The Ops procedures direct that running of redundant diesel generator units for purposes of testing shall be performed independently (non-concurrently) to minimize common failure modes resulting from undetected interdependencies among diesel generator units (Reg Guide 1.108, Section C.2.b). Running the 2A D/G to maintain Lube Oil temperatures is not required since the D/G is inoperable.

EMERGENCY DIESEL GENERATORS	0300-000.00S-EDG000-00	VI.A, VII.C.1.b	95, 99-100	10, 12
Salem - Unit 2 Technical Specifications		3.8.1.1 Action b.	3/4 8-1	Amend 152
2A DIESEL GENERATOR OPERATION	S2.OP-SO.DG-0001(Q)	3.6 & 3.15	5-6	22

Technical Specifications Required for Compliance: TS 3.8.1.1

Question Source: New

Question Source: Comment

Comment Type	Comment

A steamline break inside containment and loss of off-site power have occurred on Unit 1. All D/Gs are running loaded in SEC Mode 3. All required equipment started and the crew has implemented 1-EOP-TRIP-1, Reactor Trip or Safety Injection. The SECs have not been reset. OHA alarm J-20, 1C DG URGENT TRBL and console bezel alarm 1C TROUBLE have actuated. The NEO dispatched to investigate reports the local annunciator panel alarm is HIGH LUBE OIL TEMPERATURE and Lube oil temperature is 208 degrees F.

Which one of the following is the correct response for this situation?

- Direct an NCO to block 1C SEC on the RP-1 Panel to avoid losing 1C 4KV Vital Bus when 1C SEC is reset in the EOPs.
- Direct the NEO to investigate and attempt to correct the problem. 1C 4KV Vital Bus will be lost if the SEC is reset with this problem standing.
- Direct the NEO to push the local EMERGENCY TRIP pushbutton. 1C EDG should have tripped automatically.
- Direct the NEO to trip 1C EDG at the fuel rack. The local EMERGENCY TRIP is not functional on a SEC start.

b	B	Application	Salem	2/22/99
73	58	54		

064 Emergency Diesel Generators

K4. Knowledge of Emergency Diesel Generators design feature(s) and or interlock(s) which provide for the following:

K4.02 Trips for ED/G while operating (normal or emergency) 3.9 4.2

b. Correct. Oil temp will not trip the D/G during a Mode OP. But if the SEC is reset and the oil temp is still valid, the D/G will trip. a. Blocking the SEC will a trip when reset occurs. c. Auto trip for oil temp is disabled during a Mode-Op. d. During an actual accident, it is not appropriate to trip the D/G for a Lube Oil temp problem.

EDG LP	0300-000.00S-EDG000-00	V.A.3.b.1).a)	82	6,9

NRC Exam Bank Significantly Modified

comment type	

Which one of the following correctly describes the condition that will cause the Steam Generator Blowdown Isolation Valves (GB4) to CLOSE on the Unit 2 Steam Generators?

- Auto start of Auxiliary Feed Pumps.
- High setpoint reached on any Main Steam Line Monitor, 2R46A-E.
- High setpoint reached on Condenser Air Ejector Monitor, 2R15.
- Warning on Steam Generator Blowdown Monitor, 2R19.

Answer	a	Feedback	R	Comments	Memory	Print	Salem	Date	2/22/99
Question Number	74	Points	59	Rating					

068 Liquid Radwaste System

A4. Ability to manually operate and/or monitor in the control room:

A4.04 Automatic isolation 3.8 3.7

The warning for 2R19 only closes GB10, 185, 50. 2R46's & 2R15 High Flow cause no auto action.

[redacted]	[redacted]	[redacted]	[redacted]	[redacted]	[redacted]
Steam Generator LP	003-000.00S-STMGEN-01	IV.B.10.g	31		6,9

[redacted]

[redacted] New [redacted]

[redacted]

[redacted]	[redacted]

Which one of the following correctly completes the description of the condition that ensures release limits are NOT exceeded when discharging the contents of a WGDT?

The Radioactive Gaseous Waste Release Valve (WG41)...

- will close when pressure exceeds 2.9 psig upstream of WG41.
- will close when pressure exceeds 5.3 psig downstream of WG41.
- must be adjusted to limit the discharge flowrate to 32 scfm during the release.
- is designed to limit the discharge flowrate to 32 scfm when the valve is full open.

Instal	d	EMPL	B	Memory	Salem	2/22/99
Record Number	75	60	55			

071 Waste Gas Disposal System

A4. Ability to manually operate and/or monitor in the control room:

A4.27 Opening and closing of the decay tank discharge control valve .0* .7*

the valve stroke is adjusted to limit the flowrate at 100% open, NOT throttled. There are no AUTO actions as a result of high pressure associated with WG41. 2.9 psig is an interlock preventing WG41 from opening. 5.3 psig is the constant pressure maintained upstream of WG41.

Equipment	Tag Number	Section	Quantity	Location
Rad. Waste Gas System LP	0300-000.00S-WASGAS00-00	IV.B.3	25	3.a.xi,4 .k

Material Requirements: 25 min

Question Source: New

Question Source Comments:

Equipment Type	

Which one of the following Radiation Monitors initiates safety related actions?

- WGDT (R42) Alarm.
- Control Room (R1A) Alarm.
- Containment Low Range (R2) Alarm.
- Fuel Handling Building-Spent Fuel Pit Area (R5) Alarm.

Answer	d	Level	R	Memory	Salem	2/22/99
Record Number	76		61			

072 Area Radiation Monitoring System

2.1 Conduct Of Operations

2.1.27 Knowledge of system purpose and or function. 2.8 2.9

d. Correct. Stops upward motion of the Fuel Handling crane. a&c. These monitors initiate no automatic action. b. R1B initiates Control room Vent Isolation but the R1A performs no auto action.

Room/Panel	Identification Number	Revision	Quantity	Position	Unit
RMS LP	0300-00.00S-RMS000-01	III.C.1.a	16		2

Material Required for Acquisition

Position SOURCE: New

Position SOURCE: Comments

Comment Type

Which one of the following correctly describes the effect on the GB4s (S/G Blowdown Outlet Isolation Valves) of a rising radiation condition on Unit 1 and Unit 2 R19D, Steam Generator Blowdown Liquid Monitor (14, 24 SG)?

- On Unit 1, only 14GB4 will close on warning alarm condition.
On Unit 2, all GB4 valves will close on high alarm condition.
- On Unit 1, all GB4 valves will close on high alarm condition.
On Unit 2, only 24GB4 will close on high alarm condition.
- On Unit 1, only 14GB4 will close on warning alarm condition.
On Unit 2, all GB4 valves will close on warning alarm condition.
- On Unit 1, all GB4 valves will close on warning alarm condition.
On Unit 2, only 24GB4 will close on high alarm condition.

073 Process Radiation Monitoring System

A4. Ability to manually operate and/or monitor in the control room:

A4.01 Effluent release 3.9 3.9

Unit 1 has NO warning alarm actions; Unit 2 does have warning alarm actions for other SGBD valves. On Unit 1, any R19 alarm closes all GB4 valves; On Unit 2 only the affected SG isolation valve is closed.

System	Reference	Location	Code	Revision
STEAM GENERATOR, SG BLOWDOWN AND DRAIN SYSTEMS	0300-000.00S-STMGEN-01	IV.B.10.g	31	9
RADIATION MONITORING SYSTEM	0300-000.00S-RMS000-01	IV.B.1.j	24	6.k, 11

Question Source

Previous 2 NRC Exams Direct From Source

On last NRC Exam Changed position of correct answer.

Comments

NRC This is also a Unit difference.

RP-1 OH Annunciator, MN STM MON R46A-D FAIL was received. Investigation reveals:

- LOW COOLANT FLOW and VALVE SHUT-OFF indicating lights on panel 158 have illuminated for Steam Line Radiation Monitors (2R46).
- It is noted that 2R46A and E monitors have lost coolant flow to their shields.

Which one of the following correctly describes the condition that will allow steam to be admitted to the remaining shields that are verified to have sufficient coolant flow?

- When the low coolant flow alarms are clear, the solenoid valves can be manually opened.
- All low coolant flow alarms must clear before the solenoid valves can be opened manually.
- The OVERRIDE key switch for each of the shields that have proper cooling flow is utilized to open their solenoid valves.
- The MANUAL STEAM SHUTOFF key switch for R46A is utilized to close its solenoid valve. Then the remaining solenoid valves can be opened manually.

1	c	S	Comprehension	Salem	2/22/99
78			57		

073 Process Radiation Monitoring System

A4. Ability to manually operate and/or monitor in the control room:

A4.02 Radiation monitoring system control panel 3.7 3.7

An override key switch is used to manually admit steam to shields which have not lost cooling flow. R46 does not have a manual steam shutoff or override keyswitch.

Item	Quantity	Unit	Location	Notes
RMS LP	0300-000.00S-RMS000-01		IV.B.4	49-50 8

Material required for completion:

Quantity: New

Comments	

Which one of the following correctly describes the protective feature for the CFCUs Service Water System on Unit 1 for a loss of off-site power?

- A travel stop on closing for SW-223, Outlet flow control valve, protects the piping from overpressure.
- A bypass line with orifices installed around SW-223, Outlet flow control valve, protects the piping from overpressure.
- A relief valve installed around SW-223, Outlet flow control valve, mitigates waterhammer when SW flow is re-initiated.
- A SW accumulator installed just upstream of SW-223, Outlet flow control valve, maintains CFCU Flow until Service Water Pumps are started by the Blackout sequencer.

b

R

Memory

Salem

2/22/99

79

63

076 Service Water System

K4. Knowledge of Service Water System design feature(s) and or interlock(s) which provide for the following:

K4.03 Automatic opening features associated with SWS isolation valves to CCW heat exchangers .9* .4*

On Unit 1 (and to be installed on Unit 2 - but currently provided only with relief valve) the orifices provide a path for overpressure protection around the 1SW223 valves. This is for the case of a LOOP where coastdown of the CFCU fans continue to add heat to water in CFCU with discharge valve closed (and inlet check valves closed) causing pressure to rise. As stated the relief valves provide same function on Unit 2. The accumulators are provided to maintain the CFCU piping full to prevent waterhammer when the SW pumps are re-started on the SEC. Only the SW57s Inlet Pressure Control have incorporated the travel stop. The travel stops are set at 100 gpm minimum flow position. This is in excess of the 67 gpm design flow through its respective relief valve SW-531 (Unit 2 only), so a stuck open relief valve will not drain the CFCU.

Component	Reference	Section	Page	Unit
SERVICE WATER - NUCLEAR HEADER	0300-000.00S-SW0NUC-01	IV.B.2.a 1) & 5)	21-24	4, 11

Question Source: New

Question Source Comments:

Common type: Common

NRC NOTE this question also incorporates Unit differences.

A rupture of the A Control Air header has occurred downstream of the supply from the Control Air Dryer and has resulted in lowering air pressure.

Which one of the following correctly completes the statement concerning operation of the 1CV3,4,5, Letdown Orifice Isolation Valves, on Unit 1 during this event?

The 1CV3,4,5, Letdown Orifice Isolation Valves, will be supplied adequate air for control due to...

- auto start of #3 Station Air Compressor on Unit 2.
- auto start of the Unit 1 Emergency Control Air Compressor.
- actuation of the Excess Flow Check Valve (EFCV) 1CA920.
- swap of the 1CV3,4,5, Letdown Orifice Isolation Valves Redundant Air Panel (Lunkenheimer) to the B header.

id	R	Comprehension	Salem	2/22/99
80	64			

078 Instrument Air System

K3. Knowledge of the effect that a loss or malfunction of the Instrument Air System will have on the following:

K3.02 Systems having pneumatic valves and controls 3.4 3.6

Explanation of d. Correct. The Lunkenheimer ensures that a loss of an individual CA header does not result in a loss of CA to instruments and/or air-operated devices required for an orderly and controlled shutdown. b. The header is backed up by #1 ECAC, NOT backed up by the #2 ECAC. a. The start of #3 SAC also does NOT provide assurance of maintenance of air supply due to location of leak. c. Excess flow check valves close to isolate loads or section of headers from the main supply. EFCV actuation will not occur here and would not help if it did.

CONTROL AIR SYSTEM	0300-000.00S-CONAIR-00	IV.B.9	26-27	4.1
LOSS OF CONTROL AIR	S1.OP-AB.CA-0001(Q)	Attachment 2	5	6

Material Required for:

Location/Source: New

Location/Source:

Location/Source:

Unit 2 is at the end of life with the following conditions:

- A plant startup is in progress
- Reactor power - 8%
- RCS boron concentration 100 ppm
- Control Bank D is at 138 steps
- Circuit failure at the RAISE RODS pushbutton results in outward rod motion

Which one of the following correctly identifies the condition that will terminate the power increase if NO operator action is taken?

- Power Range High Flux HI setpoint trip.
- Power Range High Flux LO setpoint trip.
- C-11, Control Bank D Fully Withdrawn Rod Stop.
- C-1, Intermediate Range High Flux Rod Withdrawal Stop.

d	B	Application	Salem	2/22/99
81	65	58		

001 Continuous Rod Withdrawal

AA2. Ability to determine and interpret the following as they apply to Continuous Rod Withdrawal:

AA2.04 Reactor power and its trend

4.2: 4.3

The rod stops and trips are applied in sections of rod control (Logic Cabinet and SSPS/reactor trip breakers) NOT affected by the given failure. From 8% power to 20% power, the power defect requires a reactivity insertion of approximately 200 pcm (S2.RE-RA.ZZ0012, Fig. 2). This corresponds to rod position of change from 138 steps to about 178-180 steps (S2.RE-RA.ZZ0012, Fig. 4). At this point C-1 actuates well below the associated C-11 position of 225 steps, Auto Rod Stop. Also C-11 is an AUTO rod stop only. The power range trips are at 25% and 109% power, respectively.

ROD CONTROL AND POSITION INDICATION SYSTEMS	0300-000.00S-RODS00-00	V.B.1.a & e; V.B.2.a.2	55-57	6, 12
REACTOR PROTECTION SYSTEM	0300-000.00S-RXPROT-00	V.A & V.D	34, 37	12, 13
Figures	S2.RE-RA.ZZ-0012(Q)	Figures 2 & 4	6, 8	33

S2.RE-RA.ZZ-0012(Q) Figure 2 (page 6) and Figure 4 (page 8).

New

Given the following conditions on Unit 2:

- A reactor startup is in progress
- All Shutdown Bank rods are fully withdrawn
- Control Banks A, B are fully withdrawn
- Control Bank C is being withdrawn at 210 steps
- Control Bank C rod H-14 dropped due to a fuse failure

Which one of the following correctly completes the statement about the status of the ROD BANK URGENT FAIL alarm (OHA E-40)?

The alarm actuates...

- only when the rod is being recovered.
- after the fuse failed and rod motion was commanded.
- as soon as the rod is misaligned by at least 12 steps.
- both when the rod dropped during motion and when the rod is being recovered.

Answer:	b	B	Comprehension	Salem	2/22/99
Record Number:	82	66	59		

003 Dropped Control Rod

AK3. Knowledge of the reasons for the following responses as they apply to Dropped Control Rod:

AK3.04 Actions contained in EOP for dropped control rod

.8* .1*

Explanation of: The alarm initially actuates due to Regulation failure in the power cabinet for SDC due to loss of power to the stationary coil. Since the rod is in Shutdown Bank C & D which have only ONE group of rods, the alarm is NOT actuated due to the motion of rods with the Lift Coil Disconnect switches open. Bank position has NO affect on alarm actuation.

Reference	Reference	Reference	Reference	Revision	Rev
ROD CONTROL AND POSITION INDICATION SYSTEMS	0300-000.00S-RODS00-00	IV.B.15.b.2), V.B.15.b.2)	48, 59		11
DROPPED ROD	0300-000.00S-ABROD2-00	II.C.1.e	8		4.A
DROPPED ROD	S2.OP-AB.ROD-0002(Q)	NOTE - 3.24	5	5	

Final Review of explanation

Approval Source: New

Approval Source: [Blank]

Comment type	Comment

Unit 2 was at 95% power with a power ascension in progress when PT-505 failed high causing control rods to be withdrawn at 72 steps per minute. When rods were placed in manual, the following conditions existed :

- Reactor power is 95%
- Current Group Counter positions for Control Bank D
 - Group 1 - 200 steps
 - Group 2 - 199 steps
- Current rod positions indications (IRPI and Plant Computer)
 - 1D1 - 180 steps
 - 1D2 - 199 steps
 - 1D3 - 200 steps
 - 1D4 - 200 steps
 - 2D1 - 186 steps
 - 2D2 - 199 steps
 - 2D3 - 199 steps
 - 2D4 - 200 steps
 - 2D5 - 200 steps

During troubleshooting all rods in Control Bank D inserted TWO steps but during restoration to initial position, B6 and H8 failed to withdraw. All rods were determined to be trippable.

IAW Technical Specifications, which one of the following correctly describes the action required to be taken?

- Enter and take the actions of Tech Spec 3.0.3.
- Reduce reactor power to less than 85% within 1 hour.
- Reduce power to less than 50% within 1 hour.
- No action is required until a 1 hour soak is completed.

id	S	Application	Salem	2/22/99
Record Number	83		60	

005 Inoperable/Stuck Control Rod

2.1 Conduct Of Operations

2.1.12 Ability to apply technical specifications for a system. 2.9 4.0

Explanation: c. Correct. Two control rods in the same bank are misaligned by > 12 steps (1D1 & 2D1). Since reactor power is >85% RTP, the 12 step limit applies, and Tech Specs 3.1.3.1 ACTION b and the AB requires the Unit be shutdown. a. TS 3.0.3 does not apply since TS 3.1.3.1 action b covers these conditions. b. The 85% power applies only for allowed value of misalignment and is NOT applicable to action. d. The 1 hour soak only applies below 50% power.

IMMOVABLE/MISALIGNED CONTROL ROD	0300-000.00S-ABROD1-01	steps 35-38	11		2.C
IMMOVABLE/MISALIGNED CONTROL RODS	S2.OP-AB.ROD-0001(Q)	3.35-3.37	6	6	
Salem - Unit 2 Technical Specifications		3.1.3.1 ACTION b.	3/4 1-13	Amend 48	

Material Required for Examination: Technical Specification 3.1.3.1

Question Source: New

Question Source - 50% result:

Comments:

Unit 2 is operating at 50% power. PR1 inadvertently opens.

Assuming no operator action, which one of the following correctly describes the plant response to this condition?

- Reactor Trip and Safety Injection on low pressure.
- Reactor Trip on OPDT and Safety Injection on low pressure.
- Pressurizer level will rise causing a Reactor Trip on high Pressurizer level and Safety Injection on low pressure.
- Safety Injection and Reactor Trip on High Containment Pressure

a	S	Application	Salem	2/22/99
84		61		

008 Pressurizer Vapor Space Accident

AA2. Ability to determine and interpret the following as they apply to Pressurizer Vapor Space Accident:

AA2.22 Consequences of loss of pressure in RCS; methods for evaluating pressure loss 3.8 4.2

a. Correct. With no operator actions, a vapor space leak will result in a reduction in Pressurizer pressure and an automatic Reactor Trip and Safety injection. b. OPDT is not affected by Pressure and will not cause a Reactor Trip on low pressure. c. With an open PORV, pressurizer level will drop until voiding occurs in the RCS. The Reactor will be tripped long before this occurs.

EOP-LOCA-01	0300-000.00S-LOCA01-00	2.1.3	6,21	00	3

Initial/Revised/Cancelled/Superseded

0300-000.00S-LOCA01-00

New

Commentary

Summary

Operators are performing the actions of 2-EOP-LOCA-2 "POST LOCA COOLDOWN AND DEPRESSURIZATION". A Pressurizer PORV is opened to de-pressurize the RCS to fill the Pressurizer. No RCPs are operating.

Which one of the following correctly describes the basis for stopping the depressurization when Pressurizer level is above 33%?

- Prevents isolation of CVCS letdown when a RCP is started.
- Ensures RCS subcooling is maintained when SI flow reduction is initiated.
- Maintains Pressurizer level above the SI reinitiation criteria when a RCP is started.
- Provides adequate Pressurizer level to maintain Pressurizer heaters operable as RCS voids collapse.

C	B	Comprehension	Salem	2/22/99
85	67	62		

009 Small Break LOCA

EK3. Knowledge of the reasons for the following responses as they apply to Small Break LOCA:

EK3.24 ECCS throttling or termination criteria

4.1 4.6

c. Correct. CAS for 2-EOP-LOCA 2 states: RCS subcooling 0°F OR PZR level CANNOT be maintained > 11%, Start ECCS Pumps as necessary to restore subcooling and Pressurizer level. At 1200 psig and 576°F, subcooling is <0°F which requires restarting ECCS Pumps IAW the CAS. a. Normal seal injection flow is between 6 gpm and 12 gpm per pump, so that flow < 24 gpm is outside the normal range but NO specific actions are required (and definitely starting ECCS pumps is NOT required). b. A cooldown may reduce Pressurizer level but no data is given to suggest level is below the 11% value of the CAS and a cooldown will raise subcooling. d. Pressurizer level of 17% is not at the CAS value.

EOP-LOCA-2, POST LOCA COOLDOWN AND DEPRESSURIZATION	0300-000.00S-LOCA02-01	3.2.7	14		2, 5
POST LOCA COOLDOWN AND DEPRESSURIZATION	2-EOP-LOCA-2	CAS	1	20	

Internal Review/Preparation

Author: [New]

Reviewed by: []

Approved by: []

During a Large Break LOCA, the Safety Injection Accumulators will inject water into the vessel.

Which one of the following correctly describes the accumulator injection?

The accumulators will inject...

during the Blowdown Phase.

after the Refill Phase.

during the Refill Phase.

after the Reflood Phase.

<input type="checkbox"/>	c	<input type="checkbox"/>	R	Comprehension	<input type="checkbox"/>	Salem	<input type="checkbox"/>	2/22/99
<input type="checkbox"/>	87	<input type="checkbox"/>	68	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

011 Large Break LOCA

EA1. Ability to operate and / or monitor the following as they apply to Large Break LOCA:

EA1.09 Core flood tank initiation

4.3 4.3

c. Correct. The injection of the accumulators is the refill phase and will fill the reactor vessel lower plenum with water. a. The Blowdown Phase occurs first and is the depressurization of the Reactor Vessel which allows the accumulators to inject. b. The accumulator injection is the refill phase. d. The Reflood Phase raises Reactor Vessel level into the core region and takes place after the accumulators inject.

Accident Type	Event ID	Phase	Time (min)	Level (ft)	Notes
Loss Of Coolant Accident	0300-000.00S-LOCA01-00	2.3.3	7,25	00	4

New
 Revised
 Deleted
 Other

A LOCA has occurred on Unit 2.

Which one of the following correctly identifies the reason RCPs are stopped if containment pressure exceeds 15 psig?

- RCP seal flow cooling is lost.
- RCP motor bearings will be damaged.
- RCP control may be lost since the electrical insulation is NOT qualified.
- Continued RCP heat input will contribute to containment pressure exceeding design limits.

011 Large Break LOCA

EK3. Knowledge of the reasons for the following responses as they apply to Large Break LOCA:

EK3.14 RCP tripping requirement

4.1 4.2

At 15 psig in the CNMT a Containment Isolation Phase B signal is generated, which will isolate CCW to the RCPs. The loss of CCW will particularly affect RCP motor bearings.

QUESTION	ANSWER	POINTS	STATUS	SCORE	GRADE
EOP-TRIP-1, REACTOR TRIP OR SAFETY INJECTION AND INTRODUCTION TO THE USE OF EOPs	0300-000.00S-TRP001-02	7.2.5	36		22
INTRODUCTION TO ENGINEERED SAFETY FEATURES AND DESIGN CRITERIA	0300-000.00S-ESF000-00	VII.B.4	52		21
REACTOR TRIP OR SAFETY INJECTION	EOP-TRIP-1	CAS	1	20	

Location of Exam

Source: NRC Exam Bank

Editorially Modified

Previous NRC exam B Grp SRO 61. Editorially changed both stem and answers. Change location of selections and correct answer.

Comments	Comments

The following conditions exist on Unit 2:

- Reactor power - 100% power for 4 months
- 24 RCP trips resulting in a reactor and turbine trip
- Plant stabilizes with steam dumps controlling at no-load Tavg

Which one of the following correctly completes the description of 24 SG pressure and steam flow parameters as compared with those of the unaffected loops?

24 SG pressure will be...

- lower and steam flow will be lower.
- the same and steam flow will be lower.
- the same and steam flow will be the same.
- higher and steam flow will be the same.

b	B	Comprehension	Salem	2/22/99
89	70	65		

015 Reactor Coolant Pump Malfunctions

AK1. Knowledge of the operational implications of the following concepts as they apply to Reactor Coolant Pump Malfunctions:

AK1.02 Consequences of an RCPs failure

3.7 4.1

With the RCP in the loop stopped, flow in the idle loop is reduced and heat transfer to the associated SG is less. Since all steam lines are connected, SG pressures will be the same. Steam flow will be lower due to reduced heat transfer.

Abnormality	Code	Category	Points	Version	Order
REACTOR COOLANT PUMP ABNORMALITY	0300-000.00S-ABRCP1-01	V.C	18		5.A

Material Requirements Summary

Revision Source: NRC Exam Bank Editorially Modified

Revision Source Summary: Previous NRC exam B Grp SRO 61. Editorially changed both stem (layout) and answers. Change location of selections and correct answer.

Revision Date	Revision Description

Given the following Unit 2 conditions:

- Reactor power - 100%
- No dilutions or borations in progress
- VCT level transmitter, 2LT114, fails HIGH

Which one of the following correctly completes the description of what occurs if NO operator action is taken?

VCT level...

- rises until CV35 modulates to HUT and maintains VCT level.
- lowers when CV35 diverts to the HUT.
- lowers faster than auto makeup capability causing charging suction to shift to the RWST.
- lowers with NO auto makeup capability causing charging suction to shift to the RWST.

90	b	B	Comprehension	Salem	2/22/99
90		71	66		

022 Loss of Reactor Coolant Makeup

AA1. Ability to operate and / or monitor the following as they apply to Loss of Reactor Coolant Makeup:

AA1.08 VCT level

3.4 3.3

b. Correct. LT-114 will modulate to the HUT at 80% to maintain level. a. When LT-114 fails high, CV35 will divert to the HUT and actual level will lower. c&d. Shift to the RWST requires low level from LT114 & LT-112 and will not occur with LT-114 failed high.

CHEMICAL AND VOLUME CONTROL SYSTEM	0300-000.00S-CVCS00-00	IV.G.1, IV.C.15, V.B.1.o	59, 38, 77	8.c, 9

Given the following for Unit 2:

- The reactor was shutdown 220 hours ago after extended power operation
- RCS Tavg - 155°F
- Pressurizer level - 20%
- RHR flow is 1600 gpm for this loop
- Time to core boiling is approximately 15 min.
- The 21 RHR Pump is available for immediate start

22 RHR Pump was in service for cooldown but has been stopped due to indications of cavitation. S2.OP-AB.RHR-0001, Loss of RHR has been entered.

IAW S2.OP-AB.RHR-0001, Loss of RHR, which one of the following correctly describes the action(s) required for this situation?

- A normal restoration and venting of the entire RHR System.
- Start any RHR pump and cycle the RH18s to rapidly change flow and sweep voids away.
- 21 or 22 RHR pump should be started at full flow to sweep voids away.
- The 21 RHR Pump should be started with suction from the RWST for adequate NPSH.

c	B	Application	Salem	2/22/99
91	72	67		

Which one of the following correctly identifies the leakage location for a CCW leak that would result in the fastest rate of rise of CCW Surge Tank? (Assume the size of the leak is equal at 0.25 square inches for each component.)

21 RHR Heat Exchanger with RHR providing shutdown cooling.

21 CCW Heat Exchanger aligned for cooling, at power.

No. 2 Spent Fuel Pit Heat Exchanger when in service, at power.

No. 2 Excess Letdown Heat Exchanger when in service, at power.

id	B	Application	Salem	2/22/99
92	73	68		

026 Loss of Component Cooling Water

AA1. Ability to operate and / or monitor the following as they apply to Loss of Component Cooling Water:

AA1.05 The CCWS surge tank, including level control and level alarms, and radiation alarm

3.1 3.1

The rate of rise of the CCW Surge tank level is dependent on in-leakage to CCW. With the leak size being the same size, the rate is directly proportional to the differential pressure across the leak site. In this case the expected (maximum) DP is experienced across the Excess letdown Hx. CCW pressure is ~95 psig; Excess letdown is 2235 psig (RCS pressure); RHR is 420 psig; SFPCS is 55 psig and SW (at CCW Hx) is 120 psig.

Component	Reference	Step	Page Numbers	Revision	Code
COMPONENT COOLING ABNORMALITY	0300-00S.000-ABCC01-00	III.A.2.e	13		1.B, 5.B
COMPONENT COOLING WATER	0300-000.00S-CCW000-01	IV.A.	16-18		3
COMPONENT COOLING ABNORMALITY	S2.OP-AB.CC-0001(Q)	Step 3.8	2	3	

Following a transient during which Pressurizer level fell below 17%, level was rapidly restored by increasing charging flow. During the transient, Pressurizer pressure fell to 2185 psig.

Which one of the following correctly identifies the reason why the pressure recovery from 2185 psig takes a longer time for this event, than it does if a PORV fails open and the PORV block valve was closed at 2185 psig?

- The volume of steam generation and cooling is greater with the level change.
- Subcooled water insurge during refill reduced the Pressurizer liquid space temperature.
- When the PORV opens, only the steam space needs to be reheated to raise pressure.
- The heaters are less effective since they had tripped off and cooled off on low PZR level.

93	b	B	Comprehension	Salem	2/22/99
93		74	69		

027 Pressurizer Pressure Control Malfunction

AK3. Knowledge of the reasons for the following responses as they apply to Pressurizer Pressure Control Malfunction:

AK3.04 Why, if PZR level is lost and then restored, that pressure recovers much more slowly 2.8 3.3

The level recovery introduces a large amount of subcooled water inventory into the Pressurizer. The process of heating the water to the saturation temperature takes a longer time than for the case where the water inventory remains saturated but at a lower pressure. This case does not require additional sensible heat to reach saturation.

System	Reference	Section	Page Number	Revision
PRESSURIZER PRESSURE AND LEVEL CONTROL	0300-000.00S-PZRP&L-00	III.B.1	15	2, 4
REACTOR COOLANT SYSTEM	0300-000.00S-RCS000-02	IV.C.3.a, c	19	4.c

NRC Exam Bank		Editorially Modified
Braidwood NRC Exam Oct. 1998		

Given the following conditions for Unit 2:

- 21 Charging Pump is in service
- Reactor power - 100%
- CVCS parameters:
 - Letdown flow (FI134) - 75 gpm
 - Charging flow (FI128B1) - 87 gpm
 - Total seal injection flow (FI115, 116, 143, 144) - 33 gpm
 - Controlling Pressurizer level channel LT-459 fails low

Assuming NO operator action is taken, which one of the following correctly completes the description of the effect on initial total seal injection flow?

Total seal injection flow will...

- be off-scale high on CC2 indication.
- decrease to about 20 gpm.
- remain approximately 33 gpm.
- increase to no more than 40 gpm.

d	B	Comprehension	Salem	2/22/99
94	75	70		

028 Pressurizer Level Control Malfunction

AA1. Ability to operate and / or monitor the following as they apply to Pressurizer Level Control Malfunction:

AA1.02 CVCS

3.4 3.4

d. Correct. The failure of the level instrument low increases charging flow and charging discharge header pressure. Since seal injection flow is normally increased by throttling close on CV71 to increase backpressure, the result is the same and seal injection flow will increase but will be limited to 40 gpm by the CV98s, Seal Injection Throttle Valves. a. Flow will increase but to not more than 10 gpm each which is on scale. b. If failed high, flow would decrease but not drop to zero due to flow stop on CV-55 which is set for 47 gpm. (Note with CV-71 in current throttled position, part of that flow would still go to RCS.) c. Flow will increase.

System	Code	Reference	Page	Section
PRESSURIZER PRESSURE AND LEVEL CONTROL	0300-000.00S-PZRP&L-00	IX.B.2	42	12
CHEMICAL AND VOLUME CONTROL SYSTEM	0300-000.00S-CVCS00-00	IV.C.20.d & 21	45, 47-48	3, 4

NRC Exam Bank

Editorially Modified

Byron NRC exam 9/1998.

Comment Type	Comment

An ATWS has occurred on Unit 2 and actions are being taken in accordance with 2-EOP-FRSM-1 "Response to Nuclear Power Generation." The operator initiated rapid boration flow by starting both Boric Acid Pumps, opening 2CV175 Rapid Borate Stop Valve, and closing 21 and 22CV160 BAT Recirc valves.

The following conditions exist:

- Reactor power - 3% ; SUR just negative
- RCS temperature (Tavg) - 550°F
- Pressurizer pressure - 2340 psig & rising slowly
- Pressurizer level - 29% & lowering slowly
- Control rods being inserted in MANUAL; Control Bank D is fully inserted
- Turbine is tripped
- Charging flow (FI128B) - 52 gpm
- Boration flow (FI113A) - 35 gpm

IAW 2-EOP-FRSM-1, Response to Nuclear Power Generation, which one of the following correctly describes the action the operator should take to increase the boration rate?

- Manually actuate Safety Injection.
- Locally open 2CV-174, Manual Boration Valve.
- Close 2CV40 and 2CV41, the VCT Discharge Stop Valves.
- Open a Pressurizer PORV and its associated PORV Stop Valve.

id	B	Comprehension	Salem	2/22/99
Record Number	95	76	71	

Which one of the following correctly identifies the parameters that must be satisfied in order to transition from 2-EOP-FRSM-1 "Response To Nuclear Power Generation"?

- The Cold Shutdown SDM value is achieved.
- No more than two control rods failed to insert.
- Either reactor trip breaker or the associated trip bypass breaker is open.
- Three Power Range NIS channels less than 5% and Intermediate Range SUR negative.

id	S	Memory	Salem	2/22/99
96		72		

029 Anticipated Transient Without Scram

EK3. Knowledge of the reasons for the following responses as they apply to Anticipated Transient Without Scram:

EK3.12 Actions contained in EOP for ATWS

4.4 4.7

d. Correct. The parameters for adequate shutdown is subcriticality as indicated on 3 PR NIS and a negative SUR on IR NIS. a. Boration is initiated and SDM verified before transition; however, the Cold Shutdown value is NOT required to be satisfied for transition. b&c. Attempts are made in performance of the procedure to insert rods and to open the reactor trip breakers; however, these are NOT satisfactory measures for ensuring the reactor shutdown and must NOT be met to transition.

EOP-FRSM-1 and 2 RESPONSE TO NUCLEAR POWER GENERATION	0300-000.00S-FRSM00-02	3.2.16, 3.2.17	32-34	7.B
RESPONSE TO NUCLEAR POWER GENERATION	2-EOP-FRSM-1	Step 16-17	2	20

Source/Reference Information:

NRC Exam Bank

Editorially Modified

Publication Source Information:

Catawaba 11/94 NRC Examination.

Comments:

The following conditions exist on Unit 2:

- Plant shutdown is in progress
- All power range channels indicate 6% reactor power
- Intermediate range channel N36 fails HIGH

Which one of the following correctly completes the description of the plant response to this failure?

The reactor will...

- NOT trip, but the Source Range channels will NOT automatically reinstate if the plant trips.
- trip on high IR flux, and Source Range channels will NOT automatically be reinstated.
- trip on high IR flux, and Source Range channels are automatically reinstated when N35 decreases to P6.
- NOT trip, but the Source Range channels will automatically be reinstated if the plant trips.

b	R	Comprehension	Salem	2/22/99
97	77			

033 Loss of Intermediate Range Nuclear Instrumentation

AA2. Ability to determine and interpret the following as they apply to Loss of Intermediate Range Nuclear Instrumentation:

AA2.04 Satisfactory overlap between source-range, intermediate-range and power-range instrumentation 3.2 3.6

With PR channels below P10, the IR high level trip is instated and when the one channel fails high this will generate a reactor trip. When power falls below P6 setpoint on IR channels, normally the SR channels are automatically energized and unblocked. However for this to occur BOTH IR channels must be below P6. Only one would be in this case, so operator action is required to energize the SR. If power was above 10% on 2/4 PR channels, the reactor would NOT trip on the failure with IR trips blocked.

NUCLEAR INSTRUMENTATION SYSTEM MALFUNCTION	0300-000.00S-ABNIS1-00	II.A.2, III.C.11	5, 11		1
EXCORE NUCLEAR INSTRUMENTATION SYSTEM	0300-000.00S-EXCORE-00	IV.D.3.e, IV.E.3.g	32-33, 39		9.d, 10
NUCLEAR INSTRUMENTATION SYSTEM MALFUNCTION	S2.OP-AB.NIS-0001(Q)	3.11 CAUTION	3	3	

Exam Bank	NRC Exam Bank	Significantly Modified
Exam Bank	Watts Bar NRC Exam 8/94.	
Exam Bank		
Exam Bank		
Exam Bank		

Given the following conditions on Unit 2:

- Reactor power - 9%
- Intermediate channel N-35 fails high
- Plant conditions remain stable at current power level

IAW NC.NA-AP.ZZ-0005, Station Operating Practices, which one of the following correctly describes required operator actions?

- Manually trip the reactor.
- Reduce power to <5% within 15minutes.
- Maintain power below P10.
- Raise power to greater than P10 setpoint and block both intermediate ranges.

Time	a	Equipment	S	Memory	Salem	2/22/99
98				73		

During Unit 1 refueling, a fuel bundle is dropped during the transit from the upender to the core. Only the bundle that was dropped is damaged.

Which one of the following correctly describes the potential radiation hazzard associated with this event?

- None. All Iodine will be removed by absorption into the Refueling Cavity Water.
- Minimal to personnel inside containment. A small % of Iodine will enter containment and will be removed by starting the IRUs.
- An off-site release will occur through any open containment penetrations and will exceed 10CFR100 limits.
- None. The IRUs are required to be operating during refueling operations and will remove all Iodine released from the bundle.

b	S	Comprehension	Salem	2/22/99
99		74		

036 Fuel Handling Incidents

AK1. Knowledge of the operational implications of the following concepts as they apply to Fuel Handling Incidents:

AK1.01 Radiation exposure hazards

3.5 4.1

b. Correct. If water level is >23 ft, 99% of the iodine contained in 10% of the gap space will be removed by the water as the gas bubbles to the surface. The 1% that is released to the containment is removed by the IRUs. a. See 'b' Some iodine is released to containment atmosphere. c. Accident analyses show that CFR100 limits will not be exceeded. d. IRUs are only started if iodine is detected in containment by chemistry sample.

FUEL HANDLING ACCIDENT	0300-000.00S-ABFUEL1-00	III.C.11	12	3
FUEL HANDLING INCIDENT	S2.OP-AB.FUEL-0001(Q)	Attachment 1	7	1
FUEL HANDLING INCIDENT TECHNICAL BASES DOCUMENT	S2.OP-AB.FUEL-0001(Q)	2.3	4	2

QUESTION SOURCE	NRC Exam Bank	EDITORIAL MODIFIED	Editorially Modified
QUESTION SOURCE	Salem BRGP NRC exam. Changed wording and layout of premise. Changed positions for answers.		
QUESTION TYPE	Multiple Choice		

Given the following conditions on Unit 2:

- Primary to secondary leak has been diagnosed in the 21 S/G
- Operators are performing actions of S2.OP-AB.SG-0001(Q) "STEAM GENERATOR TUBE LEAK"
- Unit cooldown from Hot Shutdown conditions has been commenced
- 21 SG has been isolated

Which one of the following correctly identifies the radiation monitor that would be used to continue trending of the primary to secondary leak rate?

Main Steam Line Monitor 2R46A.

Main Steam Line Process (N-16) Monitor 2R53A.

Steam Generator Blowdown Liquid Monitor 2R19A.

Condenser Air Removal and Priming System Process Monitor 2R15.

<input type="checkbox"/> C	<input type="checkbox"/> B	Comprehension	Salem	2/22/99
100	78	75		

037 Steam Generator Tube Leak

AA2. Ability to determine and interpret the following as they apply to Steam Generator Tube Leak:

AA2.01 Unusual readings of the monitors; steps needed to verify readings

3.0 3.4

All monitors can be used to determine Rad levels associated with a S/G tube leak. By procedural direction 2R19, 2R15 and 2R53 are particularly trended for determination of action. The steamline monitors, in particular the N-16 monitor, is NOT effective once the unit is shutdown (< MODE 1). 2R15 would NOT be effective since the Main Steam Stop for 21 SG is closed and the cooldown is being performed by cooling the remaining SGs. Therefore only the SG Blowdown monitor (sample) would be the only monitor directly aligned to the leaking SG.

Event Description	Reference	Code	Page Number(s)	Revision	Page(s)
STEAM GENERATOR TUBE LEAK	0300-000.00S-ABSG01-01	II.A.1.c, III.C.8	8, 12		3
STEAM GENERATOR TUBE LEAK	S2.OP-AB.SG-0001(Q)	Attachment 1, CAS	2	10	
STEAM GENERATOR TUBE LEAK TECHNICAL BASES DOCUMENT	S2.OP-AB.SG-0001(Q)	2.1	6	10	

New
 Revision
 Comment Type: Comment

Given the following conditions on Unit 2:

- A SGTR has occurred on the 22 S/G
- 2-EOP-SGTR-2 "POST SGTR COOLDOWN" is the procedure in effect
- Backfill method is being used
- The 23 RCP is running
- Due to a malfunctioning spray valve, RCS pressure dropped causing 22 S/G Narrow Range level to indicate off-scale low

Which one of the following correctly identifies the main concern for this condition?

- Primary dilution from the S/G back leakage will result in core criticality.
- S/G depressurization will occur reinitiating primary-to-secondary leakage.
- Pressurizer level will fall below the minimum value resulting in automatic starting of SI Pumps.
- Heat removal from the RCS is reduced such that the optimal cooldown rate CANNOT be maintained.

b	R	Comprehension	Salem	2/22/99
101	79			

038 Steam Generator Tube Rupture

EK3. Knowledge of the reasons for the following responses as they apply to Steam Generator Tube Rupture:

EK3.06 Actions contained in EOP for RCS water inventory balance, S/G tube rupture, and plant shutdown procedures 4.2 4.5

Explanation of Answer: If the U-tubes uncover, the ruptured SG pressure could rapidly decrease due to condensation of steam on the cooler surface of the U-tubes. This rapid depressurization could reinitiate break flow. Re-criticality is a concern in the event the first RCP started is in the ruptured loop following natural circulation. Pressurizer level is a concern but under given condition auto starting of ECCS equipment is NOT expected (SI blocked). Heat removal from the RCS is accomplished through the intact S/Gs. However, by allowing ruptured S/G level to fall in the NR (where the tubes remained covered) without feed, the S/G will remain at higher pressure (temperature).

PROBABLE CAUSE	QUESTION NUMBER	QUESTION	ANSWER	POINTS	STATUS
EOP-SGTR-2, POST STEAM GENERATOR TUBE RUPTURE COOLDOWN	0300-000.00S-SGTR02-01	2.1.2	9	1, 6	
STEAM GENERATOR, SG BLOWDOWN AND DRAIN SYSTEMS	0300-000.00S-STMGEN-01	TP-16		4	

Material Review Note: _____

Question Source: New _____

Question Source Committee: _____

Comments: _____

While attempting to identify a ruptured S/G in accordance with 2-EOP-SGTR-1, Steam Generator Tube Rupture, the Reactor Operator notes that RCS pressure has dropped to 1330 psig, even with maximum ECCS flow.

Which one of the following correctly states why the operator is required to trip the RCPs under these conditions?

- Minimize heat transfer to the ruptured S/G.
- Ensure against possible misdiagnosis, operator error, or multiple events.
- Ensure natural circulation is established prior to pressure equalization steps.
- Minimize the likelihood of RCS voiding impeding heat transfer to the intact S/Gs.

b	B	Memory	Salem	2/22/99
102	80	76		

038 Steam Generator Tube Rupture

EK3. Knowledge of the reasons for the following responses as they apply to Steam Generator Tube Rupture:

EK3.08 Criteria for securing RCP

4.1 4.2

RCP trip is required to ensure core cooling for certain small LOCA sizes and conditions. Although RCP trip to ensure core cooling is not necessary for a SGTR, RCP trip is required if the specified criteria are met to insure against possible operator misdiagnosis, operator error or a multiple failure event scenario.

Document	Revision	Page	Section	Code
Steam Generator Tube Rupture Basis Document	2 EOP-SGTR-1			
Steam Generator Tube Rupture	0300-000.00S-SGTR01-01	4.2	27	01 7

1/97 Salem NRC Exam Bank

1/97 Salem NRC Exam Bank

1/97 Salem NRC Exam Bank

Given the following conditions on Unit 2:

- A Steam Generator Tube Rupture has occurred
- Operators are performing 2-EOP-SGTR-1 "STEAM GENERATOR TUBE RUPTURE"
- Condenser steam dumps were used to cooldown to the required cooldown temperature
- RCS depressurization with Pressurizer spray valves is about to start
- The RO reports Pressurizer level is now indicating 0%
- Pressurizer pressure is 1230 psig
- RCS Subcooling is 20°F
- High Head charging flow and SI flow have been verified

IAW 2-EOP-SGTR-1, STEAM GENERATOR TUBE RUPTURE, which one of the following correctly describes the actions to be taken for this situation?

- Maintain current RCPs running. Continue depressurization using normal sprays.
- Trip all RCPs based on loss of subcooling. Depressurize the RCS using a PORV.
- Trip all RCPs since ECCS flow is verified to the RCS. Maintain stable RCS pressure.
- Stop all RCPs except the 21 RCP, if available. Use this RCP to continue depressurization with normal sprays.

Answer	a	QUESTION	S	Comprehension	Salem	2/22/99
Record Number	103			77		

038 Steam Generator Tube Rupture

EK3. Knowledge of the reasons for the following responses as they apply to Steam Generator Tube Rupture:

EK3.08 Criteria for securing RCP

4.1 4.2

RCP trip criteria (RCS pressure < 1350 psig & ECCS flow established) as listed in the CAS no longer applies once the operator controlled cooldown has been initiated. The intent of this portion of the procedure is to depressurize the RCS to equalize break flow (RCS pressure = ruptured SG pressure) and to raise ECCS flow to fill RCS. This action restores Pressurizer level and has specific stop criteria. Using the 21 RCP is the least desired configuration since this minimizes spray flow (scoop on loop opposite Pressurizer surge line). RCS subcooling is monitored in CAS but this is for ECCS reinitiation (which should not have been reduced at this point).

EOP-SGTR-1, STEAM GENERATOR TUBE RUPTURE	300S-000.00S-SGTR01-01	4.2.1, 4.3.15	26, 56	3, 8
STEAM GENERATOR TUBE RUPTURE	2-EOP-SGTR-1	17	3	20

Position Source: NRC Exam Bank

Significantly Modified

QUESTION SOURCE: EDITORIAL: Salem BGRP NRC exam Q 93. Change layout and some specific conditions of premise. Changed selections and positions for choices.

Comment Type	Comment

The following conditions were observed while Unit 2 was operating at 100% power:

- Pressurizer level lowering rapidly at 42%
- Pressurizer pressure lowering rapidly at 2100 psig
- All S/G pressures lowering at 682 psig
- 2R11A indication is steady
- Containment pressure is 2 psig and rising
- Reactor power is 103%

Choose the statement below that correctly describes these conditions:

These conditions are caused by:

- a LOCA inside containment.
- a S/G safety valve opening.
- a Pressurizer steam space break upstream of PR1.
- A Steam Line Break inside containment.

id	B -	Comprehension	Salem	2/22/99
Record Number	104	81	78	

040 Steam Line Rupture

AA2. Ability to determine and interpret the following as they apply to Steam Line Rupture:

AA2.03 Difference between steam line rupture and LOCA

4.6 4.7

d. Correct. a&c. R11A will rise for a LOCA inside Containment. b. Containment pressure will not rise.

System Name	Reference	Version	Page Number	Revision	Code
ADVANCED DIGITAL FEEDWATER CONTROL SYSTEM	0300-000.00S-ADFWCS-00	V.I.3	37		13.a
AUXILIARY FEEDWATER SYSTEM	0300-000.00S-AFW000-01	IV.B.5.b & c	31-32		9

Materials Required for Examination:

Question Source: New

Initial Source Form:

Common No.	Comments

A rapid loss of condenser vacuum has occurred due to a leak in the condenser.

Which one of the following correctly identifies the first automatic function to occur as vacuum degrades?

Steam Generator Feed Pump trip.

Block of Steam Dump Valves.

Main Turbine Trip.

LP Turbine rupture disks break.

DATE	c	EMPLOYEE	B	POSITION	Memory	PLANT	Salem	REVISION	2/22/99
ACCOUNT	105	PHONE	82	EXTENSION	79				

051 Loss of Condenser Vacuum

AA2. Ability to determine and interpret the following as they apply to Loss of Condenser Vacuum:

AA2.02 Conditions requiring reactor and/or turbine trip 3.9 4.1

The condenser interlock will prevent steam dump operation at pressure < 20 in. Hg vacuum (10 in. Hga). Alarms for condenser vacuum also come in at various levels: 25 in. Hg vacuum for 2CC3 Bezel Alarm 6-22 "CONDENSER VACUUM LO" and OHA G-5 "CNDSR VAC LO"; OHA G-13 "CNDSR VAC LO-LO" at 22 (±1) in. Hg vacuum. The main turbine trips between 18 and 22 in. Hg vacuum.

Event Name	Event ID	Reference	Page Number	Unit	Notes
LOSS OF CONDENSER VACUUM	0300-000.00S-ABCOND-01	III.C.5	11		1.A, 4.B
STEAM DUMP SYSTEM	0300-000.00S-STDUMP-01	V.A.7.b	23		10
LOSS OF CONDENSER VACUUM	S2.OP-AB.COND-0001(Q)	3.9 NOTE	3	6	

Event Description:

Event ID:

Event Name:

Event Type:

Event Status:

Event Date:

Event Time:

Event Location:

Event Category:

Event Sub-Category:

Event Priority:

Event Severity:

Event Impact:

Event Action:

Event Comments:

An electrical disturbance resulted in a loss of all Unit 2 Circulators and a reactor trip from 50% power. Significant decay heat causes RCS temperature to increase following the trip.

Which one of the following correctly identifies the temperature at which the RCS Tavg stabilizes 10 minutes after the trip?

555°F, the value of the lowest set Main Steam Safety Valve.

552°F, per the Steam Dump Load Rejection Controller.

548°F, per the MS10, Main Steam Atmospheric Relief setpoint at 1015 psig.

543°F, per the Steam Dump Plant Trip Controller.

Answer	C	Exam Code	B	Application	Salem	2/22/99
Record Number	106	83	80			

051 Loss of Condenser Vacuum

AK3. Knowledge of the reasons for the following responses as they apply to Loss of Condenser Vacuum:

AK3.01 Loss of steam dump capability upon loss of condenser vacuum

.8* .1*

The condenser would NOT be available for steam dumps (either on trip controller or load rejection controller). The S/G pressure would stabilize based on the secondary PORV opening setpoint normally set at 1015 psig (548°F). The Main Steam safety valve setting is 1070 psig (555°F). At 543°F the steam dumps would be blocked (P12). If the Steam Dumps were controlled on Load Rejection controller, RCS temperature would be at No-load + 5°F (552°F).

System	Code	Version	Page	Revision
MAIN STEAM SYSTEM	0300-000.00S-MSTEAM-00	IV.B.4.g	21	4.c, 9
STEAM DUMP SYSTEM	0300-000.00S-STDUMP-01	V.A.7.a, f	22-23	10

New
 Deleted
 Modified
 Other

Given the following conditions on Unit 2:

- A break has occurred on the Feedwater line to the 23 SG inside containment
- SI is actuated
- The following parameters are noted:
 - Pressurizer pressure - 1920 psig
 - Lowest Tavg - 544°F
 - Lowest S/G pressure - 980 psig (23)
 - Containment pressure 4.2 psig

Assuming no operator action has been taken, which one of the following correctly describes the expected S/G conditions?

- Only the 23 S/G pressure would be decreasing from the break.
- All S/G pressures would be decreasing from the break via interconnection of the Main Steam lines.
- All S/G pressures would be decreasing from the break via interconnection of the Main Feedwater lines.
- All S/G pressures would be decreasing from the break via interconnection of the Auxiliary Feedwater lines.

b	B	Comprehension	Salem	2/22/99
Record Number	107	84	81	

054 Loss of Main Feedwater

AK1. Knowledge of the operational implications of the following concepts as they apply to Loss of Main Feedwater:

AK1.01 MFW line break depressurizes the S/G (similar to a steam line break) 4.1 4.3

Explanation: All S/Gs would still be connected via the main steam lines and pressure would be dropping in all due to the FW line leak. If (and it would soon occur) a steamline isolation had occurred then only the 23 SG pressure would be dropping. The FW lines are no longer intertied since the SI would have closed FW Isol Stops. The AFW lines have check valves which prevent this type of interaction.

Reference	Code	Section	Page Numbers	Revision
MAIN STEAM SYSTEM	0300-000.00S-MSTEAM-00	III.C.4, IV.B.5	16, 23	3, 4
INTRODUCTION TO ENGINEERED SAFETY FEATURES AND DESIGN CRITERIA	0300-000.00S-ESF000-00	VII.B.1, 2, 3	50-51	21

Initial Review/Correction:

Source: INRC Exam Bank **Change:** Significantly Modified

Revision Source/Comments: Beaver Valley Unit 2 written 6/98. Stem modified to provide conditions. Correct answer changed.

Revision No.	Revision

Which one of the following correctly completes the operator action concerning Safety Injection actuation in the event of an extended loss of all AC power?

The SI signal will be manually actuated...

- and reset while the 4KV Vital buses are de-energized.
- and reset after power is restored to at least ONE 4KV Vital bus.
- only if automatic actuation is present and is reset while the 4KV Vital buses are de-energized.
- only if an automatic actuation signal is present and is reset after power is restored to at least ONE 4KV Vital bus.

055 Station Blackout

EK3. Knowledge of the reasons for the following responses as they apply to Station Blackout:

EK3.02 Actions contained in EOP for loss of offsite and onsite power

4.3 4.6

If power is NOT immediately restored during performance of 2-EOP-LOPA-1, then SI is manually actuated and reset to provide controlled loading of equipment when power is restored to Vital Bus(es).

Event/Condition	Reference	Step	Count	Weight	Notes
EOP-LOPA-1, 2, 3; LOSS OF ALL AC POWER AND RECOVERY	0300-000.00S-LOPA00-02	4.3.21	38		7, 8
LOSS OF ALL AC POWER	2-EOP-LOPA-1	step 21	2	20	

Material Required for Examination

Question Source: New

Question Source Comment:

Document Type:

The following conditions exist on Unit 1:

- 1A 4KV Vital Bus is powered from 13 SPT
- 1B & 1C 4KV Vital Bus is powered from 14 SPT
- 1B Emergency D/G surveillance is being performed with the D/G paralleled to the bus and loaded to 2600 kW

An overcurrent condition results in the loss of the 14 Station Power Transformer.

Which one of the following correctly describes the final electrical alignment?

1A 4KV Vital Bus remains powered from 13 SPT.
1B 4KV Vital Bus is powered from the 1B D/G only.
1C 4KV Vital Bus swaps to the 13 SPT.

All busses are stripped and aligned to their respective D/G IAW Mode II SEC Loading.

1A 4KV Vital Bus remains powered from 13 SPT.
1B 4KV Vital Bus swaps to the 13 SPT with the 1B D/G running and its output breaker open.
1C 4KV Vital Bus swaps to the 13 SPT.

1A 4KV Vital Bus remains powered from 13 SPT.
1B 4KV Vital Bus swaps to the 13 SPT with the 1B D/G paralleled to the bus.
1C 4KV Vital Bus swaps to the 13 SPT.

Answer	a	Question	B	Comprehension	Score	Salem	Created	2/22/99
Record Number	109	Question	86	Question	83			

056 Loss of Off-Site Power

AA2. Ability to determine and interpret the following as they apply to Loss of Off-Site Power:

AA2.53 Status of emergency bus under voltage relays

2.9 3.2

Explanation: a. Correct. When the 14 SPT is lost, the 1A bus will be unaffected since it is already powered from 13 SPT. The 1C bus transfer relay will sense voltage <70% which will cause the normal feeder breaker, 14ASD to open. When 1A bus voltage drops below 35%, the 35% transfer relay will initiate closure of the alternate feeder breaker, 13ASD. This transfer will occur fast enough to prevent the blackout relays from actuating and fast enough to prevent the loss of any bus loads. The 1B bus normal feed transfer relay will see low voltage since the relay is on the transformer side of the feeder breaker and will open the normal feeder breaker 14BSD. Since the 1B D/G is paralleled to the bus, bus voltage will not drop to pick up the 35% transfer relay so the alternate feeder breaker, 13BSD will not close. The 1B D/G will remain on the bus as the only source since no fault or SEC signals are generated that affect the D/G or its output breaker.

DESCRIPTION	ALTERNATE FEEDER	SYSTEM	NO. OF BREAKERS	NO. OF RELAYS	NO. OF LOADS
4160 ELECTRICAL SYSTEM	0300-000.00S-4KVAC0-00	V.C.1	47	00	6, 9

Item Name: _____

Item Status: New

Item Location: _____

Item Description: _____

Item Notes: _____

Power for the 2A Vital Instrument Bus transferred from the 2A Vital Instrument Inverter to AC Line Regulator due to a momentary overload on the Inverter.

Which one of the following correctly identifies when the 2A Vital Instrument Bus will revert to the Inverter?

- Automatically as Inverter voltage rises.
- When the Return Mode toggle switch is placed in MAN.
- Following rotation of the Static Switch to the INV position.
- When the ALARM CONTACT RESET pushbutton is depressed.

Answer	a	Comprehension	Salem	2/22/99
Record Number	110	87	84	

057 Loss of Vital AC Instrument Bus

AA1. Ability to operate and / or monitor the following as they apply to Loss of Vital AC Instrument Bus:

AA1.01 Manual inverter swapping

.7* 3.7

Explanation: An automatic transfer from the inverter to the AC Line Regulator is indicative of an overload on the affected VIB or failure of an inverter. If the VIB is automatically transferred back to the inverter, then the overload was only momentary. In the event that the loss (overload) was sustained (NOT momentary), then operation of the ALARM CONTACT RESET pushbutton is required. The Static Switch is involved with manual transfer of other inverters (to prevent auto transfer). RETURN MODE toggle switch is normally in AUTO. This selects mode of return to preferred source; either MAN. or AUTO. Auto. - return transfer is not affected by the switch. MAN. - Return transfer is inhibited until the switch is moved to AUTO or the RESET switch is pushed (will cause a transfer to occur).

Reference	Reference Number	Section	Points	Version	Code
LOSS OF 2A VIB	0300-000.00S-AB115-01	III.A.2	8		1.A
115VAC ELECTRICAL SYSTEMS	0300-000.00S-115VAC-00	V.C.2	24		3.b
LOSS OF 2A VIB	S2.OP-AB.ZZ-115-0001	3.12	4	8	

Final Reviewed for Exam Bank:

Source: NRC Exam Bank

Significantly Modified

Final Source Comment: Based on BGRP NRC exam Question 73.

Comment Type: Comment

During the performance of 2-EOP-LOPA-1, Loss of All AC Power, the operating crew is directed to implement AB.LOOP-0001, Loss of Off-Site Power, Attachment 1, Blackout Coping Actions. An operator is sent to place both Unit 3 engines in LOCKOUT and open the 125 VDC distribution panel main breaker.

Which one of the following correctly describes the reasons for these actions?

- Unload the Unit 3 battery while the switchyard is prepared for the Unit 3 startup.
- Prepare the Unit 3 battery charger to feed into the station 125 VDC System.
- Reduce heat loads in the Jet Control House until power can be restored.
- Prevent Auto start of Unit 3 until the switchyard is prepared.

a	B	Memory	Salem	2/22/99
111	88	85		

058 Loss of DC Power

2.1 Conduct Of Operations

2.1.32 Ability to explain and apply all system limits and precautions.

3.4 3.8

a. Correct. EOP-LOPA-1 directs concurrent completion of AB.LOOP-1 for mitigating, coping and recovery actions on a loss of off-site power. All Unit 3 battery loads are removed to ensure that DC power will be available for Unit 3 startup after the switchyard has been aligned IAW the procedure. b. The Unit 3 battery and charger are independent of the station 125 VDC System. c. The Unit 3 actions are only for conservation of the Jet batteries and are not part of the Backout study. d. Once the Jet is started, it will automatically accelerate up to speed and the generator breaker will automatically close but there is no auto start of the engine.

Event	Code	Section	Frequency	Impact	Notes
LOSS OF ALL AC POWER AND RECOVERY	0300-000.00S-abLOP01-00	III.C.1	13	00	1,2
LOSS OF OFF-SITE POWER	S1.OP-AB.LOOP-0001(Q)	Att. 1	38	8	

Material Required for Examination:

Question Source: C Grp NRC Exam **Changed to a Unit 1 question, chan**

Comments:

Comment Type	Comment

Given the following:

- All Unit 1 & 2 Circulating Pumps are in service
- Unit 1 is in Mode 3
- Unit 2 is at 100% power
- 21,23 & 26 Service Water Pumps are running
- 21 CVCS Monitor Tank is being released via 21 CCW Hx to the Circulating Water System

IAW S2.OP-SO.WL-0001, RELEASE OF RADIOACTIVE LIQUID WASTE FROM 21 CVCS MONITOR TANK, which one following correctly identifies the condition that would require termination of the liquid release?

- The 21A & 21B Circulators trip.
- The 11A & 11 B Circulators trip.
- 21 CCW Pump trips.
- 23 Service Water Pump trips and service Water header pressure drops from 115 to 105 psig.

b	B	Comprehension	Salem	2/22/99
112	89	86		

059 Accidental Liquid Radwaste Release

AA2. Ability to determine and interpret the following as they apply to Accidental Liquid Radwaste Release:

AA2.02 The permit for liquid radioactive-waste release

2.9 3.9

Explanation of: b. Correct. Procedure requires the release to be terminated if both circulators for the affected condenser are lost. a. Unit 2 SW Headers do not discharge to Unit 2 CW. c. A CCW pump trip will start the third pump and will not affect the release. d. 23 SW Pump trip will result in the flow control valve for the CCW Hx opening to maintain header Flow or in the start of the Auto SW pump but will not affect the release.

Event Description	Reference	Frequency	Consequence	Frequency	Consequence
RADIOACTIVE LIQUID WASTE SYSTEM	0300-000.00S-WASLIQ-00	IV.D.5	45		3.b, 12
RELEASE OF RADIOACTIVE LIQUID WASTE FROM 21 CVCS MONITOR TANK	S2.OP-SO.WL-0001(Q)	5.3.2	7	12	
CIRC WATER MALFUNCTION	S2.OP-AB.CW-0001	3.2	1	10	

Total Response Extension
 New
 Common to...
 ...
 ...
 ...

Unit 2 is operating at 100% power. A Service Water leak has occurred in the 21 CCW Hx with CCW Surge Tank level rising at 68%.

Which one of the following correctly describes the consequence of this event?

- RCPs may need to be tripped due to a reduction in CCW header pressure.
- The Aux Building Exhaust System filters and in service Waste Holdup Tanks may become contaminated with chromates.
- Chromates will be transported to the Delaware river by the Service Water System.
- Components cooled by CCW will experience a reduction in cooling that could cause a plant shutdown.

Answer	b	Question	B	Comprehension	100%	Salem	2/22/99
Score	113	Points	90	Percentage	87		

062 Loss of Nuclear Service Water

AA1. Ability to operate and / or monitor the following as they apply to Loss of Nuclear Service Water:

AA1.05 The CCWS surge tank, including level control and level alarms, and radiation alarm 3.1 3.1

Explanation of b. Correct. The Surge Tank vent and relief valves are piped to a common line that is connected to the Aux
Alarm Bldg Exh Filters and also to the Waste Holdup Tank. If chromates were to be released from the tank, the
 Filters and WHUT would both be contaminated. a. The CCW system is a vented system and header
 pressure will not lower during a SW leak. c. Since SW pressure is higher than CCW pressure, SW will leak
 into the CCW System and not the other way around. d. SW temperature will always be lower than CCW
 temperature so a SW leak into CCW will not result in a reduction in cooling.

Reference ID	Reference ID	Category	Impact	Priority	Score
Component Cooling Water	0300-000.00S-ABCC01-00		7	0	4
Component Cooling Abnormality	S2.OP-AB.CC-0001(Q)	3.8	2	3	

Alarm Report -

Alarm Name New

Alarm Type

Alarm Category

The following conditions exist on Unit 2:

- A loss of Control Air has occurred
- The operators have tripped the reactor and stabilized the unit at no-load Tavg
- Restoration of air is expected to take up to TWO hours

Which one of the following correctly identifies the basis associated with the preferred CVCS pump operation during this time period?

- Run 23 Charging to provide the minimum RCS makeup.
- Run 23 Charging Pump because CCP Flow Control Valve, CV55 failed closed.
- Run any Centrifugal Charging Pump to provide more stable seal flow to the RCPs.
- Run any Centrifugal Charging Pump because the mini-flow provides automatic pump protection.

a	R	Comprehension	Salem	2/22/99
114	91			

065 Loss of Instrument Air

AA2. Ability to determine and interpret the following as they apply to Loss of Instrument Air:

AA2.08 Failure modes of air-operated equipment

.9* 3.3

It is recommended to operate 23 Charging Pump (if available), since its speed controller is failed at the low speed stop (minimum RCP seal flow). With 2CV55 failed open and 2CV71 failed closed, operating a Centrifugal Charging Pump (CCP), will result in higher flow and pressure to the RCP seals. This will result in higher flow into the RCS and thus raise Pressurizer level faster. The other problem with running a CCP concerns the recirc. This is normally lined up to the VCT (2CV130). The mini-flow can never be assured, so the recirc must remain in service. If it is left to the VCT, 60 gpm of RWST inventory (3,600 gal/hr) will be lost to the holdup tanks.

LOSS OF CONTROL AIR	0300-000.00S-ABCA01-01	25- 2	14	2, 3
LOSS OF CONTROL AIR	S2.OP-AB.CA-0001(Q)	Attachment 8	1	5

Location/Source	New			
Summary/Notes				

In response to a fire found in the ABV Charcoal Filters, the operators on BOTH units have actuated FIRE OUTSIDE THE CONTROL ROOM.

Which one of the following correctly describes the Control Area HVAC operation in this condition?

- The Control Room Envelope (Zone 1) is recirculated through BOTH EACS. The remaining Control Area Zones are recirculated through BOTH CAACS.
- The Control Room Envelope (Zone 1) is recirculated through BOTH EACS. The remaining Control Area Zones are recirculated through CAACS for the Unit which actuated first while the other CAACS provides outside air.
- The Control Room Envelope (Zone 1) is recirculated through EACS for the Unit which actuated first. The remaining Control Area Zones are recirculated through and provided outside air by BOTH CAACS.
- The Control Room Envelope (Zone 1) is recirculated through EACS for the Unit which actuated first. The remaining Control Area Zones are recirculated through CAACS for the Unit which actuated first while the other CAACS provides outside air.

a	R	Comprehension	Salem	2/22/99
115	92			

067 Plant Fire on Site

AA2. Ability to determine and interpret the following as they apply to Plant Fire on Site:

AA2.06 Need for pressurizing control room (recirculation mode)

3.3 3.6

If both units have selected Fire Outside Control Area, zone 1 is on recirc through both EACS. Remaining zones are on recirc through both CAACS. If it is actuated on only one Unit, the EACS for the actuating unit recircs zone 1. EACS for non-affected unit is not in service. CAACS for non-affected unit recircs and supplies outside air to all zones. CAACS for actuating unit recircs remaining zones

CONTROL AREA VENTILATION SYSTEM	0300-000.00S-CAVENT-00				
DESIGN CHANGE PACKAGES	0300S-000.00S-DCP963-00	III.A.5 & 11	7, 9		2

Non-Required
 Required
 New
 Deleted
 Modified
 Other

A fire occurs in Unit 2 Turbine Building with all Fire Systems in a normal lineup. While en route to the scene, a fire truck crashed into # 1 FW Storage Tank, rupturing the tank.

With no operator action, which one of the following correctly describes the status of the alternate sources to the Salem Fire Water header?

The Salem Fire Water Header will be supplied by:

- #2 Diesel Fire Pump with suction from the #2 FW Storage Tank even if #1 FW Tank is not isolated.
- #1 Diesel Fire Pump with suction from #2 FW Tank
- Hope Creek Fire Pumps via a normally open cross-tie.
- Hope Creek Fire Pumps via a normally closed cross-tie.

d	S	Comprehension	Salem	2/22/99
116		88		

067 Plant Fire on Site

2.4 Emergency Procedures / Plan

2.4.25 Knowledge of fire protection procedures.

2.9 3.4

d. Correct. The cross-tie is opened as directed by procedure to allow Hope Creek Fire Header to supply Salem Fire System. a. Both FW Tanks are cross-tied with normally open isolation valves and no check valves. #2 FW Tank will also drain if not isolated from the ruptured tank. c. The cross-tie is normally closed

DESCRIPTION	SYMBOL	SECTION	REVISIONS	REVISION
FIRE PROTECTION SYSTEM MALFUNCTION	0300-000.00S-ABFP01-00	III.A.3	7	2, 3
FIRE PROTECTION SYSTEM MALFUNCTION	S2.OP-AB.FP-0001	3.0	1-2	1
FIRE PROTECTION P&ID	205222		sh. 4	54

New
 Revision
 Deleted
 Other

The operators are initiating seal injection to the RCPs in accordance with S2.OP-AB.CR-0002 "CONTROL ROOM EVACUATION DUE TO FIRE IN CONTROL ROOM, RELAY ROOM, OR CEILING OF THE 460/230V SWITCHGEAR ROOM". The following systems have been verified in-service:

- Service Water
- Component Cooling Water
- 4160 V AC Vital Electrical power

Which one of the following correctly describes another requirement for establishing seal injection?

- Control Air is in service.
- 125 V Vital DC is in service.
- An operator is available to operate CV73, CV71 manual bypass valve.
- An operator is available to manually operate MOVs.

a	B	Comprehension	Salem	2/22/99
117	93	89		

Which one of the following correctly describes the reason for starting a RCP when performing 2-EOP-FRCC-1 "Response to Inadequate Core Cooling"?

- Facilitate rapid RCS depressurization using a normal Pressurizer Spray valve.
- Improve core cooling until additional makeup flow to the RCS can be established.
- Allow the use of RVLIS dynamic head range for a better indication of RCS level.
- Minimize the inventory loss by using two-phase heat transfer when rapidly de-pressurizing the S/Gs.

Answer	b	Question	B	Question ID	Memory	Author	Salem	Date	2/22/99
Record Number	118	Reference	94	Reference	90				



074 Inadequate Core Cooling

EK2. Knowledge of the interrelations between Inadequate Core Cooling and the following:

EK2.01 RCP

3.6 3.8

RCPs cannot be expected to run indefinitely under highly voided RCS conditions. Action to establish a makeup source to the RCS to restore adequate long term cooling must be taken. During NON-accident conditions it is desirable to start a RCP to allow for Pressurizer sprays in controlling pressure; however, in this case voiding in the head is at least expected and Pressurizer spray would NOT be effective. Inventory loss is increased by running the RCP but is allowed to provide the temporary cooling enhancement. RVLIS dynamic head is used if RCP running but is NOT preferential.

Reference	Document	Section	Number	Revision	Page
EOP-FRCC-1, 2, and 3 ACCIDENT MITIGATION STRATEGY	0300-000.00S-FRCC00-01	II.C.6	22		2, 6

Source: NRC Exam Bank

Editorially Modified

Beaver Valley Unit 1 NRC exam 6/98. Modified question and all answers.

Source	Document



Radiation alarms and confirmatory sample results indicate that RCS activity has exceeded Technical Specification limits. The reactor has been shutdown.

IAW S2.OP-AB.RC-0002, HIGH ACTIVITY IN REACTOR COOLANT SYSTEM, which one of the following correctly describes the action taken to minimize the likelihood of a radioactive release to the environment in the event that a Steam Generator Tube Rupture were to occur with the elevated RCS activity?

- The MSIVs are closed.
- S/G blowdown is maximized.
- The RCS is cooled down below 500°F.
- CVCS letdown flow is maximized with all demineralizers in service.

119	95	91	2/22/99
-----	----	----	---------



076 High Reactor Coolant Activity

AA2. Ability to determine and interpret the following as they apply to High Reactor Coolant Activity:

AA2.02 Corrective actions required for high fission product activity in RCS

2.8 3.4

Explanation: Maximizing letdown is a step in the procedure to expedite cleanup for a valid elevated RCS activity but is NOT related to potential secondary release. Closure of MSIV may actually increase potential for release since any cooling is accomplished by steam release from MS10s. Maximizing blowdown flow may provide for earlier detection of primary to secondary leakage but does NOT reduce the likelihood of release.

HIGH ACTIVITY IN REACTOR COOLANT SYSTEM	0300-000.00S-ABRC02-00	III.C.2	9		4.c
HIGH ACTIVITY IN REACTOR COOLANT SYSTEM	S2.OP-AB.RC-0002(Q)	CAS 2.0	1	2	

Information on Exam

Question Source: Previous 2 NRC Exams Editorially Modified

Question Source: C Grp NRC Exam Q 84. Editorially modified. A particular change was from stopping SGBD flow to maximizing.

Comments/Reps:	

The following conditions exist on Unit 2:

- An inadvertent SI resulted in a reactor trip
- Transition has been made to 2-EOP-TRIP-3 "Safety Injection Termination"
- Immediately following the reset of SI and Phase A Isolation, off-site power is lost

Which one of the following correctly describes the response of the 4 kV vital buses?

- Electrical load shed occurs, the EDG output breakers shut, and then the SEC actuates in MODE II Blackout.
- Electrical load shed occurs, the EDG output breakers shut, and then the SEC actuates in MODE III SI and Blackout.
- The Emergency Diesel Generators start, the EDG output breakers shut and then the SEC actuates in MODE II Blackout.
- The Emergency Diesel Generators start, the EDG output breakers shut and then the SEC actuates in MODE III SI and Blackout.

a	B	Comprehension	Salem	2/22/99
120	96	92		

A LOCA has occurred on Unit 2 and all equipment has operated as designed. Actions are being taken IAW EOP-LOCA-2. The following plant conditions are observed after stopping ONE Charging Pump:

- Pressurizer pressure - 830 psig stable
- Pressurizer level - 28%
- RCS temperature (CETs) - 480° F
- Containment pressure has risen to 3.4 psig
- Containment Radiation levels have risen to 1000 R/hr and have stabilized.

IAW EOP-LOCA-2, which one of the following correctly describes the action that should be taken for these conditions?

- SI should be manually re-initiated.
- The Charging pump should be restarted based on subcooling value.
- Stopping of ONE SI pump should be evaluated using the normal values for subcooling and Pressurizer level.
- Stopping of ONE SI Pump should be evaluated using the Adverse Containment values for subcooling and Pressurizer level.

c	S	Application	Salem	2/22/99
121		93		

E03 LOCA Cooldown and Depressurization

EK1. Knowledge of the operational implications of the following concepts as they apply to LOCA Cooldown and Depressurization:

EK1.2 Normal, abnormal and emergency operating procedures associated with (LOCA Cooldown and Depressurization). 3.6 4.1

Explanation: Evaluation of stopping the SI Pump(s) is the next action. SI would be reinitiated per CAS only if Subcooling falls to 0°F OR Pressurizer level falls below 11% (19%). Under current conditions Adverse CNMT does NOT exist (CNMT pressure < 4 psig and Radiation levels < 1E5 R/hr.).

EOP-LOCA-2, POST LOCA COOLDOWN AND DEPRESSURIZATION	0300-000.00S-LOCA02-01	3.3.21, 3.3.22	27, 29-30	4, 7
EOP-TRIP-1, REACTOR TRIP OR SAFETY INJECTION AND INTRODUCTION TO THE USE OF EOPs	0300-000.00S-TRP001-01	2.14	27	1.G
POST LOCA COOLDOWN AND DEPRESSURIZATION	2-EOP-LOCA-2	22	3	20

Steam Tables

Unit:	New		
Quantity:			
Comment:			

The following conditions exist on Unit 2:

- A small break LOCA has occurred outside containment.
- Actions of 2-EOP-LOCA-6 "LOCA Outside Containment" have failed to isolate the break.
- At the completion 2-EOP-LOCA-6, RCS pressure is continuing to drop.

Which one of the following correctly identifies the procedural transition from 2-EOP-LOCA-6 "LOCA Outside Containment"?

- 2-EOP-TRIP-7 "Re-diagnosis" in an attempt to diagnosis the break location.
- 2-EOP-LOCA-1 "Loss of Reactor Coolant" to resume actions to address the LOCA.
- 2-EOP-TRIP-1 "Reactor Trip or Safety Injection" in order to re-verify that all automatic actions have been completed.
- 2-EOP-LOCA-5 "Loss of Emergency Coolant Recirculation" in order to deal with the loss of available inventory for core cooling.

Answer	d	Score	S	Comprehension	94	Salem	2/22/99
Question Number	122				94		

E04 LOCA Outside Containment

EK1. Knowledge of the operational implications of the following concepts as they apply to LOCA Outside Containment:

EK1.2 Normal, abnormal and emergency operating procedures associated with (LOCA Outside Containment). 3.5 4.2

Explanation of: With the location of the LOCA NOT identified nor located, and RCS pressure continuing to drop, the concern is directed toward maintaining/restoring RCS inventory. The operator actions in LOCA-5 deals with actions to maximize available resource and deal with the loss of recirculation capability. If the leakage were isolate such that RCS pressure was rising, LOCA-1 would be the appropriate transition to address other actions associated with LOCA conditions (SI termination, cooldown). Trip-1 and Trip-7 are NOT appropriate for these conditions but could be credible since either procedure has potential for being transferred to under other circumstances.

Procedure	Procedure ID	Step	Frequency	Duration	Priority
EOP-LOCA-6 LOCA OUTSIDE CONTAINMENT	0300-000.00S-LOCA06-01	1.2.3	6		1, 7.2
LOCA OUTSIDE CONTAINMENT	2-EOP-LOCA-6	Step 6	1	20	

Procedure Source: New

Procedure Source Comments:

Comment Type: Summary

A Unit 2 Reactor Trip occurred after a 200 day continuous run at 100% power. Following the trip, all AFW flow was lost and the Crew transitioned to FRHS-1. Due to distractions caused by a pressure channel failure, bleed and feed steps were not initiated until WR S/G levels were all <10%.

Which one of the following correctly describes the general consequence of the delay?

- Core uncover will not occur as long as one PZR PORV is open and one centrifugal charging pump is injecting prior to SG dryout.
- Core uncover will not occur as long as both PZR PORVs are open and both centrifugal charging pumps are injecting prior to SG dryout.
- Core uncover will be more severe because RCS pressure will remain at a higher value for a longer time, limiting ECCS flow.
- Core uncover will be more severe only if the PRT rupture disk fails, increasing the loss of mass, while ECCS flow is limited by RCS pressure.

c	S	Memory	Salem	2/22/99
123		95		

E05 Loss of Secondary Heat Sink

EK2. Knowledge of the interrelations between Loss of Secondary Heat Sink and the following:

EK2.2 Facility's heat removal systems, including primary coolant, emergency coolant, the decay heat removal systems, and relations between the proper operation of these systems to the operation of the facility. 3.9 4.2

c. Correct. Boiling begins when reactor coolant reaches saturation temperature. RCS steam generation results in large volumetric increases and PZR PORVs may not be able to compensate for this. RCS pressure will remain high thus limiting ECCS flow. This will result in a more severe core uncover. a&b. The only recovery method that will be successful once the plant reaches this stage is to restore feed to the S/Gs. d. The PRT has a minimal affect on cooling flow and flow will be enhanced when the rupture disk breaks.

EOP-FRHS-1, 2, 3, 4, and 5 HEAT SINK FUNCTIONAL RESTORATION	0300-000.00S-FRHS00-03	1.2.9; 2.7.6	9, 13		2, 3
FRHS Basis Document		Step 26	33	24	

Previous 2 NRC Exams

Editorially Modified

Last Salem NRC exam. Minor word changes and position of correct answer changed.

Given the following conditions for Unit 2:

- A LOCA has been identified
- 2-EOP-FRTS-1 "Response To Imminent Pressurized Thermal Shock Conditions" has been entered due to a PURPLE path condition
- SI has actuated and is reset
- All RCPs are stopped
- ECCS flow CANNOT be terminated
- Support conditions required to start an RCP have been met
- RCS Subcooling is 0 degrees

Which one of the following correctly describes the basis for not starting an RCP?

An RCP should not be started because:

- the subsequent pressure surge could aggravate the flaw.
- the sudden flow change could cause rapid temperature changes.
- the loss of RCS inventory may be aggravated.
- natural circulation will slowly remove thermal gradients.

<input type="checkbox"/> c	<input type="checkbox"/> B	<input type="checkbox"/> Memory	<input type="checkbox"/> Salem	<input type="checkbox"/> 2/22/99
<input type="checkbox"/> 124	<input type="checkbox"/> 97	<input type="checkbox"/> 96		

E08 Pressurized Thermal Shock

EK3. Knowledge of the reasons for the following responses as they apply to Pressurized Thermal Shock:

EK3.1 Facility operating characteristics during transient conditions, including coolant chemistry and the effects of temperature, pressure, and reactivity changes and operating limitations and reasons for these operating characteristics. 3.4 3.9

c. Correct. In the event of SBLOCA condition, restart of an RCP is NOT appropriate since it can result in a degraded core cooling scenario due to additional inventory loss. a&b. For FRTS conditions without a LOCA, RCPs are started to provide mixing and reduce thermal gradients without a significant affect on the flow. d. Natural Circulation will not provide sufficient flow to reduce thermal gradients.

EOP-FRTS-1 AND 2, RESPONSE TO PRESSURIZED THERMAL SHOCK CONDITIONS	0300-000.00S-FRTS00-01	3.2.9.4	23		3,7
REESONSE TO PTS CONDITIONSBASIS DOCUMENT	2-EOP-FRTS-01	Step 9	11	24	

DO NOT REUSE THIS QUESTION

Previous 2 NRC Exams Significantly Modified

Question modified from steamline break condition to a SBLOCA condition. This changed correct answer.

Comments	

Which one of the following correctly describes the reason for waiting for RCS T-hot values to lower below 543°F before continuing with RCS depressurization during the initial cooldown performed in 2-EOP-TRIP-4 "Natural Circulation Cooldown"?

- To allow time for Natural Circulation to develop.
- Provide for raising Pressurizer level to at least 22% for the establishment of letdown.
- Ensure a minimum RCS subcooling of 50°F during subsequent depressurization.
- Prevent the delta-T between the Pressurizer Spray nozzle and Pressurizer vapor space from exceeding limits.

Question ID	c	Reason for	R	Memory	Salem	2/22/99
Record Number	125	Question ID	98	Answer		

E09 Natural Circulation Operations

EK3. Knowledge of the reasons for the following responses as they apply to Natural Circulation Operations:

EK3.2 Normal, abnormal and emergency operating procedures associated with (Natural Circulation Operations). 3.2 3.6

c. Correct. The cooldown is required to ensure a minimum RCS subcooling of 50°F during subsequent depressurization necessary to block SI circuitry. a. At this point in the event, natural circulation will have already been established. That dropping to 543 is not significant with respect to natural circulation. b. Pressurizer level is established at least 22% for ensuring Pressurizer pressure control (letdown and heaters trips) but is not related to delaying the depressurization until That is <543. d. There is a limit of 320°F between Pressurizer Aux spray and Pressurizer vapor space for thermal stress but it is not related to delaying the depressurization until That is <543.

DESCRIPTION	REFERENCE	STEP	NO. OF STEPS	NO. OF ACTIONS	NO. OF COMMENTS
EOP-TRIP 4, 5, 6; NATURAL CIRCULATION COOLDOWN	0300-000.00S-TRP004-01	3.3.10	18		5
NATURAL CIRCULATION COOLDOWN	2-EOP-TRIP-4	Step 10	1	20	

DISCONTINUED
 NEW
 MODIFIED
 COMMENTED

Comments:

Given the following Unit 2 conditions:

- Off-site power is unavailable
- RCS temperature - 540°F
- Pressurizer pressure - 2200 psig
- All RCPs are stopped
- RVLIS is NOT available
- A rapid cooldown, with the potential for vessel upper head void formation, is required.

For these conditions, which one of the following correctly describes the difference in actions between a rapid cooldown when RVLIS is NOT available as compared to a rapid cooldown when RVLIS is available?

The maximum cooldown rate is...

- 100°F/hr with RVLIS and 50°F/hr without RVLIS.
- 100°F/hr with or without RVLIS.
- 100°F/hr with RVLIS and 50°F/hr without RVLIS only for the initial cooldown to 500°F, and then is 100°F/hr with or without RVLIS for subsequent cooldown steps.
- 100°F/hr with or without RVLIS only for the initial cooldown to 500°F, and then is 100°F/hr with RVLIS and 50°F/hr without RVLIS for subsequent cooldown steps.

C	S	Memory	Salem	2/22/99
126		97		

Given the following conditions on Unit 2:

- A LOCA has occurred
- 2-EOP-LOCA-5 "LOSS OF EMERGENCY RECIRCULATION" is the procedure in effect
- A PURPLE path exists for Containment Environment due to high pressure

Which one of the following correctly describes the reasons for the operator's actions associated with the Containment Spray System?

The Containment Spray System is operated as directed in...

- LOCA-5 because it establishes minimum required containment spray flow and conserves RWST inventory.
- LOCA-5 since FRPs are not implemented during the performance of LOCA-5.
- 2-EOP-FRCE-1 "RESPONSE TO EXCESSIVE CONTAINMENT PRESSURE" because actions concerning Containment Spray operation are more restrictive.
- 2-EOP-FRCE-1 "RESPONSE TO EXCESSIVE CONTAINMENT PRESSURE" since restoration of the critical safety function takes precedence.

a	S	Comprehension	Salem	2/22/99
127		98		

E11 Loss of Emergency Coolant Recirculation

EA2. Ability to determine and interpret the following as they apply to Loss of Emergency Coolant Recirculation:

EA2.1 Facility conditions and selection of appropriate procedures during abnormal and emergency operations. 3.4 4.2

Step 3.1 of 2-EOP-FRCE-1 checks if LOCA-5 is in effect and if so directs that spray be operated IAW LOCA-5. This is done to minimize the depletion of RWST volume by reducing operation of CS and utilizing CFCUs. The comparison of usage due to CSF hierarchy is NOT appropriate since LOCA-5 is a contingency EOP. FRCE-1 is less restrictive but NOT appropriate for use in conditions as step directs operation of CS per LOCA-5.

EOP-FRCE-1, 2, and 3 CONTAINMENT ENVIRONMENT FUNCTIONAL RESTORATION	0300-000.00S-FRCE00-02	3.2.3.1	14-15	6
EOP-LOCA-5, LOSS OF EMERGENCY RECIRCULATION	0300-000.00S-LOCA05-01	1.2.3	7	1
RESPONSE TO EXCESSIVE CONTAINMENT PRESSURE	2-EOP-FRCE-1	3.1	1	20

NRC Exam Bank

Significantly Modified

B Grp NRC Exam Q 79. Change the premise to give conditions of operation and changed selections to determine appropriate procedure with reasons.

Which of the following correctly describes the post-accident condition that can lead to high containment pressure and subsequent containment failure early (within the first few hours) in the progression of an accident?

- Hydrogen gas buildup and ignition.
- Loss of all CFCUs.
- Loss of on Containment Spray Subsystem and 2 CFCUs.
- RCPs are not tripped at 1350 psig.


a	B	Comprehension	Salem	2/22/99
128	99	99		

Which of the choices below correctly completes the following statement?

If containment radiation exceeds 1E5 R/hr during an accident:

- Control Room instrumentation will no longer be reliable.
- Adverse containment values for key parameters must be used for the remainder of the accident until permission to return to normal values is granted by the TSC.
- Only environmentally qualified instrumentation may be used because it is not susceptible to radiation damage.
- Containment failure may occur due to radiation embrittlement.

Answer	b	Question	B	Comprehension	Facility	Salem	2/22/99
Score	129	Points	100	Points	100		



PACKAGE DIVIDER