



South Texas Project Electric Generating Station P.O. Box 289 Wadsworth, Texas 77483

January 3, 2000
NOC-AE-000732
File No.: G26
10CFR50.73
STI: 31007347

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555-0001

South Texas Project
Unit 1
Docket No. STN 50-498
Revision 1 to Licensee Event Report 99-007
Unit 1 Train 'B' Control Room Makeup and Cleanup Filtration System Inoperable
for Greater Than Allowed Outage Time

Pursuant to 10CFR50.73, the STP Nuclear Operating Company submits the attached Revision 1 to Unit 1 Licensee Event Report 99-007. The original Licensee Event Report described an occurrence in which the South Texas Project Unit 1 Train 'B' Control Room Makeup and Cleanup Filtration System was inoperable for greater than the Technical Specification 3.7.7 allowed outage time due to charcoal sample analysis results being outside Surveillance Requirement 4.7.7.c.2 limits. This revision documents a similar event, which occurred December 6, 1999 regarding the Unit 1 Train 'B' Fuel Handling Building Exhaust Air System. This event did not have an adverse effect on the health and safety of the public.

This event is being reported in accordance with the guidance provided in NUREG-1022, Revision 1, "Event Reporting Guidelines 10 CFR 50.72 and 50.73".

As stated in Revision 0 of this Licensee Event Report, should additional charcoal sample analysis results exceed Surveillance Requirement limits, but remain within design basis assumptions, it is our intention to append the "Additional Information" section of this LER with a brief description of the test results, rather than submit a separate LER. However, should future laboratory analysis results fall outside design basis requirements, a separate LER will be submitted. The appended information is shown by a change bar in the right hand margin.

JBA

Licensee commitments are listed in the Corrective Action section of the attachment. If there are any questions on this submittal, please contact either Mr. Scott M. Head at (361) 972-7136 or me at (361) 972-7800.



G. L. Parkey
Plant General Manager

JRM

Attachment: Revision 1 to LER 99-007 (South Texas, Unit 1)

Ellis W. Merschhoff
Regional Administrator, Region IV
U. S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

John A. Nakoski
Project Manager, Mail Code 14-D4
U. S. Nuclear Regulatory Commission
Washington, DC 20555-0001

Cornelius F. O'Keefe
Sr. Resident Inspector
c/o U. S. Nuclear Regulatory Commission
P. O. Box 910
Bay City, TX 77404-0910

A. H. Gutterman
Morgan, Lewis & Bockius
1800 M. Street, N.W.
Washington, DC 20036-5869

W. C. Gunst/M. T. Hardt
City Public Service
P. O. Box 1771
San Antonio, TX 78296

A. Ramirez/C. M. Canady
City of Austin
Electric Utility Department
721 Barton Springs Road
Austin, TX 78704

Jon C. Wood
Matthews & Branscomb
One Alamo Center
106 S. St. Mary's Street, Suite 700
San Antonio, TX 78205-3692

Institute of Nuclear Power
Operations - Records Center
700 Galleria Parkway
Atlanta, GA 30339-5957

Richard A. Ratliff
Bureau of Radiation Control
Texas Department of Health
1100 West 49th Street
Austin, TX 78756-3189

D. G. Tees/R. L. Balcom
Houston Lighting & Power Co.
P. O. Box 1700
Houston, TX 77251

Central Power and Light Company
ATTN: G. E. Vaughn/C. A. Johnson
P. O. Box 289, Mail Code: N5012
Wadsworth, TX 77483

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555-0001