Mr. J. P. O'Hanlon Senior Vice President - Nuclear Virginia Electric and Power Company Innsbrook Technical Center 5000 Dominion Blvd. Glen Allen, VA. 23060

SUBJECT:

SURRY UNITS 1 AND 2 AND NORTH ANNA UNITS 1 AND 2 - REQUEST FOR ADDITIONAL INFORMATION RELATED TO GENERIC LETTER 96-05 (MOTOR-OPERATED VALVES) (TAC NOS. M97107, M97108, M97073, AND M97074)

Dear Mr. O'Hanlon:

The purpose of this letter is to request additional information so that we may continue to review your September 17, 1999, response to Generic Letter 96-05, "Periodic Verification of Design-Basis Capability of Safety-Related Motor-Operated Valves."

Specific questions are provided in the Enclosure. The questions were discussed with Dave Sommers of your licensing staff on December 28, 1999, and he agreed to provide a response to these questions by March 1, 2000.

Sincerely,

Original signed by:

Gordon E. Edison, Senior Project Manager, Section 1 Project Directorate II Division of Licensing Project Management Office of Nuclear Reactor Regulation

Docket Nos. 50-280, 50-281, 50-338, and 50-339

Enclosure: As stated

cc w/encl: See next page

Distribution:

Docket File

**PUBLIC** 

PD II-1 R/F

S. Black

L. Berry

E. Dunnington

G. Edison (2)

OGC

**ACRS** 

R. Haag, RII

DOCUMENT NAME: G:\PDII-1\SURRY\RAI97107.wpd\* See previous concurrence To receive a copy of this document, indicate in the box C=Copy w/o attachment/enclosure

E=Copy with attachment/enclosure N = No copy

OFFICE	PDII-1/PM E	PDII-1/LA*	PDII/SC*
NAME	GEdison:cn	EDunnington	REmch
DATE	11519900	12/29/99	1/4/00

OFFICIAL RECORD COPY





## UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

January 6,2000

Mr. J. P. O'Hanlon Senior Vice President - Nuclear Virginia Electric and Power Company Innsbrook Technical Center 5000 Dominion Blvd. Glen Allen, VA. 23060

SUBJECT:

SURRY UNITS 1 AND 2 AND NORTH ANNA UNITS 1 AND 2 - REQUEST FOR

ADDITIONAL INFORMATION RELATED TO GENERIC LETTER 96-05 (MOTOR-OPERATED VALVES) (TAC NOS. M97107, M97108, M97073.

**AND M97074)** 

Dear Mr. O'Hanlon:

The purpose of this letter is to request additional information so that we may continue to review your September 17, 1999, response to Generic Letter 96-05, "Periodic Verification of Design-Basis Capability of Safety-Related Motor-Operated Valves."

Specific questions are provided in the Enclosure. The questions were discussed with Dave Sommers of your licensing staff on December 28, 1999, and he agreed to provide a response to these questions by March 1, 2000.

Sincerely.

LE Edward

Gordon E. Edison, Senior Project Manager, Section 1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-280, 50-281, 50-338, and 50-339

Enclosure: As stated

cc w/encl: See next page

Mr. J. P. O'Hanlon Virginia Electric & Power Company

cc:

Mr. J. Jeffrey Lunsford County Administrator Louisa County P.O. Box 160 Louisa, Virginia 23093

Mr. Donald P. Irwin, Esquire Hunton and Williams Riverfront Plaza, East Tower 951 E. Byrd Street Richmond, Virginia 23219

Dr. W. T. Lough Virginia State Corporation Commission Division of Energy Regulation P. O. Box 1197 Richmond, Virginia 23209

Old Dominion Electric Cooperative 4201 Dominion Blvd. Glen Allen, Virginia 23060

Mr. J. H. McCarthy, Manager Nuclear Licensing & Operations Support Virginia Electric and Power Company Innsbrook Technical Center 5000 Dominion Blvd. Glen Allen, Virginia 23060

Office of the Attorney General Commonwealth of Virginia 900 East Main Street Richmond, Virginia 23219

Senior Resident Inspector North Anna Power Station U.S. Nuclear Regulatory Commission 1024 Haley Drive Mineral, Virginia 23117 North Anna Power Station Units 1 and 2

Mr. W. R. Matthews Site Vice President North Anna Power Station P. O. Box 402 Mineral, Virginia 23117

Mr. E. S. Grecheck Site Vice President Surry Power Station Virginia Electric and Power Company 5570 Hog Island Road Surry, Virginia 23883

Robert B. Strobe, M.D., M.P.H. State Health Commissioner Office of the Commissioner Virginia Department of Health P.O. Box 2448 Richmond, Virginia 23218

## Virginia Electric and Power Company

cc:

Mr. Donald P. Irwin, Esq. Hunton and Williams Riverfront Plaza, East Tower 951 E. Byrd Street Richmond, Virginia 23219

Mr. E. S. Grecheck Site Vice President Surry Power Station Virginia Electric and Power Company 5570 Hog Island Road Surry, Virginia 23883

Senior Resident Inspector Surry Power Station U. S. Nuclear Regulatory Commission 5850 Hog Island Road Surry, Virginia 23883

Chairman
Board of Supervisors of Surry County
Surry County Courthouse
Surry, Virginia 23683

Dr. W. T. Lough
Virginia State Corporation
Commission
Division of Energy Regulation
P. O. Box 1197
Richmond, Virginia 23209

Robert B. Strobe, M.D., M.P.H. State Health Commissioner Office of the Commissioner Virginia Department of Health P.O. Box 2448 Richmond, Virginia 23218

## **Surry Power Station**

Office of the Attorney General Commonwealth of Virginia 900 East Main Street Richmond, Virginia 23219

Mr. J. H. McCarthy, Manager Nuclear Licensing & Operations Support Innsbrook Technical Center Virginia Electric and Power Company 5000 Dominion Blvd. Glen Allen, Virginia 23060

Mr. J. P. O'Hanlon Senior Vice President - Nuclear Virginia Electric and Power Company Innsbrook Technical Center 5000 Dominion Blvd. Glen Allen, Virginia 23060

Mr. W. R. Matthews
Site Vice President
North Anna Power Station
Virginia Electric and Power Company
P. O. Box 402
Mineral, Virginia 23117

## NORTH ANNA POWER STATION, UNITS 1 AND 2, SURRY POWER STATION, UNITS 1 AND 2

- 1. The Joint Owners Group (JOG) program focuses on the potential age-related increase in the thrust or torque required to operate valves under their design-basis conditions. In the NRC Safety Evaluation (SE) of the JOG program, dated October 30, 1997, the NRC specified that licensees are responsible for addressing the thrust or torque delivered by the motor operated valve (MOV) motor actuator and its potential degradation. Describe the plan at Surry and North Anna for ensuring adequate ac and dc MOV motor actuator output capability, including consideration of guidance in Limitorque Technical Update 98-01 and its Supplement 1. Clarify if there are any dc-powered MOVs in the Surry or North Anna Generic Letter 96-05 programs. Briefly discuss the MOV parameters that are trended in order to detect degradation of MOV performance.
- 2. Your letter dated September 17, 1999, states that the maximum interval between static diagnostic tests, including the grace period, will not exceed 10 years. In the NRC SE dated October 30, 1997, regarding the Westinghouse Owners Group (WOG) Topical Report MPR-1807 describing the JOG program, the NRC staff stated that MOVs tested at frequencies beyond 5 years will need to be grouped with other MOVs that will be tested at frequencies less than 5 years in order to validate assumptions for the longer test intervals. The NRC staff stated that this review must include valve thrust (or torque) requirements and actuator output capability. Please describe how your MOV static diagnostic testing program will satisfy this condition of the NRC Safety Evaluation.
- 3. In a letter dated September 17, 1999, VEPCO stated that it plans to implement (1) the three elements of the JOG program as described in Topical Report MPR-1807 (Revision 2); and (2) the MOV risk-ranking methodology described in WOG Engineering Report V-EC-1658 (Revision 2). Discuss the JOG dynamic test program and the JOG interim periodic test program implementation dates, and when MOV risk ranking will be complete.