

January 27, 2000

Mr. D. E. Young, Vice President  
Carolina Power & Light Company  
H. B. Robinson Steam Electric Plant,  
Unit No. 2  
3581 West Entrance Road  
Hartsville, South Carolina 29550

SUBJECT: H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2 (HBRSEP2) -  
THIMBLE TUBE THINNING IN WESTINGHOUSE REACTORS - CLOSE OUT  
OF TAC NO. MA4636

Dear Mr. Young:

On July 26, 1988, the U.S. Nuclear Regulatory Commission (NRC) issued NRC Bulletin No. 88-09, "Thimble Tube Thinning in Westinghouse Reactors" requiring establishment and implementation of a thimble tube inspection program. On February 8, 1991, you provided in a letter to the Nuclear Regulatory Commission (NRC) a response to the above bulletin. It confirmed that an inspection program had been established and the initial thimble tube inspection had been performed for HBRSEP2. You planned to repeat the eddy current inspection of the incore neutron monitoring system thimble tubes in every other refueling outage. In your supplemental response on the subject in your letter dated January 20, 1999, you said that this was subject to change as the knowledge pertaining to double-wall thimble tubes accumulated and if wear became evident on subsequent eddy current inspections. Since during the last three inspections covering six operating cycles, no detectable wear has been identified, you requested postponing the RFO-19 inspection to RFO-20. Staff reviewed your efforts in this area and finds your request for postponing the same to RFO-20 to be reasonable. Please keep the NRC updated on your results of the thimble tube inspection program and the results for the ensuing RFO-20.

Please be informed that your efforts on the implementation of the requirements of Bulletin No. 88-09 may be subject to NRC inspection.

If you have any questions regarding this matter, please contact Ram Subbaratnam at (301) 415-1478.

Sincerely,

*/RA/*

Ram Subbaratnam, Project Manager, Section 2  
Project Directorate II  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-261  
cc: See next page

January 27, 2000

Mr. D. E. Young, Vice President  
Carolina Power & Light Company  
H. B. Robinson Steam Electric Plant,  
Unit No. 2  
3581 West Entrance Road  
Hartsville, South Carolina 29550

SUBJECT: H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2 (HBRSEP2) -  
THIMBLE TUBE THINNING IN WESTINGHOUSE REACTORS - CLOSE OUT  
OF TAC NO. MA4636

Dear Mr. Young:

On July 26, 1988, the U.S. Nuclear Regulatory Commission (NRC) issued NRC Bulletin No. 88-09, "Thimble Tube Thinning in Westinghouse Reactors" requiring establishment and implementation of a thimble tube inspection program. On February 8, 1991, you provided in a letter to the Nuclear Regulatory Commission (NRC) a response to the above bulletin. It confirmed that an inspection program had been established and the initial thimble tube inspection had been performed for HBRSEP2. You planned to repeat the eddy current inspection of the incore neutron monitoring system thimble tubes in every other refueling outage. In your supplemental response on the subject in your letter dated January 20, 1999, you said that this was subject to change as the knowledge pertaining to double-wall thimble tubes accumulated and if wear became evident on subsequent eddy current inspections. Since during the last three inspections covering six operating cycles, no detectable wear has been identified, you requested postponing the RFO-19 inspection to RFO-20. Staff reviewed your efforts in this area and finds your request for postponing the same to RFO-20 to be reasonable. Please keep the NRC updated on your results of the thimble tube inspection program and the results for the ensuing RFO-20.

Please be informed that your efforts on the implementation of the requirements of Bulletin No. 88-09 may be subject to NRC inspection.

If you have any questions regarding this matter, please contact Ram Subbaratnam at (301) 415-1478.

Sincerely,  
**/RA/**  
Ram Subbaratnam, Project Manager, Section 2  
Project Directorate II  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-261

cc: See next page

**DISTRIBUTION:**

File Center PUBLIC PDII Rdg E. Dunnington F. Grubelich, EMEB, NRR  
J. Zwolinski/S. Black R. Correia R. Subbaratnam  
ACRS B. Bonser, RII J. Hannon, NRR

FILENAME - C:\ma4636.clo.wpd \* See Previous concurrence

PM:PDII-S2	LA:PDII-S2	EMEB:NRR	SC:PDII-S2
RSubbaratnam	EDunnington	F.Grubelich	R. Correia
01/14/00	01/13/00	01/13/00	01/14/00
Yes/No	Yes/No	Yes/No	Yes/No

OFFICIAL RECORD COPY

Mr. D. E. Young  
Carolina Power & Light Company

H. B. Robinson Steam Electric  
Plant, Unit No. 2

cc:

Mr. William D. Johnson  
Vice President and Corporate Secretary  
Carolina Power & Light Company  
Post Office Box 1551  
Raleigh, North Carolina 27602

Mr. Mel Fry, Director  
N.C. Department of Environment  
and Natural Resources  
Division of Radiation Protection  
3825 Barrett Dr.  
Raleigh, North Carolina 27609-7721

Ms. Karen E. Long  
Assistant Attorney General  
State of North Carolina  
Post Office Box 629  
Raleigh, North Carolina 27602

Mr. Robert P. Gruber  
Executive Director  
Public Staff - NCUC  
Post Office Box 29520  
Raleigh, North Carolina 27626-0520

U.S. Nuclear Regulatory Commission  
Resident Inspector's Office  
H. B. Robinson Steam Electric Plant  
2112 Old Camden Road  
Hartsville, South Carolina 29550

Mr. Virgil R. Autry, Director  
South Carolina Department of Health  
Bureau of Land & Waste Management  
Division of Radioactive Waste Management  
2600 Bull Street  
Columbia, South Carolina 29201

Mr. T. D. Walt  
Plant General Manager  
Carolina Power & Light Company  
H. B. Robinson Steam Electric Plant, Unit No. 2  
3581 West Entrance Road  
Hartsville, SC 29550

Mr. Terry C. Morton  
Manager  
Performance Evaluation and  
Regulatory Affairs CPB 7  
Carolina Power & Light Company  
Post Office Box 1551  
Raleigh, North Carolina 27602-1551

Mr. J. W. Moyer  
Director of Site Operations  
Carolina Power & Light Company  
H. B. Robinson Steam Electric Plant, Unit No. 2  
3581 West Entrance Road  
Hartsville, South Carolina 29550

Mr. John H. O'Neill, Jr.  
Shaw, Pittman, Potts & Trowbridge  
2300 N Street, NW.  
Washington, DC 20037-1128

Public Service Commission  
State of South Carolina  
Post Office Drawer 11649  
Columbia, South Carolina 29211

Mr. R. L. Warden  
Manager - Regulatory Affairs  
Carolina Power & Light Company  
H. B. Robinson Steam Electric Plant,  
Unit No. 2  
3581 West Entrance Road  
Hartsville, South Carolina 29550-0790

Mr. H. K. Chernoff  
Supervisor, Licensing/Regulatory Programs  
Carolina Power & Light Company  
H. B. Robinson Steam Electric Plant,  
Unit No. 2  
3581 West Entrance Road  
Hartsville, South Carolina 29550