
 OPERATING DATA REPORT

 Docket No. 50-317
 Calvert Cliffs Unit 1
 January 5, 2000
 Prepared by Herman O. Olsen
 Telephone: (410)495-6734

REPORTING PERIOD DECEMBER 1999
 DESIGN ELECTRICAL RATING (NET MWe) 845
 MAXIMUM DEPENDABLE CAP'Y (NET MWe) 825

	This month	Year- to-Date	Cumulative to Date
	-----	-----	-----
1. NUMBER OF HOURS REACTOR WAS CRITICAL	744.0	8,332.3	161,323.9
2. HOURS GENERATOR ON LINE	744.0	8,233.0	158,307.0
3. UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	0.0
4. NET ELECTRICAL ENERGY GENERATED (MWH)	641,075	6,994,341	128,617,701

UNIT SHUTDOWNS

DOCKET NO. 50-317
 UNIT NAME Calvert Cliffs - U1
 DATE January 6, 2000
 COMPLETED BY Herman O. Olsen
 TELEPHONE (410) 495-6734

REPORTING MONTH December 1999

NO.	DATE	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASON ¹	METHOD OF SHUTTING DOWN ²	CAUSE/CORRECTIVE ACTIONS COMMENTS
						There were no shutdowns this month.

- ¹ Reason:
- A - Equipment Failure
 - B - Maintenance or Test
 - C - Refueling
 - D - Regulatory Restriction
 - E - Operator Training & License Examination
 - F - Administrative
 - G - Operational Error
 - H - Other

- ² Method:
- 1 - Manual
 - 2 - Manual Scram.
 - 3 - Automatic Scram.
 - 4 - Continued
 - 5 - Other

DOCKET NO. 50-317
CALVERT CLIFFS - UNIT 1
January 6, 2000

SUMMARY OF OPERATING EXPERIENCE

December 1999

The unit began the month at 100% power.

On 12/10/99 at 2211, power was reduced to 85% for Main Turbine Valve Testing and water box cleaning. Power was returned to 100% on 12/11/99 at 0830.

The unit operated at 100% power for the remainder of the month.

OPERATING DATA REPORT

Docket No. 50-318
 Calvert Cliffs Unit 2
 January 5, 2000
 Prepared by Herman O. Olsen
 Telephone: (410) 495-6734

REPORTING PERIOD	DECEMBER 1999
DESIGN ELECTRICAL RATING (NET MWe)	845
MAXIMUM DEPENDABLE CAP'Y (NET MWe)	835

	This month	Year- to-Date	Cumulative to Date

1. NUMBER OF HOURS REACTOR WAS CRITICAL	744.0	7,452.6	152,845.7
2. HOURS GENERATOR ON LINE	744.0	7,401.8	151,032.1
3. UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	0.0
4. NET ELECTRICAL ENERGY GENERATED (MWH)	648,587	6,332,718	123,513,321

UNIT SHUTDOWNS

DOCKET NO.	50-318
UNIT NAME	Calvert Cliffs-U2
DATE	January 6, 2000
COMPLETED BY	Herman O. Olsen
TELEPHONE	(410) 495-6734

REPORT MONTH December 1999

NO.	DATE	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASON ¹	METHOD OF SHUTTING DOWN ²	CAUSE/CORRECTIVE ACTIONS COMMENTS
						There were no shutdowns this month.

- ¹ Reason:
- A - Equipment Failure
 - B - Maintenance or Test
 - C - Refueling
 - D - Regulatory Restriction
 - E - Operator Training & License Examination
 - F - Administrative
 - G - Operational Error
 - H - Other

- ² Method:
- 1 - Manual
 - 2 - Manual Scram.
 - 3 - Automatic Scram.
 - 4 - Continued
 - 5 - Other

DOCKET NO. 50-318
CALVERT CLIFFS - UNIT 2
January 6, 2000

SUMMARY OF OPERATING EXPERIENCE

December 1999

The unit began the month at 100% power.

On 12/31/99 at 1800 power was reduced to 65% at the request of the distribution network, due to low system electrical demand.

The unit operated at 65% power for the remainder of the month.