



H. B. Barron
Vice President

Duke Energy Corporation
McGuire Nuclear Station
12700 Hagers Ferry Road
Huntersville, NC 28078-9340
(704) 875-4800 OFFICE
(704) 875-4809 FAX

January 5, 2000

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555-0001

Subject: McGuire Nuclear Station
Docket No. 50-370
Relief Request 98-005

Pursuant to 10CFR50.55a(g)(5)(iii), Duke Energy Corporation requests relief from some requirements of the ASME Boiler and Pressure Vessel Code as described in the attached Relief Request 98-005.

Questions should be directed to Julius Bryant, McGuire Licensing and Compliance, at (704) 875-4162.

Sincerely,

H. B. Barron, Vice President
McGuire Nuclear Station

Attachment

A047

POZ A0001 0500370

U.S. Nuclear Regulatory Commission
January 5, 2000
Page 2 of 2

cc: Mr. L. A Reyes
Regional Administrator, Region II
U. S. Nuclear Regulatory Commission
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Mr. F. Rinaldi, Project Manager
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
One White Flint North, Mail Stop 9H3
Washington, D.C. 20555

S. M. Shaeffer
Senior NRC Resident Inspector
McGuire Nuclear Station

bxw/att:

J. W. Bryant
J. O. Barbour
R. Branch
G. J. Underwood
D. E. Caldwell
R. K. Rhyne
G. D. Scarboro
NRIA File/ELL

Duke Energy Corporation
Station: McGuire Unit 2

SECOND 10-YEAR INTERVAL REQUEST FOR RELIEF NO. 98-005

Pursuant to 10CFR50.55a(g)(5)(iii), Duke Energy Corporation has determined that compliance with the specified examination requirements of ASME Section XI is impractical for McGuire Nuclear Station Unit 2. Information is therefore being submitted in support of this determination and request is being sought for relief from the applicable ASME Section XI requirements.

I. System / Components(s) For Which Relief Is Requested:

ASME Section XI Class 1 Components listed below:

Examination Category B-A: (Pressure Retaining Welds in Reactor Vessel)

Reactor Vessel (Head-to-Flange Weld)

<u>ID Numbers</u>	<u>Item Numbers</u>	<u>End Of Cycle</u>
2RPV-W08	B01.040.001	11

Examination Category B-D: (Full Penetration Welds of Nozzles in Vessels)

Reactor Vessel (Nozzle-to-Vessel Welds)

<u>ID Numbers</u>	<u>Item Numbers</u>	<u>End Of Cycle</u>
2RPV-W15	B03.090.05A	9
2RPV-W16	B03.090.06A	9
2RPV-W17	B03.090.07A	9
2RPV-W18	B03.090.08A	9

Reactor Vessel (Nozzle Inner Radius Section)

<u>ID Numbers</u>	<u>Item Numbers</u>	<u>End Of Cycle</u>
2RPV-W15	B03.100.005	9
2RPV-W16	B03.100.006	9
2RPV-W17	B03.100.007	9
2RPV-W18	B03.100.008	9

Pressurizer (Nozzle-to-Vessel Welds)

<u>ID Numbers</u>	<u>Item Numbers</u>	End Of Cycle
2PZR-10	B03.110.001	11
2PZR-12	B03.110.003	10

Examination Category B-D (continued)

Pressurizer (Nozzle Inner Radius Section)

<u>ID Numbers</u>	<u>Item Numbers</u>	<u>End Of Cycle</u>
2PZR-12R	B03.120.002	10

Examination Category B-F: (Pressure Retaining Dissimilar Metal Welds)

Steam Generator (Nozzle-to-Safe End Butt Welds)

<u>ID Numbers</u>	<u>Item Numbers</u>	<u>End Of Cycle</u>
2SGA-INLET-SE	B05.070.001	9
2SGA-OUTLET-SE	B05.070.002	9

Piping Dissimilar Metal Butt Welds

<u>ID Numbers</u>	<u>Item Numbers</u>	<u>End Of Cycle</u>
2NC2F-1-2	B05.130.002	9
2NC2F-1-3	B05.130.003	9

Examination Category B-J: (Pressure Retaining Welds in Piping)

Branch Connection Welds (NPS 4 or Larger)

<u>ID Numbers</u>	<u>Item Numbers</u>	<u>End Of Cycle</u>
2NC16-WN8A	B09.031.001	10
2NC22-WN4	B09.031.002	9
2NC22-WN8	B09.031.003	9

ASME Section XI Class 2 Components listed below:**Examination Category C-B: (Pressure Retaining Nozzle Welds in Vessels)**

Nozzle Inner Radius Section

<u>ID Numbers</u>	<u>Item Numbers</u>	<u>End Of Cycle</u>
2SGA-SB-02	C02.022.002	9

II. Code Requirement:

ASME Boiler and Pressure Vessel Code, Section XI, 1989 Edition with no Addenda, Tables IWB-2500 and IWC-2500, lists the following requirements for each Examination Categories as shown below:

"Examination Category B-A, Pressure Retaining Welds in Reactor Vessels; Figure Number IWB-2500-5"

Note (2) adds the words "Includes essentially 100% of weld length."

"Examination Category B-D, Full Penetration Welds of Nozzles in Vessels- Inspection Program B; Figure Number IWB-2500-7 (a) through (d)"

"Examination Category B-F, Pressure Retaining Dissimilar Metal Welds; Figure Number IWB-2500-8"

"Examination Category B-J, Pressure Retaining Welds in Piping; Figure Number IWB-2500- 9, 10 and 11"
Note (3) adds the words "Includes essentially 100% of weld length."

"Examination Category C-B, Pressure Retaining Nozzle Welds in Vessels; Figure Number IWC-2500-4 (a) or (b)"
Note (1) adds the words "Includes essentially 100% of the weld length."

Note: Duke Energy Corporation, with NRC approval, has adopted Code Case N-460 which defines "essentially 100%" as greater than 90% coverage.

III. Code Requirement From Which Relief Is Requested:

Relief is requested from the requirement of examining essentially 100% of the weld length. Due to part geometry and actual physical barriers, obtaining greater than 90% of the weld volume as defined in Code Case N-460, which is utilized by Duke Energy, is not possible.

Examination Category B-A

Reactor Vessel (Head-to-Flange Weld)

<u>Item Numbers</u>	<u>Actual Coverage Obtained</u>
B01.040.001	87.78%

See Note 1

Examination Category B-D

Reactor Vessel (Nozzle-to-Vessel Welds)

<u>Item Numbers</u>	<u>Actual Coverage Obtained</u>
B03.090.005A	43.70%
B03.090.006A	43.70%
B03.090.007A	43.70%
B03.090.008A	43.70%

See Note 1

See Note 1

See Note 1

See Note 1

Reactor Vessel (Nozzle Inner Radius Section)

<u>Item Numbers</u>	<u>Actual Coverage Obtained</u>	
B03.100.005	87.70%	See Note 1
B03.100.006	87.70%	See Note 1
B03.100.007	87.70%	See Note 1
B03.100.008	87.70%	See Note 1

Pressurizer (Nozzle-to-Vessel Welds)

<u>Item Numbers</u>	<u>Actual Coverage Obtained</u>	
B03.110.001	74.78%	See Note 1
B03.110.003	71.50%	See Note 1

Note 1

ASME Section V, T-441.3.2 Scanning Requirements, 1989 Edition with no addenda as modified by Code Case N-460.

This Paragraph requires scanning of the examination volume(s) using three angle beams and a straight beam from both sides of the weld.

When scanning for reflectors parallel to the weld, the angle beams shall be aimed at right angles to the weld axis, with the search unit(s) manipulated so that the ultrasonic beams pass through the entire volume of weld metal. The adjacent base metal in the examination volume must be completely scanned by two angle beams, but need not be completely scanned by both angle beams from both directions (any combination of two angle beams will satisfy the requirement).

When scanning for reflectors transverse to the weld, the angle beam search units shall be aimed parallel to the axis of longitudinal and circumferential welds. The search unit shall be manipulated so that the ultrasonic beams pass through all of the examination volume. Scanning shall be done in two directions 180 degrees to each other to the extent possible. Areas blocked by geometric conditions shall be examined from at least one direction.

Code Case N-460 allows credit for full volume coverage if it can be shown that greater than 90% of the required weld volume has been examined.

Examination Category B-D

Pressurizer (Nozzle Inner Radius Section)

<u>Item Numbers</u>	<u>Actual Coverage Obtained</u>	
B03.120.002	62.86%	See Note 2

NOTE 2

ASME Section XI, 1989 Edition, Examination Volume shown in Figure IWB-2500-7 (b)

Examination Category B-F

Steam Generator (Nozzle-to-Safe End Butt Welds)

<u>Item Numbers</u>	<u>Actual Coverage Obtained</u>	
B05.070.001	75.00%	See Note 3
B05.070.002	75.00%	See Note 3

Piping Dissimilar Metal Butt Welds

<u>Item Numbers</u>	<u>Actual Coverage Obtained</u>	
*B05.130.002	75.00%	See Note 3
*B05.130.003	75.00%	See Note 3

*Item numbers B05.130.002 and B05.130.003 no longer exist due to the Steam Generators being replaced. The new welds are no longer considered to be Dissimilar Metal Welds.

Examination Category B-J

Branch Connection Welds (NPS 4 or Larger)

<u>Item Numbers</u>	<u>Actual Coverage Obtained</u>	
B09.031.001	49.40%	See Note 3
B09.031.002	49.81%	See Note 3
B09.031.003	50.00%	See Note 3

Note 3

ASME Section XI, Appendix III, Paragraph III-4420, 1989 Edition with no addenda as modified by Code Case N-460. "The examination shall be performed using a sufficiently long examination beam path to provide coverage of the required examination volume in two-beam path directions. The examination shall be performed from two sides of the weld where practicable, or from one side of the weld, as a minimum."

Code Case N-460 allows credit for full volume coverage if it can be shown that greater than 90% of the required volume has been examined.

ASME Section XI Class 2 Components listed below:

Examination Category C-B

Nozzle Inner Radius Section

<u>Item Numbers</u>	<u>Actual Coverage Obtained</u>	
C02.022.002	84.30%	See Note 4

Note 4

Limitations caused by the ratio of the nozzle OD to the vessel thickness resulted in 84.30% coverage of the required volume. When the nozzle OD is small in relation to the vessel thickness, more coverage can be obtained when scanning from the vessel side.

Conducting examinations from nozzle boss and OD blend radius using compound angles; determining which angles to use; metal paths to calibrate and area of coverage are not accurate with manual calculations. Duke Energy is investigating the use of computer modeling to solve the limitation problems. Radiography is not practical because of the geometry of the component, which prevents placement of the film and exposure source.

Nozzle inner radius sections are examined with the ultrasonic method to the maximum extent practical from the vessel wall. Calibration blocks and procedures are in accordance with ASME Section V, Article 4.

IV. Basis for Relief:

ASME Section XI Class 1 Components listed below:

Examination Category B-A, Item B01.040, Pressure Retaining Welds in Reactor Vessel

During the ultrasonic examination of the Reactor Vessel Closure Head Weld 2RPV-W08 (Item Number B01.040.001) shown in Attachment 1, coverage of required examination volume could not be obtained. Geometric limitations caused by the proximity of lifting lugs and the head flange resulted in examination coverage of 87.78%. In order to achieve greater than 90% coverage, the weld would have to be redesigned to eliminate the interferences.

**Examination Category B-D, Items B03.090., B03.100.,
B03.110., B03.120., Full Penetration Welds of Nozzles
in Vessels and Nozzle Inner Radius Sections**

During the ultrasonic examination of the Reactor Vessel Outlet Nozzle to Shell Welds

2RPV-W15 (Item Number B03.090.005A)
2RPV-W16 (Item Number B03.090.006A)
2RPV-W17 (Item Number B03.090.007A)
2RPV-W18 (Item Number B03.090.008A)

shown in Attachment 2, coverage of the required examination volume was limited to 43.70%. Limitations caused by the nozzle geometry, i.e. the nozzle taper prevented obtaining greater than 90% coverage. In order to achieve additional coverage, the nozzle would have to be re-designed to eliminate the taper.

During the ultrasonic examination of the Reactor Vessel Outlet Nozzle to Shell Welds (Inner Radius Sections)

2RPV-W15 (Item Number B03.100.005)
2RPV-W16 (Item Number B03.100.006)
2RPV-W17 (Item Number B03.100.007)
2RPV-W18 (Item Number B03.100.008)

shown in Attachment 2, coverage of the required examination volume was limited to 87.70%. Limitations caused by the nozzle geometry, i.e. the nozzle taper prevented obtaining greater than 90% coverage. In order to achieve additional coverage, the nozzle would have to be re-designed to eliminate the taper.

During the ultrasonic examination of the Pressurizer Nozzle to Lower Head Weld 2PZR-10 (Item Number B03.110.001) shown in Attachment 3, coverage of the required examination volume could not be obtained. The examination coverage was limited to 74.78%, due to single-sided access caused by the nozzle geometry. In order to achieve more coverage, the nozzle would have to be redesigned to allow access from both sides.

During the ultrasonic examination of the Pressurizer Nozzle to Upper Head Weld 2PZR-12 (Item Number B03.110.003) shown in Attachment 3, coverage of the required examination volume could not be obtained. The examination coverage was limited to 71.50%, due to single-sided access caused by the nozzle geometry. In

order to achieve more coverage, the nozzle would have to be redesigned to allow access from both sides.

During the ultrasonic examination of the Pressurizer Spray Nozzle to Upper Head Weld 2PZR-12R (Item Number B03.120.002) shown in Attachment 3, coverage of the required examination volume could not be obtained. The examination coverage was limited to 62.86%. Limitations are caused by the ratio of the nozzle O. D. to the vessel thickness. When the nozzle O. D. is large in relation to the vessel thickness, less coverage can be obtained when scanning from the vessel side. Single-sided access caused by the nozzle geometry resulted in limited coverage of the required volume. In order to achieve more coverage the nozzle would have to be redesigned to allow access from both sides.

Examination Category B-F, Items B5.70., B5.130.
Pressure Retaining Dissimilar Metal Welds

Note: These 4 welds were cut out and re-welded due to Steam Generator Replacement

During the ultrasonic examination of the Steam Generator Nozzle-to-Safe End Welds:

2SGA-Inlet SE (B05.070.001) and
2SGA-Outlet SE (B05.070.002)

shown in Attachment 4, coverage of required examination volume could not be obtained. The examination coverage was limited to 75.00%. SEE NOTE 5.

During the ultrasonic examination of the Piping Dissimilar Metal Welds (Steam Generator Safe End to Pipe):

2NC2F-1-2 (B05.130.002) and
2NC2F-1-3 (B05.130.003)

shown in Attachment 4, coverage of required examination volume could not be obtained. The examination coverage was limited to 75.00%. SEE NOTE 5.

NOTE 5

Material characteristics and single-sided access caused by the component geometry prevents two-beam path direction coverage of the examination volume.

The most effective ultrasonic technique for the examination of dissimilar metal welds uses refracted longitudinal waves. The longitudinal wave is preferred as the austenitic weld metal and buttering create highly attenuative barriers to shear wave ultrasound. The longitudinal wave is less affected by these difficulties. However, the longitudinal wave is affected by mode conversion when it strikes the inside surface of the safe end or pipe at any angle other than a right angle to the surface.

The calculations below shows that a 45° refracted longitudinal wave striking the inside surface of a pipe will produce a 22.9° refracted shear wave in addition to the normally expected 45° reflected longitudinal wave.

$$\begin{aligned}\sin^{-1} &= (\sin 45^\circ \times V_s) + V_L \\ &= (0.707 \times 0.123) + 0.223\end{aligned}$$

Where: \sin^{-1} is the shear wave angle

V_s is the shear wave velocity of the stainless steel safe end/pipe material in inches/ μ sec.


V_L is the longitudinal wave velocity of the stainless steel safe/pipe end material in inches/ μ sec.

As shown in the graph below, the mode conversion process creates two sound beams of differing intensities reflecting off of the inside surface.¹ At incident angles greater than 30° the shear wave will predominate. However, the shear wave is attenuated and scattered by the austenitic weld metal and the layer of buttering. The examination sensitivity is degraded to such an extent that any examination using the second sound path leg is meaningless. Therefore, the two-beam path direction coverage requirement is impractical.

In order to obtain the required two-beam path direction coverage, welds would have to be re-designed to allow scanning from both sides.

¹ Firestone, F. A. : Tricks with the Supersonic Reflectoscope, *J. Soc. Nondestructive Testing*, vol. 7, no. 2 Fall 1948.

Reflected Sound Beam Energy In Steel on A Free Face



Examination Category B-J Item B09.031.Pressure Retaining Welds in Piping

During the ultrasonic examination of Weld Number 2NC16-WN8A (B09.031.001) shown in Attachment 5, coverage of required examination volume could not be obtained. The examination coverage was limited to 49.40%. SEE NOTE 6.

During the ultrasonic examination of Weld Number 2NC22-WN4 (B09.031.002) shown in Attachment 5, coverage of required examination volume could not be obtained. The examination coverage was limited to 49.81%. SEE NOTE 6.

During the ultrasonic examination of Weld Number 2NC22-WN8 (B09.031.003) shown in Attachment 5, coverage of required examination volume could not be obtained. The examination coverage was limited to 50.00%. SEE NOTE 6.

Note 6

Single-sided access caused by the branch connection geometry prevents scanning from both sides of the weld.

Cast stainless steel characteristics mandate the use of refracted longitudinal waves. This type of ultrasonic

wave produces mode conversion at the pipe inside surface, thus preventing the use of sound path distances beyond the first "leg". Therefore, coverage of the required examination volume in two-beam path directions is not practical. In order to obtain the required two-beam path direction coverage, the branch connections and the elbow to pump weld would have to be re-designed to allow scanning from both sides of the weld over the required examination volume.

ASME Section XI Class 2 Components listed below:

Examination Category C-B, Items C2.22 Pressure Retaining Nozzle Welds in Vessels

NOTE: THIS WELD AND GENERATOR HAVE BEEN REPLACED

During the ultrasonic examination of the Feedwater Nozzle Inner Radius 2SGA-SB-02 (C02.022.002) shown in Attachment 6, coverage of the required examination volume was limited to 84.30%. Limitations were caused by the ratio of the nozzle OD to the vessel thickness. When the nozzle OD is small in relation to the vessel thickness, more coverage can be obtained when scanning from the vessel side. Duke Energy Corporation is investigating the use of computer modeling to solve the limitation problem.

Nozzle inner radius sections were examined with the ultrasonic method to the maximum extent practical from the vessel wall. Calibration blocks and procedures were in accordance with ASME Section V, Article 4.

V. Alternate Examinations or Testing:

The use of radiography as an alternate volumetric examination for all the above listed components is not practical due to component thickness and geometric configurations. Other restrictions making radiography impractical are the physical barriers prohibiting access for placement of source, film, image quality indicator, etc.

Since radiography is impractical, Duke Energy Corporation will continue to use ultrasonic examination procedures to obtain maximum coverage to the extent practicable of the Item Numbers referenced in Section I of this Request for Relief. No additional ultrasonic examinations or alternate exams are planned during the

current interval for the welds referenced in Section I of the request.

For the Class 1 Components listed in Section I above, Duke Energy proposes to use the pressure test to compliment the limited examination coverage. The Code requires (reference Table IWB-2500-1, Item Number B15.) that a system leakage test be performed after each refueling outage. Additionally a system hydrostatic test (reference Table IWB-2500-1, Item Number B15.) is required once during each 10-year inspection interval. These tests require a VT-2 visual examination for evidence of leakage. This testing will provide adequate assurance of pressure boundary integrity.

For the Class 2 Components listed in Section I above, Duke Energy proposes to use the pressure test to compliment the limited examination coverage. The Code requires (reference Table IWC-2500-1, Item Number C7.) that a system pressure test be performed once each period. Additionally a system hydrostatic test (reference Table IWB-2500-1, Item Number C7.) is required once during each 10-year inspection interval. These tests require a VT-2 visual examination for evidence of leakage. This testing will provide adequate assurance of pressure boundary integrity.

VI. Justification for the Granting of Relief

Examination Category B-A, Item B01.040, Pressure Retaining Welds in Reactor Vessel

During the ultrasonic examination of the Reactor Vessel Closure Head Weld 2RPV-W08 (Item Number B01.040.001) coverage of the required volume was limited to 87.78%. This limitation is caused by the proximity of three lifting lugs and the head flange. In order to achieve greater than 90% coverage, the weld would have to be redesigned to eliminate the interfering conditions. Reference Attachment 1

The Reactor Vessel Closure Head Weld listed above is located on the McGuire Unit 2 Reactor Vessel. This weld is not exposed to significant neutron fluence and is not prone to negative material property changes (i.e., embrittlement) associated with neutron bombardment. This weld was rigorously inspected by radiography and

dye penetrant during construction and verified to be free from unacceptable fabrication defects. If a leak were to occur at the weld in question, the reactor coolant leakage calculation which is normally performed daily (and required by Technical Specifications to be performed every 72 hours) would provide an early indication of leakage. The unidentified leakage specification in Technical Specification 3.4.13 is 1 gpm. Several other indicators such as containment radiation monitors EMF-38, -39, and -40, the containment floor and equipment sump levels, containment humidity instruments, and the ventilation unit condensate drain tank level would provide early indication of weld leakage for prompt Operations and Engineering evaluation.

Duke Energy Corporation will continue to examine the referenced items using ultrasonic techniques to the maximum extent practical. These examinations will provide assurance of weld/component integrity. It is the belief of Duke Energy that this limited examination is the best available.

Pursuant to 10 CFR 50.55a(g)(6)(i), granting this relief for the welds listed under Examination Category B-A will provide reasonable assurance of weld/component integrity, and is authorized by law. In addition, the requested relief will not endanger life or property or the common defense and security and is otherwise in the public interest giving due consideration to the burden upon the licensee that could result if the requirements were imposed on the facility.

Examination Category B-D, Items B3.90., B3.100., B3.110., B3.120., Full Penetration Welds of Nozzles in Vessels and Nozzle Inner Radius Sections

The Reactor Vessel (Nozzle-to-Vessel Welds) at 22, 158, 202 and 338 degrees are:

2RPV-W15 (Item Numbers B03.090.005A),
2RPV-W16 (Item Numbers B03.090.006A),
2RPV-W17 (Item Numbers B03.090.007A), and
2RPV-W18 (Item Numbers B03.090.008A).

These four Outlet Nozzle to Shell Welds were limited due to the reactor vessel nozzle configuration. Therefore, the 100% volumetric examination is impractical for this weld. The imposition of this requirement would create a considerable burden on Duke

Energy Corporation. During the examination of these welds, techniques were utilized to obtain the maximum possible coverage. Reference Attachment 2 for scan coverage.

The Reactor Vessel (Nozzle Inner Radius Sections) are:

2RPV-W15 (Item Numbers B03.100.005),
2RPV-W16 (Item Numbers B03.100.006),
2RPV-W17 (Item Numbers B03.100.007), and
2RPV-W18 (Item Numbers B03.100.008).

These four Outlet Nozzle Inner Radius Sections are limited due to the reactor vessel nozzle configuration. Therefore, the 100% volumetric examination is impractical for this weld. The imposition of this requirement would create a considerable burden on Duke Energy Corporation. During the examination of these welds, techniques were utilized to obtain the maximum possible coverage. Reference Attachment 2 for scan coverage.

The Pressurizer (Nozzle-to-Vessel Welds) are 2PZR-10 (Item Number B03.110.001/Nozzle to Lower Head), and 2PZR-12 (Item Number B03.110.003/Nozzle to Upper Head). These two Pressurizer Nozzle to Head Welds are limited due to single-sided access caused by the nozzles geometry. In order to achieve more coverage, the nozzles would have to be redesigned to allow access from both sides. Therefore, the 100% volumetric examination is impractical for this weld. The imposition of this requirement would create a considerable burden on Duke Energy Corporation. During the examination of these welds, techniques were utilized to obtain the maximum possible coverage. Reference Attachment 3 for scan coverage.

The Pressurizer (Nozzle Inner Radius Section) is: 2PZR-12R (Item Number B03.120.002). This Pressurizer Nozzle to Upper Head Weld (Inner Radius Section) is limited due to the ratio of the nozzle O.D. to the vessel thickness. When the nozzle O.D. is large in relation to the vessel thickness, less coverage can be obtained when scanning from the vessel side. Therefore, the 100% volumetric examination is impractical for this weld. The imposition of this requirement would create a considerable burden on Duke Energy Corporation. During the examination of these welds, techniques were utilized to obtain the maximum

possible coverage. Reference Attachment 3 for scan coverage.

Although the examination volume requirements as defined in ASME Section XI 1989 Edition, Figure IWB-2500-7 could not be met, the amount of coverage obtained for these examinations provides an acceptable level of quality and integrity.

The Reactor Pressure Vessel (RPV) Outlet Nozzle to Shell Welds including the Nozzle Inner Radius Welds (Weld Numbers 2RPV-W15, 2RPV-W16, 2RPV-W17, 2RPV-W18) are by definition not in the beltline area of the RPV; therefore, it is not subject to fluence levels equal to or greater than 1 E7 n/cm^2 . RPV materials not in the highly irradiated beltline region are not prone to negative material property changes (i.e., embrittlement) associated with neutron bombardment. Based upon 10 CFR 50.55a, the ASME Code Section XI 1989 Edition requires essentially 100% RPV weld volumetric examinations of beltline welds during every inspection interval. The RPV Outlet Nozzle Welds do not meet the requirements of a beltline weld due to a significantly lower fluence exposure, resulting in far less potential degradation of ductility. The McGuire Nuclear Station Unit 2 RPV was fabricated by the Combustion Engineering Company and is free from unacceptable fabrication defects. Combustion Engineering performed rigorous state-of-the-art RPV inspections following fabrication to ensure no significant flaws existed.

The Pressurizer Nozzle to Lower/Upper Head Welds (Weld Numbers 2PZR-10, 2PZR-12, and 2PZR-12R) are located on the lower/upper head of the pressurizer and are not part of the reactor pressure vessel. These welds are not exposed to significant neutron fluence and are not prone to negative material property changes (i.e., embrittlement) associated with neutron bombardment. The McGuire Nuclear Station Unit 2 Pressurizer was fabricated by Westinghouse and is free from unacceptable fabrication defects. Westinghouse performed rigorous state-of-the-art inspections following fabrication to ensure no significant flaws existed.

The McGuire Unit 2 RPV Outlet Nozzle geometry and Pressurizer Nozzle to Lower/Upper Head Weld geometry prevents obtaining 100% volumetric examination coverage and the 100% examinations are impractical. Replacement or re-design of these nozzles is not a viable

alternative and would create an undue burden on Duke Energy Corporation (See Note A)

Note A: The McGuire Plant Technical Specifications require primary coolant leakage detection systems to be operable at all times or the Unit is to be taken to a shutdown condition. As per Reg. Guide 1.45, "Reactor Coolant Pressure Boundary Leakage Detection Systems", these leakage detection systems are of sufficient sensitivity so as to detect an increase in primary leakage of 1 gpm within 1 hour. Plant Technical Specifications also impose limits on the total amount of primary coolant leakage allowable during Unit operation. As a result, the Primary Coolant leakage is required to be maintained at low levels at all times and systems are in place to detect increases in the primary coolant leakage. In addition to the required leakage limits and detection systems, McGuire Engineering maintains an aggressive monitoring program to detect and trend all levels of leakage, regardless of magnitude. As a result, there is added confidence that pressure boundary leakage will be identified well within the scope of leak-before-break methodology.

Pursuant to 10 CFR 50.55a(g)(6)(i), granting this relief for the welds listed under Examination Category B-D will provide reasonable assurance of weld/component integrity, and is authorized by law. In addition, the requested relief will not endanger life or property or the common defense and security and is otherwise in the public interest giving due consideration to the burden upon the licensee that could result if the requirements were imposed on the facility.

Examination Category B-F, Items B5.70., B5.130.
Pressure Retaining Dissimilar Metal Welds

Steam Generator (Nozzle-to-Safe End Butt Welds)

2SGA-INLET-SE (B05.070.001),
2SGA-OUTLET-SE (B05.070.002)

Piping Dissimilar Metal Butt Welds

2NC2F-1-2 (B05.130.002),
2NC2F-1-3 (B05.130.003)

These four Dissimilar Metal Butt Welds are limited due to material characteristics and single-sided access caused by the component geometry prevents two-beam path

direction coverage of the examination volume. In order to obtain the required two-beam path direction coverage, these four welds would have to be re-designed to allow scanning from both sides. The Steam Generator Nozzle-to-Safe End Butt Welds (Weld Numbers 2SGA-INLET-SE and 2SGA-OUTLET-SE) are located on the inlet and outlet of the steam generators nozzles for the reactor coolant piping. Weld Numbers 2NC2F-1-2, and 2NC2F-1-3 are located on the Safe End to Reactor Coolant Piping. The weld geometry on these four welds prevented obtaining 100% volumetric examination coverage and therefore the 100% examinations are impractical. During the examination of these welds, techniques were utilized to obtain the maximum possible coverage. Reference Attachment 4 for scan coverage.

Although the examination volume requirements as defined in ASME Section XI 1986 Edition, Figure IWB-2500-8 could not be met, the amount of coverage obtained for these examinations provided an acceptable level of quality and integrity. Furthermore, these four welds were cutout and re-welded during the steam generator replacement (2EOC11 outage). These new welds received a complete radiographic examination to satisfy ASME Section III requirements. There is no safety significance to the lack of weld examination coverage for the previous cycle.

Pursuant to 10 CFR 50.55a(g)(6)(i), granting this relief for the welds listed under Examination Category B-F will provide reasonable assurance of weld/component integrity, and is authorized by law. In addition, the requested relief will not endanger life or property or the common defense and security and is otherwise in the public interest giving due consideration to the burden upon the licensee that could result if the requirements were imposed on the facility.

Examination Category B-J, Item B9.31, Pressure Retaining Welds in Piping

Branch Connection Welds:

During the ultrasonic examination of the Pipe to Nozzle Branch Connection, Weld Number 2NC16-WN8A, (B09.031.001) shown in Attachment 5, coverage of the required examination volume could not be obtained. The examination coverage was limited due to single-sided access caused by the branch connection geometry that prevents scanning from both sides of the weld.

During the ultrasonic examination of the Pipe to Nozzle Branch Connection, Weld Number 2NC22-WN4 (B09.031.002) shown in Attachment 5, coverage of the required examination volume could not be obtained. The examination coverage was limited due to single-sided access caused by the branch connection geometry that prevents scanning from both sides of the weld.

During the ultrasonic examination of the Pipe to Nozzle Branch Connection, Weld Number 2NC22-WN8 (B09.031.003) shown in Attachment 5, coverage of the required examination volume could not be obtained. The examination coverage was limited due to single-sided access caused by the branch connection geometry that prevents scanning from both sides of the weld.

In order to obtain the required coverage, these welds would have to be redesigned. The 100% volumetric examination is impractical due to nozzle and weld material geometry, or branch piping interferences. Replacement or re-design of this piping Class 1 piping is not a viable alternative and would create an undue burden on Duke Energy Company. During the examination of these welds, techniques were utilized to obtain the maximum possible coverage. Reference Attachment 5 for scan coverage.

Although the examination volume requirements as defined in ASME Section XI 1989 Edition, Figures IWB-2500-9 thru -11 could not be met, the amount of coverage obtained for these examinations provides an acceptable level of quality and integrity. See Note B.

Note B: The McGuire Plant Technical Specifications require primary coolant leakage detection systems to be operable at all times or the Unit is to be taken to a shutdown condition. As per Reg. Guide 1.45, "Reactor Coolant Pressure Boundary Leakage Detection Systems", these leakage detection systems are of sufficient sensitivity so as to detect an increase in primary leakage of 1 gpm within 1 hour. Plant Technical Specifications also impose limits on the total amount of primary coolant leakage allowable during Unit operation. As a result, the Primary Coolant leakage is required to be maintained at low levels at all times and systems are in place to detect increases in the primary coolant leakage. In addition to the required leakage limits and detection systems, McGuire Engineering maintains an aggressive monitoring program

to detect and trend all levels of leakage, regardless of magnitude. As a result, there is added confidence that pressure boundary leakage will be identified well within the scope of leak-before-break methodology.

Pursuant to 10 CFR 50.55a(g)(6)(i), granting this relief for the welds listed under Examination Category B-J will provide reasonable assurance of weld/component integrity, and is authorized by law. In addition, the requested relief will not endanger life or property or the common defense and security and is otherwise in the public interest giving due consideration to the burden upon the licensee that could result if the requirements were imposed on the facility.

ASME Section XI Class 2 Components listed below:

Examination Category C-B, Items C2.22 Pressure Retaining Nozzle Welds in Vessels

During the ultrasonic examination of the Feedwater Nozzle to Shell Weld 2SGA-SB-02 (C02.022.002) shown in Attachment 6, coverage of the required examination volume was limited to 84.30%. Limitations were caused by the ratio of the nozzle OD to the vessel thickness. When the nozzle OD is small in relation to the vessel thickness, more coverage can be obtained when scanning from the vessel side. Duke Energy Corporation is investigating the use of computer modeling to solve the limitation problems for nozzle inner radius examinations.

Nozzle inner radius sections were examined with the ultrasonic method to the maximum extent practical from the vessel wall. Calibration blocks and procedures were in accordance with ASME Section V, Article 4.

Although the examination volume requirements as defined in ASME Section XI 1989 Edition, Figure IWC-2500-4 (a) or (b) could not be met, the amount of coverage obtained for these examinations provided an acceptable level of quality and integrity.

The steam generators and associated nozzles have been replaced and there is no safety significance to the past examination coverage. The current steam generators were fully inspected by BWI prior to installation and relief for inspection of currently installed equipment is not requested.

Pursuant to 10 CFR 50.55a(g)(6)(i), granting this relief for the welds listed under Examination Category C-B will provide reasonable assurance of weld/component integrity, and is authorized by law. In addition, the requested relief will not endanger life or property or the common defense and security and is otherwise in the public interest giving due consideration to the burden upon the licensee that could result if the requirements were imposed on the facility.

VII. Implementation Schedule:

These examinations will continue to be scheduled in accordance with the requirements of ASME Section XI for future inspection intervals at McGuire Nuclear Station, Unit 2.

Attachment 1.

Drawings of affected weld details including calculation methods for:

B01.040.001

Attachment 2.

Drawings of affected weld details including calculation methods for:

B03.090.005A
B03.090.006A
B03.090.007A
B03.090.008A
B03.100.005
B03.100.006
B03.100.007
B03.100.008

Attachment 3.

Drawings of affected weld details including calculation methods for:

B03.110.001
B03.110.003
B03.120.002

Attachment 4 .

Drawings of affected weld details including calculation methods for:

B05.070.001

B05.070.002

B05.130.002

B05.130.003

Attachment 5.

Drawings of affected weld details including calculation methods for:

B09.031.001

B09.031.002

B09.031.003

Attachment 6.

Drawings of affected weld details including calculation methods for:

C02.022.002

The following individuals were involved in the development of this request for relief. Ken Pitser (McGuire Engineering) provided input to the engineering justification (section VI, Note A and B) for granting relief. Jim McArdle (NDE Level III) provided sections III., IV., and V. Gary Scarboro (McGuire ISI Plan Manager) compiled and completed the request.

Sponsored By: Gary D Scarboro Date 8/19/99

Approved By: L. Kevin Rhyme Date 8/19/99

DUKE POWER COMPANY
ULTRASONIC EXAMINATION DATA SHEET FOR PLANAR REFLECTORS
 (Reg. Guide 1.150)

Exam Start: 0106 Form NDE-UT-2A/RPV
 Exam Finish: 0251 Revision 4

Station: McGuire Unit: 2 Component/Weld ID: 2RPV-W08 Date: 10/10/97

Weld Length (in.): 542" Surface Condition: AS GROUND Lo: 0° VES. Surface Temperature: 80 ° F

Examiner: Larry Mauldin <i>Larry Mauldin</i> Level: III	Scans: 45 <input checked="" type="checkbox"/> 55 dB 70 <input type="checkbox"/> _____ dB 45T <input checked="" type="checkbox"/> 55 dB 70T <input type="checkbox"/> _____ dB 60 <input type="checkbox"/> _____ dB 60T <input type="checkbox"/> _____ dB Other: _____ dB	Pyrometer S/N: MCNDE 27022
Examiner: N/A Level: II		Cal Due: 2/14/98
Procedure: NDE-660 Rev: 2 FC: 97-15		Configuration: .08 Upper Head to PC.09 Flar
Calibration Sheet No: 9702053		PC.08 to PC.09

IND #	<input checked="" type="checkbox"/>	Max % DAC	Mp Max	W Max	L Max	L1	L2	W1	Mp1	W2	Mp2	Beam Dir.	Exam Surf.	Scan	Damps	
		DO NOT WRITE IN THIS SPACE				20%dac	20%dac	20%dac	20%dac	20%dac	20%dac		DO NOT WRITE IN THIS SPACE			
						50%dac	50%dac	50%dac	50%dac	50%dac	50%dac					
						100%dac	100%dac	100%dac	100%dac	100%dac	100%dac					
NRI	45°															

Remarks:

Limitations: (see NDE-UT-4) 90% or greater coverage obtained: yes no

Reviewed By: *Paul S. [Signature]* Level: II Date: 11-4-97 Authorized Inspector: *[Signature]* Date: 11-6-97 Sheet _____ of _____

Item No: B01.040.001

SERIAL No. 98-005
 Attachment 1
 Page 1 of 17

DUKE POWER COMPANY						Exam Start: 0101		Form NDE-UT-2A/RPV		
ULTRASONIC EXAMINATION DATA SHEET FOR PLANAR REFLECTORS						Exam Finish: 0246		Revision 4		
<i>(Reg. Guide 1.150)</i>										
Station: McGuire		Unit: 2	Component/Weld ID: 2RPV-W08				Date: 10/10/97			
Weld Length (in.): 542"		Surface Condition: AS GROUND		Lo: 0° VES.		Surface Temperature: 80 ° F				
Examiner: Marion T. Weaver <i>Marion T. Weaver</i>		Level: II	Scans:			Pyrometer S/N: MCNDE 27022				
Examiner: Winfred C. Leeper <i>Winfred C. Leeper</i>		Level: II	45 <input type="checkbox"/> _____ dB	70 <input type="checkbox"/> _____ dB	Cal Due: 2/14/98					
Procedure: NDE-660		Rev: 2	45T <input type="checkbox"/> _____ dB	70T <input type="checkbox"/> _____ dB	Configuration: .08 Upper Head to PC.09 Flar					
		FC:	60 <input type="checkbox"/> _____ dB							
Calibration Sheet No: 9702062		97-15	60T <input type="checkbox"/> _____ dB							
			Other: 35°-52 dB	Scan Surface: OD						

IND #	Max % DAC	Mp Max	W Max	L Max	L1	L2	W1	Mp1	W2	Mp2	Beam Dir.	Exam Surf.	Scan	Damps
4														
	DO NOT WRITE IN THIS SPACE				20%dac	20%dac	20%dac	20%dac	20%dac	20%dac		DO NOT WRITE IN THIS SPACE		
					50%dac	50%dac	50%dac	50%dac	50%dac	50%dac				
					100%dac	100%dac	100%dac	100%dac	100%dac	100%dac				
NRI	35°													

Remarks:					
Limitations: (see NDE-UT-4) <input type="checkbox"/>		90% or greater coverage obtained: yes <input type="checkbox"/> no <input checked="" type="checkbox"/>		Sheet _____ of _____	
Reviewed By: <i>Red Griffith</i>	Level: II	Date: 11-4-97	Authorized Inspector: <i>Dejein</i>		Date: 11-6-97
			Item No: B01.040.001		

Attachment 1
Page 2 of 17

**DUKE POWER COMPANY
ISI LIMITATION REPORT**

FORM NDE-UT-4

Revision 1

Component/Weld ID: 2RPV-W08

Item No: B01.040.001

Remarks:

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L 539° to L 3.0° INCHES FROM WO 1.5° to BEYOND
 ANGLE: 0 45 60 Other 35° FROM N/A DEG to N/A DEG

LIFTING LUG @ 0°

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L 177.6° to L 183.6° INCHES FROM WO 1.5° to BEYOND
 ANGLE: 0 45 60 Other 35° FROM N/A DEG to N/A DEG

LIFTING LUG @ 120°

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L 358.3° to L 364.3° INCHES FROM WO 1.5° to BEYOND
 ANGLE: 0 45 60 Other 35° FROM N/A DEG to N/A DEG

LIFTING LUG @ 240°

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L N/A to L N/A INCHES FROM WO 3.0° to BEYOND
 ANGLE: 0 45 60 Other 35° FROM 0 DEG to 360

FLANGE

Prepared By: Ray Mauldin Level: II Date: 10-10-97 Sketch(s) attached yes no Sheet of

Reviewed By: Rob Sheffield Date: 11-4-97 Authorized Inspector: Reglein Date: 11-6-97

Attachment 1
Page 3 of 17

DUKE POWER COMPANY						NDE-91-1			
Limited Examination Coverage Worksheet						Revision 0			
Examination Volume/Area Defined									
<input checked="" type="checkbox"/> Base Metal		<input type="checkbox"/> Weld		<input type="checkbox"/> Near Surface		<input type="checkbox"/> Bolting		<input type="checkbox"/> Inner Radius	
Area Calculation				Volume Calculation					
7.0/2(3.5+3.8) = 25.55 X 2 = 51.1 SQ. IN				51.1 SQ IN X 542" = 27696 CU. IN					
Coverage Calculations									
Scan #	Angle	Beam Direction	Area Examined (sq.in.)	Length Examined (in.)	Volume Examined (cu.in.)	Volume Required (cu.in.)	Percent Coverage		
					121557.8	138481	87.78		

		Item No: B01.040.001
Prepared By: <i>Larry Mauldin</i>	Level: <i>III</i>	Date: <i>10-10-97</i>
Reviewed By: <i>Rod Kiffel</i>	Level: <i>II</i>	Date: <i>11-4-97</i>

DUKE POWER COMPANY Limited Examination Coverage Worksheet	NDE-91-1
Revision 0	

Examination Volume/Area Defined	
<input checked="" type="checkbox"/> Base Metal <input type="checkbox"/> Weld <input type="checkbox"/> Near Surface <input type="checkbox"/> Bolting <input type="checkbox"/> Inner Radius	
Area Calculation	Volume Calculation
$7.0/2(3.5+3.8) = 25.55 \times 2 = 51.1 \text{ SQ. IN}$	$51.1 \text{ SQ IN} \times 542" = 27696 \text{ CU. IN}$

Coverage Calculations							
Scan #	Angle	Beam Direction	Area Examined (sq.in.)	Length Examined (in.)	Volume Examined (cu.in.)	Volume Required (cu.in.)	Percent Coverage
1	0	N/A	51.1	52.4	26776.4	26776.4	100.00
1	0	N/A	28.7	18	516.6	919.8	56.16
2	35	S2	47.95	524	25125.8	26776.4	93.84
2	35	S2	11.7	18	210.6	919.8	22.90
3	45	S2	48.9	524	25623.6	26776.4	95.69
3	45	S2	8.4	18	151.2	919.8	16.44
4	35/45	CW	40.6	524	21274.4	26776.4	79.45
4	35/45	CW	16.8	18	302.4	919.8	32.88
5	35/45	CCW	40.6	524	21274.4	26776.4	79.45
5	35/45	CCW	16.8	18	302.4	919.8	3.29

Item No:	B01.040.001
----------	-------------

Prepared By: <i>Randy Mauldin</i>	Level: <i>III</i>	Date: <i>10-10-97</i>
Reviewed By: <i>Rod Sheffield</i>	Level: <i>II</i>	Date: <i>11-4-97</i>

DUKE POWER COMPANY Limited Examination Coverage Worksheet	NDE-91-1
Revision 0	

Examination Volume/Area Defined				
<input type="checkbox"/> Base Metal	<input checked="" type="checkbox"/> Weld	<input type="checkbox"/> Near Surface	<input type="checkbox"/> Bolting	<input type="checkbox"/> Inner Radius

Area Calculation	Volume Calculation
$7.0/2(1.375 + 0.8) = 7.6 \text{ SQ. IN.}$	$7.6 \times 542 = 4119.2 \text{ CU. IN.}$

Coverage Calculations							
Scan #	Angle	Beam Direction	Area Examined (sq.in.)	Length Examined (in.)	Volume Examined (cu.in.)	Volume Required (cu.in.)	Percent Coverage
1	0	N/A	7.6	542	4119.2	4119.2	100.00
2	35	S2	7.6	524	3982.4	3982.4	100.00
3	35	S2	1.4	18	25.2	136.8	18.42
3	35	S1	4.1	542	2222.2	4119.2	53.95
4	45	S2	7.6	524	3982.4	3982.4	100.00
4	45	S2	0.95	18	17.1	136.8	12.50
5	45	S1	2.8	542	1517.6	4119.2	36.84
6	35	CW	7.6	542	4119.2	4119.2	100.00
7	35	CCW	7.6	542	4119.2	4119.2	100.00
8	45	CW	7.6	542	4119.2	4119.2	100.00

Item No:	B01.040.001
----------	-------------


Prepared By: <i>Larry Mauldin</i>	Level: <i>III</i>	Date: <i>10-10-97</i>
-----------------------------------	-------------------	-----------------------

Reviewed By: <i>Rod Jeffell</i>	Level: <i>II</i>	Date: <i>11-4-97</i>
---------------------------------	------------------	----------------------

DUKE POWER COMPANY						NDE-91-1			
Limited Examination Coverage Worksheet						Revision 0			
Examination Volume/Area Defined									
<input type="checkbox"/> Base Metal		<input checked="" type="checkbox"/> Weld		<input type="checkbox"/> Near Surface		<input type="checkbox"/> Bolting		<input type="checkbox"/> Inner Radius	
Area Calculation				Volume Calculation					
7.0/2(1.375 + 0.8) = 7.6 SQ. IN.				7.6 X 542 = 4119.2 CU. IN.					
Coverage Calculations									
Scan #	Angle	Beam Direction	Area Examined (sq.in.)	Length Examined (in.)	Volume Examined (cu.in.)	Volume Required (cu.in.)	Percent Coverage		
9	45	CCW	7.6	542	4119.2	4119.2	100.00		
					32342.9	37072.8	87.24		

		Item No: B01.040.001
Prepared By: <i>Larry Mauldin</i>	Level: <i>III</i>	Date: <i>10-10-97</i>
Reviewed By: <i>Bob Sheffield</i>	Level: <i>I</i>	Date: <i>11-4-97</i>

MNS UNIT 2
RPV HEAD



WELD I.D. 2 RPV-W08
ITEM # B01.040.001

EXAM AREAS

BASE METAL

A-B-C-D $\frac{7.0}{2}(3.5+3.8) = 25.55 \text{ sq. in.}$

E-F-G-H $\frac{7.0}{2}(3.5+3.8) = 25.55 \text{ sq. in.}$

51.1 sq. in.


WELD METAL

B-D-E-F $\frac{7.0}{2}(1.375+.8) = 7.625$

7.6 sq. in.

SCALE 1/4" = 1.0"

MNS UNIT 1
RPV HEAD



WELD I.D. 2RPV-W08
ITEM # BOI.040 DCH

EXAM AREAS:

BASE METAL

Loss: 0° TOTAL COVERAGE 51.1 sq.in.

35° S1-S2 OR S2-S1 =
A-B-D $\frac{2.1 \times 3.0}{2} = 3.15 \text{ sq.in.}$


45° S1-S2 OR S2-S1 =
A-B-C $\frac{2.1 \times 2.1}{2} = 2.2 \text{ sq.in.}$

35° 51.1 - 3.15 = COVERAGE 47.95 sq.in.

45° 51.1 - 2.2 = COVERAGE 48.9 sq.in.

SCALE 1/4" = 1.0"

MNS UNIT 2
RPV HEAD



WELD I.D. 2RPV-W08
ITEM # B01.040.071

WELD METAL

35° S1-S2 TOTAL COVERAGE 7.6 sq.in.
35° S2-S1

A-B-E-F $\frac{1.375}{2} (3.8 + 2.2) = 4.125$

COVERAGE 4.1 sq.in.

45° S1-S2 TOTAL COVERAGE 7.6 sq.in.
45° S2-S1


A-B-C-D $\frac{1.375}{2} (2.7 + 1.4) = 2.818$

COVERAGE 2.8 sq.in.

0° TOTAL COVERAGE 7.6 sq.in.

SCALE 1/4" = 1.0"

MNS UNIT 1
RPV HEAD



WELD I.D. ZRPV-W08
ITEM # B01.040.001

BASE METAL:
35°/45° CW & CCW

LOSS:
A-B-C-D = 7.0 x 1.5 = 10.5 sq.in.

(TOTAL AREA) 51.1 sq.in. - 10.5 sq.in. = 40.6


CW/CCW SCAN COVERAGE = 40.6 sq.in.

WELD METAL:

CW/CCW SCAN COVERAGE (TOTAL) 7.6 sq.in.

SCALE 1/4" = 1.0"

MNS UNIT 2
RPV HEAD



WELD I.D. 2RPV-W08
ITEM # 301.04001

LIMITATIONS Due To Loss

BASE METAL

0°

LOSS:

A-B-C-D

$3.2 \times 7.0 = 22.4 \text{ sq. in.}$

(TOTAL AREA) $51.1 - 22.4 = 28.7 \text{ sq. in.}$

COVERAGE 28.7 sq. in.

WELD METAL


0°

TOTAL COVERAGE 7.6 sq. in.

NOTE: THIS COVERAGE IS FOR 1 LUG ONLY.
FOR FINAL PERCENTAGE MULTIPLY BY 3.

SCALE 1/4" = 1.0"

MNS UNIT 2
RPV HEAD



WELD I.D. 2RPV-W08
ITEM # 301.040.001

LIMITATIONS DUE TO LUGS

BASE METAL

35° &/or 45° CW &/or CCW

LOSS:

A-B-C-D + E-F-G-H

$$1.5 \times 7.0 + 3.4 \times 7.0 =$$

$$10.5 + 23.8 = 34.3 \text{ sq. in.}$$

$$(\text{TOTAL AREA}) 51.1 - 34.3 = 16.8 \text{ sq. in.}$$

CW & CCW COVERAGE = 16.8 sq. in.

WELD METAL

CW & CCW COVERAGE (TOTAL) 7.6 sq. in.

NOTE: THIS COVERAGE IS FOR 1 LUG ONLY.
FOR FINAL PERCENTAGE MULTIPLY BY 3.

SCALE 1/4" = 1.0"

MNS UNIT 2
RPV HEAD

WELD I.D. 2RPV WOB
ITEM # B01.040.001

LIMITATIONS DUE TO LUGS

BASE METAL:

35° S1-S2,

(A-C-E-I) - (G-H-I) =

$$\frac{2.2}{2} (8.9 + 3.7) - \frac{1.2 \times 2.5}{2} =$$

$$13.2 - 1.5 = 11.7$$

COVERAGE 11.7 sq. in.

45° S1-S2

(A-B-D-I) - (F-H-I) =


$$\frac{2.0}{2} (7.2 + 2.3) - \frac{1.0 \times 2.2}{2} =$$

$$9.5 - 1.1 = 8.4$$

COVERAGE 8.4 sq. in.

NOTE: THIS COVERAGE IS FOR 1 LUG ONLY.
FOR FINAL PERCENTAGE MULTIPLY BY 3.

SCALE 1/4" = 1.0"



MNS UNIT 2
RPV HEAD

WELD I.D. 2RPV-W08
ITEM # 301.040.001

LIMITATIONS DUE TO LUGS

WELD METAL:

35° S2-S1

$$A.C.D.F \frac{1.375}{2}(3.8+2.2) = 4.125$$

COVERAGE 4.1 sq. in.

45° S2-S1


$$A.B.E-F \frac{1.375}{2}(2.7+1.4) = 2.818$$

COVERAGE 2.8 sq. in.


NOTE: THIS COVERAGE IS FOR 1 LUG ONLY.
FOR FINAL PERCENTAGE MULTIPLY BY 3.

NO ADDITIONAL LOSS WAS INCLUDED
DUE TO LUGS IN THE WELD
METAL THIS WAS IN THE S2-S1
DIRECTION.

SCALE 1/4" = 1.0"



MNS UNIT 2
RPV HEAD



WELD I.D. 2RPV-W08
ITEM # B01.040001

LIMITATIONS DUE TO LUGS

WELD METAL
35° S₁-S₂
A-B-D $\frac{2.0 \times 1.375}{2} = 1.375$

COVERAGE 1.459 IN.

45° S₁-S₂


A-B-C $\frac{1.375 \times 1.375}{2} = .945$

COVERAGE .959 IN.

NOTE: THIS COVERAGE IS FOR 1 LUG ONLY.
FOR FINAL PERCENTAGE MULTIPLY BY 3.

SCALE 1/4" = 1.0"

MNS UNIT 2
RPV HEAD



WELD I.D. 2RPV-W/08
ITEM # BOL. 5/12/91

LIMITATIONS DUE TO LUGS

BASE METAL
35° S2-S1

(A-D-J-M) - (B-I-J-C + E-K-M)

$$(9' \times 2') - \left[\frac{1.375(2.0 + 3.8) + \frac{2.6 + 1.1}{2}}{2} \right] = 18'' - (1.975 + 1.43) = 8.595$$

COVERGE 8.6 sq. in.

45° S2-S1

(A-L-J-N) - (H-I-J-G + F-L-N-O)

$$(10.4 \times 1.8) - \left[\frac{1.375(1.5 + 2.7) + 1.8(5.0 + 1.2)}{2} \right] = 18.72 - (2.8875 + 5.58) = 10.2525$$

COVERGE 10.3 sq. in.

NOTE: THIS COVERGE IS FOR 1 LUG ONLY.
FOR FINAL PERCENTAGE MULTIPLY BY 3.

SCALE 1/4" = 1.0"

OUTLET NOZZLE TO SHELL WELDS & OUTLET NOZZLE INSIDE RADIUS

Total Area = 216.35 in ²	(Near Surface + Weld + T/2)
Near Surface Area = 15.07 in ²	(Vertical Cross-Section)
Weld Area = 18.84 in ²	(Vertical Cross-Section)
T/2 Area = 182.44 in ²	(Vertical Cross-Section)
Inside Radius Area = 8.76 in ²	(Vertical Cross-Section)
Total Area = 204.11 in ²	(Near Surface + Weld + T/2)
Near Surface Area = 15.10 in ²	(Horizontal Cross-Section)
Weld Area = 13.08 in ²	(Horizontal Cross-Section)
T/2 Area = 175.93 in ²	(Horizontal Cross-Section)
Inside Radius Area = 8.90 in ²	(Horizontal Cross-Section)

OUTLET NOZZLE INSIDE RADIUS

ITEM NO.: B03.100.005	ITEM NO.: B03.100.006
I.D. NO.: 2RPV-W15	I.D. NO.: 2RPV-W16
ITEM NO.: B03.100.007	ITEM NO.: B03.100.008
I.D. NO.: 2RPV-W17	I.D. NO.: 2RPV-W18

CIRC	70°	Gets 7.82 in ² Coverage Vertical Section
	70°	Gets 7.07 in ² Coverage Horizontal Section
		Covered Area = $\left(\frac{7.82}{8.76} + \frac{7.07}{8.90} \right) \times .50 = 84.4 \%$
AXIAL	70°	Gets 8.40 in ² Coverage Vertical Section
	70°	Gets 7.66 in ² Coverage Horizontal Section
		Covered Area = $\left(\frac{8.40}{8.76} + \frac{7.66}{8.90} \right) \times .50 = 91.0 \%$

70° INSIDE RADIUS COVERAGE

<u>AXIAL</u>	<u>CIRC</u>
91.0	84.4

Aggregate Coverage = 87.7 %

OUTLET NOZZLE TO SHELL WELDS

ITEM NO.: B03.090.005/A ITEM NO.: B03.090.006/A
I.D. NO.: 2RPV-W15 I.D. NO.: 2RPV-W16

ITEM NO.: B03.090.007/A ITEM NO.: B03.090.008/A
I.D. NO.: 2RPV-W17 I.D. NO.: 2RPV-W18

CIRC

70° Gets 6.17 in² Coverage Vertical Section

70° Gets 6.36 in² Coverage Horizontal Section

$$\text{Covered Area} = \left(\frac{6.17}{15.07} + \frac{6.36}{15.10} \right) \times .50 = 41.5$$

0° Gets 33.28 in² Coverage Vertical Section

0° Gets 16.47 in² Coverage Horizontal Section

$$\text{Covered Area} = \left(\frac{33.28}{201.28} + \frac{16.47}{189.01} \right) \times .50 = 12.6 \%$$

45° & 60° Get 3.75 in² Weld Coverage Vertical Section

45° & 60° Get 56.95 in² T/2 Coverage Vertical Section

45° & 60° Get 0.00 in² Weld Coverage Horizontal Section

45° & 60° Get 44.92 in² T/2 Coverage Horizontal Section

$$\begin{aligned} 45^\circ \ \& \ 60^\circ \ \text{Covered Area} &= \left[\left(\frac{56.95 + 3.75 + 3.75}{182.44 + 18.84 + 18.84} \right) \right. \\ &\quad \left. + \left(\frac{44.92 + 0.00 + 0.00}{175.93 + 13.08 + 13.08} \right) \right] \times .50 \\ &= 25.8 \% \end{aligned}$$

OUTLET NOZZLE TO SHELL WELDS CONTINUED

AXIAL 45° Gets 12.77 in² Coverage Vertical Section of Near Surface
 45° Gets 9.96 in² Coverage Horizontal Section of Near Surface
 Covered Area = $(\frac{12.77}{15.07} + \frac{9.96}{15.10}) \times .50 = 75.3 \%$

0° Gets 180.77 in² Coverage Vertical Section
 0° Gets 124.50 in² Coverage Horizontal Section
 Covered Area = $(\frac{180.77}{201.28} + \frac{124.50}{189.01}) \times .50 = 77.8 \%$


45° Gets 154.56 in² Coverage Vertical Section
 45° Gets 155.82 in² Coverage Horizontal Section
 Covered Area = $(\frac{154.56}{201.28} + \frac{155.82}{189.01}) \times .50 = 79.6 \%$

AXIAL			CIRC			
NS	0	45	70	60	45	0
75.3	77.8	79.6	41.5	25.8	25.8	12.6

Aggregate Coverage =

$$\begin{aligned}
 & [75.3 \times (15.07 + 15.10) + (77.8 + 79.6) \times (201.28 + 189.01) \\
 & + 41.5 \times (15.07 + 15.10) + (25.8 + 25.8) \\
 & \times (182.44 + 18.84 + 18.84 + 175.93 + 13.08 + 13.08) \\
 & + 12.6 \times (216.35 + 204.11)] / \\
 & [(15.07 + 15.10) \times 2 + (201.28 + 189.01) \times 2 \\
 & + (182.44 + 18.84 + 18.84 + 175.93 + 13.08 + 13.08) \times 2 \\
 & + (216.35 + 204.11)]
 \end{aligned}$$

Aggregate Coverage = 43.7 %



- NOTES:
1. THE DIMENSIONS IN THE NOZZLE BORE REFERENCE THE DTD OF THE BORE TAKEN AT THE VESSEL CENTERLINE AND THE DTD OF THE CENTER OF THE CONTACT HEAD IS OFFSET FROM THE DTD OF THE BORE SUCH THAT R = 80.44" IN ALL DIRECTIONS [2.00"]
 2. SPACINGS BETWEEN THE THUNDERBOLTS IS 3.18" IN ALL DIRECTIONS.
 3. MEASUREMENTS ARE IN INCHES AND DECIMAL DECIMALS.
 4. UT SCAN PATHS DESIGNATED BY..... LINES.

TABLE II

UT	Scan	UT	Scan	UT	Scan	UT	Scan	UT	Scan
1	1	1	1	1	1	1	1	1	1
2	2	2	2	2	2	2	2	2	2
3	3	3	3	3	3	3	3	3	3
4	4	4	4	4	4	4	4	4	4
5	5	5	5	5	5	5	5	5	5
6	6	6	6	6	6	6	6	6	6
7	7	7	7	7	7	7	7	7	7
8	8	8	8	8	8	8	8	8	8
9	9	9	9	9	9	9	9	9	9
10	10	10	10	10	10	10	10	10	10

TABLE III

YIELD NO.	SCAN	Q &
V-15	818	22
V-16	818	158
V-17	817	282
V-18	818	338

TABLE I

UT	Scan	UT	Scan	UT	Scan	UT	Scan	UT	Scan
1	1	1	1	1	1	1	1	1	1
2	2	2	2	2	2	2	2	2	2
3	3	3	3	3	3	3	3	3	3
4	4	4	4	4	4	4	4	4	4
5	5	5	5	5	5	5	5	5	5
6	6	6	6	6	6	6	6	6	6
7	7	7	7	7	7	7	7	7	7
8	8	8	8	8	8	8	8	8	8
9	9	9	9	9	9	9	9	9	9
10	10	10	10	10	10	10	10	10	10

McQUIRE UNIT 2
OUTLET NOZZLE
AS IS EXAMINATION
SCAN COVERAGE

1227599 D

REVISIONS

REV	DESCRIPTION	DATE	APP

DUKE POWER COMPANY					Exam Start: 1005	Form NDE-UT-2A
ULTRASONIC EXAMINATION DATA SHEET FOR PLANAR REFLECTORS					Exam Finish: 1034	Revision 4
Station: McGuire	Unit: 2	Component/Weld ID: 2PZR-10			Date: 11/18/97	
Weld Length (in.): 76.0"	Surface Condition: AS GROUND		Lo: 9.2.3	Surface Temperature: <u>71</u> ° <u>F</u>		
Examiner: James W. Setzer <i>James W Setzer</i>	Level: III	Scans: 45 <input checked="" type="checkbox"/> <u>49.5</u> dB 70 <input type="checkbox"/> _____ dB 45T <input checked="" type="checkbox"/> <u>49.5</u> dB 70T <input type="checkbox"/> _____ dB 60 <input type="checkbox"/> _____ dB 60T <input type="checkbox"/> _____ dB Other: <u>35°-52</u> dB			Pyrometer S/N: <u>MCNDE 27024</u>	
Examiner: Larry Mauldin <i>Larry Mauldin</i>	Level: III				Cal Due: <u>2/14/98</u>	
Procedure: NDE-620 Rev: 5	FC: N/A				Configuration: <u>IRGE NOZZLE to PZR LOWEF</u> <u>S1</u> Flow <u>S2</u> <u>LOWER HEAT</u> to <u>NOZZLE</u> Scan Surface: <u>OD</u> Applies to NDE-680 only Skew Angle: N/A	
Calibration Sheet No: 9702098, 9702099						

IND #	<input checked="" type="checkbox"/>	Max % Ref	Mp Max	W Max	L Max	L1	L2	W1	Mp1	W2	Mp2	Beam Dir.	Exam Surf.	Scan	Damps	
		DO NOT WRITE IN THIS SPACE				20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA			DO NOT WRITE IN THIS SPACE		
						50%dac	50%dac	50%dac	50%dac	50%dac	50%dac					
						100%dac	100%dac	100%dac	100%dac	100%dac	100%dac					
35°	NRI															
45°	NRI															

Remarks:					
Limitations: (see NDE-UT-4) <input type="checkbox"/> 90% or greater coverage obtained: yes <input type="checkbox"/> no <input checked="" type="checkbox"/>					Sheet _____ of _____
Reviewed By:	Level:	Date:	Authorized Inspector:	Date:	Item No:
<i>Paul Sheffield</i>	<u>II</u>	<u>11-20-97</u>	<i>[Signature]</i>	<u>11-25-97</u>	B03.110.001

SERIAL NO. 98-005
 Attachment 3
 Page 1 of 31

**DUKE POWER COMPANY
ISI LIMITATION REPORT**

FORM NDE-UT-4

Revision 1

Component/Weld ID: 2PZR-10

Item No: B03.110.001

Remarks:

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L 0+0° to L 0+48° INCHES FROM WO C/L +2.5° to BEYOND
 ANGLE: 0 45 60 Other 35° FROM DEG to DEG

HEATER BUNDLE CONFIGURATION

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L to L INCHES FROM WO C/L +2.0° to BEYOND
 ANGLE: 0 45 60 Other 35° FROM 0 DEG to 360 DEG

NOZZLE CONFIGURATION

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L to L INCHES FROM WO to
 ANGLE: 0 45 60 Other FROM DEG to DEG

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L to L INCHES FROM WO to
 ANGLE: 0 45 60 Other FROM DEG to DEG

Prepared By: JIM SETZER *Jim Setzer* Level: III Date: 11/24/97 Sketch(s) attached yes no Sheet of

Reviewed By: *Red Sheffield* Date: 11-24-97 Authorized Inspector: _____ Date: _____

Attachment 3
Page 2 of 31

DUKE POWER COMPANY				NDE-91-1			
Limited Examination Coverage Worksheet				Revision 0			
Examination Volume/Area Defined							
<input checked="" type="checkbox"/> Base Metal		<input checked="" type="checkbox"/> Weld		<input type="checkbox"/> Near Surface		<input type="checkbox"/> Bolting	
						<input type="checkbox"/> Inner Radius	
Area Calculation				Volume Calculation			
TOTAL AGGREGATE COVERAGE FOR WELD AND BASE METAL COMBINED							
Coverage Calculations							
Scan #	Angle	Beam Direction	Area Examined (sq.in.)	Length Examined (in.)	Volume Examined (cu.in.)	Volume Required (cu.in.)	Percent Coverage
			BASE METAL		1879.8	3042	61.79
			WELD		2862	3299.4	86.74
			AGGREGATE		4741.8	6341.4	74.78

		Item No: B03.110.001
Prepared By:	<i>Randy Moulden</i>	Level: <i>III</i> Date: <i>11-18-97</i>
Reviewed By:	<i>Rod Sheffield</i>	Level: <i>II</i> Date: <i>11-20-97</i>

DUKE POWER COMPANY Limited Examination Coverage Worksheet	NDE-91-1
	Revision 0

Examination Volume/Area Defined	
<input checked="" type="checkbox"/> Base Metal <input type="checkbox"/> Weld <input type="checkbox"/> Near Surface <input type="checkbox"/> Bolting <input type="checkbox"/> Inner Radius	
Area Calculation	Volume Calculation
2.6/ 2 X (1.3 + 1.7) X 2 = 7.8 SQ. IN.	TOTAL VOLUME = 7.8 X 78" = 608.4 CU. IN.

Coverage Calculations							
Scan #	Angle	Beam Direction	Area Examined (sq.in.)	Length Examined (in.)	Volume Examined (cu.in.)	Volume Required (cu.in.)	Percent Coverage
1	0°	N/A	4.4	78	343.2	608.4	56.41
2	45°	S2	6.7	78	522.6	608.4	85.90
3	35°	S2	5.4	78	421.2	608.4	69.23
4	35/45	CW	3.8	78	296.4	608.4	48.72
5	35/45	CCW	3.8	78	296.6	608.4	48.75
				TOTAL	1879.8	3042	61.79

Item No:	B03.110.001
----------	-------------

Prepared By: <i>Kary Mauldin</i>	Level: <i>III</i>	Date: <i>11-18-97</i>
Reviewed By: <i>Rob Hoffman</i>	Level: <i>II</i>	Date: <i>11-26-97</i>

DUKE POWER COMPANY Limited Examination Coverage Worksheet	NDE-91-1
	Revision 0

Examination Volume/Area Defined				
<input type="checkbox"/> Base Metal	<input checked="" type="checkbox"/> Weld	<input type="checkbox"/> Near Surface	<input type="checkbox"/> Bolting	<input type="checkbox"/> Inner Radius

Area Calculation	Volume Calculation
2.6 / 2 X (2.6 + 1.0) = 4.68 = 4.7 SQ. IN.	TOTAL VOLUME = 7.8 X 78" = 608.4 CU. IN. HEATER BUNDLE VOL. = 4.7 X 48 = 225.6 CU. IN.

Coverage Calculations							
Scan #	Angle	Beam Direction	Area Examined (sq.in.)	Length Examined (in.)	Volume Examined (cu.in.)	Volume Required (cu.in.)	Percent Coverage
1	0°	N/A	4.7	78	366.6	366.6	100.00
2	45°	S2	4.7	30	141	141	100.00
3	45°	S2	4.2	48	201.6	225.6	89.36
4	45°	S1	2.1	78	163.8	366.6	44.68
5	45°	CW	4.7	78	366.6	366.6	100.00
6	45°	CCW	4.7	78	366.6	366.6	100.00
7	35°	S1	4.6	30	138	141	97.87
8	35°	S1	4.6	48	220.8	225.6	97.87
9	35°	S2	2.1	78	163.8	366.6	44.68
10	35°	CW	4.7	78	366.6	366.6	100.00

			Item No: B03.110.001
Prepared By: <i>Randy Mauldin</i>	Level: <i>III</i>	Date: <i>11-18-97</i>	
Reviewed By: <i>Bob Sheff</i>	Level: <i>II</i>	Date: <i>11-20-97</i>	

DUKE POWER COMPANY						NDE-91-1			
Limited Examination Coverage Worksheet						Revision 0			
Examination Volume/Area Defined									
<input type="checkbox"/> Base Metal		<input checked="" type="checkbox"/> Weld		<input type="checkbox"/> Near Surface		<input type="checkbox"/> Bolting		<input type="checkbox"/> Inner Radius	
Area Calculation				Volume Calculation					
2.6 / 2 X (2.6 + 1.0) = 4.68 = 4.7 SQ. IN.				TOTAL VOLUME = 7.8 X 78" = 608.4 CU. IN. HEATER BUNDLE VOL. = 4.7 X 48 = 225.6 CU. IN.					
Coverage Calculations									
Scan #	Angle	Beam Direction	Area Examined (sq.in.)	Length Examined (in.)	Volume Examined (cu.in.)	Volume Required (cu.in.)	Percent Coverage		
11	35°	CCW	4.7	78	366.6	366.6	100.00		
				TOTAL	2862	3299.4	86.74		


		Item No: B03.110.001
Prepared By: <i>Larry Mauldin</i>	Level: <i>III</i>	Date: <i>11-18-97</i>
Reviewed By: <i>Rod Sheffield</i>	Level: <i>II</i>	Date: <i>11-26-97</i>


AREA CALCULATIONS
P27 SURGE NOZZLE

BASE MAT'L = $H-B-C-D = \frac{2.6}{2} (1.3' + 1.7') = 3.9 \text{ sq ft}$
 $E-F-G-H = \frac{2.6}{2} (1.3' + 1.7') = 3.9 \text{ sq ft}$
7.8 sq ft

WELD MAT'L = $C-D-E-F = \frac{2.6}{2} (2.6' + 10') = 4.68' = \underline{4.7 \text{ sq ft}}$

ITEM # BO3.110.001
BY: Randy Mauldin
DATE: 11-18-97





DATE: 11-18-97

BY: *[Signature]*
ITEM # BOS 110.001

4.4 sqm. COVERAGE

(Total Area) 7.8 sqm - 3.37 sqm = 4.4 sqm

0. BASE MAT'L A.B.C.D $\frac{12}{2} (3.1 + 2.55) = 3.39$

0. WELD MAT'L Total Coverage

PER. SURGE Nozzle

0°


P.C.R. SURGE NALZIE BASE MAT'L

45° S₁ TO S₂ LOSS A-B-C $\frac{1.8 \times 1.2}{2} = 1.1 \text{ sq. m.}$
 (TOTAL AREA) 7.8 sq. m. - 1.1 sq. m. = 6.7 sq. m. COVERAGE

35° S₁ TO S₂ LOSS (C-D-E) - (A-E-G) = $\frac{3.0 \times 1.7}{2} - \frac{7 \times 4}{2} = 2.4 \text{ sq. m.}$
 (TOTAL AREA) 7.8 sq. m. - 2.4 sq. m. = 5.4 sq. m. COVERAGE

35° AND/OR 45° CIRCUMFERENTIAL SCANS
 LOSS A-C-D-F $\frac{1.4}{2} (3.1 + 2.55) = 3.955 = 4.0 \text{ sq. m.}$
 (TOTAL AREA) 7.8 sq. m. - 4.0 sq. m. = 3.8 sq. m. COVERAGE

ITEM # BO3.110.001
 BY: Lou Mauldin
 DATE: 11-18-97



Surf. 2

Surf. 1

PER SURGE NOZZLE

HEATEL BUNDLE AREA


BASE MAT'L

45° S₁ TO S₂ -

THIS AREA WAS PREVIOUSLY FIGURED.
DOES NOT NEED TO BE RE FIGURED
FOR THIS AREA.

THIS AREA THAT WAS MISSED
WHN THESE SCANS, WAS SCANNED
FROM THE OTHER DIRECTION (S₂ TO S₁).

ITEM # B03 110.001
BY: Paul Moulder
DME: 11-18-97



PZR. SURGE NOZZLE

WELD MAT'L


45° S₁ TO S₂ TOTAL COVERAGE
35° S₁ TO S₂ (LOSS) A.R.C. $\frac{.7 \times .9}{2} = .14 \text{ sq. in.} = .1 \text{ sq. in.}$
TOTAL AREA 4.7 sq.in. - .1 sq.in. = 4.6 sq.in. COVERAGE

35° AND/OR 45° CIRCUMFERENTIAL SCANS
(LOSS) B.C.D. $\frac{.45 \times .1}{2} = .023 \sim .02 \text{ sq. in.}$
TOTAL AREA 4.7 sq.in. - .02 sq.in. = 4.68 = 4.7 sq.in.
4.7 sq.in. COVERAGE

ITEM # B03.110.001


BY: Lam Mauldin

DATE: 11-18-97



Sue. 2

Sue. 1



PZR. SURGE NOZZLE

HEATER BUNDLE AREA

WELD MATL

45° S₁ TO S₂ LOSS ABC = $\frac{1.6 \times 6}{2} = .48 \text{ sq. in.}$
 (TOTAL AREA) 4.68 sq. in. - .48 sq. in. = 4.2 sq. in. COVERAGE

35° S₁ TO S₂ LOSS D-E-F = $\frac{.5 \times .3}{2} = .075 = .08 \text{ sq. in.}$
 (TOTAL AREA) 4.68 sq. in. - .08 sq. in. = 4.6 sq. in. COVERAGE

ITEM # B 03.110.001
 BY: Lou Manelli
 DATE: 11-18-97

SUR. 2

SUR. 1


P22. SURGE NOZZLE

WELD MAT'L

45° S2 TO S1 A-C-D $\frac{2.65 \times 1.6}{2} = 2.12 = 2.1 \text{ SQ IN. COVERAGE}$
35° S2 TO S1 B-C-E $\frac{2.6 \times 1.65}{2} = 2.145 = 2.1 \text{ SQ IN. COVERAGE}$

ITEM # 303.110.001

BY: Paul Moulder
DATE: 11-18-97



SUR. 2

SUR. 1
45°

DUKE POWER COMPANY

ULTRASONIC EXAMINATION DATA SHEET FOR PLANAR REFLECTORS

Exam Start: 1154 Form NDE-UT-2A
 Exam Finish: 1230 Revision 4

Station: McGuire Unit: 2 Component/Weld ID: 2PZR-12 Date: 4/11/96

Weld Length (in.): 40.0 Surface Condition: AS GROUND Lo: B&W#1 Surface Temperature: 78 °

Examiner: Rodney G. Sheffield *Rodney G. Sheffield* II

Scans:

Pyrometer S/N: MCNDE 27029

Examiner: David Zimmerman *David Zimmerman* II

45 59 dB 70 _____ dB

Cal Due: 6/14/96

Procedure: NDE-620 Rev: 3
 NDE-640 1

FC: 96-02

45T 59 dB 70T _____ dB

Configuration: NOZZLE

Calibration Sheet No:
 9602073, 9602072, 9602074, 9602075

**

60 57 dB

NOZZLE Flow SHELL
 to _____
 Scan Surface: OD

60T 57 dB

Applies to NDE-680 only

Other: _____ * _____ dB

Skew Angle:

IND #	4	Max % Ref	Mp Max	W Max	L Max	L1	L2	W1	Mp1	W2	Mp2	Beam Dir.	Exam Surf.	Scan	Damps	
						20%dac HMA 50%dac 100%dac	20%dac HMA 50%dac 100%dac	20%dac HMA 50%dac 100%dac	20%dac HMA 50%dac 100%dac	20%dac HMA 50%dac 100%dac	20%dac HMA 50%dac 100%dac					
		DO NOT WRITE IN THIS SPACE														
NRI	0°															
NRI	45°															
NRI	60°															

Remarks: Scans Other * 0° 22, 60°L - 72.5 / FC ** 95-18, 95-19

Limitations: (see NDE-UT-4) 90% or greater coverage obtained: yes no Sheet _____ of _____

Reviewed By: *Wingard C. Lopez* Level: II Date: 5-7-96 Authorized Inspector: *W. J. Klein* Date: 5-9-96 Item No: B03.110.003

Attachment 3
Page 14 of 31

DUKE POWER COMPANY

ISI LIMITATION REPORT

FORM NDE- UT-4

Revision 1

Component/Weld ID: 2P22-12 Item No: B03.110.007003

remarks:

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
FROM _____ to _____ INCHES FROM WO 1.4 to BEYOND
ANGLE: 0 45 60 other _____ FROM 0 DEG to 360 DEG

DUE TO NOZZLE
CONFIGURATION

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
FROM _____ to _____ INCHES FROM WO _____ to _____
ANGLE: 0 45 60 other _____ FROM _____ DEG to _____ DEG

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
FROM _____ to _____ INCHES FROM WO _____ to _____
ANGLE: 0 45 60 other _____ FROM _____ DEG to _____ DEG

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
FROM _____ to _____ INCHES FROM WO _____ to _____
ANGLE: 0 45 60 other _____ FROM _____ DEG to _____ DEG

Sketch(s) attached
 yes no

Prepared By: Daniel R. [Signature] Level: II Date: 4-11-96

Sheet 7 of 20

Reviewed By: Walter P. Leeper Date: 5-7-96

Authorized Inspector: [Signature] Date: 5-9-96

Attachment 3
Page 15 of 31

DUKE POWER COMPANY Limited Examination Coverage Worksheet	NDE-91-1
	Revision 0

Examination Volume/Area Defined				
<input checked="" type="checkbox"/> Base Metal	<input checked="" type="checkbox"/> Weld	<input type="checkbox"/> Near Surface	<input type="checkbox"/> Bolting	<input type="checkbox"/> Inner Radius

Area Calculation	Volume Calculation
1.8 x 5.8 = 10.44 sq. in.	10.44 x 40 = 417.6 sq. cu. in.

Coverage Calculations							
Scan #	Angle	Beam Direction	Area Examined (sq.in.)	Length Examined (in.)	Volume Examined (cu.in.)	Volume Required (cu.in.)	Percent Coverage
1	45	2	10.06	40	402.6	417.6	96.41
2	60	2	10.41	40	416.4	417.6	99.71
3	45	1	3.22	40	128.8	417.6	30.84
4	60	1	1.40	40	56	417.6	13.41
5	45	CW	8.64	40	345.6	417.6	82.76
6	45	CCW	8.64	40	345.6	417.6	82.76
7	60	CW	8.64	40	345.6	417.6	82.76
8	60	CCW	8.64	40	345.6	417.6	82.76
Total =					2386.2	3340.8	71.43

Total Volume Examined - 3053.6 / Total Volume Required 4268.8 = 71.5% Total Coverage

		Item No:	B03.110.003
Prepared By: <i>David H. Zimmerman</i>	Level: <i>II</i>	Date:	<i>4-11-96</i>
Reviewed By: <i>William C. Leeper</i>	Level: <i>II</i>	Date:	<i>5-6-96</i>

DUKE POWER COMPANY Limited Examination Coverage Worksheet	NDE-91-1 Revision 0
---	------------------------

9 of 20

Examination Volume/Area Defined

Base Metal
 Weld
 Near Surface
 Bolting
 Inner Radius

Area Calculation	Volume Calculation
5.8 x 1.0 = 5.8 sq. in.	5.8 sq. in. x 40 in. = 232 cu. in.

Coverage Calculations

Scan #	Angle	Beam Direction	Area Examined (sq.in.)	Length Examined (in.)	Volume Examined (cu.in.)	Volume Required (cu.in.)	Percent Coverage	
1	60L	2	4.62	40	184.4	232	79.48	
2	60L	1	3.275	40	131	232	56.47	
3	60L	CW	4.4	40	176	232	75.86	
4	60L	CCW	4.4	40	176	232	75.86	
<i>Total =</i>						667.4	928	71.92

wet B03.110.003

Item No:	B03.041.003
----------	-------------

*R
6/17/96*

Prepared By: <i>David K. Zimmerman</i>	Level: <i>II</i>	Date: <i>4-11-96</i>
Reviewed By: <i>Wenjun L. Lee</i>	Level: <i>II</i>	Date: <i>5-6-96</i>

DUKE POWER COMPANY
ULTRASONIC EXAMINATION DATA SHEET FOR PLANAR REFLECTORS
 (continuation)

Form NDE-UT-2B

Revision 3


Station: McGuire				Unit: 2	Component/Weld ID: 2PZR-12							Date: 4/11/96			
IND #	Max % Ref	Mp Max	W Max	L Max	L1	L2	W1	Mp1	W2	Mp2	Beam Dir.	Exam Surf.	Scan	Damps	
	DO NOT WRITE IN THIS SPACE				20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA		DO NOT WRITE IN THIS SPACE			
	50%dac				50%dac	50%dac	50%dac	50%dac	50%dac	50%dac					
	100%dac				100%dac	100%dac	100%dac	100%dac	100%dac	100%dac					
NRI	60°L														


Examiner: Rodney G. Sheffield <i>Rodney G. Sheffield</i> Level: II	Examiner: David Zimmerman <i>David Zimmerman</i> Level: II
Remarks: Scans Other * 0° 22, 60°L - 72.5 FC ** 95-18, 95-19	
Reviewed By: <i>W. J. C. Leary</i> Level: II Date: 5-6-96	Authorized Inspector: <i>[Signature]</i> Date: 5-7-96
Item No: B03.110.003	

Attachment 3
Page 18 of 31

Item # 803.110.003

SCAN 4 60°






Item # 803.110.003
SCAN 1 60%


Item # B03.110.003

SCAN 7+8 60°




Item # 803, 110, 003

SCAN 5+6 45°





Item # B03.110.003

SCAN 3+4 60°L




Item # 803.110.003
SCAN 3 45°






Item # 803.110.003
SCAN 2 60°



Item # 803.110.003
SCAN 2 60°



Item # B03.110.003
Scan 1 45°

DUKE POWER COMPANY				Exam Start: 1211	Form NDE-UT-2A
ULTRASONIC EXAMINATION DATA SHEET FOR PLANAR REFLECTORS				Exam Finish: 1241	Revision 4
Station: McGuire	Unit: 2	Component/Weld ID: 2PZR-12R			Date: 4/11/96
Weld Length (in.): <i>N/A</i>	Surface Condition: GROUND	Lo: B&W #1	Surface Temperature: <u>78</u> °		
Examiner: David Zimmerman <i>David Zimmerman</i> - Level: II	Scans:		Pyrometer S/N: <u>MCNDE 27029</u>		
Examiner: Rodney G. Sheffield <i>Rodney G. Sheffield</i> - Level: II	45 <input type="checkbox"/> _____ dB 70 <input checked="" type="checkbox"/> <u>63</u> dB		Cal Due: <u>6/14/96</u>		
Procedure: NDE-680 Rev: 1	FC: 95-16	45T <input type="checkbox"/> _____ dB 70T <input type="checkbox"/> _____ dB	Configuration: <u>INNER RADIUS</u>		
Calibration Sheet No: 9602035, 9602036		60 <input checked="" type="checkbox"/> <u>57</u> dB	_____ Flow _____		
		60T <input type="checkbox"/> _____ dB	_____ to _____		
		Other: _____ dB	Scan Surface: <u>OD</u>		
			Applies to NDE-680 only		
			Skew Angle: <u>23°</u>		

IND #	<input checked="" type="checkbox"/>	Max % Ref	Mp Max	W Max	L Max	L1	L2	W1	Mp1	W2	Mp2	Beam Dir.	Exam Surf.	Scan	Damps
		DO NOT WRITE IN THIS SPACE				20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA		DO NOT WRITE IN THIS SPACE		
						50%dac	50%dac	50%dac	50%dac	50%dac	50%dac				
						100%dac	100%dac	100%dac	100%dac	100%dac	100%dac				
	60°	NRI													
	70°	NRI													

Remarks:				
Limitations: (see NDE-UT-4) <input type="checkbox"/> 90% or greater coverage obtained: yes <input type="checkbox"/> no <input checked="" type="checkbox"/>				Sheet _____ of _____
Reviewed By: <i>Winfred C. Keap</i>	Level: <u>II</u>	Date: <u>4-18-96</u>	Authorized Inspector: <i>R. G. Klein</i>	Date: <u>4-26-96</u>
			Item No: <u>B03.120.002</u>	

Attachment 3
 Page 28 of 31

**DUKE POWER COMPANY
ISI LIMITATION REPORT**

FORM NDE-UT-4

Revision 1

Component/Weld ID: 2PZR-12R	Item No: B03.120.002	Remarks:		
<input checked="" type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L _____ NA _____ to L _____ NA _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input checked="" type="checkbox"/> 60 <input type="checkbox"/> Other _____	SURFACE <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 INCHES FROM WO _____ NA _____ to _____ NA _____ FROM _____ 0 _____ DEG to _____ 360 _____ DEG	BEAM DIRECTION <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw		
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L _____ to L _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____	SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2 INCHES FROM WO _____ to _____ FROM _____ DEG to _____ DEG	BEAM DIRECTION <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw		
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L _____ to L _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____	SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2 INCHES FROM WO _____ to _____ FROM _____ DEG to _____ DEG	BEAM DIRECTION <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw		
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L _____ to L _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____	SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2 INCHES FROM WO _____ to _____ FROM _____ DEG to _____ DEG	BEAM DIRECTION <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw		
Prepared By: <i>David K. Zinner</i>	Level: <u>II</u>	Date: <u>4-12-96</u>	Sketch(s) attached <input type="checkbox"/> yes <input checked="" type="checkbox"/> no	Sheet _____ of _____
Reviewed By: <i>Winfred P. Long</i>	Date: <u>4-18-96</u>	Authorized Inspector: <i>[Signature]</i>	Date: <u>4-26-96</u>	

Attachment 3
 Page 29 of 31

DUKE POWER COMPANY Limited Examination Coverage Worksheet	NDE-91-1 Revision 0
---	----------------------------

5 of 5

Examination Volume/Area Defined

Base Metal
 Weld
 Near Surface
 Boltina
 Inner Radius

Area Calculation	Volume Calculation
3.5 in X 0.5 in = 1.7 sq in	3.5 in X 0.5 in X 40.0 in = 70 cu in

Coverage Calculations							
Scan #	Angle	Beam Direction	Area Examined (sq.in.)	Length Examined (in.)	Volume Examined (cu.in.)	Volume Required (cu.in.)	Percent Coverage
1*	60°,70°	SKEW	1.74 ^{1.1}	40.0	44	70	62.86
							0.00
							0.00
							0.00
							0.00
							0.00
							0.00
							0.00
							0.00
							0.00

* 60° & 70° USED AS ONE SCAN TO OBTAIN MAXIMUM COVERAGE - NOT TO BE FIGURED SEPERATELY.

Total Volume Examined 44 / Total Volume Required 70 = 62.86 %
Total Coverage

		Item No: B03.120.002
Prepared By: <i>David K. Zinner</i>	Level: <i>II</i>	Date: 4-12-96
Reviewed By: <i>Winfred P. Lopez</i>	Level: <i>II</i>	Date: 4-18-96

A
GJ
4/17/96

PZR. SPRAY NOZZLE

Area: $3.5 \times .5 = 1.75 \text{ sq. in.}$


Area No Scanned:

$$A = \frac{\pi}{2} (1.2 + 1.4)$$

$$A = .65 \text{ sq. in.}$$

Area Examined =

$$\underline{\underline{1.75 - .65 = 1.1 \text{ sq. in.}}}$$



DUKE POWER COMPANY

ULTRASONIC EXAMINATION DATA SHEET FOR PLANAR REFLECTORS

Exam Start: 1350

Form NDE-U.

Exam Finish: 1406

Revision 4

Station: McGuire

Unit: 2

Component/Weld ID: 2SGA-INLET-SE

Date: 12-05-94

Weld Length (in.): 97.34"

Surface Condition: As Ground

 PER B&W
Lo: REF. 1

Surface Temperature: 83 ° F

Pyrometer S/N: MCNDE27020

Cal Due: 951101

 Examiner: *Amy S. Buhl*

Level: II

Scans:

 45 62.5 dB 70 dB

 Examiner: *W. C. Leaper*

Level: II

 45T 61.5 dB 70T dB

Procedure: NDE 610

Rev: 2

FC: NONE

 60 dB

Calibration Sheet No:

9402033 ,9402034

 60T dB

Other: _____ dB

Configuration: CIRC. WELD

S2 Flow S1

SAFE END to Nozzle

Scan Surface: OD

Applies to NDE-680 only

Skew Angle: n/a

IND #	Max % Ref	Mp Max	W Max	L Max	L1	L2	Applies only to NDE-620, 640 and 680				Beam Dir	Exam surf.	Scan	Damps	
							W1	Mp1	W2	Mp2					
					20%dac HMA 50%dac	20%dac HMA 50%dac	20%dac HMA 50%dac	20%dac HMA 50%dac	20%dac HMA 50%dac	20%dac HMA 50%dac					
	DO NOT WRITE IN THIS SPACE														
45°L	No Recordable Indications (Axial or Circ.)														

Remarks: DUE TO SIGNAL NOISE RATIO CIRC. SCAN WAS PERFORMED AT REF. DB AND AXIAL SCAN WAS AT +6DB

 Limitations: (see NDE-UT-4)

 90% or greater coverage obtained: yes no

Sheet _____ of _____

Reviewed By:

Kenny Maulder

Level:

II

Date:

12-7-94

Authorized Inspector

RD Klein

Date

12-12-94

Item No:

B05.070.001

 SERIAL No. 98-005
 Attachment 4
 Page 1 of 12

DUKE POWER COMPANY

ISI LIMITATION REPORT

FORM NDE- UT-4

Revision 1

Component/Weld ID: 25GA-Inf-SG Item No: 1305.070.001

remarks:

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L 0" to L 97.34" INCHES FROM WO ^{CenterLine} to Beyond
 ANGLE: 0 45 60 other _____ FROM 0 DEG to 360 DEG

*NO SCAN DUE TO
Nozzle Configuration*

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM WO _____ to _____
 ANGLE: 0 45 60 other _____ FROM _____ DEG to _____ DEG

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM WO _____ to _____
 ANGLE: 0 45 60 other _____ FROM _____ DEG to _____ DEG

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM WO _____ to _____
 ANGLE: 0 45 60 other _____ FROM _____ DEG to _____ DEG

Sketch(s) attached
 yes no

Prepared By: W. C. Leep Level: II Date: 12.5.94

Sheet _____ of _____


Reviewed By: Harry Maulden Date: 12.7.94

Authorized Inspector: [Signature] Date: 12.12.94

Attachment 4
Page 2 of 12

Station McGuire Unit 2 Rev. _____ File No. _____ Sheet _____ Of _____
 Subject 2SGA-INT-5E

By W.C. Leaper Date 12-5-94
 Prob No. 305.070.001 Checked By Randy Mauldin Date 12-7-94



CROSS SECTIONAL AREA =

A 45° L-WAVE WAS USED TO INSPECT WELD.
 ONE DIRECTION WAS NOT SCANNED DUE TO TAPER
 ON GENERATOR SIDE.

AXIAL DIRECTION LOSS - 50%

CIRC. DIRECTION LOSS - 0%

TOTAL LOSS - 50%

50% ÷ 2 = 25%

100 - 25% = 75% COVERAGE

DUKE POWER COMPANY

ULTRASONIC EXAMINATION DATA SHEET FOR PLANAR REFLECTORS

Exam Start: 1411

Form NDE-U

Exam Finish: 1434

Revision 4

Station: McGuire

Unit: 2

Component/Weld ID: 2SGA-OUTLET-SE

Date: 12-05-94

Weld Length (in.): 97.34"

Surface Condition: As Ground

 PER B&W
Lo: REF. 1

Surface Temperature: 83 ° F

Pyrometer S/N: MCNDE27020

Cal Due: 951101

 Examiner: *Doug J. Bell* Level: II

Scans:

 45 62.5 dB 70 dB

 Examiner: *W.C. Leaper* Level: II

 45T 61.5 dB 70T dB

Procedure: NDE 610 Rev: 2

FC: NONE

 60 dB

Calibration Sheet No:

9402033 ,9402034

 60T dB

Other: _____ dB

Configuration: CIRC. WELD

S1 Flow S2

SAFE END to Nozzle

Scan Surface: OD

Applies to NDE-680 only

Skew Angle: n/a

IND #	Max % Ref	Mp Max	W Max	L Max	L1	L2	Applies only to NDE-620, 640 and 680				Beam Dir	Exam surf.	Scan	Damps
							W1	Mp1	W2	Mp2				
					20%dac HMA 50%dac	20%dac HMA 50%dac	20%dac HMA 50%dac	20%dac HMA 50%dac	20%dac HMA 50%dac	20%dac HMA 50%dac				
	DO NOT WRITE IN THIS SPACE													
45°L	No Recordable Indications (Axial or Circ.)													

Remarks: DUE TO SIGNAL TO NOISE RATIO CIRC. SCAN WAS PERFORMED AT REF. DB AND AXIAL SCAN WAS AT +6 DB

 Limitations: (see NDE-UT-4) 90% or greater coverage obtained: yes no

Sheet _____ of _____

Reviewed By:

Larry Mauldin

Level:

II

Date:

12-7-94

Authorized Inspector

R. Klein

Date:

12-12-94

Item No:

B05.070.002

 Attachment 4
Page 4 of 12

DUKE POWER COMPANY

ISI LIMITATION REPORT

FORM NDE- UT-4

Revision 1

Component/Weld ID: 2 SGA-outlet-SE Item No: 1305.070.002

remarks:

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L 0" to L 97.74" INCHES FROM WO ^{Center Line} to Beyond
 ANGLE: 0 45 60 other _____ FROM 0 DEG to 360 DEG

No scan Due To
Nozzle Configuration

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM WO _____ to _____
 ANGLE: 0 45 60 other _____ FROM _____ DEG to _____ DEG

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM WO _____ to _____
 ANGLE: 0 45 60 other _____ FROM _____ DEG to _____ DEG

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM WO _____ to _____
 ANGLE: 0 45 60 other _____ FROM _____ DEG to _____ DEG

Sketch(s) attached
 yes no

Prepared By: W.G. Leary Level: II Date: 11-5-94

Sheet _____ of _____

Reviewed By: Harry Maulden Date: 12-7-94

Authorized Inspector: [Signature] Date: 12-12-94

Attachment 4
Page 5 of 12

Station *McAuliffe* Unit *2* Rev. File No. Sheet *01*

Subject *25GA-outlet-SC*


By *L.J. Keenan* Date *12-5-94*

Checked By *Tommy Thawlin* Date *12-7-94*

Prob No. *B05.070.002*

SUR 1

SUR 2



CROSS SECTIONAL AREA =

A 45° T-WIRE WAS USED TO INSPECT WELD.
ONE DIRECTION WAS NOT SPANNED DUE TO THICK
ON OPPOSITE SIDE.

AXIAL DIRECTION LOSS - 50%

CIRC. DIRECTION LOSS - 0%

TOTAL LOSS - 50%

$$50\% \div 2 = 25\%$$

$$100 - 25\% - 75\% \text{ CORRECTION}$$

DUKE POWER COMPANY

ULTRASONIC EXAMINATION DATA SHEET FOR PLANAR REFLECTORS

Exam Start: 1350

Form NDE-U.

Exam Finish: 1406

Revision 4

Station: McGuire

Unit: 2

Component/Weld ID: 2NC2F-1-2

Date: 12-05-94

Weld Length (in.): 97.34"

Surface Condition: As Ground

 PER B&W
Lo: REF. 1

Surface Temperature: 83 ° F

Pyrometer S/N: MCNDE27020

Cal Due: 951101

 Examiner: *Jay J. Bibb* Level: II

 Examiner: *W.C. Leaper* Level: II

Procedure: NDE 610 Rev: 2

FC: NONE

Calibration Sheet No:

9402033 ,9402034

Scans:

 45 62.5 dB 70 dB

 45T 61.5 dB 70T dB

 60 dB

 60T dB

Other: _____ dB

Configuration: CIRC. WELD

S2 Flow S1

PIPE to SAFE END

Scan Surface: OD

Applies to NDE-680 only

Skew Angle: n/a

IND #	Max % Ref	Mp Max	W Max	L Max	L1	L2	Applies only to NDE-620, 640 and 680				Beam Dir	Exam surf.	Scan	Damps
							W1	Mp1	W2	Mp2				
					20%dac HMA 50%dac	20%dac HMA 50%dac	20%dac HMA 50%dac	20%dac HMA 50%dac	20%dac HMA 50%dac	20%dac HMA 50%dac				
	DO NOT WRITE IN THIS SPACE													
45°L	No Recordable Indications (Axial or Circ.)													

Remarks: DUE TO SIGNAL TO NOISE RATIO CIRC. SCAN WAS PERFORMED AT REF. DB AND AXIAL SCAN WAS AT +6DB

 Limitations: (see NDE-UT-4)

 90% or greater coverage obtained: yes

 no

Sheet _____ of _____

Reviewed By:

Larry Mauder II

Level:

Date:

12-7-94

Authorized Inspector

Atkins

Date:

12-12-94

Item No:

B05.130.002

 Attachment 4
Page 7 of 12

DUKE POWER COMPANY

ISI LIMITATION REPORT

FORM NDE- UT-4

Revision 1

Component/Weld ID: 2NC2F-1-2 Item No: B05.130022

remarks:

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L 0" to L 97.34' INCHES FROM Center Line WO to Beyond
 ANGLE: 0 45 60 other _____ FROM 0 DEG to 360 DEG

No SCAN DUE TO
Nozzle Configuration

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM WO _____ to _____
 ANGLE: 0 45 60 other _____ FROM _____ DEG to _____ DEG

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM WO _____ to _____
 ANGLE: 0 45 60 other _____ FROM _____ DEG to _____ DEG

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM WO _____ to _____
 ANGLE: 0 45 60 other _____ FROM _____ DEG to _____ DEG


Sketch(s) attached
 yes no

Prepared By: W.C. Leeen Level: II Date: 12-5-94 Sheet _____ of _____
 Reviewed By: Larry Mauldin Date: 12-7-94 Authorized Inspector: [Signature] Date: 12-12-94

Attachment 4
Page 8 of 12

Station McGuire Unit 2 Rev. _____ File No. _____ Sheet _____ Of _____
 Subject 2SGA- 2NC2F-1-2

By W.C. Leeper Date 12-5-94
 Prob No. BOS. 130. 002 Checked By Randy Mauldin Date 12-7-94



CROSS SECTIONAL AREA =

A 45° L-WAVE WAS USED TO INSPECT WELD.
 ONE DIRECTION WAS NOT SCANNED DUE TO TAPER
 ON GENERATOR SIDE.

AXIAL DIRECTION LOSS - 50%

CIRC. DIRECTION LOSS - 0%

TOTAL LOSS - 50%

$50\% \div 2 = 25\%$

$100 - 25\% = 75\% \text{ COVERAGE}$

DUKE POWER COMPANY

ULTRASONIC EXAMINATION DATA SHEET FOR PLANAR REFLECTORS

Exam Start: 1411	Form NDE-U1-zA
Exam Finish: 1434	Revision 4

Station: McGuire	Unit: 2	Component/Weld ID: 2NC2F-1-3	Date: 12-05-94
------------------	---------	------------------------------	----------------

Weld Length (in.): 97.34"	Surface Condition: As Ground	PER B&W Lo: REF. 1	Surface Temperature: 83 ° F
---------------------------	------------------------------	-----------------------	-----------------------------

Examiner: <i>Lucy S. Bell</i> Level: <i>II</i>	Scans: 45 <input checked="" type="checkbox"/> 62.5 dB 70 <input type="checkbox"/> _____ dB	Pyrometer S/N: MCNDE27020
--	---	---------------------------

Examiner: <i>W. C. Leeper</i> Level: <i>II</i>	45T <input checked="" type="checkbox"/> 61.5 dB 70T <input type="checkbox"/> _____ dB	Cal Due: 951101
--	---	-----------------

Procedure: NDE 610 Rev: 2	FC: NONE	Configuration: <u>CIRC. WELD</u> <u>S1</u> Flow <u>S2</u> <u>PIPE</u> to <u>SAFE END</u>
---------------------------	----------	--

Calibration Sheet No: 9402033 ,9402034	60 <input type="checkbox"/> _____ dB	Scan Surface: OD
	60T <input type="checkbox"/> _____ dB	Applies to NDE-680 only
	Other: _____ dB	Skew Angle: n/a

IND #	Max % Ref	Mp Max	W Max	L Max	L1	L2	Applies only to NDE-620, 640 and 680				Beam Dir	Exam surf.	Scan	Damps
							W1	Mp1	W2	Mp2				
					20%dac	20%dac	20%dac	20%dac	20%dac	20%dac				
					HMA	HMA	HMA	HMA	HMA	HMA				
					50%dac	50%dac	50%dac	50%dac	50%dac	50%dac				
45°L					No Recordable Indications (Axial or Circ.)									

Remarks: DUE TO SIGNAL TO NOISE RATIO CIRC. SCAN WAS PERFORMED AT REF. DB AND AXIAL SCAN WAS AT +6 DB

Limitations: (see NDE-UT-4) 90% or greater coverage obtained: yes no Sheet _____ of _____

Reviewed By: <i>Larry Mauldin</i>	Level: <i>II</i>	Date: <i>12-7-94</i>	Authorized Inspector: <i>[Signature]</i>	Date: <i>12-12-94</i>	Item No: B05.130.003
-----------------------------------	------------------	----------------------	--	-----------------------	----------------------

Attachment 4
Page 10 of 12

DUKE POWER COMPANY

ISI LIMITATION REPORT

FORM NDE- UT-4

Revision 1

Component/Weld ID: 21C2F-13 Item No: B05.130.003

remarks:

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L 0 to L 97.34 INCHES FROM WO centerline AND Beyond
 ANGLE: 0 45 60 other _____ FROM 0 DEG to 360 DEG

No scan Due To
Nozzle Configuration

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM WO _____ to _____
 ANGLE: 0 45 60 other _____ FROM _____ DEG to _____ DEG

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM WO _____ to _____
 ANGLE: 0 45 60 other _____ FROM _____ DEG to _____ DEG

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM WO _____ to _____
 ANGLE: 0 45 60 other _____ FROM _____ DEG to _____ DEG

Sketch(s) attached
 yes no

Prepared By: W.C. Leeper Level: II Date: 12-5-74

Sheet _____ of _____

Reviewed By: Larry Maulder Date: 12-7-94

Authorized Inspector: [Signature] Date: 12-12-94


Attachment 4
 Page 11 of 12

Station McGuire Unit 2 Rev. _____ File No. _____ Sheet _____ Of _____

Subject 2SGA- 2NP2F-1-3

By W.C. Lopez Date 12-5-94

Prob No. 805.130.003, Checked By Randy Thadden Date 12-7-94



CROSS SECTIONAL AREA =

A 45° L-WAVE WAS USED TO INSPECT WELD.
 ONE DIRECTION WAS NOT SCANNED DUE TO TAPER
 ON GENERATOR SIDE.

AXIAL DIRECTION LOSS - 50%

CIRC. DIRECTION LOSS - 0%

TOTAL LOSS - 50%

$50\% \div 2 = 25\%$

$100 - 25\% = 75\% \text{ COVERAGE}$

DUKE POWER COMPANY					Exam Start: 1302	Form NDE-UT-2A
					ULTRASONIC EXAMINATION DATA SHEET FOR PLANAR REFLECTORS	
Station: McGuire	Unit: 2	Component/Weld ID: 2NC16-WN8A				Date: 4/9/96
Weld Length (in.): 54"	Surface Condition: AS GROUND		Lo: 9.1.1.6	Surface Temperature: <u>70</u> °		
Examiner: Guy G. Bibb <i>Guy G. Bibb</i>	Level: III	Scans:		Pyrometer S/N: <u>MCNDE 27029</u>		
Examiner: James H. Resor <i>James H. Resor</i>	Level: I	45 <input type="checkbox"/> _____ dB	70 <input type="checkbox"/> _____ dB	Cal Due: <u>6/14/96</u>		
Procedure: NDE-610	Rev: 2	45T <input type="checkbox"/> _____ dB	70T <input type="checkbox"/> _____ dB	Configuration: <u>Pipe (P1) to Nozzle (PC. B)</u>		
Calibration Sheet No: 9602033	FC:	60 <input type="checkbox"/> _____ dB		<u>S1</u> Flow <u>S2</u>		
		60T <input type="checkbox"/> _____ dB		<u>COOL LOOP</u> to <u>NOZZLE</u>		
			Other: <u>45L 52*</u> dB	Scan Surface: OD		
				Applies to NDE-680 only		
				Skew Angle:		

IND #	<input checked="" type="checkbox"/>	Max % Ref	Mp Max	W Max	L Max	L1	L2	W1	Mp1	W2	Mp2	Beam Dir.	Exam Surf.	Scan	Damps	
		DO NOT WRITE IN THIS SPACE				20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA			DO NOT WRITE IN THIS SPACE		
						50%dac	50%dac	50%dac	50%dac	50%dac	50%dac					
						100%dac	100%dac	100%dac	100%dac	100%dac	100%dac					
		NRI														
		NRI														

Remarks: DID NOT SCAN WITH + 14db DUE TO SIGNAL TO NOISE RATIO					
Limitations: (see NDE-UT-4) <input checked="" type="checkbox"/> 90% or greater coverage obtained: yes <input type="checkbox"/> no <input checked="" type="checkbox"/>					Sheet _____ of _____
Reviewed By: <i>Wingard C. Lane</i>	Level: <u>TL</u>	Date: <u>4-15-96</u>	Authorized Inspector: <i>Phyllis</i>	Date: <u>4-26-96</u>	Item No: B09.031.001

SERIAL NO. 98-005
 Attachment 5
 Page 1 of 17

**DUKE POWER COMPANY
ISI LIMITATION REPORT**

FORM NDE-UT-4

Revision 1

Component/Weld ID: 2NC16-WN8A

Item No: B09.031.001

Remarks:

<input type="checkbox"/> NO SCAN	SURFACE	BEAM DIRECTION
<input checked="" type="checkbox"/> LIMITED SCAN	<input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2	<input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw
FROM L _____ to L _____	INCHES FROM WO	_____ 0.0 _____ to _____ 2.0 _____
ANGLE: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____		FROM _____ 0 _____ DEG to _____ 360 _____ DEG

DUE TO BRANCH CONNECTION WELD

<input checked="" type="checkbox"/> NO SCAN	SURFACE	BEAM DIRECTION
<input type="checkbox"/> LIMITED SCAN	<input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2	<input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input checked="" type="checkbox"/> ccw
FROM L _____ to L _____	INCHES FROM WO	_____ _____ to _____ _____
ANGLE: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____		FROM _____ 0 _____ DEG to _____ 360 _____ DEG

WELD JOINT CONFIGURATION

<input type="checkbox"/> NO SCAN	SURFACE	BEAM DIRECTION
<input type="checkbox"/> LIMITED SCAN	<input type="checkbox"/> 1 <input type="checkbox"/> 2	<input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw
FROM L _____ to L _____	INCHES FROM WO	_____ _____ to _____ _____
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____		FROM _____ _____ DEG to _____ _____ DEG

<input type="checkbox"/> NO SCAN	SURFACE	BEAM DIRECTION
<input type="checkbox"/> LIMITED SCAN	<input type="checkbox"/> 1 <input type="checkbox"/> 2	<input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw
FROM L _____ to L _____	INCHES FROM WO	_____ _____ to _____ _____
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____		FROM _____ _____ DEG to _____ _____ DEG

Prepared By: Larry S. Bell Level: III Date: 4/9/96 Sketch(s) attached yes no Sheet _____ of _____

Reviewed By: Whitaker C. Leason Date: 4-15-96 Authorized Inspector: [Signature] Date: 4-26-96

Attachment 5
Page 2 of 17

DUKE POWER COMPANY Limited Examination Coverage Worksheet	NDE-91-1 Revision 0
---	----------------------------

Examination Volume/Area Defined				
<input checked="" type="checkbox"/> Base Metal	<input checked="" type="checkbox"/> Weld	<input type="checkbox"/> Near Surface	<input type="checkbox"/> Boltina	<input type="checkbox"/> Inner Radius

Area Calculation	Volume Calculation
	DRWG #1 - .77" x 2.2" x 27" = 45.7 DRWG #2 - .77" x 2.2" x 27" = 45.7 TOTAL WELD LENGTH = 54"

Coverage Calculations							
Scan #	Angle	Beam Direction	Area Examined (sq.in.)	Length Examined (in.)	Volume Examined (cu.in.)	Volume Required (cu.in.)	Percent Coverage

DRWG #1	45°	1 TO 2	1.69	27	45.7	45.7	100.00
DRWG #1	45°	2 TO 1	0	27	0	45.7	0.00
DRWG #1	45°	CW	1.69	27	45.7	45.7	100.00
DRWG #1	45°	CCW	1.69	27	45.7	45.7	100.00
DRWG #2	45°	1 TO 2	1.61	27	43.47	45.7	95.12
DRWG #2	45°	2 TO 1	0	27	0	45.7	0.00
DRWG #2	45°	CW	0	27	0	45.7	0.00
DRWG 2	45°	CCW	0	27	0	45.7	0.00

$180.57 \div 365.6$


Aggregate % : 49.4%

Item No: B09.031.001	
Prepared By: <i>Sue A. Bell</i>	Level: <i>III</i> Date: 4/9/96
Reviewed By: <i>Walter C. Leeper</i>	Level: <i>II</i> Date: 4-15-96

10" $\frac{7}{8}$ NOZZLE DRAWING #2

AREA .77' x .22' = 1.694 = 1.69 sq. in.

45° CIRC.	CW	Loss = 100%	1.69 sq. in.
45° CIRC.	CCW	Loss = 100%	1.69 sq. in.



AREA SCANNED
 AREA NOT SCANNED


309.031.001
 Larry Mauldin III

10" $\frac{7}{8}$ NOZZLE DRAWING #2

AREA $.77 \times 2.2 = 1.694 = 1.69 \text{ sq. in.}$

45° AXIAL 1 TO 2 LOSS = $\frac{4 \times 4}{2} = .08 \text{ sq. in.}$

45° AXIAL 2 TO 1 LOSS = TOTAL LOSS 1.69 sq. in.



AREA SCANNED

AREA NOT SCANNED

309.031.001
Laurie Mauldin III


Attachment 5
Page 5 of 12

10" NOZZLE DRAWING #1

AREA .77 x 2.2 = 1.694 = 1.69 sq. in.

45° CIRC. CW LOSS = 0%

45° CIRC. CCW LOSS = 0%



AREA SCANNED

AREA NOT SCANNED

309.031.001
Larry Mauldin III


10 1/8" NOZZLE

DRAWING #1

AREA $.77 \times 2.2 = 1.694 = 1.69 \text{ sq. in.}$

45° AXIAL 1 TO 2 LOSS = 0%

45° AXIAL 2 TO 1 LOSS = 1.69 sq. in. 100%



AREA SCANNED
AREA NOT SCANNED

309.031.001

Law, Thauler III

DUKE POWER COMPANY

ULTRASONIC EXAMINATION DATA SHEET FOR PLANAR REFLECTORS

Exam Start: 1341

Form NDE-U A

Exam Finish: 1353

Revision 4

Station: McGuire

Unit: 2

Component/Weld ID: 2NC22-WN 4

Date: 11-29-94

Weld Length (in.): 63"

Surface Condition: As Ground

 NDE 90
Lo.9.1.1.6

Surface Temperature: 75 ° F

Pyrometer S/N: MCNDE27023

 Examiner: *Harry Maulder*

Level: II

Scans:

 45 64 dB 70 dB

Cal Due: 951101

 Examiner: *Winfred C. Logan*

Level: II

 45T 64 dB 70T dB

Configuration: Branch Connection

S1 Flow S2

Procedure: NDE 610 Rev: 2

FC:

Coolant Loop to Nozzle

Calibration Sheet No:

NONE

Scan Surface: OD

9402024

 60 dB

Applies to NDE-680 only

 60T dB

Other: _____ dB

Skew Angle: n/a

IND #	Max % Ref	Mp Max	W Max	L Max	L1	L2	Applies only to NDE-620, 640 and 680				Beam Dir	Exam surf.	Scan	Damps
							W1	Mp1	W2	Mp2				
					20%dac HMA 50%dac	20%dac HMA 50%dac	20%dac HMA 50%dac	20%dac HMA 50%dac	20%dac HMA 50%dac	20%dac HMA 50%dac				
	DO NOT WRITE IN THIS SPACE													
45°L	No Recordable Indications (Axial or Circ.)													

Remarks:

 Limitations: (see NDE-UT-4)

 90% or greater coverage obtained: yes

 no

Sheet _____ of _____

Reviewed By:

Level:

Date:

Authorized Inspector

Date

Item No:

Maureen T. Weaver

II

12-7-94

[Signature]

12-12-94

B09.031.002

DUKE POWER COMPANY

ISI LIMITATION REPORT

FORM NDE- UT-4

Revision 1

Component/Weld ID: 2NC 22-WN4 Item No: B09.031.002

remarks:

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
FROM L _____ to L _____ INCHES FROM WO 0.0" to 2.0"
ANGLE: 0 45L 60 other _____ FROM 0 DEG to 360 DEG

Due to Branch Connection

weld

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
FROM L _____ to L _____ INCHES FROM WO _____ to _____
ANGLE: 0 45L 60 other _____ FROM 0 DEG to 360 DEG

Not Required by ISI Plan

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
FROM L _____ to L _____ INCHES FROM WO _____ to _____
ANGLE: 0 45 60 other _____ FROM _____ DEG to _____ DEG

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
FROM L _____ to L _____ INCHES FROM WO _____ to _____
ANGLE: 0 45 60 other _____ FROM _____ DEG to _____ DEG

Sketch(s) attached

 yes noPrepared By: Larry Mauldin Level: II Date: 11-29-94

Sheet _____ of _____

Reviewed By: Kevin T. Weaver Date: 12-7-94Authorized Inspector: [Signature] Date: 12-12-94Attachment 5
Page 9 of 17

Limited Exam Data Sheet

Station McGUIRE Unit 2 I.D. # 2NC22-WN4
 By P. Mauldin Date 11-29-94 Item # 809.031.002
 Checked By Marvin T. Wanner Date 12-7-94 Page Of

**DETERMINING THE CUMULATIVE TOTAL OF WELD VOLUME INSPECTED
(in percentage)**

Total Cross Sectional Area 2.112 x (Number of Scans) 2 = 4.224 (% Factor)

Vessels:

Area Loss : Zone #1 _____
 Zone #2 _____
 Zone #3 _____

Total Zone Loss _____ / (% Factor) N/A x 100 = _____ % of Loss
 Lump Sum Loss From Other Limitations + _____ %
 Total Loss _____ %
 100% - (Total Loss) _____ = _____ % of Coverage
 (Additional _____ % of Partial Coverage)
 Qualifies for Request for Relief Yes No

Piping:

Axial Scan 45° L WAVE (Loss) _____ / _____ (% Factor) x 100 = _____ % of Loss
 Circumferential Scan Over Root Area Yes No _____ % of Loss
 Axial Loss _____ + Circ. Loss _____ = _____ / 2 = _____ % Loss
 Additional Losses (Due to hangers, restraints, etc.) + _____ % Loss
 Explain: _____ Total % Loss
SEE ATTACHMENT FOR PERCENTAGES

100% - (Total Loss) 50.19 = 49.81 % of Coverage
 Qualifies for Request for Relief Yes No

Disposition: _____

By: _____ Date: _____

Station 11C GUIRE Unit 2 Rev. _____ File No. _____ Sheet 1
 Subject LIMITED EXAM DATA
10" 5/8 Nozzle By R. Mauldin Date 11-29-94
 Prob No. B09.031.002 Checked By _____ Date _____

DRAWING #1

CROSS SECTIONAL AREA: $.88" \times 2.4" = 2.112 \text{ sq. in.}$

$$\begin{array}{r} \times 2 \text{ SCANS} \\ \hline 4.224 \text{ sq. in.} \end{array}$$

AREA OF LOSS:

$$\text{AXIAL: } 2.112 \div 4.224 \times 100 = 50\%$$

$$\text{CIRC: } \text{No Loss}$$

DRAWING #2

CROSS SECTIONAL AREA: $.88" \times 2.4" = 2.112 \text{ sq. in.}$

$$\begin{array}{r} \times 2 \text{ SCANS} \\ \hline 4.224 \text{ sq. in.} \end{array}$$

AREA OF LOSS:

$$\text{AXIAL: } \frac{25 \times .25}{2} + 2.112 = 2.14325$$

$$2.14325 \div 4.224 \times 100 = 50.73982$$

$$\text{CIRC: } 100\%$$

DRAWING #1

AXIAL	CIRC			
50	+ 0	= 2	=	25

DRAWING #2

50.74	+ 100	= 2	=	75.37
-------	-------	-----	---	-------

$$100.37$$

$$\text{100.37} \div 2 = 50.185 = 50.19 \text{ LOSS}$$

WITH NO LIMITATIONS

$$100 - 50.19 = 49.81\% \text{ COVERAGE}$$

∴ A 45° L-WAVE WAS USED TO SCAN WELD FROM 1 DIRECTION ONLY.
 NO SCAN WAS PERFORMED FROM SUR 2 (NOZZLE WELD) DUE TO
 NOZZLE WELD CONFIGURATION.

OTHER LIMITATIONS: No


49.81% COVERAGE

10 ^{1/8}" NOZZLE

DRAWING #1

ZNC 22-WN 4


B09.031.002.



10" $\frac{7}{8}$ NOZZLE
DRAWING #2

2 NC 22-WN4

B09.031.002



DUKE POWER COMPANY

Exam Start: 1410

Form NDE-UT-2A

ULTRASONIC EXAMINATION DATA SHEET FOR PLANAR REFLECTORS

Exam Finish: 1430

Revision 4

Station: MCGUIRE

Unit: II

Component/Weld ID: ZNC22 - WN8

Date: 12/5/94

Weld Length (in.): 20.8"

Surface Condition: Flush

Lo: 9.1.1(8)

Surface Temperature: 83 ° F

Pyrometer S/N: 27023

Cal Due: 951101

Examiner: ME Hansen

Level: II

Scans:

45L 69 dB 70 _____ dB

Examiner:

Level:

45T 77 dB 70T _____ dB

Procedure: NDE G10 Rev: 2

FC:

60 _____ dB

Calibration Sheet No:
9402035
9402036

NONE

60T _____ dB

Other: _____ dB

Configuration: CIRC.

2 Flow 1

Nozzle to PIPE

Scan Surface: OD

Applies to NDE-680 only

Skew Angle:

IND #	<input checked="checked" type="checkbox"/>	Max % Ref	Mp Max	W Max	L Max	L1	L2	W1	Mp1	W2	Mp2	Beam Dir	Exam surf.	Scan	Damps
DO NOT WRITE IN THIS SPACE						20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA	DO NOT WRITE IN THIS SPACE			
45L						50%dac	50%dac	50%dac	50%dac	50%dac	50%dac				
						100% dac	100% dac	100% dac	100% dac	100% dac	100% dac				
						<u>NO</u>	<u>RECORDABLE INDICATIONS</u>								

Remarks:

Limitations: (see NDE-UT-4)

90% or greater coverage obtained: yes no

Sheet _____ of _____

Reviewed By:

Randy Naumbor

Level: II

Date: 12-7-94

Authorized Inspector

[Signature]

Date: 12-7-94

Item No:

B09,031.003

Attachment 5
Page 14 of 17

DUKE POWER COMPANY

ISI LIMITATION REPORT

FORM NDE- UT-4

Revision 1

Component/Weld ID: 2 NC 22-WNB Item No: B09.031.003

remarks:

no scans due to nozzle

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
FROM L 0 to L 20.80" INCHES FROM WO ^{Get} ~~FROM WO~~ From CLIN to Beyond
ANGLE: 0 45 60 other _____ FROM 0 DEG to 360 DEG

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
FROM L _____ to L _____ INCHES FROM WO _____ to _____
ANGLE: 0 45 60 other _____ FROM _____ DEG to _____ DEG

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
FROM L _____ to L _____ INCHES FROM WO _____ to _____
ANGLE: 0 45 60 other _____ FROM _____ DEG to _____ DEG

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
FROM L _____ to L _____ INCHES FROM WO _____ to _____
ANGLE: 0 45 60 other _____ FROM _____ DEG to _____ DEG

Sketch(s) attached

yes no

Prepared By: J. E. Hoyer

Level: II

Date: 12.5.94

Sheet _____ of _____

Reviewed By: Larry Mauldin

Date: 12.7.94

Authorized Inspector: [Signature]

Date: 12-12-94

Attachment 5
Page 15 of 17

Limited Exam Data Sheet


Station McGuire Nuclear Unit II I.D. # 2NE 22-WN8
By DE Houser Date 12-5-94 Item # B09.031.003
Checked By Randy Thauler Date 12-7-94 Page Of

DETERMINING THE CUMULATIVE TOTAL OF WELD VOLUME INSPECTED (in percentage)

Total Cross Sectional Area _____ x (Number of Scans) _____ = _____ (% Factor)

Vessels:

Area Loss : Zone #1 _____
 Zone #2 _____
 Zone #3 _____
Total Zone Loss _____ / (% Factor) _____ x 100 = _____ % of Loss
Lump Sum Loss From Other Limitations + _____ %
Total Loss _____ %
100% - (Total Loss) _____ = _____ % of Coverage
(Additional _____ % of Partial Coverage)
Qualifies for Request for Relief Yes No



Piping:

Axial Scan _____ (Loss) _____ / _____ (% Factor) x 100 = _____ % of Loss
Circumferential Scan Over Root Area Yes No _____ % of Loss
Axial Loss _____ + Circ. Loss _____ = _____ / 2 = _____ % Loss
Additional Losses (Due to hangers, restraints, etc.) + _____ % Loss
Explain: see attached drawing _____ Total % Loss
for limited information

100% - (Total Loss) 50% = 50% % of Coverage


Qualifies for Request for Relief Yes No

Disposition: _____

By: _____ Date: _____

2" SIS Nozzle
 Item#: B09.031.003
 QNC 22-WN8

MUS #2
 Bit + Leg



Required Coverage:
 100% (25% in 4 Directions) OR
 88.52" (.760 x 1.4 x 360° in 4 Directions)
 Actual AREA Covered = 25% + 12.5% + 12.5% = 50%
 OR 22.13" + 11.06" + 11.06" = 44.25 ÷ 88.52 = 49.98%
 See Below

45° AXIAL (1st direction) = .760 x 1.4 x 20.80 x 1dir = 22.1
 OR 25% coverage
 45° AXIAL (2nd direction) = NO SCAN due to NOZ
 0% coverage
 45° Circ (3rd direction) = .760 x (1.4 ÷ 2) x 20.80 x
 1 direction = 11.06". Transducer only
 covered up to 1/2 the weld width resulting
 in 50% coverage of the 25% Required.
 25% x 50% = 12.5%
 45° Circ (4th direction) = Same Situation as in
 the 45° Circ (3rd direction) Coverage
 equals 12.5% OR 11.06"
 CHECKED BY: *Larry Thacker* 12.27.24 BY: *SE Hawker II* 12.5.9

DUKE POWER COMPANY

ULTRASONIC EXAMINATION DATA SHEET FOR PLANAR REFLECTORS

Exam Start: 1519 Form NDE-UT-2A

Exam Finish: 1539 Revision 4

Station: M⁵ CURVE Unit: 2 Component/Weld ID: 25GA-SB-02 Date: 12-12-94

Weld Length (in.): 44.25" Surface Condition: A₃ (GROUND) TOP OF NOZZLE PER B&W LO: #1 REF. Surface Temperature: 78 ° E

Examiner: David K. Ziemer Level: II Scans: 45 _____ dB 70 _____ dB Pyrometer SN: MCNDF 27023

Examiner: _____ Level: _____ 45T _____ dB 70T _____ dB Cal Due: 951101

Procedure: NDE-680 Rev: 1 FC: NA 60 _____ dB Configuration: INNER RADIUS

Calibration Sheet No: 9402063 60T 53.5 dB (Interdiameter) NOZZLE to STUD BARREL Scan Surface: OD
Applies to NDE-680 only
Skew Angle: 25.06°

IND #	Max % Ref	Mp Max	W Max	L Max	L1	L2	W1	Mp1	W2	Mp2	Beam Dir	Exam surf.	Scan	Damps	
					20% dac	20% dac	20% dac	20% dac	20% dac	20% dac					
					HMA	HMA	HMA	HMA	HMA	HMA					
					50% dac	50% dac	50% dac	50% dac	50% dac	50% dac					
					100% dac	100% dac	100% dac	100% dac	100% dac	100% dac					
<u>60°</u>					<u>NO RECORDABLE INDICATIONS</u>										

Remarks:

Limitations: (see NDE-UT-4) 90% or greater coverage obtained: yes no Sheet _____ of _____

Reviewed By: [Signature] Level: II Date: 12/21/94 Authorized Inspector: [Signature] Date: 12/28/94 Item No: C02.022.002

SERIAL No. 98-005
Attachment
Page 1 of 5

DUKE POWER COMPANY

Exam Start: 1156 Form NDE-UT-2A

Exam Finish: 1228 Revision 4

ULTRASONIC EXAMINATION DATA SHEET FOR PLANAR REFLECTORS

Station: M=CLURE Unit: 2 Component/Weld ID: 2XA-SB-02 Date: 12-14-94

Weld Length (in.): 94.25 Surface Condition: As (TROUGH) TOP OF NOZZLE PER BEW LO: #1 REF. Surface Temperature: 78 ° F

Examiner: David K Zimmerman Level: II Scans: 45 _____ dB 70 _____ dB
Pyrometer S/N: MCNOE 27023
Cal Due: 951101

Examiner: _____ Level: _____ 45T _____ dB 70T 59.5 dB
Configuration: INNER RADIUS

Procedure: NDE-680 Rev: 1 FC: NO 60 _____ dB
S2 Flow S1
NOZZLE to STUD BARREL

Calibration Sheet No: 9402072 60T _____ dB
Scan Surface: OD
Applies to NDE-680 only
Skew Angle: 17.49 °

IND #	Max % Ref	Mp Max	W Max	L Max	L1	L2	W1	Mp1	W2	Mp2	Beam Dir	Exam surf.	Scan	Damps	
					20% dac HMA	20% dac HMA	20% dac HMA	20% dac HMA	20% dac HMA	20% dac HMA					
					50% dac	50% dac	50% dac	50% dac	50% dac	50% dac					
					100% dac	100% dac	100% dac	100% dac	100% dac	100% dac					
<u>70°</u>					<u>NO RECORDABLE INDICATIONS</u>										

Remarks: SCANNED WITH 70° TO SUPPLEMENT 60° COVERAGE

Limitations: (see NDE-UT-4) 90% or greater coverage obtained: yes no Sheet _____ of _____

Reviewed By: [Signature] Level: II Date: 12/21/94 Authorized Inspector: [Signature] Date: 12-28-94 Item No: CO2.022.002

Attachment 6
Page 2 of 5

DUKE POWER COMPANY

ISI LIMITATION REPORT

FORM NDE- UT-4

Revision 1

Component/Weld ID: 256A-5B-02 Item No: COZ.022.002

remarks:

NOZZLE CONFIGURATION
84.3% coverage
obtained

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM WO +2.7" to BEYOND
 ANGLE: 0 45 60 other 70 FROM 0 DEG to 360 DEG

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM WO _____ to _____
 ANGLE: 0 45 60 other FROM _____ DEG to _____ DEG

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM WO _____ to _____
 ANGLE: 0 45 60 other FROM _____ DEG to _____ DEG

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM WO _____ to _____
 ANGLE: 0 45 60 other FROM _____ DEG to _____ DEG

Sketch(s) attached
 yes no

Prepared By: David K. [Signature] Level: II Date: 12-14-94

Sheet _____ of _____

Reviewed By: [Signature] Date: 12/21/94

Authorized Inspector: [Signature] Date: 12-23-94

Attachment 6
Page 3 of 5

Limited Exam Data Sheet

Station M-CRUISE Unit 2 I.D. # 25GA-SB-02

By David K. Zimm Date 12-14-94 Item # 102,022,002

Checked By _____ Date 12/21/94 Page _____ Of _____

DETERMINING THE CUMULATIVE TOTAL OF WELD VOLUME INSPECTED (in percentage)

Total Cross Sectional Area _____ x (Number of Scans) _____ = _____ (% Factor)

Vessels:

Area Loss : Zone #1 N/A

Zone #2 N/A

Zone #3 N/A

Total Zone Loss N/A / (% Factor) N/A x 100 = N/A % of Loss

Lump Sum Loss From Other Limitations +15.7 %

SEE ATTACHED SKETCH Total Loss 15.7 %

100% - (Total Loss) 15.7 = 84.3 % of Coverage

(Additional _____ % of Partial Coverage)

Qualifies for Request for Relief Yes No

Piping:

Axial Scan _____ (Loss) _____ / _____ (% Factor) x 100 = _____ % of Loss

Circumferential Scan Over Root Area Yes No _____ % of Loss

Axial Loss _____ + Circ. Loss _____ = _____ / 2 = _____ % Loss

Additional Losses (Due to hangers, restraints, etc.) + _____ % Loss

Explain: _____ Total % Loss

100% - (Total Loss) _____ = _____ % of Coverage

Qualifies for Request for Relief Yes No

Disposition: _____

By: _____ Date: _____

I.D. NO. ZSCA-SB-02

McGUIRE UNIT 2

TOTAL AREA OF INNER RADIUS

$$\frac{\pi r^2}{4} = \frac{\pi (2)^2}{4} = 3.14 \text{ in}^2$$

$$2" \times 2" = \frac{4.00 \text{ in}^2}{7.14 \text{ in}^2}$$

AREA OF LOSS

$$\frac{1.6 \text{ in} \times 1.4 \text{ in}}{2} = 1.12 \text{ in}^2$$


$$\frac{1.12 \text{ in}^2}{7.14 \text{ in}^2} \times 100 = 15.7\%$$

AREA OF COVERAGE

$$100\% - 15.7\% = 84.3\%$$

FEEDWATER NOZZLE
SURFACE Z

STUD
BARREL
SURFACE 1



David K. Zimmerman II
12-12-94
CHECKED BY *[Signature]* 12/21/94

Attachment 6
Page 5 of 5