# VERMONT YANKEE NUCLEAR POWER CORPORATION



P.O. Box 157, Governor Hunt Road Vernon, Vermont 05354-0157 (802) 257-7711

> January 10, 2000 BVY-00-03

United States Nuclear Regulatory Commission ATTN: Document Control Desk Washington, D.C. 20555

Reference: (a) License No. DPR-28 (Docket No. 50-271)

In accordance with section 6.7.A.3 of the Vermont Yankee Technical Specifications, submitted herewith is the Monthly Statistical Report for the Vermont Yankee Nuclear Power Station for the month of December, 1999.

Sincerely,

VERMONT YANKEE NUCLEAR POWER CORPORATION

Michael A. Balduzzi

Plant Manager

cc: USNRC Region I Administrator
USNRC Resident Inspector - VYNPS
USNRC Project Manager - VYNPS
Vermont Department of Public Service

IE24

# VERMONT YANKEE NUCLEAR POWER STATION MONTHLY STATISTICAL REPORT 99-12 FOR THE MONTH OF DECEMBER 1999

#### OPERATING DATA REPORT

DOCKET NO.50-271

DATE 000110

COMPLETED BY G.A. WALLIN

TELEPHONE (802)258-5414

#### OPERATING STATUS

1.	Unit Name: <u>Vermont Yankee</u>								
2.	Reporting Period: <u>December</u>								
3.	Licensed Thermal Power (MWt): 1593								
4.	Nameplate Rating(Gross MWe): 540								
5.	Design Electrical Rating(Net MWe): 522	2							
6.	Maximum Dependable Capacity(Gross MWe): 535								
7.	Maximum Dependable Capacity(Net MWe):	<u>510</u>							
8.	If changes, occur in capacity ratings() last report, give reasons:	Items Number	3 through 7	since					
	Power level to which restricted, if any Reasons for restrictions, if any:	/(Net MWe): N/A	N/A						
12. 13. 14. 15. 16. 17. 18. 19. 20. 21. 22.	Hours in Reporting Period Number Of Hours Reactor was Critical Reactor Reserve Shutdown Hours Hours Generator On-Line Unit Reserve Shutdown Hours Gross Thermal Energy Generated (MWH) Gross Electrical Energy Generated (MWH) Net Electrical Energy Generated (MWH) Unit Service Factor Unit Availability Factor Unit Capacity Factor (Using MDC Net) Unit Capacity Factor (Using DER Net) Unit Forced Outage Rate Shutdowns scheduled over next 6 months Each:	This Month  744.00  733.72  0.00  701.95  0.00  1058643.15  363837.00  349531.00  94.30  94.30  92.10  90.00  4.69  (Type, Date,	4260371.00 4059107.00 90.60 90.90 88.80 0.43	$\begin{array}{r} 236664.00\\\hline 198174.46\\\hline 0.00\\\hline 194660.95\\\hline 0.00\\\hline 293561183.40\\\hline 98302568.00\\\hline 93500558.00\\\hline 81.20\\\hline 77.20\\\hline 75.60\\\hline 4.37\\\hline \end{array}$					
	If shut down at end of report period, end of the Units In Test Status (prior to commercial INITIAL CRITICALITY INITIAL ELECTRICITY COMMERCIAL OPERATION		): N/A	o: N/A					

VYDPF 0411.01 (Sample) DP 0411 Rev. 7 Page 1 of 1 RT No. 13.F01.19F

#### AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-271

UNIT

Vermont Yankee

DATE

TELEPHONE

000110

COMPLETED BY

G.A. WALLIN (802)258-5414

MONTH December

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1.	0	17.	531
2.	30	18.	530
3.	199	19.	530
4.	487	20.	531
5.	515	21.	231
6.	529	22.	386
7.	528	23.	519
8.	529	24.	531
9.	531	25.	529
10.	531	26.	529
11.	531	27.	530
12.	531	28.	530
13.	530	29.	530
14.	531	30.	531
15.	531	31.	531
16.	530		

#### **INSTRUCTIONS:**

On this format, list the average daily unit power level in MWE-Net for each day in the reporting month. Compute to the nearest whole megawatt.

VYDPF 0411.02 (Sample) DP 0411 Rev. 7 Page 1 of 1 RT No. 13.F01.18V

#### UNIT SHUTDOWNS AND POWER REDUCTIONS

#### REPORT MONTH DECEMBER

DOCKET NO 50-271

UNIT NAME Vermont Yankee

DATE 000110

COMPLETED BY G.A. Wallin

TELEPHONE (802)258-5414

No.	Date	1 Type	Duration (hours)	2 Reason	3 Method of Shutting Down Reactor	License Event Report#	4 System Code	5 Component Code	Cause and Corrective Action to Prevent Recurrence
99-11	991202	S	41.65	В	N/A	N/A	N/A	N/A	Turbine overspeed testing
99-12	991221	F	34.53	А	N/A	N/A	СВ	PUMPXX	"A" recirculation pump tripped due to the loss of a second motor generator lube oil pump. (See detail on summary page)

1 F: Forced

VYDPF 0411.03

DP 0411 Rev. 7

Page 1 of 1

S: Scheduled

2 Reason:

A-Equipment Failure (Explain)

B-Maintenance or Test

C-Refueling

D-Regulatory Restriction

E-Operator Training and License Examination

License Examina

F-Administrative

G-Operational Error (Explain)

H-(Explain) -

3 Method:

1 - Manual

2 - Manual Scram

3 - Automatic Scram

4 - Other (Explain)

4 Exhibit G- Instructions

for Preparation of Data

Entry Sheets for License

Event Report (LER) File

(NUREG 0161)

5 Exhibit I - Same Source

DOCKET NO. 50-271

DATE 000110

COMPLETED BY G.A. WALLIN

TELEPHONE (802)258-5414

# REPORT MONTH December

#### SUMMARY OF OPERATING EXPERIENCES

## Highlights

Vermont Yankee operated at 89.3% of rated thermal power for the month. Gross electrical generation was 363,837 MWHe or 89.6% design electrical capacity.

## Operating Summary

The following is a chronological description of plant operations including other pertinent items of interest for the month:

At the beginning of the reporting period the plant was operating at 0.17% of rated thermal power.

- 991201 At 1017 hours, the reactor was critical.
- 991202 At 1605 hours, the turbine-generator was phased to the grid.
- 991202 At 2329 hours, the turbine-generator was removed from the grid.
- 991203 At 0127 hours, the turbine-generator was phased to the grid and a return to full power was initiated. (See Unit Shutdowns and Power Reductions)
- 991221 At 0318 hours, the "A" recirculation pump tripped due to the loss of a second motor generator lube oil pump. Reduced "B" recirculation pump to 70% speed and power was reduced to 42%. (See Unit Shutdowns and Power Reductions)
- 991221 At 2213 hours, started the "A" recirculation pump following valve repair to the "A" motor generator lube oil pumps.
- 991221 At 2242 hours, secured the "B" recirculation pump for valve repair on the "B" motor generator lube oil pumps. (See Unit Shutdowns and Power Reductions)
- 991222 At 0517 hours, started the "B" recirculation pump following valve repair to the "B" motor generator lube oil pumps.
- 991222 At 0530 hours, began a return to full power.

At the end of the reporting period the plant was operating at 99.9% of rated thermal power.

VYDPF 0411.04 (Sample) DP 0411 Rev. 7 Page 1 of 1 RT No. 13.F01.18X