

Britt T. McKinney Vice President Plant Operations and Plant Manager

JAN 1 2 2000

WO 00-0002

U. S. Nuclear Regulatory Commission ATTN: Document Control Desk Mail Station P1-137 Washington, D. C. 20555

Subject: Docket No. 50-482: December, 1999, Monthly Operating Report

Gentlemen:

Attached to this letter is the December, 1999, Monthly Operating Report for Wolf Creek Generating Station. This submittal is being made in accordance with the requirements of Technical Specification 5.6.4. This submittal also follows the guidance of Generic Letter 97-02, "Revised Contents of the Monthly Operating Report." If you have questions regarding this report, please contact me at (316) 364-4112, or Mr. Michael J. Angus at (316) 364-4077.

Very truly yours,

Brict T. McKinney

BTM/rlr

Attachment

cc: J. N. Donohew (NRC), w/a

W. D. Johnson (NRC), w/a

E. W. Merschoff (NRC), w/a

Senior Resident Inspector (NRC), w/a

IEAY

Attachment to WO 00-0002 Page 1 of 2

OPERATING DATA REPORT Report Number: 178

DOCKET NO.:

50-482

UNIT NAME:

Wolf Creek Generating Station

DATE:

January 6, 2000

COMPLETED BY: K. A. Harris TELEPHONE:

316-364-4038

REPORT MONTH: December, 1999

1.	Design Electrical Rating (MWe - Net):	1170
2.	Maximum Dependable Capacity (MWe - Net):	1170

		This Month	Year to Date	Cumulative
3.	Number of Hours Reactor Critical:	744.0	7,890.1	105,745.2
4.	Number of Hours Generator On-Line:	744.0	7,847.4	104,722.4
5.	Unit Reserve Shutdown Hours:	0.0	0.0	339.8
6.	Net Electrical Energy Generated (MWH)	877,313	9,156,619	117,629,511

UNIT SHUTDOWN AND POWER REDUCTIONS

DOCKET NO. :

50-482

UNIT NAME:

Wolf Creek Generating Station

DATE:

January 6, 2000

COMPLETED BY: TELEPHONE:

K. A. Harris 316-364-4038

No		Type F: FORCED S: SCHEDULED	DURATION (Hours)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTIONS/COMMENTS
4	12/1/99	F	8.5	A	1	Power supply card replaced and equipment returned to service.
5	12/31/99	s	12	H	1	Support site Y2K contingencies.

The unit operated at approximately 100% power until 0219 on December 1, 1999, when the unit began power SUMMARY: reduction to 52% to replace a failed SA036D power supply card and then to replace a driver card in AB PT-507, steam dump pressure transmitter. The card was replaced, and the unit began power increase at 1040, December 1, 1999. The unit reached 100% power at 1318, December 1, 1999, and continued at or near 100% power, Mode 1. At 1213, December 31, 1999, the unit reduced power to 52% to support site Y2K contingencies.

1) REASON: A: EQUIPMENT FAILURE (EXPLAIN) E: OPERATOR TRAINING AND LICENSE EXAMINATION (2) METHOD: 1. MANUAL

2. MANUAL SCRAM

B: MAINTENANCE OR TEST

F: ADMINISTRATIVE

C: REFUELING

G: OPERATIONAL ERROR (EXPLAIN)

3. AUTOMATIC SCRAM

D: REGULATORY RESTRICTION

H: OTHER (EXPLAIN)

4. CONTINUATION

5. OTHER

Wolf Creek Generating Station Monthly Operating Report December, 1999 Page 2 of 2