



NRC-00-001

**Wisconsin Public Service Corporation**  
(a subsidiary of WPS Resources Corporation)  
Kewaunee Nuclear Power Plant  
North 490, Highway 42  
Kewaunee, WI 54216-9511  
920-388-2560

January 13, 2000

10 CFR 50.36

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D.C. 20555

Ladies/Gentlemen:

Docket 50-305  
Operating License DPR-43  
Kewaunee Nuclear Power Plant  
Monthly Operating Report

The narrative "Summary of Operating Experience" and completed forms covering plant and component availability for the Kewaunee Nuclear Power Plant for December 1999 are enclosed in accordance with Technical Specification 6.9.a.3.

Sincerely,

for

Mark L. Marchi  
Vice President-Nuclear

MLA

Enc.

cc - US NRC - Region III  
NRC Senior Resident Inspector  
INPO Records Center  
PSCW - Sharon Hennings

JE24

**KEWAUNEE NUCLEAR POWER PLANT - DOCKET 50-305  
SUMMARY OF OPERATING EXPERIENCE**

**December 1999**

On Saturday, December 18, 1999, at 0000, a backdown was initiated to perform SP54-086, Turbine Stop Valve Test. After successfully completing the test, the unit was returned to full power (97%, 534 MWe) at 0624.

The unit continues to operate at 97% NI power, steady state operation.

**Instrument and Control Group Activities for the Month:**

Supported plant engineering during service water flow testing of containment fan coils.

Repaired/adjusted waste gas compressor gas header control valve for proper gas header operation.

Supported motor operated valve testing on plant equipment.

**Maintenance Group Activities for the Month:**

**Electrical Maintenance**

Completed monthly and quarterly safeguards battery surveillance.

Supported I&C on their monthly SP 316 reactor protection surveillance.

Tested Bus 1 and 2 UV and UF and Bus 5 and 6 UV relays.

Performed maintenance on RHR 299A (MOV Testing).

Performed maintenance on SI 300B (MOV Testing).

Performed maintenance on breaker for C & D containment fan coil unit and TDAFW Room FCU.

Performed maintenance on 1B RHR pump motor and breaker.

Removed and installed 1B2 SW pump motor.

**Mechanical Maintenance**

Completed performance monitoring on numerous components including auxiliary feedwater pumps, containment fan coils, diesel generator heat exchangers, Zone SV exhaust fans and various safety related fan coil units. All were found to be operating acceptably.

Repaired "C" containment fan coil unit bypass check valve.

Inspected "1B2" service water pump shaft for cracking. Found pump shaft to be acceptable.

A V E R A G E   D A I L Y   U N I T   P O W E R   L E V E L

DOCKET NO- 50-305  
UNIT- KEWAUNEE  
COMPLETED BY- M. L. ANDERSON  
TELEPHONE- 920-388-8453

REPORT MONTH   DECEMBER, 1999

DAY                      AVERAGE DAILY  
                            POWER LEVEL  
                            (MWE-NET)

1	507
2	507
3	507
4	507
5	507
6	511
7	507
8	508
9	509
10	504
11	509
12	509
13	508
14	508
15	508
16	509
17	509
18	492
19	508
20	508
21	508
22	508
23	508
24	508
25	508
26	513
27	508
28	508
29	508
30	513
31	504

**DOCKET NO:** 50-305  
**UNIT NAME:** Kewaunee  
**DATE:** January 10, 2000  
**COMP BY:** Mary L. Anderson  
**TELEPHONE:** 920-388-8453

**UNIT SHUTDOWNS AND POWER REDUCTIONS**  
**REPORT MONTH - DECEMBER 1999**

NO.	DATE	TYPE	DURATION	REASON	METHOD	LER NO.	SYS	COMPONENT	COMMENTS
									No shutdowns or power reductions in December

**TYPE**

**F: FORCED**  
**S: SCHEDULED**

**REASON**

**A-Equipment Failure (explain)**  
**B-Maintenance or Test**  
**C-Refueling**  
**D-Regulatory Restriction**  
**E-Operator Training & License Examination**  
**F-Administrative**  
**G-Operational Error (explain)**  
**H-Other (explain)**

**METHOD**

**1-Manual**  
**2-Manual Scram**  
**3-Automatic Scram**  
**4-Continuations**  
**5-Load Reductions**  
**9-Other**

**SYSTEM & COMPONENT CODES**

From NUREG-0161

