

Mr. C. Randy Hutchinson  
 Vice President, Operations ANO  
 Entergy Operations, Inc.  
 1448 S. R. 333  
 Russellville, AR 72801

January 13, 2000

SUBJECT: ARKANSAS NUCLEAR ONE, UNIT NO. 1 - ISSUANCE OF AMENDMENT RE:  
 REVISION TO STEAM GENERATOR SURVEILLANCE REQUIREMENTS  
 (TAC NO. MA7370)

Dear Mr. Hutchinson:

The Commission has issued the enclosed Amendment No. 203 to Facility Operating License No. DPR-51 for the Arkansas Nuclear One, Unit No. 1. The amendment consists of changes to the Technical Specifications (TSs) in response to your application dated December 16, 1999 (1CAN129904).

The amendment revises TS 4.18.5.b to allow tube 110/60 to remain in service through the current operating fuel cycle (cycle 16) with two axial indications that have potential through-wall depths greater than the plugging limit.

A copy of our related Safety Evaluation is also enclosed. The Notice of Issuance will be included in the Commission's next biweekly *Federal Register* notice.

Sincerely,

/RA/

M. Christopher Nolan, Project Manager, Section 1  
 Project Directorate IV & Decommissioning  
 Division of Licensing Project Management  
 Office of Nuclear Reactor Regulation

Docket No. 50-313

Enclosures: 1. Amendment No. 203 to DPR-51  
 2. Safety Evaluation

cc w/encls: See next page

**DISTRIBUTION** SRichards (cover ltr only)  
 File Center OGC (15B18)  
 PUBLIC ACRS  
 PDIV-1 Reading G.Hill(2)  
 W.Beckner K.Brockman, RIV  
 L.Hurley, RIV J.Kilcrease, RIV  
 R.Scholl (e-mail SE only)

To receive a copy of this document, indicate "C" in the box								
OFFICE	PDIV-1/PM	<input checked="" type="checkbox"/>	PDIV-1/LA	<input checked="" type="checkbox"/>	EMCB/SC	OGC <sup>with comments</sup>	PDIV-1/SC	<input checked="" type="checkbox"/>
NAME	CNolan(2): <i>ml</i>		DJohnson <i>dly</i>		E.Sullivan <i>ES</i>	<i>RMW</i> R Weisman	R.Gramm <i>RG</i>	
DATE	12 / 30 / 99		01 / 03 / 00		1 / 3 / 00	Jan / 13 / 00	1 / 14 / 00	

DOCUMENT NAME: G:\PDIV-1\ANO1\AMDMA7370.wpd

OFFICIAL RECORD COPY

DF01



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

January 13, 2000

Mr. C. Randy Hutchinson  
Vice President, Operations ANO  
Entergy Operations, Inc.  
1448 S. R. 333  
Russellville, AR 72801

SUBJECT: ARKANSAS NUCLEAR ONE, UNIT NO. 1 - ISSUANCE OF AMENDMENT RE:  
REVISION TO STEAM GENERATOR SURVEILLANCE REQUIREMENTS  
(TAC NO. MA7370)

Dear Mr. Hutchinson:

The Commission has issued the enclosed Amendment No. 203 to Facility Operating License No. DPR-51 for the Arkansas Nuclear One, Unit No. 1. The amendment consists of changes to the Technical Specifications (TSs) in response to your application dated December 16, 1999 (1CAN129904).

The amendment revises TS 4.18.5.b to allow tube 110/60 to remain in service through the current operating fuel cycle (cycle 16) with two axial indications that have potential through-wall depths greater than the plugging limit.

A copy of our related Safety Evaluation is also enclosed. The Notice of Issuance will be included in the Commission's next biweekly *Federal Register* notice.

Sincerely,

A handwritten signature in black ink, appearing to read "M. Christopher Nolan".

M. Christopher Nolan, Project Manager, Section 1  
Project Directorate IV & Decommissioning  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-313

Enclosures: 1. Amendment No. 203 to DPR-51  
2. Safety Evaluation

cc w/encls: See next page

**Arkansas Nuclear One**

cc:

Executive Vice President  
& Chief Operating Officer  
Entergy Operations, Inc.  
P. O. Box 31995  
Jackson, MS 39286-1995

Vice President, Operations Support  
Entergy Operations, Inc.  
P. O. Box 31995  
Jackson, MS 39286-1995

Director, Division of Radiation  
Control and Emergency Management  
Arkansas Department of Health  
4815 West Markham Street, Slot 30  
Little Rock, AR 72205-3867

Wise, Carter, Child & Caraway  
P. O. Box 651  
Jackson, MS 39205

Winston & Strawn  
1400 L Street, N.W.  
Washington, DC 20005-3502

Manager, Rockville Nuclear Licensing  
Framatone Technologies  
1700 Rockville Pike, Suite 525  
Rockville, MD 20852

Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
P. O. Box 310  
London, AR 72847

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 400  
Arlington, TX 76011-8064

County Judge of Pope County  
Pope County Courthouse  
Russellville, AR 72801