



Carolina Power & Light Company

Robinson Nuclear Plant
3581 West Entrance Road
Hartsville SC 29550

Serial: RNP-RA/00-0001

JAN 20 2000

United States Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261/LICENSE NO. DPR-23

SUBMITTAL OF 90 DAY INSERVICE INSPECTION SUMMARY REPORT


Ladies and Gentlemen:

In accordance with the requirements of 10 CFR 50.55a, "Codes and Standards," Carolina Power & Light (CP&L) Company is providing, as an attachment to this letter, the Inservice Inspection (ISI) Summary Report for Class 1 and Class 2 pressure retaining components and their supports. This report has been prepared to meet the stipulation of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, Section XI, 1986 Edition, no addenda, Article IWA-6000. These inspections were conducted during Refueling Outage 19 at the H. B. Robinson Steam Electric Plant, Unit No. 2.

Within the ISI Summary Report, one of the NIS-2 forms was not signed by the Authorized Nuclear Inspector because of questions the inspector raised related to the need for a certified material test report for a helical-coil insert installed in a Steam Generator "C" secondary side inspection port. CP&L's assessment is that the helical-coil insert complies with the current code of record. CP&L is addressing this item through our corrective action program.

If you have any questions concerning this matter, please contact Mr. H. K. Chernoff.

Sincerely,



R.L. Warden

Manager - Regulatory Affairs

CTB/ctb

Attachment

c: Resident Inspector, HBRSEP
Mr. R. Subbaratnam, NRC, NRR
Mr. L. A. Reyes, NRC, Region II

A047 %