

February 2, 2000

Mr. Harold W. Keiser
Chief Nuclear Officer & President -
Nuclear Business Unit
Public Service Electric & Gas
Company
Post Office Box 236
Hancocks Bridge, NJ 08038

SUBJECT: COMPLETION OF LICENSING ACTION FOR GENERIC LETTER 99-02,
"LABORATORY TESTING OF NUCLEAR-GRADE ACTIVATED CHARCOAL,"
HOPE CREEK GENERATING STATION (TAC NO. MA5801)

Dear Mr. Keiser:

On June 3, 1999, the U.S. Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 99-02, "Laboratory Testing of Nuclear-Grade Activated Charcoal," to all holders of operating licenses for nuclear power reactors, except those who have permanently ceased operations and have certified that fuel has been permanently removed from the reactor vessel.

The purpose of the GL was to:

- (1) Alert addressees that the NRC has determined that testing nuclear-grade activated charcoal to standards other than American Society for Testing and Materials (ASTM) D3803-1989, "Standard Test Method for Nuclear-Grade Activated Carbon," does not provide assurance for complying with the current licensing basis as it relates to the dose limits of General Design Criterion (GDC) 19 of Appendix A to Part 50 of Title 10 of the *Code of Federal Regulations* (10 CFR) and Subpart A of 10 CFR Part 100.
- (2) Request that all addressees determine whether their Technical Specifications (TS) reference ASTM D3803-1989 for charcoal filter laboratory testing. Addressees whose TS do not reference ASTM D3803-1989 should either amend their TS to reference ASTM D3803-1989 or propose an alternative test protocol and provide the information discussed in the requested actions.
- (3) Alert addressees to the NRC staff's intent to exercise enforcement discretion under certain conditions.
- (4) Request that all addressees send the NRC written responses on the implementation of the actions requested in this GL.

In GL 99-02, the NRC staff established the following four groups of plants:

- (1) plants in compliance with their TS that test in accordance with ASTM D3803-1989

- (2) plants in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989
- (3) plants not in compliance with their TS that test in accordance with ASTM D3803-1989
- (4) plants not in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989

In response to GL 99-02, you provided letter LR-N990466 dated November 24, 1999, for the Hope Creek Generating Station. Associated with your response was a request for a license amendment to change your TS to provide for testing as described in the GL (reference letter LR-N99474 also dated November 24, 1999). The NRC staff has reviewed your submittals and has concluded that you have provided the requested information and a TS change request in accordance with GL 99-02. In addition you have committed to test in accordance with ASTM D3803-1989 until your TS amendment is issued. Therefore, we consider GL 99-02 to be closed for your facility. The TS change will be reviewed as a separate, plant-specific action under TAC No. MA7322. We thank you for your prompt and complete response.

If you have any questions regarding this matter, please contact me at (301) 415-1420.

Sincerely,

/RA/

Richard B. Ennis, Project Manager, Section 2
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-354

cc: See next page

- (2) plants in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989
- (3) plants not in compliance with their TS that test in accordance with ASTM D3803-1989
- (4) plants not in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989

In response to GL 99-02, you provided letter LR-N990466 dated November 24, 1999, for the Hope Creek Generating Station. Associated with your response was a request for a license amendment to change your TS to provide for testing as described in the GL (reference letter LR-N99474 also dated November 24, 1999). The NRC staff has reviewed your submittals and has concluded that you have provided the requested information and a TS change request in accordance with GL 99-02. In addition you have committed to test in accordance with ASTM D3803-1989 until your TS amendment is issued. Therefore, we consider GL 99-02 to be closed for your facility. The TS change will be reviewed as a separate, plant-specific action under TAC No. MA7322. We thank you for your prompt and complete response.

If you have any questions regarding this matter, please contact me at (301) 415-1420.

Sincerely,

/RA/

Richard B. Ennis, Project Manager, Section 2
 Project Directorate I
 Division of Licensing Project Management
 Office of Nuclear Reactor Regulation

Docket No. 50-354

cc: See next page

DISTRIBUTION

File Center	JClifford	JSegala	OGC
PUBLIC	TClark	SWest	ACRS
PDI-2 Reading	REnnis	JHannon	
EAdensam (EGA1)	BMozaafari	GMeyer, RGN-I	

OFFICE	PDI-2/PM	PDI-2/LA	LPM	SPLB/SC	PDI-2/SC
NAME	REnnis	TClark	BMozaafari	SWest	JClifford
DATE	1/ 18/00	1/19/00	1 /19/00	1/21/00	1/28/00

Hope Creek Generating Station

cc:

Jeffrie J. Keenan, Esquire
Nuclear Business Unit - N21
P.O. Box 236
Hancocks Bridge, NJ 08038

Hope Creek Resident Inspector
U.S. Nuclear Regulatory Commission
Drawer 0509
Hancocks Bridge, NJ 08038

Mr. Louis Storz
Sr. Vice President - Nuclear Operations
Nuclear Department
P.O. Box 236
Hancocks Bridge, NJ 08038

General Manager - Hope Creek Operations
Hope Creek Generating Station
P.O. Box 236
Hancocks Bridge, NJ 08038

Director - Licensing Regulation & Fuels
Nuclear Business Unit - N21
P.O. Box 236
Hancocks Bridge, NJ 08038

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Dr. Jill Lipoti, Asst. Director
Radiation Protection Programs
NJ Department of Environmental
Protection and Energy
CN 415
Trenton, NJ 08625-0415

Manager - Joint Generation
Atlantic Energy
6801 Black Horse Pike
Egg Harbor Twp., NJ 08234-4130

Richard Hartung
Electric Service Evaluation
Board of Regulatory Commissioners
2 Gateway Center, Tenth Floor
Newark, NJ 07102

Lower Alloways Creek Township
c/o Mary O. Henderson, Clerk
Municipal Building, P.O. Box 157
Hancocks Bridge, NJ 08038

Mr. Elbert Simpson
Senior Vice President-
Nuclear Engineering
Nuclear Department
P.O. Box 236
Hancocks Bridge, NJ 08038