Mr. William T. Cottle President and Chief Executive Officer STP Nuclear Operating Company South Texas Project Electric **Generating Station** P. O. Box 289 Wadsworth, TX 77483

SUBJECT:

SOUTH TEXAS PROJECT, UNITS 1 AND 2 - ISSUANCE OF AMENDMENTS ON DEFINITION OF CORE ALTERATIONS (TAC NOS. MA7343 AND MA7344)

Dear Mr. Cottle:

The Commission has issued the enclosed Amendment No. 123 to Facility Operating License No. NPF-76 and Amendment No. 111 to Facility Operating License No. NPF-80 for the South Texas Project, Units 1 and 2, respectively. The amendments consist of changes to the Technical Specifications (TSs) in response to your application dated December 6, 1999.

The amendments revise TS Definition 1.9, "Core Alterations," to explicitly define core alterations as the movement of any fuel, sources, or reactivity control components within the reactor vessel with the vessel head removed and fuel in the vessel.

A copy of our related Safety Evaluation is enclosed. The Notice of Issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,

/RA/

John A. Nakoski, Senior Project Manager, Section 1 Project Directorate IV & Decommissioning Division of Licensing Project Management Office of Nuclear Reactor Regulation

Docket Nos. 50-498 and 50-499

Enclosures:

1. Amendment No. 123 to NPF-76

2. Amendment No. 111 to NPF-80

3. Safety Evaluation

e pas center con

cc w/encls: See next page

DISTRIBUTION:

File Center

W. Beckner

L. Hurley, RIV

T. Alexion

PUBLIC

G. Hill (4)

J. Kilcrease, RIV

T. Tjader

PDIV-1 r/f

ACRS

R. Scholl (e-mail SE)

S. Richards

OGC

J. Tapia, RIV

To receive a copy of this document, indicate "C" in the box							
OFFICE	PDIV-1/PM C	PDIV-1/PM	¢ PDIV-D/LA	RTSB/BC	OGG	PDIV-1/SC C	
NAME	TAlexidn:	JNakoski	CJamerson	WBeckner wo	C. HOM	RGramm66	
DATE	116/08	1/10/00	1/5/00	117/08	OD. 10/2/	1/18/00	

DOCUMENT NAME: G:\PDIV-1\SouthTexas\AMDA7343.WPD OFFICIAL RECORD COPY

South Texas, Units 1 & 2

cc:

Mr. Cornelius F. O'Keefe Senior Resident Inspector U.S. Nuclear Regulatory Commission P. O. Box 910 Bay City, TX 77414

A. Ramirez/C. M. Canady City of Austin Electric Utility Department 721 Barton Springs Road Austin, TX 78704

Mr. M. T. Hardt Mr. W. C. Gunst City Public Service Board P. O. Box 1771 San Antonio, TX 78296

Mr. G. E. Vaughn/C. A. Johnson Central Power and Light Company P. O. Box 289 Mail Code: N5012 Wadsworth, TX 74483

INPO Records Center 700 Galleria Parkway Atlanta, GA 30339-3064

Regional Administrator, Region IV U.S. Nuclear Regulatory Commission 611 Ryan Plaza Drive, Suite 400 Arlington, TX 76011

D. G. Tees/R. L. Balcom Houston Lighting & Power Co. P. O. Box 1700 Houston, TX 77251

Judge, Matagorda County Matagorda County Courthouse 1700 Seventh Street Bay City, TX 77414 Jack R. Newman, Esq. Morgan, Lewis & Bockius 1800 M Street, N.W. Washington, DC 20036-5869

Mr. J. J. Sheppard, Vice President Engineering & Technical Services STP Nuclear Operating Company P. O. Box 289 Wadsworth, TX 77483

S. M. Head, Supervisor, Licensing Quality & Licensing Department STP Nuclear Operating Company P. O. Box 289 Wadsworth, TX 77483

Office of the Governor
ATTN: John Howard, Director
Environmental and Natural
Resources Policy
P. O. Box 12428
Austin, TX 78711

Jon C. Wood Matthews & Branscomb One Alamo Center 106 S. St. Mary's Street, Suite 700 San Antonio, TX 78205-3692

Arthur C. Tate, Director
Division of Compliance & Inspection
Bureau of Radiation Control
Texas Department of Health
1100 West 49th Street
Austin, TX 78756

Jim Calloway
Public Utility Commission of Texas
Electric Industry Analysis
P. O. Box 13326
Austin, TX 78711-3326



UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

STP NUCLEAR OPERATING COMPANY

DOCKET NO. 50-498

SOUTH TEXAS PROJECT, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 123 License No. NPF-76

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by STP Nuclear Operating Company* acting on behalf of itself and for Houston Lighting & Power Company (HL&P), the City Public Service Board of San Antonio (CPS), Central Power and Light Company (CPL), and the City of Austin, Texas (COA) (the licensees), dated December 6, 1999, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

^{*}STP Nuclear Operating Company is authorized to act for Houston Lighting & Power Company (HL&P), the City Public Service Board of San Antonio, Central Power and Light Company, and the City of Austin, Texas, and has exclusive responsibility and control over the physical construction, operation, and maintenance of the facility.

- 2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 2.C.(2) of Facility Operating License No. NPF-76 is hereby amended to read as follows:
 - 2. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 123, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. The license amendment is effective as of its date of issuance and shall be implemented within 30 days from the date of issuance.

Colvert A Fram

FOR THE NUCLEAR REGULATORY COMMISSION

Robert A. Gramm, Chief, Section 1

Project Directorate IV & Decommissioning Division of Licensing Project Management

Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical

Specifications

Date of Issuance: February 1, 2000



UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

STP NUCLEAR OPERATING COMPANY

DOCKET NO. 50-499

SOUTH TEXAS PROJECT, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 111 License No. NPF-80

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by STP Nuclear Operating Company* acting on behalf of itself and for Houston Lighting & Power Company (HL&P), the City Public Service Board of San Antonio (CPS), Central Power and Light Company (CPL), and the City of Austin, Texas (COA) (the licensees), dated December 6, 1999, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

^{*}STP Nuclear Operating Company is authorized to act for Houston Lighting & Power Company (HL&P), the City Public Service Board of San Antonio, Central Power and Light Company, and the City of Austin, Texas, and has exclusive responsibility and control over the physical construction, operation, and maintenance of the facility.

- 2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 2.C.(2) of Facility Operating License No. NPF-80 is hereby amended to read as follows:
 - 2. <u>Technical Specifications</u>

The Technical Specifications contained in Appendix A, as revised through Amendment No. 111, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. The license amendment is effective as of its date of issuance and shall be implemented within 30 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Robert A. Gramm, Chief, Section 1

Robert A Issam

Project Directorate IV & Decommissioning Division of Licensing Project Management Office of Nuclear Reactor Regulation

Attachment:

Changes to the Technical

Specifications

Date of Issuance:

February 1, 2000

ATTACHMENT TO LICENSE AMENDMENT NOS. 123 AND 111

FACILITY OPERATING LICENSE NOS. NPF-76 AND NPF-80

DOCKET NOS. 50-498 AND 50-499

Replace the following pages of the Appendix A Technical Specifications with the attached revised pages. The revised pages are identified by amendment number and contain marginal lines indicating the areas of change.

REMOVE	÷	INSERT
1-1 1-2		1-1* 1-2

^{*}Overleaf page provided to maintain document completeness. No changes on this page.

1.0 DEFINITIONS

The defined terms of this section appear in capitalized type and are applicable throughout these Technical Specifications.

ACTION

1.1 ACTION shall be that part of a Technical Specification that prescribes remedial measures required under designated conditions.

ACTUATION LOGIC TEST

1.2 An ACTUATION LOGIC TEST shall be the application of various simulated input combinations in conjunction with each possible interlock logic state and verification of the required logic output. The ACTUATION LOGIC TEST shall include a continuity check, as a minimum, of output devices.

ANALOG CHANNEL OPERATIONAL TEST

1.3 An ANALOG CHANNEL OPERATIONAL TEST shall be the injection of a simulated signal into the channel as close to the sensor as practicable to verify OPERABILITY of alarm, interlock and/or trip functions. The ANALOG CHANNEL OPERATIONAL TEST shall include adjustments, as necessary, of the alarm, interlock and/or Trip Setpoints so that the Setpoints are within the required range and accuracy.

AXIAL FLUX DIFFERENCE

1.4 AXIAL FLUX DIFFERENCE shall be the difference in normalized flux signals between the top and bottom halves of a 2-section excore neutron detector.

CHANNEL CALIBRATION

1.5 A CHANNEL CALIBRATION shall be the adjustment, as necessary, of the channel so that it responds within the required range and accuracy to known values of input. The CHANNEL CALIBRATION shall encompass the entire channel including the sensors and alarm, interlock, and/or trip functions and may be performed by any series of sequential, overlapping, or total channel steps so that the entire channel is calibrated.

CHANNEL CHECK

1.6 A CHANNEL CHECK shall be the qualitative assessment of channel behavior during operation by observation. This determination shall include, where possible, comparison of the channel indication and/or status with other indications and/or status derived from independent instrument channels measuring the same parameter.

CONTAINMENT INTEGRITY

- 1.7 CONTAINMENT INTEGRITY shall exist when:
 - a. All penetrations required to be closed during accident conditions are either:
 - 1) Capable of being closed by an OPERABLE containment automatic isolation valve system, or
 - 2) Closed by manual valves, blind flanges, or deactivated automatic valves secured in their closed positions, except as provided in Specification 3.6.3.
 - b. All equipment hatches are closed and sealed,
 - c. Each air lock is in compliance with the requirements of Specification 3.6.1.3,
 - d. The containment leakage rates are within the limits of Specification 3.6.1.2, and
 - e. The sealing mechanism associated with each penetration (e.g., welds, bellows, or O-rings) is OPERABLE.

CONTROLLED LEAKAGE

1.8 CONTROLLED LEAKAGE shall be that seal water flow supplied to the reactor coolant pump seals.

CORE ALTERATIONS

1.9 CORE ALTERATIONS shall be the movement of any fuel, sources, or reactivity control components within the reactor vessel with the vessel head removed and fuel in the vessel. Suspension of CORE ALTERATIONS shall not preclude completion of movement of a component to a safe position.

CORE OPERATING LIMITS REPORT

1.9a The CORE OPERATING LIMITS REPORT is the unit-specific document that provides core operating limits for the current operating reload cycle. These cycle-specific core operating limits shall be determined for each reload cycle in accordance with Specification 6.9.1.6. Plant operation within these core operating limits is addressed within the individual Specifications.

DIGITAL CHANNEL OPERATIONAL TEST

1.10 A DIGITAL CHANNEL OPERATIONAL TEST shall consist of injecting simulated process data where available or exercising the digital computer hardware using data base manipulation to verify OPERABILITY of alarm, interlock, and/or trip functions.

DOSE EQUIVALENT I-131

1.11 DOSE EQUIVALENT I-131 shall be that concentration of I-131 (microCurie/gram) which alone would produce the same thyroid dose as the quantity and isotopic mixture of I-131, I-132, I-133, I-134, and I-135 actually present. The thyroid dose conversion factors used for this calculation shall be those listed in Table E-7 of NRC Regulatory Guide 1.109, Revision 1, October 1977.



UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NOS. 123 AND 111 TO

FACILITY OPERATING LICENSE NOS. NPF-76 AND NPF-80

STP NUCLEAR OPERATING COMPANY, ET AL.

SOUTH TEXAS PROJECT, UNITS 1 AND 2

DOCKET NOS. 50-498 AND 50-499

1.0 INTRODUCTION

By application dated December 6, 1999, STP Nuclear Operating Company (the licensee) requested changes to the South Texas Project, Units 1 and 2, Technical Specifications (TSs). The proposed changes would revise TS Definition 1.9, "Core Alterations," to explicitly define core alterations as the movement of any fuel, sources, or reactivity control components within the reactor vessel with the vessel head removed and fuel in the vessel.

2.0 BACKGROUND

The current TS definition of core alterations is "the movement or manipulation of any component within the reactor pressure vessel with the vessel head removed and fuel in the vessel. Suspension of CORE ALTERATION shall not preclude completion of movement of a component to a safe conservative position." The proposed TS definition of core alterations is "the movement of any fuel, sources, or reactivity control components within the reactor vessel with the vessel head removed and fuel in the vessel. Suspension of CORE ALTERATIONS shall not preclude completion of movement of a component to safe position." The staff notes that the proposed definition is identical to that in NUREG-1431, Revision 1 (Standard Technical Specifications, Westinghouse Plants).

3.0 EVALUATION

The proposed definition of core alterations is less restrictive than the current definition because the proposed definition would apply only to those activities that create the potential for a reactivity excursion and thus warrant special precautions or controls. The proposed definition would apply to fewer activities. The proposed definition would restrict core alterations to the movement of fuel, sources, or reactivity control components which may cause significant reactivity changes in the core. Under the proposed definition, in-vessel movement of instruments, cameras, lights, tools, moveable incore detector thimbles, etc., would not be considered to be core alterations. This change is acceptable because special controls on components other than fuel, sources, or reactivity control components to prevent reactivity excursions, are not warranted. In addition, the word "conservative" is deleted from the second sentence of the proposed definition because it is redundant to the word "safe."

4.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Texas State official was notified of the proposed issuance of the amendments. The State official had no comments.

5.0 ENVIRONMENTAL CONSIDERATION

The amendments change a requirement with respect to the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The NRC staff has determined that the amendments involve no significant increase in the amounts and no significant change in the types of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendments involve no significant hazards consideration, and there has been no public comment on such finding (64 FR 73099). Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

6.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: T. Alexion

Date: February 1, 2000