

Mr. Charles M. Dugger
Vice President Operations
Entergy Operations, Inc.
17265 River Road
Killona, LA 70066-0751

February 8, 2000

SUBJECT: WATERFORD STEAM ELECTRIC STATION, UNIT 3, SITE-SPECIFIC
WORKSHEETS FOR USE IN THE NUCLEAR REGULATORY COMMISSION'S
SIGNIFICANCE DETERMINATION PROCESS (TAC NO. MA6544)

Dear Mr. Dugger:

The purpose of this letter is to provide you with one of the key implementation tools to be used by the Nuclear Regulatory Commission (NRC) in the revised reactor oversight process, which is currently expected to be implemented at the Waterford Steam Electric Station, Unit 3, (Waterford 3) in April 2000. Included in the enclosed Risk-Informed Inspection Notebook are the Significance Determination Process (SDP) worksheets that inspectors will be using to risk-characterize inspection findings. The SDP is discussed in more detail below.

On January 8, 1999, the NRC staff described to the Commission plans and recommendations to improve the reactor oversight process in SECY-99-007, "Recommendations for Reactor Oversight Process Improvements." SECY-99-007 is available on the NRC's web site at www.nrc.gov/NRC/COMMISSION/SECYS/index.html. The new process, developed with stakeholder involvement, is designed around a risk-informed framework, which is intended to focus both the NRC's and licensee's attention and resources on those issues of more risk significance.

The performance assessment portion of the new process involves the use of both licensee-submitted performance indicator data and inspection findings that have been appropriately categorized based on their risk significance. In order to properly categorize an inspection finding, the NRC has developed the SDP. This process was also described to the Commission in SECY-99-007A, "Recommendations for Reactor Oversight Process Improvements (Follow-up to SECY-99-007)," dated March 22, 1999, also available at the same web site noted above.

The SDP for power operations involves evaluating an inspection finding's impact on the plant's capability to limit the frequency of initiating events; ensure the availability, reliability, and capability of mitigating systems; and ensure the integrity of the fuel cladding, reactor coolant system, and containment barriers. As described in SECY-99-007A, the SDP involves the use of three tables: Table 1 is the estimated likelihood for initiating event occurrence during the degraded period, Table 2 describes how the significance is determined based on remaining mitigation system capabilities, and Table 3 provides the bases for the failure probabilities associated with the remaining mitigation equipment and strategies.

As a result of the recently concluded Pilot Plant review effort, the NRC has determined that site-specific risk data is needed in order to provide a repeatable determination of the significance of an issue. Therefore, the NRC has contracted with Brookhaven National Lab to develop site-specific worksheets to be used in the SDP review. These enclosed worksheets were developed based on your Individual Plant Examination (IPE) submittal that was requested by Generic Letter 88-20. The NRC plans to use this site-specific information in evaluating the significance of issues identified at your facility when the revised reactor oversight process is implemented industry wide. It is recognized that the IPE utilized during this effort may not contain current information. Therefore, the NRC or its contractor will conduct a site visit in the near future to discuss with your staff any changes that may be appropriate. We are not requesting written comments on the NRC's work product.

We will coordinate our efforts through your licensing or risk organizations as appropriate. If you have any questions, please contact me at 301-415-1480.

Sincerely,

/RA/

N. Kalyanam, Project Manager, Section 1
Project Directorate IV and Decommissioning
Division of Licensing Project management
Office of Nuclear Reactor Regulation

Docket No. 50-382

Enclosure: Risk-Informed Inspection Notebook

cc: see next page

As a result of the recently concluded Pilot Plant review effort, the NRC has determined that site-specific risk data is needed in order to provide a repeatable determination of the significance of an issue. Therefore, the NRC has contracted with Brookhaven National Lab to develop site-specific worksheets to be used in the SDP review. These enclosed worksheets were developed based on your Individual Plant Examination (IPE) submittal that was requested by Generic Letter 88-20. The NRC plans to use this site-specific information in evaluating the significance of issues identified at your facility when the revised reactor oversight process is implemented industry wide. It is recognized that the IPE utilized during this effort may not contain current information. Therefore, the NRC or its contractor will conduct a site visit in the near future to discuss with your staff any changes that may be appropriate. We are not requesting written comments on the NRC's work product.

We will coordinate our efforts through your licensing or risk organizations as appropriate. If you have any questions, please contact me at 301-415-1480.

Sincerely,

/RA/

N. Kalyanam, Project Manager, Section 1
Project Directorate IV and Decommissioning
Division of Licensing Project management
Office of Nuclear Reactor Regulation

Docket No. 50-382

Enclosure: Risk-Informed Inspection Notebook

cc: see next page

DISTRIBUTION:

File Center OGC M. Branch
PUBLIC ACRS W. Dean
PD IV-1 Reading K. Brockman, RIV D. Coe

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

| | | | | | | |
|--------|-----------|---|-----------|--|-----------|---|
| OFFICE | PM:PDIV-1 | C | LA:PDIV-1 | | PDIV-1:SC | C |
| NAME | NKalyanam | | DJohnson | | RGramm | |
| DATE | 02/07/00 | | 02/07/00 | | 02/8/00 | |

DOCUMENT NAME: C:\SDP-coverletter and workshe~.wpd

OFFICE COPY

Waterford Generating Station 3

cc:

Administrator
Louisiana Department of Environmental Quality
P. O. Box 82215
Baton Rouge, LA 70884-2215

Vice President, Operations Support
Entergy Operations, Inc.
P. O. Box 31995
Jackson, MS 39286

Director
Nuclear Safety Assurance
Entergy Operations, Inc.
17265 River Road
Killona, LA 70066-0751

Wise, Carter, Child & Caraway
P. O. Box 651
Jackson, MS 39205

General Manager Plant Operations
Waterford 3 SES
Entergy Operations, Inc.
17265 River Road
Killona, LA 70066-0751

Licensing Manager
Entergy Operations, Inc.
17265 River Road
Killona, LA 70066-0751

Winston & Strawn
1400 L Street, N.W.
Washington, DC 20005-3502

Resident Inspector/Waterford NPS
P. O. Box 822
Killona, LA 70066-0751

Regional Administrator, Region IV
U. S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76011

Parish President Council
St. Charles Parish
P. O. Box 302
Hahnville, LA 70057

Executive Vice-President
and Chief Operating Officer
Entergy Operations, Inc.
P. O. Box 31995
Jackson, MS 39286-1995

Chairman
Louisiana Public Services Commission
Baton Rouge, LA 70825-1697

Steve Floyd
Nuclear Energy Institute
1776 I Street NW, Suite 400
Washington, DC 20006

David Lochbaum
Nuclear Safety Engineer
Union of Concerned Scientists
1616 P Street NW, Suite 310
Washington, DC 20036-1495

RISK-INFORMED INSPECTION NOTEBOOK FOR WATERFORD 3 NUCLEAR POWER PLANT

PWR, COMBUSTION ENGINEERING, TWO-LOOP PLANT WITH LARGE DRY CONTAINMENT

Prepared by

**Brookhaven National Laboratory
Department of Advanced Technology**

Contributors

**M. A. Azarm
J. Carbonaro
T. L. Chu
A. Fresco
J. Higgins
G. Martinez-Guridi
P. K. Samanta**

NRC Technical Review Team

| | |
|-------------------------|-------------------|
| John Flack | RES |
| Morris Branch | NRR |
| Doug Coe | NRR |
| Gareth Parry | NRR |
| Peter Wilson | NRR |
| Jim Trapp | Region I |
| Michael Parker | Region III |
| William B. Jones | Region IV |

Prepared for

**U. S. Nuclear Regulatory Commission
Office of Nuclear Regulatory Research
Division of Risk Analysis & Applications**

NOTICE

This notebook was developed for the NRC's inspection teams to support risk-informed inspections. The activities involved in these inspections are discussed in "Reactor Oversight Process Improvement," SECY-99-007A, March 1999. The user of this notebook is assumed to be an inspector with an extensive understanding of plant-specific design features and operation. Therefore, the notebook is not a stand-alone document, and may not be suitable for use by non-specialists. This notebook will be periodically updated with new or replacement pages incorporating additional information on this plant. Technical errors in, and recommended updates to, this document should be brought to the attention of the following person:

Mr. Jose G. Ibarra
U. S. Nuclear Regulatory Commission
RES/DSARE/REAHFB
TWFN T10 E46
11545 Rockville Pike
Rockville, MD 20852

ABSTRACT

This notebook contains summary information to support the Significance Determination Process (SDP) in risk-informed inspections for the Waterford 3 Nuclear Plant.

SDP worksheets support the significance determination process in risk-informed inspections and are intended to be used by the NRC's inspectors in identifying the significance of their findings, i.e., in screening risk-significant findings, consistent with Phase-2 screening in SECY-99-007A. To support the SDP, additional information is given in an Initiators and System Dependency table, and as simplified event-trees, called SDP event-trees, developed in preparing the SDP worksheets.

The information contained herein is based on the licensee's IPE submittal. The information is revised based on IPE updates or other licensee or review comments providing updated information and/or additional details.

CONTENTS

| | Page |
|--|-------------|
| Notice | ii |
| Abstract | iii |
| Contents | iv |
| Figures | v |
| Tables | vi |
| 1. Information Supporting Significance Determination Process (SDP) | 1 |
| 1.1 Initiators and System Dependency | 3 |
| 1.2 SDP Worksheets | 7 |
| 1.3 SDP Event Trees | 24 |
| 2. Resolution and Disposition of Comments | 32 |
| References | 33 |

FIGURES

| | Page |
|--|-------------|
| SDP Event Tree — Transients | 25 |
| SDP Event Tree — Small LOCA | 26 |
| SDP Event Tree — Stuck Open PSV | 27 |
| SDP Event Tree — Medium LOCA | 28 |
| SDP Event Tree — Large LOCA | 29 |
| SDP Event Tree — LOOP | 30 |
| SDP Event Tree — Steam Generator Tube Rupture (SGTR) | 31 |
| SDP Event Tree — Anticipated Transients Without Scram (ATWS) | 32 |

TABLES

| | | Page |
|-----|---|-------------|
| 1 | Initiators and System Dependency for Waterford 3 | 4 |
| 2.1 | SDP Worksheet — Transients | 8 |
| 2.2 | SDP Worksheet — Small LOCA | 9 |
| 2.3 | SDP Worksheet — Stuck-open PORV | 11 |
| 2.4 | SDP Worksheet — Medium LOCA | 13 |
| 2.5 | SDP Worksheet — Large LOCA | 14 |
| 2.6 | SDP Worksheet — LOOP | 15 |
| 2.7 | SDP Worksheet — Steam Generator Tube Rupture (SGTR) | 17 |
| 2.8 | SDP Worksheet — Anticipated Transients Without Scram (ATWS) | 19 |
| 2.9 | SDP Worksheet — Special Initiators | 21 |

1. INFORMATION SUPPORTING SIGNIFICANCE DETERMINATION PROCESS (SDP)

SECY-99-007A (NRC, March 1999) describes the process for making a Phase-2 evaluation of the inspection findings. In Phase 2, the first step is to identify the pertinent core damage scenarios that require further evaluation based on the specifics of the inspection findings. To aid in this process, this notebook provides the following information:

1. Initiator and System Dependency Table
2. Significance Determination Process (SDP) Worksheets
3. SDP Event Trees

The initiator and system dependency table shows the major dependencies between front-line- and support-systems, and identifies their involvement in different types of initiators. The information in this table identifies the most risk-significant front-line- and support-systems; it is not an exhaustive nor comprehensive compilation of the dependency matrix as known in Probabilistic Risk Assessments (PRAs). For pressurized water reactors (PWRs), the support systems for Reactor Coolant Pump (RCP) seals are explicitly denoted to assure that the inspection findings on them are properly accounted for. This table is used to identify the SDP worksheets to be evaluated, corresponding to the inspection's findings on systems and components.

To evaluate the impact of the inspection's finding on the core-damage scenarios, the SDP worksheets are developed and provided. They contain two parts. The first part identifies the functions, the systems, or combinations thereof that can perform mitigating functions, the number of trains in each system, and the number of trains required (success criteria) for each class of initiators. The second part of the SDP worksheet contains the core-damage accident sequences associated with each initiator class; these sequences are based on SDP event trees. In the parenthesis next to each of the sequence the corresponding event tree branch number(s) representing the sequence is included. Multiple branch numbers indicate that the different accident sequences identified by the event tree are merged into one through the boolean reduction. The classes of initiators that are considered in this notebook are 1) Transients, 2) Small Loss of Coolant Accident (LOCA), 3) Stuck-open Power Operated Relief Valve (PORV), 4) Medium LOCA, 5) Large LOCA, 6) Loss of Offsite Power (LOOP), 7) Steam Generator Tube Rupture (SGTR), and 8) Anticipated Transients Without Scram (ATWS). Main Steam Line Break (MSLB) events are included separately if they are treated as such in the licensee's Individual Plant Examination (IPE) submittal.

Following the SDP worksheets, the SDP event trees corresponding to each of the worksheets are presented. The SDP event trees are simplified event trees developed to define the accident sequences identified in the SDP worksheets.

The following items were considered in establishing the SDP event trees and the core-damage sequences in the SDP worksheets:

1. Event trees and sequences were developed such that the worksheet contains all the major accident sequences identified by the plant-specific IPEs. In cases where a plant-specific feature introduced a sequence that is not fully captured by our existing set of initiators and event trees, then a separate worksheet is included.
2. The event trees and sequences for each plant took into account the IPE models and event trees for all similar plants. Any major deviations in one plant from similar plants typically are noted at the end of the worksheet.
3. The event trees and the sequences were designed to capture core-damage scenarios, without including containment-failure probabilities and consequences. Therefore, branches of event trees that are only for the purpose of a Level II PRA analysis are not considered. The resulting sequences are merged using Boolean logic.
4. The simplified event-trees focus on classes of initiators, as defined above. In so doing, many separate event trees in the IPEs often are represented by a single tree. For example, some IPEs define four classes of LOCAs rather than the three classes considered here. The sizes of LOCAs for which high-pressure injection is not required are some times divided into two classes, the only difference between them being the need for reactor scram in the smaller break size. Some IPEs also may define several classes of transients, depending on the initiator's impact on the systems. Such differentiations generally are not considered in the SDP worksheets unless they could not be accounted for by the Initiator and System Dependency table.
5. Major operator actions during accident scenarios are assigned as high stress operator action or an operator action using simple, standard criteria among a class of plants. This approach resulted in the designation of some actions as high-stress operator actions, even though the PRA may have assumed a (routine) operator action; hence, they have been assigned an error probability less than $5E-2$ in the IPE. In such cases, a note is given at the end of the worksheet.

The three sections that follow include the initiators and dependency table, SDP worksheets, and the SDP event-trees for the Waterford 3 Nuclear Power Plant.

1.1 INITIATORS AND SYSTEM DEPENDENCY

Table 1 provides the list of the systems included in the SDP worksheets, the major components in the systems, and the support system dependencies. The system involvements in different initiating events are noted in the last column.

Table 1 Initiators and System Dependency for Waterford 3

| Affected Systems | Major Components | Support Systems | Initiating Event |
|---|---|----------------------------------|--|
| AC Power System | AC Power Distribution & AC Instrument Power | DC, HVAC | Transient, SLOCA, MLOCA, LLOCA, LOOP, SGTR, ATWS, RCP seal LOCA |
| EFW | 2 MDPs, condensate storage pool (CSP) | AC, DC, ESFAS, HVAC | Transient, SLOCA, LOOP, SGTR, ATWS, RCP seal LOCA |
| | 1 TDP, CSP | ESFAS, DC, main steam | |
| CCW | 3 Pumps in two trains with one dry cooling tower and one CCW heat exchanger in each train | AC, DC, ESFAS, ACCW, HVAC, IA | Transient, SLOCA, MLOCA, LLOCA, LOOP, SGTR, ATWS, RCP seal LOCA |
| Auxiliary Component Cooling Water (ACCW) | 2 Pumps and 2 wet cooling towers | AC,DC | Transient, SLOCA, MLOCA, LLOCA, LOOP, SGTR, ATWS, RCP seal LOCA |
| Condensate / MFW | 3 Condensate pumps | AC | Transient, SLOCA |
| | 2 SGFPs | AC, DC, IA, main steam | |
| | 1 Auxiliary feedwater pump (AFW), condensate storage tank (CST) | AC, DC, IA | |
| Containment Cooling System (CCS) | 4 Fan coolers | AC, ESFAS, CCW | SLOCA, MLOCA, LLOCA, RCP seal LOCA |
| Containment Spray System(CSS) | 2 Trains, each with 1 pump | AC, DC, ESFAS, HVAC, IA, CCW | SLOCA, MLOCA, LLOCA, RCP seal LOCA |

| Affected Systems | Major Components | Support Systems | Initiating Event |
|-----------------------------|---|---|---|
| HPSI | 2 HPSI trains with a third swing train | AC, DC, ESFAS, CCW, HVAC | Transient, SLOCA, MLOCA, LOOP, SGTR, ATWS, RCP seal LOCA |
| Charging Pumps (CHG) | 3 Pumps | AC, DC, IA, HVAC | SGTR, ATWS |
| DC Power System | Buses, battery chargers and batteries | AC Dist. (without AC, battery capacity is 4 hrs.) | Transient, SLOCA, MLOCA, LLOCA, LOOP, SGTR, ATWS, RCP seal LOCA |
| EDG | 2 EDGs: | DC, HVAC, CCW | LOOP |
| HVAC | Area fan coolers and 3 essential service chilled water trains | AC, CCW, ESFAS?, DC | Transient, SLOCA, MLOCA, LLOCA, LOOP, SGTR, ATWS, RCP seal LOCA |
| Instrument Air (IA) | 2 Air compressors | AC, DC, turbine building cooling water | Transient, SLOCA, MLOCA, LLOCA, LOOP, SGTR, ATWS, RCP seal LOCA |
| Main Steam | 2 SGs, each with 1 ARV, 6 safety valves, 1 MSIV and 3 turbine bypass valves | DC, IA, Vital AC | Transient, SLOCA, MLOCA, LLOCA, LOOP, SGTR, ATWS, RCP seal LOCA |
| Pressurizer Pressure Relief | 2 Safety valves open at 2500 psia | none | Transient, LOOP, ATWS |
| RCP | Seals | 1 / 3 CCW pumps to thermal barrier heat exchanger | RCP seal LOCA |
| Safety Injection Tank (SIT) | 4 SITs | none | LLOCA |
| LHSI | 2 LPSI pumps | AC, DC, ESFAS, CCW, HVAC | LLOCA |

Notes:

(1) Plant internal event CDF (including internal floods) = 1.67 E-5/yr.

1.2 SDP WORKSHEETS

This section presents the SDP worksheets to be used in the Phase 2 evaluation of the inspection findings for the Waterford 3 Nuclear Plant. The SDP worksheets are presented for the following initiating event categories:

1. Transients
2. Small LOCA
3. Stuck Open PSV
4. Medium LOCA
5. Large LOCA
6. LOOP
7. Steam Generator Tube Rupture (SGTR)
8. Anticipated Transients Without Scram (ATWS)
9. Special Initiators

Table 2.1 SDP Worksheet for Waterford 3 Nuclear Plant Transients

| | | | |
|---|--|--|------------------------------|
| Estimated Frequency (Table 1 Row) _____ Exposure Time _____ Table 1 Result (circle): A B C D E F G H | | | |
| Safety Functions Needed: | | <u>Full Creditable Mitigation Capability for Each Safety Function:</u> | |
| Power Conversion System (PCS) | | 1 / 2 Main Feedwater trains with 1 / 3 condensate trains or 1/1 AFW pump or depressurization with 1 / 2 ADVs or 1/6 TBVs and feed with 1/3 condensate pumps (operator action) ⁽¹⁾ | |
| Emergency Feedwater System (EFW) | | 1 / 2 MD EFW trains (1 multi-train system) or 1 TD EFW train (1 ASD train) | |
| <u>Circle Affected Functions</u> | <u>Recovery of Failed Train</u> | <u>Remaining Mitigation Capability Rating for Each Affected Sequence</u> | <u>Sequence Color</u> |
| 1 TRANS - PCS - EFW (3) | | | |
| Identify any operator recovery actions that are credited to directly restore the degraded equipment or initiating event: | | | |
| | | | |
| If operator actions are required to credit placing mitigation equipment in service or for recovery actions, such credit should be given only if the following criteria are met: 1) sufficient time is available to implement these actions, 2) environmental conditions allow access where needed, 3) procedures exist, 4) training is conducted on the existing procedures under conditions similar to the scenario assumed, and 5) any equipment needed to complete these actions is available and ready for use. | | | |

Notes:

(1) The human error probability used in the IPE is 3.0E-4 for operator failure to recognize the need for feedwater. (Event OPER-2 on page 3.4-8.)

Table 2.2 SDP Worksheet for Waterford 3 Nuclear Plant

Small LOCA

| Estimated Frequency (Table 1 Row) _____ Exposure Time _____ Table 1 Result (circle): A B C D E F G H | | | |
|--|--|--|------------------------------|
| <u>Safety Functions Needed:</u> High Head Safety Injection (HPSI) Main Feedwater (MFW) Emergency Feedwater System(EFW) High Pressure Recirculation (HPR) Containment Heat Removal (CHR) | | <u>Full Creditable Mitigation Capability for Each Safety Function:</u> 1 /3 high pressure injection pumps inject to 2 intact cold legs from refueling water storage pool (RWSP) (1 multi-train system) 1 / 2 MFW trains or 1AFW train (operator action) ⁽¹⁾ 1 / 2 MD EFW trains (1 multi-train system) or 1 TD EFW train (1 ASD train) 1 / 3 HPSI pumps in recirculation mode (operator action) ⁽²⁾ 1/4 trains of fan coolers or 1 /2 trains of containment spray injection and recirculation (2 multi-train systems) | |
| <u>Circle Affected Functions</u> | <u>Recovery of Failed Train</u> | <u>Remaining Mitigation Capability Rating for Each Affected Sequence</u> | <u>Sequence Color</u> |
| 1 SLOCA - CHR (2,5) | | | |
| 2 SLOCA - HPR (3,6) | | | |
| 3 SLOCA - MFW - EFW (7) | | | |
| 4 SLOCA - HPSI (8) | | | |

Identify any operator recovery actions that are credited to directly restore the degraded equipment or initiating event:

If operator actions are required to credit placing mitigation equipment in service or for recovery actions, such credit should be given only if the following criteria are met: 1) sufficient time is available to implement these actions, 2) environmental conditions allow access where needed, 3) procedures exist, 4) training is conducted on the existing procedures under conditions similar to the scenario assumed, and 5) any equipment needed to complete these actions is available and ready for use.

Notes:

- (1) The human error probability used in the IPE is 3.0E-4 for operator failure to recognize the need for feedwater. (Event OPER-2 on page 3.4-8.)
- (2) The IPE did not document the human error probability. Recirculation is actuated automatically. The operator has to manually close the RWSP discharge valves.

Table 2.3 SDP Worksheet for Waterford 3 Nuclear Plant

Stuck Open PORV (SORV)⁽¹⁾

| Estimated Frequency (Table 1 Row) _____ Exposure Time _____ Table 1 Result (circle): A B C D E F G H | | | |
|---|---------------------------------|--|-----------------------|
| Safety Functions Needed: Stuck Open PSV (SOSV) Isolation of Small LOCA (BLK) High Head Safety Injection (HPSI) Main Feedwater (MFW) Emergency Feedwater System(EFW) High Pressure Recirculation (HPR) Containment Heat Removal (CHR) | | Full Creditable Mitigation Capability for Each Safety Function: 1 / 2 PSV fail to reclose when demended (1 train system). Failure to re-close the PSV (Probability of 1) 1 / 3 high pressure injection pumps inject to 2 intact cold legs from refueling water storage pool (RWSP) (1 multi-train system) 1 / 2 MFW trains or 1AFW train (operator action) ⁽²⁾ 1 / 2 MD EFW trains (1 multi-train system) or 1 TD EFW train (1 ASD train) 1 / 3 HPSI pumps in recirculation mode (operator action) ⁽³⁾ 1/4 trains of fan coolers or 1 / 2 trains of containment spray injection and recirculation (2 multi-train systems) | |
| <u>Circle Affected Functions</u> | <u>Recovery of Failed Train</u> | <u>Remaining Mitigation Capability Rating for Each Affected Sequence</u> | <u>Sequence Color</u> |
| 1 SOSV - BLK - HPSI (9) | | | |
| 2 SOSV - BLK - MFW - EFW (8) | | | |
| 3 SOSV - BLK - HPR (4,7) | | | |

| | | | |
|---|--|--|--|
| 4 SOSV - BLK - CHR (3,6) | | | |
| <p>Identify any operator recovery actions that are credited to directly restore the degraded equipment or initiating event:</p> <p>If operator actions are required to credit placing mitigation equipment in service or for recovery actions, such credit should be given only if the following criteria are met: 1) sufficient time is available to implement these actions, 2) environmental conditions allow access where needed, 3) procedures exist, 4) training is conducted on the existing procedures under conditions similar to the scenario assumed, and 5) any equipment needed to complete these actions is available and ready for use.</p> | | | |

Notes:

- (1) The Waterford 3 plant does not have PORVs. The work sheet was developed to model the scenarios that started with a transient and a pressurizer safety valve failed to re-close.
- (2) The human error probability used in the IPE is 3.0E-4 for operator failure to recognize the need for feedwater. (Event OPER-2 on page 3.4-8.)
- (3) The IPE did not document this human error probability. Recirculation is actuated automatically. The operator has to manually close the RWSP discharge valves.

Table 2.4 SDP Worksheet for Waterford 3 Nuclear Plant

Medium LOCA

| | | | |
|--|--|---|------------------------------|
| Estimated Frequency (Table 1 Row) _____ Exposure Time _____ Table 1 Result (circle): A B C D E F G H | | | |
| Safety Functions Needed: | | <u>Full Creditable Mitigation Capability for Each Safety Function:</u> | |
| High Head Safety Injection (HPSI) | | 1/3 high pressure injection pumps inject to 2 intact cold legs from refueling water storage pool (RWSP) (1 multi-train system) | |
| High Pressure Recirculation (HPR) | | 1/3 HPSI pumps in recirculation mode (operator action) ⁽¹⁾ | |
| Containment Heat Removal (CHR) | | 1/4 trains of fan coolers (multi-train systems) or 1 /2 trains of containment spray injection and recirculation (multi-train systems) | |
| <u>Circle Affected Functions</u> | <u>Recovery of Failed Train</u> | <u>Remaining Mitigation Capability Rating for Each Affected Sequence</u> | <u>Sequence Color</u> |
| 1 MLOCA - CHR (2) | | | |
| 2 MLOCA - HPR (3) | | | |
| 3 MLOCA - HPSI (4) | | | |

Identify any operator recovery actions that are credited to directly restore the degraded equipment or initiating event:

If operator actions are required to credit placing mitigation equipment in service or for recovery actions, such credit should be given only if the following criteria are met: 1) sufficient time is available to implement these actions, 2) environmental conditions allow access where needed, 3) procedures exist, 4) training is conducted on the existing procedures under conditions similar to the scenario assumed, and 5) any equipment needed to complete these actions is available and ready for use.

Notes:

- (1) The IPE did not document the human error probability. Recirculation is actuated automatically. The operator has to manually close the RWSP discharge valves.

Table 2.5 SDP Worksheet for Waterford Nuclear Plant

Large LOCA

| Estimated Frequency (Table 1 Row) _____ Exposure Time _____ Table 1 Result (circle): A B C D E F G H | | | |
|---|--|--|------------------------------|
| Safety Functions Needed: Safety Injection Tank(SIT) High Head Safety Injection (HPSI) Low Pressure Safety Injection(LPSI) High Pressure Recirculation (HPR) Containment Heat Removal (CHR) | | <u>Full Creditable Mitigation Capability for Each Safety Function:</u> 3/3 intact SITs inject into intact RCS legs (1 train system/high reliability) 1/3 high pressure injection pumps inject to 2 intact cold legs from refueling water storage pool (RWSP) (1 multi-train system) 1 / 2 LHSI trains inject from RWSP to 1 intact cold leg (1 multi-train system) 1 / 3 HPSI pumps in recirculation mode (operator action) ⁽¹⁾ 1/4 trains of fan coolers (multi-train systems) or 1 /2 trains of containment spray injection and recirculation (multi-train systems) | |
| <u>Circle Affected Functions</u> | <u>Recovery of Failed Train</u> | <u>Remaining Mitigation Capability Rating for Each Affected Sequence</u> | <u>Sequence Color</u> |
| 1 LLOCA - CHR (2) | | | |
| 2 LLOCA - HPR (3) | | | |
| 3 LLOCA - LPSI (4) | | | |
| 4 LLOCA - HPSI (5) | | | |

| | | | |
|--|--|--|--|
| 5 LLOCA - SIT (6) | | | |
| <p>Identify any operator recovery actions that are credited to directly restore the degraded equipment or initiating event:</p> <p>If operator actions are required to credit placing mitigation equipment in service or for recovery actions, such credit should be given only if the following criteria are met: 1) sufficient time is available to implement these actions, 2) environmental conditions allow access where needed, 3) procedures exist, 4) training is conducted on the existing procedures under conditions similar to the scenario assumed, and 5) any equipment needed to complete these actions is available and ready for use.</p> | | | |

Notes:

- (1) The IPE did not document the human error probability. Recirculation is actuated automatically. The operator has to manually close the RWSP discharge valves.

Table 2.6 SDP Worksheet for Waterford 3 Nuclear Plant

LOOP

| | | | |
|---|--|--|------------------------------|
| Estimated Frequency (Table 1 Row) _____ Exposure Time _____ Table 1 Result (circle): A B C D E F G H | | | |
| Safety Functions Needed: Emergency Diesel Generator (EDG) Turbine-driven EFW pump (TDEFW) Emergency Feedwater (EFW) Recovery of AC Power in < 1 hrs (REC1) Recovery of AC Power in < 6 hrs (REC6) | | <u>Full Creditable Mitigation Capability for Each Safety Function:</u> 1 / 2 Emergency Diesel Generators (1 multi-train system) 1 / 1 TDP trains of EFW (1 ASD train) 1 / 2 MDEFW trains (1 multi-train system) or 1 TDEFW train (1 ASD train) (operator action under high stress) ⁽¹⁾ (operator action) ⁽²⁾ | |
| <u>Circle Affected Functions</u> | <u>Recovery of Failed Train</u> | <u>Remaining Mitigation Capability Rating for Each Affected Sequence</u> | <u>Sequence Color</u> |
| 1 LOOP - EFW (2,6) | | | |
| 2 LOOP - EAC - REC6 (4) | | | |
| 3 LOOP - EAC - TDEFW - REC1(7) | | | |

Identify any operator recovery actions that are credited to directly restore the degraded equipment or initiating event:

If operator actions are required to credit placing mitigation equipment in service or for recovery actions, such credit should be given only if the following criteria are met: 1) sufficient time is available to implement these actions, 2) environmental conditions allow access where needed, 3) procedures exist, 4) training is conducted on the existing procedures under conditions similar to the scenario assumed, and 5) any equipment needed to complete these actions is available and ready for use.

Notes:

- (1) The IPE uses a probability of 0.286 for failure to recover in 50 minutes. (Event Z-LOOP-R0 on page 3.7-20)
- (2) The IPE uses a probability of 0.186 for failure to recover in 6 hours. (Event Z-LOOP6)

Table 2.7 SDP Worksheet for Waterford 3 SGTR

| | | | |
|---|--|---|------------------------------|
| Estimated Frequency (Table 1 Row) _____ Exposure Time _____ Table 1 Result (circle): A B C D E F G H | | | |
| Safety Functions Needed: Pressure Equalization (EQ) Power Conversion System (PCS) Emergency Feedwater System (EFW) RCS Inventory Makeup(RCSMU) | | <u>Full Creditable Mitigation Capability for Each Safety Function:</u> Operator isolates the ruptured SG and depressurizes RCS using 1 / 1 ADV or 1/6 SBVs and RCS pressurizer spray or blowdown the ruptured SG to less than setpoint of relief valves (high stress operator action) ⁽¹⁾ 1 / 2 Main Feedwater trains with 1 / 3 condensate trains or 1/1 AFW to the unaffected SG pump (operator action) ⁽²⁾ 1 / 2 MDPs of EFW (1 multi-train system) or 1 / 1 TDP of EFW (1 ASD Train) to the unaffected SG 1 / 3 high head injection pumps (1 multi-train system) or 2/3 charging pumps (1 multi-train system) | |
| <u>Circle Affected Functions</u> | <u>Recovery of Failed Train</u> | <u>Remaining Mitigation Capability Rating for Each Affected Sequence</u> | <u>Sequence Color</u> |
| 1 SGTR - EQ (6) | | | |
| 2 SGTR - RCSMU (2,4) | | | |
| 3 SGTR - PCS -EFW (5) | | | |

Identify any operator recovery actions that are credited to directly restore the degraded equipment or initiating event:

If operator actions are required to credit placing mitigation equipment in service or for recovery actions, such credit should be given only if the following criteria are met: 1) sufficient time is available to implement these actions, 2) environmental conditions allow access where needed, 3) procedures exist, 4) training is conducted on the existing procedures under conditions similar to the scenario assumed, and 5) any equipment needed to complete these actions is available and ready for use.

Notes:

- (1) The IPE did not document the human error probability.
- (2) The IPE did not document the human error probability. Recirculation is actuated automatically. The operator has to manually close the RWSP discharge valves.

Table 2.8 SDP Worksheet for Waterford 3 Nuclear Plant ATWS

| | | | |
|--|--|---|------------------------------|
| Estimated Frequency (Table 1 Row) _____ Exposure Time _____ Table 1 Result (circle): A B C D E F G H | | | |
| Safety Functions Needed: Turbine Trip (TTP) Emergency Feedwater (EFW) Primary Safety Valves Open (SRVO) Emergency Boration (EB) Primary Safety Valves Reclose (SRVR) High Head Safety Injection (HPSI) High Pressure Recirculation (HPR) Containment Heat Removal (CHR) | | Full Creditable Mitigation Capability for Each Safety Function: Manually trip the turbine (operator action) 1 / 2 MDEFW trains (1 multi-train system) or 1 TDEFW train (1 ASD train) 2/2 SVs open (1 train) Operator conducts emergency boration using 1 / 3 charging pumps from RWSP or BAST (operator action) ⁽¹⁾ 2/2 SRVs reclose 1/3 high pressure injection pumps inject to 2 intact cold legs from refueling water storage pool (RWSP) (1 multi-train system) 1/3 HPSI pumps in recirculation mode (operator action) ⁽²⁾ 1/4 trains of fan coolers (multi-train systems) or 1 /2 trains of containment spray injection and recirculation (multi-train systems) | |
| <u>Circle Affected Functions</u> | <u>Recovery of Failed Train</u> | <u>Remaining Mitigation Capability Rating for Each Affected Sequence</u> | <u>Sequence Color</u> |
| 1 ATWS - TTP (9) | | | |
| 2 ATWS - EFW (8) | | | |

| | | | |
|---|--|--|--|
| 3 ATWS - SRVO (7) | | | |
| 4 ATWS - RC (6) | | | |
| 5 ATWS - SRVR - HPSI (5) | | | |
| 6 ATWS - SRVR - HPR (4) | | | |
| 7 ATWS - SRVR - CHR (3) | | | |
| <p>Identify any operator recovery actions that are credited to directly restore the degraded equipment or initiating event:</p> <p>If operator actions are required to credit placing mitigation equipment in service or for recovery actions, such credit should be given only if the following criteria are met: 1) sufficient time is available to implement these actions, 2) environmental conditions allow access where needed, 3) procedures exist, 4) training is conducted on the existing procedures under conditions similar to the scenario assumed, and 5) any equipment needed to complete these actions is available and ready for use.</p> | | | |

Notes:

- (1) The IPE did not document the human error probability.
- (2) The IPE did not document the human error probability. Recirculation is actuated automatically. The operator has to manually close the RWSP discharge valves.

Table 2.9 SDP Worksheet for Farley Nuclear Plant

Special Initiators

| | | | |
|---|---------------------------------|--|-----------------------|
| Estimated Frequency (Table 1 Row) _____ Exposure Time _____ Table 1 Result (circle): A B C D E F G H | | | |
| Safety Functions Needed: Interfacing System LOCAs | | Full Creditable Mitigation Capability for Each Safety Function: none | |
| Circle Affected Functions | Recovery of Failed Train | Remaining Mitigation Capability Rating for Each Affected Sequence | Sequence Color |
| Initiator: Internal failure of the RHR suction valves ⁽¹⁾ | | | |
| Identify any operator recovery actions that are credited to directly restore the degraded equipment or initiating event: | | | |
| If operator actions are required to credit placing mitigation equipment in service or for recovery actions, such credit should be given only if the following criteria are met: 1) sufficient time is available to implement these actions, 2) environmental conditions allow access where needed, 3) procedures exist, 4) training is conducted on the existing procedures under conditions similar to the scenario assumed, and 5) any equipment needed to complete these actions is available and ready for use. | | | |

Notes:


(1) The frequency of interfacing LOCA is 4.86E-7 per year. It is assumed to lead to core damage.

1.3 SDP Event Trees

This section provides the simplified event trees called SDP event trees used to define the accident sequences identified in the SDP worksheets in the previous section. An event tree for the stuck-open PORV is not included since it is similar to the small LOCA event tree. The event tree headings are defined in the corresponding SDP worksheets.

The following event trees are included:

1. Transients
2. Small LOCA
3. Medium LOCA
4. Large LOCA
5. LOOP
6. Steam Generator Tube Rupture (SGTR)
7. Anticipated Transients Without Scram (ATWS)

| | TRANS | PCS | EFW | # | STATUS |
|---|-------|-----|-----|---|--------|
|  <p data-bbox="772 1203 1262 1243">Plant abbrev.: WTRF</p> | | | | | |

| SLOCA | HPSI | MFW | EFW | HPR | CHR | # | STATUS |
|-------|------|-----|-----|-----|-----|---|--------|
| | | | | | | 1 | OK |
| | | | | | | 2 | CD |
| | | | | | | 3 | CD |
| | | | | | | 4 | OK |
| | | | | | | 5 | CD |
| | | | | | | 6 | CD |
| | | | | | | 7 | CD |
| | | | | | | 8 | CD |

Plant abbrev.: WTRF

| SOSV | BLK | HPSI | MFW | EFW | HPR | CHR | # | STATUS |
|------|-----|------|-----|-----|-----|-----|---|--------|
| | | | | | | | 1 | OK |
| | | | | | | | 2 | OK |
| | | | | | | | 3 | CD |
| | | | | | | | 4 | CD |
| | | | | | | | 5 | OK |
| | | | | | | | 6 | CD |
| | | | | | | | 7 | CD |
| | | | | | | | 8 | CD |
| | | | | | | | 9 | CD |

Plant abbrev.: WTRF

| | MLOCA | HPSI | HPR | CHR | # | STATUS |
|---------------------|-------|------|-----|-----|---|--------|
| | | | | | 1 | OK |
| | | | | | 2 | CD |
| | | | | | 3 | CD |
| | | | | | 4 | CD |
| Plant abbrev.: WTRF | | | | | | |

| | LLOCA | SIT | HPSI | LPSI | HPR | CHR | # | STATUS |
|--|-------|-----|------|------|-----|-----|---|--------|
| | | | | | | | 1 | OK |
| | | | | | | | 2 | CD |
| | | | | | | | 3 | CD |
| | | | | | | | 4 | CD |
| | | | | | | | 5 | CD |
| | | | | | | | 6 | CD |

Plant abbrev.: W TRF

| | LOOP | EDG | TDEFW | REC1 | EFW | REC6 | # | STATUS |
|--|------|-----|-------|------|-----|------|---|--------|
| | | | | | | | 1 | OK |
| | | | | | | | 2 | CD |
| | | | | | | | 3 | OK |
| | | | | | | | 4 | CD |
| | | | | | | | 5 | OK |
| | | | | | | | 6 | CD |
| | | | | | | | 7 | CD |

Plant abbrev.: WTRF

| SGTR | EQ | PCS | EFW | RCSMN | # | STATUS |
|------|----|-----|-----|-------|---|--------|
| | | | | | 1 | OK |
| | | | | | 2 | CD |
| | | | | | 3 | OK |
| | | | | | 4 | CD |
| | | | | | 5 | CD |
| | | | | | 6 | CD |

Plant abbrev.: WTRF

| ATWS | TTP | EFW | SRVO | EB | SRVR | HPSI | HPR | CHR | # | STATUS |
|------|-----|-----|------|----|------|------|-----|-----|---|--------|
| | | | | | | | | | 1 | OK |
| | | | | | | | | | 2 | OK |
| | | | | | | | | | 3 | CD |
| | | | | | | | | | 4 | CD |
| | | | | | | | | | 5 | CD |
| | | | | | | | | | 6 | CD |
| | | | | | | | | | 7 | CD |
| | | | | | | | | | 8 | CD |
| | | | | | | | | | 9 | CD |

Plant abbrev.: WTRF

2. RESOLUTION AND DISPOSITION OF COMMENTS

This section documents the comments received on the material included in this report and their resolution. This section is blank until comments are received and are addressed.

REFERENCES

1. NRC SECY-99-007A, Recommendations for Reactor Oversight Process Improvements (Follow-up to SECY-99-007), March 22, 1999.
2. Waterford Steam Electric Station, Unit 3, IPE submittal,