

February 8, 2000

Mr. Charles M. Dugger
Vice President Operations
Entergy Operations, Inc.
P. O. Box B
Killona, LA 70066

SUBJECT: COMPLETION OF LICENSING ACTION FOR GENERIC LETTER 98-04, "POTENTIAL FOR DEGRADATION OF THE EMERGENCY CORE COOLING SYSTEM AND THE CONTAINMENT SPRAY SYSTEM AFTER A LOSS-OF-COOLANT ACCIDENT BECAUSE OF CONSTRUCTION AND PROTECTIVE COATING DEFICIENCIES AND FOREIGN MATERIAL IN CONTAINMENT," DATED JULY 14, 1998; WATERFORD STEAM ELECTRIC STATION, UNIT 3 (TAC NO. MA4116)

Dear Mr. Dugger:

On July 14, 1998, the U.S. Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 98-04, "Potential for Degradation of the Emergency Core Cooling System and the Containment Spray System after a Loss-of-Coolant Accident Because of Construction and Protective Coating Deficiencies and Foreign Material in Containment," to all holders of operating licenses or construction permits. The NRC issued GL 98-04 to determine the status of containment coating programs.

In GL 98-04, the NRC staff specifically requested that the licensees provide information outlined below for each of their facilities.

- (1) A summary description of the plant-specific program or programs implemented to ensure that Service Level 1 protective coatings used inside the containment are procured, applied, and maintained in compliance with applicable regulatory requirements and the plant-specific licensing basis for the facility. Include a discussion of how the plant-specific program meets the applicable criteria of 10 CFR Part 50, Appendix B, as well as information regarding any applicable standards, plant-specific procedures, or other guidance used for (a) controlling the procurement of coatings and paints used at the facility; (b) the qualification testing of protective coatings; and (c) surface preparation, application, surveillance, and maintenance activities for protective coatings. Maintenance activities refer to rework of degraded coatings, removing degraded coatings to sound coatings, correctly preparing the surfaces, applying new coating, and verifying the quality of coatings.

- (2) Information demonstrating compliance with item (i) or item (ii).
- (i) For plants with licensing-basis requirements for tracking the amount of unqualified coatings inside the containment and for assessing the impact of potential coating debris on the operation of safety-related systems, structures, and components (SSCs) during a postulated design basis loss-of-coolant accident (DB LOCA), the following information shall be provided to demonstrate compliance:
 - (a) The date and findings of the last assessment of coatings and the planned date of the next assessment of coatings.
 - (b) The limit for the amount of unqualified protective coatings allowed in the containment and how this limit is determined. Discuss any conservatism in the method used to determine this limit.
 - (c) If a commercial-grade dedication program is being used at your facility for dedicating commercial-grade coatings for Service Level 1 applications inside the containment, discuss how the program adequately qualifies a coating for Service Level 1. Identify what standards or other guidance are currently being used to dedicate containment coatings at your facility.
 - (ii) For plants without the above licensing-basis requirements, information shall be provided to demonstrate compliance with the requirements of 10 CFR 50.46(b)(5), "Long-term cooling" and the functional capability of the safety-related containment spray system (CSS) as set forth in your licensing basis. If a licensee can demonstrate this compliance without quantifying the amount of unqualified coatings, this is acceptable. The following information shall be provided:
 - If a commercial-grade dedication program is not being used at your facility for qualifying and dedicating commercial-grade coatings for Service Level 1 applications, provide the regulatory and safety basis for not controlling these coatings in accordance with such a program. Additionally, explain why the facility's licensing basis does not require such a program.

In response to GL 98-04, you provided a letter dated November 11, 1998, for Waterford Steam Electric Station, Unit 3. This submittal provided the information requested by GL 98-04. Clarification was provided during a phone call that took place on December 10, 1999, confirmed by the email sent by Mr. R. Williams of your staff. The NRC staff has reviewed your response and has concluded that all requested information has been provided; therefore, we consider GL 98-04 to be closed for your facility. We thank you for your prompt and complete response.

February 8, 2000

If you have any questions regarding this matter, please contact N. Kalyanam at (301) 415-1480.

Sincerely,

/RA/

N. Kalyanam, Project Manager, Section 1
Project Directorate IV & Decommissioning
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-382

cc: See next page

February 8, 2000

If you have any questions regarding this matter, please contact N. Kalyanam at (301) 415-1480.

Sincerely,

/RA/

N. Kalyanam, Project Manager, Section 1
Project Directorate IV & Decommissioning
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-382

cc: See next page

DISTRIBUTION:

File Center	PUBLIC	PDIV-1 Reading	JKilcrease,RIV
OGC	LHurley,RIV	ACRS	RPulsifer
JDavis	CLauron		

DOCUMENT NAME: C:\MA4116-GL98-04 closeout.wpd

INDICATE IN BOX: "C"=COPY W/O ATTACHMENT/ENCLOSURE, "E"=COPY W/ATT/ENCL, "N"=NO COPY

OFFICE	PM:PDIV-1	C	LA:PDIV-1	N	SC: EMCB		SC	C
NAME	NKalyanam		DJohnson		ESullivan		RGramm	
DATE	02/04/00		02/04/00		02/04/00		02/08/00	

OFFICIAL RECORD COPY

Waterford Generating Station 3

cc:

Administrator
Louisiana Department of Environmental Quality
P. O. Box 82215
Baton Rouge, LA 70884-2215

Vice President, Operations Support
Entergy Operations, Inc.
P. O. Box 31995
Jackson, MS 39286

Director, Nuclear Safety & Regulatory Affairs
Entergy Operations, Inc.
17265 River Road
Killona, LA 70066-0751

Wise, Carter, Child & Caraway
P. O. Box 651
Jackson, MS 39205

General Manager Plant Operations
Waterford 3 SES
Entergy Operations, Inc.
17265 River Road
Killona, LA 70066-0751

Licensing Manager
Entergy Operations, Inc.
17265 River Road
Killona, LA 70066-0751

Winston & Strawn
1400 L Street, N.W.
Washington, DC 20005-3502

Resident Inspector/Waterford NPS
P. O. Box 822
Killona, LA 70066-0751

Regional Administrator, Region IV
U. S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76011

Parish President Council
St. Charles Parish
P. O. Box 302
Hahnville, LA 70057

Executive VP & Chief Operating Officer
Entergy Operations, Inc.
P. O. Box 31995
Jackson, MS 39286-1995

Chairman
Louisiana Public Services Commission
Baton Rouge, LA 70825-1697