

February 9, 2000

Mr. Charles H. Cruse  
Vice President - Nuclear Energy  
Baltimore Gas and Electric Company  
Calvert Cliffs Nuclear Power Plant  
1650 Calvert Cliffs Parkway  
Lusby, MD 20657

SUBJECT: COMPLETION OF LICENSING ACTION FOR GENERIC LETTER 99-02,  
"LABORATORY TESTING OF NUCLEAR-GRADE ACTIVATED CHARCOAL" -  
CALVERT CLIFFS NUCLEAR POWER PLANT, UNIT NOS. 1 AND 2 (TAC NOS.  
MA5774 AND MA5775)

Dear Mr. Cruse:

On June 3, 1999, the U.S. Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 99-02, "Laboratory Testing of Nuclear-grade Activated Charcoal," to all holders of operating licenses for nuclear power reactors, except those who have permanently ceased operations and have certified that fuel has been permanently removed from the reactor vessel.

The purpose of the GL was to:

- (1) Alert addressees that the NRC has determined that testing nuclear-grade activated charcoal to standards other than American Society for Testing and Materials (ASTM) D3803-1989, "Standard Test Method for Nuclear-Grade Activated Carbon," does not provide assurance for complying with the current licensing basis as it relates to the dose limits of General Design Criterion (GDC) 19 of Appendix A to Part 50 of Title 10 of the *Code of Federal Regulations* (10 CFR) and Subpart A of 10 CFR Part 100.
- (2) Request that all addressees determine whether their Technical Specifications (TS) reference ASTM D3803-1989 for charcoal filter laboratory testing. Addressees whose TS do not reference ASTM D3803-1989 should either amend their TS to reference ASTM D3803-1989 or propose an alternative test protocol and provide the information discussed in the requested actions.
- (3) Alert addressees to the staff's intent to exercise enforcement discretion under certain conditions.
- (4) Request that all addressees send the NRC written responses on the implementation of the actions requested in this GL.

In GL 99-02, the NRC staff established the following four groups of plants:

- (1) plants in compliance with their TS that test in accordance with ASTM D3803-1989

- (2) plants in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989
- (3) plants not in compliance with their TS that test in accordance with ASTM D3803-1989
- (4) plants not in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989

In response to GL 99-02, you provided a letter dated November 22, 1999, as supplemented November 24, 1999, for Calvert Cliffs Nuclear Power Plant, Unit Nos. 1 and 2. Associated with your response was a request for a license amendment to change your TS to provide for testing as described in the GL. The NRC staff has reviewed your response and has concluded that you have provided requested information and a TS change request in accordance with the GL. In addition, you have committed to test in accordance with ASTM D3803-1989 until your TS amendment is issued. Therefore, we consider GL 99-02 to be closed for your facilities. The TS change will be reviewed as a separate, plant-specific action under TAC NOS. MA7222 and MA7223. We thank you for your prompt and complete response.

If you have any questions regarding this matter, please contact me at 301-415-3473.

Sincerely,

***/RA/***

Alexander W. Dromerick, Sr. Project Manager, Section 1  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-317 and 50-318

cc: See next page

- (2) plants in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989
- (3) plants not in compliance with their TS that test in accordance with ASTM D3803-1989
- (4) plants not in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989

In response to GL 99-02, you provided a letter dated November 22, 1999, as supplemented November 24, 1999, for Calvert Cliffs Nuclear Power Plant, Unit Nos. 1 and 2. Associated with your response was a request for a license amendment to change your TS to provide for testing as described in the GL. The NRC staff has reviewed your response and has concluded that you have provided requested information and a TS change request in accordance with the GL. In addition, you have committed to test in accordance with ASTM D3803-1989 until your TS amendment is issued. Therefore, we consider GL 99-02 to be closed for your facilities. The TS change will be reviewed as a separate, plant-specific action under TAC NOS. MA7222 and MA7223. We thank you for your prompt and complete response.

If you have any questions regarding this matter, please contact me at 301-415-3473.

Sincerely,

***/RA/***

Alexander W. Dromerick, Sr. Project Manager, Section 1  
 Project Directorate I  
 Division of Licensing Project Management  
 Office of Nuclear Reactor Regulation

Docket Nos. 50-317 and 50-318

cc: See next page

**DISTRIBUTION:**

- File Center
- PUBLIC
- PDI-1 R/F
- EAdemsam (E-mail)
- MGamberoni (A)
- ADromerick
- BMozafari
- JSegala
- JHannon
- OGC
- ACRS
- MOprendek, RGN-I

**TO RECEIVE A COPY, WRITE A "C" IN THE BOX.**

DOCUMENT NAME: G:\PDI-1\CC1-2\CLOA5774.WPD

OFFICE	PDI-1/PM		PDI-1/LA		LPM		SC: SPLB		PDI-1/SC(A)	
NAME	ADromerick:lcc		SLittle		BMozafari		E. Weiss		MGamberoni	
DATE	1 / 27 /00		1 / 27 /00		1/27 /00		2 / 8 /00		2 / 8 /00	

Calvert Cliffs Nuclear Power Plant,  
Unit Nos. 1 and 2

cc:

President  
Calvert County Board of  
Commissioners  
175 Main Street  
Prince Frederick, MD 20678

James P. Bennett, Esquire  
Counsel  
Baltimore Gas and Electric Company  
P.O. Box 1475  
Baltimore, MD 21203

Jay E. Silberg, Esquire  
Shaw, Pittman, Potts, and Trowbridge  
2300 N Street, NW  
Washington, DC 20037

Mr. Bruce S. Montgomery, Director  
NRM  
Calvert Cliffs Nuclear Power Plant  
1650 Calvert Cliffs Parkway  
Lusby, MD 20657-4702

Resident Inspector  
U.S. Nuclear Regulatory  
Commission  
P.O. Box 287  
St. Leonard, MD 20685

Mr. Richard I. McLean, Manager  
Nuclear Programs  
Power Plant Research Program  
Maryland Dept. of Natural Resources  
Tawes State Office Building, B3  
Annapolis, MD 21401

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Mr. Joseph H. Walter, Chief Engineer  
Public Service Commission of  
Maryland  
Engineering Division  
6 St. Paul Centre  
Baltimore, MD 21202-6806

Kristen A. Burger, Esquire  
Maryland People's Counsel  
6 St. Paul Centre  
Suite 2102  
Baltimore, MD 21202-1631

Patricia T. Birnie, Esquire  
Co-Director  
Maryland Safe Energy Coalition  
P.O. Box 33111  
Baltimore, MD 21218

Mr. Loren F. Donatell  
NRC Technical Training Center  
5700 Brainerd Road  
Chattanooga, TN 37411-4017