



GPU Nuclear, Inc.  
U.S. Route #9 South  
Post Office Box 388  
Forked River, NJ 08731-0388  
Tel 609-971-4000

January 21, 2000  
1940-00-20029

U.S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D.C. 20555

Dear Sir:

Subject: Oyster Creek Nuclear Generating Station  
Docket No. 50-219  
Emergency Plan Implementing Procedure Revisions

In accordance with 10 CFR 50, Appendix E, Section V, enclosed is the newly revised Index for the Oyster Creek Emergency Plan Implementing Procedures and the below listed procedure.

<u>Procedure Number</u>	<u>Title</u>	<u>Revision</u>
EPIP-OC-.03	Emergency Notification	24

If further information is required, please contact Mr. George Busch, Manager Nuclear Safety and Licensing at 609-971-4643.

Very truly yours,

Sander Levin  
Acting Site Director

MBR\GWB:gl

Enclosures

cc: Administrator, Region I  
NRC Project Manager  
NRC Resident Inspector

A045

**EPIP SERIES - EMERGENCY PLAN IMPLEMENTING PROCEDURES**

<b><u>PROCEDURE NO.</u></b>	<b><u>TITLE</u></b>	<b><u>REV. NO.</u></b>	<b><u>DATE</u></b>
EPIP-OC-.01	Classification of Emergency Conditions	6	06/03/99
EPIP-OC-.02	Direction of Emergency Response/Emergency Control Center	24	11/11/99
EPIP-OC-.03	Emergency Notification	24	01/22/00
EPIP-OC-.06	Additional Assistance and Notification	21	09/03/99
EPIP-OC-.10	Emergency Radiological Surveys Onsite	9	01/06/00
EPIP-OC-.11	Emergency Radiological Surveys Offsite	14	01/06/00
EPIP-OC-.12	Personnel Accountability	7	02/21/99
EPIP-OC-.13	Site Evacuation and Personnel Mustering at Remote Assembly Areas	6	11/10/97
EPIP-OC-.25	Emergency Operations Facility (EOF)	21	07/01/99
EPIP-OC-.26	The Technical Support Center	20	11/14/99
EPIP-OC-.27	The Operations Support Center	8	11/11/99
EPIP-OC-.31	Environmental Assessment Command Center	10	03/08/98
EPIP-OC-.33	Core Damage Estimation	4	12/03/99
EPIP-OC-.35	Radiological Controls Emergency Actions	13	07/11/99
EPIP-OC-.40	Site Security Emergency Actions	9	10/04/99
EPIP-OC-.41	Emergency Duty Roster Activation	4	06/21/97
EPIP-OC-.44	Thyroid Blocking	0	03/11/99
EPIP-OC-.45	Classified Emergency Termination/Recovery	0	02/21/99
OEP-ADM-1311.03	Emergency Preparedness Section Administration	3	08/28/99
OEP-ADM-1319.01	Oyster Creek Emergency Preparedness Program	6	05/15/99
OEP-ADM-1319.02	Emergency Response Facilities & Equipment Maintenance	6	09/03/99
OEP-ADM-1319.04	Prompt Notification System	1	05/02/97
OEP-ADM-1319.05	Oyster Creek Emergency Preparedness Program	0	02/20/99



OYSTER CREEK EMERGENCY PLAN  
IMPLEMENTING PROCEDURE

Number  
EPIP-OC-.03

Title Emergency Notification	Revision No. 24
Applicability/Scope Applies to Oyster Creek Division & Support Divisions	Responsible Office Emergency Prep.
This document is within QA plan scope <u>X</u> Yes ___ No Safety Reviews Required <u>X</u> Yes ___ No	Effective Date (01/12/00) 01/22/00

Prior Revision 23 incorporated the following Temporary Changes:

N/A

This Revision 24 incorporates the following Temporary Changes:

N/A

List of Pages (all pages rev'd to Rev. 24)

1.0 to 7.0  
E1-1 to E1-5  
E2-1 to E2-2

NON-CONTROLLED  
This Document Will Not  
Be Kept Up To Date  
DCC Oyster Creek

	Signature	Concurring Organization Element	Date
Originator		Emergency Planner	1/6/00
Concurred By		Director, OC	1-7-00
Approved By		Emergency Preparedness Mgr, OC	1/10/00

Title  
Emergency NotificationRevision No.  
24PROCEDURE HISTORY

Revision	Date	Originator	Summary of Change
11	06/07/94	A. Smith	Update NRC telephone numbers and add Document History page.
12	05/94	A. Smith	Remove requirement for SS checklist to be transmitted to BNE at end of UE. Modify off-site notification forms to align with states, clarify NRC notification following state and local notifications. Add BNE phone #, Block and route to SAE and GE Forms.
13		A. Smith	Change beeper number for L. Briggs NRC
14		A. Smith	Remove INPO & ANI notifications from EXHIBIT 1B. Communications now taking that over.
15	06/95	A. Smith	Update phone numbers and add new notes to Exhibit 4, NRC Status Board data, to clarify this exhibit only used when ERDS is down.
16	12/95	T. Blount	Correct ED information, modify Notification Matrix, capture cont. inj. person notification requirements, remove North Gate as point of egress.
17	01/96	T. Blount	Pager changes requires changing phone numbers.
18	07/96	P. Hays	Prevent confusion as to whether a form is related to a drill event or a real event.
19	10/96	T. Blount	Allow use of other forms for documentation of Notification process. Incorporate follow-up notifications.
20	06/97	T. Blount	Delete AEOF consistent w/E-Plan Rev. 11, Add Sample forms to use. Remove/change NRC resident information. Remove reference to PTFC. Also, delete Exhibit 4 NRC Status Board Data and clean up signature blocks.
21	10/97	A. Smith	Delete reference to EPIP-.04. Correct nomenclature on ERF telephone circuits correct typo on E3-2 "T" to "U".
22	09/98	P. Hays	Clarify offsite notification forms by removing the notification matrix and related exhibits and keeping the new NCR triplicate form. Update the Plant Condition Follow-up Form.
23	05/99	A. Smith	Clarify off-site notification transfer between the ECC and EOF.
24	01/00	A. Smith	Clarify emergency notification sequence to on-site and off-site agencies.



Title  
Emergency Notification

Revision No.  
24

1.0 PURPOSE

- 1.1 This procedure provides the mechanism for emergency notifications to be made to on-site personnel and off-site agencies (as required in the Emergency Plan) in an accurate and timely manner.
- 1.2 This procedure shall be initiated by the Emergency Director and implemented by the ECC and EOF Communications Coordinator.
  - 1.2.1 A communicator designated by the Emergency Director will initially implement this procedure until relieved by the on-call ECC or EOF Communications Coordinator.

2.0 APPLICABILITY/SCOPE

- 2.1 This procedure applies to those persons making notifications and/or providing information to on-site personnel or off-site agencies during a declared or simulated emergency.
- 2.2 This procedure applies to the 10CFR50.72 requirement for immediate notification of any declared emergency class. All other notifications shall be made in accordance with the applicable station procedure.

3.0 DEFINITIONS

None

4.0 RESPONSIBILITIES

- 4.1 The GSS/Emergency Director shall:
  - 4.1.1 Designate a communicator to implement this procedure until properly relieved by the on-call ECC or EOF Communications Coordinator.
  - 4.1.2 Direct all off-site notifications made in accordance with this procedure until the ESD has activated the EOF and assumed the off-site notifications. The EOF Communicator will notify the ECC of the transfer.
  - 4.1.3 Direct Control Room Staff to make appropriate on-site announcements.

Title  
Emergency NotificationRevision No.  
24

- 4.2 The On-Shift ECC Communications Coordinator (designated CRO) shall:
- 4.2.1 Complete Off-Site Notifications Checklist (Exhibit 1A) until relieved of this duty by the on call ECC or EOF Communications Coordinator.
- 4.2.2 Complete On-Site Notifications Checklist (Exhibit 1A).
- 4.3 The On-Call ECC Communications Coordinator shall relieve the On-Shift ECC Communicator and complete Off-Site Notification Checklist (Exhibit 1A) until directed to transfer the offsite notifications to the EOF Communications Coordinator.

NOTE

When offsite notifications are transferred to the EOF, the EOF Communication Coordinator shall be notified via telephone of the transfer and inform the communicator that a fax of all completed offsite notifications from the ECC will follow.

5.0 PROCEDURE

- 5.1 Emergency Notifications should be performed using forms similar to Exhibit 1A to document off-site and on-site notifications.
- 5.1.1 Page announcements and notifications should be made in the following order:
1. Plant Page (on-site copy)
  2. OEM State Police (off-site copy)
  3. Only at GE, Lacey Twp., Ocean Twp., and Ocean County (off-site copy)
  4. NRC (off-site copy)
  5. Other On-site Notifications (on-site copy)
- 5.1.2 Exhibit 1B (or similar form) is used to document the communication of a follow-up Protective Action Recommendation (PAR) or a change in plant conditions that is not associated with an escalation of the declaration.
- 5.1.3 Exhibit 2 should be used to document plant operating conditions. Other forms or methods are permitted so long as the pertinent information is provided (e.g. Major Transients, ECCS Status, Rad Monitoring).



Title  
Emergency Notification

Revision No.  
24

5.1.4 Emergency notifications to on-site personnel will be accomplished by using the Plant Paging System.

5.2 Emergency notifications to the New Jersey State Police will be accomplished within 15 minutes of the declaration of any emergency classification.

5.2.1 If a General Emergency has been declared, Ocean County, Lacey and Ocean Townships will also be notified within 15 minutes.

5.2.2 Notifications to the New Jersey State Police and Ocean County will be verified by a return call from each organization. This verification call must be answered to ensure validity of incident. If the verification has not been received within 5 minutes of the notification call then contact the agency via the notification line to request a verification call.

5.3 Emergency notifications to the Nuclear Regulatory Commission (NRC) will be made as soon as possible after making the state and local notifications but within 1 hour of the declaration of any emergency classification. NRC may request continuous manning of this line. Only one (1) Emergency Center at one time should provide this continuous communication link.

5.3.1 The NRC should be notified of the "Protective Action" implemented by the State of New Jersey. This info should be verified through the NJSP-OEM by the ED/ESD. Use Ex. 1C - Protective Action Notification (to NRC) form or similar form to document transmittal.

Title  
Emergency NotificationRevision No.  
24

- 5.4 The Station Status Checklist will be completed and updated every 30 minutes or as changes occur for transmittal to the N.J. Bureau of Nuclear Engineering (BNE) when requested. Only initial, and any significant changes require a SSC to be sent when in a UE level of emergency. After BNE is established at the EOF, no further transmittal of the SSC is required. Refer to Station Status Checklist (Exhibit 2).
- 5.5 If Communication equipment problems or failures arise, attempt to utilize alternate means and contact the TSC to initiate repairs.
- 5.6 If additional notification phone numbers are needed, refer to Procedure EPIP-OC-.06, "Additional Assistance and Notifications".
- 5.7 The "Simulator Communications Interface" switch on the operators communication console shall be left in the OFF position unless the GSS has authorized placing the switch in ON. The switch should be placed in ON only for Emergency Preparedness Drills, training evolutions and communication system testing and then returned to OFF when completed.

NOTE

When both the Simulator Communications Interface switch in the Control Room and the same switch in the Simulator Control Room are in the ON position the following communications are affected:

- Phone systems transferred to the Simulator completely:
  - NRC ENS
  - NJSP notification & verification
  - Ocean County notification & verification
  - All ERF Circuits
  - 693-8728 Plant Status Update Line Alt. (Fax)
  - 971-4959
  - 971-0220
  - 971-4550
  - BNE Info Line
  - ECC/EACC Direct Line
  - ED/ESD Hotline
  - NJ State ED Hotline
- Plant page and Radio capability are provided to the Simulator Control Room without affecting onsite systems.





Title  
Emergency Notification

Revision No.  
24

6.0 REFERENCES

- 6.1 Title 10, Code of Federal Regulations, Part 50.72 "Immediate Notification requirements for Operating Nuclear Power Reactors".
- 6.2 Procedure EPIP-OC.06 "Additional Assistance and Notifications".
- 6.3 Procedure 8000-IMP-1720.01, Emergency Public Information Implementing Procedure.

7.0 EXHIBITS

- 7.1 Exhibit 1A Notification Checklist
- 7.2 Exhibit 1B PAR/Plant Conditions Follow-up
- 7.3 Exhibit 1C Protective Action Notification to NRC
- 7.4 Exhibit 2 Station Status Checklist



Title  
Emergency Notification

Revision No.  
24

EXHIBIT 1A

SAMPLE - NOTIFICATION FORM



EMERGENCY REPORT FORM - OC  
(Press Firmly and Write Clearly)

Part 1 of 3  
ED-Copy

This is a Drill. This is a Drill.  This is NOT a Drill. This is NOT a Drill.

EMERGENCY CLASSIFICATION

An/a \_\_\_\_\_ was declared at \_\_\_\_\_ on \_\_\_\_\_ The EAL is \_\_\_\_\_  
Event Declared 24 Hour Clock Date  
 The Event has been de-escalated to an/a \_\_\_\_\_ at \_\_\_\_\_ on \_\_\_\_\_ The EAL is \_\_\_\_\_  
Event Declared 24 Hour Clock Date  
 The Event has been terminated at \_\_\_\_\_ on \_\_\_\_\_  
24 Hour Clock Date

EVENT DESCRIPTION

RADIOACTIVE RELEASE STATUS

There is no abnormal radioactive release in progress.  
 There is an abnormal \_\_\_\_\_ radioactive release in progress. (i.e. exceeds ODCM Limits)  
airborne and/or liquid

METEOROLOGICAL CONDITION

Wind direction is from \_\_\_\_\_ degrees and wind speed is \_\_\_\_\_ miles per hour. Use 380' Elev For wind direction and speed

OFF-SITE PROTECTIVE ACTION RECOMMENDATION (Only at GE)

PAR will be given at a later time.  
 We recommend **EVACUATION** for the general population living with 2 miles of the plant  
and Compass Sectors \_\_\_\_\_, \_\_\_\_\_, and \_\_\_\_\_ out to a distance of \_\_\_\_\_ miles.  
 We recommend **SHELTERING** for the general population living with 2 miles of the plant  
and Compass Sectors \_\_\_\_\_, \_\_\_\_\_, and \_\_\_\_\_ out to a distance of \_\_\_\_\_ miles.  
 Other - Describe: \_\_\_\_\_  
 We also recommend **SHELTERING** for the general population living within all other areas of the EPZ.

ON-SITE PROTECTIVE ACTION

(UE) All personnel should continue with their normal duties pending further notice.  
 (ALERT/SAE/GE) All on-duty members of the Emergency Response Organization report to emergency centers.  
 (ALERT only) All other personnel should continue with their normal duties pending further instruction.  
 (ALERT/SAE/GE) Eating, Drinking and Smoking is prohibited until further notice.  
 (SAE only) **Site Accountability** has been ordered. All non-essential personnel in the protected area report to  
the Emergency Assembly Area in the (select one)  OCAB Cafeteria or  Warehouse. Route (if needed) \_\_\_\_\_  
 (GE only) **Site Evacuation** has been ordered. All non-essential personnel, who do not have a specific emergency  
assignment shall leave the site through the Main Gate Processing Center. Use the \_\_\_\_\_ (SOUTH/NORTH)  
evacuation route.  
Route to Main Gate (if needed) \_\_\_\_\_

NOTES ONLY

DO NOT WRITE IN THIS SPACE

- In the special case of a security event which does not upgrade current classification, ensure the NRC is notified of the event and status of plant security VIA the ENS line.
- If an environmental injured person must be transported off-site, ensure appropriate notifications are complete.
- If a contaminated injured person must be transported off-site, ensure appropriate notifications are complete.
- The Station Status Checklist should be completed and communicated to the NJBNE once per half-hour or as conditions change. Only initial and any significant changes require SSC to be sent when in a UE level of emergency. After confirmation that the BNE is established at the EOF the SSC is no longer required to be transmitted.
- At a GE level of emergency provide PAR to NJSP. If the NJSP EOC is not staffed, provide PAR to Ocean County, Lacey Township and Ocean Township. If the BNE is staffed at the EOF provide the initial PAR in writing to BNE first, and then only notify the NJSP.
- Ensure the organizations contacted as listed on the notification forms are notified of termination.

APPROVAL

Signature \_\_\_\_\_ 24 Hour Clock \_\_\_\_\_ Date \_\_\_\_\_ Communicator Signature \_\_\_\_\_ 24 Hour Clock \_\_\_\_\_ Date \_\_\_\_\_



OYSTER CREEK EMERGENCY PLAN  
IMPLEMENTING PROCEDURE

Number  
EPIP-OC-.03

Title  
Emergency Notification

Revision No.  
24

EXHIBIT 1A

SAMPLE - NOTIFICATION FORM (Cont'd)



EMERGENCY REPORT FORM - OC  
(Press Firmly and Write Clearly)

Part 2 of 3  
On-Site Copy

Start here for notification or contact. Read Message - Slowly - Clearly  
Attention all personnel. Attention all personnel.  
Sound Station Alarm for 10 seconds.

This is a Drill. This is a Drill.  This is NOT a Drill. This is NOT a Drill.

EMERGENCY CLASSIFICATION

An/a \_\_\_\_\_ was declared at \_\_\_\_\_ on \_\_\_\_\_ The EAL is \_\_\_\_\_  
Event Declared 24 Hour Clock Date  
 The Event has been de-escalated to an/a \_\_\_\_\_ at \_\_\_\_\_ on \_\_\_\_\_ The EAL is \_\_\_\_\_  
Event Declared 24 Hour Clock Date  
 The Event has been terminated at \_\_\_\_\_ on \_\_\_\_\_  
24 Hour Clock Date

EVENT DESCRIPTION

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

RADIOACTIVE RELEASE STATUS

There is no abnormal radioactive release in progress.  
 There is an abnormal \_\_\_\_\_ radioactive release in progress. (i.e. exceeds ODCM Limits)  
airborne and/or liquid

ON-SITE PROTECTIVE ACTION

(UE) All personnel should continue with their normal duties pending further notice.  
 (ALERT/SAE/GE) All on-duty members of the Emergency Response Organization report to emergency centers.  
 (ALERT only) All other personnel should continue with their normal duties pending further instruction.  
 (ALERT/SAE/GE Eating, Drinking and Smoking is prohibited until further notice.  
 (SAE only) Site Accountability has been ordered. All non-essential personnel in the protected area report to the Emergency Assembly Area in the (select one)  OCAB Cafeteria or  Warehouse. Route (if needed) \_\_\_\_\_  
 (GE only) Site Evacuation has been ordered. All non-essential personnel, who do not have a specific emergency assignment shall leave the site through the Main Gate Processing Center. Use the \_\_\_\_\_ (SOUTH/NORTH) evacuation route.  
Route to Main Gate (if needed) \_\_\_\_\_

TIME	INITIALS	TITLE and/or NAME to be Notified	OFFICE	HOME	BEEPER
_____	_____	On-shift - Shift Technical Advisor			
_____	_____	On-call Emergency Director (Unusual Event Only)			
		Team 1 - P. Scallon	4625		609-660-3472
		Team 2 - K. Mulligan	4119		609-660-3420
		Team 3 - W. Stewart	4775		609-660-3463
_____	_____	Senior RadCon Representative	4660/2599		
_____	_____	Communications Dept. Representative	4020		
_____	_____	Emergency Preparedness Manager/Alternate	4188/2411		609-660-3470 609-660-3372
_____	_____	Resident NRC Inspectors	4978		
		Sr. Resident			1-800-398-6650
		Resident			1-800-398-7497

APPROVAL

Signature \_\_\_\_\_ 24 Hour Clock \_\_\_\_\_ Date \_\_\_\_\_ Communicator Signature \_\_\_\_\_ 24 Hour Clock \_\_\_\_\_ Date \_\_\_\_\_



OYSTER CREEK EMERGENCY PLAN  
IMPLEMENTING PROCEDURE

Number  
EPIP-OC-.03

Title  
Emergency Notification

Revision No.  
24

EXHIBIT 1A

SAMPLE - NOTIFICATION FORM (Cont'd)



EMERGENCY REPORT FORM - OC  
(Press Firmly and Write Clearly)

Part 3 of 3  
Off-Site Copy

Start Here for notification or contact. Read Message - Slowly - Clearly  
 This is a Drill. This is a Drill.  This is NOT a Drill. This is NOT a Drill.  
This is \_\_\_\_\_ at Oyster Creek Nuclear Generating Station (select one)  CR  TSC  EOF  
Communicator's Name \_\_\_\_\_

EMERGENCY CLASSIFICATION

- An/a \_\_\_\_\_ was declared at \_\_\_\_\_ on \_\_\_\_\_ Date The EAL is \_\_\_\_\_  
Event Declared \_\_\_\_\_ 24 Hour Clock \_\_\_\_\_ Date
- The Event has been de-escalated to an/a \_\_\_\_\_ at \_\_\_\_\_ on \_\_\_\_\_ Date The EAL is \_\_\_\_\_  
Event Declared \_\_\_\_\_ 24 Hour Clock \_\_\_\_\_ Date
- The Event has been terminated at \_\_\_\_\_ on \_\_\_\_\_ Date  
24 Hour Clock \_\_\_\_\_ Date

EVENT DESCRIPTION

\_\_\_\_\_

RADIOACTIVE RELEASE STATUS

- There is no abnormal radioactive release in progress.
- There is an abnormal \_\_\_\_\_ radioactive release in progress. (i.e. exceeds ODCM Limits)  
airborne and/or liquid

METEOROLOGICAL CONDITION

Wind direction is from \_\_\_\_\_ degrees and wind speed is \_\_\_\_\_ miles per hour. Use 380' Elev For wind direction and speed

OFF-SITE PROTECTIVE ACTION RECOMMENDATION (Only at GE)

- PAR will be given at a later time.
- We recommend **EVACUATION** for the general population living with 2 miles of the plant  
and Compass Sectors \_\_\_\_\_, \_\_\_\_\_, and \_\_\_\_\_ out to a distance of \_\_\_\_\_ miles.
- We recommend **SHELTERING** for the general population living with 2 miles of the plant  
and Compass Sectors \_\_\_\_\_, \_\_\_\_\_, and \_\_\_\_\_ out to a distance of \_\_\_\_\_ miles.
- Other - Describe: \_\_\_\_\_
- We also recommend **SHELTERING** for the general population living within all other areas of the EPZ.

OFF-SITE NOTIFICATION RECORD

- NJ State Police** (within 15 minutes of all declarations) via State Notification Line or Alternate 609-882-2000  
Time of initial contact \_\_\_\_\_ Person Contacted \_\_\_\_\_  
Time of verification \_\_\_\_\_ Person Calling \_\_\_\_\_

\*\*\*\*\*  
NOTE: Verifications should be within 5 minutes of initial contact.

- Ocean County** (at GE only) (within 15 minutes of declaration of General Emergency) via Dedicated Line or Alter. 732-349-9100  
Time of Contact \_\_\_\_\_ Person Contacted \_\_\_\_\_  
Time of Verification \_\_\_\_\_ Person Calling \_\_\_\_\_

- Lacey Township** (at GE only) (within 15 minutes of declaration of General Emergency) via 609-693-6636 or Alter. 609-639-6637  
Time of Contact \_\_\_\_\_ Person Contacted \_\_\_\_\_

- Ocean Township** (at GE only) (within 15 minutes of General Emergency) via 609-693-4007 or Alter. 609-693-4008  
Time of Contact \_\_\_\_\_ Person Contacted \_\_\_\_\_

- NRC** (immediately following State and Local Notifications) via ENS Line or Alter. 301-816-5100 or 301-951-0550  
Time of Contact \_\_\_\_\_ Person Contacted \_\_\_\_\_

- ERDS** initiated at \_\_\_\_\_ (within 1 hour of a declaration of an ALERT or higher)

- On-call **BNE** Information (Contact NJSP if BNE has not called within 30 minutes of initial NJSP Notification  
Name \_\_\_\_\_ Voice Phone # \_\_\_\_\_ FAX # \_\_\_\_\_

APPROVAL

Signature _____	24 Hour Clock _____	Date _____	Communicator Signature _____	24 Hour Clock _____	Date _____
-----------------	---------------------	------------	------------------------------	---------------------	------------



OYSTER CREEK EMERGENCY PLAN  
IMPLEMENTING PROCEDURE

Number  
EPIP-OC-.03

Title  
Emergency Notification

Revision No.  
24

EXHIBIT 1B



PAR/PLANT CONDITIONS FOLLOW-UP

This is a Drill. This is a Drill.  This is NOT a Drill. This is NOT a Drill.  
This is \_\_\_\_\_ at Oyster Creek Nuclear Generating Station.  
Name/Title \_\_\_\_\_

I am notifying you of an INITIAL/UPGRADED protective action recommendation.  
Circle One

We recommend **EVACUATION** for the general population living within 2 miles of the plant and compass sectors  
\_\_\_\_, \_\_\_\_, and \_\_\_\_ out to a distance of \_\_\_\_ miles.

We recommend **SHELTERING** for the general population living within all other areas of the EPZ.

Other \_\_\_\_\_  
\_\_\_\_\_

The following plant/events conditions have changed: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**OFF-SITE NOTIFICATION RECORD**

**NJ State Police** (within 15 minutes of all declarations) via State Notification Line or Alternate 609-882-2000  
Time of initial contact \_\_\_\_\_ Person Contacted \_\_\_\_\_  
Time of verification \_\_\_\_\_ Person Calling \_\_\_\_\_

\*\*\*\*\*  
**NOTE: Verifications should be within 5 minutes of initial contact.**

**Ocean County** (at GE only) (within 15 minutes of declaration of General Emergency) via Dedicated Line or Alter. 732-349-9100  
Time of Contact \_\_\_\_\_ Person Contacted \_\_\_\_\_  
Time of Verification \_\_\_\_\_ Person Calling \_\_\_\_\_

**NOTE: Verifications should be within 5 minutes of initial contact.**

**Lacey Township** (at GE only) (within 15 minutes of declaration of General Emergency) via 609-693-6636 or Alter. 609-639-6637  
Time of Contact \_\_\_\_\_ Person Contacted \_\_\_\_\_

**Ocean Township** (at GE only) (within 15 minutes of General Emergency) via 609-693-4007 or Alter. 609-693-4008  
Time of Contact \_\_\_\_\_ Person Contacted \_\_\_\_\_

\*\*\*\*\*  
 **NRC** (immediately following State and Local Notifications) via ENS Line or Alter. 301-816-5100 or 301-951-0550  
Time of Contact \_\_\_\_\_ Person Contacted \_\_\_\_\_

\*\*\*\*\*  
 **ERDS** initiated at \_\_\_\_\_ (within 1 hour of a declaration of an ALERT or higher)

\*\*\*\*\*  
 On-call **BNE** Information (Contact NJSP if BNE has not called within 30 minutes of initial NJSP Notification  
Name \_\_\_\_\_ Voice Phone # \_\_\_\_\_ FAX # \_\_\_\_\_

**APPROVAL**

Signature \_\_\_\_\_ 24 Hour Clock \_\_\_\_\_ Date \_\_\_\_\_ Communicator Signature \_\_\_\_\_ 24 Hour Clock \_\_\_\_\_ Date \_\_\_\_\_



Title  
Emergency Notification

Revision No.  
24

EXHIBIT 1C

PROTECTIVE ACTION NOTIFICATION (to NRC)  
AS IMPLEMENTED BY THE STATE OF NEW JERSEY

"THIS IS NOT A DRILL - I REPEAT, THIS IS NOT A DRILL"

-OR-

"THIS IS A DRILL - THIS IS A DRILL"

"This is \_\_\_\_\_ at Oyster Creek Nuclear Generating Station.  
(Name/Title)

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

\_\_\_\_\_  
ED/ESD Approve/Time

"Please State Your Name"

NRC (ENS Phone)

MAID (301) 816-5100  
BACKUP (301) 951-0550

\_\_\_\_\_  
Name of NRC Representative/Time Call Initiated

Notification Complete: \_\_\_\_\_  
Communicator Signature/Name/Title

ED Asst/ESD Asst Review: \_\_\_\_\_  
Signature/Title



Title  
Emergency Notification

Revision No.  
24

EXHIBIT 2

STATION STATUS CHECKLIST  
(page 1 of 2)

EXAMPLE

"THIS IS NOT A DRILL - I REPEAT, THIS IS NOT A DRILL"  
- OR -  
"THIS IS A DRILL - THIS IS A DRILL"

1. Message Date: \_\_\_\_\_ Time: \_\_\_\_\_ Transmitted by: \_\_\_\_\_  
Name/Title or Position
2. Emergency Unusual Event Site Area Emergency  
Classification: Alert General Emergency  
at Date: \_\_\_\_\_ Time: \_\_\_\_\_
3. EAL Number: \_\_\_\_\_ Description of Emergency: \_\_\_\_\_  
(EPIP-OC-.01 Appendix 1.)  
\_\_\_\_\_  
\_\_\_\_\_
4. Reactor Status: Scrammed @ \_\_\_\_\_ (Time) At Power \_\_\_\_\_ %  
Hot Shutdown Cold Shutdown
5. Reactor Pressure: \_\_\_\_\_ PSIG Recirc Loop Temp: \_\_\_\_\_ °F  
Reactor Water Level: \_\_\_\_\_ "TAF
6. Off-site Power available? Yes No
7. EDG 1 operable? Yes No On Line? Yes No  
EDG 2 operable? Yes No On Line? Yes No
8. Did Isolation Condenser(s) initiate? Yes No  
Did Core Spray(s) inject? Yes No  
Did ADS actuate? Yes No
9. Primary Containment operable? Yes No Isolated? Yes No  
Secondary Containment operable? Yes No Isolated? Yes No  
(Reactor Building)
10. Other Pertinent Information: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

"THIS IS NOT A DRILL - I REPEAT, THIS IS NOT A DRILL"  
- OR -  
"THIS IS A DRILL - THIS IS A DRILL"



Title  
Emergency Notification

Revision No.  
24

EXHIBIT 2

STATION STATUS CHECKLIST  
(page 2 of 2)

**EXAMPLE**

"THIS IS NOT A DRILL - I REPEAT, THIS IS NOT A DRILL"  
- OR -  
"THIS IS A DRILL - THIS IS A DRILL"

RADIOLOGICAL INFORMATION Message Date \_\_\_\_\_ Time \_\_\_\_\_  
(Obtain Rad information from RAC or Group Leader R & EC)

11. **Gaseous Release:** YES Start Time \_\_\_\_\_, Terminated YES Time \_\_\_\_\_  
NO NO  
Anticipated or Known Duration \_\_\_\_\_ Hrs.

Type of Release: Ground Elevated  
Wind Speed \_\_\_\_\_ (mph) Wind Direction From \_\_\_\_\_ (deg)  
Stability Class A B C D E F G  
Iodine (DEI) Release Rate: \_\_\_\_\_  $\mu$ Ci/s  
Noble Gas Release Rate: \_\_\_\_\_  $\mu$ Ci/s

12. **Projected Off-Site Dose Rate Calculations** (As Soon As Data is Available)  
Distance (miles) Total Whole Body Adult Thyroid Dose  
Dose Rate (TEDE) Rate (CDE) Commitment  
SB .25 \_\_\_\_\_ mrem/hr \_\_\_\_\_ mrem/hr  
2 \_\_\_\_\_ mrem/hr \_\_\_\_\_ mrem/hr  
5 \_\_\_\_\_ mrem/hr \_\_\_\_\_ mrem/hr  
10 \_\_\_\_\_ mrem/hr \_\_\_\_\_ mrem/hr  
(Millirem Per Inhalation Hour)

13. **Liquid Release:** YES Start Time \_\_\_\_\_, Terminated YES Time \_\_\_\_\_  
NO NO  
Anticipated or Known Duration \_\_\_\_\_ Hrs  
Estimated Concentration \_\_\_\_\_  $\mu$ Ci/ml  
Release Flow Rate \_\_\_\_\_ Gallons/min

14. Other Information: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Approved \_\_\_\_\_ (Licensed Operator or STA)

"THIS IS NOT A DRILL - I REPEAT, THIS IS NOT A DRILL"  
- OR -  
"THIS IS A DRILL - THIS IS A DRILL"