February 14, 2000

Mr. Eliot Protsch President IES Utilities Inc. 200 First Street, SE P.O. Box 351 Cedar Rapids, IA 52406-0351

SUBJECT: COMPLETION OF LICENSING ACTION FOR GENERIC LETTER 99-02, "LABORATORY TESTING OF NUCLEAR-GRADE ACTIVATED CHARCOAL" -

DUANE ARNOLD ENERGY CENTER, (TAC NO. MA5790)

Dear Mr. Protsch:

On June 3, 1999, the U.S. Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 99-02, "Laboratory Testing of Nuclear-grade Activated Charcoal," to all holders of operating licenses for nuclear power reactors, except those who have permanently ceased operations and have certified that fuel has been permanently removed from the reactor vessel.

The purpose of the GL was to:

- (1) Alert addressees that the NRC has determined that testing nuclear-grade activated charcoal to standards other than American Society for Testing and Materials (ASTM) D3803-1989, "Standard Test Method for Nuclear-Grade Activated Carbon," does not provide assurance for complying with the current licensing basis as it relates to the dose limits of General Design Criterion (GDC) 19 of Appendix A to Part 50 of Title 10 of the Code of Federal Regulations (10 CFR) and Subpart A of 10 CFR Part 100.
- (2) Request that all addressees determine whether their Technical Specifications (TS) reference ASTM D3803-1989 for charcoal filter laboratory testing. Addressees whose TS do not reference ASTM D3803-1989 should either amend their TS to reference ASTM D3803-1989, or propose an alternative test protocol and provide the information discussed in the requested actions.
- (3) Alert addressees to the staff's intent to exercise enforcement discretion under certain conditions.
- (4) Request that all addressees send the NRC written responses on the implementation of the actions requested in this GL.

In GL 99-02, the NRC staff established the following four groups of plants:

(1) plants in compliance with their TS that test in accordance with ASTM D3803-1989

E. Protsch - 2 -

- (2) plants in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989
- (3) plants not in compliance with their TS that test in accordance with ASTM D3803-1989
- (4) plants not in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989

In response to GL 99-02, you provided a letter dated November 10, 1999, for the Duane Arnold Energy Center. Associated with your response was a request for a license amendment to change your TS to provide for testing as described in the GL. The NRC staff has reviewed your response and has concluded that you have provided requested information and a TS change request in accordance with the GL. In addition, you have committed to test in accordance with ASTM D3803-1989 until your TS amendment is issued. Therefore, we consider GL 99-02 to be closed for your facility. The TS change will be reviewed as a separate, plant-specific action under TAC No. MA7269. We thank you for your prompt and complete response.

If you have any questions regarding this matter, please contact Brenda Mozafari at (301) 415-2020.

Sincerely,

/RA/

Brenda L. Mozafari, Project Manager, Section 1 Project Directorate III Division of Licensing Project Management Office of Nuclear Reactor Regulation

Docket No. 50-331

cc: See next page

- (2) plants in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989
- (3) plants not in compliance with their TS that test in accordance with ASTM D3803-1989
- (4) plants not in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989

In response to GL 99-02, you provided a letter dated November 10, 1999, for the Duane Arnold Energy Center. Associated with your response was a request for a license amendment to change your TS to provide for testing as described in the GL. The NRC staff has reviewed your response and has concluded that you have provided requested information and a TS change request in accordance with the GL. In addition, you have committed to test in accordance with ASTM D3803-1989 until your TS amendment is issued. Therefore, we consider GL 99-02 to be closed for your facility. The TS change will be reviewed as a separate, plant-specific action under TAC No. MA7269. We thank you for your prompt and complete response.

If you have any questions regarding this matter, please contact Brenda Mozafari at (301) 415-2020.

Sincerely,

/RA/

Brenda L. Mozafari, Project Manager, Section 1 Project Directorate III Division of Licensing Project Management Office of Nuclear Reactor Regulation

Docket No. 50-331

cc: See next page

DISTRIBUTION:

File Center OGC JSegala
PUBLIC ACRS JHannon
PDIII-1 Reading BMozafari GGrant, RIII

C:\MA5790LTR.wpd

TO RECEIVE A COPY OF THIS DOCUMENT, WRITE A "C" IN THE BOX *See Drevious concurrence

OFFICE	PDIII-1/PM	С	SPLB/SC*	PDIII-1/LA	С	PDIII-1/SC	
NAME	BMozafari		EWeiss	THarris		CCraig	
DATE	2/9/00		2/8/00	2/9/00		2/9/00	

OFFICIAL RECORD COPY

Duane Arnold Energy Center

cc:

Al Gutterman Morgan, Lewis, & Bockius LLP 1800 M Street, N. W. Washington, DC 20036-5869

Chairman, Linn County Board of Supervisors Cedar Rapids, IA 52406

IES Utilities Inc. ATTN: Richard L. Anderson Plant Manager, Nuclear 3277 DAEC Road Palo, IA 52324

David L. Wilson Vice President, Nuclear Duane Arnold Energy Center 3277 DAEC Road Palo, IA 52324

Ken Peveler Manager, Nuclear Licensing Duane Arnold Energy Center 3277 DAEC Road Palo, IA 52324

U.S. Nuclear Regulatory Commission Resident Inspector's Office Rural Route #1 Palo, IA 52324

Regional Administrator U.S. NRC, Region III 801 Warrenville Road Lisle, IL 60532-4531

Daniel McGhee Utilities Division Iowa Department of Commerce Lucas Office Building, 5th floor Des Moines, IA 50319