

February 15, 2000

Mr. Oliver D. Kingsley, President
Nuclear Generation Group
Commonwealth Edison Company
Executive Towers West III
1400 Opus Place, Suite 500
Downers Grove, IL 60515

SUBJECT: LASALLE - REQUEST FOR ADDITIONAL INFORMATION (TAC NOS. MA6070
AND MA6071)

Dear Mr. Kingsley:

By letter dated July 14, 1999, Commonwealth Edison Company (ComEd, the licensee) submitted a proposed license amendment for LaSalle County Station, Units 1 and 2, to allow the units to operate at an uprated power level of 3489 MWt. We have reviewed your request and determined that we need additional information to complete our review. The enclosed questions were discussed with your staff during a conference call on January 21, 2000. It was agreed that a response would be provided within 30 days of the date of this letter.

If there should be any questions regarding this request, please contact me at (301) 415-1322.

Sincerely,

/RA/

Donna M. Skay, Project Manager, Section 2
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-373 and 50-374

Enclosure: Request for Additional Information

cc: See next page

February 15, 2000

Mr. Oliver D. Kingsley, President
Nuclear Generation Group
Commonwealth Edison Company
Executive Towers West III
1400 Opus Place, Suite 500
Downers Grove, IL 60515

SUBJECT: LASALLE - REQUEST FOR ADDITIONAL INFORMATION (TAC NOS. MA6070 AND MA6071)

Dear Mr. Kingsley:

By letter dated July 14, 1999, Commonwealth Edison Company (ComEd, the licensee) submitted a proposed license amendment for LaSalle County Station, Units 1 and 2, to allow the units to operate at an uprated power level of 3489 MWt. We have reviewed your request and determined that we need additional information to complete our review. The enclosed questions were discussed with your staff during a conference call on January 21, 2000. It was agreed that a response would be provided within 30 days of the date of this letter.

If there should be any questions regarding this request, please contact me at (301) 415-1322.

Sincerely,

/RA/

Donna M. Skay, Project Manager, Section 2
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-373 and 50-374

Enclosure: Request for Additional Information

cc: See next page

DISTRIBUTION:

File Center	PUBLIC	PD3 r/f	SBlack
LBerry	OGC	ACRS	MLeach, RIII

*see previous page for concurrence

DOCUMENT NAME: C:\MA6070-scsb.wpd

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

OFFICE	PM:LPD3	LA:LPD3	SPLB	SC:LPD3
NAME	DSKAY	CMOORE	*RPGoel for GHubbard	AMENDIOLA
DATE	02/10/00	02/10/00	01/ 14 /00	02/11/00

OFFICIAL RECORD COPY

O. Kingsley
Commonwealth Edison Company

LaSalle County Station
Units 1 and 2

cc:

Phillip P. Steptoe, Esquire
Sidley and Austin
One First National Plaza
Chicago, Illinois 60603

Robert Cushing, Chief, Public Utilities Division
Illinois Attorney General's Office
100 W. Randolph Street
Chicago, Illinois 60601

Assistant Attorney General
100 W. Randolph St. Suite 12
Chicago, Illinois 60601

Document Control Desk-Licensing
Commonwealth Edison Company
1400 Opus Place, Suite 400
Downers Grove, Illinois 60515

U.S. NRC-LaSalle Resident Inspectors Office
2605 N. 21st Road
Marseilles, Illinois 61341-9756

Commonwealth Edison Company
Site Vice President - LaSalle
2601 N. 21st Road
Marseilles, Illinois 61341-9757

Chairman
LaSalle County Board
707 Etna Road
Ottawa, Illinois 61350

Mr. David Helwig
Senior Vice President
Commonwealth Edison Company
Executive Towers West III
1400 Opus Place, Suite 900
Downers Grove, Illinois 60515

Attorney General
500 S. Second Street
Springfield, Illinois 62701

Chairman
Illinois Commerce Commission
527 E. Capitol Avenue, Leland Building
Springfield, Illinois 62706

Mr. Gene H. Stanley
Vice President - Nuclear Operations
Commonwealth Edison Company
Executive Towers West III
1400 Opus Place, Suite 900
Downers Grove, Illinois 60515

Illinois Department of Nuclear Safety
Office of Nuclear Facility Safety
1035 Outer Park Drive
Springfield, Illinois 62704

Mr. Christopher Crane
Senior VP - Nuclear Operations
Commonwealth Edison Company
Executive Towers West III
1400 Opus Place, Suite 900
Downers Grove, Illinois 60515

Regional Administrator
U.S. NRC, Region III
801 Warrenville Road
Lisle, Illinois 60532-4351

Commonwealth Edison Company
LaSalle Station Manager
2601 N. 21st Road
Marseilles, Illinois 61341-9757

O. Kingsley
Commonwealth Edison Company

- 2 -

LaSalle County Station
Units 1 and 2

Mr. R. M. Krich
Vice President - Regulatory Services
Commonwealth Edison Company
Executive Towers West III
1400 Opus Place, Suite 500
Downers Grove, Illinois 60515

Commonwealth Edison Company
Reg. Assurance Supervisor - LaSalle
2601 N. 21st Road
Marseilles, Illinois 61341-9757

Ms. Pamela B. Stroebel
Senior Vice President and General Counsel
Commonwealth Edison Company
P.O. Box 767
Chicago, Illinois 60690-0767

REQUEST FOR ADDITIONAL INFORMATION

LASALLE COUNTY STATION, UNITS 1 AND 2

The following questions refer to Attachment E of your submittal dated July 14, 1999, GE Report NEDC-32701P, "Power Uprate Safety Analysis Report for LaSalle County Station, Units 1 and 2."

1. Section 4.1.1.1 for Local Pool Temperature with SRV Discharge, indicates that LaSalle T-Quenchers are at a submersion of 24 feet and provide 20 degrees Fahrenheit subcooling with a bulk temperature of 208 degrees Fahrenheit and the wetwell at atmospheric pressure. Is there any scenario under EOP heat capacity temperature limit curve in which 20 degrees Fahrenheit subcooling may not be maintained?
2. Section 4.1.1.1 for Steam Bypass Case states that an analysis was performed to bound 102 percent of uprated power to ensure that there is sufficient time for corrective operator action. Please quantify the available time for corrective operator action.
3. Section 4.1.1.3 for Short-Term Pressure Response states that the peak calculated drywell-to-wetwell pressure difference is less than or equal to design value using M3CPT code which is overly conservative and that a new analysis is being performed to account for air space compressibility to recapture margin with respect to the design value. Please provide a description of the new analysis and the factors which make M3CPT overly conservative.
4. Please provide the Containment Maximum Pressure and Temperature analyses curves at uprated power.

ENCLOSURE