

February 15, 2000

Mr. J. V. Parrish  
Chief Executive Officer  
Energy Northwest  
P.O. Box 968 (Mail Drop 1023)  
Richland, WA 99352-0968

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION (RAI) FOR WNP-2 (TAC NO.  
MA6165)

Dear Mr. Parrish:

By letter dated July 29, 1999, Energy Northwest submitted for NRC staff review, an amendment request to revise License Condition 2.C.(16) of Facility Operating License No. NPF-21. As a result of the review, the NRC staff has determined that additional information is needed to complete the review. The information needed is detailed in the enclosure.

The enclosed request was discussed with Mr. Inserra of your staff on February 1, 2000. A mutually agreeable target date of March 15, 2000, was established for responding to the RAI. If circumstances result in the need to revise the target date, please call me at your earliest opportunity at (301) 415-1424.

Sincerely,

*/RA/*

Jack Cushing, Project Manager, Section 2  
Project Directorate IV & Decommissioning  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-397

Enclosure: Request for Additional Information

cc w/encl: See next page

February 15, 2000

Mr. J. V. Parrish  
Chief Executive Officer  
Energy Northwest  
P.O. Box 968 (Mail Drop 1023)  
Richland, WA 99352-0968

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION (RAI) FOR WNP-2 (TAC NO. MA6165)

Dear Mr. Parrish:

By letter dated July 29, 1999, Energy Northwest submitted for NRC staff review, an amendment request to revise License Condition 2.C.(16) of Facility Operating License No. NPF-21. As a result of the review, the NRC staff has determined that additional information is needed to complete the review. The information needed is detailed in the enclosure.

The enclosed request was discussed with Mr. Inserra of your staff on February 1, 2000. A mutually agreeable target date of March 15, 2000, was established for responding to the RAI. If circumstances result in the need to revise the target date, please call me at your earliest opportunity at (301) 415-1424.

Sincerely,

*/RAI/*

Jack Cushing, Project Manager, Section 2  
Project Directorate IV & Decommissioning  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-397

Enclosure: Request for Additional Information

cc w/encl: See next page

DISTRIBUTION:

File Center  
PUBLIC  
PDIV-2 Reading  
SBlack  
SRichards (clo)  
LBerry  
OGC  
ACRS  
LSmith, Region IV

To receive a copy of this document, indicate "C" in the box					
OFFICE	PDIV-2/PM	C	PDIV-2/LA	C	PDIV-2/SC
NAME	JCushing:lcc		EPeyton		SDembek
DATE	02/14/00		02/14/00		02/14/00

DOCUMENT NAME: C:\RAIA6165.wpd

OFFICIAL RECORD COPY

WNP-2

cc:

Mr. Greg O. Smith (Mail Drop 927M)  
Vice President, Generation  
Energy Northwest  
P. O. Box 968  
Richland, Washington 99352-0968

Mr. Rodney L. Webring (Mail Drop PE08)  
Vice President, Operations Support/PIO  
Energy Northwest  
P. O. Box 968  
Richland, Washington 99352-0968

Mr. Albert E. Mouncer (Mail Drop 1396)  
Chief Counsel  
Energy Northwest  
P.O. Box 968  
Richland, Washington 99352-0968

Thomas C. Poindexter, Esq.  
Winston & Strawn  
1400 L Street, N.W.  
Washington, DC 20005-3502

Ms. Deborah J. Ross, Chairman  
Energy Facility Site Evaluation Council  
P. O. Box 43172  
Olympia, Washington 98504-3172

Mr. Bob Nichols  
Executive Policy Division  
Office of the Governor  
P.O. Box 43113  
Olympia, Washington 98504-3113

Mr. D. W. Coleman (Mail Drop PE20)  
Manager, Regulatory Affairs  
Energy Northwest  
P.O. Box 968  
Richland, Washington 99352-0968

Mr. Paul Inserra (Mail Drop PE20)  
Manager, Licensing  
Energy Northwest  
P.O. Box 968  
Richland, Washington 99352-0968

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
Harris Tower & Pavilion  
611 Ryan Plaza Drive, Suite 400  
Arlington, Texas 76011-8064

Chairman  
Benton County Board of Commissioners  
P.O. Box 69  
Prosser, Washington 99350-0190

Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
P.O. Box 69  
Richland, Washington 99352-0069

REQUEST FOR ADDITIONAL INFORMATION

POST ACCIDENT NEUTRON FLUX MONITORING LICENSE CONDITION 2.C(16)

WNP-2

DOCKET NO. 50-397

1. In Section 2.2, Accuracy: NEDO Section 5.2.2, of your July 29, 1999, submittal, you state that due to inaccuracies in the detectors, amplifiers and recorders, the APRMs would slightly exceed the accuracy requirement of  $\pm 2$  percent of rated thermal power. Please provide additional clarification of the APRM accuracy and justification if the criterion cannot be met.
2. In Section 2.8, Power Sources: NEDO Section 5.2.8, you stated that the APRMs will lose power on a loss of offsite power until power is restored by division 1 and 2 diesel generators and the motor generator breakers are manually reset. The NEDO criterion is for an uninterruptable and reliable power source. Please provide additional justification for not meeting this criterion.

Enclosure