

ENERGY NORTHWEST

INTEROFFICE MEMORANDUM

DATE: February 7, 2000

TO: Distribution

Alicia Meyer

FROM: Procedure Control, Administrative Services, WNP-2 (927A)

SUBJECT: WNP-2 PLANT PROCEDURES MANUAL - VOLUME 13
PACKAGE NO. 00-58

REFERENCE:

The following Procedure(s) have been revised/approved and are to be inserted in your controlled copy of the Manual and the superseded revisions are to be removed and destroyed:

<u>Procedure</u>	<u>Rev.</u>
13.9.1	22
13.9.5	13
13.10.16	2

Also included in this package are EDITORIAL CHANGES, please replace the pages located in your manual with the attached pages:

13.1.1A 13.5.1

To verify receipt or cancellation of the subject Procedure(s), please sign, date and return this receipt to Procedure Control, MD 927A within TEN (10) WORKING DAYS of the date of this IOM.

_____ 87 _____
Date Signature of Manual Holder Controlled Copy Number

af
Attachments:

Return Receipt to:

Energy Northwest
Procedure Control (Mail Drop 927A)
PO Box 968
Richland, WA 99352

AD45

DISTRIBUTION - VOLUME 13

<u>Control Copy</u>	<u>Location</u>	<u>Mail Drop</u>
2	*Control Room (IOM to CRS)	927A
3	*Shift Manager	927A
5	Licensed Training	1027
6	*Simulator	1027
12	PEC Library	PEC
25	Project Manager, Raytheon	964D
26	Region IV, NRC	---
28	Region IV, NRC	---
30	EOF Support Engineering Library	1050
31	*TSC Emergency Response	927A
35	NRC Resident Inspector	---
42	Maintenance Training	184
52	State of Washington, Military Department	---
55	Federal Emergency Mgmt. Agency	---
57	Benton County Dept of Emerg. Mgmt.	---
58	*WNP-2 Security (SAS-CR) (13.1.1, 13.4.1, 13.5.1, 13.5.3, 13.5.5, 13.10.8, 13.11.10, 13.12.19, 13.13.4)	927A
59	*WNP-2 Security (CAS-AAP) (13.1.1, 13.4.1, 13.5.1, 13.5.3, 13.5.5, 13.10.8, 13.11.10, 13.12.19, 13.13.4)	927A
60	WNP-2 Security	956
63	Emergency Training	PE30
64	*Radwaste Control Room	927A
66	*Simulator, Shift Manager	1027
68	*Remote Shutdown Room (13.1.1, 13.2.1, 13.2.2, 13.4.1, 13.5.1, 13.10.1, 13.10.9)	927A
75	Dept. of Health Radiation Protection	---
78	*Control Room - STA's Desk	927A
83	*MUDAC	1020
86	*Simulator - STA's Desk	1034
87	Document Control Desk, NRC	---
+ +90	*Joint Information Center	PE30
94	*EOF	1020
97	*EOF	1020
114	EP Manager	PE30
127-130 (4)	Licensed Training	1027
132	Licensed Training	1027
134-136 (3)	*MUDAC Field Team Kits (13.9.1, 13.9.5, 13.9.8, 13.13.4, 13.14.4)	1020
+ +137	*MPF Field Team Kits (13.7.5, 13.9.1, 13.9.5, 13.9.8, 13.13.4, 13.14.4)	PE30
142	Hanford UDAC	---
146	FEMA RX Liaison	---
155	*Maintenance Library (Memo to Georgia)	927A
160	*OSC Emergency Support	927A
161	Equipment Operator Training	1027
164	Oregon State Dept. of Energy	---
218	U.S. Nuclear Regulatory Commission	---
219-221 (3)	Licensed Training	1027
223	Franklin County Emergency Management	---

+ + Procedure Control assures delivery is arranged/made to J. Ittner

* Level 1 File

DATE: 02/07/00

EDITORIAL

13.1.1A

ENERGY NORTHWEST		USE CURRENT REVISION
WNP-2 PLANT PROCEDURES MANUAL		
PROCEDURE NUMBER	APPROVED BY	DATE
*13.1.1A	DWC - Revision 4	09/14/99
VOLUME NAME		
EMERGENCY PLAN IMPLEMENTING PROCEDURES		
SECTION		
EMERGENCY CLASSIFICATION		
TITLE		
CLASSIFYING THE EMERGENCY - TECHNICAL BASES		

TABLE OF CONTENTS

	Page
1.0 PURPOSE	2
2.0 REFERENCES	2
3.0 PROCEDURE	4
3.1 Plant Emergency Response Personnel Responsibilities	4
3.2 Use Of Plant Instruments And Indications	4
3.3 Emergency Class Description	4
3.4 Mode Applicability	5
4.0 ATTACHMENTS	5
4.1 EAL Technical Bases	5
4.2 Fission Product Barrier Degradation Table Bases	5

PROCEDURE NUMBER	REVISION	PAGE
13.1.1A	4	1 of 159

Entry into the unsafe region of the Pressure Suppression Pressure curve (PPM 5.2.1, "Primary Containment Control", Figure F, PSP) is included as a potential primary containment barrier loss. A rapid depressurization of the RPV (e.g., occurrence of a large break LOCA or initiation of ADS) at wetwell pressures in excess of the PSP may cause either:

- Wetwell pressure responses indicative of failure in the drywell-to-wetwell boundary, or
- Wetwell pressure increases to or beyond the Primary Containment Pressure Limit (PPM 5.2.1, "Primary Containment Control", Figure B, PCPL).

Refer to Attachment 4.2 for the bases of each of the following referenced barrier loss/potential loss indicators.

Table 1 RCS Barrier Loss Indicators
<ul style="list-style-type: none"> • Containment Radiation Monitor CMS-RIS-27E and CMS-RIS-27F reading GT 70 R/hr • RPV level LT -161 in. • Drywell pressure GT 1.68 psig with indications of RCS leakage inside drywell

Table 2 PC Barrier Loss Indicators
<ul style="list-style-type: none"> • Rapid unexplained decrease of PC pressure following an initial increase • Failure of <u>both</u> containment isolation valves (LCS Table 1.6.1.3-1) in any one line to close following auto or manual initiation <p style="text-align: center;">AND</p> <p>downstream pathway to the environment exists</p>

REFERENCE(S):

WNP-2 Technical Specifications

NUMARC NESP-007, Methodology for Development of Emergency Action Levels, Rev. 2, Fission Product Barrier Basis Information for Table 3

WNP-2 Fission Product Barrier Evaluation

WNP-2 Plant Specific EAL Guideline, FC1.1 + RCS3.1, RCS2.1, RCS1.2, PC1.1, PC2.1

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1A	4	10 of 159

Entry into the unsafe region of the Pressure Suppression Pressure curve (PPM 5.2.1, "Primary Containment Control", Figure F, PSP) is included as a potential primary containment barrier loss. A rapid depressurization of the RPV (e.g., occurrence of a large break LOCA or initiation of ADS) at wetwell pressures in excess of the PSP may cause either:

- Wetwell pressure responses indicative of a failure in the drywell-to-wetwell boundary, or
- Wetwell pressure increases to or beyond the Primary Containment Pressure Limit (PPM 5.2.1, "Primary Containment Control", Figure B, PCPL).

Refer to Attachment 4.2 for the bases of each of the following referenced barrier loss/potential loss indicators.

Table 1 RCS Barrier Loss Indicators
<ul style="list-style-type: none"> • Containment Radiation Monitor CMS-RIS-27E and CMS-RIS-27F reading GT 70 R/hr • RPV level LT -161 in. • Drywell pressure GT 1.68 psig with indications of RCS leakage inside drywell

Table 2 PC Barrier Loss Indicators
<ul style="list-style-type: none"> • Rapid unexplained decrease of PC pressure following an initial increase • Failure of <u>both</u> containment isolation valves (LCS Table 1.6.1.3-1) in any one line to close following auto or manual initiation <p style="text-align: center;">AND</p> <p>downstream pathway to the environment exists</p>

REFERENCE(S):

WNP-2 Technical Specifications

NUMARC NESP-007, Methodology for Development of Emergency Action Levels, Rev. 2, Fission Product Barrier Basis Information for Table 3

WNP-2 Fission Product Barrier Evaluation

WNP-2 Plant Specific EAL Guideline, FC1.1 + (RCS2.1, 3.1, 4.1) + (PC1.1, PC2.1, PC 1.5, PC5.2)

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1A	4	15 of 159

Entry into the unsafe region of the Pressure Suppression Pressure curve (PPM 5.2.1, "Primary Containment Control", Figure F, PSP) is included as a potential primary containment barrier loss. A rapid depressurization of the RPV (e.g., occurrence of a large break LOCA or initiation of ADS) at wetwell pressures in excess of the PSP may cause either:

- Wetwell pressure responses indicative of a failure in the drywell-to-wetwell boundary, or
- Wetwell pressure increases to or beyond the Primary Containment Pressure Limit (PPM 5.2.1, "Primary Containment Control", Figure B, PCPL).

Containment or drywell pressure responses not consistent with LOCA conditions indicate a loss of the Primary Containment barrier. This may be noticed as a decrease in drywell pressure when no operation action (e.g., starting drywell cooling fans) has been taken. It would also include a failure of the drywell pressure to increase as expected during a LOCA.

Refer to Attachment 4.2 for the bases of each of the following referenced PC barrier loss indicators.

Table 2 PC Barrier Loss Indicators
<ul style="list-style-type: none"> • Rapid unexplained decrease of PC pressure following an initial increase • Failure of <u>both</u> containment isolation valves (LCS Table 1.6.1.3-1) in any one line to close following auto or manual initiation AND downstream pathway to the environment exists

REFERENCE(S):

NUMARC NESP-007, Methodology for Development of Emergency Action Levels, Rev. 2, Fission Product Barrier Basis Information for Table 3

WNP-2 Fission Product Barrier Evaluation

Engineering Calculation No. NE-02-94-57

WNP-2 Plant Specific EAL Guideline, FC3.1 + PC1.5, PC5.2, PC1.1, PC1.2, PC2.1

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1A	4	21 of 159

3 Primary Containment 3.1 Primary Containment Pressure

3.1.G.1 General Emergency

NUMARC IC: A loss of any two fission product barriers and loss or potential loss of the third

APPLICABILITY:

Operating Conditions

1	2	3			
----------	----------	----------	--	--	--

EMERGENCY ACTION LEVEL:

PC pressure exceeds PCPL

BASES:

This indicator is considered to be a loss of both the Fuel Clad and RCS barriers in conjunction with the potential loss of PC.

Containment pressures that exceeds 37.4 psig, the maximum expected pressure following a LOCA, have the potential to result in a loss of the containment barrier. Preparations to vent containment are required by PPM 5.2.1, "Primary Containment Control" before the Wetwell pressure reaches the Primary Containment Pressure Limit (PCPL). Therefore this condition is considered a potential loss of containment.

With PC pressure GT PCPL and increasing, a loss of the RCS barrier has occurred due to the elevated containment pressure. Continued wetwell pressure increase could result in complete and uncontrolled loss of the primary containment due to containment failure. With no assurance as to where the containment may fail, an attendant loss of the suppression pool should be assumed with a consequent complete and unrecoverable loss of core cooling whereby the degraded core condition and loss of containment integrity releases substantial amounts of radioactivity to the general environment. Therefore, this condition is also considered to be a loss of both fuel clad and RCS.

REFERENCE(S):

NUMARC NESP-007, Methodology for Development of Emergency Action Levels, Rev. 2, Fission Product Barrier Basis Information for Table 3

WNP-2 Fission Product Barrier Evaluation

Attachment 4.1

PROCEDURE NUMBER 13.1.1A	REVISION 4	PAGE 46 of 159
---	-----------------------------	---------------------------------

Entry into the unsafe region of the Pressure Suppression Pressure curve (PPM 5.2.1, "Primary Containment Control", Figure F, PSP) is included as a potential primary containment barrier loss. A rapid depressurization of the RPV (e.g., occurrence of a large break LOCA or initiation of ADS) at wetwell pressures in excess of the PSP may cause either:

- Wetwell pressure responses indicative of failure in the drywell-to-wetwell boundary, or
- Wetwell pressure increases to or beyond the Primary Containment Pressure Limit (PPM 5.2.1, "Primary Containment Control", Figure B, PCPL).

Total leakage is considered to be the total of both identified and unidentified leakage as measured on EDR-FRS-623, Pen 1 (unidentified Floor Drain Sump Fill Rate) and Pen 2 (identified Equipment Drain Sump Fill Rate). The maximum measurable identified leak rate (Pen 2) in the Control Room at WNP-2 is 30 gpm, therefore, 30 gpm is used instead of the 50 gpm limit recommended by NUMARC.

A 70 R/hr reading on CMS-RIS-27e and CMS-RIS-27F is used to indicate a loss of the Reactor Coolant System barrier. This value assumes a 0.1% clad damage and the instantaneous release and dispersal of the reactor coolant noble gas and iodine inventory into the drywell atmosphere. The value of 0.1% clad damage was assumed to be the greatest amount of fuel failure under which power operation could occur.

The 1.68 psig drywell pressure for the Reactor Coolant System barrier loss is based on the drywell pressure scram and isolation setpoint and indicates a Loss of Coolant Accident (LOCA). A potential loss of the Reactor Coolant System barrier would not result in an increasing drywell pressure and, therefore, no indicator is provided. The qualifier of "with indications of RCS leak inside the drywell" is included as an indicator of RCS boundary degradation and eliminates a drywell pressure increase due to loss of drywell ventilation.

REFERENCE(S):

NUMARC NESP-007, Methodology for Development of Emergency Action Levels, Rev. 2, Fission Product Barrier Basis Information for Table 3

WNP-2 Fission Product Barrier Evaluation

WNP-2 Plant Specific EAL Guideline, PC1.5/PC5.2 + RCS1.2, RCS3.1, RCS2.1

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1A	4	51 of 159

TABLE 6. FISSION PRODUCT BARRIER DEGRADATION TABLE BASES (Contd.)

Wetwell pressure exceeds PSP

Entry into the unsafe region of the Pressure Suppression Pressure curve (PPM 5.2.1, "Primary Containment Control", Figure F, PSP) is included as a potential primary containment barrier loss. A rapid depressurization of the RPV (e.g., occurrence of a large break LOCA or initiation of ADS) at wetwell pressures in excess of the PSP may cause either:

- Wetwell pressure responses indicative of a failure in the drywell-to-wetwell boundary, or
- Wetwell pressure increases to or beyond the Primary Containment Pressure Limit (PPM 5.2.1, "Primary Containment Control", Figure B, PCPL).

PC pressure GT PCPL and increasing

Containment pressures that exceeds 37.4 psig, the maximum expected pressure following a LOCA, have the potential to result in a loss of the containment barrier. Preparations to vent containment are required by PPM 5.2.1, "Primary Containment Control" when Drywell pressure exceeds PCPL and before the Wetwell pressure reaches the Primary Containment Pressure Limit (PCPL). Therefore, this condition is considered a potential loss of containment.

Attachment 4.2

PROCEDURE NUMBER	REVISION	PAGE
13.1.1A	4	159 of 159

TABLE 6. FISSION PRODUCT BARRIER DEGRADATION TABLE BASES

PROCEDURE NUMBER
13.1.1.A
 REVISION
4
 PAGE
153 OF 159

Attachment 4.2

Fuel Clad Loss	Fuel Clad Potential Loss	RCS Loss	RCS Potential Loss	PC Loss	PC Potential Loss
<p>Coolant activity GT 300 μCi/gm dose equivalent iodine</p> <p>Containment Radiation Monitor CMS-RIS-27E and CMS-RIS-27F reading GT 3,600 R/hr</p> <p>Entry into Severe Accident Guidelines</p>	<p>RPV level LT -161 inches</p>	<p>Containment Radiation Monitor CMS-RIS-27E and CMS-RIS-27F reading GT 70 R/hr</p> <p>RPV level LT -161 inches</p> <p>Drywell pressure GT 1.68 psig with indications of RCS leakage inside drywell</p>	<p>Total RCS leakage GT 30 gpm inside PC or EDR-FRS-623, Pen 2 upscale high</p> <p>Unisolable primary system discharging outside PC resulting in any area temperature or radiation level above Maximum Safe Operating Values (PPM 5.3.1, "Secondary Containment Control")</p>	<p>Rapid unexplained decrease of PC pressure following an initial increase</p> <p>Drywell pressure response not consistent with LOCA conditions</p> <p>Failure of <u>both</u> containment isolation valves (LCS Table 1.6.3.1-1) in any one line to close following auto or manual initiation AND downstream pathway to the environment exists OR</p> <p>Unisolable primary system discharging outside PC resulting in any area temperature or radiation level above Maximum Safe Operating Values (PPM 5.3.1, "Secondary Containment Control")</p> <p>Intentional venting per PPM 5.2.1, "Primary Containment Control"</p>	<p>Containment Radiation Monitor CMS-RIS-27E and CMS-RIS-27F reading GT 14,000 R/hr</p> <p>PC H₂ and O₂ concentrations GT 6% H₂ and 5% O₂</p> <p>Entry into Severe Accident Guidelines</p> <p>Loss of pressure suppression function</p> <p>Cannot maintain plant parameters within HCTL, SRVTPLL</p> <p>Wetwell pressure exceeds PSP</p> <p>PC pressure GT PCPL</p>

<p>Any event, in the judgment of the Emergency Director, that could lead or has led to a loss or potential loss of the fuel clad barrier</p>	<p>Any event, in the judgment of the Emergency Director, that could lead or has led to a loss or potential loss of the RCS barrier</p>	<p>Any event, in the judgment of the Emergency Director, that could lead to or has led to a loss or potential loss of primary containment barrier</p>
---	---	--

DATE: 02/07/00

EDITORIAL

13.1.1A



USE CURRENT REVISION

WNP-2
PLANT PROCEDURES MANUAL

PROCEDURE NUMBER	APPROVED BY	DATE
*13.1.1A	DWC - Revision 4	09/14/99
VOLUME NAME		
EMERGENCY PLAN IMPLEMENTING PROCEDURES		
SECTION		
EMERGENCY CLASSIFICATION		
TITLE		
CLASSIFYING THE EMERGENCY - TECHNICAL BASES		

TABLE OF CONTENTS

	<u>Page</u>
1.0 PURPOSE	2
2.0 REFERENCES	2
3.0 PROCEDURE	4
3.1 Plant Emergency Response Personnel Responsibilities	4
3.2 Use Of Plant Instruments And Indications	4
3.3 Emergency Class Description	4
3.4 Mode Applicability	5
4.0 ATTACHMENTS	5
4.1 EAL Technical Bases	5
4.2 Fission Product Barrier Degradation Table Bases	5

PROCEDURE NUMBER	REVISION	PAGE
13.1.1A	4	1 of 159

Entry into the unsafe region of the Pressure Suppression Pressure curve (PPM 5.2.1, "Primary Containment Control", Figure F, PSP) is included as a potential primary containment barrier loss. A rapid depressurization of the RPV (e.g., occurrence of a large break LOCA or initiation of ADS) at wetwell pressures in excess of the PSP may cause either:

- Wetwell pressure responses indicative of failure in the drywell-to-wetwell boundary, or
- Wetwell pressure increases to or beyond the Primary Containment Pressure Limit (PPM 5.2.1, "Primary Containment Control", Figure B, PCPL).

Refer to Attachment 4.2 for the bases of each of the following referenced barrier loss/potential loss indicators.

Table 1 RCS Barrier Loss Indicators
<ul style="list-style-type: none"> • Containment Radiation Monitor CMS-RIS-27E and CMS-RIS-27F reading GT 70 R/hr • RPV level LT -161 in. • Drywell pressure GT 1.68 psig with indications of RCS leakage inside drywell

Table 2 PC Barrier Loss Indicators
<ul style="list-style-type: none"> • Rapid unexplained decrease of PC pressure following an initial increase • Failure of <u>both</u> containment isolation valves (LCS Table 1.6.1.3-1) in any one line to close following auto or manual initiation <p style="text-align: center;">AND</p> <p>downstream pathway to the environment exists</p>

REFERENCE(S):

WNP-2 Technical Specifications

NUMARC NESP-007, Methodology for Development of Emergency Action Levels, Rev. 2, Fission Product Barrier Basis Information for Table 3

WNP-2 Fission Product Barrier Evaluation

WNP-2 Plant Specific EAL Guideline, FC1.1 + RCS3.1, RCS2.1, RCS1.2, PC1.1, PC2.1

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1A	4	10 of 159

Entry into the unsafe region of the Pressure Suppression Pressure curve (PPM 5.2.1, "Primary Containment Control", Figure F, PSP) is included as a potential primary containment barrier loss. A rapid depressurization of the RPV (e.g., occurrence of a large break LOCA or initiation of ADS) at wetwell pressures in excess of the PSP may cause either:

- Wetwell pressure responses indicative of a failure in the drywell-to-wetwell boundary, or
- Wetwell pressure increases to or beyond the Primary Containment Pressure Limit (PPM 5.2.1, "Primary Containment Control", Figure B, PCPL).

Refer to Attachment 4.2 for the bases of each of the following referenced barrier loss/potential loss indicators.

Table 1 RCS Barrier Loss Indicators
<ul style="list-style-type: none"> • Containment Radiation Monitor CMS-RIS-27E and CMS-RIS-27F reading GT 70 R/hr • RPV level LT -161 in. • Drywell pressure GT 1.68 psig with indications of RCS leakage inside drywell

Table 2 PC Barrier Loss Indicators
<ul style="list-style-type: none"> • Rapid unexplained decrease of PC pressure following an initial increase • Failure of <u>both</u> containment isolation valves (LCS Table 1.6.1.3-1) in any one line to close following auto or manual initiation <p style="text-align: center;">AND</p> <p>downstream pathway to the environment exists</p>

REFERENCE(S):

WNP-2 Technical Specifications

NUMARC NESP-007, Methodology for Development of Emergency Action Levels, Rev. 2, Fission Product Barrier Basis Information for Table 3

WNP-2 Fission Product Barrier Evaluation

WNP-2 Plant Specific EAL Guideline, FC1.1 + (RCS2.1, 3.1, 4.1) + (PC1.1, PC2.1, PC 1.5, PC5.2)

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1A	4	15 of 159

Entry into the unsafe region of the Pressure Suppression Pressure curve (PPM 5.2.1, "Primary Containment Control", Figure F, PSP) is included as a potential primary containment barrier loss. A rapid depressurization of the RPV (e.g., occurrence of a large break LOCA or initiation of ADS) at wetwell pressures in excess of the PSP may cause either:

- Wetwell pressure responses indicative of a failure in the drywell-to-wetwell boundary, or
- Wetwell pressure increases to or beyond the Primary Containment Pressure Limit (PPM 5.2.1, "Primary Containment Control", Figure B, PCPL).

Containment or drywell pressure responses not consistent with LOCA conditions indicate a loss of the Primary Containment barrier. This may be noticed as a decrease in drywell pressure when no operation action (e.g., starting drywell cooling fans) has been taken. It would also include a failure of the drywell pressure to increase as expected during a LOCA.

Refer to Attachment 4.2 for the bases of each of the following referenced PC barrier loss indicators.

Table 2 PC Barrier Loss Indicators
<ul style="list-style-type: none"> • Rapid unexplained decrease of PC pressure following an initial increase • Failure of <u>both</u> containment isolation valves (LCS Table 1.6.1.3-1) in any one line to close following auto or manual initiation <p style="text-align: center;">AND</p> <p>downstream pathway to the environment exists</p>

REFERENCE(S):

NUMARC NESP-007, Methodology for Development of Emergency Action Levels, Rev. 2, Fission Product Barrier Basis Information for Table 3

WNP-2 Fission Product Barrier Evaluation

Engineering Calculation No. NE-02-94-57

WNP-2 Plant Specific EAL Guideline, FC3.1 + PC1.5, PC5.2, PC1.1, PC1.2, PC2.1

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1A	4	21 of 159

3 Primary Containment 3.1 Primary Containment Pressure

3.1.G.1 General Emergency

NUMARC IC: A loss of any two fission product barriers and loss or potential loss of the third

APPLICABILITY:

Operating Conditions

1	2	3			
---	---	---	--	--	--

EMERGENCY ACTION LEVEL:

PC pressure exceeds PCPL

BASES:

This indicator is considered to be a loss of both the Fuel Clad and RCS barriers in conjunction with the potential loss of PC.

Containment pressures that exceeds 37.4 psig, the maximum expected pressure following a LOCA, have the potential to result in a loss of the containment barrier. Preparations to vent containment are required by PPM 5.2.1, "Primary Containment Control" before the Wetwell pressure reaches the Primary Containment Pressure Limit (PCPL). Therefore this condition is considered a potential loss of containment.

With PC pressure GT PCPL and increasing, a loss of the RCS barrier has occurred due to the elevated containment pressure. Continued wetwell pressure increase could result in complete and uncontrolled loss of the primary containment due to containment failure. With no assurance as to where the containment may fail, an attendant loss of the suppression pool should be assumed with a consequent complete and unrecoverable loss of core cooling whereby the degraded core condition and loss of containment integrity releases substantial amounts of radioactivity to the general environment. Therefore, this condition is also considered to be a loss of both fuel clad and RCS.

REFERENCE(S):

NUMARC NESP-007, Methodology for Development of Emergency Action Levels, Rev. 2, Fission Product Barrier Basis Information for Table 3

WNP-2 Fission Product Barrier Evaluation

Attachment 4.1

PROCEDURE NUMBER 13.1.1A	REVISION 4	PAGE 46 of 159
------------------------------------	----------------------	--------------------------

Entry into the unsafe region of the Pressure Suppression Pressure curve (PPM 5.2.1, "Primary Containment Control", Figure F, PSP) is included as a potential primary containment barrier loss. A rapid depressurization of the RPV (e.g., occurrence of a large break LOCA or initiation of ADS) at wetwell pressures in excess of the PSP may cause either:

- Wetwell pressure responses indicative of failure in the drywell-to-wetwell boundary, or
- Wetwell pressure increases to or beyond the Primary Containment Pressure Limit (PPM 5.2.1, "Primary Containment Control", Figure B, PCPL).

Total leakage is considered to be the total of both identified and unidentified leakage as measured on EDR-FRS-623, Pen 1 (unidentified Floor Drain Sump Fill Rate) and Pen 2 (identified Equipment Drain Sump Fill Rate). The maximum measurable identified leak rate (Pen 2) in the Control Room at WNP-2 is 30 gpm, therefore, 30 gpm is used instead of the 50 gpm limit recommended by NUMARC.

A 70 R/hr reading on CMS-RIS-27e and CMS-RIS-27F is used to indicate a loss of the Reactor Coolant System barrier. This value assumes a 0.1% clad damage and the instantaneous release and dispersal of the reactor coolant noble gas and iodine inventory into the drywell atmosphere. The value of 0.1% clad damage was assumed to be the greatest amount of fuel failure under which power operation could occur.

The 1.68 psig drywell pressure for the Reactor Coolant System barrier loss is based on the drywell pressure scram and isolation setpoint and indicates a Loss of Coolant Accident (LOCA). A potential loss of the Reactor Coolant System barrier would not result in an increasing drywell pressure and, therefore, no indicator is provided. The qualifier of "with indications of RCS leak inside the drywell" is included as an indicator of RCS boundary degradation and eliminates a drywell pressure increase due to loss of drywell ventilation.

REFERENCE(S):

NUMARC NESP-007, Methodology for Development of Emergency Action Levels, Rev. 2, Fission Product Barrier Basis Information for Table 3

WNP-2 Fission Product Barrier Evaluation

WNP-2 Plant Specific EAL Guideline, PC1.5/PC5.2 + RCS1.2, RCS3.1, RCS2.1

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1A	4	51 of 159

TABLE 6. FISSION PRODUCT BARRIER DEGRADATION TABLE BASES (Contd.)

Wetwell pressure exceeds PSP

Entry into the unsafe region of the Pressure Suppression Pressure curve (PPM 5.2.1, "Primary Containment Control", Figure F, PSP) is included as a potential primary containment barrier loss. A rapid depressurization of the RPV (e.g., occurrence of a large break LOCA or initiation of ADS) at wetwell pressures in excess of the PSP may cause either:

- Wetwell pressure responses indicative of a failure in the drywell-to-wetwell boundary, or
- Wetwell pressure increases to or beyond the Primary Containment Pressure Limit (PPM 5.2.1, "Primary Containment Control", Figure B, PCPL).

PC pressure GT PCPL and increasing

Containment pressures that exceeds 37.4 psig, the maximum expected pressure following a LOCA, have the potential to result in a loss of the containment barrier. Preparations to vent containment are required by PPM 5.2.1, "Primary Containment Control" when Drywell pressure exceeds PCPL and before the Wetwell pressure reaches the Primary Containment Pressure Limit (PCPL). Therefore, this condition is considered a potential loss of containment.

Attachment 4.2

PROCEDURE NUMBER	REVISION	PAGE
13.1.1A	4	159 of 159

TABLE 6. FISSION PRODUCT BARRIER DEGRADATION TABLE BASES

Fuel Clad Loss	Fuel Clad Potential Loss	RCS Loss	RCS Potential Loss	PC Loss	PC Potential Loss
<p>Coolant activity GT 300 μCi/gm dose equivalent iodine</p> <p>Containment Radiation Monitor CMS-RIS-27E and CMS-RIS-27F reading GT 3,600 R/hr</p> <p>Entry into Severe Accident Guidelines</p>	<p>RPV level LT -161 inches</p>	<p>Containment Radiation Monitor CMS-RIS-27E and CMS-RIS-27F reading GT 70 R/hr</p> <p>RPV level LT -161 inches</p> <p>Drywell pressure GT 1.68 psig with indications of RCS leakage inside drywell</p>	<p>Total RCS leakage GT 30 gpm inside PC or EDR-FRS-623, Pen 2 upscale high</p> <p>Unisolable primary system discharging outside PC resulting in any area temperature or radiation level above Maximum Safe Operating Values (PPM 5.3.1, "Secondary Containment Control")</p>	<p>Rapid unexplained decrease of PC pressure following an initial increase</p> <p>Drywell pressure response not consistent with LOCA conditions</p> <p>Failure of <u>both</u> containment isolation valves (LCS Table 1.6.3.1-1) in any one line to close following auto or manual initiation AND downstream pathway to the environment exists OR Unisolable primary system discharging outside PC resulting in any area temperature or radiation level above Maximum Safe Operating Values (PPM 5.3.1, "Secondary Containment Control") Intentional venting per PPM 5.2.1, "Primary Containment Control"</p>	<p>Containment Radiation Monitor CMS-RIS-27E and CMS-RIS-27F reading GT 14,000 R/hr</p> <p>PC H₂ and O₂ concentrations GT 6% H₂ and 5% O₂</p> <p>Entry into Severe Accident Guidelines</p> <p>Loss of pressure suppression function</p> <p>Cannot maintain plant parameters within HCTL, SRVTPLL</p> <p>Wetwell pressure exceeds PSP</p> <p>PC pressure GT PCPL</p>

<p>Any event, in the judgment of the Emergency Director, that could lead or has led to a loss or potential loss of the fuel clad barrier</p>	<p>Any event, in the judgment of the Emergency Director, that could lead or has led to a loss or potential loss of the RCS barrier</p>	<p>Any event, in the judgment of the Emergency Director, that could lead to or has led to a loss or potential loss of primary containment barrier</p>
---	---	--


PROCEDURE NUMBER
13.1.1.A
 REVISION
4
 PAGE
153 OF 159

Attachment 4.2

DATE: 02/07/00

EDITORIAL

13.5.1



**CONDITION
"B"
SITE MAP AND
EVACUATION ROUTE**

**EVACUEE PROTECTED
AREA EXIT THROUGH
PROTECTED AREA
ACCESS POINT (PAAP)**

848317.2
DEC 1991

Attachment 5.3

PROCEDURE NUMBER	REVISION	PAGE
13.5.1	14	9 of 9



USE CURRENT REVISION

WNP-2
PLANT PROCEDURES MANUAL

PROCEDURE NUMBER *13.9.1	APPROVED BY TM - Revision 22	DATE 02/07/00
VOLUME NAME EMERGENCY PLAN IMPLEMENTING PROCEDURES		
SECTION ENVIRONMENTAL FIELD MONITORING AND SAMPLING		
TITLE ENVIRONMENTAL FIELD MONITORING OPERATIONS		

TABLE OF CONTENTS

	<u>Page</u>
1.0 PURPOSE	2
2.0 REFERENCES	2
3.0 PRECAUTIONS AND LIMITATIONS	3
4.0 PROCEDURE	3
4.1 Field Team Coordinator Duties	3
4.2 Field Team Dispatcher Duties	6
4.3 Environmental Field Team Member Duties	7
5.0 ATTACHMENTS	11
5.1 Radiation Survey Instruments: Battery and Response Checks	13
5.2 Radio, Cellular Phone and GPS Operation Instructions	18
5.3 Field Radiation Surveys (General Area and Ground Contamination)	21
5.4 Portable Air Sampling Instructions	23
5.5 Sample Identification Form (968-19234) Instructions	27
5.6 Air Sampling Worksheet	28
5.7 Environmental TLD and Fixed Air Sample Retrieval Instructions	29
5.8 Field Team Coordinator Checklist	31
5.9 Field Team Briefing Worksheet	33
5.10 Field Team Kit Replenishment Log	34

PROCEDURE NUMBER 13.9.1	REVISION 22	PAGE 1 of 34
-----------------------------------	-----------------------	------------------------

1.0 PURPOSE

This procedure provides those individuals involved with Environmental Field Team (EFT), or Field Team, operations with instructions for responding to radiological emergencies at Energy Northwest nuclear facilities. The Environmental Field Teams will confirm radiological releases through actual measurements in the field to determine the extent of plume travel and contamination spread. Sampling and field analysis will be conducted following the instructions contained in attachments to this procedure.

2.0 REFERENCES

- 2.1 FSAR, Chapter 13.3, Emergency Plan, Sections 2, 5
- 2.2 CI 4.10, WNP-2 Environmental Thermoluminescent Dosimeter (TLD) Distribution and Collection
- 2.3 CI 4.11, Trip Directions to TLD Stations
- 2.4 CI 4.12, Airborne Samples Distribution, Collection and Shipping
- 2.5 CI 4.13, Trip Directions to Environmental Air Sampler Stations
- 2.6 PPM 13.2.1, Emergency Exposure Levels/Protective Action Guides
- 2.7 PPM 13.9.5, Environmental Sample Collection
- 2.8 PPM 13.9.8, River Evacuation Monitoring
- 2.9 PPM 13.13.4, After Action Reporting
- 2.10 PPM 13.14.4, Emergency Equipment
- 2.11 Sample Identification Form, 968-19324
- 2.12 Emergency Response Log, 968-23895
- 2.13 Field Team Dispatch and Tracking Worksheet, 968-25815
- 2.14 Ten Mile EPZ Field Team Summary Map, 968-25130
- 2.15 Field Team Radiation Survey Data, 968-26097

PROCEDURE NUMBER	REVISION	PAGE
13.9.1	22	2 of 34

3.0 PRECAUTIONS AND LIMITATIONS

- 3.1 Environmental air sampling should be performed sufficiently downwind to minimize dose. All field team personnel should be instructed to contact MUDAC prior to entering the plume and should be made aware of expected dose rates. Air sampling should not be conducted in fields greater than 2 rem/hr.
- 3.2 When driving off-road during the dry summer months, Field Team personnel should be aware of the potential for grass fires started by the vehicle's hot exhaust.
- 3.3 Due to the potential hazard of explosion or fire, adhere to good safety practices when obtaining environmental air samples by connecting the sampler's positive battery terminal lead first, then connecting the negative lead to a ground away from the battery's negative lead cable post (a ground connection can be any metal object within the vehicle's engine compartment). When completed air sampling, disconnect the negative lead first.
- 3.4 Field Team personnel need to be aware of the potential for heat stress problems when dressed in protective clothing on a hot summer day. The Field Team Coordinator should request a Safety Representative be called out for advisory purposes if this is perceived to be a potential problem.

4.0 PROCEDURE

4.1 Field Team Coordinator Duties

NOTE: The Field Team Coordinator checklist (Attachment 5.8) is provided for guidance.

- 4.1.1 Provide overall direction of environmental field teams. Coordinate each organization's team activities with the responsible agency for their respective area:
 - a. Exclusion Area Boundary -- Energy Northwest
 - b. Hanford Reservation -- Energy Northwest and DOE-RL
 - c. Outside the Hanford Reservation -- Energy Northwest and Washington State Department of Health
 - d. Oregon -- Oregon Department of Energy
- 4.1.2 Assign each field team deployed an identification number for use in communications and reporting (e.g., EN-1, EN-2, DOE-1, DOE-2, etc.).

PROCEDURE NUMBER	REVISION	PAGE
13.9.1	22	3 of 34

- 4.1.3 Interface with the Dose Projection Health Physicist (DPHP) to determine the following:
- a. Projected release path.
 - b. Areas which may require surveys, air sampling, or environmental sampling to verify plume location and deposition.
 - c. Emergency worker dose correction factor. The REM may need to be consulted for this information.
 - the emergency worker dose adjustment factor should be multiplied by the PIC reading to determine total exposure.
- 4.1.4 Determine current year-to-date (YTD) dose of each Energy Northwest field team member by referencing the Total Exposure System (TES) in Passport, on any available computer connected to the LAN. During normal working hours, Radiation Exposure Records may be contacted for assistance. During off hours, the HP Access Control Area may be contacted for assistance.
- 4.1.5 Using a dose projection computer, double click on the "Run Exposure Report" icon. This will download the most recent exposure report to the computer.
- a. Double click on the "View Exposure Report" icon. This will display a list of all Energy Northwest personnel and their exposure history. Scroll to the desired name or select "Edit" and use the "Find" option.
 - b. Close the window when all desired records have been obtained.
- 4.1.6 Log each field team member's current year-to-date (YTD) dose, available dose and the emergency worker dose correction factor in the Emergency Worker Dose Worksheet Section of the Field Team Dispatch and Tracking Worksheet (Form 968-25815). Available dose is 5000 mrem minus current YTD dose.
- 4.1.7 If necessary, request a support person or additional field team member to assist with recording incoming field team data.
- 4.1.8 Perform initial briefing of field teams prior to dispatch per Attachment 5.9.
- a. Initial briefings should include individual exposures and limits.
 - b. Obtain field team vehicle license and cell phone numbers, and record them on the briefing guide.
- 4.1.9 Direct the Field Team Dispatcher in the control and routine briefing of field teams after they are dispatched.

PROCEDURE NUMBER	REVISION	PAGE
13.9.1	22	4 of 34

- 4.1.10 Develop an initial plan of action to detect radiological effluent releases through the use of field teams taking into account computer generated data on current and potential effluent release exposure areas.

CAUTION: Environmental air sampling should be performed sufficiently downwind to minimize dose. All field team personnel should be instructed to contact MUDAC prior to entering the plume and should be made aware of expected dose rates. Air sampling should not be conducted in fields, projected or actual, greater than 2 rem/hr.

- 4.1.11 Position field teams per the following guidelines ensuring that field team member exposure is controlled in accordance with ALARA principles:
- a. Locate one field team downwind in close proximity to the plant (about $\frac{1}{4}$ - $\frac{1}{2}$ mile depending on wind conditions) to verify through field readings when the release begins. Use landmarks rather than GPS coordinates when field teams are close to the plant.
 - b. Locate the other field teams farther downwind to detect the leading edge and possibly the approximate side boundaries of the plume.
- 4.1.12 Direct field teams to contact the Field Team Coordinator for further instructions when they have located the plume boundary and prior to entering the plume for additional readings.
- 4.1.13 Keep the DPHP informed of field monitoring results.
- 4.1.14 Reposition field teams as necessary to track the plume's leading edge, the side boundaries and, when the release terminates, the trailing edge.
- 4.1.15 Consult with the REM to determine when an environmental air sample is necessary to determine specific isotopic content of the plume. If so, direct the field team to enter the plume and obtain the air sample keeping exposures ALARA.
- 4.1.16 Periodically request dosimeter readings of field team members to assure personnel do not exceed Energy Northwest guides. The Emergency Worker dose limit is 5 rem thyroid, minus any accumulated dose. Ensure dosimeter readings are logged on the Field Team Dispatch and Tracking Worksheet (Form 968-25815).
- 4.1.17 Maintain up-to-date 10 mile and 50 mile MUDAC Field Team display maps, showing field team locations, and showing field team radiological monitoring results. Update Field Team Summary Maps (968-25130) as needed.

PROCEDURE NUMBER	REVISION	PAGE
13.9.1	22	5 of 34

- 4.1.18 Periodically, or as requested, provide completed Field Team Summary Maps (Form 968-25130) to the REM.
- 4.1.19 When directed to assist with river evacuation monitoring, dispatch a field team to implement PPM 13.9.8.
- 4.1.20 Notify field teams when decisions are made to take KI, or to implement other protective measures.
- 4.1.21 Arrange for replacement of field team instrumentation or supplies when needed.
- 4.1.22 Upon shift change, brief your relief on current status of the emergency and field team activities.
- 4.1.23 Upon shift change or termination of the emergency:
 - a. Prepare an individual After Action Report. Refer to PPM 13.13.4.
 - b. Collect Field Team Kit Inventory Sheets and After Action Reports from all field teams.
 - c. Deliver After Action Reports to the DPHP.

4.2 Field Team Dispatcher Duties

- 4.2.1 Assign and dispatch field teams as directed and record data on the Field Team Dispatch and Tracking Worksheet (Form 968-25815).
- 4.2.2 Maintain radio contact with field teams and enforce radio discipline and good practices.
- 4.2.3 When significant changes occur during the emergency, complete a Field Team Briefing Worksheet (Attachment 5.9), conduct a roll call of all field teams and provide a radio briefing of worksheet information. Record field team acknowledgement following the briefing.
 - a. Continue to follow up with any teams that fail to acknowledge the briefing. The Washington field team coordinator should be informed of state teams not receiving the briefing.
- 4.2.4 When directed, notify field teams of any Protective Action Decisions (PADs) affecting the field teams or the public.

PROCEDURE NUMBER	REVISION	PAGE
13.9.1	22	6 of 34

- 4.2.5 Periodically request dosimetry readings from field team members to ensure they are within limits and notify the Field Team Coordinator of results.
- 4.2.6 Maintain radio communications capability until all field teams have returned to the Plant Support Facility.
- 4.2.7 Act as Field Team Coordinator when requested.
- 4.2.8 Upon shift change, brief your relief on the current status of the emergency and field team activities.
- 4.2.9 Upon shift change or termination of the emergency:
 - a. Prepare an individual After Action Report. Refer to PPM 13.13.4.
 - b. Deliver After Action Report, and logs to the Field Team Coordinator.

4.3 Environmental Field Team Member Duties

- 4.3.1 Upon notification of Alert or higher classification, or as directed, proceed to the Emergency Operations Facility, or if directed, to Energy Northwest Alternate EOF at the MPF, and report to the Radiological Emergency Manager, Field Team Coordinator, or Field Team Dispatcher (by telephone if necessary).

NOTE: If none of the above personnel are present, proceed with those procedure steps listed for getting field team equipment ready for use. Check back with one of the listed personnel when ready for dispatch.

- 4.3.2 Sign in on the EOF staffing board designated for listing field team members and obtain a field team identification designator number (i.e., EN-1, EN-2, etc.).
- 4.3.3 Obtain keys for the Energy Northwest designated field team vehicles from the MUDAC Emergency Supply Cabinet.

NOTE: Two of the designated field team vehicles are pool vehicles. One is normally located at Building 11. The second vehicle is located in front of the PEC. Use of another Energy Northwest or personal vehicle may be required to obtain these vehicles. Keys to all designated field team vehicles are located in the EOF Field Team Emergency Cabinet.

PROCEDURE NUMBER	REVISION	PAGE
13.9.1	22	7 of 34

4.3.4 The first team member to arrive at the EOF should retrieve the Field Team Emergency Cabinet keys (and the key to the First Aid Room for entry to the ambulance bay) from the red key box on the MUDAC Emergency Supply Cabinet and unlock the following:

- a. Field Team Emergency Cabinets #1 through #3 (PSF Ambulance Garage).
- b. EOF Decon Supply Cabinet (PSF Room 118A - by decon shower).
- c. Radio Charger Cabinet (PSF Room 118A - by decon shower).

NOTE: Additional field team kits and the River Evacuation and Monitoring Kits are located outside Room 201 of the MPF. Keys for the cabinet are located in the glass front key box on the wall adjacent to the Room 201 door. Enter the MPF via the southeast keycard sliding door.

4.3.5 Obtain field team equipment from the designated cabinets which includes the following:

NOTE: The combination to the field team kits is 911.

- a. Field Team Document Packet of Maps, Forms and Procedures, and a GPS unit from the EOF supply cabinet
- b. Protective Clothing Kit
- c. Instrumentation Kit
- d. Ribbonded Stakes for marking sample locations
- e. Air Sampling Kit
- f. Field Sampling Kit
- g. Field Team Portable Radios (2) and Spare Batteries (2) located in the Radio Charging Cabinets in PSF Room 118A.

4.3.6 If the inventory seal on any of the kits is broken, inventory the contents of that kit per the PPM 13.14.4 inventory list (located in the Field Team Document Packet) and notify the Field Team Coordinator if anything is missing.

PROCEDURE NUMBER	REVISION	PAGE
13.9.1	22	8 of 34

NOTE: The source to be used for performing instrument response checks is located in the Radio Charging Cabinet in Room 118A. The source shall be returned to this cabinet when response checks are complete, and the cabinet locked.

- 4.3.7 Perform battery and response check, as applicable, on all radiation survey instruments in the instrumentation kit and record the information on the Checklist for Equipment Test, Attachment 5.1, located in the Field Team Document Packet, using the guidance contained in Attachment 5.1 and Attachment 5.2.
- 4.3.8 Zero the low range and high range pocket dosimeters, and place dosimeters on the front of your upper torso.
- 4.3.9 When equipment check and vehicle loading is complete, establish radio contact with MUDAC and conduct radio check. See Attachment 5.2, Radio, Cellular Phone and GPS Operation Instructions, for guidance.

NOTE: If your radio is inoperable, establish contact by phone, or by cellular phone from a Field Team vehicle.

- 4.3.10 Turn on the GPS unit and verify the following:
 - a. GPS unit is set to read out in degrees, minutes, and tenths of degrees
 - b. Batteries are not low (low battery condition is indicated by a battery symbol displayed at the bottom of the screen)
 - c. Position information is displayed
- 4.3.11 Obtain initial deployment assignment from MUDAC, and when directed by the MUDAC Field Team Coordinator, don appropriate protective clothing (PCs), and proceed to assigned location, continuously monitoring radiation levels.
- 4.3.12 The following Stability Class tables are provided to complement the briefing information received from the Field Team Coordinator.

PROCEDURE NUMBER	REVISION	PAGE
13.9.1	22	9 of 34

STABILITY CLASS TABLE

Stability Classification	NRC Categories (Stability)
Extremely unstable	<i>A (1)</i>
Moderately unstable	<i>B (2)</i>
Slightly unstable	<i>C (3)</i>
Neutral	<i>D (4)</i>
Slightly stable	<i>E (5)</i>
Moderately stable	<i>F (6)</i>
Extremely stable	<i>G (7)</i>

- 4.3.13 Notify the Field Team Dispatcher upon arrival at your assigned location.
- 4.3.14 As directed, perform general area surveys, ground contamination surveys and portable air samples following the instructions contained in Attachments 5.3 through 5.6.
- 4.3.15 Maintain a chronology of significant inputs, actions, events and their resolutions on an already established log, or on the Emergency Response Log (Form 968-23895), for attachment to your After Action Report per PPM 13.13.4.
- 4.3.16 If directed to perform River Evacuation Monitoring refer to PPM 13.9.8.
- 4.3.17 If directed to retrieve environmental TLDs and/or fixed air samples, refer to Attachment 5.7.
- 4.3.18 When relieved at shift change, or termination of emergency event:
- a. Brief your relief on responsibilities, duties and current status of actions being performed.
 - b. Report to the PSF ambulance bay area for survey, and, if necessary, decontamination.
 - c. Turn in personnel dosimetry to the Health Physics Center staff and report to MUDAC for debriefing.
 - d. Prepare an individual After Action Report per PPM 13.13.4.
 - e. Deliver After Action Reports to the Field Team Coordinator.
- 4.3.19 When assigned as relief for the on shift Environmental Field Team Members:

PROCEDURE NUMBER	REVISION	PAGE
13.9.1	22	10 of 34

- a. Report to the Field Team Coordinator in MUDAC.
- b. Receive an update on present conditions, and instructions for relieving the on shift team members.
- c. Prior to beginning the assignment, report to the Health Physics Center for personnel dosimetry issuance and a complete set of protective clothing.
- d. Obtain replacement radio batteries from the radio charging cabinets in PSF Room 118A.
- e. Proceed to the field team location you are relieving, receive briefing and relieve the on shift field team.
- f. Perform a battery check on all applicable instrumentation. Complete the Checklist for Equipment Test, Attachment 5.1.
- g. Upon return of field team equipment:
- h. Restore equipment to correct field team kit container and place in designated cabinet.
- i. Refer to PPM 13.14.4, Emergency Equipment, for a list of kit contents. If kits contain the required items, reseal the kits.
- j. Complete the Field Team Kit Replenishment Log located on the inside of the field team cabinet door noting any items used out of the kits. Refer to Attachment 5.10.
 - Include the replenishment log with your After Action Report.
- k. Prepare an Individual After Action Report per PPM 13.13.4.
- l. Deliver all logs, data work sheets, and After Action Reports to the Field Team Coordinator.

5.0 ATTACHMENTS

- 5.1 Radiation Survey Instruments: Battery and Response Checks
- 5.2 Radio, Cellular Phone and GPS Operation Instructions
- 5.3 Field Radiation Surveys (General Area and Ground Contamination)
- 5.4 Portable Air Sampling Instructions

PROCEDURE NUMBER	REVISION	PAGE
13.9.1	22	11 of 34

- 5.5 Sample Identification Form (968-19234) Instructions
- 5.6 Air Sampling Worksheet
- 5.7 Environmental TLD and Fixed Air Sample Retrieval Instructions
- 5.8 Field Team Coordinator Checklist
- 5.9 Field Team Briefing Worksheet
- 5.10 Field Team Kit Replenishment Log

PROCEDURE NUMBER 13.9.1	REVISION 22	PAGE 12 of 34
-----------------------------------	-----------------------	-------------------------

RADIATION SURVEY INSTRUMENTS: BATTERY AND RESPONSE CHECKS

Prior to departure from the EOF, all radiation survey instruments should be battery and response checked. The Cesium 137 check source for response checking the instruments is located in the left most radio cabinet inside a lead container. When response checking the instruments you are looking for any indication of an elevated reading.

When response checking the RO-2A (Beta/Gamma Dose Rate Meter) you may need to remove the source from the lead container and check window open in order to see a response. When finished, return the source to its container, and the container to the radio cabinet. Lock the cabinet to maintain adequate source control, and return the key to the EOF key cabinet.

1. Ludlum Model 2 Count Rate Meter

The Ludlum Model 2 Count rate meter should be used when measuring gamma and beta radiation to determine Beta and Gamma contamination. It is used to take readings on air sample cartridges and filters. It is also used to detect levels of contamination on samples, equipment and on yourself.

The Count rate meter can be used to differentiate between Gamma and Beta radiation by placing a piece of cardboard over the probe. If uncovered readings are higher than covered readings then this is an indication of the presence of Beta radiation. If there is no difference between the readings, you are seeing only Gamma. An indication of Beta would mean you are in the plume. An indication of only Gamma would mean the plume is overhead.

1.1 Battery Check

1.1.1 Place Selector switch to BAT. The needle should deflect to BAT TEST portion of the scale.

- If the battery response does not deflect into the BAT TEST portion of the scale, the two D cell batteries should be replaced.

1.2 Response Check

1.2.1 Press the RES button to ensure that scale reading goes to zero.

1.2.2 Set the Selector switch to X1.

1.2.3 Set the F-S switch to fast. The F-S response toggle switch dampens meter response from 3 seconds (F) to 11 seconds (S).

1.2.4 Set the audio toggle to ON

Attachment 5.1

Page 1 of 5

PROCEDURE NUMBER	REVISION	PAGE
13.9.1	22	13 of 34

- 1.2.5 Slowly pass the probe over the surface of the source at about one centimeter.
- 1.2.6 If the response check was satisfactory; initial, date and check the SAT block on the checklist..
- 1.2.7 If the instrument fails the response check, contact the HP in the Health Physics Center for assistance.

2. Ludlum Model 3 Micro R Meter

The Ludlum Micro R meter should be used for detection of very low level gamma radiation. This instrument is used to determine plume boundaries (10 times background or approximately 100 micro R) and to determine dose rates. The Micro R meter has a range of 0 to 3000 Micro R/hr. When levels exceeding 2000 Micro R/hr are detected, the RO-2A should be used.

The Range selector switch positions for the Micro R meter includes a X0.1 scale. On the meter this indicates a range of 0 to 3 Micro R/hr. Because background is approximately 10 Micro R/hr, this scale will always be pegged. For initial surveys, the meter should be set to the X1 range.

2.1 Battery Check

2.1.1 Place Selector switch to BAT. The needle should deflect to BAT TEST portion of the scale.

- If the battery response does not deflect into the BAT TEST portion of the scale, the two D cell batteries should be replaced.

2.2 Response Check

2.2.1 Press the RES button to ensure that scale reading goes to zero. The RES button should also be pushed when changing ranges to quickly re-zero the meter.

2.2.2 Set the Selector switch to X1.

2.2.3 Set the F-S switch to fast. The F-S response toggle switch dampens meter response from 3 seconds (F) to 11 seconds (S).

2.2.4 Set the audio toggle to ON.

Attachment 5.1
Page 2 of 5

PROCEDURE NUMBER	REVISION	PAGE
13.9.1	22	14 of 34

- 2.2.5 Slowly pass the probe over the surface of the source at about one centimeter.
- 2.2.6 If the response check was satisfactory; initial, date and check the SAT block on the checklist.
- 2.2.7 If the instrument fails the response check, contact the HP in the Health Physics Center for assistance.

3. Eberline Model RO-2A Meter

The Eberline Model RO-2A meter should be used once levels of radiation exceed 2000 Micro R/hr detected by the Micro R meter. The chamber face of the RO-2A is a Beta window of ultra-thin mylar and is covered by a sliding Beta shield to allow Beta/Gamma differentiation. Caution should be taken not to puncture the mylar screen when the Beta shield is open.

The Beta window is moved by first depressing the friction release button located on the side of the instrument case. To slide the window, tilt the case either up or down while depressing the button.

Full instrument response time of the RO-2A is five seconds. This means the meter needle will move from a reading of zero to 90% of full scale in five seconds. To obtain accurate results, the instrument should be moved slowly enough to evaluate the extent of a change in meter reading.

To differentiate between Beta and Gamma radiation, a reading should first be taken with the window open and then with window closed. If there is no difference in readings you are seeing only Gamma. If there is a difference then you are seeing both Gamma and Beta. A reading with both Gamma and Beta detected would indicate that you are in the plume.

3.1 Battery Check

- 3.1.1 The RO-2A has two battery checks with two nine volt batteries for each test. Place the Range Selector switch in each BAT position and verify that the meter indicates above the BATT OK mark.
 - If the battery response does not deflect into the BAT OK portion of the scale, the nine volt batteries should be replaced.

PROCEDURE NUMBER	REVISION	PAGE
13.9.1	22	15 of 34

3.2 Response Check

- 3.2.1 Place the Range Selector switch in the ZERO position and adjust ZERO knob until the meter indicates ZERO (0).
- 3.2.2 Set the Selector Switch to the 0-50 mR/hour position.
- 3.2.3 With the window open, slowly pass the instrument over the source at about one centimeter. (You may need to remove the source from the lead container to obtain a response.)
- 3.2.4 If the response check was satisfactory; initial, date and check the SAT block on the checklist.
- 3.2.5 If the instrument fails the response check, contact the HP in the Health Physics Center for assistance.

Attachment 5.1
Page 4 of 5

PROCEDURE NUMBER	REVISION	PAGE
13.9.1	22	16 of 34

CHECKLIST FOR EQUIPMENT TEST

NOTE: Return the check source to the radio cabinet and lock the cabinet when done response checking instruments. Return the key to the key cabinet.

Instrumentation Kit	Serial Number	Initials/Date & Time	Response Check		Battery Check	
			Sat	Unsat	Sat	Unsat
Micro R Meter						
Beta/Gamma Dose Rate Meter (RO-2A)						
Count Rate Meter/Pancake GM Probe (Frisker/Geiger counter)						
Portable Radio (Check operability with Field Team Coordinator)	N/A		N/A	N/A		
Verify Cell Phone operation	N/A		N/A	N/A	N/A	N/A
Global Positioning System (GPS) Unit			N/A	N/A		
Zero High Range Pocket Dosimeters	N/A		N/A	N/A	N/A	N/A
Zero Low Range Pocket Dosimeters	N/A		N/A	N/A	N/A	N/A
Return Source to Radio Cabinet; lock cabinet; return key to key cabinet.	N/A		N/A	N/A	N/A	N/A
Other (Specify)						

Attachment 5.1
Page 5 of 5

PROCEDURE NUMBER 13.9.1	REVISION 22	PAGE 17 of 34
----------------------------	----------------	------------------

RADIO, CELLULAR PHONE AND GPS OPERATION INSTRUCTIONS

1. Radio Operating Procedures

- a. Turn on the radio.
- b. Set the frequency selector to the F-1 channel.
- c. Place the speaker toggle switch to normal position (speaker open).
- d. Rotate the squelch control counterclockwise until you receive squelch.
- e. Adjust the volume to desired level.
- f. Rotate the squelch control clockwise until the noise just stops. This is the threshold setting. Do not adjust further. Excessive squelch reduces radio sensitivity. If unable to silence squelch, the battery must be replaced. Contact the Field Team Dispatcher for replacement batteries.

2. Radio Transmitting Instructions

NOTE: Continuous transmissions lasting longer than approximately 30 seconds will be automatically interrupted by the repeater.

- a. Hold the radio upright with the speaker-microphone grill two or three inches from your mouth.
- b. Do not interrupt another user. If you do, someone will not be heard.
- c. When preparing to transmit, press the talk switch, and wait approximately one second before talking.
- d. Talk in a slow, clear, normal voice, with brief transmissions.
- e. When finished transmitting, release the talk switch to receive.
- f. State the station you are calling first, then state your identification number (e.g., MUDAC this is EN-2, or EN-2 this is WA-3).

3. Cellular Phone Instructions

- a. The cellular phone is activated automatically when the vehicle's ignition switch is in the ON position (vehicle running or not). If the phone does not activate, check the ON/OFF push button on the left side of the stand. It must be IN for operation.
- b. To place a call:
 - Remove the phone from its stand (or leave in the stand to use the remote microphone), enter the phone number you are calling and press the SND key.
 - When the call is complete, press the END key and hold the CLR key until the number you called is removed from the display.
- c. To receive a call:
 - Remove the phone from its stand, or to use the remote microphone, press the SND key to answer the call. Your phone will be disconnected when the calling party hangs up.

Attachment 5.2

Page 1 of 3

PROCEDURE NUMBER	REVISION	PAGE
13.9.1	22	18 of 34

GPS OPERATING INSTRUCTIONS

1. Start up

- a. Attach the cigarette lighter adapter to the GPS unit.
- b. Press the ON/OFF button.
- c. Select AUX 8, SETUP.
- d. On the SETUP menu, select Coordinates (05) and verify the unit is set to LAT/LONG and DEG/MIN.
- e. Press POS to return to the position screen.
- f. Refer to the default settings provided in the GPS unit box if settings need to be changed. Refer to the Magellan Users Guide for additional detail.

2. Obtaining a Position

NOTE: The unit activation requires the unit to lock onto several satellites. Depending upon the length of time since the last activation, this could take as long as 15 minutes.

- a. Press POS at any time during operation of the unit to display the current position.

3. Saving a Waypoint (position fix)

NOTE: Waypoints should be stored for any locations at which a sample has been taken, or survey readings have been taken which are reported to the EOF.

- a. Press the POS key to display coordinates.
- b. Press ENTER and a field at the top for entering a waypoint name displays.
- c. Use the numeric keypad to enter the necessary letters. Use the right arrow key to display the desired letter. Press Enter to select that letter. Continue to press the numeric keys and right arrow until all letters are entered.
- d. Press ENTER once the name is entered.
- e. Waypoints may be entered automatically. If this option is used, the GPS unit will assign a location code to the waypoint, such as WPxxx, where xxx is a number between 1 and 500. Keep a log of your entries for future reference. This is important if the automatic waypoint option is used.

Attachment 5.2
Page 2 of 3

PROCEDURE NUMBER	REVISION	PAGE
13.9.1	22	19 of 34

GPS OPERATING INSTRUCTIONS, (Cont'd)

4. Viewing Stored Waypoints

- a. Press WPT and use the down arrow to scroll through the waypoints.

5. Deleting a Waypoint

- a. Highlight the waypoint in the catalog, and press CLEAR CLEAR.

6. Transmitting and Recording Position

- a. Verify data is current. Old data is identified with the Old Data symbol, X, on the screen.
- b. Unless instructed otherwise, report location data in decimal format as degrees and minutes.
- c. Always report latitude first.
- d. Do not use north and west designators.

PROCEDURE NUMBER	REVISION	PAGE
13.9.1	22	20 of 34

FIELD RADIATION SURVEYS

1.0 General Area Surveys

- 1.1 Before entering an affected area, perform a background measurement using the Micro-R Meter and record background reading and time on form 968-26097.
- 1.2 As directed by MUDAC, proceed toward the plume using the Emergency Zone Map booklet from the Field Team Kit and GPS unit to determine the location of the plume.
- 1.3 Search for the edge of the plume (defined as ten (10) times background) starting on lowest meter scale and increase scales as radiation levels increase.
- 1.4 When directed by MUDAC, traverse the plume constantly monitoring radiation levels and record locations, dose rates and other required information for the plume centerline and edges on form 968-26097 (indicate type of survey by G for general area). Proceed until the other edge of the plume is identified.
- 1.5 When the Micro-R Meter reads 2000 micro-R/hr (2 mrem/hr) or greater, change to the beta/gamma dose rate instrument, RO-2A.
- 1.6 If the dose rate is greater than 2 mrem/hr, use the beta/gamma dose rate instrument to tell if you are in the plume or just seeing plume shine as follows:

NOTE: All open and closed readings must be done in the same location and not from a moving vehicle. Consider ALARA practices in choosing how many readings to take.

- a. When first entering the plume, and again at centerline, take open and closed window readings at 3 feet and 6 inches above the ground.
- b. If the open and closed window readings are approximately the same, then the plume is probably overhead and has not touched down.
- c. If the open window reading is higher than the closed window reading, (by approximately 20% or greater) then you are probably in the plume.
- d. Record both sets of open and closed window readings.

Attachment 5.3
Page 1 of 2

PROCEDURE NUMBER	REVISION	PAGE
13.9.1	22	21 of 34

- 1.7 If the Micro-R Meter indicates a plume reading of less than 2000 micro-R/hr, you can determine if you are actually in the plume (instead of under it) by repeating Step 1.6 using the Count Rate Meter/GM pancake probe as the instrument, and the cardboard from your notebook as a window.
- 1.8 Do not stop to report data while in the plume. Report the plume edge and centerline readings and their locations to the Field Team Dispatcher at the earliest possible time.
- 1.9 Leave the plume area when not taking readings, but leave the instrument turned on at all times for constant monitoring purposes.
- 1.10 After being in the plume, periodically conduct a survey of yourself and your vehicle using the count rate meter, and if grossly contaminated, advise the Field Team Dispatcher.

2.0 Ground Contamination Surveys

- 2.1 As directed by the Field Team Dispatcher, perform a ground contamination survey:
 - a. Select small area of level ground (3' x 3') with minimal vegetation.

NOTE: The detector probe should not be allowed to touch the ground or come in contact with potentially contaminated vegetation.
 - b. Using the Micro-R Meter and the count rate meter, take readings at ground-level (1-2 inches (5 cm) above the surface) and at waist level, approximately 3 feet above the ground.
 - c. If Micro-R Meter readings are above 2000 micro-R/hr, use the dose rate meter and repeat ground level and waist level readings at the same locations.
 - d. If ground level reading is higher than waist level reading, assume the ground to be contaminated.
- 2.2 Record all four readings on the Field Team Radiation Survey Data Form, 968-26097 (indicate the type of survey by C for contamination).
- 2.3 Repeat the ground contamination survey in several locations.
- 2.4 Select the highest set of readings and report them to the Field Team Dispatcher.

Attachment 5.3

Page 2 of 2

PROCEDURE NUMBER	REVISION	PAGE
13.9.1	22	22 of 34

PORTABLE AIR SAMPLING INSTRUCTIONS

WARNING: Environmental air sampling should be performed sufficiently downwind to minimize dose. All field team personnel should be instructed to contact MUDAC prior to entering the plume and should be made aware of expected dose rates. Air sampling should not be conducted in fields, projected or actual, greater than 2 rem/hr.

When directed by MUDAC, collect an environmental air sample in accordance with the following instructions:

NOTE: Air sampler preparation (sample head assembly) and paperwork initiation should be performed outside the plume. Test operate the air sampler and determine CFM flow setting prior to entering the plume to reduce risk of exposure. Refer to steps 9 and 10 of this Attachment.

1. Use a portable air sampler, equipped with a two-inch sample head, to obtain particulate and radioiodine samples.
2. Continue to monitor your exposure during performance of this procedure.

NOTE: During drills, use the charcoal cartridges marked for drill use. DO NOT use silver zeolite cartridges during drills.

3. Insert the silver zeolite cartridge with the arrow pointing in the direction of air flow. Refer to the diagram in this Attachment.
4. Insert a clean two-inch filter paper, (spongy side facing outward), into the air sample head. Refer to the diagram in this Attachment.
5. Proceed to assigned sample location.

WARNING: Potential hazard of explosion or fire during connection of the sampler's leads to the vehicle's battery terminals exists.

6. Connect the sampler's positive lead to the vehicle's battery first, then connect the negative lead to a ground away from the battery's negative terminal. A ground connection can be any metal object within the vehicle's engine compartment.
7. Leave vehicle engine running while operating the air sampler to assure constant voltage.

Attachment 5.4

Page 1 of 4

PROCEDURE NUMBER	REVISION	PAGE
13.9.1	22	23 of 34

8. Ensure the following conditions of operation are met:
 - If at all possible, do not place sampler on a known contaminated surface
 - Keep sampler away from vehicle exhaust gases
 - Do not point air sampler inlet toward any object which may restrict air flow
 - Do not stand in front of sampler inlet when running or allow loose clothing to restrict air flow
 9. Turn the air sampler on. Determine initial flow rate from the rotometer on the side of the air sampler.
 10. If the flow rate is less than one or greater than five CFM, the air sample will be invalid. Leave the plume and contact the Field Team Coordinator for further instructions.
 11. Perform area dose rate survey for sample location.
 12. Return to the vehicle's interior and record start flow rate, sample start time and sample location dose rate on the Sample Identification Form (Form 968-19324).
 13. Based on air sampler flow rate, determine the sample time necessary to obtain a sample of 10 cubic feet.
- NOTE: When air sampling is complete, disconnect the negative lead first, then the positive lead.
14. Upon completion of sampling, note stop flow rate and sample stop time, then turn off and disconnect sampler.
 15. Leave the area of the plume to complete your documentation following the instructions in Attachment 5.5.
 16. Label the plastic bags for the filter and charcoal cartridges with the sample identification number, location, date, and time collected.
 17. If using charcoal cartridge vs. Silver Zeolite, purge noble gases by reconnecting air sampler to vehicle battery and drawing clean air through filter and cartridge for a minimum of 2 minutes.

Attachment 5.4
Page 2 of 4

PROCEDURE NUMBER	REVISION	PAGE
13.9.1	22	24 of 34

18. Disassemble sample head to allow access to the particulate filter and the cartridge.
19. Determine filter and cartridge dose rate or count rate by placing the appropriate instrument detector on the inlet side of the filter or cartridge.
20. Record field iodine and particulate results in Remarks Section of Sample Identification Form and report to Field Team Coordinator.
21. Record sample readings on Sample Identification Form (968-19324).
22. Remove the filter (using tweezers) and the cartridge from sample head and place filter and cartridge in separate plastic bags then seal bags.
23. When requested by MUDAC, perform a field analysis of the cartridge or particulate filter by doing the following steps:


NOTE: If the sample must be measured by dose rate meter, call the dose rate in to MUDAC and skip step b.

 - a. Obtain background count rate (should be less than 500 cpm) and cartridge or filter count rate (see Step 18 above) and record on Attachment 5.6.
 - b. Calculate the $\mu\text{Ci/cc}$ of Iodine Activity or Particulate Activity using the equations in Step 1 and Step 2 of Attachment 5.6.
24. Survey team members for contamination. If contaminated, advise the Field Team Dispatcher.
25. Transport the samples, with Sample Identification Forms, as directed by the Field Team Coordinator. Ensure that particulate filters and the corresponding cartridges are transported together and that Sample Identification Forms accompany the samples.


Attachment 5.4
Page 3 of 4

PROCEDURE NUMBER	REVISION	PAGE
13.9.1	22	25 of 34

SAMPLE HEAD DIAGRAM



Sample Head - Assembled



Sample Head - Disassembled

970713
Nov 1997

**Filter Cartridge and Sample Head for High Volume Air Sampling Pumps
Model CFH-30**

Attachment 5.4
Page 4 of 4

PROCEDURE NUMBER	REVISION	PAGE
13.9.1	22	26 of 34

SAMPLE IDENTIFICATION FORM (968-19234) INSTRUCTIONS

1. **SAMPLE IDENTIFICATION FORM**

List one sample per form. For air samples, use one sample form and one sample identification number for both the cartridge and particulate filter. Attach one copy of the form to the cartridge and one to the particulate filter.

2. **SAMPLE IDENTIFICATION NUMBER DESIGNATION**

SAMPLE ID NUMBERS will be in a two segment alpha-numeric code using the following format:

FIELD TEAM

AA0

SEQUENCE

000

FIELD TEAM CODES

Use a two-letter and single number designator, (e.g., EN-1 for Energy Northwest Field Team 1).

SEQUENCE

Use sequential numbers for each team throughout an event, (e.g., 003 for the third sample taken by a given team).

3. **SAMPLE TYPE**

Describe the type of sample being collected-air, soil, vegetation, water, etc.

4. **FIELD TEAM SAMPLE LOCATION/DESIGNATION**

Use sample station numbers where they exist, such as continuous environmental air sampling stations (e.g., Sample Station 3). Where no sample station number exists, as in emergency field samples, enter the GPS location.

Attachment 5.5

PROCEDURE NUMBER 13.9.1	REVISION 22	PAGE 27 of 34
----------------------------	----------------	------------------

AIR SAMPLING WORKSHEET

Sample No. _____

Analysis Time _____

Analyst _____

1. Cartridge Filter: AgZ Filter

Charcoal Filter

(Sample CPM _____) - (Background CPM _____) = Net CPM _____

$$\frac{\text{Net CPM}}{(1.89 \times 10^8) \times (\text{sample volume ft}^3)} = \text{_____ } \mu\text{Ci/cc I Activity}$$

NOTE 1: $1.89 \times 10^8 = 0.003 \text{ (eff)} \times 2.83 \times 10^4 \text{ cc/ft}^3 \times 2.22 \times 10^6 \text{ dpm}/\mu\text{Ci}$

NOTE 2: If using charcoal cartridge, ensure cartridge is purged of noble gases.

2. Particulate Filter

(Sample CPM _____) - (Background CPM _____) = Net CPM _____

$$\frac{\text{Net CPM}}{(5.65 \times 10^9) \times (\text{sample volume ft}^3)} = \text{_____ } \mu\text{Ci/cc Particulate Activity}$$

NOTE: $5.65 \times 10^9 = 0.09 \text{ (eff)} \times 2.83 \times 10^4 \text{ cc/ft}^3 \times 2.22 \times 10^6 \text{ dpm}/\mu\text{Ci}$

Attachment 5.6

PROCEDURE NUMBER	REVISION	PAGE
13.9.1	22	28 of 34

ENVIRONMENTAL TLD AND FIXED AIR SAMPLE RETRIEVAL INSTRUCTIONS

1.0 ENVIRONMENTAL TLD RETRIEVAL

Radiological Emergency Manager/Field Team Coordinator Duties

- 1.1 Consult with the Washington DOH representative at the Emergency Operations Facility (EOF) and determine the need for collection and replacement of environmental TLDs during the emergency.

NOTE: If possible, involve the Radiological Environmental Monitoring Program (REMP) Supervisor in any nonscheduled collection or deployment of environmental TLDs.

- 1.2 When collection is determined advisable, dispatch an experienced REMP staff member as part of an Environmental Field Team, to replace the ANNUAL TLD badges at selected locations as described in CI 4.10 and CI 4.11.

NOTE: Copies of CI 4.10 and CI 4.11 are in the document packet of the Environmental Field Team kit located in the MUDAC emergency supply cabinet.

REMP Staff Member Duties

- 1.3 Contact the Energy Northwest TLD Administrator to obtain replacement environmental TLDs for distribution.
- 1.4 Ensure that the required number of TLDs are provided for each exchange group as directed by the Radiological Emergency Manager (REM).
- 1.5 Contact the Field Team Coordinator regarding radiological conditions in the field, and follow his/her directions on individual radiation protection measures.
- 1.6 Proceed to the TLD stations as directed by the Field Team Coordinator.
- 1.7 Exchange only the ANNUAL TLDs.
- 1.8 When the TLDs have been exchanged, return to the Health Physics Center and turn them in to the Health Physics Center Staff for processing.

Attachment 5.7
Page 1 of 2

PROCEDURE NUMBER	REVISION	PAGE
13.9.1	22	29 of 34

2.0 FIXED AIR SAMPLE RETRIEVAL

Radiological Emergency Manager/Field Team Coordinator Duties

2.1 Consult with the Washington DOH representative at the EOF and determine the need for collection of fixed air samples during the emergency.

NOTE: If possible, involve the REMP Supervisor in any nonscheduled collection of fixed air samples.

2.2 If collection is determined advisable, dispatch experienced REMP personnel as part of an Environmental Field Team to collect air samples at selected locations in accordance with CI 4.12 and CI 4.13.

NOTE: Copies of CI 4.12 and CI 4.13 are in the document packet of the Environmental Field Team kit located in the MUDAC emergency supply cabinet.

REMP Staff Member Duties

2.3 Contact the Field Team Coordinator regarding radiological conditions in the field and follow his/her directions on radiation protection measures to be taken.

2.4 Proceed to the fixed air sample stations as directed by the Field Team Coordinator.

2.5 Collect the air samples.

NOTE: If the emergency involved a radioactive release, calculations of the volume of air sampled may need to be restricted to the time during which the plume or puff was over the station. Request guidance from the Field Team Coordinator if the fixed air sample was in the path of a release during the sampling period.

2.6 When the air samples have been collected, return to the Health Physics Center and turn them in to the Health Physics Center Staff for processing.

PROCEDURE NUMBER	REVISION	PAGE
13.9.1	22	30 of 34

FIELD TEAM COORDINATOR CHECKLIST

DATE _____

	<u>Actions</u>	<u>Time Completed</u>	<u>Initials</u>
1.	Sign in on board, obtain supply drawer from EOF supply cabinet, and notify the REM of your availability.	_____	_____
2.	Brief the field team coordinators from other agencies supplying field teams and reach a consensus about management of their field teams.	_____	_____
3.	Determine current year-to-date exposure of Energy Northwest field team members prior to deployment.	_____	_____
4.	Assign field team members and a designate team identification number (one HP and one non HP per team, if possible).	_____	_____
5.	Ensure field teams have transportation and other equipment.	_____	_____
6.	Direct the Field Team Dispatcher(s) to brief the teams approximately each 30 minutes on current radiological projections or other appropriate information about emergency conditions.	-ongoing-	
7.	If necessary, assign an individual to act as field team recorder.	_____	_____
8.	Interface with the Dose Projection HP to determine projected plume path and emergency worker dose factor.	-ongoing-	
9.	Develop a strategy for assigning Field Teams initially, verifying plume path, and dealing with EOF inaccessibility.	-ongoing-	
10.	Direct field teams to perform field surveys per field team survey instructions contained in this procedure.	-ongoing-	
11.	Provide completed Field Team data summary maps to the Dose Projectionist Health Physicist (DPHP) as new information is developed. During rapidly changing conditions, try to do this at least every 30 minutes.	-ongoing-	
12.	Provide field team air sample data to the Dose Projection Health Physicist (DPHP) for use in calculating dose projections.	-ongoing-	
13.	If requested to assist with river evacuation monitoring, implement PPM 13.9.8 (kits are in MPF).	_____	_____
14.	Direct the dispatcher to periodically ask for field team dosimetry readings. Keep exposure ALARA.	-ongoing-	

Attachment 5.8
Page 1 of 2

PROCEDURE NUMBER 13.9.1	REVISION 22	PAGE 31 of 34
-----------------------------------	-----------------------	-------------------------

<u>Actions</u>	<u>Time Completed</u>	<u>Initials</u>
15. Arrange for field team replacement supplies, as necessary.	-ongoing-	
16. Provide completed Field Team Summary Maps to the REM.	-ongoing-	
17. Notify field teams when decision is made to recommend KI.	_____	_____
18. Upon shift change or change to State control, brief replacements.	_____	_____
19. Upon shift change or termination of the emergency:		
a. Prepare an individual After Action Report. Refer to PPM 13.13.4.	_____	_____
b. Deliver After Action Report, logs, and all field team work sheets to the REM.	_____	_____

Attachment 5.8
Page 2 of 2

PROCEDURE NUMBER	REVISION	PAGE
13.9.1	22	32 of 34

FIELD TEAM BRIEFING WORKSHEET

Date _____
Time _____

Plant Status: _____

Initial Briefing: 1) Cell Phone: EN-1: _____ EN-2: _____ EN-3: _____
2) YTD Exposures: _____

Emergency Classification: _____

Release Point: _____ Release Type: _____

Environmental Release Time: _____ Duration: _____

Projected Dose/Location: _____

Weather: Wind Direction From: _____ Speed: _____

Forecast: _____

PAD for Public: _____

RADIOLOGICAL ASSESSMENT

Expected Conditions: __Hi Rad __Hi Contamination __Hi Airborne

Protective Clothing: __None __Single

Exposure Limitations: Individual Dose Limits _____

Dose/Dose Rate to Notify MUDAC: _____

Roll Call/Acknowledgment:

TEAM NO.	ACKNOWLEDGED AT: (Time)	COMMENTS

Attachment 5.9

PROCEDURE NUMBER	REVISION	PAGE
13.9.1	22	33 of 34

FIELD TEAM KIT REPLENISHMENT LOG

Date _____ Team Members _____

FIELD TEAM MEMBERS: List below the items used from each kit during the drill/event so that the kits can be restocked appropriately. Include the completed log with your After Action Report.

INSTRUMENTATION KIT:

AIR SAMPLING KIT:

PROTECTIVE CLOTHING KIT:

FIELD SAMPLING KIT:

MISCELLANEOUS (FORMS, MAPS, PROCEDURES, ETC.)

Attachment 5.10

PROCEDURE NUMBER 13.9.1	REVISION 22	PAGE 34 of 34
----------------------------	----------------	------------------

ENERGY NORTHWEST		USE CURRENT REVISION
WNP-2 PLANT PROCEDURES MANUAL		
PROCEDURE NUMBER *13.9.5	APPROVED BY TM - Revision 13	DATE 02/07/00
VOLUME NAME EMERGENCY PLAN IMPLEMENTING PROCEDURES		
SECTION ENVIRONMENTAL FIELD MONITORING		
TITLE ENVIRONMENTAL SAMPLE COLLECTION		

TABLE OF CONTENTS

	<u>Page</u>
1.0 PURPOSE	2
2.0 REFERENCES	2
3.0 PRECAUTIONS AND LIMITATIONS	2
4.0 PROCEDURE	3
4.1 Collecting Soil Samples	3
4.2 Collecting Snow and Ice Samples	4
4.3 Collecting Vegetation and Garden Produce Samples	5
4.4 Collecting Milk Samples	6
4.5 Collecting Water Samples	7
5.0 ATTACHMENTS	7
5.1 Sample Identification Form Instructions	8

PROCEDURE NUMBER 13.9.5	REVISION 13	PAGE 1 of 8
-----------------------------------	-----------------------	-----------------------

1.0 PURPOSE

This procedure describes the methods to be employed by Environmental Field Teams for collecting environmental samples (described below) during an emergency.

2.0 REFERENCES

- 2.1 FSAR, Chapter 13.3, Emergency Plan, Sections 5.2.2 and 5.13.4
- 2.2 PPM 13.9.1, Environmental Field Monitoring Operations
- 2.3 CI 4.14, Milk Sampling
- 2.4 CI 4.19, Drinking, Discharge and River Water Sample Collection
- 2.5 CI 4.21, Groundwater Collection
- 2.6 Sample Identification Form, 968-19324

3.0 PRECAUTIONS AND LIMITATIONS

- 3.1 When collecting environmental samples, use appropriate contamination protection, i.e., gloves, shoe covers, coveralls, etc., before proceeding.
- 3.2 Prior to, and after sample collection, survey your hands (gloves) for contamination and change gloves as necessary to reduce the chances of contaminating environmental samples.
- 3.3 After completing sample collection, perform a whole body frisk. If you detect contamination, advise the Field Team Dispatcher and take necessary precautions to keep the Field Team vehicle interior free of contamination.
- 3.4 Refer media requests for information to Joint Information Center (JIC) personnel.

PROCEDURE NUMBER 13.9.5	REVISION 13	PAGE 2 of 8
----------------------------	----------------	----------------

4.0 PROCEDURE

This procedure applies to environmental samples collected during declared emergencies, coordinated with the Washington State Department of Health, normally in locations outside the WNP-2 Exclusion Area boundary. Soil and vegetation samples can also be collected within the Exclusion Area boundary to quantify and qualify the amount of radioactive material deposited by the passing plume.

The Radiological Emergency Manager, in consultation with representatives of the Washington State Department of Health (DOH) should determine the disposition of environmental samples.

4.1 Collecting Soil Samples

4.1.1 Proceed to the soil sampling location as directed by the Field Team Dispatcher and perform radiation survey per PPM 13.9.1.

4.1.2 With indelible pen, label a new, clean, dry plastic bag with sample identification number. Refer to Attachment 5.1.

NOTE: Clipped vegetation obtained during soil sample collection may be saved and used for Section 3.3 (Vegetation Samples) samples of this procedure.

4.1.3 Select an area with minimum vegetation. Clip and remove remaining vegetation down to the soil surface and discard rocks larger than one cm diameter and any obviously foreign material.

4.1.4 Use a small digging tool from the kit to skim off a one square foot layer of soil no more than one inch deep to give a sample of two to three pounds.

4.1.5 Place soil sample in the labeled plastic bag, press zip-lock to close or twist, as appropriate, and seal shut with masking tape.

4.1.6 Complete the applicable parts of the Sample Identification Form, No. 968-19324.

4.1.7 Check each sample container with a dose rate meter. Record the reading on the sample container and on the Sample Identification Form.

4.1.8 Mark the approximate sample location area by driving a ribboned stake in the ground, and note the sample's identification number on the stake.

PROCEDURE NUMBER	REVISION	PAGE
13.9.5	13	3 of 8

4.1.9 Deliver the soil samples, radiation survey data, and Sample Identification Forms as directed by the Field Team Dispatcher.

4.2 Collecting Snow and Ice Samples

4.2.1 Proceed to the snow or ice sampling location as directed by the Field Team Dispatcher and perform radiation survey per PPM 13.9.1.

4.2.2 Select a sample area from the general location that has not been subjected to non-meteorological disturbances (e.g., plowing, snowmobiles, pedestrians, etc.).

4.2.3 Consider the following factors in selecting a sample area:

- a. Rate of snowfall since or during a release in order to determine what level of snow sample would give meaningful result.
- b. Weather conditions since or during release that may affect drifting such as wind speed and direction.
- c. Weather conditions since or during release that may affect snow volume, such as temperature change, rain, or sunshine.

4.2.4 Measure the selected area to be sampled in units of square feet.

4.2.5 With indelible pen, label a new, clean, plastic bag with the sample identification number. Refer to Attachment 5.1.

NOTE: Snow fall before, during, and after the release may have drifted. Melting and freezing and/or rain may fix the snow deposition in an ice layer that is not affected by winds. These possibilities should be considered and existing weather conditions used to determine the area to be sampled.

4.2.6 Identify a snow layer of interest by excavating the snow immediately adjacent to the sampling area and performing a survey of the snow cross-section. Alternatively, samples may be taken and surveyed for every inch of snow depth.

NOTE: A snow sample volume (to give meaningful data) should exceed three liters of melted snow. Loose snow volume is approximately four times its liquid volume. Icy snow is approximately twice its liquid volume. The snow can be packed in the collection bag.

PROCEDURE NUMBER	REVISION	PAGE
13.9.5	13	4 of 8

- 4.2.7 Using a digging tool from the kit, remove snow to a depth sufficient to collect a snow layer of interest.
- 4.2.8 Estimate the thickness and depth of the snow layer collected and record the information on the Sample Identification Form.
- 4.2.9 Complete the applicable parts of the Sample Identification Form, No. 968-19324.
- 4.2.10 Check each sample container with a count rate or dose rate meter and record the reading on the sample container, and on the Sample Identification Form.
- 4.2.11 Mark the approximate sample location area by driving a ribboned stake in the ground, and note the sample's identification number on the stake.
- 4.2.12 Deliver the snow or ice sample, radiation survey data and Sample Identification Forms as directed by the Field Team Dispatcher.

4.3 Collecting Vegetation and Garden Produce Samples

- 4.3.1 Proceed to the location as directed by the Field Team Dispatcher to perform a vegetation survey in accordance with PPM 13.9.1. Inform the dispatcher if there is no vegetation in the area.
- 4.3.2 With indelible pen, label a new, clean, plastic bag with the sample identification number. Refer to Attachment 5.1.
- 4.3.3 Wearing clean rubber or plastic gloves, collect a representative sample of vegetation from within an approximate 30 x 30 foot area using the following guidelines:
 - a. Obtain enough natural vegetation to fill a 12" x 15" bag, or approximately two pounds of material.
 - b. Clip off grasses at ground level.
 - c. Perennial vegetation samples should include cuttings from growing ends.
 - d. Cattle farm vegetation samples should be representative of dairy and/or beef animal foodstuffs (grains, pasture grass etc.).
 - e. Garden produce should be collected as directed by Field Team Dispatcher from designated garden plots.

PROCEDURE NUMBER	REVISION	PAGE
13.9.5	13	5 of 8

- f. Plant roots, woody stems, and soil should not be included in vegetation samples.
- 4.3.4 Check each sample container with a dose rate meter. Record the reading on the sample container and on the Sample Identification Form, No. 968-19324.
- 4.3.5 Mark the approximate sample location area by driving a ribboned stake in the ground and note the sample's identification number on the stake.
- 4.3.6 Deliver the samples, radiation survey data and Sample Identification Forms as directed by the Field Team Dispatcher.

4.4 Collecting Milk Samples

NOTE: The Radiological Emergency Manager (REM) or Field Team Coordinator will dispatch an experienced Radiological Environmental Monitoring Programs (REMP) individual, with a milk sampling kit and a copy of the milk sampling procedure (CI 4.14), as part of an Environment Field Team milk sampling operation.

- 4.4.1 Confer with the REM or Field Team Coordinator for radiological conditions in the sampling locations and follow directions on radiation protection measures that may need to be taken.
- 4.4.2 Proceed to the milk sampling locations as directed by the Field Team Dispatcher or per directions given in CI 4.14.
- 4.4.3 Perform a radiation survey at that location per PPM 13.9.1.
- 4.4.4 Record sample location, milk producer, time and date of sampling on the Sample Identification Form, No. 968-19324, and assign a sample identification number according to Attachment 5.1.
- 4.4.5 Collect a one-gallon sample of raw milk (use a 1 gallon cubitainer) from the milk supplier per CI 4.14.
- 4.4.6 With an indelible marker, label the container with the sample identification number. Refer to Attachment 5.1.
- 4.4.7 Deliver the samples, survey data and Sample Identification Forms as soon as possible to prevent spoilage, to a location as directed by the Field Team Dispatcher.

PROCEDURE NUMBER	REVISION	PAGE
13.9.5	13	6 of 8

4.5 Collecting Water Samples

- 4.5.1 Proceed to the water sample locations as directed by the Field Team Dispatcher.
- 4.5.2 Perform radiation survey at each location in accordance with PPM 13.9.1.
- 4.5.3 Fill a one gallon container with water from the supply being sampled. Refer to CI 4.19 or 4.21 as appropriate.
- 4.5.4 With an indelible marker, label the container with the sample identification number. Refer to Attachment 5.1.
- 4.5.5 Complete the applicable parts of the Sample Identification Form, No. 968-19324.
- 4.5.6 Check each sample container with a dose rate meter and record the reading on the sample container, and on the Sample Identification Form.
- 4.5.7 Mark the approximate area the sample was taken from by driving a ribboned stake in the ground, and note the sample's identification number on the stake.
- 4.5.8 Deliver the water samples and Sample Identification Forms as directed by the Field Team Dispatcher.

5.0 ATTACHMENTS

5.1 Sample Identification Form Instructions

PROCEDURE NUMBER 13.9.5	REVISION 13	PAGE 7 of 8
-----------------------------------	-----------------------	-----------------------

SAMPLE IDENTIFICATION FORM INSTRUCTIONS

1. SAMPLE IDENTIFICATION FORM

List one sample per form. For air samples, use one sample form and one sample identification number for both the cartridge and particulate filter. Attach one copy of the form to the cartridge and one to the particulate filter.

2. SAMPLE IDENTIFICATION NUMBER DESIGNATION

SAMPLE ID NUMBERS will be in a two segment alpha-numeric code using the following format:

FIELD TEAM

AA0

SEQUENCE

000

FIELD TEAM CODES

Use a two-letter and single number designator, (e.g., EN1 for Energy Northwest Field Team 1).

SEQUENCE

Use sequential numbers for each team throughout an event, (e.g., 007 for the seventh sample taken by a given team).

3. SAMPLE TYPE

Describe the type of sample being collected-air, soil, vegetation, water, etc.

4. FIELD TEAM SAMPLE LOCATION/DESIGNATION

Use sample station numbers where they exist, such as continuous environmental air sampling stations, e.g., Sample Station 3. Where no sample station number exists, as in emergency field samples, use the latitude and longitude provided by the Global Positioning System (GPS) unit.

Attachment 5.1

PROCEDURE NUMBER 13.9.5	REVISION 13	PAGE 8 of 8
----------------------------	----------------	----------------



USE CURRENT REVISION

WNP-2
PLANT PROCEDURES MANUAL

PROCEDURE NUMBER *13.10.16	APPROVED BY DWC - Revision 2	DATE 02/07/00
VOLUME NAME EMERGENCY PLAN IMPLEMENTING PROCEDURES		
SECTION PLANT EMERGENCY FACILITIES		
TITLE CHEMISTRY/EFFLUENT MANAGER DUTIES		

TABLE OF CONTENTS

1.0 PURPOSE 2

2.0 REFERENCES 2

3.0 PROCEDURE 2

 3.1 Chemistry/Effluent Manager Responsibilities 2

4.0 ATTACHMENTS 4

 4.1 Area Radiation Monitor (ARM) Reading Worksheet 5

PROCEDURE NUMBER 13.10.16	REVISION 2	PAGE 1 of 5
-------------------------------------	----------------------	-----------------------

1.0 PURPOSE

The purpose of this procedure is to describe the emergency responsibilities and duties of the Chemistry/Effluents Manager.

2.0 REFERENCES

- 2.1 FSAR, Chapter 13.3, Emergency Plan, Section 2
- 2.2 PPM 13.8.1, Emergency Dose Projection System Operations
- 2.3 PPM 13.13.4, After Action Reporting
- 2.4 Emergency Response Log, Form No. 968-23895

3.0 PROCEDURE

3.1 Chemistry/Effluent Manager Responsibilities

- 3.1.1 Upon notification of an Alert, Site Area, or General Emergency, or if so directed, proceed to the Technical Support Center (TSC).
- 3.1.2 Obtain dosimetry and log in on the emergency RWP.
- 3.1.3 Present your keycard to the TSC cardreader located by the outer hallway access door to establish electronic Personnel Accountability.
- 3.1.4 Enter your name on the TSC Accountability Log located on the table just inside the TSC to establish manual Personnel Accountability.
- 3.1.5 Write your name on the TSC staffing board in the space next to your emergency position.
- 3.1.6 If you leave the TSC temporarily, inform the TSC Manager of your destination and approximate time of return. Note your destination on the TSC Personnel Accountability Log.
- 3.1.7 Upon arrival at the TSC, ensure dose projection computers are turned on and begin to monitor Area Radiation Monitor (ARM) readings from any TSC computer terminal that can access the Rad Status screen on PDIS.
- 3.1.8 If necessary, boot up the PC at the work station. Log onto the LAN using the appropriate password:

- TSC: USERID = TSC Password = TSC1

PROCEDURE NUMBER	REVISION	PAGE
13.10.16	2	2 of 5

3.1.9 Start PDIS by double-clicking on the appropriate PDIS icon on the Windows desktop. Minimize PDIS, and start QEDPS.

- When both programs are running, window back and forth for data selection and dose projection input.

3.1.10 Access RSTAT by pulling down the EOP menu from the PDIS menu bar. Select Rad Status to obtain key radiation monitor data, meteorological, and effluent data.

- a. Other PDIS pulldown menus may be selected to view other plant parameters or trends as desired.
- b. Contact the Computer Engineer in the TSC for assistance as needed.

NOTE: Use <CTRL I> to print the Radiological Parameters screen so that the pull down menu does not obscure data.

3.1.11 Monitor and periodically print the Radiological Parameters Screen and indicate changes in ARM readings with either an up or down arrow. Provide a copy of the printout or Attachment 4.1 to the RPM and Admin Support for distribution to TSC staff.

3.1.12 Keep the Radiation Protection Manager (RPM) informed of readings and immediately notify the RPM of abnormal trends.

3.1.13 RSTAT displays only Reactor Building ARMs. Turbine Building and Radwaste Building ARM data should be requested from the Control Room via the TSC Information Coordinator.

3.1.14 Establish contact with the EOF Dose Projection HP for status updates.

3.1.15 Perform Offsite Dose Projections using QEDPS until relieved by the Dose Projection HP in the EOF or when requested by the RPM. Perform offsite dose projection calculations in accordance with PPM 13.8.1.

3.1.16 Participate in TSC staff decisions when chemistry tasks are being considered in order to ensure impacts on plant systems are properly analyzed, and an appropriate priority is assigned.

3.1.17 Confer with the Radiation Protection Manager (RPM) concerning the potential for radiological problems occurring during operational activities.

PROCEDURE NUMBER	REVISION	PAGE
13.10.16	2	3 of 5

- 3.1.18 Confer with the Maintenance Manager to coordinate Operations and Maintenance activities.
- 3.1.19 Keep the TSC Manager informed of all significant operational matters and assist in assessing preventative or corrective actions.
- 3.1.20 Review special procedures with the Shift Manager and obtain appropriate approval. If special procedures require prior NRC approval, coordinate NRC review with the Plant/NRC Liaison.
- 3.1.21 If chemistry support is necessary for environmental field team sample analysis, contact appropriate chemistry staff.
- 3.1.22 Refer any incoming Media calls to the Joint Information Center (JIC).
- 3.1.23 Upon shift change, fully brief your relief as to events, and status of actions being taken.
- 3.1.24 Upon shift change or termination of the emergency:
 - a. Prepare an individual After Action Report, refer to PPM 13.13.4.
 - b. Deliver After Action Reports, Logs, Checklists, and Status Board Logs to the TSC Manager.

4.0 ATTACHMENTS

4.1 Area Radiation Monitor (ARM) Reading Worksheet

PROCEDURE NUMBER	REVISION	PAGE
13.10.16	2	4 of 5

**AREA RADIATION MONITOR (ARM)
READING WORKSHEET**

Chemistry/Effluent Manager:

Date:

ARM #	DESCRIPTION	RANGE mR/HR	BLDG ELEV	TIME	TIME	TIME	TIME	TIME	TIME	TIME	TIME
1	Fuel Pool W	10 ² -10 ⁶	RX606								
34	Hi Range Dryer/Sep E	10 ¹ -10 ⁶ R/hr	RX 606								
8	SGTS Filter Area N	1-10 ⁴	RX572								
6	ROA HVAC S	1-10 ⁴	RX572								
4	CRD E	1-10 ⁴	RX 522								
5	CRD W	1-10 ⁴	RX 522								
33	Hi Range NW Entry	10 ¹ -10 ⁶ R/hr	RX501								
7	Neutron Mon. (TIP)	1-10 ⁴	RX 501								
32	Hi Range NE Valve Room	10 ¹ -10 ⁶ R/hr	RX 471								
24	Equip Access Area West Side	1-10 ⁴	RX 471								
10	RHR 1 Pump Room 1 SW	1-10 ⁴	RX 422								
9	RHR 2 Pump Room 2 W	1-10 ⁴	RX 422								
11	RHR 3 Pump Room 4 NE	1-10 ⁴	RX 422								
23	CRD Pump Room SE	1-10 ⁴	RX 422								
12	RCIC Pump Room 3 N	1-10 ⁴	RX 422								
13	HPCS Pump Room 6 SE	1-10 ⁴	RX 422								
2	Fuel Pool W (Criticality Monitor)*	1-10 ⁴	RX606								
3	New Fuel Area NE	10 ² -10 ⁶	RX 606								
3a	New Fuel Pit NE*	10 ² -10 ⁶	RX606								
14	TG Front Std. E*	1-10 ⁴	TG501								
15	TG Bldg Entry SE*	1-10 ⁴	TG441								
16	Rx Feed Pump Room 1A*	1-10 ⁴	TG441								
17	Rx Feed Pump Room 1B*	1-10 ⁴	TG441								
18	Condensate Pumps W*	1-10 ⁴	TG441								
19	Main Control Room	1-10 ⁴	RW501								
20	Valve Room E*	1-10 ⁴	RW467								
21	Valve Room W*	1-10 ⁴	RW467								
22	Sample Room (Chem Lab)*	1-10 ⁴	RW487								
25	Hot Machine Shop*	1-10 ⁴	RW487								
26	Contaminated Tool Rm*	1-10 ⁴	RW467								
27	Waste Surge Tank Tk Area*	1-10 ⁴	RW437								
28	Tank Corridor N*	1-10 ⁴	RW437								
29	Tank Corridor S*	1-10 ⁴	RW437								
30	Radwaste Control Room*	1-10 ⁴	RW467								

* Contact the Control Room via the Information Coordinator for these ARM readings.

Attachment 4.1

PROCEDURE NUMBER 13.10.16	REVISION 2	PAGE 5 of 5
------------------------------	---------------	----------------