



PECO NUCLEAR

A Unit of PECO Energy

John Doering, Jr.
Vice President
Peach Bottom Atomic Power Station

PECO Energy Company
1848 Lay Road
Delta, PA 17314-9032
717 456 4000
Fax 717 456 4243
E-mail: jdoering@peco-energy.com

10 CFR 50.55a

January 31, 2000

Docket No. 50-278

License No. DPR-56

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Subject: Peach Bottom Atomic Power Station, Unit 3
Submittal of Inservice Inspection Summary Report

Dear Sir/Madam:

In accordance with the PECO Energy Company Third, Ten-Year Interval, Inservice Inspection (ISI) Program, inservice inspections were completed on Peach Bottom Atomic Power Station, Unit 3 during the November 2, 1997 through October 27, 1999, twelfth refueling outage period. As required by ASME Section XI, IWA-6230 ("Summary Report Submittal"), attached is the Inservice Inspection (ISI) Summary Report.

Also attached is an evaluation of the PBAPS, Unit 3 core shroud examination results. The Unit 3 core shroud H-3 and H-4 welds were examined during the twelfth refueling outage period and will have fluence levels which exceed 5×10^{20} n/cm² at the next scheduled inspection. The attached evaluation report is being submitted as required by Table 2-1 of "BWR Vessel and Internals Project BWR Core Shroud Inspection and Flaw Evaluation Guidelines," BWRVIP-76, dated November 1999.

If you have any questions, please contact us.

Very truly yours,

John Doering, Jr.
Vice President
Peach Bottom Atomic Power Station

A047

January 31, 2000
Page 2

GLJ/ARP/CKG/RES

Enclosures

CCN: 00-14014

cc: H. J. Miller, Administrator, Region I, USNRC
A. C. McMurtray, USNRC Senior Resident Inspector, PBAPS

PEACH BOTTOM ATOMIC POWER STATION

UNIT 3

INSERVICE INSPECTION

SUMMARY REPORT

FOR THE

NOVEMBER 2, 1997 TO OCTOBER 27, 1999

PERIODIC INSPECTION

TABLE OF CONTENTS

		<u>Pages</u>
Form NIS-1	Owner's Report for Inservice Inspections	2
Introduction		1
Section 1	Summary of Inservice Inspections Summary of Augmented Inspections	43 A52
	Results Prior to and During Unit #3, 12 th Refuel Cycle	
Section 2	Summary of Reportable Conditions Observed During Inservice Inspection	2
Section 3	Summary of ASME XI Repairs and Replacements	6

FORM NIS-1
INSERVICE INSPECTION REPORT

PECO ENERGY COMPANY
965 Chesterbrook Blvd.
Wayne, Pa. 19087-5691

Date: January 24, 2000

Peach Bottom Atomic Power Station - Unit 3
1848 Lay Road
Delta, Pennsylvania 17314

Inspection Date:
November 2, 1997 to
October 27, 1999

Commercial Service Date: December 23, 1974

Gross Generating Capability: 1159 Mwe

Pennsylvania State Identification Number: B116764 (NB 3904)

Component Identification ASME Class 1, 2, and 3 Components,
Primary Containment and other Augmented Components.

Abstract of Inspections Performed, Conditions Observed,
Corrective Measures Recommended and Taken are Attached.

Section 1 - Summary of Inservice Inspection Results

Section 2 - Summary of Reportable Conditions Observed


Section 3 - Summary of ASME XI Repairs and Replacements

Name of Inspector: James J Fuhrman

Name of Mailing Address of Inspector's Employer:

The Hartford Steam Boiler Inspection & Insurance Company
610 Freedom Business Center Drive
Suite 300
King of Prussia, Pennsylvania 19406

I certify that the statements made in this report are correct and the examinations and corrective measures taken conform to the rules of the ASME Section XI Code, or Generic Letter 88-01, or other augmented requirements as applicable.


PECO Energy ISI Engineer - Nuclear Maintenance Division

1/24/00
Date


FORM NIS-1
INSERVICE INSPECTION REPORT
Page 2

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Inspectors and/or State or Province of Pennsylvania employed by Hartford Steam Boiler Inspection & Insurance Company of Hartford, Connecticut have inspected the components described in the Owner's Data Report during the period 11/02/97 to 10/27/99 and state that to the best of my knowledge and belief the Owner has performed examinations and taken corrective measures described in this Owner's Data Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Date: 1/24/2000



Inspector's Signature

Commissions NB7592, PA-2163
National Board, State,
Province & No.
I, S, N, A, IS

INTRODUCTION

During the period from November 2, 1997 through October 27, 1999, Inservice Inspections were performed at Peach Bottom Atomic Power Station Unit 3. Unit 3 was shutdown for a scheduled refuel outage during the period September 29, 1999 through October 27, 1999. The inspections performed during this period were credited towards the first period of the second ten year interval.

Examinations completed during this period were performed by PECO Energy Company and General Electric Company in accordance with the requirements of ASME Section XI: 1989 Edition for Class 1,2 and 3 Components; and 1992 Edition through 1992 Addenda for Primary Containmentment.

In addition to ASME Section XI, other examinations were performed to meet the augmented inspection requirements of the following:

Generic Letter 88-01	Intergranular Stress Corrosion Cracking
BWRVIP-01.	BWR Core Shroud Inspection and Flaw Evaluation Guideline
BWRVIP-07	Guidelines for Reinspection of BWR Core Shrouds
BWRVIP-18	Core Spray Internals Inspection and Flaw Evaluation Guidelines
BWRVIP-38	BWR Shroud Support Inspection and Flaw Evaluation Guideline
BWRVIP-41	Jet Pump Assembly Inspection and Flaw Evaluation Guidelines
BWRVIP-47	BWR Lower Plenum Inspection and Flaw Evaluation Guideline
BWRVIP-48	Vessel ID Attachment Weld Inspection and Flaw Evaluation Guideline

SECTION 1

**SUMMARY OF IN-SERVICE INSPECTION AND
AUGMENTED INSPECTION RESULTS
PRIOR TO AND DURING 12TH REFUEL OUTAGE
PEACH BOTTOM ATOMIC POWER STATION
UNIT 3
NOVEMBER 2, 1997 TO OCTOBER 27, 1999**

SUMMARY OF IN-SERVICE INSPECTION RESULTS
PRIOR TO AND DURING 12TH REFUEL OUTAGE
PEACH BOTTOM ATOMIC POWER STATION
UNIT 3
NOVEMBER 2, 1997 TO OCTOBER 27, 1999

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

EXAM CATEGORY: B-A

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
CH-C-2	Head to Flange Weld	1

SYSTEM DESCRIPTION: REACTOR PRESSURE VESSEL

NDE METHOD: UT-0/L,UT-45/S,UT-60/S,UT-70/RL,MT **NDE PROCEDURE:** GE-UT-300-R3 / GE-MT-100-R2

RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications. Previously recorded indication was detected at an amplitude below recordable levels. There was no apparent change in the length and throughwall dimensions.	YES

TOTAL EXAMS FOR CATEGORY B-A 1

EXAM CATEGORY: B-G-2

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
RV-3-1-70A(PRB)	Safety Relief Valve Flange B	1

SYSTEM DESCRIPTION: MAIN STEAM

NDE METHOD: Visual, VT1 **NDE PROCEDURE:** MAG-CG-407-R6

RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
RV-3-1-71B(PRB)	Relief Valve Flange Bolting	1

SYSTEM DESCRIPTION: MAIN STEAM

NDE METHOD: Visual, VT1 **NDE PROCEDURE:** MAG-CG-407-R6

RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications	YES

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

EXAM CATEGORY: B-G-2

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
RV-3-1-71C(PRB)	Relief Valve Flange Bolting	1
SYSTEM DESCRIPTION:	MAIN STEAM	
NDE METHOD: Visual, VT1	NDE PROCEDURE:	MAG-CG-407-R6
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
RV-3-1-71F(PRB)	Relief Valve Flange Bolting	1
SYSTEM DESCRIPTION:	MAIN STEAM	
NDE METHOD: Visual, VT1	NDE PROCEDURE:	MAG-CG-407-R6
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
RV-3-1-71J(PRB)	Relief Valve Flange Bolting	1
SYSTEM DESCRIPTION:	MAIN STEAM	
NDE METHOD: Visual, VT1	NDE PROCEDURE:	MAG-CG-407-R6
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications	YES

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

EXAM CATEGORY: B-G-2

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
RV-3-1-71K(PRB)	Relief Valve Flange Bolting	1
SYSTEM DESCRIPTION:	MAIN STEAM	
NDE METHOD: Visual, VT1	NDE PROCEDURE:	MAG-CG-407-R6
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
RV-3-1-71L(PRB)	Relief Valve Flange Bolting	1
SYSTEM DESCRIPTION:	MAIN STEAM	
NDE METHOD: Visual, VT1	NDE PROCEDURE:	MAG-CG-407-R6
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
CRD Housing Bolting	Flange Bolting	1
SYSTEM DESCRIPTION:	REACTOR PRESSURE VESSEL	
NDE METHOD: VT-1	NDE PROCEDURE:	MAG-CG-407-R6
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
RI	Recordable Indications. Examined Bolting From Cells: 06-31, 10-27, 14-51, 18-55, 22-27, 26-11, 30-19, 30-23, 30-27, 30-39, 34-31, 34-35, 38-07, 38-51, 38-55, 42-19, 42-59, 46-43, 54-23. Slight pitting and galling observed.	YES

TOTAL EXAMS FOR CATEGORY B-G-2 8

EXAM CATEGORY: B-J

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

EXAM CATEGORY: B-J

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
1-A-7	Elbow to Pipe	1
SYSTEM DESCRIPTION:	MAIN STEAM	
NDE METHOD: UT-45/S,MT	NDE PROCEDURE:	GE-UT-106-R2 / GE-MT-100-R2
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications.	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
1-A-7/ASA	Pipe to Branch	1
SYSTEM DESCRIPTION:	MAIN STEAM	
NDE METHOD: UT-45/S,MT	NDE PROCEDURE:	GE-UT-106-R2 / GE-MT-100-R2
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications.	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
1-A-7/ASG	Pipe to Branch	1
SYSTEM DESCRIPTION:	MAIN STEAM	
NDE METHOD: UT-45/S,MT	NDE PROCEDURE:	GE-UT-106-R2 / GE-MT-100-R2
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications. Limited exam due to pipe to branch configuration. Code coverage was achieved.	YES

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

EXAM CATEGORY: B-J

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
1-A-8	Pipe to Pipe	1
SYSTEM DESCRIPTION: MAIN STEAM		
NDE METHOD: UT-45/S,MT	NDE PROCEDURE:	GE-UT-106-R2 / GE-MT-100-R2
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications. Added scope to supplement weld 1-A-9 less than Code minimum exam coverage.	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
1-A-9	Pipe to Elbow	1
SYSTEM DESCRIPTION: MAIN STEAM		
NDE METHOD: UT-45/S,MT	NDE PROCEDURE:	GE-UT-106-R2 / GE-MT-100-R2
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications. Limited exam due to pipe to elbow configuration. 49% Code Coverage was achieved.	NO - 49%

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
1-ASA-1	Branch Conn to Pipe	1
SYSTEM DESCRIPTION: MAIN STEAM		
NDE METHOD: UT-45/S,MT	NDE PROCEDURE:	GE-UT-106-R2 / GE-MT-100-R2
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications. Limited exam due to branch to pipe configuration. Code Coverage was achieved.	YES

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

EXAM CATEGORY: B-J

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
1-ASA-2	Pipe to Flange	1
SYSTEM DESCRIPTION:	MAIN STEAM	
NDE METHOD: UT-45/S,MT	NDE PROCEDURE:	GE-UT-106-R2 / GE-MT-100-R2
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications. Limited exam due to pipe to flange configuration. Code coverage was achieved.	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
1-ASG-1	Branch to Pipe	1
SYSTEM DESCRIPTION:	MAIN STEAM	
NDE METHOD: UT-45/S,MT	NDE PROCEDURE:	GE-UT-106-R2 / GE-MT-100-R2
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications.	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
1-ASG-2	Pipe to Flange	1
SYSTEM DESCRIPTION:	MAIN STEAM	
NDE METHOD: UT-45/S,MT	NDE PROCEDURE:	GE-UT-106-R2 / GE-MT-100-R2
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications.	YES

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

EXAM CATEGORY: B-J

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
4-RD-10	Elbow to Pipe Bend	1
SYSTEM DESCRIPTION: REACTOR DRAIN		
NDE METHOD: PT	NDE PROCEDURE:	GE-PT-100-R2
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications.	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
4-RD-11	Pipe to Elbow	1
SYSTEM DESCRIPTION: REACTOR DRAIN		
NDE METHOD: PT	NDE PROCEDURE:	GE-PT-100-R2
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications.	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
4-RD-12	Elbow to Pipe	1
SYSTEM DESCRIPTION: REACTOR DRAIN		
NDE METHOD: PT	NDE PROCEDURE:	GE-PT-100-R2
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications.	YES

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

EXAM CATEGORY: B-J

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
4-RD-13	Pipe to Elbow	1
SYSTEM DESCRIPTION:	REACTOR DRAIN	
NDE METHOD: PT	NDE PROCEDURE:	GE-PT-100-R2
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications.	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
4-RD-14	Coupling to Pipe Bend	1
SYSTEM DESCRIPTION:	REACTOR DRAIN	
NDE METHOD: PT	NDE PROCEDURE:	GE-PT-100-R2
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications.	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
4-RD-15	Pipe Bend to Coupling	1
SYSTEM DESCRIPTION:	REACTOR DRAIN	
NDE METHOD: PT	NDE PROCEDURE:	GE-PT-100-R2
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications.	YES

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

EXAM CATEGORY: B-J

COMPONENT ID **COMPONENT DESCRIPTION** **CODE CLASS**
12-O-22/4-RD Pipe to Coupling 1

SYSTEM DESCRIPTION: REACTOR WATER CLEAN-UP

NDE METHOD: PT **NDE PROCEDURE:** GE-PT-100-R2

RESULTS **RESULTS / COMMENTS** **CODE COVERAGE MET ?**
NRI No Recordable Indications. YES

TOTAL EXAMS FOR CATEGORY B-J 16

EXAM CATEGORY: B-J-X

COMPONENT ID **COMPONENT DESCRIPTION** **CODE CLASS**
12-O-20A Branch to Pipe 9

SYSTEM DESCRIPTION: REACTOR WATER CLEAN-UP

NDE METHOD: UT-45/S **NDE PROCEDURE:** PDI-UT-2

RESULTS **RESULTS / COMMENTS** **CODE COVERAGE MET ?**
NRI No Recordable Indications. YES

TOTAL EXAMS FOR CATEGORY B-J-X 1

EXAM CATEGORY: B-K

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

EXAM CATEGORY: B-K

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
HA2(1A)	Integral Attachment	1

SYSTEM DESCRIPTION: MAIN STEAM

NDE METHOD: MT NDE PROCEDURE: GE-MT-100-R2

RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications.	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
I2DCN-H152(1A)	Spring Hanger	1

SYSTEM DESCRIPTION: REACTOR WATER CLEAN-UP

NDE METHOD: PT NDE PROCEDURE: GE-PT-100-R2

RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications.	YES

TOTAL EXAMS FOR CATEGORY B-K 2

EXAM CATEGORY: B-M-2

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
RV-3-1-71K	Relief Valve	1

SYSTEM DESCRIPTION: MAIN STEAM

NDE METHOD: Visual, VT3 NDE PROCEDURE: MAG-CG-407-R6

RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications	YES

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

EXAM CATEGORY: B-M-2

COMPONENT ID **COMPONENT DESCRIPTION** **CODE CLASS**
MO-3-12-68 Gate Valve 1

SYSTEM DESCRIPTION: REACTOR WATER CLEAN-UP

NDE METHOD: Visual, VT3 **NDE PROCEDURE:** MAG-CG-407-R6

RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications	YES

TOTAL EXAMS FOR CATEGORY B-M-2 2

EXAM CATEGORY: B-P

COMPONENT ID **COMPONENT DESCRIPTION** **CODE CLASS**
Class 1 RPV Leakage Test SYSTEM PRESSURE TEST 1

SYSTEM DESCRIPTION: REACTOR PRESSURE VESSEL

NDE METHOD: VT-2 **NDE PROCEDURE:** ST-O-080-675-3

RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
SAT	Completed Sat - 10/24/99	YES

TOTAL EXAMS FOR CATEGORY B-P 1

EXAM CATEGORY: C-C

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

EXAM CATEGORY: C-C

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
10HB-H14(IA)	Integral Attachment	2

SYSTEM DESCRIPTION: RESIDUAL HEAT REMOVAL

NDE METHOD: MT NDE PROCEDURE: GE-MT-100-R2

RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications.	YES

TOTAL EXAMS FOR CATEGORY C-C 1

EXAM CATEGORY: C-F-2

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
14-2DA12-1	Pump to Pipe	2

SYSTEM DESCRIPTION: CORE SPRAY

NDE METHOD: UT-0/L,UT-45/S,MT NDE PROCEDURE: GE-UT-106-R2 / GE-MT-100-R2

RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
RI	Recordable Indication. Observed indication was determined to be inside surface geometry. No other recordable indications.	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
14-2DA12-8	Elbow to Pipe	2

SYSTEM DESCRIPTION: CORE SPRAY

NDE METHOD: UT-0/L,UT-45/S,MT NDE PROCEDURE: GE-UT-106-R2 / GE-MT-100-R2

RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
RI	Recordable Indication. Observed indication was determined to be inside surface geometry. No other recordable indications.	YES

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

EXAM CATEGORY: C-F-2

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
14-2TSA14-17	Pipe to Tee	2
SYSTEM DESCRIPTION:	CORE SPRAY	
NDE METHOD: UT-0/L,UT-45/S,MT	NDE PROCEDURE:	GE-UT-106-R2 / GE-MT-100-R2
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications.	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
14-2TSA16-16	Pipe to Pump	2
SYSTEM DESCRIPTION:	CORE SPRAY	
NDE METHOD: UT-0/L,UT-45/S,MT	NDE PROCEDURE:	GE-UT-106-R2 / GE-MT-100-R2
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications.	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
10-2SCSA20-3	Elbow to Pipe	2
SYSTEM DESCRIPTION:	RESIDUAL HEAT REMOVAL	
NDE METHOD: UT-0/L,UT-45/S,MT	NDE PROCEDURE:	GE-UT-106-R2 / GE-MT-100-R2
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
RI	Recordable Indication. Observed indication was determined to be root geometry. No other recordable indications.	YES

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

EXAM CATEGORY: C-F-2

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
10-2SCSA20-5	Elbow to Pipe	2
SYSTEM DESCRIPTION:	RESIDUAL HEAT REMOVAL	
NDE METHOD: UT-0/L,UT-45/S,MT	NDE PROCEDURE:	GE-UT-106-R2 / GE-MT-100-R2
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications.	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
10-2SCSC20-3	Elbow to Pipe	2
SYSTEM DESCRIPTION:	RESIDUAL HEAT REMOVAL	
NDE METHOD: UT-0/L,UT-45/S,MT	NDE PROCEDURE:	GE-UT-106-R2 / GE-MT-100-R2
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications.	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
10-2SCSC20-5	Elbow to Pipe	2
SYSTEM DESCRIPTION:	RESIDUAL HEAT REMOVAL	
NDE METHOD: UT-0/L,UT-45/S,MT	NDE PROCEDURE:	GE-UT-106-R2 / GE-MT-100-R2
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications.	YES

TOTAL EXAMS FOR CATEGORY C-F-2 8

EXAM CATEGORY: C-H

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

EXAM CATEGORY: C-H

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
Core Spray Loop A Pressure Test	SYSTEM PRESSURE TEST	2
SYSTEM DESCRIPTION:	CORE SPRAY	
NDE METHOD: VT-2	NDE PROCEDURE:	ST-O-014-611-3
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
SAT	Completed Sat - 2/18/99	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
Core Spray Loop B Pressure Test	SYSTEM PRESSURE TEST	2
SYSTEM DESCRIPTION:	CORE SPRAY	
NDE METHOD: VT-2	NDE PROCEDURE:	ST-O-014-616-3
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
SAT	Completed Sat - 4/7/99	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
Main Steam Lines Pressure Test	SYSTEM PRESSURE TEST	2
SYSTEM DESCRIPTION:	MAIN STEAM	
NDE METHOD: VT-2	NDE PROCEDURE:	ST-O-001-635-3
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
SAT	Completed Sat - 9/29/99	YES

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

EXAM CATEGORY: C-H

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
RHR Loop A Pressure Test	SYSTEM PRESSURE TEST	2
SYSTEM DESCRIPTION:	RESIDUAL HEAT REMOVAL	
NDE METHOD: VT-2	NDE PROCEDURE:	ST-O-010-611-3
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
SAT	Completed Sat - 6/27/99	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
RHR Loop B Pressure Test	SYSTEM PRESSURE TEST	2
SYSTEM DESCRIPTION:	RESIDUAL HEAT REMOVAL	
NDE METHOD: VT-2	NDE PROCEDURE:	ST-O-010-616-3
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
SAT	Completed Sat - 7/16/99	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
Scram Discharge Volume Pressure Test	SYSTEM PRESSURE TEST	2
SYSTEM DESCRIPTION:	SCRAM DISCHARGE VOLUME	
NDE METHOD: VT-2	NDE PROCEDURE:	ST-O-003-635-3
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
SAT	Completed Sat - 9/29/99	YES

TOTAL EXAMS FOR CATEGORY C-H 6

EXAM CATEGORY: D-A

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

EXAM CATEGORY: D-A

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
32GB-H65(IA)	Integral Attachment	3
SYSTEM DESCRIPTION: HIGH PRESSURE SERVICE WATER		
NDE METHOD: VT-3	NDE PROCEDURE:	MAG-CG-407-R6
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications.	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
1GG-H295(IA)	Integral Attachment	3
SYSTEM DESCRIPTION: MAIN STEAM RELIEF VALVE		
NDE METHOD: VT-3	NDE PROCEDURE:	MAG-CG-407-R6
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications.	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
1GG-S210K(IA)	Integral Attachment	3
SYSTEM DESCRIPTION: MAIN STEAM RELIEF VALVE		
NDE METHOD: VT-3	NDE PROCEDURE:	MAG-CG-407-R6
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications.	YES

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

EXAM CATEGORY: D-A

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
1GG-S51(IA)	Integral Attachment	3

SYSTEM DESCRIPTION: MAIN STEAM RELIEF VALVE

NDE METHOD: VT-3 **NDE PROCEDURE:** MAG-CG-407-R6

RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications.	YES

TOTAL EXAMS FOR CATEGORY D-A 4

EXAM CATEGORY: F-A

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
33HB-H127	Rigid Restraint	3

SYSTEM DESCRIPTION: EMERGENCY SERVICE WATER

NDE METHOD: Visual, VT3 **NDE PROCEDURE:** MAG-CG-407-R5

RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications. Examined per disposition of NCR# PB 97-01669.	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
33HB-S63	Rigid Restraint	3

SYSTEM DESCRIPTION: EMERGENCY SERVICE WATER

NDE METHOD: Visual, VT3 **NDE PROCEDURE:** MAG-CG-407-R5

RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications. Examined per disposition of NCR# PB 97-01669.	YES

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

EXAM CATEGORY: F-A

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
32GB-H65	Spring Hanger	3
SYSTEM DESCRIPTION:		HIGH PRESSURE SERVICE WATER
NDE METHOD:	VT-3	NDE PROCEDURE: MAG-CG-407-R6
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications.	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
32GB-S28	Rigid Restraint	3
SYSTEM DESCRIPTION:		HIGH PRESSURE SERVICE WATER
NDE METHOD:	VT-3	NDE PROCEDURE: MAG-CG-407-R6
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
32GB-S30	Rigid Restraint	3
SYSTEM DESCRIPTION:		HIGH PRESSURE SERVICE WATER
NDE METHOD:	VT-3	NDE PROCEDURE: MAG-CG-407-R6
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications.	YES

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

EXAM CATEGORY: F-A

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
H17B	Spring Hanger	1
SYSTEM DESCRIPTION:	MAIN RECIRCULATION	
NDE METHOD: VT-3	NDE PROCEDURE:	MAG-CG-407-R6
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
SS2B	Mechanical Snubber	1
SYSTEM DESCRIPTION:	MAIN RECIRCULATION	
NDE METHOD: VT-3	NDE PROCEDURE:	MAG-CG-407-R6
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
HA2	Spring Hanger	1
SYSTEM DESCRIPTION:	MAIN STEAM	
NDE METHOD: VT-3	NDE PROCEDURE:	MAG-CG-407-R6
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications.	YES

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

EXAM CATEGORY: F-A

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
HA4	Spring Hanger	1
SYSTEM DESCRIPTION:	MAIN STEAM	
NDE METHOD: VT-3	NDE PROCEDURE:	MAG-CG-407-R6
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
1GG-H295	Spring Hanger	3
SYSTEM DESCRIPTION:	MAIN STEAM RELIEF VALVE	
NDE METHOD: VT-3	NDE PROCEDURE:	MAG-CG-407-R6
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications.	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
1GG-S210K	Guide	3
SYSTEM DESCRIPTION:	MAIN STEAM RELIEF VALVE	
NDE METHOD: VT-3	NDE PROCEDURE:	MAG-CG-407-R6
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications.	YES

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

EXAM CATEGORY: F-A

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
IGG-S210L	Guide	3
SYSTEM DESCRIPTION:	MAIN STEAM RELIEF VALVE	
NDE METHOD: VT-3	NDE PROCEDURE:	MAG-CG-407-R6
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications.	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
IGG-S51	Hydraulic Snubber	3
SYSTEM DESCRIPTION:	MAIN STEAM RELIEF VALVE	
NDE METHOD: VT-3	NDE PROCEDURE:	MAG-CG-407-R6
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications.	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
PH-86	Variable Spring	1
SYSTEM DESCRIPTION:	REACTOR DRAIN	
NDE METHOD: VT-3	NDE PROCEDURE:	MAG-CG-407-R6
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indication. The support spring can has a defaced load scale per MAG-CG-407-1.	YES

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

EXAM CATEGORY: F-A

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
PH-87	Variable Spring	1
SYSTEM DESCRIPTION:	REACTOR DRAIN	
NDE METHOD: VT-3	NDE PROCEDURE:	MAG-CG-407-R6
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications.	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
RPV-SK(SC)	RPV Support Skirt	1
SYSTEM DESCRIPTION:	REACTOR PRESSURE VESSEL	
NDE METHOD: VT-3	NDE PROCEDURE:	MAG-CG-407-R6
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
SUPPORT-1	Stabilizing Bar @ 0°	1
SYSTEM DESCRIPTION:	REACTOR PRESSURE VESSEL	
NDE METHOD: VT-3	NDE PROCEDURE:	MAG-CG-407-R6
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications	YES

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

EXAM CATEGORY: F-A

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
SUPPORT-2	Stabilizing Bar @ 45°	1

SYSTEM DESCRIPTION: REACTOR PRESSURE VESSEL

NDE METHOD: VT-3 NDE PROCEDURE: MAG-CG-407-R6

RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
12DCN-H152	Spring Hanger	1

SYSTEM DESCRIPTION: REACTOR WATER CLEAN-UP

NDE METHOD: VT-3 NDE PROCEDURE: MAG-CG-407-R6

RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications.	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
10HB-H14	Spring Hanger	2

SYSTEM DESCRIPTION: RESIDUAL HEAT REMOVAL

NDE METHOD: VT-3 NDE PROCEDURE: MAG-CG-407-R6

RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indication. Slight bend on lower spring hanger rod.	YES

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

EXAM CATEGORY: F-A

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
10HB-H28	Spring Hanger	2
SYSTEM DESCRIPTION:	RESIDUAL HEAT REMOVAL	
NDE METHOD: VT-3	NDE PROCEDURE:	MAG-CG-407-R6
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications.	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
10HB-H36	Spring Hanger	2
SYSTEM DESCRIPTION:	RESIDUAL HEAT REMOVAL	
NDE METHOD: VT-3	NDE PROCEDURE:	MAG-CG-407-R6
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications.	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
3GE-H20	Rigid Restraint	2
SYSTEM DESCRIPTION:	SCRAM DISCHARGE VOLUME	
NDE METHOD: VT-3	NDE PROCEDURE:	MAG-CG-407-R6
RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications.	YES

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

EXAM CATEGORY: F-A

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
3GE-H40	Rigid Restraint	2

SYSTEM DESCRIPTION: SCRAM DISCHARGE VOLUME

NDE METHOD: VT-3 NDE PROCEDURE: MAG-CG-407-R6

RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications.	YES

COMPONENT ID	COMPONENT DESCRIPTION	CODE CLASS
3GE-H95	Rigid Restraint	2

SYSTEM DESCRIPTION: SCRAM DISCHARGE VOLUME

NDE METHOD: VT-3 NDE PROCEDURE: MAG-CG-407-R6

RESULTS	RESULTS / COMMENTS	CODE COVERAGE MET ?
NRI	No Recordable Indications.	YES

TOTAL EXAMS FOR CATEGORY F-A 25

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

**PEACH BOTTOM ATOMIC POWER STATION
CONTAINMENT INSPECTION PROGRAM - 3R12**

EXAM CATEGORY	E-A	CODE CLASS	MC
COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM EXAM METHOD
3-DWELL-GV	Drywell	E1.11	Gen. Visual*
		NDE PROCEDURE	MAG-CG-425-R0
RESULTS	COMMENTS	CODE COVERAGE MET?	
RI	Recordable Indications. Areas of varying surface corrosion and staining were observed.	YES	
COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM EXAM METHOD
3-DWELL-VT3	Drywell	E1.12	Visual, VT-3
		NDE PROCEDURE	MAG-CG-425-R0
RESULTS	COMMENTS	CODE COVERAGE MET?	
RI	Recordable Indications. Areas of varying surface corrosion and staining were observed.	YES	
COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM EXAM METHOD
3-ELUG-135-VT3	Drywell exterior lug outside penetration N-110D at 135°	E1.12	Visual, VT-3
		NDE PROCEDURE	MAG-CG-425-R0
RESULTS	COMMENTS	CODE COVERAGE MET?	
RI	Recordable Indication. Light debris observed.	YES	

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

**PEACH BOTTOM ATOMIC POWER STATION
CONTAINMENT INSPECTION PROGRAM - 3R12**

EXAM CATEGORY	E-A	CODE CLASS	MC
COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM EXAM METHOD
3-ELUG-180-VT3	Drywell exterior lug outside penetration N-110E at 180°	E1.12	Visual, VT-3
		NDE PROCEDURE	MAG-CG-425-R0
RESULTS	COMMENTS	CODE COVERAGE MET?	
RI	Recordable Indication. Light debris observed.	YES	
COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM EXAM METHOD
3-TORUS-GV	Suppression Chamber	E1.11	Gen. Visual*
		NDE PROCEDURE	MAG-CG-425-R0
RESULTS	COMMENTS	CODE COVERAGE MET?	
RI	Recordable indications. Scattered areas of coating failure and resultant light surface corrosion were observed.	YES	
COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM EXAM METHOD
3-TORUS-VT3	Suppression Chamber	E1.12	Visual, VT-3
		NDE PROCEDURE	MAG-CG-425-R0
RESULTS	COMMENTS	CODE COVERAGE MET?	
RI	Recordable Indications. Scattered areas of coating failure and resultant light surface corrosion were observed.	YES	

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

**PEACH BOTTOM ATOMIC POWER STATION
CONTAINMENT INSPECTION PROGRAM - 3R12**

EXAM CATEGORY	E-A	CODE CLASS	MC
----------------------	------------	-------------------	-----------

COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM	EXAM METHOD
3-VENT-022-GV	Vent line A at 22° 30'	E1.11		Gen. Visual*
		NDE PROCEDURE		MAG-CG-425-R0
RESULTS	COMMENTS			CODE COVERAGE MET?
RI	Recordable Indications. Areas of coating loss, staining, mechanical dings & coating peeling at water line observed.			YES

COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM	EXAM METHOD
3-VENT-022-VT3	Vent line A at 22° 30'	E1.12		Visual, VT-3
		NDE PROCEDURE		MAG-CG-425-R0
RESULTS	COMMENTS			CODE COVERAGE MET?
RI	Recordable Indications. Areas of coating loss, staining, mechanical dings & coating peeling at water line observed.			YES

COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM	EXAM METHOD
3-VENT-067-GV	Vent line B at 67° 30'	E1.11		Gen. Visual*
		NDE PROCEDURE		MAG-CG-425-R0
RESULTS	COMMENTS			CODE COVERAGE MET?
RI	Recordable Indications. Areas of coating loss, staining, mechanical dings & coating peeling at water line observed.			YES

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

**PEACH BOTTOM ATOMIC POWER STATION
CONTAINMENT INSPECTION PROGRAM - 3R12**

EXAM CATEGORY	E-A	CODE CLASS	MC
COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM EXAM METHOD
3-VENT-067-VT3	Vent line B at 67° 30'	E1.12	Visual, VT-3
		NDE PROCEDURE	MAG-CG-425-R0
RESULTS	COMMENTS	CODE COVERAGE MET?	
RI	Recordable Indications. Areas of coating loss, staining, mechanical dings & coating peeling at water line observed.	YES	
COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM EXAM METHOD
3-VENT-112-GV	Vent line C at 112° 30'	E1.11	Gen. Visual*
		NDE PROCEDURE	MAG-CG-425-R0
RESULTS	COMMENTS	CODE COVERAGE MET?	
RI	Recordable Indications. Areas of coating loss, staining, mechanical dings & coating peeling at water line observed.	YES	
COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM EXAM METHOD
3-VENT-112-VT3	Vent line C at 112° 30'	E1.12	Visual, VT-3
		NDE PROCEDURE	MAG-CG-425-R0
RESULTS	COMMENTS	CODE COVERAGE MET?	
RI	Recordable Indications. Areas of coating loss, staining, mechanical dings & coating peeling at water line observed.	YES	

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

PEACH BOTTOM ATOMIC POWER STATION CONTAINMENT INSPECTION PROGRAM - 3R12

EXAM CATEGORY	E-A	CODE CLASS	MC
COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM EXAM METHOD
3-VENT-157-GV	Vent line D at 157° 30'	E1.11	Gen. Visual*
		NDE PROCEDURE	MAG-CG-425-R0
RESULTS	COMMENTS	CODE COVERAGE MET?	
RI	Recordable Indications. Areas of coating loss, staining, mechanical dings & coating peeling at water line observed.	YES	
COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM EXAM METHOD
3-VENT-157-VT3	Vent line D at 157° 30'	E1.12	Visual, VT-3
		NDE PROCEDURE	MAG-CG-425-R0
RESULTS	COMMENTS	CODE COVERAGE MET?	
RI	Recordable Indications. Areas of coating loss, staining, mechanical dings & coating peeling at water line observed.	YES	
COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM EXAM METHOD
3-VENT-202-GV	Vent line E at 202° 30'	E1.11	Gen. Visual*
		NDE PROCEDURE	MAG-CG-425-R0
RESULTS	COMMENTS	CODE COVERAGE MET?	
RI	Recordable Indications. Areas of coating loss, staining, mechanical dings & coating peeling at water line observed.	YES	

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

**PEACH BOTTOM ATOMIC POWER STATION
CONTAINMENT INSPECTION PROGRAM - 3R12**

EXAM CATEGORY	E-A	CODE CLASS	MC
---------------	-----	------------	----

COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM	EXAM METHOD
3-VENT-202-VT3	Vent line E at 202° 30'	E1.12		Visual, VT-3
		NDE PROCEDURE		MAG-CG-425-R0

RESULTS	COMMENTS	CODE COVERAGE MET?
RI	Recordable Indications. Areas of coating loss, staining, mechanical dings & coating peeling at water line observed.	YES

COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM	EXAM METHOD
3-VENT-247-GV	Vent line F at 247° 30'	E1.11		Gen. Visual*
		NDE PROCEDURE		MAG-CG-425-R0

RESULTS	COMMENTS	CODE COVERAGE MET?
RI	Recordable Indications. Areas of coating loss, staining, mechanical dings & coating peeling at water line observed.	YES

COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM	EXAM METHOD
3-VENT-247-VT3	Vent line F at 247° 30'	E1.12		Visual, VT-3
		NDE PROCEDURE		MAG-CG-425-R0

RESULTS	COMMENTS	CODE COVERAGE MET?
RI	Recordable Indications. Areas of coating loss, staining, mechanical dings & coating peeling at water line observed.	YES

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

**PEACH BOTTOM ATOMIC POWER STATION
CONTAINMENT INSPECTION PROGRAM - 3R12**

EXAM CATEGORY	E-A	CODE CLASS	MC
COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM EXAM METHOD
3-VENT-292-GV	Vent line G at 292° 30'	E1.11	Gen. Visual*
		NDE PROCEDURE	MAG-CG-425-R0
RESULTS	COMMENTS	CODE COVERAGE MET?	
RI	Recordable Indications. Areas of coating loss, staining, mechanical dings & coating peeling at water line observed.	YES	
COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM EXAM METHOD
3-VENT-292-VT3	Vent line G at 292° 30'	E1.12	Visual, VT-3
		NDE PROCEDURE	MAG-CG-425-R0
RESULTS	COMMENTS	CODE COVERAGE MET?	
RI	Recordable Indications. Areas of coating loss, staining, mechanical dings & coating peeling at water line observed.	YES	
COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM EXAM METHOD
3-VENT-337-GV	Vent line H at 337° 30'	E1.11	Gen. Visual*
		NDE PROCEDURE	MAG-CG-425-R0
RESULTS	COMMENTS	CODE COVERAGE MET?	
RI	Recordable Indications. Areas of coating loss, staining, mechanical dings & coating peeling at water line observed.	YES	

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

**PEACH BOTTOM ATOMIC POWER STATION
CONTAINMENT INSPECTION PROGRAM - 3R12**

EXAM CATEGORY	E-A	CODE CLASS	MC
----------------------	------------	-------------------	-----------

COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM	EXAM METHOD
3-VENT-337-VT3	Vent line H at 337° 30'	E1.12		Visual, VT-3
		NDE PROCEDURE		MAG-CG-425-R0
RESULTS	COMMENTS			CODE COVERAGE MET?
RI	Recordable Indications. Areas of coating loss, staining, mechanical dings & coating peeling at water line observed.			YES

COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM	EXAM METHOD
3-VENTSYS-VT3	Vent system	E1.20		Visual, VT-3
		NDE PROCEDURE		MAG-CG-425-R0
RESULTS	COMMENTS			CODE COVERAGE MET?
NRI	No Recordable Indications.			YES

TOTAL EXAMS FOR CATEGORY	E-A	23
---------------------------------	------------	-----------

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

PEACH BOTTOM ATOMIC POWER STATION CONTAINMENT INSPECTION PROGRAM - 3R12

EXAM CATEGORY	E-D	CODE CLASS	MC
---------------	-----	------------	----

COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM	EXAM METHOD
3-MBAR-INT	Drywell interior moisture barrier	E5.30		Visual, VT-3
		NDE PROCEDURE		MAG-CG-425-R0
RESULTS	COMMENTS			CODE COVERAGE MET?
NRI	No Recordable Indications.			YES

TOTAL EXAMS FOR CATEGORY	E-D	1
--------------------------	-----	---

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

**PEACH BOTTOM ATOMIC POWER STATION
CONTAINMENT INSPECTION PROGRAM - 3R12**

EXAM CATEGORY	NA	CODE CLASS	NA
----------------------	-----------	-------------------	-----------

COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM	EXAM METHOD
DA-135	Drywell Airgap	NA	CB	Visual, VT3
		NDE PROCEDURE		MAG-CG-425-R0
RESULTS	COMMENTS			CODE COVERAGE MET?
NRI	No Recordable Indications.			NA

COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM	EXAM METHOD
DA-180	Drywell Airgap	NA	CB	Visual, VT3
		NDE PROCEDURE		MAG-CG-425-R0
RESULTS	COMMENTS			CODE COVERAGE MET?
NRI	No Recordable Indications.			NA

COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM	EXAM METHOD
DA-DL-FT	Drywell Airgap Drain Line Functional Test	NA	CC	Visual, VT3
		NDE PROCEDURE		MAG-CG-425-R0
RESULTS	COMMENTS			CODE COVERAGE MET?
NRI	No Recordable Indications.			NA

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

PEACH BOTTOM ATOMIC POWER STATION CONTAINMENT INSPECTION PROGRAM - 3R12

EXAM CATEGORY	NA	CODE CLASS	NA
---------------	----	------------	----

COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM	EXAM METHOD
DAD-VT-045	Drywell Airgap Drain Line Visual Examination	NA	CC	Visual, VT3
		NDE PROCEDURE		MAG-CG-425-R0
RESULTS	COMMENTS			CODE COVERAGE MET?
NRI	No Recordable Indications.			NA

COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM	EXAM METHOD
DAD-VT-135	Drywell Airgap Drain Line Visual Examination	NA	CC	Visual, VT3
		NDE PROCEDURE		MAG-CG-425-R0
RESULTS	COMMENTS			CODE COVERAGE MET?
NRI	No Recordable Indications.			NA

COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM	EXAM METHOD
DAD-VT-225	Drywell Airgap Drain Line Visual Examination	NA	CC	Visual, VT3
		NDE PROCEDURE		MAG-CG-425-R0
RESULTS	COMMENTS			CODE COVERAGE MET?
NRI	No Recordable Indications.			NA

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

**PEACH BOTTOM ATOMIC POWER STATION
CONTAINMENT INSPECTION PROGRAM - 3R12**

EXAM CATEGORY	NA	CODE CLASS	NA
----------------------	-----------	-------------------	-----------

COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM	EXAM METHOD
DAD-VT-315	Drywell Airgap Drain Line Visual Examination	NA	CC	Visual, VT3
		NDE PROCEDURE		MAG-CG-425-R0

RESULTS	COMMENTS	CODE COVERAGE MET?
NRI	No Recordable Indications.	NA

COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM	EXAM METHOD
DE-135	Drywell Exterior	NA	CB	Visual, VT3
		NDE PROCEDURE		MAG-CG-425-R0

RESULTS	COMMENTS	CODE COVERAGE MET?
NRI	No Recordable Indications.	NA

COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM	EXAM METHOD
DE-180	Drywell Exterior	NA	CB	Visual, VT3
		NDE PROCEDURE		MAG-CG-425-R0

RESULTS	COMMENTS	CODE COVERAGE MET?
NRI	No Recordable Indications.	NA

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

**PEACH BOTTOM ATOMIC POWER STATION
CONTAINMENT INSPECTION PROGRAM - 3R12**

EXAM CATEGORY	NA	CODE CLASS	NA
----------------------	-----------	-------------------	-----------

COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM	EXAM METHOD
DESS-135	Drywell Exterior Stabilizer Support	NA	CA	Visual, VT3
		NDE PROCEDURE		MAG-CG-425-R0
RESULTS	COMMENTS			CODE COVERAGE MET?
NRI	No Recordable Indications.			NA

COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM	EXAM METHOD
DESS-180	Drywell Exterior Stabilizer Support	NA	CA	Visual, VT3
		NDE PROCEDURE		MAG-CG-425-R0
RESULTS	COMMENTS			CODE COVERAGE MET?
NRI	No Recordable Indications.			NA

COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM	EXAM METHOD
TEQ-000	Torus Earthquake Tie	NA	CA	Visual, VT3
		NDE PROCEDURE		MAG-CG-425-R0
RESULTS	COMMENTS			CODE COVERAGE MET?
NRI	No Recordable Indications.			NA

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

PEACH BOTTOM ATOMIC POWER STATION CONTAINMENT INSPECTION PROGRAM - 3R12

EXAM CATEGORY	NA	CODE CLASS	NA
----------------------	----	-------------------	----

COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM	EXAM METHOD
TES-BAY1-2	Torus External Column Support	NA	CA	Visual, VT3
		NDE PROCEDURE		MAG-CG-425-R0
RESULTS	COMMENTS			CODE COVERAGE MET?
NRI	No Recordable Indications.			NA

COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM	EXAM METHOD
TES-BAY2-3	Torus External Column Support	NA	CA	Visual, VT3
		NDE PROCEDURE		MAG-CG-425-R0
RESULTS	COMMENTS			CODE COVERAGE MET?
NRI	No Recordable Indications.			NA

COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM	EXAM METHOD
TES-BAY3-4	Torus External Column Support	NA	CA	Visual, VT3
		NDE PROCEDURE		MAG-CG-425-R0
RESULTS	COMMENTS			CODE COVERAGE MET?
NRI	No Recordable Indications.			NA

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

PEACH BOTTOM ATOMIC POWER STATION CONTAINMENT INSPECTION PROGRAM - 3R12

EXAM CATEGORY	NA	CODE CLASS	NA
---------------	----	------------	----

COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM	EXAM METHOD
TES-BAY4-5	Torus External Column Support	NA	CA	Visual, VT3
		NDE PROCEDURE		MAG-CG-425-R0
RESULTS	COMMENTS			CODE COVERAGE MET?
NRI	No Recordable Indications.			NA

COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM	EXAM METHOD
VHS-BAY1-2	Vent Header Support	NA	CA	Visual, VT3
		NDE PROCEDURE		MAG-CG-425-R0
RESULTS	COMMENTS			CODE COVERAGE MET?
NRI	No Recordable Indications.			NA

COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM	EXAM METHOD
VHS-BAY2-3	Vent Header Support	NA	CA	Visual, VT3
		NDE PROCEDURE		MAG-CG-425-R0
RESULTS	COMMENTS			CODE COVERAGE MET?
NRI	No Recordable Indications.			NA

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

**PEACH BOTTOM ATOMIC POWER STATION
CONTAINMENT INSPECTION PROGRAM - 3R12**

EXAM CATEGORY	NA	CODE CLASS	NA
----------------------	-----------	-------------------	-----------

COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM	EXAM METHOD
VHS-BAY3-4	Vent Header Support	NA	CA	Visual, VT3
		NDE PROCEDURE		MAG-CG-425-R0
RESULTS	COMMENTS			CODE COVERAGE MET?
NRI	No Recordable Indications.			NA

COMPONENT ID	DESCRIPTION	ITEM NO	AUG PROGRAM	EXAM METHOD
VHS-BAY4-5	Vent Header Support	NA	CA	Visual, VT3
		NDE PROCEDURE		MAG-CG-425-R0
RESULTS	COMMENTS			CODE COVERAGE MET?
NRI	No Recordable Indications.			NA

TOTAL EXAMS FOR CATEGORY	NA	20
---------------------------------	-----------	-----------

SUMMARY OF AUGMENTED INSPECTION RESULTS
PRIOR TO AND DURING 12TH REFUEL OUTAGE
PEACH BOTTOM ATOMIC POWER STATION
UNIT 3
NOVEMBER 2, 1997 TO OCTOBER 27, 1999

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 03 CORE SPRAY INTERNALS (BWRVIP-18)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
A DNCOMER RPR CLAMP	DOWNCOMER REPAIR CLAMP	VT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
B DNCOMER RPR CLAMP	DOWNCOMER REPAIR CLAMP	VT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
C DNCOMER RPR CLAMP	DOWNCOMER REPAIR CLAMP	VT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
D DNCOMER RPR CLAMP	DOWNCOMER REPAIR CLAMP	VT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
HDR TBOX REPAIR 120AZ	REPAIR PLATES ATTACHMENT WELDS	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 03 CORE SPRAY INTERNALS (BWRVIP-18)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
HDR TBOX REPAIR 240AZ	REPAIR PLATES ATTACHMENT WELDS	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
P1A	THRML SLV/JUNCTBX WELD 240 AZ	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
P1B	THRML SLV/JUNCTBX WELD 120 AZ	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
P2A	JUNCTBX COVER PLATE WELD 240 AZ	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
P2B	JUNCTBX COVER PLATE WELD 120 AZ	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 03 CORE SPRAY INTERNALS (BWRVIP-18)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
P4aA	HDR PIPE TO ELBOW WELD 352.5 AZ	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
P4bA	ELBOW TO DWNCMR WELD 352.5 AZ	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
P4cA	DWNCMR TO ELBOW WELD 352.5 AZ	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
P4dA	ELBOW TO SHROUD WELD 352.5 AZ	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
P5A	SLDG SLV TO DWNCMR WLD 352.5 AZ	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications. Examined upper HAZ only. Remainder of weld inaccessible due to clamp.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 03 CORE SPRAY INTERNALS (BWRVIP-18)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
P5B	SLDG SLV TO DWNCMR WLD 7.5 AZ	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications. Examined upper HAZ only. Remainder of weld inaccessible due to clamp.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
P5C	SLDG SLV TO DWNCMR WLD 187.5 AZ	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications. Examined upper HAZ only. Remainder of weld inaccessible due to clamp.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
P5D	SLDG SLV TO DWNCMR WLD 172.5 AZ	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications. Examined upper HAZ only. Remainder of weld inaccessible due to clamp.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
P6A	SLDG SLV TO OUTSLV WLD 352.5 AZ	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
P6B	SLDG SLV TO OUTSLV WLD 7.5 AZ	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 03 CORE SPRAY INTERNALS (BWRVIP-18)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
P6C	SLDG SLV TO OUTSLV WLD 187.5 A	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
P7A	OUTSLV TO DWNCMR WLD 352.5 AZ	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
P7B	OUTSLV TO DWNCMR WLD 7.5 AZ	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
P7C	OUTSLV TO DWNCMR WLD 187.5 AZ	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
P8aA	COLLAR TO SHROUD PIPE 352.5 AZ	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 03 CORE SPRAY INTERNALS (BWRVIP-18)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
P8aB	COLLAR TO SHROUD PIPE 7.5 AZ	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
P8aC	COLLAR TO SHROUD PIPE 187.5 AZ	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
P8aD	COLLAR TO SHROUD PIPE 172.5 AZ	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
P8bA	COLLAR TO SHROUD WELD 352.5 AZ	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
P8bB	COLLAR TO SHROUD WELD 7.5 AZ	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 03 CORE SPRAY INTERNALS (BWRVIP-18)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
P8bC	COLLAR TO SHROUD WELD 187.5 AZ	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
P8bD	COLLAR TO SHROUD WELD 172.5 AZ	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
S1A	CVR PL TO SPGR TBX WLD 352.5 AZ	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
S1B	CVR PL TO SPGR TBX WLD 7.5 AZ	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
S1C	CVR PL TO SPGR TBX WLD 187.5 AZ	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 03 CORE SPRAY INTERNALS (BWRVIP-18)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
S1D	CVR PL TO SPGR TBX WLD 172.5 AZ	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
S2A1	SPRGR PIPE TO TBX WLD 352.5 AZ	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
S2A2	SPRGR PIPE TO TBX WLD 352.5 AZ	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
S2B1	SPRGR PIPE TO TBX WLD 7.5 AZ	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
S2B2	SPRGR PIPE TO TBX WLD 7.5 AZ	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 03 CORE SPRAY INTERNALS (BWRVIP-18)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
S2C1	SPRGR PIPE TO TBX WLD 187.5 AZ	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
S2C2	SPRGR PIPE TO TBX WLD 187.5 AZ	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
S2D1	SPRGR PIPE TO TBX WLD 172.5 AZ	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
S2D2	SPRGR PIPE TO TBX WLD 172.5 AZ	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
S3aA	NZZL TO A SPRGR PIPE TYP OF 65	VT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 03 CORE SPRAY INTERNALS (BWRVIP-18)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
S3aB	NZZL TO B SPRGR PIPE TYP OF 65	VT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
S3aC	NZZL TO C SPRGR PIPE TYP OF 65	VT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
S3aD	NZZL TO D SPRGR PIPE TYP OF 65	VT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
S3bA	NZZL TO ORIFICE TYP OF 65 NOZ	VT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
S3bB	NZZL TO ORIFICE TYP OF 65 NOZ	VT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 03 CORE SPRAY INTERNALS (BWRVIP-18)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
S3bC	NZZL TO ORIFICE TYP OF 65 NOZ	VT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
S3bD	NZZL TO ORIFICE TYP OF 65 NOZ	VT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
S3cB1	B SPARGER DRAIN WELDS	VT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
S3cB2	B SPARGER DRAIN WELDS	VT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
S3cD1	D SPARGER DRAIN WELDS	VT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 03 CORE SPRAY INTERNALS (BWRVIP-18)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
S3cD2	D SPARGER DRAIN WELDS	VT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
S4A1	END CAP TO A SPRGR PIPE WELD	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
S4A2	END CAP TO A SPRGR PIPE WELD	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
S4B1	END CAP TO B SPRGR PIPE WELD	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
S4B2	END CAP TO B SPRGR PIPE WELD	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 03 CORE SPRAY INTERNALS (BWRVIP-18)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
S4C1	END CAP TO C SPRGR PIPE WELD	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
S4C2	END CAP TO C SPRGR PIPE WELD	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
S4D1	END CAP TO D SPRGR PIPE WELD	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
S4D2	END CAP TO D SPRGR PIPE WELD	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
SB1 BRACKET 7.5AZ	SPRGR BRKTS AND WELDS 7.5 AZ	VT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 03 CORE SPRAY INTERNALS (BWRVIP-18)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
SB10 BRACKET 276AZ	SPRGR BRKTS AND WELDS 264 AZ	VT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
SB11 BRACKET 316AZ	SPRGR BRKTS AND WELDS 264 AZ	VT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
SB12 BRACKET 352.5AZ	SPRGR BRKTS AND WELDS 264 AZ	VT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
SB2 BRACKET 44AZ	SPRGR BRKTS AND WELDS 44 AZ	VT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
SB3 BRACKET 84AZ	SPRGR BRKTS AND WELDS 84 AZ	VT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 03 CORE SPRAY INTERNALS (BWRVIP-18)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
SB4 BRACKET 96AZ	SPRGR BRKTS AND WELDS 96 AZ	VT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
SB5 BRACKET 136AZ	SPRGR BRKTS AND WELDS 136 AZ	VT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
SB6 BRACKET 172.5AZ	SPRGR BRKTS AND WELDS 172.5 AZ	VT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
SB7 BRACKET 187.5AZ	SPRGR BRKTS AND WELDS 187.5 AZ	VT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
SB8 BRACKET 224AZ	SPRGR BRKTS AND WELDS 224 AZ	VT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 03 CORE SPRAY INTERNALS (BWRVIP-18)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
SB9 BRACKET 264AZ	SPRGR BRKTS AND WELDS 264 AZ	VT-1	VT-PECO-204-V1
RESULTS	NRJ	COMMENTS	No Recordable Indications.

TOTAL EXAMS FOR AUGMENTED PROGRAM 03 76

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 04 JET PUMP ASSEMBLY (BWRVIP-41)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-1 JP1	Adapter Top to Adapter Bottom Weld	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-1 JP10	Adapter Top to Adapter Bottom Weld	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-1 JP2	Adapter Top to Adapter Bottom Weld	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-1 JP3	Adapter Top to Adapter Bottom Weld	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-1 JP4	Adapter Top to Adapter Bottom Weld	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 04 JET PUMP ASSEMBLY (BWRVIP-41)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-1 JP5	Adapter Top to Adapter Bottom Weld	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-1 JP6	Adapter Top to Adapter Bottom Weld	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-1 JP7	Adapter Top to Adapter Bottom Weld	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-1 JP8	Adapter Top to Adapter Bottom Weld	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-1 JP9	Adapter Top to Adapter Bottom Weld	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 04 JET PUMP ASSEMBLY (BWRVIP-41)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-2 JP1	Adapter Bottom (or Lower Ring) to Shroud Support	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-2 JP10	Adapter Bottom (or Lower Ring) to Shroud Support	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-2 JP2	Adapter Bottom (or Lower Ring) to Shroud Support	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-2 JP3	Adapter Bottom (or Lower Ring) to Shroud Support	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-2 JP4	Adapter Bottom (or Lower Ring) to Shroud Support	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 04 JET PUMP ASSEMBLY (BWRVIP-41)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-2 JP5	Adapter Bottom (or Lower Ring) to Shroud Support	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-2 JP6	Adapter Bottom (or Lower Ring) to Shroud Support	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-2 JP7	Adapter Bottom (or Lower Ring) to Shroud Support	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-2 JP8	Adapter Bottom (or Lower Ring) to Shroud Support	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-2 JP9	Adapter Bottom (or Lower Ring) to Shroud Support	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 04 JET PUMP ASSEMBLY (BWRVIP-41)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-3a JP1	Adapter Backing Ring Fillet Welds	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-3a JP10	Adapter Backing Ring Fillet Welds	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-3a JP2	Adapter Backing Ring Fillet Welds	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-3a JP3	Adapter Backing Ring Fillet Welds	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-3a JP4	Adapter Backing Ring Fillet Welds	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 04 JET PUMP ASSEMBLY (BWRVIP-41)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-3a JP5	Adapter Backing Ring Fillet Welds	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-3a JP6	Adapter Backing Ring Fillet Welds	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-3a JP7	Adapter Backing Ring Fillet Welds	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-3a JP8	Adapter Backing Ring Fillet Welds	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-3a JP9	Adapter Backing Ring Fillet Welds	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 04 JET PUMP ASSEMBLY (BWRVIP-41)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-3b JP1	Adapter Backing Ring Fillet Welds	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-3b JP10	Adapter Backing Ring Fillet Welds	EVT-1	VT-PECO-204-V1
RESULTS	RI	COMMENTS	Reportable Indications. Observed linear indications approx. 1.2 & .4 inches long. BWRVIP-41 evaluation resulted in use-as-is disposition. See NCR # PB 99-02244.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-3b JP11	Adapter Backing Ring Fillet Welds	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications. Expanded scope as result of indications observed at Jet Pumps 2 & 10.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-3b JP12	Adapter Backing Ring Fillet Welds	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications. Expanded scope as result of indications observed at Jet Pumps 2 & 10.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-3b JP13	Adapter Backing Ring Fillet Welds	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications. Expanded scope as result of indications observed at Jet Pumps 2 & 10.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 04 JET PUMP ASSEMBLY (BWRVIP-41)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-3b JP14	Adapter Backing Ring Fillet Welds	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications. Expanded scope as result of indications observed at Jet Pumps 2 & 10.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-3b JP15	Adapter Backing Ring Fillet Welds	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications. Expanded scope as result of indications observed at Jet Pumps 2 & 10.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-3b JP16	Adapter Backing Ring Fillet Welds	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications. Expanded scope as result of indications observed at Jet Pumps 2 & 10.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-3b JP17	Adapter Backing Ring Fillet Welds	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications. Expanded scope as result of indications observed at Jet Pumps 2 & 10.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-3b JP18	Adapter Backing Ring Fillet Welds	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications. Expanded scope as result of indications observed at Jet Pumps 2 & 10.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 04 JET PUMP ASSEMBLY (BWRVIP-41)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-3b JP19	Adapter Backing Ring Fillet Welds	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications. Expanded scope as result of indications observed at Jet Pumps 2 & 10.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-3b JP2	Adapter Backing Ring Fillet Welds	EVT-1	VT-PECO-204-V1
RESULTS	RI	COMMENTS	Reportable Indication. Observed linear indication approx. 1.9 inches long. BWRVIP-41 evaluation resulted in use-as-is disposition. See NCR # PB 99-02244.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-3b JP20	Adapter Backing Ring Fillet Welds	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications. Expanded scope as result of indications observed at Jet Pumps 2 & 10.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-3b JP3	Adapter Backing Ring Fillet Welds	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-3b JP4	Adapter Backing Ring Fillet Welds	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 04 JET PUMP ASSEMBLY (BWRVIP-41)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-3b JP5	Adapter Backing Ring Fillet Welds	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-3b JP6	Adapter Backing Ring Fillet Welds	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-3b JP7	Adapter Backing Ring Fillet Welds	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-3b JP8	Adapter Backing Ring Fillet Welds	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
AD-3b JP9	Adapter Backing Ring Fillet Welds	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 04 JET PUMP ASSEMBLY (BWRVIP-41)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
DF-2 JP1	Diffuser Collar to Tailpipe Weld	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
DF-2 JP10	Diffuser Collar to Tailpipe Weld	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
DF-2 JP2	Diffuser Shell to Tailpipe Weld	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
DF-2 JP3	Diffuser Shell to Tailpipe Weld	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
DF-2 JP4	Diffuser Shell to Tailpipe Weld	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 04 JET PUMP ASSEMBLY (BWRVIP-41)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
DF-2 JP5	Diffuser Shell to Tailpipe Weld	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
DF-2 JP6	Diffuser Shell to Tailpipe Weld	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
DF-2 JP7	Diffuser Shell to Tailpipe Weld	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
DF-2 JP8	Diffuser Shell to Tailpipe Weld	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
DF-2 JP9	Diffuser Shell to Tailpipe Weld	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 04 JET PUMP ASSEMBLY (BWRVIP-41)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#01 HOLD DOWN BEAM/BB-1	BEAM BOLT HOLE REGION	UT	GE-UT-504-V6
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#01 HOLD DOWN BEAM/BB-2	BEAM TRANSITION ARM REGION	UT	GE-UT-504-V6
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#02 HOLD DOWN BEAM/BB-1	BEAM BOLT HOLE REGION	UT	GE-UT-504-V6
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#02 HOLD DOWN BEAM/BB-2	BEAM TRANSITION ARM REGION	UT	GE-UT-504-V6
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#03 HOLD DOWN BEAM/BB-1	BEAM BOLT HOLE REGION	UT	GE-UT-504-V6
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 04 JET PUMP ASSEMBLY (BWRVIP-41)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#03 HOLD DOWN BEAM/BB-2	BEAM TRANSITION ARM REGION	UT	GE-UT-504-V6
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#04 HOLD DOWN BEAM/BB-1	BEAM BOLT HOLE REGION	UT	GE-UT-504-V6
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#04 HOLD DOWN BEAM/BB-2	BEAM TRANSITION ARM REGION	UT	GE-UT-504-V6
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#05 HOLD DOWN BEAM/BB-1	BEAM BOLT HOLE REGION	UT	GE-UT-504-V6
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#05 HOLD DOWN BEAM/BB-2	BEAM TRANSITION ARM REGION	UT	GE-UT-504-V6
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 04 JET PUMP ASSEMBLY (BWRVIP-41)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#06 HOLD DOWN BEAM/BB-1	BEAM BOLT HOLE REGION	UT	GE-UT-504-V6
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#06 HOLD DOWN BEAM/BB-2	BEAM TRANSITION ARM REGION	UT	GE-UT-504-V6
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#07 HOLD DOWN BEAM/BB-1	BEAM BOLT HOLE REGION	UT	GE-UT-504-V6
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#07 HOLD DOWN BEAM/BB-2	BEAM TRANSITION ARM REGION	UT	GE-UT-504-V6
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#08 HOLD DOWN BEAM/BB-1	BEAM BOLT HOLE REGION	UT	GE-UT-504-V6
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 04 JET PUMP ASSEMBLY (BWRVIP-41)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#08 HOLD DOWN BEAM/BB-2	BEAM TRANSITION ARM REGION	UT	GE-UT-504-V6
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#09 HOLD DOWN BEAM/BB-1	BEAM BOLT HOLE REGION	UT	GE-UT-504-V6
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#09 HOLD DOWN BEAM/BB-2	BEAM TRANSITION ARM REGION	UT	GE-UT-504-V6
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#10 HOLD DOWN BEAM/BB-1	BEAM BOLT HOLE REGION	UT	GE-UT-504-V6
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#10 HOLD DOWN BEAM/BB-2	BEAM TRANSITION ARM REGION	UT	GE-UT-504-V6
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 04 JET PUMP ASSEMBLY (BWRVIP-41)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#11 HOLD DOWN BEAM/BB-1	BEAM BOLT HOLE REGION	UT	GE-UT-504-V6
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#11 HOLD DOWN BEAM/BB-2	BEAM TRANSITION ARM REGION	UT	GE-UT-504-V6
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#12 HOLD DOWN BEAM/BB-1	BEAM BOLT HOLE REGION	UT	GE-UT-504-V6
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#12 HOLD DOWN BEAM/BB-2	BEAM TRANSITION ARM REGION	UT	GE-UT-504-V6
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#13 HOLD DOWN BEAM/BB-1	BEAM BOLT HOLE REGION	UT	GE-UT-504-V6
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 04 JET PUMP ASSEMBLY (BWRVIP-41)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#13 HOLD DOWN BEAM/BB-2	BEAM TRANSITION ARM REGION	UT	GE-UT-504-V6
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#14 HOLD DOWN BEAM/BB-1	BEAM BOLT HOLE REGION	UT	GE-UT-504-V6
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#14 HOLD DOWN BEAM/BB-2	BEAM TRANSITION ARM REGION	UT	GE-UT-504-V6
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#15 HOLD DOWN BEAM/BB-1	BEAM BOLT HOLE REGION	UT	GE-UT-504-V6
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#15 HOLD DOWN BEAM/BB-2	BEAM TRANSITION ARM REGION	UT	GE-UT-504-V6
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 04 JET PUMP ASSEMBLY (BWRVIP-41)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#16 HOLD DOWN BEAM/BB-1	BEAM BOLT HOLE REGION	UT	GE-UT-504-V6
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#16 HOLD DOWN BEAM/BB-2	BEAM TRANSITION ARM REGION	UT	GE-UT-504-V6
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#17 HOLD DOWN BEAM/BB-1	BEAM BOLT HOLE REGION	UT	GE-UT-504-V6
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#17 HOLD DOWN BEAM/BB-2	BEAM TRANSITION ARM REGION	UT	GE-UT-504-V6
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#18 HOLD DOWN BEAM/BB-1	BEAM BOLT HOLE REGION	UT	GE-UT-504-V6
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 04 JET PUMP ASSEMBLY (BWRVIP-41)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#18 HOLD DOWN BEAM/BB-2	BEAM TRANSITION ARM REGION	UT	GE-UT-504-V6
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#19 HOLD DOWN BEAM/BB-1	BEAM BOLT HOLE REGION	UT	GE-UT-504-V6
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#19 HOLD DOWN BEAM/BB-2	BEAM TRANSITION ARM REGION	UT	GE-UT-504-V6
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#20 HOLD DOWN BEAM/BB-1	BEAM BOLT HOLE REGION	UT	GE-UT-504-V6
RESULTS	RI	COMMENTS	Reportable Indications. Observed in beam ligament area. BEAM REPLACED (WO C0190949)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
JP#20 HOLD DOWN BEAM/BB-2	BEAM TRANSITION ARM REGION	UT	GE-UT-504-V6
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 04 JET PUMP ASSEMBLY (BWRVIP-41)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
RISER CLAMP JP1/2	Riser Clamp at 150° Azimuth Unit 3 Only	VT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
RISER CLAMP JP13/14	Riser Clamp at 300° Azimuth Unit 3 Only	VT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
RS-2 (3/4)	Riser Pipe to Transition Piece Weld	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
RS-2 (5/6)	Riser Pipe to Transition Piece Weld	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
RS-2 (7/8)	Riser Pipe to Transition Piece Weld	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 04 **JET PUMP ASSEMBLY (BWRVIP-41)**

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
RS-3 (3/4)	Riser Pipe to Transition Piece Weld	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
RS-3 (5/6)	Riser Pipe to Transition Piece Weld	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
RS-3 (7/8)	Riser Pipe to Transition Piece Weld	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

TOTAL EXAMS FOR AUGMENTED PROGRAM 04 108

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 07 SHROUD SUPPORT (BWRVIP-38)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
H8	Shroud Support-to-Shroud Weld	EVT-1	VT-PECO-204-V1

RESULTS	NRI	COMMENTS	No Recordable Indications. Examined 10% of weld length.
----------------	-----	-----------------	---------------------------------------------------------

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
H9	Shroud Support-to-RPV Weld	EVT-1	VT-PECO-204-V1

RESULTS	NRI	COMMENTS	No Recordable Indications. Examined 10% of weld length.
----------------	-----	-----------------	---------------------------------------------------------

TOTAL EXAMS FOR AUGMENTED PROGRAM 07 2

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 09 CORE SHROUD (BWRVIP-01)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
H-3 SHROUD	SHROUD H-3 WELD	VT-1 OR UT	GE-UT-504-V6

RESULTS	RI	COMMENTS	Reportable Indications. Total weld length examined 87.67% of which 37.9% was found flawed on lower side of weld. Reference NCR# 99-00041 for use-as-is disposition & SIR-99-141.
----------------	----	-----------------	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
H-4 SHROUD	SHROUD H-4 WELD	VT-1 OR UT	GE-UT-504-V6

RESULTS	RI	COMMENTS	Reportable Indications. Total weld length scanned 87.99% of which 18.4% found flawed on upper side and 28.9% found flawed on lower side of weld. Reference NCR # 99-00041 for use-as-is disposition & SIR-99-141.
----------------	----	-----------------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

TOTAL EXAMS FOR AUGMENTED PROGRAM 09 2

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 11 LOWER PLENUM REGION (BWRVIP-47)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
CRGT-1 14-15	GUIDE TUBE TO ALIGNMENT LUG	VT-3	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
CRGT-1 14-31	GUIDE TUBE TO ALIGNMENT LUG	VT-3	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
CRGT-1 14-47	GUIDE TUBE TO ALIGNMENT LUG	VT-3	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
CRGT-1 18-19	GUIDE TUBE TO ALIGNMENT LUG	VT-3	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
CRGT-1 18-27	GUIDE TUBE TO ALIGNMENT LUG	VT-3	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 11 LOWER PLENUM REGION (BWRVIP-47)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
CRGT-1 18-35	GUIDE TUBE TO ALIGNMENT LUG	VT-3	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
CRGT-1 18-43	GUIDE TUBE TO ALIGNMENT LUG	VT-3	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
CRGT-1 26-11	GUIDE TUBE TO ALIGNMENT LUG	VT-3	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
CRGT-1 34-35	GUIDE TUBE TO ALIGNMENT LUG	VT-3	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
CRGT-1 42-19	GUIDE TUBE TO ALIGNMENT LUG	VT-3	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 11 LOWER PLENUM REGION (BWRVIP-47)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
CRGT-2 14-15	GUIDE TUBE BODY TO SLEEVE	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
CRGT-2 14-31	GUIDE TUBE BODY TO SLEEVE	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
CRGT-2 14-47	GUIDE TUBE BODY TO SLEEVE	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
CRGT-2 18-19	GUIDE TUBE BODY TO SLEEVE	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
CRGT-2 18-27	GUIDE TUBE BODY TO SLEEVE	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 11 LOWER PLENUM REGION (BWRVIP-47)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
CRGT-2 18-35	GUIDE TUBE BODY TO SLEEVE	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
CRGT-2 18-43	GUIDE TUBE BODY TO SLEEVE	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
CRGT-2 26-11	GUIDE TUBE BODY TO SLEEVE	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
CRGT-2 34-35	GUIDE TUBE BODY TO SLEEVE	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
CRGT-2 42-19	GUIDE TUBE BODY TO SLEEVE	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 11 LOWER PLENUM REGION (BWRVIP-47)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
CRGT-3 14-15	GUIDE TUBE BASE TO BODY	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
CRGT-3 14-31	GUIDE TUBE BASE TO BODY	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
CRGT-3 14-47	GUIDE TUBE BASE TO BODY	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
CRGT-3 18-19	GUIDE TUBE BASE TO BODY	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
CRGT-3 18-27	GUIDE TUBE BASE TO BODY	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 11 LOWER PLENUM REGION (BWRVIP-47)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
CRGT-3 18-35	GUIDE TUBE BASE TO BODY	EVT-1	VT-PECO-204-V1

RESULTS NRI COMMENTS No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
CRGT-3 18-43	GUIDE TUBE BASE TO BODY	EVT-1	VT-PECO-204-V1

RESULTS NRI COMMENTS No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
CRGT-3 26-11	GUIDE TUBE BASE TO BODY	EVT-1	VT-PECO-204-V1

RESULTS NRI COMMENTS No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
CRGT-3 34-35	GUIDE TUBE BASE TO BODY	EVT-1	VT-PECO-204-V1

RESULTS NRI COMMENTS No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
CRGT-3 42-19	GUIDE TUBE BASE TO BODY	EVT-1	VT-PECO-204-V1

RESULTS NRI COMMENTS No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 11 **LOWER PLENUM REGION (BWRVIP-47)**

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
FS/GT-ARPIN-1 14-15	ALIGNMENT PIN	VT-3	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
FS/GT-ARPIN-1 14-31	ALIGNMENT PIN	VT-3	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
FS/GT-ARPIN-1 14-47	ALIGNMENT PIN	VT-3	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
FS/GT-ARPIN-1 18-19	ALIGNMENT PIN	VT-3	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
FS/GT-ARPIN-1 18-27	ALIGNMENT PIN	VT-3	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 11 LOWER PLENUM REGION (BWRVIP-47)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
FS/GT-ARPIN-1 18-35	ALIGNMENT PIN	VT-3	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
FS/GT-ARPIN-1 18-43	ALIGNMENT PIN	VT-3	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
FS/GT-ARPIN-1 26-11	ALIGNMENT PIN	VT-3	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
FS/GT-ARPIN-1 34-35	ALIGNMENT PIN	VT-3	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
FS/GT-ARPIN-1 42-19	ALIGNMENT PIN	VT-3	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

TOTAL EXAMS FOR AUGMENTED PROGRAM 11 40

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 14 RPV ID ATTACHMENT WELDS (BWRVIP-48)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
CORE SPRAY BRACKET PAD AZ 117	VESSEL ID ATTACHMENT WELD	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
CORE SPRAY BRACKET PAD AZ 123	VESSEL ID ATTACHMENT WELD	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
CORE SPRAY BRACKET PAD AZ 15	VESSEL ID ATTACHMENT WELD	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
CORE SPRAY BRACKET PAD AZ 165	VESSEL ID ATTACHMENT WELD	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
CORE SPRAY BRACKET PAD AZ 195	VESSEL ID ATTACHMENT WELD	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

PBAPS ISI OUTAGE SUMMARY REPORT

3R12

AUG PROGRAM 14 RPV ID ATTACHMENT WELDS (BWRVIP-48)

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
CORE SPRAY BRACKET PAD AZ 237	VESSEL ID ATTACHMENT WELD	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
CORE SPRAY BRACKET PAD AZ 243	VESSEL ID ATTACHMENT WELD	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

COMPONENT ID	DESCRIPTION	EXAM METHOD	NDE PROCEDURE
CORE SPRAY BRACKET PAD AZ 345	VESSEL ID ATTACHMENT WELD	EVT-1	VT-PECO-204-V1
RESULTS	NRI	COMMENTS	No Recordable Indications.

TOTAL EXAMS FOR AUGMENTED PROGRAM 14 8

SECTION 2

**SUMMARY OF REPORTABLE CONDITIONS OBSERVED
DURING IN-SERVICE INSPECTION
PEACH BOTTOM ATOMIC POWER STATION
UNIT 3
NOVEMBER 2, 1997 TO OCTOBER 27, 1999**

SUMMARY OF REPORTABLE CONDITIONS OBSERVED

As a result of examinations performed prior to and during the Unit 3, 12th Refuel Outage, numerous conditions were noted. Subsequent examinations and/or evaluations determined most conditions to be either insignificant or geometric in nature. However, several reportable conditions were recorded and are summarized below:

H-3, H-4

Core Shroud Welds

On weld H-3, 8 - IGSCC/IASCC associated indications totaling 216.39 inches were reported in the 570.43 inches of weld length examined. The examinations were performed from the lower side of the weld.

Weld H-4 was examined from the upper and lower side for a total of 572.51 inches. On the upper side, 13 - IGSCC/IASCC associated indications totaling 101.72 inches were reported. On the lower side, 16 - IGSCC/IASCC associated indications totaling 165.62 inches were reported.

Details of these reportable indications can be found in the PB 3R12 ISI Summary Report. An engineering evaluation of these indications was made and concluded that there are substantial margins for the H-3 and H-4 welds, under conservative, bounding conditions, to allow for continued operation without reinspection for at least six years. Reference NCR # 99-00041, rev. 1. Subsequent to the disposition of this NCR, an additional engineering evaluation was performed by Structural Integrity Associates. Report SIR-99-141 dated 12/1/99 (copy attached) provides justification for a reinspection frequency of ten years.

AD-3b WELD

Jet Pumps # 2 & 10

At Jet Pump #2 weld AD-3b, a crack-like indication measuring approximately 1.9 inches was observed. Similarly, Jet Pump #10 weld AD-3B was observed to contain two crack-like indications measuring approximately 1.2 and 0.4 inches.

SECTION 2

SUMMARY OF REPORTABLE CONDITIONS OBSERVED

Details of these reportable indications can be found in the PB 3R12 ISI Summary Report. An engineering evaluation of these indications was performed and concluded that structural integrity is demonstrated through the next two 24 month operating cycles. Reference NCR # 99-02244.

HOLD DOWN BEAM

Jet Pump # 20

At Jet Pump # 20, the beam ligament area examination produced recordable responses that could be interpreted as being cracks. The beam was replaced, see Work Order # C0190949.

SECTION 3

**SUMMARY OF ASME REPAIRS
AND REPLACEMENTS COMPLETED
PEACH BOTTOM ATOMIC POWER STATION
UNIT 3
NOVEMBER 2, 1997 TO OCTOBER 27, 1999**

**SUMMARY OF ASME REPAIRS AND REPLACEMENTS COMPLETED
FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 3
NOVEMBER 2, 1997 TO OCTOBER 27, 1999
(END OF 3R12 REFUEL OUTAGE)**

** Denotes that use of Code Case N-416-1 was employed in completing the repair / replacement activity

SYSTEM 01: MAIN STEAM SYSTEM

Code Class	Repair, Replacement, or Corrective Measure	Item Description (component I.D.)	Description Of Work Performed	Flaw or Relevant Condition Found During Scheduled Section XI Exam	Date	R&R Plan # and W/O #	
				Or Test	Complete		
Class 1	replacement	RV-3-02-071E	Installed a rebuilt safety relief valve	No	11/29/1997	97-034,	R0647295
Class 1	replacement	RV-3-02-071J	Installed a rebuilt safety relief valve	No	10/15/1999	99-016,	R0647296
Class 1	replacement	RV-3-02-070A	Installed a rebuilt safety relief valve	No	10/12/1999	99-017,	R0647936
Class 1	replacement	RV-3-02-071B	Installed a rebuilt safety relief valve	No	10/13/1999	99-018,	R0647939
Class 1	replacement	RV-3-02-071F	Installed a rebuilt safety relief valve	No	10/11/1999	99-019,	R0648058
Class 1	replacement	RV-3-02-071L	Installed a rebuilt safety relief valve	No	10/12/1999	99-020,	R0648064
Class 3	replacement	1-GG-S-3	Installed new pressurized reservoir snubber	No	10/12/1999	99-042,	R0471778
Class 3	replacement	1-GG-S-6	Installed new pressurized reservoir snubber	No	10/08/1999	99-043,	R0471782
Class 3	replacement	1-GG-S-7	Installed new pressurized reservoir snubber	No	10/09/1999	99-044,	R0471785
Class 3	replacement	1-GG-S-16	Installed new pressurized reservoir snubber	No	10/08/1999	99-045,	R0471797
Class 3	replacement	1-GG-S-66	Installed new pressurized reservoir snubber	No	10/12/1999	99-046,	R0508496
Class 2	replacement	7-DB-S-11	Installed new pressurized reservoir snubber	No	10/08/1999	99-060,	R0508500
Class 1	replacement	SS-B-3	Installed new pressurized reservoir snubber	No	10/12/1999	99-076,	R0471775
Class 1	replacement	RV-3-02-071K	Installed a rebuilt safety relief valve	No	10/15/1999	99-085,	R0648063
Class 1	replacement	RV-3-02-071C	Installed a rebuilt safety relief valve	No	10/23/1999	99-134,	C0190996

SYSTEM 02: REACTOR AND RECIRCULATION

Code Class	Repair, Replacement, or Corrective Measure	Item Description (component I.D.)	Description Of Work Performed	Flaw or Relevant Condition Found During Scheduled Section XI Exam	Date	R&R Plan # and W/O #	
				Or Test	Complete		
Class 1	replacement	SS-1-A	Installed new pressurized reservoir snubber	No	10/04/1999	99-075,	R0471772
Class 1	replacement	SS-3-C	Installed new pressurized reservoir snubber	No	10/06/1999	99-084,	R0508163

**SUMMARY OF ASME REPAIRS AND REPLACEMENTS COMPLETED
FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 3
NOVEMBER 2, 1997 TO OCTOBER 27, 1999
(END OF 3R12 REFUEL OUTAGE)**

** Denotes that use of Code Case N-416-1 was employed in completing the repair / replacement activity

SYSTEM 03: CONTROL ROD DRIVE

<u>Code Class</u>	<u>Repair, Replacement, or Corrective Measure</u>	<u>Item Description (component I.D.)</u>	<u>Description Of Work Performed</u>	<u>Flaw or Relevant Condition Found During Scheduled Section XI Exam Or Test</u>	<u>Date Complete</u>	<u>R&R Plan # and W/O #</u>
Class 1	replacement	CRD-3-03-4247	Replaced CRD during 3J12 mini-outage	No	03/17/1998	98-016, R0749129
Class 1	replacement	CRD-3-03-4251	Replaced CRD during 3J12 mini-outage	No	03/17/1998	98-016, R0749129
Class 1	replacement	CRD-3-03-2643	Replaced CRD during 3J12 mini-outage	No	03/17/1998	98-097, C0181166
Class 1	replacement	CRD's 06-31 10-27, 14-51, 18-55, 22-27, 30-19, 30-23, 30-27, 30-39, 34-31, 38-07, 38-51, 38-55, 42-59, 46-43, 54-23, 26-11, 34-35, 42-19,	Exchanged CRD's with rebuilt CRD's during 3R12 outag	No	10/10/1999	99-028, R0767661

SYSTEM 04: REACTOR PRESSURE VESSEL AND INTERNALS

<u>Code Class</u>	<u>Repair, Replacement, or Corrective Measure</u>	<u>Item Description (component I.D.)</u>	<u>Description Of Work Performed</u>	<u>Flaw or Relevant Condition Found During Scheduled Section XI Exam Or Test</u>	<u>Date Complete</u>	<u>R&R Plan # and W/O #</u>
Class 1	replacement	PB-3-04-30S001	Replaced a drywell head washer	No	06/01/1998	98-014, R0746745

SYSTEM 06: FEEDWATER SYSTEM

<u>Code Class</u>	<u>Repair, Replacement, or Corrective Measure</u>	<u>Item Description (component I.D.)</u>	<u>Description Of Work Performed</u>	<u>Flaw or Relevant Condition Found During Scheduled Section XI Exam Or Test</u>	<u>Date Complete</u>	<u>R&R Plan # and W/O #</u>
Class 2	replacement	MO-3-06D-3163A	Installed a new valve bonnet and plugged leakoff port	No	03/02/1998	98-024, C0180112
Class 2	replacement	MO-3-06D-3163C	Installed a new valve bonnet and plugged leakoff port	No	03/02/1998	98-025, C0179889
Class 1	replacement	6-DDNL-S-8	Installed new pressurized resevoir snubber	No	10/04/1999	99-070, R0471995
Class 1	replacement	6-DDNL-S-9	Installed new pressurized reservoir snubber	No	10/04/1999	99-073, R0471997
Class 1	replacement	6-DDNL-S-13	Installed new pressurized reservoir snubber	No	10/03/1999	99-077, R0508497

**SUMMARY OF ASME REPAIRS AND REPLACEMENTS COMPLETED
FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 3
NOVEMBER 2, 1997 TO OCTOBER 27, 1999
(END OF 3R12 REFUEL OUTAGE)**

**** Denotes that use of Code Case N-416-1 was employed in completing the repair / replacement activity**

SYSTEM 07: PRIMARY CONTAINMENT

<u>Code Class</u>	<u>Repair, Replacement, or Corrective Measure</u>	<u>Item Description (component I.D.)</u>	<u>Description Of Work Performed</u>	<u>Flaw or Relevant Condition Found During Scheduled Section XI Exam Or Test</u>	<u>Date Complete</u>	<u>R&R Plan # and W/O #</u>
Class M	replacement	PB-3-07-N-002	Replaced gaskets on primary containment equipment access hatch with personnel lock.	No	03/27/1998	98-081, R0748968
Class M	replacement	PB-3-07-N-200B	Replaced o-rings on suppression chamber access hatch	No	03/19/1998	98-082, R0747871
Class M	replacement	PB-3-07-N-006	Replaced gaskets on the primary containment CRD removal hatch.	No	03/20/1998	98-083, R0745410
Class M	replacement	PB-3-04-30S001	Replaced the drywell head o-rings	No	03/26/1998	98-084, R0746753

SYSTEM 10: RESIDUAL HEAT REMOVAL

<u>Code Class</u>	<u>Repair, Replacement, or Corrective Measure</u>	<u>Item Description (component I.D.)</u>	<u>Description Of Work Performed</u>	<u>Flaw or Relevant Condition Found During Scheduled Section XI Exam Or Test</u>	<u>Date Complete</u>	<u>R&R Plan # and W/O #</u>
Class 2	replacement	3-10HB-S10	Installed new anchor bolt on wall support	Yes	12/08/1997	97-077, C0178678
Class 2	repair	3-10HB-H33	Rework support base plates per NCR PB98-00208	No	09/15/1998	98-124, C0182674
** Class 2	replacement	RV-3-10-33425	Install new relief valve, 3/4" sockolet to 20" "DLA" pipe	No	10/18/1999	99-087, C0188199
Class 2	replacement	10-GB-S-43-2	Installed new pressurized reservoir snubber	No	10/15/1999	99-068, R0471765
Class 2	replacement	10-HB-S-7	Installed new pressurized reservoir snubber	No	10/02/1999	99-069, R0471766

SYSTEM 11: STANDBY LIQUID CONTROL SYSTEM

<u>Code Class</u>	<u>Repair, Replacement, or Corrective Measure</u>	<u>Item Description (component I.D.)</u>	<u>Description Of Work Performed</u>	<u>Flaw or Relevant Condition Found During Scheduled Section XI Exam Or Test</u>	<u>Date Complete</u>	<u>R&R Plan # and W/O #</u>
Class 2	replacement	RV-3-11-39A	Installed new relief valve	No	10/12/1999	99-054, R0743870
Class 2	replacement	RV-3-11-39B	Installed new relief valve	No	10/12/1999	99-055, R0743871

**SUMMARY OF ASME REPAIRS AND REPLACEMENTS COMPLETED
FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 3
NOVEMBER 2, 1997 TO OCTOBER 27, 1999
(END OF 3R12 REFUEL OUTAGE)**

**** Denotes that use of Code Case N-416-1 was employed in completing the repair / replacement activity**

SYSTEM 12: REACTOR WATER CLEANUP SYSTEM

<u>Code Class</u>	<u>Repair, Replacement, or Corrective Measure</u>	<u>Item Description (component I.D.)</u>	<u>Description Of Work Performed</u>	<u>Flaw or Relevant Condition Found During Scheduled Section XI Exam Or Test</u>	<u>Date Complete</u>	<u>R&R Plan # and W/O #</u>
Class 1	replacement	MO-3-12-068	Incidental bonnet bolt replacement - not due to failure	No	10/09/1999	99-128, C0190847

SYSTEM 13: REACTOR CORE ISOLATION COOLING SYSTEM

<u>Code Class</u>	<u>Repair, Replacement, or Corrective Measure</u>	<u>Item Description (component I.D.)</u>	<u>Description Of Work Performed</u>	<u>Flaw or Relevant Condition Found During Scheduled Section XI Exam Or Test</u>	<u>Date Complete</u>	<u>R&R Plan # and W/O #</u>
Class 2	replacement	VRV-3-13C-139A	Installed new 2" vacuum relief valve	No	01/27/1998	98-005, R0627006
Class 2	replacement	VRV-3-13C-139B	Installed new 2" vacuum relief valve	No	01/27/1998	98-006, R0627007
Class 1	replacement	MO-3-13-016	Installed new bonnet on 3" - class 1 valve	No	03/16/1998	98-010, C0179445
** Class 2	replacement	CHK-3-13C-133	Installed new check valve, 2" - class 2 valve	No	10/03/1999	98-119, C0181952
** Class 2	replacement	CHK-3-13C-38	Installed new check valve, 2" - class 2 valve	No	10/06/1999	99-066, C0187046

SYSTEM 14: CORE SPRAY COOLING SYSTEM

<u>Code Class</u>	<u>Repair, Replacement, or Corrective Measure</u>	<u>Item Description (component I.D.)</u>	<u>Description Of Work Performed</u>	<u>Flaw or Relevant Condition Found During Scheduled Section XI Exam Or Test</u>	<u>Date Complete</u>	<u>R&R Plan # and W/O #</u>
Class 1	replacement	14-DCN-S-27	Installed new pressurized reservoir snubber	No	10/12/1999	99-064, R0471600
Class 1	replacement	14-DCN-S-26	Installed new pressurized reservoir snubber	No	10/12/1999	99-071, R0472003

**SUMMARY OF ASME REPAIRS AND REPLACEMENTS COMPLETED
FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 3
NOVEMBER 2, 1997 TO OCTOBER 27, 1999
(END OF 3R12 REFUEL OUTAGE)**

** Denotes that use of Code Case N-416-1 was employed in completing the repair / replacement activity

SYSTEM 19: FUEL POOL COOLING SYSTEM

<u>Code Class</u>	<u>Repair, Replacement, or Corrective Measure</u>	<u>Item Description (component I.D.)</u>	<u>Description Of Work Performed</u>	<u>Flaw or Relevant Condition Found During Scheduled Section XI Exam Or Test</u>	<u>Date Complete</u>	<u>R&R Plan # and W/O #</u>
Class 1	replacement	Flange Spool Piece	Installed new studs & nuts, fuel pool skimmer cross tie	No	09/03/1999	99-088, C0188510

SYSTEM 23: HIGH PRESSURE COOLANT INJECTION SYSTEM

<u>Code Class</u>	<u>Repair, Replacement, or Corrective Measure</u>	<u>Item Description (component I.D.)</u>	<u>Description Of Work Performed</u>	<u>Flaw or Relevant Condition Found During Scheduled Section XI Exam Or Test</u>	<u>Date Complete</u>	<u>R&R Plan # and W/O #</u>
Class 2	replacement	VRV-3-23C-140A,B,C,D	Installed new vacuum relief valves	No	02/01/1999	99-003, C0185425
Class 1	replacement	23-DBN-S-22	Installed new pressurized reservoir snubber	No	10/03/1999	99-065, R0471762
Class 1	replacement	23-DBN-S-23	Installed new pressurized reservoir snubber	No	10/03/1999	99-067, R0471763
Class 2	replacement	23-DBN-S-1	Installed new pressurized reservoir snubber	No	09/30/1999	99-074, C0187683
Class 2	replacement	23-HB-S-1-A	Installed new pressurized reservoir snubber	No	09/30/1999	99-078, R0472035
Class 2	replacement	23-DBN-S-6-1	Installed new pressurized reservoir snubber & base plate	No	09/30/1999	99-082, R0471770
Class 2	replacement	23-DBN-S-6-2	Installed new pressurized reservoir snubber & base plate	No	09/30/1999	99-083, R0471771
Class 2	replacement	3-23DDN-S32	Add 3" x 3" x 1/4" angle to support	No	10/28/1999	99-089, C0188342
Class 2	replacement	3-23DBN-S53	Rework rigid restraint	No	10/16/1999	99-112, C0189708
			Rework rigid restraint			

SYSTEM 32: HIGH PRESSURE SERVICE WATER SYSTEM

<u>Code Class</u>	<u>Repair, Replacement, or Corrective Measure</u>	<u>Item Description (component I.D.)</u>	<u>Description Of Work Performed</u>	<u>Flaw or Relevant Condition Found During Scheduled Section XI Exam Or Test</u>	<u>Date Complete</u>	<u>R&R Plan # and W/O #</u>
Class 3	repair	3-32GB-S59, 3-32GB-H27	Installed shims on rigid restraint	No	02/10/1998	97-071, C0177815
** Class 3	replacement	RO-3789A and RO-3800A	Installed new 14" pipe, slip-on flanges, and elbow	No	05/27/1999	98-171, C0185060

**SUMMARY OF ASME REPAIRS AND REPLACEMENTS COMPLETED
FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 3
NOVEMBER 2, 1997 TO OCTOBER 27, 1999
(END OF 3R12 REFUEL OUTAGE)**

**** Denotes that use of Code Case N-416-1 was employed in completing the repair / replacement activity**

SYSTEM 33: EMERGENCY SERVICE WATER SYSTEM

<u>Code Class</u>	<u>Repair, Replacement, or Corrective Measure</u>	<u>Item Description (component I.D.)</u>	<u>Description Of Work Performed</u>	<u>Flaw or Relevant Condition Found During Scheduled Section XI Exam Or Test</u>	<u>Date Complete</u>	<u>R&R Plan # and W/O #</u>
Class 3	repair	33HB-H127, 33HB-S63	Installed shims to correct gap on pipe supports	No	11/13/1997	97-072, C0178470
** Class 3	replacement	HV-3-33-502, FW#501	Installed half coupling, pipe, cap on FW#501	No	10/18/1999	99-124, C0190598

SYSTEM 60: PLANT PROTECTION INSTRUMENTATION

<u>Code Class</u>	<u>Repair, Replacement, or Corrective Measure</u>	<u>Item Description (component I.D.)</u>	<u>Description Of Work Performed</u>	<u>Flaw or Relevant Condition Found During Scheduled Section XI Exam Or Test</u>	<u>Date Complete</u>	<u>R&R Plan # and W/O #</u>
Class 1	replacement	LPRM 32-49	Installed new bottom flange and bolts	No	10/12/1999	99-131, R0747361



December 1, 1999
SIR-99-141
RAM-99-091

3315 Almaden Expressway
Suite 24
San Jose, CA 95118-1557
Phone: 408-978-8200
Fax: 408-978-8964
www.structint.com
mattson@structint.com

Ms. Charlotte K. Geiger
PECO Energy Company
Peach Bottom Atomic Power Station
1848 Lay Road (SMB-3-6)
Delta, PA 17314

Subject: Evaluation of Peach Bottom, Unit 3 Shroud Examination Results

Dear Charlotte:

Structural Integrity Associates (SI) has performed an evaluation of the ultrasonic examination results recorded during the 1999 inspection of shroud circumferential welds H3 and H4 at Peach Bottom, Unit 3, in order to determine maximum reinspection intervals. The evaluations performed and documented herein were designed to justify operation without reinspection of these welds for at least ten years of operation. The evaluations were performed following the approach used in the BWR Vessel and Internals Project (BWRVIP) shroud evaluation guidelines [3], based on limit load and linear elastic fracture mechanics (LEFM) techniques. The following sections of this report describe the methodology used to evaluate each weld, the resulting safety margins, and the recommended inspection intervals.

INSPECTION AND EVALUATION METHODOLOGY

The inspection and evaluation approach employed at Peach Bottom, Unit 3 provides the necessary information for determination of the required amount of unflawed material to meet specified safety margins, including the appropriate amount for postulated crack growth and nondestructive examination detection and sizing uncertainties. Ultrasonic examination (UT) techniques were utilized which provided complete through-thickness interrogation of all welds. Due to accessibility limitations, the circumferential extent of examination of these welds varied. However, sufficient weld length was adequately interrogated to quantifiably demonstrate the condition, and hence, the structural integrity of all welds evaluated. Because both limit load and LEFM assessments have been performed, evaluation methodologies will be addressed separately with respect to structural integrity evaluation.

ACCEPTANCE CRITERIA

The core shroud is a core support structure which provides lateral support for the fuel. The applicable codes, standards and classification for the core shroud are as follows:

- The core shroud is classified as a safety-related component.
- The core shroud is not an ASME Code, Section III component. However, the original design is in accordance with the intent of Section III of the ASME Code.
- The evaluation of the core shroud was performed in accordance with the requirements of the BWRVIP's shroud evaluation guidelines [3].

FLAW EVALUATION RESULTS

Based upon the inspection data reported in 1999, flaw evaluations have been performed in accordance with the shroud evaluation guidelines [3], with the results documented herein. The analyses were performed using limit load as the failure criterion for each of the welds. The analyses performed take into account the distribution of good material at each weld around the circumference of the shroud. In addition, the H3 and H4 welds, which are the most highly irradiated, were evaluated using the LEFM methodology.

Substantial conservatism was built into the evaluation to account for the weld area examined, the weld area which was not examined, evaluation guidelines' detection and sizing uncertainties, crack growth, and the evaluation guidelines' flaw proximity criteria as applied to adjacent flaws. The specific conservatisms utilized in this evaluation are as follows:

1. All areas not examined, or reported with flaws, were considered cracked through-wall for all evaluations.
2. A bounding crack growth rate (5×10^{-5} inches/hour) [3] in the length direction was applied to all identified flaws, as well as to all the uninspected regions.
3. UT inspection uncertainty factors were applied to all identified indications, as well as to uninspected regions.
4. Ten years of crack growth were included in the evaluation of all welds.
5. ASME Code, Section XI proximity criteria for adjacent flaws were applied, after accounting for crack growth and inspection uncertainties.
6. ASME Code, Section XI pressure boundary safety margins were applied to these evaluations even though the core shroud is not a primary pressure boundary.

7. Dead weight of the shroud and supported components was conservatively ignored.

The conservative assumptions described above were applied to each of the horizontal welds examined in this report. Table 1 documents the input data. Tables 2 and 3 present the results of the ultrasonic examination for each of the horizontal welds evaluated in this report, from the 1999 inspections. These are graphically depicted in Figures 1 and 2. A comparison of the examination results with the values used for the analyses (which include the previously described conservatisms) is shown in Figures 3 and 4. It should be noted that flaws are considered cracked through-wall when taking into account crack growth for the specified period.

The results of the limit load analyses for each of the horizontal welds examined are presented in Table 4, based upon the stresses reported in Table 1, and the examination results reported in Tables 2 and 3. Based upon the stresses reported in Table 1, the upset condition governs for weld H4, while the faulted condition governs for weld H3. One observes from Table 4 that the factor-of-safety for the upset condition is 28.0, and for the faulted condition is 24.5. This compares to ASME Code minimum factors-of-safety of 2.77 and 1.39, respectively, specified for pressure boundary components [3]. One should note that the conservatisms utilized in this study are as described previously in this section.

Finally, an evaluation of the H3 and H4 welds was performed using the LEFM methodology to determine the applied stress intensity factor resulting from the bounding loading conditions. The results of this analysis demonstrate that the 150 ksi $\sqrt{\text{inch}}$ material toughness which is presented in the evaluation guidelines [3] as the acceptable fracture toughness for this material under irradiation embrittled conditions is met. Table 5 illustrates that the evaluation guidelines [3] minimum required factors-of-safety have been met for welds H3 and H4.

EVALUATION OF CRACK GROWTH RATE

For purposes of evaluating the Peach Bottom, Unit 3 shroud for continued service, a crack growth rate of 5×10^{-5} inches/hour has been utilized. This rate has been generally accepted by the industry for growth in the length direction. Since successive inspections have been performed on the Peach Bottom, Unit 3 shroud welds H3 and H4, an "actual" crack growth rate can also be determined.

Appendix C documents an analysis performed using data from the 1995 inspection, and that recently obtained. One observes from a review of this data that a crack growth rate of 5×10^{-5} inches/hour indeed bounds that determined from actual field data.

One should also note that Noble Metal Chemical Addition (NMCA) was installed in the Unit 3 reactor vessel prior to the 1999 outage. With this addition, it is expected that future crack growth rates will be reduced from those already observed.

SUMMARY

Based upon a review of the examination data for circumferential welds H3 and H4, there is substantial margin for each of these welds under conservative, bounding conditions to allow for continued operation without reinspection for at least ten years of operation. The analyses performed included limit load analyses under bounding design basis conditions, and LEFM evaluations for the postulated highest fluence welds. The evaluations were performed with the assumption that all regions uninspected, or reported with flaws, were cracked through-wall for all calculations. Additionally, all uninspected areas and areas with reported cracking were grown (at each end) at the bounding crack growth rate of 5×10^{-5} inches/hour, and increased in length by UT uncertainty factors. Required safety margins were used, and were exceeded in all cases.

Using the methodology defined in the evaluation guidelines [3], a minimum of ten years of operation can be technically justified without reinspection. The reinspection interval has been developed on a plant-specific basis as required by the U.S. NRC's position on shroud reinspection. [10], as documented in Table 6 for Peach Bottom, Unit 3. Therefore, reinspection of the Peach Bottom, Unit 3 core shroud is not required sooner than ten years for welds H3 and H4.


Very truly yours,

Prepared by:



R. A. Mattson, P. E.

Reviewed by:



M. L. Herrera, P. E.

gsv
Attachments
cc: Rich Ciemiewicz

REFERENCES

1. PECO Energy, "RPV Core Shroud Flaw Indications," ECR Number PB-95-04346-001, October 19, 1995, SI File No. PECO-28Q-204.
2. GE Nuclear Energy, "Evaluation and Screening Criteria for the Peach Bottom Unit-3 Shroud Indications," Report No. GENE-523-141-1093, Revision 1, December 3, 1993, SI File No. PECO-09Q-202.
3. BWR Vessel and Internals Project, "BWR Core Shroud Inspection and Flaw Evaluation Guideline, Revision 2 (BWRVIP-01)," EPRI Report No. TR-107079, October 1996, SI File No. BWRVIP-01-201P.
4. GE Nuclear Energy, "Peach Bottom Atomic Power Station – Unit 3 Core Shroud Ultrasonic Examination," Report No. 1JFF2, Revision 0, October 13, 1999, SI File No. PECO-28Q-218P.
5. BWR Vessel and Internals Project, "Reactor Pressure Vessel and Internals Examination Guidelines (BWRVIP-03) Revision 1," EPRI Report No. TR-105696-R1, March 1999, SI File No. BWRVIP-01-203P.
6. Fax from Albert Piha (PECO) to Dick Mattson (SI), December 18, 1998, SI File No. PECO-28Q-205.
7. Structural Integrity Associates, Software User Manual, "ANSC for Determining Net Section Collapse of Arbitrarily Thinned Cylinder," Report No. SIR-94-035, Revision 0, April 29, 1994, SI File No. QA-1900.
8. Rooke, D. P. and Cartwright, D. J., "Compendium of Stress Intensity Factors," The Hillingdon Press, 1976.
9. E-mail from Charlotte Geiger (PECO) to Dick Mattson (SI), "PBAPS 3 Shroud Indications," November 9, 1999, Received at 10:15 am, SI File No. PECO-28Q-218P.
10. Letter from William H. Bateman (U.S. NRC) to Carl Terry (BWRVIP Chairman), "Errata in Revised BWRVIP-07 Report Table 1 (TAC No. M94959)," November 3, 1999, SI File No. PECO-28Q-219.



Table 1

Design Input ¹

Weld Designation	Shroud Mean Radius [2]	Shroud Thickness [2]	Bending Moment Stresses [1]		Pressure Differential Stresses [1]	
			Upset	Faulted	Upset	Faulted
H3	102.5625"	2.0"	0.19 ksi	0.34 ksi	0.36 ksi	0.79 ksi
H4	102.5625"	2.0"	0.36 ksi	0.61 ksi	0.36 ksi	0.79 ksi

Note: 1. Other design input includes the following:

- The shroud material is Type 304 stainless steel, with S_m equal to 16.9 ksi at 550°F [2].
- The crack growth rate to be used is 5×10^{-5} inches/hour [3]. For purposes of this evaluation, it is assumed that Peach Bottom, Unit 3 is on twenty-four month fuel cycles, with 16,000 hours per cycle.
- The factors-of-safety to be considered are 2.77 for the upset condition, and 1.39 for the faulted condition [3].

Table 2

Weld Designation H3
Flaw Detection Results [4] ²

Flaw Number	Starting Azimuth (°)	Ending Azimuth (°)	Depth (inches)
1	0.00 ¹	8.54 ¹	2.00
2	9.56 ³	17.26 ³	0.36
3	53.66 ³	63.71 ³	0.65
4	104.51 ³	110.91 ³	0.77
5	143.66 ³	166.41 ³	0.83
6	170.16 ¹	188.54 ¹	2.00
7	203.11 ³	234.21 ³	0.84
8	240.06 ³	251.96 ³	0.69
9	283.96	285.61	0.28
10	299.01 ³	327.01 ³	0.71
11	342.51 ¹	360.00 ¹	2.00

- Notes:
1. Uninspected regions.
 2. UT uncertainty factors for length are based upon the transducer which determines the length. For near side detection, the factor is 0.000" for 45° shear [4, 5]. The uncertainty factor is added to each end of the flaws.
 3. Flaws which cross over lug sets are increased in length by 0.5° at each end [5, 6].

Table 3

Weld Designation H4
Flaw Detection Results [4] ²

Flaw Number	Starting Azimuth (°)	Ending Azimuth (°)	Depth (inches)
1	0.00 ¹	8.54 ¹	2.00
2	22.06 ³	30.06 ³	0.52
3	32.61 ³	36.51 ³	0.00
4	42.31 ³	54.76 ³	0.24
5	55.11 ³	58.96 ³	0.40
6	61.01 ³	68.71 ³	0.43
7	71.81	74.01	0.18
8	97.01	99.21	0.31
9	110.96	115.36	0.48
10	122.11 ³	126.51 ³	0.35
11	134.51 ³	153.36 ³	1.39
12	166.88 ¹	188.54 ¹	2.00
13	199.31 ³	206.29 ³	0.41
14	210.14 ³	213.99 ³	0.20
15	229.82	230.92	0.00
16	233.51 ³	236.81 ³	0.34
17	244.26	248.71	0.48
18	263.16 ³	266.46 ³	0.26
19	290.36 ³	303.36 ³	0.32
20	307.01 ³	311.41 ³	0.35
21	319.26	322.01	0.09
22	324.81 ³	326.46 ³	0.38
23	326.76 ³	345.26 ³	0.51
24	346.88 ¹	360.00 ¹	2.00

Notes: see next page

Table 3 (concluded)

- Notes:
1. Uninspected regions.
 2. UT uncertainty factors for length are based upon the transducer which determines the length. For near side detection, the factor is 0.000" for 45° shear [4, 5]. The uncertainty factor is added to each end of the flaws.
 3. Flaws which cross over lug sets are increased in length by 0.5° at each end [5, 6].

Table 4

Limit Load Factors-of-Safety^{1,2}

Weld Designation	Factor-of-Safety ^{3,4,5}	
	Calculated	Allowable
H3	24.5	1.39
H4	28.0	2.77

- Notes:
1. Based upon five cycles (ten years) of crack growth for all welds.
 2. See Appendix A for the detailed ANSC [7] output.
 3. The allowable factors-of-safety are 2.77 for the upset condition, and 1.39 for the faulted condition.
 4. The factors-of-safety are calculated as follows, with all stresses in ksi:

$$S.F. = \frac{P'_b + P_m}{P_b + P_m}$$

- where:
- P_b = bending moment stress from Table 1
 - P_m = pressure differential stress from Table 1
 - P'_b = minimum failure bending stress from Appendix A output

5. For weld H3, the faulted condition governs. For weld H4, the upset condition governs.

Table 5

Linear Elastic
Fracture Mechanics Factors-of-Safety^{1,2}

Weld Designation	K_I^3	Factor-of-Safety ⁴
H3	44	3.4
H4	46	3.3

- Notes:
1. Based upon five cycles (ten years) of crack growth.
 2. See Appendix B for the detailed calculations.
 3. Units are ksi $\sqrt{\text{in}}$.
 4. The factor-of-safety equals the material toughness (K_{Ic}) divided by the applied stress intensity factor (K_I), where the material toughness is 150 ksi $\sqrt{\text{in}}$ [3]. The allowable factor-of-safety for upset conditions is 2.77 (weld H4), and for faulted conditions is 1.39 (weld H3).


Table 6

U.S. NRC [10] Reinspection Criteria

Weld Designation	Maximum Stress ¹ (ksi)	Cracking (%)	Reinspection Internal	
			Limit Load	LEFM
H3	1.13	37.9	Note 2	Note 2
H4	1.40	41.4	Note 2	Note 2

- Notes:
1. Equals the sum of the bending moment plus pressure differential stress for faulted conditions from Table 1.
 2. A plant-specific analysis is required.

Figure 1. Weld Designation H3 - Flaw Detection Results






Figure 2. Weld Designation H4 – Flaw Detection Results




Figure 3. Comparison Between Weld Designation H3 Scan Results and Data Used for Analysis




Figure 4. Comparison Between Weld Designation H4 Scan Results and Data Used for Analysis

APPENDIX A

Flaw Evaluation Results Using the ANSC Software [7]

Basis for Analyses:

1. All reported indications are increased in length at each end by five cycles of crack growth (4 inches), and by the UT length sizing uncertainty shown in Tables 2 and 3, as appropriate.
2. All areas not examined, or reported with flaws, are assumed to be flawed through-wall, and increased in length as stated above.
3. Flaws increased in length per Note 1 will be combined if closer than 4 inches (twice the shroud thickness) apart [3].

Arbitrary Net Section Collapse ANSC 2.0 (4/26/94)

11-10-1999 07:55:45

Page 2

Angle	Wall t	Delta	Pb,x'	Pb,y'	Pb,max	AngleMax	A tension
0.00	0.000	54.844	37.481	5.929	37.947	8.99	433.04
1.00	0.000	54.339	37.584	5.847	38.036	9.84	435.42
2.00	0.000	53.832	37.687	5.860	38.140	10.84	437.81
3.00	0.000	53.324	37.789	5.874	38.243	11.83	440.20
4.00	0.000	52.813	37.891	5.792	38.331	12.69	442.58
5.00	0.000	52.301	37.993	5.807	38.434	13.69	444.97
6.00	0.000	51.786	38.094	5.822	38.536	14.69	447.36
7.00	0.000	51.271	38.195	5.741	38.624	15.55	449.74
8.00	0.000	50.753	38.296	5.757	38.726	16.55	452.13
9.00	0.000	50.234	38.396	5.775	38.828	17.55	454.52
10.00	0.000	49.712	38.497	5.694	38.915	18.41	456.90
11.00	0.000	49.190	38.597	5.712	39.017	19.42	459.29
12.00	0.000	48.665	38.696	5.731	39.118	20.42	461.68
13.00	0.000	48.264	38.796	5.750	39.220	21.43	463.50
14.00	0.000	48.264	38.900	6.066	39.370	22.86	463.50
15.00	0.000	48.264	39.009	6.380	39.527	24.29	463.50
16.00	0.000	48.264	39.123	6.693	39.691	25.71	463.50
17.00	0.000	48.264	39.243	7.003	39.863	27.12	463.50
18.00	0.000	48.264	39.368	7.311	40.041	28.52	463.50
19.00	0.000	48.264	39.499	7.617	40.227	29.91	463.50
20.00	2.000	48.264	39.635	7.920	40.419	31.30	463.50
21.00	2.000	48.264	39.776	8.221	40.617	32.68	463.50
22.00	2.000	48.264	39.923	8.520	40.822	34.05	463.50
23.00	2.000	48.339	40.074	8.831	41.036	35.43	463.16
24.00	2.000	48.865	40.227	8.775	41.173	36.31	460.77
25.00	2.000	49.388	40.380	8.714	41.309	37.18	458.39
26.00	2.000	49.911	40.531	8.698	41.454	38.11	456.00
27.00	2.000	50.431	40.682	8.628	41.587	38.97	453.61
28.00	2.000	50.950	40.832	8.553	41.718	39.83	451.22
29.00	2.000	51.467	40.980	8.523	41.857	40.75	448.84
30.00	2.000	51.982	41.128	8.438	41.984	41.59	446.45
31.00	2.000	52.496	41.274	8.349	42.110	42.44	444.06
32.00	2.000	53.008	41.419	8.304	42.243	43.34	441.68
33.00	2.000	53.517	41.562	8.206	42.365	44.17	439.29
34.00	2.000	54.026	41.704	8.103	42.484	44.99	436.90
35.00	2.000	54.532	41.845	8.043	42.611	45.88	434.52
36.00	2.000	55.036	41.984	7.930	42.726	46.70	432.13
37.00	2.000	55.539	42.121	7.813	42.839	47.51	429.74
38.00	2.000	56.040	42.256	7.738	42.959	48.38	427.35
39.00	2.000	56.539	42.390	7.611	43.068	49.18	424.97
40.00	2.000	57.035	42.521	7.480	43.174	49.98	422.58
41.00	2.000	57.530	42.650	7.391	43.286	50.83	420.19
42.00	2.000	58.023	42.778	7.251	43.388	51.62	417.81
43.00	2.000	58.514	42.903	7.106	43.487	52.40	415.42
44.00	2.000	59.003	43.026	7.002	43.592	53.24	413.04
45.00	2.000	59.490	43.146	6.848	43.686	54.02	410.65
46.00	2.000	59.975	43.264	6.689	43.778	54.79	408.26
47.00	2.000	60.458	43.379	6.571	43.874	55.61	405.88
48.00	2.000	60.939	43.492	6.403	43.961	56.38	403.49
49.00	2.000	61.071	43.601	6.141	44.032	57.02	402.83

Arbitrary Net Section Collapse ANSC 2.0 (4/26/94)

11-10-1999 07:55:45

Page 3

Angle	Wall t	Delta	Pb,x'	Pb,y'	Pb,max	AngleMax	A tension
50.00	2.000	61.071	43.705	5.832	44.093	57.60	402.83
51.00	0.000	61.071	43.804	5.521	44.151	58.18	402.83
52.00	0.000	61.071	43.897	5.208	44.205	58.77	402.83
53.00	0.000	61.071	43.985	4.894	44.256	59.35	402.83
54.00	0.000	61.071	44.067	4.578	44.304	59.93	402.83
55.00	0.000	61.365	44.144	4.350	44.358	60.63	401.37
56.00	0.000	61.843	44.218	4.165	44.414	61.38	398.98
57.00	0.000	62.318	44.289	4.020	44.471	62.19	396.59
58.00	0.000	62.791	44.357	3.827	44.522	62.93	394.20
59.00	0.000	63.261	44.422	3.630	44.570	63.67	391.82
60.00	0.000	63.730	44.484	3.473	44.619	64.46	389.43
61.00	0.000	64.196	44.542	3.268	44.662	65.20	387.04
62.00	0.000	64.552	44.597	3.161	44.709	66.05	385.22
63.00	0.000	64.552	44.652	3.258	44.771	67.17	385.22
64.00	0.000	64.552	44.709	3.353	44.835	68.29	385.22
65.00	0.000	64.552	44.768	3.448	44.901	69.40	385.22
66.00	0.000	64.220	44.827	3.280	44.947	70.18	386.92
67.00	2.000	63.753	44.883	3.113	44.991	70.97	389.31
68.00	2.000	63.285	44.935	2.949	45.032	71.75	391.70
69.00	2.000	62.814	44.984	2.697	45.065	72.43	394.08
70.00	2.000	62.342	45.030	2.536	45.101	73.22	396.47
71.00	2.000	61.867	45.072	2.378	45.135	74.02	398.86
72.00	2.000	61.390	45.111	2.131	45.162	74.71	401.24
73.00	2.000	60.911	45.147	1.977	45.191	75.51	403.63
74.00	2.000	60.430	45.180	1.825	45.217	76.31	406.02
75.00	2.000	60.227	45.209	1.528	45.235	76.94	407.02
76.00	2.000	60.227	45.232	1.195	45.248	77.51	407.02
77.00	2.000	60.227	45.250	0.861	45.258	78.09	407.02
78.00	2.000	60.227	45.262	0.527	45.265	78.67	407.02
79.00	2.000	60.227	45.268	0.193	45.268	79.24	407.02
80.00	2.000	60.227	45.268	-0.141	45.268	79.82	407.02
81.00	2.000	60.227	45.262	-0.475	45.265	80.40	407.02
82.00	2.000	60.227	45.251	-0.809	45.258	80.97	407.02
83.00	2.000	60.226	45.233	-1.142	45.248	81.55	407.02
84.00	2.000	60.226	45.210	-1.476	45.234	82.13	407.02
85.00	2.000	60.226	45.181	-1.808	45.218	82.71	407.02
86.00	2.000	60.226	45.147	-2.141	45.197	83.28	407.02
87.00	2.000	60.226	45.106	-2.472	45.174	83.86	407.02
88.00	2.000	60.227	45.060	-2.803	45.147	84.44	407.02
89.00	2.000	60.227	45.007	-3.133	45.116	85.02	407.02
90.00	2.000	60.227	44.949	-3.462	45.083	85.59	407.02
91.00	2.000	60.227	44.886	-3.790	45.046	86.17	407.02
92.00	2.000	60.227	44.816	-4.117	45.005	86.75	407.02
93.00	2.000	60.227	44.741	-4.443	44.962	87.33	407.02
94.00	2.000	60.227	44.661	-4.767	44.915	87.91	407.02
95.00	2.000	60.227	44.574	-5.090	44.864	88.48	407.02
96.00	2.000	60.357	44.483	-5.366	44.805	89.12	406.38
97.00	2.000	60.839	44.387	-5.550	44.733	89.87	403.99
98.00	2.000	61.318	44.289	-5.691	44.653	90.68	401.60
99.00	2.000	61.795	44.187	-5.877	44.576	91.42	399.22

Arbitrary Net Section Collapse ANSC 2.0 (4/26/94)

11-10-1999 07:55:45

Page 4

Angle	Wall t	Delta	Pb,x'	Pb,y'	Pb,max	AngleMax	A tension
100.00	2.000	62.270	44.083	-6.064	44.498	92.17	396.83
101.00	2.000	62.744	43.975	-6.208	44.411	92.96	394.44
102.00	0.000	63.214	43.865	-6.396	44.329	93.70	392.05
103.00	0.000	63.683	43.751	-6.586	44.244	94.44	389.67
104.00	0.000	64.150	43.635	-6.732	44.151	95.23	387.28
105.00	0.000	64.614	43.515	-6.922	44.062	95.96	384.89
106.00	0.000	65.077	43.392	-7.113	43.971	96.69	382.51
107.00	0.000	65.537	43.266	-7.261	43.871	97.47	380.12
108.00	0.000	65.994	43.138	-7.453	43.777	98.20	377.74
109.00	0.000	66.450	43.006	-7.646	43.680	98.92	375.35
110.00	0.000	66.903	42.870	-7.796	43.574	99.69	372.96
111.00	0.000	67.354	42.732	-7.990	43.473	100.41	370.58
112.00	0.000	67.576	42.591	-8.225	43.378	101.07	369.40
113.00	0.000	67.576	42.444	-8.544	43.295	101.62	369.40
114.00	2.000	67.576	42.291	-8.859	43.209	102.17	369.40
115.00	2.000	67.576	42.133	-9.172	43.120	102.72	369.40
116.00	2.000	67.576	41.970	-9.483	43.028	103.27	369.40
117.00	2.000	67.576	41.801	-9.790	42.932	103.82	369.40
118.00	2.000	67.576	41.627	-10.094	42.833	104.37	369.40
119.00	2.000	67.577	41.447	-10.395	42.731	104.92	369.40
120.00	2.000	67.577	41.262	-10.693	42.626	105.47	369.40
121.00	2.000	67.577	41.073	-10.988	42.517	106.02	369.40
122.00	2.000	67.577	40.878	-11.280	42.405	106.57	369.40
123.00	2.000	67.577	40.678	-11.568	42.290	107.12	369.40
124.00	2.000	67.341	40.473	-11.805	42.159	107.74	370.65
125.00	2.000	66.890	40.266	-11.913	41.991	108.52	373.03
126.00	2.000	66.436	40.056	-12.100	41.844	109.19	375.42
127.00	2.000	65.981	39.844	-12.195	41.668	109.98	377.81
128.00	2.000	65.523	39.630	-12.283	41.490	110.78	380.19
129.00	2.000	65.063	39.414	-12.452	41.334	111.47	382.58
130.00	2.000	64.600	39.196	-12.527	41.149	112.27	384.97
131.00	2.000	64.136	38.976	-12.595	40.961	113.09	387.35
132.00	2.000	63.669	38.755	-12.744	40.797	113.80	389.74
133.00	2.000	63.200	38.532	-12.799	40.602	114.62	392.13
134.00	2.000	62.729	38.308	-12.847	40.405	115.46	394.51
135.00	2.000	62.256	38.082	-12.978	40.233	116.18	396.90
136.00	2.000	61.781	37.856	-13.012	40.030	117.03	399.29
137.00	2.000	61.304	37.628	-13.040	39.823	117.88	401.67
138.00	2.000	60.824	37.399	-13.152	39.644	118.62	404.06
139.00	2.000	60.343	37.170	-13.166	39.432	119.49	406.45
140.00	2.000	59.859	36.939	-13.173	39.218	120.37	408.83
141.00	0.000	59.374	36.708	-13.266	39.032	121.13	411.22
142.00	0.000	58.886	36.477	-13.260	38.813	122.02	413.61
143.00	0.000	58.396	36.245	-13.248	38.591	122.92	416.00
144.00	0.000	57.905	36.013	-13.321	38.398	123.70	418.38
145.00	0.000	57.770	35.783	-13.110	38.109	124.88	419.03
146.00	0.000	57.770	35.557	-12.802	37.791	126.20	419.03
147.00	0.000	57.770	35.337	-12.489	37.479	127.53	419.03
148.00	0.000	57.770	35.122	-12.173	37.172	128.88	419.03
149.00	0.000	57.770	34.913	-11.854	36.870	130.25	419.03

Arbitrary Net Section Collapse ANSC 2.0 (4/26/94)

11-10-1999 07:55:45

Page 5

Angle	Wall t	Delta	Pb,x'	Pb,y'	Pb,max	AngleMax	A tension
150.00	0.000	57.770	34.710	-11.530	36.574	131.62	419.03
151.00	0.000	57.770	34.512	-11.203	36.285	133.01	419.03
152.00	0.000	57.770	34.320	-10.873	36.001	134.42	419.03
153.00	0.000	57.770	34.133	-10.539	35.723	135.84	419.03
154.00	0.000	57.770	33.953	-10.203	35.452	137.27	419.03
155.00	0.000	57.770	33.778	-9.863	35.189	138.72	419.03
156.00	0.000	57.770	33.609	-9.520	34.932	140.18	419.03
157.00	0.000	57.770	33.447	-9.174	34.682	141.66	419.03
158.00	0.000	58.042	33.289	-8.952	34.472	142.95	417.72
159.00	0.000	58.533	33.133	-8.929	34.315	143.92	415.33
160.00	0.000	59.022	32.978	-8.859	34.147	144.96	412.94
161.00	0.000	59.509	32.823	-8.836	33.991	145.93	410.56
162.00	0.000	59.994	32.669	-8.812	33.836	146.90	408.17
163.00	0.000	60.009	32.518	-8.440	33.595	148.45	408.10
164.00	0.000	60.009	32.373	-8.093	33.369	149.96	408.10
165.00	0.000	60.009	32.234	-7.743	33.151	151.49	408.10
166.00	0.000	60.009	32.101	-7.391	32.941	153.03	408.10
167.00	0.000	60.009	31.975	-7.036	32.740	154.59	408.10
168.00	0.000	60.009	31.854	-6.679	32.547	156.16	408.10
169.00	0.000	60.009	31.740	-6.321	32.364	157.74	408.10
170.00	0.000	60.009	31.633	-5.960	32.189	159.33	408.10
171.00	0.000	60.265	31.530	-5.790	32.057	160.59	406.83
172.00	0.000	60.747	31.430	-5.703	31.943	161.71	404.44
173.00	0.000	61.227	31.330	-5.662	31.837	162.76	402.06
174.00	0.000	61.704	31.231	-5.621	31.733	163.80	399.67
175.00	0.000	62.180	31.133	-5.537	31.622	164.91	397.28
176.00	0.000	62.653	31.037	-5.499	31.520	165.95	394.90
177.00	0.000	63.125	30.941	-5.461	31.419	166.99	392.51
178.00	0.000	63.594	30.846	-5.380	31.311	168.10	390.12
179.00	0.000	64.061	30.752	-5.345	31.213	169.14	387.74
180.00	0.000	64.468	30.658	-5.310	31.115	170.17	385.65
181.00	0.000	64.468	30.565	-5.406	31.039	170.97	385.65
182.00	0.000	64.468	30.469	-5.501	30.961	171.77	385.65
183.00	0.000	64.468	30.372	-5.593	30.882	172.56	385.65
184.00	0.000	64.468	30.273	-5.684	30.802	173.36	385.65
185.00	0.000	64.468	30.172	-5.774	30.720	174.17	385.65
186.00	0.000	64.468	30.070	-5.861	30.636	174.97	385.65
187.00	0.000	64.468	29.967	-5.947	30.551	175.77	385.65
188.00	0.000	64.468	29.862	-6.031	30.465	176.58	385.65
189.00	0.000	64.468	29.756	-6.113	30.377	177.39	385.65
190.00	0.000	64.468	29.648	-6.194	30.288	178.20	385.65
191.00	2.000	64.468	29.539	-6.272	30.197	179.01	385.65
192.00	2.000	64.468	29.428	-6.348	30.105	179.82	385.65
193.00	2.000	64.468	29.316	-6.423	30.011	180.64	385.65
194.00	2.000	64.468	29.203	-6.496	29.917	181.46	385.65
195.00	2.000	64.468	29.088	-6.566	29.820	182.28	385.65
196.00	2.000	64.753	28.973	-6.548	29.704	183.26	384.18
197.00	2.000	65.215	28.859	-6.486	29.579	184.33	381.79
198.00	2.000	65.674	28.747	-6.381	29.446	185.48	379.41
199.00	2.000	66.131	28.635	-6.321	29.325	186.55	377.02

Arbitrary Net Section Collapse ANSC 2.0 (4/26/94)

11-10-1999 07:55:45

Page 6

Angle	Wall t	Delta	Pb,x'	Pb,y'	Pb,max	AngleMax	A tension
200.00	2.000	66.343	28.526	-6.077	29.166	187.97	375.91
201.00	0.000	66.343	28.422	-5.714	28.991	189.63	375.91
202.00	0.000	66.343	28.325	-5.350	28.826	191.30	375.91
203.00	0.000	66.343	28.234	-4.985	28.671	192.99	375.91
204.00	0.000	66.343	28.150	-4.617	28.526	194.68	375.91
205.00	0.000	66.343	28.072	-4.249	28.392	196.39	375.91
206.00	0.000	66.343	28.000	-3.879	28.268	198.11	375.91
207.00	0.000	66.343	27.935	-3.508	28.154	199.84	375.91
208.00	0.000	66.343	27.876	-3.136	28.052	201.58	375.91
209.00	0.000	66.343	27.824	-2.762	27.961	203.33	375.91
210.00	0.000	66.354	27.779	-2.397	27.882	205.07	375.85
211.00	0.000	66.808	27.737	-2.325	27.834	206.21	373.46
212.00	0.000	67.260	27.697	-2.254	27.788	207.35	371.08
213.00	0.000	67.709	27.658	-2.143	27.741	208.57	368.69
214.00	0.000	68.156	27.621	-2.077	27.699	209.70	366.30
215.00	0.000	68.601	27.585	-2.013	27.658	210.82	363.92
216.00	0.000	69.043	27.550	-1.910	27.616	212.03	361.53
217.00	0.000	69.483	27.517	-1.850	27.579	213.15	359.14
218.00	0.000	69.921	27.485	-1.793	27.543	214.27	356.76
219.00	0.000	70.356	27.454	-1.697	27.506	215.46	354.37
220.00	0.000	70.789	27.424	-1.645	27.473	216.57	351.98
221.00	0.000	71.220	27.396	-1.595	27.442	217.67	349.60
222.00	0.000	71.648	27.368	-1.507	27.410	218.85	347.21
223.00	0.000	72.074	27.342	-1.462	27.381	219.94	344.82
224.00	0.000	72.497	27.316	-1.420	27.353	221.02	342.44
225.00	0.000	72.918	27.292	-1.340	27.325	222.19	340.05
226.00	0.000	73.336	27.268	-1.303	27.300	223.26	337.66
227.00	0.000	73.752	27.246	-1.268	27.275	224.33	335.28
228.00	0.000	74.166	27.224	-1.198	27.250	225.48	332.89
229.00	0.000	74.576	27.203	-1.168	27.228	226.54	330.50
230.00	0.000	74.985	27.182	-1.142	27.206	227.59	328.12
231.00	0.000	75.391	27.163	-1.080	27.184	228.72	325.73
232.00	0.000	75.794	27.143	-1.059	27.164	229.76	323.34
233.00	0.000	76.195	27.125	-1.041	27.145	230.80	320.95
234.00	0.000	76.593	27.107	-0.988	27.125	231.91	318.57
235.00	0.000	76.988	27.089	-0.976	27.107	232.94	316.18
236.00	0.000	77.381	27.072	-0.966	27.089	233.95	313.79
237.00	0.000	77.772	27.055	-0.923	27.071	235.05	311.41
238.00	0.000	78.159	27.039	-0.919	27.054	236.05	309.02
239.00	0.000	78.544	27.022	-0.918	27.038	237.05	306.64
240.00	0.000	78.834	27.007	-0.845	27.020	238.21	304.83
241.00	0.000	78.834	26.994	-0.595	27.000	239.73	304.83
242.00	0.000	78.830	26.985	-0.346	26.987	241.26	304.85
243.00	0.000	78.456	26.979	-0.310	26.981	242.34	307.18
244.00	0.000	78.070	26.973	-0.344	26.975	243.27	309.57
245.00	0.000	77.682	26.968	-0.302	26.969	244.36	311.96
246.00	0.000	77.291	26.962	-0.256	26.964	245.46	314.34
247.00	0.000	76.898	26.958	-0.280	26.959	246.40	316.73
248.00	0.000	76.501	26.953	-0.227	26.954	247.52	319.12
249.00	0.000	76.103	26.949	-0.170	26.950	248.64	321.51

Arbitrary Net Section Collapse ANSC 2.0 (4/26/94)

11-10-1999 07:55:45

Page 7

Angle	Wall t	Delta	Pb,x'	Pb,y'	Pb,max	AngleMax	A tension
250.00	0.000	75.701	26.946	-0.186	26.947	249.60	323.89
251.00	0.000	75.335	26.943	-0.122	26.944	250.74	326.06
252.00	0.000	75.335	26.944	0.172	26.945	252.37	326.06
253.00	0.000	75.335	26.950	0.466	26.954	253.99	326.06
254.00	0.000	75.335	26.961	0.760	26.972	255.62	326.06
255.00	2.000	75.335	26.977	1.054	26.998	257.24	326.06
256.00	2.000	75.335	26.998	1.348	27.032	258.86	326.06
257.00	2.000	75.335	27.024	1.641	27.074	260.47	326.06
258.00	2.000	75.335	27.056	1.933	27.125	262.09	326.06
259.00	2.000	75.335	27.092	2.225	27.184	263.70	326.06
260.00	2.000	75.335	27.134	2.517	27.250	265.30	326.06
261.00	2.000	75.335	27.181	2.807	27.325	266.90	326.06
262.00	2.000	75.335	27.232	3.097	27.408	268.49	326.06
263.00	2.000	75.335	27.289	3.386	27.498	270.07	326.06
264.00	2.000	75.335	27.351	3.673	27.597	271.65	326.06
265.00	2.000	75.335	27.418	3.960	27.702	273.22	326.06
266.00	2.000	75.335	27.490	4.245	27.816	274.78	326.06
267.00	2.000	75.335	27.567	4.529	27.936	276.33	326.06
268.00	2.000	75.335	27.648	4.812	28.064	277.87	326.06
269.00	2.000	75.335	27.735	5.093	28.199	279.41	326.06
270.00	2.000	75.335	27.827	5.373	28.341	280.93	326.06
271.00	2.000	75.335	27.923	5.651	28.489	282.44	326.06
272.00	2.000	75.335	28.024	5.927	28.644	283.94	326.06
273.00	2.000	75.335	28.130	6.202	28.806	285.43	326.06
274.00	2.000	75.471	28.241	6.409	28.959	286.79	325.25
275.00	2.000	75.874	28.353	6.448	29.077	287.81	322.87
276.00	2.000	76.274	28.465	6.443	29.185	288.75	320.48
277.00	2.000	76.672	28.577	6.433	29.292	289.69	318.09
278.00	2.000	77.067	28.689	6.455	29.406	290.68	315.71
279.00	2.000	77.459	28.801	6.435	29.511	291.59	313.32
280.00	2.000	77.849	28.913	6.410	29.615	292.50	310.93
281.00	2.000	78.029	29.024	6.343	29.709	293.33	309.82
282.00	0.000	78.029	29.133	6.201	29.786	294.02	309.82
283.00	0.000	78.029	29.240	6.057	29.861	294.70	309.82
284.00	0.000	78.029	29.344	5.912	29.933	295.39	309.82
285.00	0.000	78.029	29.445	5.764	30.004	296.08	309.82
286.00	0.000	78.029	29.544	5.615	30.073	296.76	309.82
287.00	0.000	77.993	29.640	5.486	30.144	297.49	310.05
288.00	2.000	77.604	29.735	5.408	30.223	298.31	312.43
289.00	2.000	77.213	29.830	5.406	30.316	299.27	314.82
290.00	2.000	76.819	29.924	5.405	30.408	300.24	317.21
291.00	2.000	76.422	30.017	5.332	30.487	301.07	319.59
292.00	2.000	76.023	30.110	5.335	30.579	302.05	321.98
293.00	2.000	75.621	30.203	5.340	30.671	303.03	324.37
294.00	2.000	75.217	30.295	5.270	30.750	303.87	326.75
295.00	2.000	74.810	30.387	5.278	30.842	304.85	329.14
296.00	2.000	74.400	30.479	5.288	30.935	305.84	331.53
297.00	0.000	73.988	30.571	5.222	31.014	306.69	333.92
298.00	0.000	73.574	30.662	5.236	31.106	307.69	336.30
299.00	0.000	73.157	30.753	5.251	31.198	308.69	338.69

Arbitrary Net Section Collapse ANSC 2.0 (4/26/94)

11-10-1999 07:55:45

Page 8

Angle	Wall t	Delta	Pb,x'	Pb,y'	Pb,max	AngleMax	A tension
300.00	0.000	72.737	30.844	5.189	31.278	309.55	341.08
301.00	0.000	72.315	30.935	5.207	31.370	310.56	343.46
302.00	0.000	71.891	31.026	5.228	31.463	311.56	345.85
303.00	0.000	71.464	31.116	5.169	31.543	312.43	348.24
304.00	0.000	71.035	31.207	5.192	31.636	313.45	350.62
305.00	0.000	70.603	31.297	5.217	31.729	314.46	353.01
306.00	0.000	70.170	31.387	5.162	31.809	315.34	355.40
307.00	0.000	69.733	31.478	5.190	31.903	316.36	357.78
308.00	0.000	69.294	31.568	5.220	31.997	317.39	360.17
309.00	0.000	68.853	31.659	5.168	32.078	318.27	362.56
310.00	0.000	68.410	31.749	5.201	32.172	319.30	364.94
311.00	0.000	67.964	31.840	5.235	32.267	320.34	367.33
312.00	0.000	67.516	31.931	5.186	32.349	321.23	369.72
313.00	0.000	67.066	32.022	5.224	32.445	322.26	372.10
314.00	0.000	66.613	32.113	5.262	32.541	323.31	374.49
315.00	0.000	66.158	32.204	5.216	32.624	324.20	376.88
316.00	0.000	65.701	32.295	5.258	32.720	325.25	379.27
317.00	0.000	65.242	32.387	5.300	32.818	326.29	381.65
318.00	0.000	64.780	32.479	5.257	32.902	327.19	384.04
319.00	0.000	64.317	32.571	5.302	33.000	328.25	386.42
320.00	0.000	64.105	32.664	5.436	33.114	329.45	387.51
321.00	0.000	64.105	32.762	5.745	33.262	330.95	387.51
322.00	0.000	64.105	32.866	6.051	33.418	332.43	387.51
323.00	0.000	64.105	32.975	6.356	33.582	333.91	387.51
324.00	0.000	64.105	33.089	6.659	33.752	335.38	387.51
325.00	0.000	64.106	33.208	6.960	33.930	336.84	387.51
326.00	0.000	64.106	33.333	7.259	34.114	338.29	387.51
327.00	0.000	64.106	33.462	7.556	34.305	339.72	387.51
328.00	0.000	64.106	33.597	7.850	34.502	341.15	387.51
329.00	0.000	64.105	33.738	8.142	34.706	342.57	387.51
330.00	2.000	63.669	33.880	8.168	34.851	343.55	389.74
331.00	2.000	63.200	34.023	8.195	34.996	344.54	392.13
332.00	2.000	62.729	34.166	8.223	35.142	345.53	394.51
333.00	2.000	62.256	34.309	8.161	35.266	346.38	396.90
334.00	2.000	61.781	34.452	8.190	35.412	347.37	399.29
335.00	2.000	61.305	34.595	8.218	35.557	348.36	401.67
336.00	2.000	61.251	34.736	8.056	35.658	349.06	401.93
337.00	2.000	61.251	34.875	7.900	35.759	349.76	401.93
338.00	2.000	61.251	35.012	7.742	35.857	350.47	401.93
339.00	2.000	61.251	35.145	7.582	35.954	351.17	401.93
340.00	2.000	61.251	35.276	7.419	36.047	351.88	401.93
341.00	0.000	61.251	35.404	7.254	36.139	352.58	401.94
342.00	0.000	61.251	35.529	7.087	36.229	353.28	401.94
343.00	0.000	61.251	35.651	6.918	36.316	353.98	401.94
344.00	0.000	61.251	35.770	6.746	36.400	354.68	401.94
345.00	0.000	61.251	35.886	6.573	36.483	355.38	401.94
346.00	0.000	61.251	35.999	6.397	36.563	356.08	401.94
347.00	0.000	61.227	36.108	6.220	36.640	356.77	402.05
348.00	0.000	60.757	36.217	6.205	36.744	357.72	404.40
349.00	0.000	60.275	36.324	6.118	36.836	358.56	406.78

Arbitrary Net Section Collapse ANSC 2.0 (4/26/94)

11-10-1999 07:55:45

Page 9

Angle	Wall t	Delta	Pb,x'	Pb,y'	Pb,max	AngleMax	A tension
350.00	0.000	59.791	36.432	6.122	36.942	359.54	409.17
351.00	0.000	59.305	36.538	6.127	37.049	0.52	411.56
352.00	0.000	58.817	36.645	6.041	37.139	1.36	413.94
353.00	0.000	58.327	36.751	6.048	37.245	2.35	416.33
354.00	0.000	57.836	36.856	6.056	37.350	3.33	418.72
355.00	0.000	57.342	36.961	5.971	37.441	4.18	421.10
356.00	0.000	56.846	37.066	5.980	37.545	5.17	423.49
357.00	0.000	56.348	37.170	5.990	37.650	6.15	425.88
358.00	0.000	55.849	37.274	5.906	37.739	7.00	428.27
359.00	0.000	55.348	37.378	5.918	37.844	8.00	430.65

MINIMUM STRESS (Pb,x') = 26.943 AT 251.00 DEGREES
 MINIMUM TOTAL STRESS (Pb,max) = 26.944 AT 250.74 DEGREES

Arbitrary Net Section Collapse ANSC 2.0 (4/26/94)

11-10-1999 08:18:58

Page 2

Angle	Wall t	Delta	Pb,x'	Pb,y'	Pb,max	AngleMax	A tension
0.00	0.000	80.350	20.243	-2.301	20.374	353.51	284.28
1.00	0.000	80.720	20.204	-2.166	20.320	354.88	281.89
2.00	0.000	81.086	20.167	-2.068	20.272	356.14	279.51
3.00	0.000	81.450	20.131	-1.973	20.228	357.40	277.12
4.00	0.000	81.812	20.098	-1.847	20.182	358.75	274.73
5.00	0.000	82.170	20.066	-1.758	20.142	359.99	272.35
6.00	0.000	82.526	20.035	-1.671	20.105	1.23	269.96
7.00	0.000	82.879	20.007	-1.554	20.067	2.56	267.57
8.00	0.000	83.229	19.980	-1.474	20.034	3.78	265.19
9.00	0.000	83.576	19.955	-1.396	20.004	5.00	262.80
10.00	0.000	83.920	19.931	-1.289	19.973	6.30	260.41
11.00	2.000	84.223	19.909	-1.182	19.944	7.60	258.30
12.00	2.000	84.223	19.890	-0.887	19.910	9.45	258.30
13.00	2.000	84.153	19.877	-0.655	19.888	11.11	258.79
14.00	2.000	83.810	19.866	-0.549	19.874	12.42	261.18
15.00	2.000	83.465	19.857	-0.504	19.863	13.54	263.56
16.00	2.000	83.117	19.849	-0.391	19.853	14.87	265.95
17.00	2.000	82.766	19.843	-0.273	19.845	16.21	268.34
18.00	2.000	82.412	19.838	-0.218	19.839	17.37	270.72
19.00	2.000	82.056	19.835	-0.093	19.836	18.73	273.11
20.00	0.000	81.696	19.835	0.036	19.835	20.10	275.50
21.00	0.000	81.334	19.836	0.100	19.836	21.29	277.88
22.00	0.000	81.058	19.839	0.305	19.841	22.88	279.69
23.00	0.000	81.265	19.846	0.527	19.853	24.52	278.34
24.00	0.000	81.628	19.856	0.626	19.865	25.81	275.95
25.00	0.000	81.988	19.867	0.721	19.880	27.08	273.56
26.00	0.000	82.042	19.880	0.746	19.894	28.15	273.20
27.00	0.000	82.042	19.892	0.737	19.906	29.12	273.20
28.00	0.000	82.042	19.904	0.727	19.918	30.09	273.20
29.00	0.000	82.042	19.917	0.718	19.930	31.06	273.20
30.00	0.000	82.042	19.929	0.708	19.941	32.04	273.20
31.00	0.000	82.042	19.940	0.699	19.953	33.01	273.20
32.00	0.000	82.042	19.952	0.688	19.964	33.98	273.20
33.00	0.000	82.042	19.964	0.678	19.975	34.95	273.20
34.00	0.000	82.042	19.975	0.668	19.986	35.91	273.20
35.00	0.000	82.377	19.987	0.757	20.001	37.17	270.96
36.00	0.000	82.731	20.000	0.842	20.018	38.41	268.58
37.00	0.000	83.082	20.016	0.957	20.039	39.74	266.19
38.00	0.000	83.430	20.033	1.035	20.059	40.96	263.80
39.00	0.000	83.776	20.051	1.109	20.082	42.17	261.42
40.00	0.000	84.119	20.071	1.212	20.108	43.46	259.03
41.00	0.000	84.459	20.092	1.279	20.133	44.64	256.64
42.00	0.000	84.796	20.115	1.341	20.160	45.82	254.26
43.00	0.000	85.130	20.139	1.432	20.190	47.07	251.87
44.00	0.000	85.461	20.164	1.486	20.219	48.22	249.48
45.00	0.000	85.544	20.191	1.703	20.263	49.82	248.88
46.00	0.000	85.544	20.223	1.972	20.319	51.57	248.88
47.00	0.000	85.527	20.259	2.240	20.383	53.31	249.01
48.00	0.000	85.197	20.298	2.261	20.424	54.36	251.39
49.00	0.000	84.863	20.339	2.348	20.474	55.58	253.78

Arbitrary Net Section Collapse ANSC 2.0 (4/26/94)

11-10-1999 08:18:58

Page 3

Angle	Wall t	Delta	Pb,x'	Pb,y'	Pb,max	AngleMax	A tension
50.00	0.000	84.526	20.380	2.437	20.525	56.82	256.17
51.00	0.000	84.187	20.423	2.466	20.571	57.88	258.55
52.00	0.000	83.976	20.466	2.522	20.621	59.03	260.02
53.00	0.000	83.976	20.510	2.488	20.660	59.92	260.02
54.00	0.000	83.976	20.553	2.453	20.699	60.81	260.02
55.00	0.000	84.265	20.596	2.513	20.748	61.96	258.00
56.00	0.000	84.604	20.640	2.569	20.799	63.09	255.62
57.00	0.000	84.940	20.685	2.652	20.854	64.31	253.23
58.00	0.000	85.273	20.731	2.699	20.906	65.42	250.84
59.00	0.000	85.603	20.779	2.742	20.959	66.52	248.46
60.00	0.000	85.930	20.827	2.811	21.016	67.69	246.07
61.00	0.000	86.254	20.876	2.845	21.069	68.76	243.68
62.00	0.000	86.576	20.926	2.874	21.122	69.82	241.30
63.00	0.000	86.894	20.976	2.929	21.179	70.95	238.91
64.00	0.000	87.210	21.027	2.950	21.233	71.99	236.52
65.00	0.000	87.522	21.078	2.966	21.286	73.01	234.14
66.00	0.000	87.832	21.130	3.007	21.343	74.10	231.75
67.00	0.000	88.139	21.182	3.014	21.396	75.10	229.36
68.00	0.000	88.247	21.235	3.126	21.464	76.37	228.51
69.00	0.000	88.247	21.292	3.329	21.551	77.89	228.51
70.00	0.000	88.247	21.352	3.531	21.642	79.39	228.51
71.00	0.000	88.247	21.415	3.732	21.738	80.88	228.51
72.00	0.000	88.247	21.482	3.932	21.839	82.37	228.51
73.00	0.000	88.247	21.553	4.130	21.945	83.85	228.51
74.00	0.000	88.247	21.627	4.327	22.056	85.32	228.51
75.00	0.000	88.247	21.704	4.523	22.171	86.77	228.51
76.00	0.000	88.247	21.785	4.718	22.290	88.22	228.51
77.00	2.000	88.240	21.869	4.911	22.414	89.66	228.57
78.00	2.000	87.940	21.955	4.933	22.502	90.66	230.91
79.00	2.000	87.680	22.041	4.925	22.584	91.59	232.92
80.00	2.000	87.680	22.126	4.831	22.647	92.32	232.92
81.00	2.000	87.680	22.209	4.737	22.709	93.04	232.92
82.00	2.000	87.680	22.291	4.641	22.769	93.76	232.92
83.00	2.000	87.680	22.371	4.543	22.827	94.48	232.92
84.00	2.000	87.680	22.449	4.444	22.884	95.20	232.92
85.00	2.000	87.680	22.525	4.344	22.940	95.92	232.92
86.00	2.000	87.680	22.600	4.243	22.995	96.63	232.92
87.00	2.000	87.680	22.673	4.140	23.047	97.35	232.92
88.00	2.000	87.680	22.744	4.036	23.099	98.06	232.92
89.00	2.000	87.680	22.813	3.930	23.149	98.78	232.92
90.00	2.000	87.680	22.880	3.824	23.198	99.49	232.92
91.00	2.000	87.616	22.946	3.705	23.243	100.17	233.42
92.00	2.000	87.304	23.011	3.715	23.309	101.17	235.81
93.00	2.000	86.989	23.076	3.729	23.375	102.18	238.19
94.00	2.000	86.672	23.140	3.686	23.432	103.05	240.58
95.00	0.000	86.503	23.205	3.683	23.495	104.02	241.84
96.00	0.000	86.503	23.268	3.580	23.541	104.75	241.84
97.00	0.000	86.503	23.329	3.476	23.586	105.48	241.84
98.00	0.000	86.503	23.388	3.371	23.630	106.20	241.84
99.00	0.000	86.503	23.445	3.265	23.672	106.93	241.84

Arbitrary Net Section Collapse ANSC 2.0 (4/26/94)

11-10-1999 08:18:58

Page 4

Angle	Wall t	Delta	Pb,x'	Pb,y'	Pb,max	AngleMax	A tension
100.00	0.000	86.503	23.501	3.158	23.712	107.65	241.84
101.00	0.000	86.503	23.554	3.050	23.751	108.38	241.84
102.00	2.000	86.617	23.606	2.971	23.793	109.17	240.99
103.00	2.000	86.927	23.658	2.949	23.841	110.11	238.66
104.00	2.000	86.932	23.711	3.122	23.915	111.50	238.63
105.00	2.000	86.922	23.767	3.305	23.995	112.92	238.70
106.00	2.000	86.608	23.824	3.310	24.053	113.91	241.06
107.00	2.000	86.287	23.881	3.258	24.103	114.77	243.44
108.00	2.000	85.963	23.939	3.269	24.161	115.78	245.83
109.00	0.000	85.636	23.996	3.283	24.219	116.79	248.22
110.00	0.000	85.306	24.052	3.237	24.269	117.67	250.60
111.00	0.000	84.973	24.109	3.256	24.328	118.69	252.99
112.00	0.000	84.638	24.166	3.279	24.387	119.73	255.38
113.00	0.000	84.299	24.223	3.240	24.438	120.62	257.76
114.00	0.000	83.958	24.280	3.268	24.499	121.67	260.15
115.00	0.000	83.614	24.337	3.298	24.559	122.72	262.54
116.00	0.000	83.267	24.394	3.266	24.612	123.63	264.92
117.00	0.000	83.188	24.451	3.245	24.665	124.56	265.47
118.00	0.000	83.188	24.506	3.147	24.707	125.32	265.47
119.00	0.000	83.188	24.560	3.049	24.748	126.08	265.47
120.00	0.000	83.188	24.611	2.949	24.787	126.83	265.47
121.00	0.000	83.188	24.661	2.849	24.825	127.59	265.47
122.00	0.000	83.188	24.710	2.747	24.862	128.34	265.47
123.00	0.000	83.188	24.756	2.645	24.897	129.10	265.47
124.00	0.000	83.188	24.801	2.542	24.931	129.85	265.47
125.00	0.000	83.183	24.844	2.406	24.960	130.53	265.50
126.00	0.000	82.833	24.886	2.405	25.002	131.52	267.88
127.00	0.000	82.480	24.928	2.437	25.047	132.58	270.27
128.00	0.000	82.124	24.971	2.405	25.086	133.50	272.66
129.00	0.000	81.765	25.013	2.443	25.132	134.58	275.04
130.00	2.000	81.403	25.056	2.484	25.179	135.66	277.43
131.00	2.000	81.039	25.100	2.459	25.220	136.60	279.82
132.00	0.000	80.672	25.143	2.506	25.268	137.69	282.20
133.00	0.000	80.302	25.187	2.555	25.317	138.79	284.59
134.00	0.000	79.929	25.232	2.537	25.359	139.74	286.98
135.00	0.000	79.554	25.277	2.592	25.410	140.86	289.36
136.00	0.000	79.176	25.323	2.650	25.461	141.97	291.75
137.00	0.000	78.796	25.369	2.639	25.506	142.94	294.14
138.00	0.000	78.412	25.416	2.702	25.559	144.07	296.52
139.00	0.000	78.026	25.464	2.768	25.614	145.20	298.91
140.00	0.000	77.638	25.512	2.764	25.662	146.18	301.30
141.00	0.000	77.246	25.562	2.835	25.718	147.33	303.68
142.00	0.000	76.853	25.612	2.909	25.776	148.48	306.07
143.00	0.000	76.456	25.663	2.910	25.827	149.47	308.46
144.00	0.000	76.057	25.715	2.989	25.888	150.63	310.85
145.00	0.000	75.656	25.768	3.071	25.950	151.80	313.23
146.00	0.000	75.251	25.821	3.078	26.004	152.80	315.62
147.00	0.000	74.845	25.876	3.165	26.069	153.97	318.01
148.00	0.000	74.650	25.933	3.408	26.156	155.49	319.14
149.00	0.000	74.650	25.995	3.727	26.260	157.16	319.14

Arbitrary Net Section Collapse ANSC 2.0 (4/26/94)

11-10-1999 08:18:58

Page 5

Angle	Wall t	Delta	Pb,x'	Pb,y'	Pb,max	AngleMax	A tension
150.00	0.000	74.650	26.062	4.045	26.374	158.82	319.14
151.00	0.000	74.681	26.135	4.335	26.492	160.42	318.96
152.00	0.000	75.089	26.210	4.379	26.573	161.48	316.57
153.00	0.000	75.494	26.287	4.418	26.656	162.54	314.19
154.00	0.000	75.897	26.364	4.490	26.744	163.67	311.80
155.00	0.000	76.297	26.443	4.520	26.826	164.70	309.41
156.00	0.000	76.695	26.522	4.546	26.909	165.73	307.03
157.00	2.000	77.089	26.601	4.604	26.997	166.82	304.64
158.00	2.000	77.482	26.682	4.621	27.079	167.82	302.25
159.00	2.000	77.713	26.762	4.596	27.154	168.74	300.84
160.00	2.000	77.713	26.841	4.496	27.215	169.51	300.84
161.00	2.000	77.713	26.918	4.394	27.275	170.27	300.84
162.00	2.000	77.713	26.994	4.291	27.333	171.03	300.84
163.00	2.000	77.713	27.068	4.187	27.390	171.79	300.84
164.00	2.000	77.713	27.140	4.082	27.445	172.55	300.84
165.00	0.000	77.713	27.210	3.975	27.499	173.31	300.84
166.00	0.000	77.713	27.278	3.867	27.551	174.07	300.84
167.00	0.000	77.713	27.344	3.758	27.601	174.83	300.84
168.00	0.000	77.713	27.409	3.648	27.650	175.58	300.84
169.00	0.000	77.713	27.471	3.537	27.698	176.34	300.84
170.00	0.000	77.713	27.532	3.424	27.744	177.09	300.84
171.00	0.000	77.713	27.590	3.311	27.788	177.84	300.84
172.00	0.000	77.713	27.647	3.197	27.831	178.60	300.84
173.00	0.000	77.713	27.701	3.081	27.872	179.35	300.84
174.00	0.000	77.713	27.754	2.965	27.912	180.10	300.84
175.00	0.000	77.665	27.804	2.870	27.952	180.89	301.13
176.00	0.000	77.274	27.854	2.827	27.997	181.80	303.52
177.00	0.000	76.881	27.904	2.861	28.050	182.85	305.90
178.00	0.000	76.484	27.954	2.897	28.104	183.92	308.29
179.00	0.000	76.085	28.004	2.860	28.150	184.83	310.68
180.00	0.000	76.001	28.054	2.836	28.197	185.77	311.18
181.00	0.000	76.001	28.102	2.725	28.234	186.54	311.18
182.00	0.000	76.001	28.148	2.612	28.269	187.30	311.18
183.00	0.000	76.001	28.192	2.499	28.303	188.06	311.18
184.00	0.000	76.001	28.234	2.384	28.335	188.83	311.18
185.00	0.000	76.000	28.275	2.270	28.365	189.59	311.18
186.00	0.000	76.001	28.313	2.154	28.394	190.35	311.18
187.00	0.000	76.001	28.349	2.038	28.422	191.11	311.18
188.00	0.000	76.001	28.383	1.921	28.448	191.87	311.18
189.00	0.000	76.001	28.415	1.804	28.472	192.63	311.18
190.00	0.000	76.001	28.444	1.686	28.494	193.39	311.18
191.00	2.000	76.001	28.472	1.567	28.515	194.15	311.18
192.00	2.000	76.001	28.498	1.448	28.535	194.91	311.18
193.00	2.000	76.001	28.522	1.329	28.553	195.67	311.18
194.00	2.000	76.001	28.543	1.209	28.569	196.43	311.18
195.00	2.000	76.001	28.563	1.089	28.584	197.18	311.18
196.00	2.000	76.000	28.580	0.969	28.597	197.94	311.18
197.00	0.000	76.000	28.596	0.848	28.608	198.70	311.18
198.00	0.000	76.000	28.609	0.727	28.618	199.46	311.18
199.00	0.000	76.000	28.620	0.606	28.627	200.21	311.18

Arbitrary Net Section Collapse ANSC 2.0 (4/26/94)

11-10-1999 08:18:58

Page 6

Angle	Wall t	Delta	Pb,x'	Pb,y'	Pb,max	AngleMax	A tension
200.00	0.000	76.000	28.629	0.485	28.633	200.97	311.18
201.00	0.000	76.000	28.636	0.363	28.638	201.73	311.18
202.00	0.000	76.000	28.641	0.242	28.642	202.48	311.18
203.00	0.000	76.000	28.643	0.120	28.643	203.24	311.18
204.00	0.000	76.001	28.644	-0.002	28.644	204.00	311.18
205.00	0.000	76.001	28.642	-0.123	28.642	204.75	311.18
206.00	0.000	76.000	28.638	-0.245	28.639	205.51	311.18
207.00	0.000	76.000	28.632	-0.366	28.635	206.27	311.18
208.00	0.000	76.001	28.624	-0.488	28.629	207.02	311.18
209.00	0.000	76.001	28.614	-0.609	28.621	207.78	311.18
210.00	0.000	76.000	28.602	-0.730	28.611	208.54	311.18
211.00	0.000	76.000	28.588	-0.851	28.600	209.29	311.18
212.00	0.000	76.000	28.571	-0.971	28.588	210.05	311.18
213.00	0.000	76.000	28.553	-1.092	28.574	210.81	311.18
214.00	0.000	76.000	28.532	-1.211	28.558	211.57	311.18
215.00	0.000	76.377	28.510	-1.219	28.536	212.55	308.93
216.00	0.000	76.774	28.489	-1.229	28.515	213.53	306.55
217.00	2.000	77.168	28.467	-1.242	28.494	214.50	304.16
218.00	2.000	77.560	28.445	-1.221	28.472	215.54	301.77
219.00	2.000	77.949	28.423	-1.240	28.451	216.50	299.39
220.00	2.000	78.335	28.402	-1.262	28.430	217.45	297.00
221.00	2.000	78.719	28.379	-1.250	28.407	218.48	294.61
222.00	2.000	79.100	28.357	-1.278	28.386	219.42	292.23
223.00	2.000	79.479	28.334	-1.308	28.365	220.36	289.84
224.00	2.000	79.855	28.311	-1.306	28.341	221.36	287.45
225.00	2.000	80.228	28.288	-1.342	28.320	222.28	285.07
226.00	2.000	80.598	28.264	-1.381	28.298	223.20	282.68
227.00	2.000	80.966	28.240	-1.388	28.274	224.18	280.29
228.00	0.000	81.330	28.215	-1.433	28.251	225.09	277.91
229.00	0.000	81.413	28.191	-1.298	28.220	226.36	277.36
230.00	0.000	81.413	28.169	-1.105	28.191	227.75	277.36
231.00	0.000	81.413	28.152	-0.911	28.167	229.15	277.36
232.00	0.000	81.413	28.138	-0.717	28.147	230.54	277.36
233.00	0.000	81.413	28.127	-0.523	28.131	231.93	277.36
234.00	0.000	81.413	28.119	-0.328	28.121	233.33	277.36
235.00	0.000	81.413	28.115	-0.134	28.115	234.73	277.36
236.00	0.000	81.413	28.114	0.061	28.114	236.12	277.36
237.00	0.000	81.490	28.117	0.231	28.118	237.47	276.86
238.00	0.000	81.703	28.120	0.149	28.120	238.30	275.45
239.00	0.000	81.703	28.120	-0.001	28.120	239.00	275.45
240.00	2.000	81.703	28.119	-0.151	28.119	239.69	275.45
241.00	2.000	81.703	28.114	-0.301	28.116	240.38	275.45
242.00	2.000	81.703	28.107	-0.451	28.111	241.08	275.45
243.00	0.000	81.703	28.097	-0.601	28.104	241.77	275.45
244.00	0.000	81.703	28.085	-0.751	28.095	242.47	275.45
245.00	0.000	81.973	28.071	-0.833	28.083	243.30	273.66
246.00	0.000	82.330	28.055	-0.885	28.069	244.19	271.27
247.00	0.000	82.685	28.040	-0.906	28.054	245.15	268.89
248.00	0.000	83.036	28.023	-0.964	28.039	246.03	266.50
249.00	0.000	83.385	28.005	-1.025	28.024	246.90	264.11

Arbitrary Net Section Collapse ANSC 2.0 (4/26/94)

11-10-1999 08:18:59

Page 7

Angle	Wall t	Delta	Pb,x'	Pb,y'	Pb,max	AngleMax	A tension
250.00	0.000	83.731	27.987	-1.056	28.007	247.84	261.73
251.00	2.000	84.074	27.968	-1.123	27.990	248.70	259.34
252.00	2.000	84.415	27.947	-1.194	27.973	249.55	256.95
253.00	2.000	84.752	27.926	-1.236	27.953	250.47	254.57
254.00	2.000	85.087	27.903	-1.312	27.934	251.31	252.18
255.00	2.000	85.419	27.880	-1.392	27.914	252.14	249.79
256.00	2.000	85.479	27.854	-1.536	27.896	252.84	249.36
257.00	2.000	85.479	27.825	-1.710	27.878	253.48	249.36
258.00	2.000	85.479	27.794	-1.884	27.858	254.12	249.36
259.00	2.000	85.479	27.759	-2.058	27.835	254.76	249.36
260.00	2.000	85.479	27.721	-2.231	27.811	255.40	249.36
261.00	0.000	85.479	27.681	-2.403	27.785	256.04	249.36
262.00	0.000	85.479	27.637	-2.574	27.757	256.68	249.36
263.00	0.000	85.479	27.590	-2.745	27.727	257.32	249.36
264.00	0.000	85.479	27.541	-2.915	27.695	257.96	249.36
265.00	0.000	85.479	27.488	-3.084	27.661	258.60	249.36
266.00	0.000	85.479	27.433	-3.252	27.625	259.24	249.36
267.00	0.000	85.479	27.374	-3.419	27.587	259.88	249.35
268.00	0.000	85.479	27.313	-3.585	27.547	260.52	249.35
269.00	0.000	85.479	27.248	-3.749	27.505	261.16	249.36
270.00	2.000	85.479	27.181	-3.913	27.462	261.81	249.36
271.00	2.000	85.479	27.111	-4.076	27.416	262.45	249.36
272.00	2.000	85.479	27.039	-4.237	27.369	263.09	249.36
273.00	2.000	85.479	26.963	-4.397	27.319	263.74	249.36
274.00	2.000	85.479	26.885	-4.555	27.268	264.38	249.36
275.00	2.000	85.479	26.804	-4.713	27.215	265.03	249.36
276.00	2.000	85.580	26.720	-4.837	27.154	265.74	248.62
277.00	2.000	85.907	26.635	-4.901	27.082	266.57	246.24
278.00	2.000	86.232	26.549	-4.937	27.004	267.46	243.85
279.00	2.000	86.553	26.461	-5.005	26.931	268.29	241.46
280.00	2.000	86.714	26.373	-5.104	26.863	269.04	240.26
281.00	2.000	86.714	26.282	-5.263	26.804	269.67	240.26
282.00	2.000	86.714	26.189	-5.420	26.744	270.31	240.26
283.00	2.000	86.714	26.092	-5.576	26.681	270.94	240.26
284.00	2.000	86.714	25.993	-5.729	26.617	271.57	240.26
285.00	2.000	86.714	25.891	-5.881	26.551	272.20	240.26
286.00	2.000	86.714	25.787	-6.031	26.483	272.83	240.26
287.00	2.000	86.714	25.680	-6.180	26.413	273.47	240.26
288.00	0.000	86.714	25.571	-6.326	26.341	274.10	240.26
289.00	0.000	86.560	25.459	-6.452	26.264	274.78	241.42
290.00	0.000	86.238	25.346	-6.471	26.159	275.68	243.80
291.00	0.000	85.914	25.232	-6.544	26.067	276.46	246.19
292.00	0.000	85.587	25.118	-6.551	25.959	277.38	248.58
293.00	0.000	85.256	25.004	-6.552	25.848	278.31	250.96
294.00	0.000	84.923	24.889	-6.610	25.752	279.13	253.35
295.00	0.000	84.587	24.774	-6.600	25.638	280.08	255.74
296.00	0.000	84.248	24.659	-6.583	25.523	281.05	258.12
297.00	0.000	83.907	24.544	-6.625	25.423	281.89	260.51
298.00	0.000	83.562	24.429	-6.598	25.304	282.89	262.89
299.00	0.000	83.215	24.314	-6.564	25.184	283.89	265.28

Arbitrary Net Section Collapse ANSC 2.0 (4/26/94)

11-10-1999 08:18:59

Page 8

Angle	Wall t	Delta	Pb,x'	Pb,y'	Pb,max	AngleMax	A tension
300.00	0.000	82.868	24.199	-6.590	25.081	284.76	267.64
301.00	0.000	82.868	24.087	-6.348	24.909	286.23	267.64
302.00	0.000	82.868	23.979	-6.104	24.744	287.72	267.64
303.00	0.000	82.868	23.875	-5.857	24.583	289.21	267.64
304.00	0.000	82.868	23.776	-5.609	24.428	290.72	267.64
305.00	0.000	82.868	23.681	-5.360	24.279	292.25	267.64
306.00	0.000	82.868	23.590	-5.108	24.136	293.78	267.64
307.00	0.000	82.868	23.503	-4.855	24.000	295.33	267.64
308.00	0.000	82.868	23.421	-4.601	23.869	296.88	267.64
309.00	0.000	82.710	23.343	-4.411	23.757	298.30	268.72
310.00	0.000	82.355	23.267	-4.350	23.670	299.41	271.11
311.00	0.000	81.998	23.191	-4.351	23.595	300.37	273.49
312.00	0.000	81.642	23.116	-4.279	23.508	301.51	275.85
313.00	0.000	81.621	23.041	-4.314	23.441	302.39	275.99
314.00	0.000	81.621	22.964	-4.374	23.377	303.21	275.99
315.00	2.000	81.622	22.887	-4.433	23.312	304.04	275.99
316.00	2.000	81.622	22.809	-4.491	23.247	304.86	275.99
317.00	2.000	81.622	22.729	-4.547	23.180	305.69	275.99
318.00	0.000	81.622	22.649	-4.602	23.112	306.51	275.99
319.00	0.000	81.516	22.568	-4.635	23.039	307.39	276.69
320.00	0.000	81.152	22.488	-4.547	22.943	308.57	279.08
321.00	0.000	80.786	22.408	-4.524	22.860	309.58	281.46
322.00	0.000	80.417	22.330	-4.427	22.765	310.79	283.85
323.00	0.000	80.045	22.254	-4.324	22.670	312.00	286.24
324.00	0.000	79.671	22.178	-4.288	22.589	313.06	288.62
325.00	0.000	79.294	22.104	-4.176	22.495	314.30	291.01
326.00	0.000	78.914	22.032	-4.059	22.403	315.56	293.40
327.00	0.000	78.531	21.961	-4.009	22.324	316.65	295.78
328.00	0.000	78.146	21.893	-3.883	22.234	317.94	298.17
329.00	0.000	77.758	21.826	-3.752	22.146	319.24	300.56
330.00	0.000	77.564	21.760	-3.679	22.069	320.40	301.75
331.00	0.000	77.953	21.697	-3.581	21.990	321.63	299.36
332.00	0.000	78.339	21.635	-3.449	21.908	322.94	296.98
333.00	0.000	78.723	21.575	-3.355	21.834	324.16	294.59
334.00	0.000	79.104	21.517	-3.263	21.763	325.38	292.20
335.00	0.000	79.483	21.461	-3.138	21.689	326.68	289.82
336.00	0.000	79.858	21.406	-3.051	21.622	327.89	287.43
337.00	0.000	80.231	21.353	-2.967	21.558	329.09	285.04
338.00	0.000	80.602	21.302	-2.850	21.492	330.38	282.66
339.00	0.000	80.813	21.252	-2.839	21.441	331.39	281.29
340.00	0.000	80.813	21.203	-2.862	21.395	332.31	281.29
341.00	0.000	80.813	21.153	-2.885	21.348	333.23	281.29
342.00	0.000	80.813	21.102	-2.907	21.301	334.15	281.29
343.00	0.000	80.813	21.051	-2.928	21.254	335.08	281.29
344.00	0.000	80.813	21.000	-2.948	21.206	336.01	281.29
345.00	0.000	80.813	20.948	-2.967	21.157	336.94	281.29
346.00	0.000	80.813	20.896	-2.986	21.108	337.87	281.29
347.00	0.000	80.813	20.844	-3.003	21.059	338.80	281.29
348.00	0.000	80.535	20.792	-2.928	20.997	339.98	283.09
349.00	0.000	80.164	20.741	-2.800	20.930	341.31	285.47

Arbitrary Net Section Collapse ANSC 2.0 (4/26/94)

11-10-1999 08:18:59

Page 9

Angle	Wall t	Delta	Pb,x'	Pb,y'	Pb,max	AngleMax	A tension
350.00	0.000	79.791	20.693	-2.739	20.873	342.46	287.86
351.00	0.000	79.418	20.646	-2.602	20.810	343.81	290.22
352.00	0.000	79.393	20.601	-2.577	20.761	344.87	290.38
353.00	0.000	79.393	20.555	-2.580	20.717	345.85	290.38
354.00	0.000	79.393	20.510	-2.581	20.672	346.83	290.38
355.00	0.000	79.393	20.464	-2.582	20.627	347.81	290.38
356.00	0.000	79.393	20.419	-2.582	20.582	348.79	290.38
357.00	0.000	79.393	20.373	-2.582	20.536	349.78	290.38
358.00	0.000	79.603	20.328	-2.510	20.482	350.96	289.05
359.00	0.000	79.978	20.285	-2.404	20.427	352.24	286.67

MINIMUM STRESS (Pb,x') = 19.835 AT 20.00 DEGREES
 MINIMUM TOTAL STRESS (Pb,max) = 19.835 AT 20.10 DEGREES

APPENDIX B

Linear Elastic Fracture Mechanics Evaluation

In order to evaluate welds H3 and H4 utilizing linear elastic fracture mechanics techniques (LEFM), the procedures outlined in BWRVIP-01 [3] will be used. For an infinite number of equally spaced through-wall flaws, the applied stress intensity factor can be calculated from the following:

$$K = G_m \sigma \sqrt{W \tan(\pi a / W)}$$

where:

K	=	applied stress intensity factor
σ	=	applied tension stress, i.e., the sum of the bending moment and pressure differential stresses from Table 1
W	=	distance between mid-points of two adjacent ligaments
a	=	one-half the length of the through-wall flaw
G_m	=	curvature correction factor

From Appendix A, the longest through-wall flaw for weld H3 is 54.31° , and the shortest adjacent ligament to this flaw is 9.61° . From Rooke [8], for a value of a/\sqrt{Rt} equal to 3.39, G_m equals 1.78. Therefore, the applied stress intensity factor for weld H3 for faulted conditions is:

$$\begin{aligned} K &= (1.78)(1.13 \text{ ksi}) \sqrt{(114.42^\circ) \tan[(\pi)(27.155^\circ)/63.92^\circ]} \\ &= 43.9 \text{ ksi}\sqrt{\text{in}} \end{aligned}$$

For weld H4, the second longest through-wall flaw is 53.74° , and the shortest adjacent ligament to this flaw is 2.89° . For a value of a/\sqrt{Rt} equal to 3.36, G_m equals 1.78. Therefore, the applied stress intensity factor for weld H4 for upset conditions is:

$$\begin{aligned} K &= (1.78)(0.72 \text{ ksi}) \sqrt{(101.37^\circ) \tan[(\pi)(26.87^\circ)/56.63^\circ]} \\ &= 45.5 \text{ ksi}\sqrt{\text{in}} \end{aligned}$$

For the longest through-wall flaw in weld H4 (56.91°), the shortest adjacent ligament to this flaw is 8.56° . For a/\sqrt{Rt} equal to 3.56, G_m equals 1.82. Therefore, the applied stress intensity factor for weld H4 for upset conditions is:

$$\begin{aligned} K &= (1.82)(0.72 \text{ ksi}) \sqrt{(117.19^\circ) \tan[(\pi)(28.455^\circ)/65.47^\circ]} \\ &= 31.1 \text{ ksi}\sqrt{\text{in}} \end{aligned}$$

APPENDIX C

Evaluation of Crack Growth Rates



This appendix contains ultrasonic examination (UT) results from the 1995 outage (3R10) of Peach Bottom, Unit 3 and the 1999 outage (3R12). The purpose of this appendix is to evaluate the data from these two successive inspections, and determine an IGSCC growth rate in the length direction. However, some discussion is first needed relative to the 3R10 data, and why it is different than that reported earlier [1].

The UT data taken in 1995 was reanalyzed in 1999 utilizing an upgraded data analysis software package [9]. Comparing the original data analysis results with those determined in 1999, there were some differences noted. The following is a brief explanation for the differences observed.

Two primary factors, computer software and personnel, contributed to the changes which were observed. These factors are each discussed in more detail below.

Computer Software – During the time period between the 1995 3R10 outage and the 1999 data reanalysis, GE Nuclear Energy had upgraded their analysis software from the “SMART 2000” to the currently used “Tomo-View” program. This software enhances and refines the data presentation used by the data analyst in more accurately characterizing specific indications. The new software presentation permits the analyst to more easily separate closely spaced or overlapping indications, and to better differentiate between service-induced cracking and non-relevant, original fabrication indications.

Personnel – Different Level III UT data analysts performed the two data evaluations. It must be emphasized that UT data analysis is not a black and white issue. To some extent the process is subjective, and an individual’s evaluation “style”, as well as personal experiences and techniques, affect the evaluation. These human factors contribute to subtle, but distinct, variations in the final product.

In summary, the evaluations performed in 1995 and 1999, when taken as a whole, reveal a very close correlation. Considering the changes in computer software and personnel, even more significant changes than those observed would not have been unexpected.

With that explanation, Tables C-1 (H3) and C-2 (H4) document the 3R10 data determined utilizing the upgrade software system and that from 3R12. Based upon a comparison of the two data sets, an average crack growth rate for this four year period can be determined. Reviewing the data, one observes that the use of 5×10^{-5} inches/hour for a crack growth rate bounds that based upon actual field data. Therefore, the use of this crack growth rate for evaluation of the Peach Bottom, Unit 3 shroud is acceptable.

Table C-1
Weld H3 Crack Growth Rate

3R10 Flaw Data [9]				3R12 Flaw Data [4]			Length ¹ Increase (inches)	Length ² CGR (in./hr.)
Indication Number	Starting Azimuth (degrees)	Ending Azimuth (degrees)	Length (degrees)	Starting Azimuth (degrees)	Ending Azimuth (degrees)	Length (degrees)		
1	9.20	13.00	3.80	9.56	17.26	7.70	7.05	1.10E-04
2	54.20	62.45	8.25	53.66	63.71	10.05	3.25	5.08E-05
3	104.70	106.35	1.65	104.51	110.91	6.40	1.63	2.55E-05
4	106.90	110.20	3.30					
5	144.20	172.95	28.75	143.66	166.41	22.75	-10.85	NONE
6	203.21	232.65	29.44	203.11	234.21	31.10	3.00	4.69E-05
7	240.92	250.32	9.40	240.06	251.96	11.90	4.52	7.06E-05
8	283.68	284.80	1.12	283.96	285.61	1.65	0.96	1.50E-05
9	298.68	309.20	10.52	299.01	327.01	28.00	2.46	3.84E-05
10	310.88	325.32	14.44					
11	348.72	353.77	5.05	Uninspected Region			Uninspected Region	
							Average ³ Crack Growth	4.47E-05

- Notes:
1. Conservatively based upon the shroud outside radius.
 2. Based upon 32,000 hours.
 3. The average crack growth rate equals the total length increase (negative growth is set to 0.00") divided by the number of entries and 64,000.

Table C-2
Weld H4 Crack Growth Rate

3R10 Flaw Data [9]				3R12 Flaw Data [4]			Length ² Increase (inches)	Length ³ CGR (in./hr.)
Indication ¹ Number	Starting Azimuth (degrees)	Ending Azimuth (degrees)	Length (degrees)	Starting Azimuth (degrees)	Ending Azimuth (degrees)	Length (degrees)		
1 (L)	10.32	11.44	1.12					
2 (U)	23.70	26.50	2.80	22.06	29.48	7.42	8.35	1.30E-04
3 (L)	24.76	25.88	1.12	25.11	30.06	4.95	1.03	1.61E-05
4 (L)	27.00	28.68	1.68					
5 (U)	28.18	29.30	1.12					
(L)				32.61	34.46	1.85	-	-
6 (U)	36.02	37.14	1.12	34.31	36.51	2.20	1.95	3.05E-05
7 (L)	42.00	45.36	3.36	42.31	46.71	4.40	1.88	2.94E-05
8 (U)	47.66	51.58	3.92	46.01	51.51	5.50	2.86	4.47E-05
9 (L)	49.28	54.32	5.04	48.71	54.76	6.05	1.83	2.86E-05
10 (L)	55.32	57.56	2.24	55.11	58.96	3.85	2.91	4.55E-05
11 (U)	62.10	67.70	5.60	61.01	68.71	7.70	3.80	5.94E-05
12 (L)	63.16	64.28	1.12	62.61	65.36	2.75	2.95	4.61E-05
13 (U)	72.06	73.18	1.12	71.81	74.01	2.20	1.95	3.05E-05
14 (U)	83.70	84.82	1.12					
15 (L)	96.52	99.32	2.80	97.01	99.21	2.20	-1.08	NONE
16 (U)	113.26	114.26	1.00	110.96	115.36	4.40	6.15	9.61E-05
17 (U)	124.34	126.02	1.68	122.11	126.51	4.40	4.92	7.69E-05
18 (L)	135.36	150.36	15.00	134.51	153.36	18.85	6.96	1.09E-04
19 (U)	201.02	205.38	4.36	199.31	206.29	6.98	4.74	7.41E-05
20 (L)	202.08	204.32	2.24	202.01	204.76	2.75	0.92	1.44E-05
21 (U)	210.98	213.22	2.24	210.14	213.99	3.85	2.91	4.55E-05



Table C-2 (concluded)
Weld H4 Crack Growth Rate

3R10 Flaw Data [9]				3R12 Flaw Data [4]			Length ² Increase (inches)	Length ³ CGR (in./hr.)
Indication ¹ Number	Starting Azimuth (degrees)	Ending Azimuth (degrees)	Length (degrees)	Starting Azimuth (degrees)	Ending Azimuth (degrees)	Length (degrees)		
22 (U)	216.02	218.82	2.80					
23 (L)	230.40	232.08	1.68	229.82	230.92	1.10	-1.05	NONE
24 (U)	233.70	235.38	1.68	233.51	236.81	3.30	2.93	4.58E-05
25 (L)	244.84	247.08	2.24	244.26	248.71	4.45	3.99	6.23E-05
26 (U)	263.70	265.38	1.68	263.16	266.46	3.30	2.93	4.58E-05
27 (L)	289.96	293.76	3.80					
28 (L)	294.32	295.44	1.12	290.36	297.51	7.15	-0.57	NONE
29 (L)	296.50	297.68	1.18					
30 (U)	296.50	297.62	1.12					
31 (L)	298.24	301.60	3.36	295.16	298.46	3.30	3.94	6.16E-05
32 (L)	306.08	308.76	2.68	297.86	303.36	5.50	3.87	6.05E-05
33 (L)	318.28	319.40	1.12	307.01	311.41	4.40	3.11	4.86E-05
34 (L)	325.44	326.56	1.12	319.26	322.01	2.75	2.95	4.61E-05
34a (L)	327.12	329.36	2.24	326.76	345.26	18.50	1.96	3.06E-05
34b (L)	329.36	339.18	9.82					
35 (L)	340.30	341.98	1.68					
36 (U)	325.38	327.06	1.68	324.81	326.46	1.65	-0.05	NONE
							Average ⁴ Crack Growth	4.56E-05

- Notes: 1. "U" is upper, and "L" is lower.
 2. Conservatively based upon the shroud outside radius.
 3. Based upon 32,000 hours.
 4. The average crack growth rate equals the total length increase (negative growth is set to 0.00") divided by the number of entries and 64,000.