



Wisconsin Electric
A WISCONSIN ENERGY COMPANY

Point Beach Nuclear Plant
6610 Nuclear Rd.
Two Rivers, WI 54241
Phone 920 755-2321

NPL 2000-0063

February 7, 2000

Document Control Desk
U. S. NUCLEAR REGULATORY COMMISSION
Mail Station P1-137
Washington, DC 20555

Ladies/Gentlemen:

DOCKETS 50-266 AND 50-301
MONTHLY OPERATING REPORTS
POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2

Attached are monthly operating reports for Units 1 and 2 of the Point Beach Nuclear Plant for the calendar month of January, 2000.

Sincerely,

A handwritten signature in black ink, appearing to read 'A. J. Cayia', written over a circular stamp or seal.

A. J. Cayia
Manager,
Regulatory Services & Licensing

MBK/tja

Attachments

cc: J. D. Loock, PSCW
NRC Regional Administrator, Region III
NRC Resident Inspector

IE24

OPERATING DATA REPORT

DOCKET NO. 50-266

DATE: 02/07/00

COMPLETED BY: M. B. Koudelka

TELEPHONE: (920) 755-6480

OPERATING STATUS

1. UNIT NAME: POINT BEACH NUCLEAR PLANT - UNIT 1
2. REPORTING PERIOD: January - 2000
3. LICENSED THERMAL POWER (MWT): 1,518.5
4. NAMEPLATING RATING (GROSS MWE): 537.7
5. DESIGN ELECTRICAL RATING (NET MWE): 515.0
6. MAXIMUM DEPENDABLE CAPACITY (GROSS MWE): 530.0
7. MAXIMUM DEPENDABLE CAPACITY (NET MWE): 510.0
8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS:
NA
9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWE): NA
10. REASONS FOR RESTRICTIONS, (IF ANY):
NA

NOTES

| | THIS MONTH | YEAR TO DATE | CUMULATIVE |
|--|-------------|--------------|---------------|
| 11. HOURS IN REPORTING PERIOD | 744.0 | 744.0 | 256,296.0 |
| 12. NUMBER OF HOURS REACTOR WAS CRITICAL | 702.7 | 702.7 | 208,219.9 |
| 13. REACTOR RESERVE SHUTDOWN HOURS | 0.0 | 0.0 | 667.3 |
| 14. HOURS GENERATOR ONLINE | 698.6 | 698.6 | 204,787.3 |
| 15. UNIT RESERVE SHUTDOWN HOURS | 0.0 | 0.0 | 846.9 |
| 16. GROSS THERMAL ENERGY GENERATED (MWH) | 1,015,684.0 | 1,015,684.0 | 291,341,314.0 |
| 17. GROSS ELECTRICAL ENERGY GENERATED | 352,880.0 | 352,880.0 | 98,693,310.0 |
| 18. NET ELECTRICAL ENERGY GENERATED (MWH) | 337,319.5 | 337,319.5 | 94,076,121.5 |
| 19. UNIT SERVICE FACTOR | 93.9% | 93.9% | 79.9% |
| 20. UNIT AVAILABILITY FACTOR | 93.9% | 93.9% | 80.2% |
| 21. UNIT CAPACITY FACTOR (USING MDC NET) | 88.9% | 88.9% | 75.3% |
| 22. UNIT CAPACITY FACTOR (USING DER NET) | 88.0% | 88.0% | 73.8% |
| 23. UNIT FORCED OUTAGE RATE | 6.1% | 6.1% | 4.6% |
| 24. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH): None | | | |
| 25. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: NA | | | |

DATA REPORTED AND FACTORS CALCULATED AS REQUESTED IN NRC LETTER DATED SEPTEMBER 22, 1977

POINT BEACH NUCLEAR PLANT

AVERAGE DAILY UNIT POWER LEVEL

MONTH JANUARY - 2000

DOCKET NO. 50-266
 UNIT NAME: Point Beach, Unit 1
 DATE: 02/02/00
 COMPLETED BY: M. B. Koudelka
 TELEPHONE: (920) 755-6480

| <u>DAY</u> | <u>AVERAGE DAILY POWER LEVEL MWe NET</u> | <u>DAY</u> | <u>AVERAGE DAILY POWER LEVEL MWe NET</u> | <u>DAY</u> | <u>AVERAGE DAILY POWER LEVEL MWe NET</u> |
|------------|--|------------|--|------------|--|
| 1 | <u>507</u> | 11 | <u>508</u> | 21 | <u>38</u> |
| 2 | <u>509</u> | 12 | <u>508</u> | 22 | <u>-13</u> |
| 3 | <u>511</u> | 13 | <u>508</u> | 23 | <u>1</u> |
| 4 | <u>509</u> | 14 | <u>506</u> | 24 | <u>341</u> |
| 5 | <u>510</u> | 15 | <u>508</u> | 25 | <u>502</u> |
| 6 | <u>510</u> | 16 | <u>508</u> | 26 | <u>501</u> |
| 7 | <u>508</u> | 17 | <u>509</u> | 27 | <u>502</u> |
| 8 | <u>510</u> | 18 | <u>508</u> | 28 | <u>502</u> |
| 9 | <u>509</u> | 19 | <u>506</u> | 29 | <u>504</u> |
| 10 | <u>508</u> | 20 | <u>508</u> | 30 | <u>505</u> |
| | | | | 31 | <u>504</u> |

POINT BEACH NUCLEAR PLANT
UNIT SHUTDOWNS AND POWER REDUCTIONS
 REPORT MONTH JANUARY - 2000

Docket No. 50-266
 Unit Name Point Beach, Unit 1
 Date 2/7/2000
 Completed By M. B. Koudelka
 Telephone No. 920/755-6480

| No. | Date | Type ¹ | Duration (Hours) | Reason ² | Method of Reactor Shut Down ³ | Licensee Event Report No. | System Code ⁴ | Component Code ⁵ | Cause and Corrective Action To Prevent Recurrence |
|-----|----------|-------------------|------------------|---------------------|--|---------------------------|--------------------------|-----------------------------|--|
| 1 | 20000121 | F | 45.4 | H | 2 | 266/2000-001-00 | NA | NA | The reactor was manually tripped because of low forebay lake water levels and icing in the intake structure. |

¹F: Forced
 S: Scheduled

²Reason:
 A - Equipment Failure (explain)
 B - Maintenance or Testing
 C - Refueling
 D - Regulatory Restriction
 E - Operator Training & Licensing Exam
 F - Administrative
 G - Operational Error (explain)
 H - Other (explain)

³Method:
 1 - Manual
 2 - Manual Scram
 3 - Automatic Scram
 4 - Continuation of Previous Shutdown
 5 - Reduced Load
 6 - Other (explain)

⁴Exhibit G - Instructions for preparation of data entry sheets LER file (NUREG-0161)

⁵Exhibit I - Same Source

DOCKET NO. 50-266
UNIT NAME Point Beach Unit 1
DATE 02/02/00
COMPLETED BY M. B. Koudelka
TELEPHONE 920/755-6480

The daily power average for Unit 1 during January, 2000, was 453.4 MWe.

One Licensee Event Report (LER) was submitted to the NRC during January, 2000:

LER 266/1999-014-00, Containment Upper Hatch Outer Door Vent Valve Found Open.

Safety-related maintenance included:

1. 1A-06 4.16 kV safeguards bus switchgear troubleshooting performed.
2. 1B42-391 D-07 station battery charger Train A contactor emergency close switch installed.
3. 1B42-491 D-09 swing station battery charger Train B contactor emergency close switch installed.
4. 1B42-494 D-108 station battery charger Train B contactor emergency close switch installed.
5. 1B42-3212H D-109 swing station battery charger Train A contactor emergency close switch installed.
6. 1B52-15C tie to 1B00-4C on 1B-01 bus breaker maintenance and amptector testing performed.
7. 1CC-00765A P-1A reactor coolant pump component cooling return header stop valve repainted.
8. D-105 125 Vdc station battery service test performed.
9. D-107 D-105 dc station battery charger inspected.
10. 83/DY-0C DY-0C white inverter static transfer switch setpoint changed.
11. G-02 emergency diesel generator and associated equipment inspection and repairs.
12. 1HX-1B steam generator header motor-operated valve repairs.
13. 1MS-02017 and 1MS-02020 HX-1A&B steam generator steam supply motor-operated valve and stop control valve troubleshooting performed.
14. 1MS-02018-O HX-1A steam generator header main steam stop control operator troubleshooting performed.

15. 1P-002A charging pump plungers, O-rings, gaskets, leak-off tubing and gland plate retainer nut replaced.
16. 1P-011A&B component cooling water pumps inboard and outboard pump bearing oil changed, coupling greased and motor intakes cleaned.
17. P-012A spent fuel pool cooling pump rebuilt and mechanical seal replaced.
18. 1P-029 and 1P-029-T turbine-driven auxiliary feedwater pump and turbine bearing oil changed.
19. 1P-029 turbine-driven auxiliary feedwater pump flush line installed between service water supply and return header.
20. P-032D-M service water pump motor upper bearings replaced.
21. P-032F-M service water pump motor upper motor bearings replaced.
22. P-038A motor-driven auxiliary feedwater pump flush line installed between service water supply and return header.
23. SF-00017 HX-13A spent fuel pool heat exchanger drain valve inspected.
24. 1SI-00857A&B HX-11A&B residual heat removal heat exchanger outlet to P-15A&B safety injection pump suction valves replaced with a motor-operated valves.
25. SW-00527 SW-2817 water treatment supply inlet valve motor operator refurbished.
26. SW-02911 SW-2911-BS north Zurn strainer automatic drain control valve troubleshooting performed.
27. SW-02912-BS south service water header Zurn strainer inspected and screens cleaned.

OPERATING DATA REPORT

DOCKET NO. 50-301

DATE: 02/02/00

COMPLETED BY: M. B. Koudelka

TELEPHONE: (920) 755-6480

OPERATING STATUS

| |
|-------|
| NOTES |
|-------|

1. UNIT NAME: POINT BEACH NUCLEAR PLANT - UNIT 2
2. REPORTING PERIOD: January - 2000
3. LICENSED THERMAL POWER (MWT): 1,518.5
4. NAMEPLATING RATING (GROSS MWE): 537.7
5. DESIGN ELECTRICAL RATING (NET MWE): 515.0
6. MAXIMUM DEPENDABLE CAPACITY (GROSS MWE): 532.0
7. MAXIMUM DEPENDABLE CAPACITY (NET MWE): 512.0
8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS:
NA
9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWE): NA
10. REASONS FOR RESTRICTIONS, (IF ANY):
NA

| | THIS MONTH | YEAR TO DATE | CUMULATIVE |
|--|-------------|--------------|---------------|
| 11. HOURS IN REPORTING PERIOD | 744.0 | 744.0 | 241,081.0 |
| 12. NUMBER OF HOURS REACTOR WAS CRITICAL | 744.0 | 744.0 | 202,678.5 |
| 13. REACTOR RESERVE SHUTDOWN HOURS | 0.0 | 0.0 | 233.9 |
| 14. HOURS GENERATOR ONLINE | 744.0 | 744.0 | 199,846.7 |
| 15. UNIT RESERVE SHUTDOWN HOURS | 0.0 | 0.0 | 302.2 |
| 16. GROSS THERMAL ENERGY GENERATED (MWH) | 1,128,131.0 | 1,128,131.0 | 287,584,214.0 |
| 17. GROSS ELECTRICAL ENERGY GENERATED | 394,680.0 | 394,680.0 | 97,892,680.0 |
| 18. NET ELECTRICAL ENERGY GENERATED (MWH) | 378,583.5 | 378,583.5 | 93,294,355.5 |
| 19. UNIT SERVICE FACTOR | 100.0% | 100.0% | 82.9% |
| 20. UNIT AVAILABILITY FACTOR | 100.0% | 100.0% | 83.0% |
| 21. UNIT CAPACITY FACTOR (USING MDC NET) | 99.4% | 99.4% | 79.2% |
| 22. UNIT CAPACITY FACTOR (USING DER NET) | 98.8% | 98.8% | 77.8% |
| 23. UNIT FORCED OUTAGE RATE | 0.0% | 0.0% | 2.3% |
| 24. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH): None | | | |
| 25. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: NA | | | |

POINT BEACH NUCLEAR PLANT

AVERAGE DAILY UNIT POWER LEVEL

MONTH JANUARY - 2000

DOCKET NO. 50-301
 UNIT NAME: Point Beach, Unit 2
 DATE: 02/02/00
 COMPLETED BY: M. B. Koudelka
 TELEPHONE: (920) 755-6480

| <u>DAY</u> | <u>AVERAGE DAILY POWER LEVEL MWe NET</u> | <u>DAY</u> | <u>AVERAGE DAILY POWER LEVEL MWe NET</u> | <u>DAY</u> | <u>AVERAGE DAILY POWER LEVEL MWe NET</u> |
|------------|--|------------|--|------------|--|
| 1 | <u>510</u> | 11 | <u>510</u> | 21 | <u>499</u> |
| 2 | <u>512</u> | 12 | <u>512</u> | 22 | <u>506</u> |
| 3 | <u>512</u> | 13 | <u>510</u> | 23 | <u>503</u> |
| 4 | <u>510</u> | 14 | <u>509</u> | 24 | <u>506</u> |
| 5 | <u>510</u> | 15 | <u>512</u> | 25 | <u>507</u> |
| 6 | <u>511</u> | 16 | <u>511</u> | 26 | <u>505</u> |
| 7 | <u>509</u> | 17 | <u>512</u> | 27 | <u>505</u> |
| 8 | <u>512</u> | 18 | <u>511</u> | 28 | <u>504</u> |
| 9 | <u>511</u> | 19 | <u>510</u> | 29 | <u>508</u> |
| 10 | <u>512</u> | 20 | <u>511</u> | 30 | <u>508</u> |
| | | | | 31 | <u>507</u> |

POINT BEACH NUCLEAR PLANT
UNIT SHUTDOWNS AND POWER REDUCTIONS
 REPORT MONTH JANUARY - 2000

Docket No. 50-301
 Unit Name Point Beach, Unit 2
 Date 2/2/2000
 Completed By M. B. Koudelka
 Telephone No. 920/755-6480

| No. | Date | Type ¹ | Duration (Hours) | Reason ² | Method of Reactor Shut Down ³ | Licensee Event Report No. | System Code ⁴ | Component Code ⁵ | Cause and Corrective Action To Prevent Recurrence |
|-----|------|-------------------|------------------|---------------------|--|---------------------------|--------------------------|-----------------------------|---|
| -- | NA | NA | NA | NA | NA | NA | NA | NA | NA |

¹F: Forced
 S: Scheduled

²Reason:
 A - Equipment Failure (explain)
 B - Maintenance or Testing
 C - Refueling
 D - Regulatory Restriction
 E - Operator Training & Licensing Exam
 F - Administrative
 G - Operational Error (explain)
 H - Other (explain)

³Method:
 1 - Manual
 2 - Manual Scram
 3 - Automatic Scram
 4 - Continuation of Previous Shutdown
 5 - Reduced Load
 6 - Other (explain)

⁴Exhibit G - Instructions for preparation of data entry sheets LER file (NUREG-0161)

⁵Exhibit I - Same Source

DOCKET NO. 50-301
UNIT NAME Point Beach Unit 2
DATE 02/02/00
COMPLETED BY M. B. Koudelka
TELEPHONE 920/755-6480

The daily power average for Unit 2 during January, 2000, was 508.9 MWe.

No Licensee Event Reports (LERs) were submitted to the NRC during January, 2000.

Safety-related maintenance included:

1. 2B-30 480 V safeguards motor control center breaker heaters replaced.
2. 2B42-391 D-09 swing station battery charger Train A contactor emergency close switch installed.
3. 2B42-394 D-109 swing station battery charger Train B contactor emergency close switch installed.
4. 2B42-491 D-08 station battery charger Train B contactor emergency close switch installed.
5. 2B42-4212B D-109 swing station battery charger Train B contactor emergency close switch installed.
6. 2B52-39C tie to 2B00-45C on 2B-01 bus reduced voltage trip testing performed.
7. 2B52-391 power to 2B42-391 D-09 swing station battery charger Train A contactor breaker replaced.
8. 2P-011B component cooling water pump bearings replaced, inboard and outboard mechanical seals replaced, oil changed, couplings greased and motor vents inspected.
9. 2W-001D1 containment accident recirculation fan vibration switch replaced.