

**ATTACHMENT I
OPERATING DATA REPORT**

DOCKET NO.	<u>50-285</u>
UNIT NAME	<u>Fort Calhoun Station</u>
DATE	<u>February 7, 2000</u>
COMPLETED BY	<u>G. R. Cavanaugh</u>
TELEPHONE	<u>(402) 533-6913</u>

REPORT PERIOD: January 1999

1. Design Electrical Rating (MWe-Net): 478
2. Maximum Dependable Capacity (MWe-Net): 478

OPERATING STATUS

	THIS MONTH	YR-TO-DATE	CUMULATIVE
3. Number of Hours Reactor was Critical:	744.0	744.0	184,677.2
4. Number of Hours Generator was On-line:	744.0	744.0	182,725.3
5. Unit Reserve Shutdown Hours:	0.0	0.0	0.0
6. Net Electrical Energy Generated (MWh):	365,428.0	365,428.0	78,150,781.4

ATTACHMENT II
UNIT SHUTDOWNS

REPORT MONTH January 2000

DOCKET NO. 50-285
 UNIT NAME Fort Calhoun Station
 DATE February 7, 2000
 COMPLETED BY G. R. Cavanaugh
 TELEPHONE (402) 533-6929

No.	Date	Type F: Forced S: Scheduled	Duration (Hours)	Reason ¹	Method of Shutting Down Reactor ²	Cause & Corrective Action to Prevent Recurrence
none						

(1)

Reason:

- A-Equipment Failure (Explain)
- B-Maintenance or Test
- C-Refueling
- D-Regulatory Restriction
- E-Operator Training/License Examination
- F-Administrative
- G-Operational Error (Explain)
- H-Other (Explain)

(2)

Method:

- 1-Manual
- 2-Manual Trip/Scram
- 3-Automatic Trip/Scram
- 4-Continuation
- 5-Other (Explain)

OPERATIONS SUMMARY

The Fort Calhoun Station (FCS) operated at a nominal 100% power level throughout the month of January with normal maintenance activities being performed. Fuel reliability problems continue to be a challenge. There were no unplanned power changes.

SAFETY VALVE OR PORV CHALLENGES/FAILURES

No failures or challenges to safety valves or PORV's occurred during this month.