

February 16, 2000

Mr. James Davis, Director
Operations Department
Nuclear Energy Institute
1776 I Street, N. W.
Suite 400
Washington, DC 20006-3708

Dear Mr. Davis:

This is to inform you of our decisions on changes to the Standard Technical Specification (STS) NUREGs proposed by the NEI Technical Specification Task Force (TSTF). Those travelers Approved are TSTFs -076, R.1, -204, R.3, -242, R.1, -284, R.3, -297, R.1, and -322, R.2. Those travelers Modified are TSTFs -207, R.3, -283, R.2, -287, R.4, -342, R.0, and -352, R.0. The traveler -333, R.1 is Rejected. Our comments on those travelers Modified or Rejected have been previously provided or are enclosed.

Please contact me at (301) 415-1161 or e-mail wdb@nrc.gov, if you have any questions or need further information.

Sincerely,

/RA/

William D. Beckner, Chief
Technical Specifications Branch
Division of Regulatory Improvement Programs
Office of Nuclear Reactor Regulation

Project No. 689
Enclosure: As stated

cc: N. Clarkson, BWOOG
H. Pontious, BWROG
T. Weber, CEOG
D. Buschbaum, WOG
D. Hoffman, EXCEL

February 16, 2000

Mr. James Davis, Director
Operations Department
Nuclear Energy Institute
1776 I Street, N. W.
Suite 400
Washington, DC 20006-3708

Dear Mr. Davis:

This is to inform you of our decisions on changes to the Standard Technical Specification (STS) NUREGs proposed by the NEI Technical Specification Task Force (TSTF). Those travelers Approved are TSTFs -076, R.1, -204, R.3, -242, R.1, -284, R.3, -297, R.1, and -322, R.2. Those travelers Modified are TSTFs -207, R.3, -283, R.2, -287, R.4, -342, R.0, and -352, R.0. The traveler -333, R.1 is Rejected. Our comments on those travelers Modified or Rejected have been previously provided or are enclosed.

Please contact me at (301) 415-1161 or e-mail wdb@nrc.gov, if you have any questions or need further information.

Sincerely,

/RA/

William D. Beckner, Chief
Technical Specifications Branch
Division of Regulatory Improvement Programs
Office of Nuclear Reactor Regulation

Project No. 689
Enclosure: As stated

cc: N. Clarkson, BWO
H. Pontious, BWROG
T. Weber, CEOG
D. Buschbaum, WOG
D. Hoffman, EXCEL

DISTRIBUTION:

FILE CENTER WDBeckner TSB Staff
PUBLIC RLDennig ADAMS
DBMatthews/SFNewberry

Document Name: G:\RTSB\JOHNSON\Owners Group Correspondence\0100DISemil.WPD

OFFICE	RTSB/DRIP/NRR	SC:RTSB/DRIP/NRR	C:RTSB/DRIP/NRR
NAME	TRTjader TRT	RLDennig RLD	WDBeckner WDB
DATE	02/15/2000	02/16/2000	02/16/2000

OFFICIAL RECORD COPY

cc: Mr. Ralph Beedle
Senior Vice President
and Chief Nuclear Officer
Nuclear Energy Institute
Suite 400
1776 I Street, NW
Washington, DC 20006-3708

Ms. Lynnette Hendricks, Director
Plant Support
Nuclear Energy Institute
Suite 400
1776 I Street, NW
Washington, DC 20006-3708

Mr. Alex Marion, Director
Programs
Nuclear Energy Institute
Suite 400
1776 I Street, NW
Washington, DC 20006-3708

Mr. Charles B. Brinkman, Director
Washington Operations
ABB-Combustion Engineering, Inc.
12300 Twinbrook Parkway, Suite 330
Rockville, Maryland 20852

Mr. David Modeen, Director
Engineering
Nuclear Energy Institute
Suite 400
1776 I Street, NW
Washington, DC 20006-3708

Mr. Anthony Pietrangelo, Director
Licensing
Nuclear Energy Institute
Suite 400
1776 I Street, NW
Washington, DC 20006-3708

Mr. Hank Sepp, Manager
Regulatory and Licensing Engineering
Westinghouse Electric Corporation
P.O. Box 355
Pittsburgh, Pennsylvania 15230

Mr. Jim Davis, Director
Operations
Nuclear Energy Institute
Suite 400
1776 I Street, NW
Washington, DC 20006-3708

DISPOSITION SUMMARY

TSTF-352, R.0: Modify

1. The proposed changes to STS 3.4.9 (For BWOG) and STS 3.4.10 (For BWOG, WOG & CEOG) regarding pressurizer water level and pressurizer safety valves are acceptable. The bases of our acceptance is that in Mode 3, a heatup transient (ie, loss of main feedwater or feed water line break,etc) would lead to miner effects on RCS pressurization. Therefore, the proposed change of completion time in the required action B.2 from 12 hours to (24) hours for going to Mode 4 would not cause significant safety concern.
2. The proposed changes to STS 3.7.4 and STS 3.7.6 (For BWOG, WOG & CEOG) regarding Atmospheric Dump Valves and Condensate Storage Tank are acceptable. The bases of our acceptance is that if there is sufficient safety grade condensate storage capacity to support the decay heat removal during Mode 3 operation, there is no safety impact due the change of completion time in the required action C.2 (STS 3.7.4) and B.2 (STS 3.7.6) from (18) hours or (12)hours to (24) hours for going to Mode 4.
3. The proposed changes to STS 3.4.12 (For BWOG, WOG & CEOG) regarding LTOP require additional information for the staff review. Current STS 3.4.12 require depressurization of RCS and establish RCS vent within 8 hours (For WOG & CEOG) or 12 hours (For BWOG) when both LTOP trains become inoperable. TSTF-352 propose to change this completion time to (24) hours. This proposed change would increase the risk of reactor vessel integrity. Additional justification is needed per the requirements of R.G. 1.177 and SRP 16.1. The required additional information will be reviewed by the combined effort from SPSB and SRXB.