



GPU Nuclear, Inc.
U.S. Route #9 South
Post Office Box 388
Forked River, NJ 08731-0388
Tel 609-971-4000

February 4, 2000
1940-00-20034

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Dear Sir:

SUBJECT: Oyster Creek Nuclear Generating Station
Docket No. 50-219
Monthly Operating Report - January 2000

Enclosed are two copies of the January 2000, Monthly Operating Report for Oyster Creek Nuclear Station. The content and format of information submitted in this report is in accordance with the guidance provided by Generic Letter 97-02.

If you should have any questions, please contact Ms. Brenda DeMerchant, Oyster Creek Regulatory Affairs Engineer, at 609-971-4642.

Very truly yours,

A handwritten signature in black ink, appearing to read "Sander Levin". The signature is fluid and cursive, with a large initial "S" and a long, sweeping underline.

Sander Levin
Acting Site Director

BDeM/gl

Enclosures

cc: Administrator, Region I (2 copies)
NRC Project Manager
NRC Sr. Resident Inspector

JE24

APPENDIX A
Operating Data Report

Docket No: 50-219
 Date: 02/01/00
 Completed By: David M. Egan
 Telephone: (609)971- 4818

Reporting Period: January 2000

		MONTH	YEAR TO DATE	CUMULATIVE
1.	DESIGN ELECTRICAL RATING (MWe NET). The nominal net electrical output of the unit specified by the utility and used for the purpose of plant design.	650	*	*
2.	MAXIMUM DEPENDABLE CAPACITY (MWe NET). The gross electrical output as measured at the output terminals of the turbine generator during the most restrictive seasonal conditions minus the normal station service loads.	619	*	*
3.	NUMBER OF HOURS REACTOR WAS CRITICAL. The total number of hours during the gross hours of the reporting period that the reactor was critical.	490.8	490.8	186,310.8
4.	HOURS GENERATOR ON LINE. (Service Hours) The total number of hours during the gross hours of the reporting period that the unit operated with the breakers closed to the station bus. The sum of the hours that the generator was on line plus the total outage hours in the reporting period.	490.8	490.8	182,428.8
5.	UNIT RESERVE SHUTDOWN HOURS. The total number of hours during the gross hours of the reporting period that the unit was removed from service for economic or similar reasons but was available for operation.	0	0	918.2
6.	NET ELECTRICAL ENERGY (MWH). The gross electrical output of the unit measured at the output terminals of the turbine generator minus the normal station service loads during the gross hours of the reporting period, expressed in megawatt hours. Negative quantities should not be used.	306,599	306,599	103,279,190

* Design values have no "Year to Date" or "Cumulative" significance.

Appendix B

Unit Shutdowns

Docket No: 50-219
 Date: 02/01/00
 Completed By: David M. Egan
 Telephone: (609)971- 4818

Reporting Period: January 2000

No.	Date	Type*	Duration (Hours)	Reason ¹	Method of Shutting Down Reactor ²	Cause & Corrective Action to Prevent Recurrence
1	000121	F	253.2	G	2	On January 21, 2000 at 1049, operators manually scrammed the reactor when the reactor recirculation pumps shutdown during an isolation condensers auto actuation test. A set of switches was not reset during the surveillance before testing of a second set.

*
 F Forced
 S Scheduled

¹
Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & Licensing Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

²
Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Other (Explain)

Summary: During January, Oyster Creek generated 306,599 net MWH electric, which was 66.6% of its MDC rating.