



State of New Jersey

Christine Todd Whitman
Governor

Department of Environmental Protection

Robert C. Shinn, Jr.
Commissioner

Division of Environmental Safety, Health,
Analytical Programs
Radiation Protection Programs
Bureau of Nuclear Engineering
PO Box 415
Trenton, NJ 08625-0415

February 02, 2000

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

To Whom It May Concern:

Subject: Salem Generating Station Units - 1 and 2
Docket No. 50-272/50-311
Amendment to Facility Operating License
License Change Request S99-11

The subject request was submitted to the NRC by PSE&G letter dated December 29, 1999. The request proposes to modify the Technical Specification Table 2.2-1 Reactor Trip System Instrumentation Set points, to add a 10% tolerance band for the Over Power and Over Temperature delta temperature units, derivative module time constants (TAU values).

The New Jersey Department of Environmental Protection's Bureau of Nuclear Engineering has reviewed the request in accordance with the requirements of 10 CFR 50.91 (b) and finds these proposed tolerances reasonable.

If you have any questions, please contact Rich Pinney at (609) 984-7558.

Sincerely,

Kent W. Tosch, Manager
Bureau of Nuclear Engineering

A001

c: Distribution

Jill Lipoti
N.J. DEP

D. Zannoni
N.J. DEP

R. Bores
NRC Region I State Liaison Officer

S. Morris
NRC Sr. Resident Inspector

W. Gleaves
NRC Sr. Project Manager

G. Saloman
PSE&G