

A. Alan Blind
Vice President

Consolidated Edison Company of New York, Inc.
Indian Point Station
Broadway & Bleakley Avenue
Buchanan, NY 10511
Telephone (914) 734-5340
Fax: (914) 734-5718
blinda@coned.com

February 15, 2000

Re: Indian Point Unit No. 2
Docket No. 50-247

Document Control Desk
US Nuclear Regulatory Commission
Mail Station P1-137
Washington, DC 20555

Dear Sir:

Enclosed is the Monthly Operating Report for Indian Point Unit No. 2 for January 2000.

Very truly yours,

Robert E. Masse
for A. Blind

Enclosure

cc: Mr. Hubert J. Miller
Regional Administrator - Region I
US Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Senior Resident Inspector
US Nuclear Regulatory Commission
PO Box 38
Buchanan, NY 10511

Mr. Paul Eddy
State of New York Department of Public Service
3 Empire Plaza
Albany, NY 12223

IE24

OPERATING DATA REPORT

DOCKET NO. 50-247

DATE February 7, 2000

COMPLETED BY J. Barlok

TELEPHONE (914)734-5325

OPERATING STATUS

Notes

1. Unit Name : Indian Point Unit No. 2
2. Reporting Period : January 2000
3. Licensed Thermal Power (Mwt) : 3071.4
4. Nameplate Rating (Gross Mwe) : 1008
5. Design Electrical Rating (Net Mwe) : 986
6. Maximum Dependable Capacity (Gross Mwe) : 985
7. Maximum Dependable Capacity (Net Mwe) : 951
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7)
Since Last Report, Give Reasons :

-
9. Power Level To Which Restricted, If Any (Net Mwe) : _____
 10. Reasons For Restrictions, If Any : _____
-

	This Month	Yr.-to-Date	Cumulative
11. Hours in Reporting Period	<u>744</u>	<u>744</u>	<u>224305</u>
12. Number of Hours Reactor Was Critical	<u>744</u>	<u>744</u>	<u>157587.10</u>
13. Reactor Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>4566.64</u>
14. Hours Generator On-Line	<u>744</u>	<u>744</u>	<u>153854.85</u>
15. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
16. Gross Thermal Energy Generated (MWH)	<u>2256411</u>	<u>2256411</u>	<u>430825105</u>
17. Gross Electrical Energy Generated (MWH)	<u>746638</u>	<u>746638</u>	<u>133806077</u>
18. Net Electrical Energy Generated (MWH)	<u>720677</u>	<u>720677</u>	<u>128137605</u>
19. Unit Service Factor	<u>100.0</u>	<u>100.0</u>	<u>68.6</u>
20. Unit Availability Factor	<u>100.0</u>	<u>100.0</u>	<u>68.6</u>
21. Unit Capacity Factor (Using MDC Net)	<u>101.9</u>	<u>101.9</u>	<u>64.3</u>
22. Unit Capacity Factor (Using DER Net)	<u>98.2</u>	<u>98.2</u>	<u>62.3</u>
23. Unit Forced Outage Rate	<u>0</u>	<u>0</u>	<u>11.3</u>

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):
Refueling and maintenance outage scheduled for April 29, 2000 with a duration of approximately 38 days.
-

25. If Shut Down At End Of Report Period, Estimated Date of Startup : _____
26. Units In Test Status (Prior to Commercial Operation) :

	Forecast	Achieved
INITIAL CRITICALITY	<u>N/A</u>	<u>N/A</u>
INITIAL ELECTRICITY	<u>N/A</u>	<u>N/A</u>
COMMERCIAL OPERATION	<u>N/A</u>	<u>N/A</u>

AVERAGE DAILY POWER LEVEL

DOCKET NO. 50-247
 UNIT I.P. Unit #2
 DATE February 7, 2000
 COMPLETED BY J. Barlok
 TELEPHONE (914)734-5325

MONTH January 2000

DAY	AVERAGE DAILY POWER LEVEL (Mwe-Net)	DAY	AVERAGE DAILY POWER LEVEL (Mwe-Net)
1	<u>969</u>	17	<u>969</u>
2	<u>970</u>	18	<u>968</u>
3	<u>969</u>	19	<u>968</u>
4	<u>969</u>	20	<u>968</u>
5	<u>969</u>	21	<u>967</u>
6	<u>969</u>	22	<u>968</u>
7	<u>969</u>	23	<u>967</u>
8	<u>969</u>	24	<u>970</u>
9	<u>969</u>	25	<u>969</u>
10	<u>970</u>	26	<u>969</u>
11	<u>968</u>	27	<u>968</u>
12	<u>968</u>	28	<u>972</u>
13	<u>969</u>	29	<u>966</u>
14	<u>969</u>	30	<u>970</u>
15	<u>969</u>	31	<u>968</u>
16	<u>968</u>		

INSTRUCTIONS

On this format, list the average daily unit power level in Mwe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

DOCKET NO. 50-247
 UNIT I.P. Unit #2
 DATE February 7, 2000
 COMPLETED BY J. Barlok
 TELEPHONE (914)734-5325

REPORT MONTH January 2000

No.	Date	Type(1)	Duration (Hours)	Reason(2)	Method of Shutting Down Reactor	Licensee Event Report #	System Code (4)	Component Code (5)	Cause & Corrective Action to Prevent Recurrence
None									

(1)
 F: Forced
 S: Scheduled

(2)
 Reason :
 A: Equipment Failure (Explain)
 B: Maintenance or Test
 C: Refueling
 D: Regulatory Restriction
 E: Operator Training & License Examination
 F: Administrative
 G: Operational Error (Explain)
 H: Other (Explain)

(3)
 Method:
 1-Manual
 2- Manual Scram.
 3-Automatic Scram.
 4-Other Explain

(4)
 Exhibit G-Instructions for Preparation of
 Data Entry Sheets for Licensee Event
 Report (LER) File (NUREG-0161)

(5)
 Exhibit I - Same Source

(9/77)

SUMMARY OF OPERATING EXPERIENCE

January 2000

Indian Point Unit No. 2 operated at full power during the entire month of January

MAJOR SAFETY RELATED MAINTENANCE

W.O. #	SYSTEM	COMPONENT	DATE COMPLETED	WORK PERFORMED
00-13855	EB	Bus 5A Compt 19 Fuse Block	1/28/2000	Performed trouble shooting to determine cause of trip circuit failure. Replaced existing fuse block with new block, performed testing satisfactorily.