



South Texas Project Electric Generating Station P.O. Box 289 Wadsworth, Texas 77483

February 21, 2000  
NOC-AE-000745  
File No.: G03.08  
10CFR50

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, DC 20555-0001

South Texas Project  
Units 1 and 2  
Docket Nos. STN 50-498, STN 50-499  
Response to Request for Additional Information: Generic Letter 96-06

- References:
- 1) Request for Additional Information, Thomas W. Alexion, Nuclear Regulatory Commission, to William T. Cottle, STP Nuclear Operating Company, dated December 20, 1999
  - 2) Response to Request for Additional Information, S. E. Thomas, South Texas Project, to NRC Document Control Desk, dated November 11, 1997 (ST-HL-AE-5780)

Pursuant to the Nuclear Regulatory Commission request for additional information (reference 1), the South Texas Project submits the attached report, "Containment Air Cooler Heat Transfer During Loss of Coolant Accident with Loss of Offsite Power Conditions," November 1996, prepared by Numerical Applications, Inc. The report was referenced in the response to Generic Letter 96-06, "Assurance of Equipment Operability and Containment Integrity During Design-Basis Accident Conditions" (reference 2).

Pursuant to a telephone conversation with Nuclear Regulatory Commission staff conducted June 24, 1999, the South Texas Project submits the following responses to questions regarding the status of calculations performed to determine the potential for piping overpressurization. The calculations were previously discussed in reference 2.

- *As stated in Attachment 1 of the November 11, 1997, submittal, additional calculations are expected to be performed to determine if a design basis accident will result in pressures less than the actual benchset pressure. What is the status of the calculations?*

The calculations for the impact of a design basis accident on piping pressure have been completed and the resulting stresses are within the ASME Code allowable limits for a faulted condition based on Appendix I of ASME Section III, 1974 Edition. Consequently, there is no need to take credit for the air-operated valves for overpressure protection.

A072

The final pipe pressurization design calculation applies to both the current steam generators and the planned replacement steam generators.

- *As stated in Attachment 2 of the November 11, 1997, submittal, listed pressure values were generated using a preliminary version of the code developed to perform the pipe pressurization analyses. These results and the results of the benchmarking study were reviewed and found acceptable by the South Texas Project. The peak pressures were not expected to change; however, the code had not yet been verified, so changes were possible. What is the status of the code verification and the calculated pressure values?*

A revised version of the code has been verified in accordance with station procedures. There were changes in peak pressures calculated using the verified code; however, the resulting stresses remain less than the ASME Code allowable limits for a faulted condition based on Appendix I of ASME Section III, 1974 Edition .

If there are any questions, please contact either Mr. P. L. Walker at (361) 972-8392 or me at (361) 972-7795.



D. A. Leazar  
Manager,  
Nuclear Fuel & Analysis

PLW

Attachment: Containment Air Cooler Heat Transfer During Loss of Coolant Accident with Loss of Offsite Power Conditions, November 1996, prepared by Numerical Applications, Inc.

cc:

Ellis W. Merschhoff  
Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 400  
Arlington, Texas 76011-8064

John A. Nakoski  
Project Manager, Mail Code 0-4D3  
U. S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Cornelius F. O'Keefe  
c/o U. S. Nuclear Regulatory Commission  
P. O. Box 910  
Bay City, TX 77404-0910

A. H. Gutterman  
Morgan, Lewis & Bockius  
1800 M. Street, N.W.  
Washington, DC 20036-5869

M. T. Hardt/W. C. Gunst  
City Public Service  
P. O. Box 1771  
San Antonio, TX 78296

A. Ramirez/C. M. Canady  
City of Austin  
Electric Utility Department  
721 Barton Springs Road  
Austin, TX 78704

Jon C. Wood  
Matthews & Branscomb  
One Alamo Center  
106 S. St. Mary's Street, Suite 700  
San Antonio, TX 78205-3692

Institute of Nuclear Power  
Operations - Records Center  
700 Galleria Parkway  
Atlanta, GA 30339-5957

Richard A. Ratliff  
Bureau of Radiation Control  
Texas Department of Health  
1100 West 49th Street  
Austin, TX 78756-3189

D. G. Tees/R. L. Balcom  
Houston Lighting & Power Co.  
P. O. Box 1700  
Houston, TX 77251

Central Power and Light Company  
ATTN: G. E. Vaughn/C. A. Johnson  
P. O. Box 289, Mail Code: N5012  
Wadsworth, TX 77483

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D.C. 20555-0001