

BOUNDARY DIAGRAM NO.: 1P41-B01-04
 FUNCTION(S) NO.: 1P41-01
 PREPARED BY: BO ROSBERG
 DATE: 1/12/98
 REVIEWED BY: ALEX MORRISON
 DATE: 2/12/98

BOUNDARY DIAGRAM NO.: 1E11-B01-08
 FUNCTION(S) NO.: 1E11-01
 PREPARED BY: WILLIE JENNINGS
 DATE: 2/2/98
 REVIEWED BY: WILLIAM P EVANS
 DATE: 4/30/98

NOTES:
 1. ONLY ONE STRAINER NEED BE IN SERVICE PER LOOP. POSITION INLET/OUTLET VALVES ACCORDINGLY. LOCK VALVES AFTER POSITIONING.
 2. ALL MPL NUMBERS ON THIS DRAWING ARE PRECEDED BY E11 UNLESS OTHERWISE NOTED.
 3. NV-601 VALVES MAY BE USED TO REPLACE GV-229 VALVES FOR VALVES 1E11-F906A-D, 1E11-F907A-D, 1E11-F908A-D AND 1E11-F909A-D.

BOUNDARY DIAGRAM NO.: 1L36-B01-03
 FUNCTION(S) NO.: 1L36-02
 PREPARED BY: M D STEPHENS
 DATE: 3/2/99
 REVIEWED BY: WILLIE JENNINGS
 DATE: 3/3/99

LICENSE RENEWAL DOCUMENT

MPL NO. E11 ACAD14 DL11004



LICENSE RENEWAL SCREENING FOR INFORMATION ONLY

EDWIN I. HATCH NUCLEAR PLANT UNIT No. 1
 P & I D. - R.H.R. SERVICE WATER
 OUTSIDE BUILDING

Revision: A Date: 12-29-99
 APPROVED. ISSUED PER LICENSE RENEWAL BOUNDARY PACKAGES. DRAWING CREATED FROM D-11004, REV.32; BY TRM.

BY	CHKD	APPR.1
TRM	RLM	ASK

DRAWN	DESIGNED	LOCATION	DOCUMENT NUMBER	REVISION
TRM	LCF			
DATE	SCALE	10-502	DL-11004	0
	None			

