


- LEGEND:**
- EA - 1 135° NOZZLE WITH BAFFLE
 - PRESSURE RELIEF VALVE
 - INSTRUMENT TEST CONNECTION
 - PRESSURE REGULATOR
 - PRESSURE SWITCH
 - RESTRICTIVE ORIFICE
 - BALL DRIP VALVE
 - BALL VALVE (LOCK CLOSE)
 - BALL VALVE (LOCK OPEN)
 - EA - 1 135° NOZZLE
 - PRESSURE INDICATOR
 - MONITOR SWITCH
 - MULTIMATIC VALVE (PREACTION)
 - GATE VALVE (LOCK OPEN)
 - GLOBE VALVE (NC)
 - ANGLE VALVE (NC)
 - CHECK VALVE
 - BREAK GLASS STATION
 - STRAINER
 - FLOW DIRECTION
 - UNION
 - PLUG
 - ADDRESSABLE INTERFACE MODULE
 - INDICATING LIGHT
 - 2 WAY SOLENOID VALVE
 - GLOBE VALVE (NO)
 - SIDE OUTLET GLOBE VALVE
 - CAP

NOTES:
 1. ALL MPL NUMBERS ARE PRECEDED BY 2T43 UNLESS NOTED OTHERWISE.

- REFERENCES:**
- B-24620 FIRE PROTECTION FCD - SYSTEM NO. 2T43164W01
 - H-21017 REACTOR & RADWASTE BUILDINGS - FIRE PROTECTION SYSTEM P&ID
 - H-21179 REACTOR BUILDING - FIRE PROTECTION SYSTEM - SECTIONS
 - S-50080 FIRE PROTECTION SPRAY/SPR. SYSTEM - HVAC RM. UNIT 2 HANGER PLAN ABOVE EL. 164'-0"
 - S-50081 FIRE PROTECTION SPRAY/SPR. SYSTEM - ISOMETRICS - HVAC ROOM UNIT 2
 - S-50266 T. P. SPRAY/SPR. SYSTEM - FDMN & CRSMN HANGERS & 8" SUPPLY HANGERS - HVAC UNIT 2
 - SX-14522 INSTRUMENTS - FIRE PROTECTION SPRINKLER SYSTEMS

BOUNDARY DIAGRAM NO.: 2X43-B01-20
FUNCTION(S) NO.: 2X46-04, 2X43-06
 PREPARED BY: M. D. Stephens
 DATE: 02/06/98
 REVIEWED BY: Alex Morrison
 DATE: 07/13/98

BOUNDARY DIAGRAM NO.: 2X43-B06-02
FUNCTION(S) NO.: 2X43-06
 PREPARED BY: M. D. Stephens
 DATE: 03/19/98
 REVIEWED BY: Alex Morrison
 DATE: 07/15/98



SYSTEM NO. 2T43164W01
 CHILLER ROOM
 FLOOR EL. 164'-0"

LICENSE RENEWAL DOCUMENT

MPL NO. 2T43 ACAD14 HL1132601

SOUTHERN COMPANY

LICENSE RENEWAL SCREENING FOR INFORMATION ONLY

EDWIN I. HATCH NUCLEAR PLANT UNIT No.2
 FIRE PROTECTION - PIPING- P&ID
 HVAC ROOM

Revision: A Date: 10-20-99
 APPROVED, ISSUED PER LICENSE RENEWAL BOUNDARY PACKAGES. DRAWING CREATED FROM H-113261, REV 8; BY BKN.

BY	CHK'D	APPR'L	DATE	SCALE	LOCATION	DOCUMENT NUMBER	REVISION
BKN	MDS	ASK		None	10-502	HL-11326	A