

### TRANSMITTAL OF MEETING HANDOUT MATERIALS FOR IMMEDIATE PLACEMENT IN THE PUBLIC DOMAIN

*This form is to be filled out (typed or hand-printed) by the person who announced the meeting (i.e., the person who issued the meeting notice). The completed form, and the attached copy of meeting handout materials, will be sent to the Document Control Desk on the same day of the meeting; under no circumstances will this be done later than the working day after the meeting. Do not include proprietary materials.*

DATE OF MEETING

03/02/2000

The attached document(s), which was/were handed out in this meeting, is/are to be placed in the public domain as soon as possible. The minutes of the meeting will be issued in the near future. Following are administrative details regarding this meeting:

Docket Number(s)	<u>50-321 AND 50-366</u>
Plant/Facility Name	<u>EDWIN I. HATCH NUCLEAR PLANT, UNITS 1 &amp; 2</u>
TAC Number(s) (if available)	_____
Reference Meeting Notice	<u>FEBRUARY 2, 2000</u>
Purpose of Meeting (copy from meeting notice)	<u>TO DISCUSS NRC'S CLASSIFICATION OF THE JUNE</u> <u>1999 HATCH 2 REACTOR TRIP WITH SUBSEQUENT</u> <u>EQUIPMENT FAILURES</u>

NAME OF PERSON WHO ISSUED MEETING NOTICE

**L. N. OLSHAN**

TITLE

**PROJECT MANAGER**

OFFICE

**NRR**

DIVISION

**DLPM**

BRANCH

**PD II-1**

Distribution of this form and attachments:

Docket File/Central File  
PUBLIC

*DF03*



June 15, 1999  
Loss of Condenser Vacuum on  
Hatch Unit 2



March 2, 2000

---

---

**██████████** *NRC/SNC Meeting*

**June 15, 1999 Loss of Condenser Vacuum on  
Hatch Unit 2**

Introduction	All
Event Description	Lewis Sumner
Risk Significance of Event	Anees Farruk
Questions/Summary	All



## *Purpose of Visit*

- Review Unit 2 Loss of Vacuum Event of June 15, 1999
- Review Event Risk Significance
- Summarize Event



# *Review of Event*

June 3, 1999

- Lowered flume level for chlorination activities at or below flume level, resulting in consequential quantities of air.

June 15, 1999

- 2010 - Shift observed decrease in condenser vacuum & reduced power to ~ 65%.
  - 2025 - Improving condenser vacuum trend was observed and power reduction stopped at 42% by 2045.
  - 2108 - Turbine low vacuum annunciator alarmed with power reduction stopped at 29%.
  - 2124 - Manual scram inserted, 4-kV buses "C" & "D" failed to auto transfer, & operators entered the appropriate procedures to respond to reactor scram.
- 
- 
-

# *Review of Event*

June 15, 1999

- 2125 - Manually initiated RCIC to control RPV water level consistent with plant procedures.
  - 2138 - 4-kV "C" bus re-energized.
  - 2139 - 4-kV "D" bus re-energized.
  - 2154 - "A" recirculation pump restarted.
  - 2200 - Attempted to restart "B" recirculation pump & received ground on Unit 1 "D" 600-V bus and other 600-V switchgear.
  - 2221 - Operators closed outboard MSIVs due to potential for water flashing to steam in condenser.
  - 2225 - Operators directed to break condenser vacuum.
  - 2250 - Torus cooling established with "A" loop RHR/RHRSW.
  - 2308 - Torus cooling supplemented with "B" loop RHR/RHRSW.
- 
- 
-

# *Review of Event*

June 16, 1999

- 0023 - HPCI started for pressure control.
- 0150 - Reactor building leak detection sump alarm received, & leakage from RHRSW vent line identified.
- 0155 - Operators elected to remove "A" RHRSW loop from service (loop remained operable and available).
- 0430 - Proceeding to cold shutdown.
- 1031 - "A" loop of RHR/RHRSW restored to operable status.



# *Review of Event Risk Significance*

- Nuclear safety was maintained during event.
- Not all equipment worked as expected.
- Operations personnel correctly identified & quickly responded to equipment issues.
- Existing plant procedures already had provisions for response to equipment issues.
- Operators executed plant procedures as trained.
- Operating crew managed the event from initiation to cold shutdown.





## *Summary*

- Developed several lessons learned.
- Made several changes as the result of event:
  - Plant configuration
  - Training
  - Operating procedures
- Concluded the event did not pose an actual or potential risk to the health and safety of the public.





# *Hatch Unit 2*

## *Loss of Condenser Vacuum*

### *Risk Significance Analysis*

Anees Farruk

PRA Supervisor

*Southern Nuclear Operating Company*



# *Risk Analysis Event Scenario*

- Event Scenario:

- Manual Reactor Scram Due to Loss of Condenser Vacuum (LOCV)
  - Failure of Auto Transfer Busses 4160V 2C & 2D
  - Recovery of Busses 4160V 2C & 2D
  - Availability of Secured RHRSW Loop A
  - Failure of 600 V Bus 1D
  - Failure of Steam Line B Inboard MSIV to Close
- 
-

# ***Risk Analysis Assumptions***

- **Failed Equipment: Failure Event Set as 'TRUE'**
  - **Recovery of Failed or Secured Equipment: Used a Random Non-recovery Probability**
  - **Successful Equipment: Used a Random Failure Probability**
  - **Occurrence of Initiator: Initiator Set as 'TRUE' or Used an Average Annual Frequency Appropriate for the Risk Measure Calculated**
  - **Cumulative Equipment Degradation Duration: 25 Days (5/22 - 6/2 and 6/3-6/15/99)**
  - **PRA Model: Used the Post-IPE Hatch U2 Average Core Damage Frequency Model**
- 
-

# **Risk Analysis Approach**

- **Perform Risk Significance Evaluation of the Initiator and Degraded Condition, and Compare Results to Various Numerical Criteria Published by the NRC Noted Below:**
  - **The Following Criteria Published in Draft NRC Management Directive 8.3, “NRC Incident Investigation Procedure”, Part I Was Used for Comparing Results of Risk Analysis:**
    - *Conditional Core Damage Probability (CCDP)*
    - *Delta Instantaneous Core Damage Frequency ( $\Delta$ ICDF)*
  - **New NRC Oversight Process Performance Indicator for Mitigating Systems:**
    - *Delta Core Damage Frequency ( $\Delta$ CDF)*
  - **NRC Significance Determination Process Matrix**
- 
-

# **██████ Numerical Criteria: Equations**

- **Conditional Core Damage Probability:**

$$\text{CCDP} = \text{Average Annual CDF From LOCV} \mid_{\text{LOCV} = 1}$$

- **Delta Instantaneous Core Damage Frequency:**

$$\begin{aligned} \Delta\text{ICDF} = & \text{Average Annual CDF From All Initiators} \mid_{\text{DEGRADED}} \\ & \text{CONDITION} \\ & - \text{Average Annual CDF From All Initiators} \mid_{\text{BASE CASE}} \end{aligned}$$

- **Delta Core Damage Frequency:**

$$\Delta\text{CDF} = \sum_{I=1}^{I=N} \Delta\text{ICDF}_I * (\text{Degraded Condition Duration})_I$$

Where N=Number of Discrete (Non-Overlapping) Degradation Condition Periods



# **██████** *PRA Results - Dominant Core Damage Sequence*

- Transient with Stuck Open SRV or Inadvertent Opening of SRV
  - Loss of Power Conversion System
  - Loss of High Pressure Coolant Injection
  - Loss of Primary System  
Depressurization
- 
-

## **██████ PRA Results - CCDP**

- This Risk Measure Provides an Estimate of Risk Significance of the Loss of Defense-in-depth Caused Subsequent to the Occurrence an Initiating Event
  - Conditional Core Damage Probability Assumes Occurrence of LOCV Initiating Event and Initial Unavailability of Failed Equipment
  - CCDP Value for the Scenario Was Calculated As ***7.5E-06***
  - As Shown in Figure 1, the Hatch U2 LOCV Event Is Classified As ***a Non-risk Significant Event***
- 
-



# PRA Results - CCDP




Figure 1

# **PRA Results - $\Delta$ ICDF**

- ***Instantaneous Core Damage Frequency (ICDF) Measure Provides an Estimate of the Core Damage Risk Assuming All Initiating Events Are Likely to Occur at a Random Frequency and the Failed Equipment Is Initially Unavailable when Demanded During an Entire Year***
  - ***Delta Instantaneous Core Damage Frequency ( $\Delta$ ICDF) Measure Provides an Estimate of the Incremental Core Damage Risk Increase Assuming All Initiating Events Are Likely to Occur at a Random Frequency and the Failed Equipment Is Initially Unavailable when Demanded During an Entire Year***
  - **ICDF Bounding Value Was Calculated As 6.42E-05/Year ( Base Case CDF = 1.65E-5/Year)**
  - **$\Delta$ ICDF Bounding Value Was Calculated As 4.77E-05/Year**
  - **As Shown in Figure 2, the Hatch U2 LOCV Event Is Classified As a Non-risk Significant Event**
- 
-



# PRA Results - $\Delta$ ICDF




Figure 2




# **PRA Results - Delta CDF**

- ***Delta Core Damage Frequency ( $\Delta CDF$ ) Measure Provides an Estimate of the Incremental Core Damage Risk Increase Assuming All Initiating Events Are Likely to Occur at a Random Frequency and the Failed Equipment Is Initially Unavailable During the Degradation Periods***
  - ***$\Delta CDF$  Value Was Calculated As  $3.08E-06$***
  - ***$\Delta LERF$  Value Was Calculated As  $5.08E-08$***
  - ***As Shown in Figure 3 the Hatch U2 LOCV Event Is Classified Under a Plant Performance Considered Acceptable (White Region)***
- 
-

# **PRA Results: $\Delta$ CDF**

Total Incremental CDF  
Attributable to Equipment  
Degradation ( $\Delta$ CDF)



# PRA Results - $\Delta$ CDF




Figure 3

# ***PRA Results - SDP Evaluation***

- **This Risk Measure Provides a Estimate of the Incremental Risk Increase in Terms of Numerical Values Considered As Surrogate to  $\Delta$ CDF Assuming All Initiating Events Are Likely to Occur at a Random Frequency and the Failed Equipment Is Initially Unavailable when Demanded During the Degradation Periods**
  - **Revised Hatch SDP Sheets Reflecting Post-IPE Model Changes Were Used for the Risk Analysis**
  - **Bounding SDP Sheet Evaluation: As Shown in Figure 4 the Hatch U2 LOCV Event + Degraded Condition Is Classified Under a Plant Performance Condition Considered Acceptable (White Region)**
- 
-

# **██████** PRA Results - SDP Evaluation

		Remaining Mitigating Capability Rating						
IE Likelihood		6	5	4	3	2	1	0
A					██████	██████	██████	██████
B				★		██████	██████	██████
C				↑			██████	██████
D								██████
E								
F								
G								
H								

Hatch U2 LOCV  
Performance  
Condition

Figure 4



# **Risk Significance Analysis**

## **Conclusions**

- **CCDP Risk Measure:** As Shown in Figure 1, the Hatch U2 LOCV Event Is Classified As a *Non-risk Significant Event*
  - **ICDF Risk Measure:** As Shown in Figure 2, the Hatch U2 LOCV Event Is Classified As a *Non-risk Significant Condition*
  - **New PI Measure:** As Shown in Figure 3 the Hatch U2 LOCV Event Is Classified Under a Plant Performance Condition Considered *Acceptable (White Region)*
  - **Bounding SDP Sheet Evaluation:** As Shown in Figure 4 the Hatch U2 LOCV Event Is Classified Under a Plant Performance Condition Considered *Acceptable (White Region)*
- 
-