



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

January 04, 2000

Mr. William A. Eaton  
Vice President, Operations GGNS  
Entergy Operations, Inc.  
P. O. Box 756  
Port Gibson, MS 39150

**SUBJECT: GRAND GULF NUCLEAR STATION, UNIT 1 - COMPLETION OF LICENSING ACTION FOR GENERIC LETTER 98-04, "POTENTIAL FOR DEGRADATION OF THE EMERGENCY CORE COOLING SYSTEM AND THE CONTAINMENT SPRAY SYSTEM AFTER A LOSS-OF-COOLANT ACCIDENT BECAUSE OF CONSTRUCTION AND PROTECTIVE COATING DEFICIENCIES AND FOREIGN MATERIAL IN CONTAINMENT" (TAC NO. MA4052)**

Dear Mr. Eaton:

On July 14, 1998, the U.S. Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 98-04 to all holders of operating licenses or construction permits. The NRC issued GL 98-04 to determine the status of containment coating programs.

In GL 98-04, the NRC staff specifically requested that the licensee provide information outlined below for each of their facilities.

- (1) A summary description of the plant-specific program or programs implemented to ensure that Service Level 1 protective coatings used inside the containment are procured, applied, and maintained in compliance with applicable regulatory requirements and the plant-specific licensing basis for the facility. Include a discussion of how the plant-specific program meets the applicable criteria of 10 CFR Part 50, Appendix B, as well as information regarding any applicable standards, plant-specific procedures or other guidance used for (a) controlling the procurement of coatings and paints used at the facility; (b) the qualification testing of protective coatings; and (c) surface preparation, application, surveillance, and maintenance activities for protective coatings. Maintenance activities refer to rework of degraded coatings, removing degraded coatings to sound coatings, correctly preparing the surfaces, applying new coating, and verifying the quality of coatings.
- (2) Information demonstrating compliance with item (i) or item (ii).
  - (i) For plants with licensing-basis requirements for tracking the amount of unqualified coatings inside the containment and for assessing the impact of potential coating debris on the operation of safety-related systems, structures, and components (SSCs) during a postulated design basis loss-of-coolant accident (DB LOCA), the following information shall be provided to demonstrate compliance:
    - (a) The date and findings of the last assessment of coatings and the planned date of the next assessment of coatings.

January 4, 2000

- (b) The limit for the amount of unqualified protective coatings allowed in the containment and how this limit is determined. Discuss any conservatism in the method used to determine this limit.
  - (c) If a commercial-grade dedication program is being used at your facility for dedicating commercial-grade coatings for Service Level 1 applications inside the containment, discuss how the program adequately qualifies a coating for Service Level 1. Identify what standards or other guidance are currently being used to dedicate containment coatings at your facility.
- (ii) For plants without the above licensing-basis requirements, information shall be provided to demonstrate compliance with the requirements of 10 CFR 50.46(b)(5), "Long-term cooling" and the functional capability of the safety-related containment spray system (CSS) as set forth in your licensing basis. If a licensee can demonstrate this compliance without quantifying the amount of unqualified coatings, this is acceptable. The following information shall be provided:
- (a) If commercial-grade coatings are being used at your facility for Service Level 1 applications, and such coatings are not dedicated or controlled under your Appendix B Quality Assurance Program, provide the regulatory and safety basis for not controlling these coatings in accordance with such a program. Additionally, explain why the facility's licensing basis does not require such a program.

In response to GL 98-04, you provided a letter dated November 11, 1998, for GGNS, Unit 1. This submittal provided the information requested by GL 98-04. Clarification was provided during a telephone call that took place on September 14, 1999. The staff has reviewed your response and has concluded that all requested information has been provided; therefore, we consider GL 98-04 to be closed for your facility. We thank you for your prompt and complete response.

Sincerely,

Original signed by  
 S. Patrick Sekerak, Project Manager, Section 1  
 Project Directorate IV & Decommissioning  
 Division of Licensing Project Management  
 Office of Nuclear Reactor Regulation

Docket No. 50-416

cc: See next page

DISTRIBUTION

File Center  
 PUBLIC  
 PDIV-1 Reading  
 OGC  
 ACRS

RECEIVED  
 DIVISION OF LICENSING PROJECT MANAGEMENT  
 JAN 10 1999

JTapia, RIV  
 RPulsifer  
 CLauron  
 JDavis

To receive a copy of this document, indicate "C" in the box						
OFFICE	PDIV-1/PM	<input checked="" type="checkbox"/>	PDIV-1/LA	EMCB/SC	PDIV-1/SC	<input checked="" type="checkbox"/>
NAME	P.Sekerak		D.Johnson	E.Sullivan	R.Gramm	
DATE	12/29/99		12/29/99	12/29/99	1/3/99	

DF01

DOCUMENT NAME: G:\PDIV-1\GrandGulf\LtrMA4052

OFFICIAL RECORD COPY

- (b) The limit for the amount of unqualified protective coatings allowed in the containment and how this limit is determined. Discuss any conservatism in the method used to determine this limit.
  - (c) If a commercial-grade dedication program is being used at your facility for dedicating commercial-grade coatings for Service Level 1 applications inside the containment, discuss how the program adequately qualifies a coating for Service Level 1. Identify what standards or other guidance are currently being used to dedicate containment coatings at your facility.
- (ii) For plants without the above licensing-basis requirements, information shall be provided to demonstrate compliance with the requirements of 10 CFR 50.46(b)(5), "Long-term cooling" and the functional capability of the safety-related containment spray system (CSS) as set forth in your licensing basis. If a licensee can demonstrate this compliance without quantifying the amount of unqualified coatings, this is acceptable. The following information shall be provided:
- (a) If commercial-grade coatings are being used at your facility for Service Level 1 applications, and such coatings are not dedicated or controlled under your Appendix B Quality Assurance Program, provide the regulatory and safety basis for not controlling these coatings in accordance with such a program. Additionally, explain why the facility's licensing basis does not require such a program.

In response to GL 98-04, you provided a letter dated November 11, 1998, for GGNS, Unit 1. This submittal provided the information requested by GL 98-04. Clarification was provided during a telephone call that took place on September 14, 1999. The staff has reviewed your response and has concluded that all requested information has been provided; therefore, we consider GL 98-04 to be closed for your facility. We thank you for your prompt and complete response.

Sincerely,



S. Patrick Sekerak, Project Manager, Section 1  
Project Directorate IV & Decommissioning  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-416

cc: See next page

Grand Gulf Nuclear Station

cc:

Executive Vice President  
& Chief Operating Officer  
Entergy Operations, Inc.  
P. O. Box 31995  
Jackson, MS 39286-1995

Wise, Carter, Child & Caraway  
P. O. Box 651  
Jackson, MS 39205

Winston & Strawn  
1400 L Street, N.W. - 12th Floor  
Washington, DC 20005-3502

Director  
Division of Solid Waste Management  
Mississippi Department of Natural  
Resources  
P. O. Box 10385  
Jackson, MS 39209

President  
Claiborne County Board of Supervisors  
P. O. Box 339  
Port Gibson, MS 39150

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 1000  
Arlington, TX 76011

Senior Resident Inspector  
U. S. Nuclear Regulatory Commission  
P. O. Box 399  
Port Gibson, MS 39150

General Manager, GGNS  
Entergy Operations, Inc.  
P. O. Box 756  
Port Gibson, MS 39150

Attorney General  
Department of Justice  
State of Louisiana  
P. O. Box 94005  
Baton Rouge, LA 70804-9005

State Health Officer  
State Board of Health  
P. O. Box 1700  
Jackson, MS 39205

Office of the Governor  
State of Mississippi  
Jackson, MS 39201

Attorney General  
Asst. Attorney General  
State of Mississippi  
P. O. Box 22947  
Jackson, MS 39225

Vice President, Operations Support  
Entergy Operations, Inc.  
P.O. Box 31995  
Jackson, MS 39286-1995

Director, Nuclear Safety  
and Regulatory Affairs  
Entergy Operations, Inc.  
P.O. Box 756  
Port Gibson, MS 39150