



NOTES:

1. UNLESS OTHERWISE NOTED, ALL MPL NUMBERS SHALL BE PREFIXED BY 2243.
2. UNIT 2 DEVICES SHOWN, FOR UNIT 1 DEVICES SEE DWG. H-11881 SH. 1 & 2.
3. SOLENOID VALVE F091A ACTUATED BY PROGRAMED DRY RELAY CONTACT IN SLAVE PANEL C.
4. FOR GENERAL NOTES AND LEGEND SEE DWG. H-11866.
5. FOR CABLE SPREAD ROOM LINEAR THERMAL DETECTION (ALISON) LAYOUT SEE H-11884 SH.2.
6. FOR HOSE STATION AND EXTINGUISHER LOCATIONS, SEE FHA DWG. H-11816.

REFERENCES:

- A-11907 SH.1 FIRE PROTECTION - LINEAR SENSOR MOUNTING BRACKET FOR CABLE TRAYS
- A-11907 SH.2 FIRE PROTECTION - LINEAR SENSOR MOUNTING BRACKET FOR CEILING
- A-11907 SH.3 FIRE PROTECTION - DETAIL FOR CEILING MOUNTING
- H-11929..... FIRE PROTECTION P&ID
- H-11816..... FIRE HAZARDS ANALYSIS.
- H-12630..... ARCH. TURB. & CONTROL BLDG. GENERAL PLAN EL. 147'-0"
- H-41106..... EQUIPMENT LAYOUT DRAWING, FIRE BRIGADE EQUIPMENT ROOM, EL. 147'-0", FIRE PROTECTION MULTIPLEX SYSTEM

BOUNDARY DIAGRAM NO.: 2X43-B06-22
 FUNCTION(S) NO.: 2X43-06
 PREPARED BY: M. D. STEPHENS
 DATE: 03-19-98
 REVIEWED BY: ALEX MORRISON
 DATE: 07-15-98

LICENSE RENEWAL DOCUMENT

ACAD14 HL11917

SOUTHERN COMPANY

LICENSE RENEWAL SCREENING FOR INFORMATION ONLY

EDWIN I. HATCH NUCLEAR PLANT UNIT No.2
 EQUIPMENT LAYOUT DRAWINGS.
 FIRE DETECTION/SUPPRESSION MULTIPLEX
 SYS. 2243 CONTROL BLDG. EL. 147'-0"

DESIGNED	ECB	DATE	1/8"=1'-0"
CHECKED	MDS	DATE	
APPROVED	ASK	DATE	

NO.	DATE	REVISION
10-502	HL-11917	A

Revision: A Date: 12-22-99
 APPROVED, ISSUED PER LICENSE RENEWAL BOUNDARY PACKAGES. DRAWING CREATED FROM H-11917, REV. 1; BY ECB