



- NOTES:**
1. ALL SUPPLY CONNECTIONS EXCEPT FOR THE HPCI AND ROIC SYSTEM, ON THE CONDENSATE STORAGE TANK MUST CONNECT TO A STANDPIPE THAT MAINTAINS A RESERVE IN THE TANK OF 100,000 GALLONS, AT MINIMUM.
 2. ALL RETURN CONNECTIONS ON THE CONDENSATE STORAGE TANK MUST CONNECT ABOVE THE 100,000 GALLON MARK.
 3. WHERE GV-NOS. ARE SHOWN THE VALVES ARE TAGGED WITH THE MPL NO., WHERE GV-NOS. ARE NOT SHOWN, THE VALVES ARE TAGGED WITH THE MPL NO.
 4. PROVIDE LOW POINT DRAIN TO DRAIN CROSS THE PIPE AFTER USE. ROUTE DRAIN TO SUMP. VALVES MUST BE CLOSED AND LINE MUST BE DRAINED AFTER USE. HIGH POINT VENT IS REQUIRED.
 5. USE FOLLOWING VALVES FOR CROSS-TIE: VALVE NO. P11-F091 → 2P11-F030 (PEH2-138), P11-F090 → GV-70A(PEH-20).
 6. THROTTLE VALVE 2P11-F094 AS REQUIRED.

- REFERENCES:**
- REFERENCES:**
- | REFERENCES | MPL ITEM NO | S.S. DWG. NO |
|---|-------------|--------------|
| 1. P.&I.D. RADWASTE SYSTEM | G11-1010 | H-16177 |
| 2. P.&I.D. RADWASTE SYSTEM | G11-1010 | H-16178 |
| 3. P.&I.D. RADWASTE SYSTEM | G11-1010 | H-16179 |
| 4. P.&I.D. RADWASTE SYSTEM | G11-1010 | H-16182 |
| 5. H.P.C.I. SYSTEM | E41-1010 | H-16332 |
| 6. R.H.R. SYSTEM | E11-1010 | H-16329 |
| 7. R.H.R. SYSTEM | E11-1010 | H-16330 |
| 8. CORE SPRAY SYSTEM | E21-1010 | H-16331 |
| 9. REACTOR CLEAN-UP SYS. | O31-1010 | H-16188 |
| 10. C.R.D. SYSTEM | G11-1010 | H-16064 |
| 11. R.C.I.C. SYSTEM | E51-1010 | H-16334 |
| 12. FUEL POOL COOLING SYS. | O41-1010 | H-16002 |
| 13. FUEL POOL COOLING SYS. | G41-1020 | H-16003 |
| 14. PIPING & INSTRUMENT SYMBOLS | A41-1010 | S-15051 |
| 15. P.&I.D. RADWASTE SYS. | G11-1010 | H-16180 |
| 16. P.&I.D. RADWASTE SYS. | G11-1010 | H-16181 |
| 17. RADWASTE BUILDING ADDITION SUPPORT SYS. | G11-1011 | H-16517 |
| 18. P.&I.D. AND PFD | P33-2010 | H-16281 |
| 19. CONDENSATE & STORAGE TRANSFER SYS. | 2P11-1010 | H-26046 |

BOUNDARY DIAGRAM NO.: L36-02
FUNCTION(S) NO.: L36-02
 PREPARED BY: M D STEPHENS
 DATE: 6/11/98
 REVIEWED BY: WILLIE JENNINGS
 DATE: 7/9/98

LICENSE RENEWAL DOCUMENT

MPL NO. P11-1010 ACAD14 HL16016



LICENSE RENEWAL SCREENING FOR INFORMATION ONLY

EDWIN I. HATCH NUCLEAR PLANT UNIT No. 1
 REACTOR BLDG. & RADWASTE BLDG.
 CONDENSATE STORAGE & TRANS. SYS. P.&I.D.

Revisions: A Date: 10-21-99
 APPROVED. ISSUED PER LICENSE RENEWAL BOUNDARY PACKAGES. DRAWING CREATED FROM H-16016, REV.35; BY JTM.

BOUNDARY DIAGRAM NO.: P111-B01-01
FUNCTION(S) NO.: 1P11-01, 1E41-01, 1E51-01
 PREPARED BY: WILLIAM P EVANS
 DATE: 2/27/98
 REVIEWED BY: BO ROSBERG
 DATE: 2/27/98

DATE	REVISION	LOCATION	REVISION NUMBER	REASON

10-502 HL-16016 A