



- NOTES**
1. AUTOMATIC START SIGNAL FROM VALVE CONTACT E41-F001
 2. AUTOMATIC START SIGNAL FROM PUMPS STARTER CIRCUIT E11-C002A, C AND/OR E21-C001A.
 3. AUTOMATIC START SIGNAL FROM PUMPS STARTER CIRCUIT E11-C002B, D AND/OR E21-C001B.
 4. AUTOMATIC START SIGNAL FROM VALVE CONTACT E51-F045.
 5. DE-ENERGIZE SOLENOID VALVE ON RESPECTIVE FAN OPERATION TO OPEN AIR OPERATED VALVE.
 6. ALL EQUIPMENT AND INSTRUMENT NO.S ON THIS DWG PRECEDED BY T41; EXAMPLE T41-B003A.

REFERENCES

REFERENCES	MPL No.	SS No.
1. REACTOR BUILDING PLANT SERVICE WATER SYSTEM P. & I.D.	P41-1010	H-16011
2. F.C.D. H.P.C.I. SYSTEM	E41-1030	H-19950
3. F.C.D. R.H.R. SYSTEM	E11-1030	H-19937
4. F.C.D. CORE SPRAY SYSTEM	E21-1030	H-19944
5. F.C.D. R.C.I.C. SYSTEM	E51-1030	H-19956
6. PIPING & INSTRUMENT SYMBOLS	A41-1010	S-15051

BOUNDARY DIAGRAM NO.: 1T41-B02-01
 FUNCTION(S) NO.: 1T41-02, 1T41-07
 PREPARED BY: ED DAVIDSON
 DATE: 4/6/98
 REVIEWED BY: ALEX MORRISON
 DATE: 5/4/98

LICENSE RENEWAL DOCUMENT

MPL T41-1030 ACAD14 HL16023

SOUTHERN COMPANY

LICENSE RENEWAL SCREENING FOR INFORMATION ONLY

EDWIN I. HATCH NUCLEAR PLANT UNIT No. 1 SAFEGUARD EQUIPMENT COOLING P. & I.D.

DATE	BY	LOCATION	REVISION
10-502	HL-16023		A

Revision: A Date: 12-30-99
 APPROVED - ISSUED PER LICENSE RENEWAL BOUNDARY PACKAGES.
 DRAWING CREATED FROM H-16023, REV. 9, BY JIM.

TRM EPD ASK