

Calculation Notebook STA-042

NUCLEAR POWER GENERATION
CF3.ID4
ATTACHMENT 7.1

TITLE: CALCULATION COVER SHEET

PACIFIC GAS AND ELECTRIC COMPANY
CALCULATION COVER SHEET

Page 1 of 1

File No. :
Calculation No.: STA-042

Preliminary Final

Project: DIABLO CANYON POWER PLANT UNITS 1 AND 2 Date: 10/1/96
Department/ Group: _____

Structure, System or Component:
STEAM GENERATOR


Type or Purpose of Calculation: LOADS ON THE STEAM GENERATOR TUBE SUPPORT PLATES DURING SLE ACCIDENT

No. of Sheets: 174 + COVER SHEET + 2 FLAPPY DISKS (ATTACHMENT 1)

| | Signature | Discipline/Dept | Date |
|-----------|----------------------------------|--------------------|----------------|
| PREPARER: | <u>[Signature]</u> | <u>S&TA/RS</u> | <u>10/1/96</u> |
| CHECKER : | <u>[Signature]</u> | <u>S&TA/RS</u> | <u>10/2/96</u> |
| APPROVAL: | <u>[Signature]</u> Supervisor | <u>S&TA/RS</u> | <u>10/2/96</u> |

For civil calculation, enter the registered engineer's stamp or seal and expiration date of certificate or authority in this space.

For other calculation, enter the registered engineer's full name and registration number, or stamp, or seal in this space.



RECORDS OF REVISIONS

| Revision Number | Date | Reasons for Revision | Prepared By | Checked By | Approval | |
|-----------------|---------|----------------------|-------------|-------------|--------------|--------|
| | | | | | Regis. Engr. | Supvr. |
| 0 | 10/1/96 | NEW ISSUE | HML | [Signature] | T. Lee | T. Lee |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 1 OF 174 SHEETS
CALC NO. STA-042 R. 0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

Table of Contents

| Section | | Page |
|--------------|--|------|
| 1. | Introduction | 2 |
| 2. | Assumptions | 3 |
| 3. | RELAP5/MOD3.2 Code | 5 |
| 4. | Analysis | 6 |
| 5. | RELAP5 Input | 7 |
| 6. | Results | 88 |
| 7. | References | 133 |
| Appendix A | Loss Coefficient of Tube Bundle Crossflow | 134 |
| Appendix B | Sensitivity Study for Initial Steam Generator Water Level | 137 |
| Appendix C | TRANFLO Input Changes for Cases 61 | 148 |
| Appendix D | Input Listing for LB Case 1 | 150 |
| Appendix E | Steam Generator Design Alternation | 160 |
| Appendix F | Westinghouse Drawing 350794-B | 166 |
| Appendix G | Microfiches for the RELAP Runs | 168 |
| Attachment 1 | Flappy Disks for Transferring Data | |

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 2 OF 174 SHEETS
CALC NO. STA-602 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY HMLBG DATE 10/1/96 CHECK BY _____ APPROVED BY _____

1. Introduction

The inspection of steam generator tubes has identified tube cracks in the portions of tubes surrounded by the tube support plat^s. Since the tube support plats hold up the tubes, the tubes will not be burst even if cracks have been developed on the tube wall in these regions. Therefore, plugging these tubes may not be required. However, a concern was raised during steam line break accident. The fast pressure transient in the steam generator during steam line break accident may result in high pressure load on the tube support plat^s which may push the tube support plat^s up from their original locations. The concern is that, if the tube support plat^s are pushed up during the steam line break, the tube cracks in these regions will not be protected by the tube support plat^s and will be exposed to the high pressure difference from the primary side to the secondary side *and fail.*

The purpose of this calculation is to calculate the pressure loads on the tube support plat^s during the steam line break accident. The RELAP5 code mod 3.2 is used to perform the calculation. The results of this calculation then be transferred to Westinghouse to perform structure analysis to determine the displacement of the tube support plat^s. Since the larger the break size results in the higher pressure load on the tube support plats, the break at the steam generator steam outlet nozzle is used. In addition, the break at the downstream of the main steam flow

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 3 OF 176 SHEETS
CALC NO. STA-002 R.O

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY JM Loo DATE 12/1/96 CHECK BY _____ APPROVED BY _____

restrictor is also analyzed.

The initial plant condition is assumed to be hot 0% power. The study of the conservatism for the initial plant condition assumption is not part of the scope of this calculation. Westinghouse already modeled the steam generator (Westinghouse Model 51) at hot 0% power using the TRANFLO code for Farley Plant (ref. 1). The Farley Model 51 steam generators are identical to the DCPD Model 51 steam generators, except for the wrapper opening at the tube sheet (Ref. 2). Therefore, in this calculation, the TRANFLO model for the steam generator is used as the bases for setting up the RELAP5 steam generator model.

2. Assumptions

The following assumptions are used in this calculation.

1. The plant is at hot 0% power.
2. The steam line break is located at the steam generator steam outlet nozzle which is upstream of the steam flow restrictor and has the largest steam flow area. The break at the downstream of the flow restrictor is also analyzed.
3. Since the high pressure loads on the tube support plats only last for less than 2 seconds, the heat transfer from the RCS to the steam generator secondary side does not have significant effect on the

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 4 OF 174 SHEETS
CALC NO. STA-042 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY HAK CG DATE 10/1/96 CHECK BY _____ APPROVED BY _____

pressure load on TSPs. The primary coolant flow is assumed at constant flow rate of 9148.5 lb/sec and the primary coolant pressure and temperature specified in Ref. 1 are used.

4. The steam line break induces tremendous high steam and water flow in the steam generator and the high pressure loads on the tube support plat^es only last for less than 2 seconds. The initial flow in the steam generator secondary side and the auxiliary feedwater injected into the steam generator have insignificant effects on the fast transient occurred in the steam generator. It is assumed that no steam is removed from the steam generator before the break and the auxiliary feedwater flow is not included in the steam generator model. The RELAP5 model does not assign any flow to the junctions of the steam generator secondary side. However, a five seconds steady state run is performed before the break is initiated which generates a natural recirculate flow in the secondary side of the steam generator due to the heat transferred from the primary side.
5. The RELAP5 code manual (Ref. 3) recommends to use the non-equilibrium model for all volumes. However, the use of non-equilibrium model for the shell side of the tube region generates more abrupt changes in the pressure loads which do not show with the use of equilibrium model for the shell side of the tube region. Since it is difficult to determine which model will generate more conservative loads on the TSPs, the non-equilibrium and equilibrium

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 5 OF 174 SHEETS
CALC NO. STA-002 R.O

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H.M. LOGG DATE 10/1/96 CHECK BY _____ APPROVED BY _____

models are used to model the shell side of the tube region in separated cases to calculate the loads on TSPs.

6. The roughness for commercial steel pipe is 0.00015 ft (or 0.0018") (Ref.) which is used for all volumes.

3. RELAP5/MOD3.2 Code

The RELAP5 code is an advanced-thermal hydraulic code which has been used as a tool to analyze transient in light water reactor systems. The RELAP5/MOD3 code is the third major variant of the RELAP5 code and the RELAP5/MOD3.2 code is the latest revision of the RELAP5/MOD3 code. The RELAP5/MOD3.2 code has been used by analysts to evaluate the thermal-hydraulic behavior of many light water ^{reactor} systems.

The RELAP5/MOD3.2 code equation set gives a two-fluid system simulation using a non-equilibrium, non-homogeneous, six-equation representation. The six basic field equations are used to solve six dependent variables- pressure, specific internal energies for gas and liquid, void fraction and velocities for gas and liquid. Constitutive models represent the interphase drag, the various flow regimes in vertical and horizontal flow, wall friction, and interphase mass transfer. The code also has the capability to simulate the presence of slabs of material adjacent to the

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 6 OF 174 SHEETS
CALC NO. STA-042 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY HMC DATE 10/1/96 CHECK BY _____ APPROVED BY _____

fluid. Thus, energy transfer to and from stationary slabs of material can be simulated. Control systems and component models permit simulations of equipment controllers, balance-of-plant equipment, and lumped-node representations of various processes.

4. Analysis

There are five cases analyzed in this calculation. These cases are described as follows.

LB Case 1: The plant is at hot 0% power. A steam line break is occurred at the steam generator outlet nozzle. The initial water level in the steam generator is at 490.4 inches from the top of the tube plat which is equivalent to narrow range of 33%.
The non-equilibrium model is used to model the secondary side of the tube region.

LB Case 2: This case is same as the LB Case 1, except the equilibrium model is used to model the secondary side of the tube region.

LB Case 3: This case is designed to study the effects of the initial water level and the resistances of the tube support plates on the calculated loads on the TSPs. The lower the initial water level and the higher the TSP resistance result in higher loads on the TSPs. Therefore, for this case, the

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 7 OF 174 SHEETS
CALC NO. STA-042 20

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY JR LBO DATE 10/1/96 CHECK BY _____ APPROVED BY _____

initial water level is the steam generator is reduced to $466.0'$ ^{10/2/96}
which is corresponding to narrow range water level of 16% , ^{14% C} 10/1/96
and the TSP resistance coefficient is increased to 0.99. The
remaining conditions for this case are same as those used for
LB Case 1.

SB Case 1: This case is same as the LB Case 1, except the break is
assumed located at the downstream of the main steam flow
restrictor.

SB Case 2: This case is same as the LB Case 2, except the break is
assumed located at the downstream of the main steam flow
restrictor.

5. RELAP5 Input

The fluid region in the steam generator is separated in two loops. The
first loop is the primary loop which models the primary side of the
tubes. The second loop is the secondary loop which models the secondary
side of the steam generator. Heat slabs are used to model the heat
transfer from the primary side to the secondary side.

RELAP5 Model for Steam Generator Secondary Side (Secondary Loop)

The schematic diagram for the RELAP5 model for the steam generator

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 9 OF 170 SHEETS
CALC NO. STA-042 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY HM LGG DATE 10/1/96 CHECK BY _____ APPROVED BY _____

secondary side is given in Figure 5-1. The RELAP5 model consists of the following elements.


- . 2 pipe components - Component 2 consists of 30 volumes and 29 junctions. The schematic diagram for the Component 2 is shown in figure 5-2. Component 35 consists of 3 volumes and 2 junctions.
- . 2 separator components - Component 19 consists of 1 volumes and 3 junctions. Component 22 consists of 1 volumes and 3 junctions.
- . 5 branch components - Component 21 consists of 1 volume and 2 junctions. Component 30 consists of 1 volume and 2 junctions. Component 33 consists of 1 volume and 2 junctions. Component 34 consists of 1 volume and 1 junctions. Component 53 consists of 1 volume and 2 junctions.
- . 7 single volume components - Components 17, 18, 20, 23, 32, 36 and 38.
- . 2 single junction components - Components 519 and 533.
- . 1 valve component - Component 518.

RELAP5 Model for Steam Generator Primary Side (Primary Loop)

The schematic diagram for the RELAP5 model for the steam generator primary side is given in Figure 5-3. The RELAP5 model consists of the following elements.

- . 1 pipe component - Component 1 consists of 60 volumes and 59 junctions.



HAL 10/1/96 9/174
STA-042 R.O



RELAP5 Steam Generator Secondary Side Model

FIGURE 5 - 1

12/17/96
 HMC 10/1/96
 STA-042 R.O




V. = Volume
 J = Junction

Component 2 and Component 30

FIGURE 5 - 2

11/174
HML 10/1/96
STA-042 R.0



RELAP5 Steam Generator Primary Side Model

FIGURE 5 - 3

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 12 OF 174 SHEETS
CALC NO. STA- 042 R. 0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY HMLGG DATE 1/1/96 CHECK BY APPROVED BY

- . 2 time dependent volume components - Components 100 and 101.
- . 2 time dependent junction components - Components 500 and 501.

Heat Slab

There are 60 heat slabs used to model the tubes and the heat transfer from the primary side fluid to the secondary fluid. Each heat slab connects a primary side volume to a secondary side volume.

Common Input

The common RELAP5 input used for the volumes and junctions are listed in this section. The RELAP5/MOD 3.2 code has certain options available for modeling the volumes and junctions which can be switched on or off by the volume control flags and junction control flags. Since the steam line break transient is a very short and fast transient with huge flows in the secondary side of the steam generator, the defaulted options are selected to model the volumes and junctions, except specially discussed and specified for particular volumes or junctions. The switching from non-equilibrium volume model to equilibrium volume model to model the shell side of the tube region has significant effects on the TSPs' loads. As described in Section 4, a sensitivity study is performed to study the effects of switching from the non-equilibrium to the equilibrium volume model for the volumes modeling the shell side of the tube region.

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 13 OF 174 SHEETS
CALC NO. _____ STA- 042 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY JM LBB DATE 10/1/96 CHECK BY _____ APPROVED BY _____

The RELAP5/MOD3.2 options for modeling the volumes and junctions associated with the defaulted volume control flags and junction control flags are listed as follows.

Volume Control Flags

- . $t=0$, the thermal front tracking model is not used.
- . $l=0$, the mixture level tracking model is not used.
- . $p=0$, the water packing scheme is used.
- . $v=0$, the vertical stratification model is used.
- . $b=0$, the pipe interphase friction model is used.
- . $f=0$, the wall friction is used.
- . $e=0$, the non-equilibrium model is used.

Junction Control Flags

- . $e=0$, the modified PV term is not used.
- . $f=0$, the CCFL model is not used.
- . $v=0$, the horizontal stratification entrainment model is not used.
- . $c=0$, the chocking model is used.
- . $a=0$, a smooth area change or no area change.
- . $h=0$, the non-homogeneous model is used.
- . $s=0$, the momentum fluxes to the volume and from the volume are used.

As described in Section 2, the roughness of 0.00015 ft is used for all

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 14 OF 174 SHEETS
CALC NO. _____ STA- D42 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY JM LBG DATE 10/1/96 CHECK BY _____ APPROVED BY _____

the Volumes and the initial liquid and vapor mass flow rates are zero for all the junctions which will not be discussed again for each Component. The description of the input variables is given in the Reference 4.

The default input value is used for all the input data which are not described in this section.

RELAP5 Input for LB Case 1

The Initial conditions for LB Case 1 are same as those specified in Reference 1 for the case with the steam generator water level 490.5" from the top of the tube plat and hot 0% power.

Secondary Loop

The secondary loop includes 16 components - 2, 17, 18, 19, 20, 21, 22, 23, 30, 32, 33, 34, 35, 36, 38, 53, 518, 519 and 533. A schematic of the secondary loop is shown in the Figure 5-1.

Component 30

Component 30 is a Branch with assigned component name "tubesh" which includes a single volume (30-01) and two junctions (30-01 and 30-02). The Volume 30-01 models the shell side of the tube region from the top of the tube plat to the height of the wrapper opening which is 14"^(Ref. 1). The Junction 30-01 is from the downcomer (Component 35) to the Component 30

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 15 OF 174 SHEETS
CALC NO. _____ STA- 042 R.O

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY HML DATE 10/1/96 CHECK BY _____ APPROVED BY _____

and the Junction 30-02 is from the Component 30 to the remaining shell side of the tube region (Component 2).

As given in Ref. 1, the flow area of the shell side of tube region is 54.22 ft². The length for the Volume 30-01 is 14" or 1.1667'. Since the Volume 30-01 is orientated as 90 degree upward, the elevation change for the Volume 30-01 is 1.1667'. The hydraulic diameter of 0.136' is used in the TRANFLO model for the shell side of tube region (Ref. 1). The same hydraulic diameter is used for the Volume 30-01. Since the Volume 30-01 contains rod bundle, the volume control flag b is set to be 1 which initiates the use of the rod bundle interphase friction model.

As used in the TRANFLO model (Ref. 1), the water temperature of the steam generator secondary side is 547 °F. The specific volume for water at 547 °F is 0.02166 ft³/lb. The water density at 547 °F is 46.17 lb/ft³. The pressure at the center of node 31 of TRANFLO model is 1033.66 psia which is located 4.21/2 = 2.105 ft from the top of the tube plat. The pressure at the center of the volume 30-01 can be calculated as:

$$1033.66 + (2.105 - 1.1667/2) * 46.17 / 144 = 1034.15 \text{ psia}$$

The flow area of Junction 30-01 is same as the flow area of Component 35 which is 7.096 ft². The forward and reverse flow resistant coefficients for Junction 30-01 should be same as those given for the segment 1 of the

PACIFIC GAS AND ELECTRIC COMPANY
 GENERAL COMPUTATION SHEET

SHEET NO. 16 OF 174 SHEETS
 CALC NO. STA-042 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
 MADE BY Hm UGG DATE 10/1/96 CHECK BY _____ APPROVED BY _____

Connector 30 or 31 which are 0.5 and 0.5.

The flow area of Junction 30-02 equals to the cross section flow area of the wrapper opening in the horizontal direction which was calculated as 2.215 ft² for the Farley Model 51 steam generator (combining the flow area given in the TRANFLO model for the Connector 30 segment 2 and the Connector 31 segment 2). The wrapper opening height for Farley steam generator is 7" (Ref. 2), while the ^{DCPP's} wrapper opening height is 14". Therefore, the flow area of Junction 30-02 is $2.215 * 2 = 4.43$ ft². As given in Westinghouse letter NSD-JLH-6070, the flow resistant coefficient for the cross flow through the wrapper opening is 5.32 based on flow area of 4.43 ft². The Westinghouse letter is attached to this calculation as Appendix A. Therefore, the forward and reverse flow resistant coefficients of 5.32 are used for the Junction 30-02. The following input are specified for the Component 30.

| | | | | | | | | | |
|---------|-----------|-----------|-------|------|------|--------|---------|-------|-------|
| 0300000 | tubesh | branch | | | | | | | |
| 0300001 | 2 | 1 | | | | | | | |
| 0300101 | 54.22 | 1.1667 | 0. | 0. | 90. | 1.1667 | 0.00015 | 0.136 | 00100 |
| 0300200 | 3 | 1034.15 | 547.0 | | | | | | |
| 0301101 | 035010000 | 030000000 | 7.096 | 0.5 | 0.5 | 000000 | | | |
| 0302101 | 030010000 | 002000000 | 4.43 | 5.32 | 5.32 | 000000 | | | |
| 0301201 | 0.0 | 0.0 | 0.0 | | | | | | |
| 0302201 | 0.0 | 0.0 | 0.0 | | | | | | |

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 17 OF 174 SHEETS
CALC NO. STA-042 B0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY HMLGG DATE 10/1/96 CHECK BY _____ APPROVED BY _____

Component 2

The Component 2 is a Pipe with assigned name shell which is used to model the secondary side from the top of wrapper opening to the bottom of the primary separator. There are 30 volumes and 29 junctions included in the Component 2. The modeling scheme of the Component 2 is shown in the Figure 5-2. Volumes 2-01 to 02-03 are used to model the region from the top of the wrapper opening to the middle of the TSP 1. Volumes 2-04 to 02-07 are used to model the region from the middle of the TSP 1 to the middle of TSP 2. Volumes 2-08 to 2-11 are used to model the region from the middle of TSP 2 to the middle of the TSP 3. Volumes 2-12 to 2-15 are used to model the region from the middle of TSP 3 to the middle of the TSP 4. Volumes 2-16 to 2-19 are used to model the region from the middle of TSP 4 to the middle of the TSP 5. Volumes 2-20 to 2-23 are used to model the region from the middle of TSP 5 to the middle of the TSP 6. Volumes 2-24 to 2-27 are used to model the region from the middle of TSP 6 to the middle of the TSP 7. Volumes 2-28 to 2-30 are used to model the region from the middle of TSP 7 to the bottom of the primary separator.

To calculate the pressure difference across the TSP, a volume length of 0.5 ft is used for all the volumes adjacent to the TSP (volumes 2-03, 2-04, 2-07, 2-08, 2-11, 2-12, 2-15, 2-16, 2-19, 2-20, 2-23, 2-24, 2-27, 2-

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 18 OF 174 SHEETS
CALC NO. STA-642 RB

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY HM CBB DATE 10/1/96 CHECK BY _____ APPROVED BY _____

28). The length between the TSPs not including the thickness of the TSP is given in the TRANFLO model as $2.073 * 2 = 4.146$ ft (the sum of the length of segments 1 and 3 of the Connectors 40). The thickness of the TSP is given in the TRANFLO model as 0.0625 ft (the length of the segment 2). The length between the middle of TSPs is $4.146 + 0.0625 = 4.2085$ ft (4.2087 ft is used in this calculation, the effect is insignificant). The length from the top of tube plat to the middle of TSP 1 is $4.146 + 0.0625/2 = 4.1773$ ft. To makeup the 4.1773 ft, the volume length for volume 2-01 and 2-02 is $(4.1773 - 1.1667 \text{ (length of Volume 30-01)} - 0.5) / 2$. *10/1/96*
Ac 10/2/96
 $= 1.2553$ ft. The volume length for the volumes between the TSPs but not adjacent to the TSPs (Volumes 2-05, 2-06, 2-09, 2-10, 2-13, 2-14, 2-17, 2-18, 2-21, 2-22, 2-25 and 2-26) can be calculated as $(4.2087 - 0.5 - 0.5) / 2 = 1.60435$ ft. As given in the TRANFLO model (Ref. 1), the length from the top of the TSP 7 to the bottom of the primary separator is 7.11 ft (length of Node 24). Including the half of the TSP thickness, the sum of the volume length for Volume of 2-28, 2-29 and 2-30 should be $7.11 + 0.0625/2 = 7.1413$ ft (see Figure 5-2). As given in the TRANFLO model (Ref. 1), the average length for the tube above the TSP 7 is 44.49" or 3.7075' (length for the Nodes 9 and 8). The Volume 2-28 and 2-29 are used to model the region with tubes and the Volume 2-30 does not have tube inside. Therefore, the volume length for Volume can be determined as $3.7075 - 0.5 = 3.2075$ ft. The volume length for Volume equals to $7.1413 - 0.5 - 3.2075 = 3.4338$ ft.

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 19 OF 74 SHEETS
CALC NO. STA-002 R0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY HMLBG DATE 10/1/96 CHECK BY _____ APPROVED BY _____

The flow areas for the Volumes 2-01 to 2-27 are the same as the flow areas used for the TRANFLO Nodes 31 to 25 which are 54.22 ft². The flow areas for the Volumes 2-28 to 2-30 are the same as the flow areas for the TRANFLO Nodes 24 which is 70.0 ft². The flow areas for the Junctions of Component 2 are the same as the flow areas for the adjacent Volumes, except the flow areas for the Junctions modeling the TSPs. The flow areas for the TSPs are given in the TRANFLO model (Ref. 1) as 23.716 ft². Therefore, the flow area of 54.22 ft² is used for the Junctions 2-01, 2-02, 2-04, 2-05, 2-06, 2-08, 2-09, 2-10, 2-12, 2-13, 2-14, 2-16, 2-17, 2-18, 2-20, 2-21, 2-22, 2-24, 2-25 and 2-26. The flow area for 23.716 ft² is used for the Junctions 2-3, 2-7, 2-11, 2-15, 2-19, 2-23 and 2-27. The flow area of 70 ft² is used for the Junctions 2-28 and 2-29.

The volume sizes for all the Volumes are not specified by the input (0.0 is input for volume size). The RELAP5 code will calculate the volume size based on the volume flow area and length. All the Volumes of Component 2 are vertical upward volumes. A 90° inclination angle is used for all the volumes. For all the Volumes, the elevation changes are the same as the volumes lengths. As the Volume 30-01, the hydraulic diameter of ~~0.216~~ ^{0.136} ft is used for all the Volumes, except the volume 2-30 (no tubes in the Volume 2-30). For the Volume 2-30, the hydraulic diameter is calculated by the RELAP5 code.

HML 10/1/96
lc 10/2/96

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 20 OF 70 SHEETS
CALC NO. STA-042 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY HM CGG DATE 10/1/96 CHECK BY _____ APPROVED BY _____

Same as the Volume 30-01, since rod bundle is contained in the Volumes 2-01 to 2-29, the volume control flag b is set to be 1 for Volumes 2-01 to 2-29 which initiates the use of the rod bundle interphase friction model.

The initial water temperature for all the volume of Component 2 is 547 °F. As calculated for Volume 30-01, the water density is 46.17 lb/ft³. The water static pressure reduces $46.17/144 = 0.3206$ psi for every foot elevation increase. The initial pressure for Volume 30-01 is 1034.15 psia. The initial pressure used in TRANFLO model for Node 24 is 1023.75 psia (Ref. 1). The elevation at the center of the Node 24 is $7.11/2 = 3.555$ ft below the bottom of the primary separator. The elevation at the center of the Volume 2-30 is $3.4338 / 2 = 1.7169$ ft below the bottom of the primary separator. The initial pressure at the center of the Volume 2-30 should be $1023.75 - (3.555 - 1.7169) * 0.3206 = 1023.17$ psia. The pressure for the remaining Volumes of Component 2 can be calculated by elevation difference from the Volume 2-30. Since a 5 seconds steady state run is performed to straighten out slight inconsistency of the initial conditions, high accuracy for the initial pressure input for the Volumes of Component 2 is not required. The initial pressures for the Volumes of Component 2 are calculated as follows.

Volume 2-29 $1023.17 + (3.2075 + 3.4338)/2 * 0.3206 = 1024.23$ psia.

Volume 2-28 $1024.23 + (3.2075 + 0.5)/2 * 0.3206 = 1024.82$ psia.

Volume 2-27 $1024.82 + (0.5 + 0.5)/2 * 0.3206 = 1024.98$ psia.

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 21 OF 174 SHEETS
CALC NO. STA-042 R.6

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H.A. CGG DATE 10/1/96 CHECK BY _____ APPROVED BY _____

Volume 2-26 $1024.98 + (0.5 + 1.60435)/2 * 0.3206 = 1025.32$ psia.
Volume 2-25 $1025.32 + (1.60435 + 1.60435)/2 * 0.3206 = 1025.83$ psia.
Volume 2-24 $1025.83 + (1.60435 + 0.5)/2 * 0.3206 = 1026.17$ psia.
Volume 2-23 $1026.17 + (0.5 + 0.5)/2 * 0.3206 = 1026.32$ psia.
Volume 2-22 $1026.32 + (0.5 + 1.60435)/2 * 0.3206 = 1026.66$ psia.
Volume 2-21 $1026.66 + (1.60435 + 1.60435)/2 * 0.3206 = 1027.18$ psia.
Volume 2-20 $1027.18 + (1.60435 + 0.5)/2 * 0.3206 = 1027.52$ psia.
Volume 2-19 $1027.52 + (0.5 + 0.5)/2 * 0.3206 = 1027.68$ psia.
Volume 2-18 $1027.68 + (0.5 + 1.60435)/2 * 0.3206 = 1028.01$ psia.
Volume 2-17 $1028.01 + (1.60435 + 1.60435)/2 * 0.3206 = 1028.53$ psia.
Volume 2-16 $1028.53 + (1.60435 + 0.5)/2 * 0.3206 = 1028.86$ psia.
Volume 2-15 $1028.86 + (0.5 + 0.5)/2 * 0.3206 = 1029.02$ psia.
Volume 2-14 $1029.02 + (0.5 + 1.60435)/2 * 0.3206 = 1029.36$ psia.
Volume 2-13 $1029.36 + (1.60435 + 1.60435)/2 * 0.3206 = 1029.87$ psia.
Volume 2-12 $1029.87 + (1.60435 + 0.5)/2 * 0.3206 = 1030.21$ psia.
Volume 2-11 $1030.21 + (0.5 + 0.5)/2 * 0.3206 = 1030.37$ psia.
Volume 2-10 $1030.37 + (0.5 + 1.60435)/2 * 0.3206 = 1030.71$ psia.
Volume 2-09 $1030.71 + (1.60435 + 1.60435)/2 * 0.3206 = 1031.22$ psia.
Volume 2-08 $1031.22 + (1.60435 + 0.5)/2 * 0.3206 = 1031.56$ psia.
Volume 2-07 $1031.56 + (0.5 + 0.5)/2 * 0.3206 = 1031.72$ psia.
Volume 2-06 $1031.72 + (0.5 + 1.60435)/2 * 0.3206 = 1032.06$ psia.
Volume 2-05 $1032.06 + (1.60435 + 1.60435)/2 * 0.3206 = 1032.57$ psia.
Volume 2-04 $1032.57 + (1.60435 + 0.5)/2 * 0.3206 = 1032.91$ psia.

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 22 OF 176 SHEETS
CALC NO. STA-042 R.O

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

Volume 2-03 $1032.91 + (0.5+0.5)/2*0.3206 = 1033.07$ psia

Volume 2-02 $1033.07 + (0.5+1.2553)/2*0.3206 = 1033.35$ psia

Volume 2-01 $1033.35 + (1.2553+1.2553)/2*0.3206 = 1033.73$ psia

The hydraulic diameter is used in the CCFL correction and the interphase drag. As shown on the input for the segment 2 of connectors 34 to 40 of the TRANFLO model, the hydraulic diameter of 0.0625 ft is used for the TSPs and the resistance coefficient of 0.78 is used for both forward and reverse flow through the TSPs which includes the resistance due to area change at the TSPs. The CCFL correlation is not used in this calculation. All the junctions of the Component 2 except those associated with TSPs have no resistance. The default values for all the CCFL data are used for all junction of the Component 2.

The following input are used for the Component 2.

| | | |
|---------|--------|------|
| 0020000 | shell | pipe |
| 0020001 | 30 | |
| 0020101 | 54.22 | 27 |
| 0020102 | 70.0 | 30 |
| 0020201 | 54.22 | 2 |
| 0020202 | 23.716 | 3 |
| 0020203 | 54.22 | 6 |
| 0020204 | 23.716 | 7 |
| 0020205 | 54.22 | 10 |
| 0020206 | 23.716 | 11 |

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 23 OF 174 SHEETS
CALC NO. STA-042 R 0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident

MADE BY HM 286 DATE 10/1/96 CHECK BY _____ APPROVED BY _____

| | | |
|---------|---------|----|
| 0020207 | 54.22 | 14 |
| 0020208 | 23.716 | 15 |
| 0020209 | 54.22 | 18 |
| 0020210 | 23.716 | 19 |
| 0020211 | 54.22 | 22 |
| 0020212 | 23.716 | 23 |
| 0020213 | 54.22 | 26 |
| 0020214 | 23.716 | 27 |
| 0020215 | 70.0 | 29 |
| 0020301 | 1.2553 | 1 |
| 0020302 | 1.2553 | 2 |
| 0020303 | 0.5 | 4 |
| 0020304 | 1.60435 | 6 |
| 0020305 | 0.5 | 8 |
| 0020306 | 1.60435 | 10 |
| 0020307 | 0.5 | 12 |
| 0020308 | 1.60435 | 14 |
| 0020309 | 0.5 | 16 |
| 0020310 | 1.60435 | 18 |
| 0020311 | 0.5 | 20 |
| 0020312 | 1.60435 | 22 |
| 0020313 | 0.5 | 24 |
| 0020314 | 1.60435 | 26 |

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 24 OF 174 SHEETS
CALC NO. STA-042 R0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H.M. LEE DATE 10/1/96 CHECK BY _____ APPROVED BY _____

| | | | |
|---------|---------|-------|----|
| 0020315 | 0.5 | 28 | |
| 0020316 | 3.2075 | 29 | |
| 0020317 | 3.4338 | 30 | |
| 0020601 | 90.0 | 30 | |
| 0020801 | 0.00015 | 0.136 | 29 |
| 0020802 | 0.00015 | 0.0 | 30 |
| 0020901 | 0.0 | 0.0 | 2 |
| 0020902 | 0.78 | 0.78 | 3 |
| 0020903 | 0.0 | 0.0 | 6 |
| 0020904 | 0.78 | 0.78 | 7 |
| 0020905 | 0.0 | 0.0 | 10 |
| 0020906 | 0.78 | 0.78 | 11 |
| 0020907 | 0.0 | 0.0 | 14 |
| 0020908 | 0.78 | 0.78 | 15 |
| 0020909 | 0.0 | 0.0 | 18 |
| 0020910 | 0.78 | 0.78 | 19 |
| 0020911 | 0.0 | 0.0 | 22 |
| 0020912 | 0.78 | 0.78 | 23 |
| 0020913 | 0.0 | 0.0 | 26 |
| 0020914 | 0.78 | 0.78 | 27 |
| 0020915 | 0.0 | 0.0 | 29 |
| 0021001 | 00100 | 29 | |
| 0021002 | 00000 | 30 | |

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 25 OF 176 SHEETS
CALC NO. _____ STA- 292 R.O

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident

MADE BY H.M. LEE DATE 10/1/96 CHECK BY _____ APPROVED BY _____

| | | | | | | | | |
|---------|--------|---------|-------|-----|-----|-----|----|--|
| 0021101 | 000000 | 29 | | | | | | |
| 0021201 | 3 | 1033.73 | 547.0 | 0.0 | 0.0 | 0.0 | 1 | |
| 0021202 | 3 | 1033.34 | 547.0 | 0.0 | 0.0 | 0.0 | 2 | |
| 0021203 | 3 | 1033.07 | 547.0 | 0.0 | 0.0 | 0.0 | 3 | |
| 0021204 | 3 | 1032.91 | 547.0 | 0.0 | 0.0 | 0.0 | 4 | |
| 0021205 | 3 | 1032.57 | 547.0 | 0.0 | 0.0 | 0.0 | 5 | |
| 0021206 | 3 | 1032.06 | 547.0 | 0.0 | 0.0 | 0.0 | 6 | |
| 0021207 | 3 | 1031.72 | 547.0 | 0.0 | 0.0 | 0.0 | 7 | |
| 0021208 | 3 | 1031.56 | 547.0 | 0.0 | 0.0 | 0.0 | 8 | |
| 0021209 | 3 | 1031.22 | 547.0 | 0.0 | 0.0 | 0.0 | 9 | |
| 0021210 | 3 | 1030.71 | 547.0 | 0.0 | 0.0 | 0.0 | 10 | |
| 0021211 | 3 | 1030.37 | 547.0 | 0.0 | 0.0 | 0.0 | 11 | |
| 0021212 | 3 | 1030.21 | 547.0 | 0.0 | 0.0 | 0.0 | 12 | |
| 0021213 | 3 | 1029.87 | 547.0 | 0.0 | 0.0 | 0.0 | 13 | |
| 0021214 | 3 | 1029.36 | 547.0 | 0.0 | 0.0 | 0.0 | 14 | |
| 0021215 | 3 | 1029.02 | 547.0 | 0.0 | 0.0 | 0.0 | 15 | |
| 0021216 | 3 | 1028.86 | 547.0 | 0.0 | 0.0 | 0.0 | 16 | |
| 0021217 | 3 | 1028.53 | 547.0 | 0.0 | 0.0 | 0.0 | 17 | |
| 0021218 | 3 | 1028.01 | 547.0 | 0.0 | 0.0 | 0.0 | 18 | |
| 0021219 | 3 | 1027.68 | 547.0 | 0.0 | 0.0 | 0.0 | 19 | |
| 0021220 | 3 | 1027.52 | 547.0 | 0.0 | 0.0 | 0.0 | 20 | |
| 0021221 | 3 | 1027.18 | 547.0 | 0.0 | 0.0 | 0.0 | 21 | |
| 0021222 | 3 | 1026.66 | 547.0 | 0.0 | 0.0 | 0.0 | 22 | |

PACIFIC GAS AND ELECTRIC COMPANY
 GENERAL COMPUTATION SHEET

SHEET NO. 26 OF 174 SHEETS
 CALC NO. _____ STA- 042 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
 MADE BY ITM LEE DATE 10/1/96 CHECK BY _____ APPROVED BY _____

| | | | | | | | |
|---------|--------|---------|-------|-----|-----|-----|----|
| 0021223 | 3 | 1026.33 | 547.0 | 0.0 | 0.0 | 0.0 | 23 |
| 0021224 | 3 | 1026.17 | 547.0 | 0.0 | 0.0 | 0.0 | 24 |
| 0021225 | 3 | 1025.83 | 547.0 | 0.0 | 0.0 | 0.0 | 25 |
| 0021226 | 3 | 1025.32 | 547.0 | 0.0 | 0.0 | 0.0 | 26 |
| 0021227 | 3 | 1024.98 | 547.0 | 0.0 | 0.0 | 0.0 | 27 |
| 0021228 | 3 | 1024.82 | 547.0 | 0.0 | 0.0 | 0.0 | 28 |
| 0021229 | 3 | 1024.23 | 547.0 | 0.0 | 0.0 | 0.0 | 29 |
| 0021230 | 3 | 1023.17 | 547.0 | 0.0 | 0.0 | 0.0 | 30 |
| 0021300 | 1 | | | | | | |
| 0021301 | 0.0 | 0.0 | 0.0 | 29 | | | |
| 0021401 | 0.0625 | 0.0 | 1.0 | 1.0 | 29 | | |

Component 533

The Component 533 is a single junction with assigned name abovetb which is used to provide a flow junction from the Volume 02-30 (Component 2) to the Volume 23-01 (Component 23). This component consists of 1 junction (Junction 533). The Junction 533 is corresponding the Connector 33 of the TRANFLO model given in Reference 1.

The smaller of the two flow areas of Volumes 2-30 and 23-01 is 49.43 ft² which is used as the flow area for this junction. As given the Reference 1, no flow resistance coefficient is specified for the Connector 33 while

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 27 OF 174 SHEETS
CALC NO. STA-042 R.O

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY HA LCG DATE 10/1/96 CHECK BY _____ APPROVED BY _____

the abrupt flow area change is specified for the Connector 33. The forward and reverse flow resistant coefficient of 0.0 is used for this junction. The junction control flag a is set to 1 to specify an abrupt area change. The following input are used for the Component 533.

```
5330000  abovetb  sngljun
5330101  002010000  023000000  49.43  0.0  0.0  000100
5330110  0.0  0.0  1.0  1.0
5330201  1  0.0  0.0  0.0
```

Component 23

The Component 23 is a single volume with assigned name abovetb which is used to model the region inside the primary separator and below the swirl vane. This component consists of 1 volume (Volume 23-01). The Volume 23-01 is corresponding the Node 23 of the TRANFLO model given in Reference 1. As given in the Table 4.2.2 of Reference 1, the flow area and volume size for the Node 23 are 49.43 ft² and 244.3 ft³. The volume length of Node 23 is $244.3/49.43 = 4.9423$ ft. The flow area and volume length are specified as input data while the volume size is not specified which will be calculated by the code using the volume length and flow area.

The Volume 23 is a vertical upward volume. The inclination angle is 90° and the elevation change is same as the volume length. The hydraulic

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 28 OF 174 SHEETS
CALC NO. STA-042 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY JML/CG DATE 10/1/96 CHECK BY _____ APPROVED BY _____

diameter of the volume is not specified also and the code will calculate it.

*HAC 11/1/96
PC 10/21/96*

The initial water properties for Node 23 are given in Reference 1 as - water pressure at 1022.72 psia, water temperature at 547°F and void fraction of 0.03. The RELAP5/MOD3.2 code recognizes the water quality instead of void fraction. The void fraction and water quality are identical when the water is in pure liquid phase (void fraction and quality are zero) and the water is pure vapor phase (void fraction and quality are one). There are 5 components (23, 32, 33, 53 and 36) having water in two phases initially. The void fractions specified in the TRANFLO model for the corresponding nodes are used for these 5 components. This results in higher void fractions in these components which is equivalent to reduce the initial water level. In Reference 1, a sensitivity study using TRANFLO code was performed which concluded that the lower the initial water level generates higher loads on the TSPs. A sensitivity study is also performed using RELAP5 code to verify this conclusion. The sensitivity study is attached in the Appendix B. For all the five cases discussed in Section 4, the void fractions given in the TRANFLO model are used as water qualities in RELAP5 analysis.

For two phases fluid, the RELAP5 code does not allow to specify both the water pressure and temperature. The water pressure of TRANFLO Node 23 is

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 29 OF 74 SHEETS
CALC NO. STA- DV2 R0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H.M. LGG DATE 10/1/96 CHECK BY APPROVED BY

used for this component. The initial water properties are specified as pressure at 1022.72 psia and the quality of 0.03. The following input are used for Component 23.

0230000 abovetb snglvol
0230101 49.43 4.9423 0.0 0.0 90.0 4.9423 0.00015 0.0 00000
0230200 2 1022.72 0.03

Component 22

The Component 22 is a separator with assigned name speratr which is used to model the region inside the primary separator and above the swirl fan. This component consists of 1 volume (Volume 22-01) and 3 junctions (Junctions 22-01, 22-02 and 22-03). The Volume 22-01 is corresponding the Node 22 of the TRANFLO model given in Reference 1. As given in the Table 4.2.2 of Reference 1, the flow area and volume size for the Node 22 are 41.73 ft² and 163.4 ft³. The volume length of Node 22 is 163.4/41.73 = 3.9156 ft. The flow area and volume length are specified as input data while the volume size is not specified which will be calculated by the code using the volume length and flow area.

The Volume 22-01 is a vertical upward volume. The inclination angle is 90° and the elevation change is same as the volume length. The hydraulic diameter of the volume is not specified also and the code will calculate it.

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 30 OF 174 SHEETS
CALC NO. _____ STA-DAL R. D

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY HML BG DATE 1/1/96 CHECK BY _____ APPROVED BY _____

The initial water properties for Node 22 are given in Reference 1 as - pressure at 1021.14 psia, temperature at 547°F and void fraction of 1.0 (pure steam). Since there is no superheated steam in the steam generator, the steam in volume 22-01 must be saturated steam. For saturated steam, the RELAP5 code does not allow to specify both the water pressure and temperature. The steam pressure of TRANFLO Node 22 is used for this component. The initial water properties are specified as pressure at 1021.14 psia and the quality of 1.0.

The Junction 22-01 connects the outlet of Volume 22-01 to the inlet of Volume 21-01 which is corresponding to the Connector 26 of the TRANFLO model. As given in the Reference 1, the smallest flow area of the three segments of the Connector 26 is 12.828 ft² and a forward and reverse flow resistant coefficients of 0.84 and 0.47 are associated with this flow area.

The Junction 22-02 connects the inlet of Volume 22-01 to the inlet of Volume 32-01 which is corresponding to the Connector 27 of the TRANFLO model. The smaller of the two flow areas of Volumes 22-01 and 32-01 is 17.35 ft² which is used as the flow area for this junction. As given the Reference 1, flow resistance is specified for the segments 2 and 3 of the Connector 27, a forward and reverse flow resistant coefficient of 0.5 associated with a flow area of 30.579 ft² for segment 2 and a forward and

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 31 OF 174 SHEETS
CALC NO. _____ STA- 042 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY HM LGG DATE 10/1/96 CHECK BY _____ APPROVED BY _____

reverse flow resistant coefficient of 0.5 associated with a flow area of 18.579 ft² for segment 3. Therefore, for Junction 22-02, the flow resistant coefficient associated with the flow area of 17.35 ft² can be calculated as:

$$0.5/(30.579/17.35)^2 + 0.5/(18.579/17.35)^2 = 0.161 + 0.436 = 0.597$$

The Junction 22-03 connects the outlet of Volume 23-01 to the inlet of Volume 22-01 which is corresponding to the Connector 32 of the TRANFLO model. The smaller of the two flow areas of Volumes 23-01 and 22-01 is 41.73 ft² which is used as the flow area for this junction. As given the Reference 1, a forward and reverse flow resistant coefficient of 10.0 associated with a flow area of 44.768 ft² is specified for the segment 2 of the Connector 32. Therefore, for Junction 22-03, the flow resistant coefficient associated with the flow area of 41.73 ft² can be calculated as:

$$10.0/(44.768/41.73)^2 = 8.689$$

The following input are used for the Component 22.

| | | | | | | | | | | |
|---------|-----------|-----------|--------|------|------|--------|---------|-----|-------|--|
| 0220000 | speratr | separatr | | | | | | | | |
| 0220001 | 3 | 1 | | | | | | | | |
| 0220101 | 41.73 | 3.9156 | 0.0 | 0. | 90. | 3.9156 | 0.00015 | 0.0 | 00000 | |
| 0220200 | 2 | 1021.14 | 1.0 | | | | | | | |
| 0221101 | 022010000 | 021000000 | 12.828 | 0.84 | 0.47 | 000000 | | | | |

PACIFIC GAS AND ELECTRIC COMPANY
 GENERAL COMPUTATION SHEET

SHEET NO. 32 OF 176 SHEETS
 CALC NO. STA- 042 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
 MADE BY HML DATE 10/1/96 CHECK BY APPROVED BY

| | | | | | | |
|---------|-----------|-----------|-------|-------|-------|--------|
| 0222101 | 022000000 | 032000000 | 17.35 | 0.597 | 0.597 | 000000 |
| 0223101 | 023010000 | 022000000 | 41.73 | 8.689 | 8.689 | 000000 |
| 0221201 | 0.0 | 0.0 | 0.0 | | | |
| 0222201 | 0.0 | 0.0 | 0.0 | | | |
| 0223201 | 0.0 | 0.0 | 0.0 | | | |

Component 21

The Component 21 is a branch with assigned name abovspr which is used to model the region below the secondary separator and above the mid-deck plate and outside the drain pipes. This component consists of 1 volume (Volume 21-01) and 2 junctions (Junctions 21-01 and 21-02). The Volume 21-01 is corresponding the Node 21 of the TRANFLO model given in Reference 1. As given in the Table 4.2.2 of Reference 1, the flow area and volume size for the Node 21 are 152.19 ft² and 347.0 ft³. The volume length of Node 21 is 347.0/152.19 = 2.281 ft. The flow area and volume length are specified as input data while the volume size is not specified which will be calculated by the code using the volume length and flow area.

*HML 10/1/96
 LC 10/2/96
 HML 10/1/96
 LC 10/2/96*

The Volume 21-01 is a vertical upward volume. The inclination angle is 90° and the elevation change is same as the volume length. The hydraulic diameter of the volume is not specified also and the code will calculate it.

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 33 OF 174 SHEETS
CALC NO. STA- 002 R0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY HMC LEE DATE 10/1/96 CHECK BY APPROVED BY

The initial water properties for Node 21 are given in Reference 1 as - pressure at 1021.12 psia, temperature at 547°F and void fraction of 1.0 (pure steam). Since there is no superheated steam in the steam generator, the steam in volume 21-01 must be saturated steam. For saturated steam, the RELAP5 code does not allow to specify both the water pressure and temperature. The steam pressure of TRANFLO Node 21 is used for this component. The initial water properties are specified as pressure at 1021.12 psia and the quality of 1.0.

The Junction 21-01 connects the outlet of Volume 21-01 to the inlet of Volume 20-01 which is corresponding to the Connector 25 of the TRANFLO model. The smaller of the two flow areas of Volumes 21-01 and 20-01 is 70.75 ft² which is used as the flow area for this junction. As given in the Reference 1, no flow resistance is specified for the Connector 25. However, a abrupt flow area change is specified for the Connector 25. Therefore, a forward and reverse flow resistant coefficient of 0.0 is used for this junction and the junction control flag a is set to 1 to specify a abrupt area change at this junction.

The Junction 21-02 connects the inlet of Volume 21-01 to the inlet of Volume 53-01 which is corresponding to the Connector 41 of the TRANFLO model. As given in the Reference 1, the smallest flow area of the three segments of the Connector ~~26~~ is 7.96 ft² and a forward and reverse flow

41
HMC 10/1/96 rc 10/2/96

PACIFIC GAS AND ELECTRIC COMPANY
 GENERAL COMPUTATION SHEET

SHEET NO. 34 OF 74 SHEETS
 CALC NO. _____ STA-002 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
 MADE BY IAH LGG DATE 10/1/96 CHECK BY _____ APPROVED BY _____

resistant coefficients of 1.78 and 1.67 are associated with this flow area.

The following input are used for the Component 21.

| | | | | | | | | | |
|---------|-----------|-----------|-------|------|------|--------|---------|-----|---|
| 0210000 | abovspr | branch | | | | | | | |
| 0210001 | 2 | 1 | | | | | | | |
| 0210101 | 152.19 | 2.281 | 0.0 | 0. | 90. | 2.281 | 0.00015 | 0.0 | 00000 |
| 0210200 | 2 | 1021.12 | 1.0 | | | | | | |
| 0211101 | 021010000 | 020000000 | 70.75 | 0.0 | 0.0 | 000100 | | | <i>Lc 10/2/96</i> <i>IAH 10/1/96</i> |
| 0212101 | 021000000 | 053000000 | 7.96 | 1.78 | 1.67 | 000000 | | | |
| 0211201 | 0.0 | 0.0 | 0.0 | | | | | | |
| 0212201 | 0.0 | 0.0 | 0.0 | | | | | | |

Component 20

The Component 20 is a single volume with assigned name spsteam which is used to model the region outside the upper and lower secondary separator. This component consists of 1 volume (Volume 20-01). The Volume 20-01 is corresponding the Node 20 of the TRANFLO model given in Reference 1. As given in the Table 4.2.2 of Reference 1, the flow area and volume size for the Node 20 are 70.75 ft² and 527.1 ft³. The volume length of Node 20 is 527.1/70.75 = 7.4502 ft. The flow area and volume length are specified as input data while the volume size is not specified which will be calculated by the code using the volume length and flow area.

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 35 OF 174 SHEETS
CALC NO. STA-042 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY HA LEE DATE 0/1/96 CHECK BY _____ APPROVED BY _____

The Volume 20-01 is a vertical upward volume. The inclination angle is 90° and the elevation change is same as the volume length. The hydraulic diameter of the volume is not specified also and the code will calculate it.

The initial water properties for Node 20 are given in Reference 1 as - pressure at 1020.96 psia, temperature at 547°F and void fraction of 1.0 (pure steam). Since there is no superheated steam in the steam generator, the steam in volume 20-01 must be saturated steam. For saturated steam, the RELAP5 code does not allow to specify both the water pressure and temperature. The steam pressure of TRANFLO Node 20 is used for this component. The initial water properties are specified as pressure at 1020.96 psia and the quality of 1.0.

The following input are used for the Component 20.

```
0200000  spsteam  snglvol
0200101  70.75  7.4502  0.0  0.  90.  7.4502  0.00015  0.0  00000
0200200  2  1020.96  1.0
```

Component 19

The Component 19 is a separator with assigned name dryer which is used to model the region inside the secondary separator peerless vane banks.

This component consists of 1 volume (Volume 19-01) and 3 junctions

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 69 OF 174 SHEETS
CALC NO. STA-042 R.O

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

| | |
|--------|---------|
| 400.0 | 55.2607 |
| 600.0 | 54.9895 |
| 800.0 | 54.7069 |
| 1000.0 | 54.3982 |
| 1200.0 | 54.0907 |
| 1400.0 | 53.7516 |

Each of the primary side volume (Component 1) connects to one heat slab as the left boundary volume. The left boundary volumes for the heat slabs 1 to 60 are Volumes 1-01 to 1-60. Due to the U-shape tubes, each secondary side volume (Components 30 and 2) connects to two heat slabs as the right boundary volume, once to the hot-leg side tubes and once to the cold-leg side tubes. The right boundary volumes for the heat slabs 1 to 60 are Volumes 30-01, 2-01 to 2-29, 2-29 to 2-01 and 30-01. The heat transfer area for each heat slab is linearly dependent on the length of heat slab which is equal to the length of the left and right boundary volumes. The heat transfer area given for the Heat Connector 1 of the TRANFLO model, which is the heat transfer area for the left side of the heat Node 1, is 2874.2 ft² with the volume length of 50.5" (or 4.2083 ft) for Node 1. Therefore, the heat transfer area per foot of the primary side volume length can be calculated as $2874.2/4.2083 = 682.9$ ft². The heat transfer area to the left boundary volumes can be calculated as follows.

For Heat Slabs 1 and 60, the length of the left boundary Volumes 1-01 and

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO 68 OF 174 SHEETS
CALC NO. STA-042 R.O

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

transfer analysis. Then, the interval between all the 11 meshes equals to $0.00438/10 = 0.000438$ ft. Since the initial water temperature at both the primary and secondary sides of the tubes is 547°F , the initial temperatures of all 11 mesh points are 547°F .

As given in the Reference 1, the tube material is inconel 600. The thermal property of the inconel 600 is given in Reference 5 which is input to the RELAP5 model as an user specified table (for composite 1). The thermal conductivity and volumetric heat capacity of inconel 600 are listed as follows.

| Temperature ($^{\circ}\text{F}$) | Thermal Conductivity (btu/s* $\text{ft}^{\circ}\text{F}$) |
|------------------------------------|--|
| 70.0 | 2.3843e-03 |
| 200.0 | 2.5232e-03 |
| 400.0 | 2.8009e-03 |
| 600.0 | 3.0787e-03 |
| 800.0 | 3.3565e-03 |
| 1000.0 | 3.6574e-03 |
| 1200.0 | 3.9815e-03 |
| 1400.0 | 4.3056e-03 |

| Temperature ($^{\circ}\text{F}$) | Volumetric Heat Capacity (btu/ $\text{ft}^3^{\circ}\text{F}$) |
|------------------------------------|--|
| 70.0 | 55.6831 |
| 200.0 | 55.5227 |

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 67 OF 174 SHEETS
CALC NO. STA-042 R.O

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

| | | | | |
|---------|---------|-----------|--------|-----|
| 5010000 | prnout | tmdpjun | | |
| 5010101 | 1010000 | 101000000 | 10.956 | |
| 5010200 | 1 | | | |
| 5010201 | 0.0 | 9148.5 | 0.0 | 0.0 |
| 5010202 | 1.0e6 | 9148.5 | 0.0 | 0.0 |

Heat Slabs

The heat slabs are used to model the steam generator tubes and provide heat transfer from the primary side of the tubes to the secondary side of the tubes. There are total 60 heat slabs modeled. Each heat slab connects one primary side volume (Component 1) and one secondary side volume (Component 2). The hydraulic diameter for Volumes 1-01 to 1-60 is 0.0642 ft which is the inside diameter of the tubes. The inside radius of the tubes is 0.0321 ft. Therefore, the left boundary coordinate for each of the heat slabs is 0.0321 ft. The tube is cylindrical shape.

The mesh location is provided by the input. As given in the heat structure input for the TRANFLO model, the distance of heat transfer for each heat connector is 0.00219 ft which equals to the half of the tube thickness. The tube thickness is $2 * 0.00219 = 0.00438$ ft. In the RELAP5 model, 11 radial mesh points are used to model the tube wall for the heat

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 66 OF 74 SHEETS
CALC NO. STA-842 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY HMLCE DATE 12/1/96 CHECK BY _____ APPROVED BY _____

This component consists of 1 time dependent junction (Junction 500). The Junction 500 connects the Volume 100-01 to the Volume 1-01. The flow area of the junction equals to the flow area of the Volume 1-01 which is 10.956 ft². As discussed in the Section 2, a constant mass flow rate of 9148.5 lb/sec is assumed through the junction.

The following input are used for the Component 500.

| | | | | |
|---------|-----------|---------|--------|-----|
| 5000000 | prmin1 | tmdpjun | | |
| 5000101 | 100000000 | 1000000 | 10.956 | |
| 5000200 | 1 | | | |
| 5000201 | 0.0 | 9148.5 | 0.0 | 0.0 |
| 5000202 | 1.0e6 | 9148.5 | 0.0 | 0.0 |

Component 501

The Component 501 is a time-dependent junction with assigned name prmount which is used to provide constant flow out the primary side of the tubes. This component consists of 1 time dependent junction (Junction 501). The Junction 501 connects the Volume 1-60 to the Volume 101-01. The flow area of the junction equals to the flow area of the Volume 1-60 which is 10.956 ft². As discussed in the Section 2, a constant mass flow rate of 9148.5 lb/sec is assumed flow out the primary side of the tubes.

The following input are used for the Component 501.

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 65 OF 74 SHEETS
CALC NO. STA-062 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY HMLCE DATE 10/1/96 CHECK BY _____ APPROVED BY _____

dependent volume (Volume 101-01). Since the volume size and length of the Volume 100-01 does not affect the calculation, an arbitrary volume size of 5000 ft³ and an arbitrary volume length of 10 ft are used for the Volume 101-01.

Since the flow rate is controlled by the time dependent junctions, Components 500 and 501, the pressure of the Volume 101-01 does not affect on the primary side flow calculation. There is no reverse flow in the primary side of the tubes. The temperature does not have any impact on the calculation. Therefore, the pressure in the volume 101-01 is set at slightly lower the pressure at the Volume 100-01 and the temperature of the Volume 101-01 is set at the same temperature of the Volume 100-01.

The following input are used for the Component 101.

| | | | | | | | | | |
|---------|---------|---------|--------|-----|-----|-----|-----|-----|---|
| 1010000 | outplen | tmdpvol | | | | | | | |
| 1010101 | 0.0 | 10.0 | 5000.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 |
| 1010200 | 3 | | | | | | | | |
| 1010201 | 0.0 | 2200.0 | 547.0 | | | | | | |
| 1010202 | 5.0 | 2200.0 | 547.0 | | | | | | |
| 1010203 | 15.0 | 700.0 | 491.0 | | | | | | |

Component 500

The Component 500 is a time-dependent junction with assigned name prmin1 which is used to provide constant flow to the primary side of the tubes.

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 64 OF 114 SHEETS
CALC NO. _____ STA-022 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H.M. CBB DATE 6/1/96 CHECK BY _____ APPROVED BY _____

the primary water pressure during the transient run. In addition, since the primary water flow rate is fixed by the time dependent junctions, the primary side pressure has negligible effect on the heat transfer calculation. Therefore, this discrepancy has no impact on this analysis.

As given in the Reference 1, the primary water temperature is 547°F at the initiation of the steam line break and the temperature then is reduced by 112°F in 20 seconds or 56°F in 10 seconds. The temperature for Volume 100-01 is specified as 547°F from time 0.0 second to 5.0 seconds (steady state run) and then reduced to 491°F at time 15 seconds.

The following input are used for the Component 100.

| | | | | | | | | | |
|---------|--------|---------|--------|-----|-----|-----|-----|-----|---|
| 1000000 | inplen | tmdpvol | | | | | | | |
| 1000101 | 0.0 | 10.0 | 5000.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 |
| 1000200 | 3 | | | | | | | | |
| 1000201 | 0.0 | 2235.7 | 547.0 | | | | | | |
| 1000202 | 5.0 | 2250.0 | 547.0 | | | | | | |
| 1000203 | 15.0 | 800.0 | 491.0 | | | | | | |

Component 101

The Component 101 is a time-dependent volume with assigned name outplen which is used as a mass sink. This component consists of 1 time

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 63 OF 176 SHEETS
CALC NO. STA-002 R10

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M LEE DATE 10/1/96 CHECK BY _____ APPROVED BY _____

0011301 9148.5 0.0 0.0 59

Component 100

The Component 100 is a time-dependent volume with assigned name inplen which is used as a mass source at preset condition for the primary side tubes (Component 1). This component consists of 1 time dependent volume (Volume 100-01). Since the volume size and length of the Volume 100-01 does not affect the calculation, an arbitrary volume size of 5000 ft³ and an arbitrary volume length of 10 ft are used for the Volume 100-01.

Since the flow rate is controlled by the time dependent junctions, Components 500 and 501, the pressure of the Volume 100-01 does not affect on the primary side flow calculation. As given in the Reference 1, the primary side pressure is 2250 psia at the initiation of the steam line break and the primary side pressure is reduced by 1450 psi in 10 seconds. Since the steam line break is initiated at 5 seconds in the RELAP5 analysis, the time history for the pressure is set at 2250 psia for the first 5 seconds of the run and then reduced to 800 psia in the next 10 seconds. A pressure of 2235.7 psia instead of 2250 psia is input for the Volume 100-01 at 0.0 second. The pressure is increased to 2250 psia at 5 seconds and then reduced to 800 psia from 5 seconds to 15 seconds as the pressure specified in the TRANFLO model. This slightly lower primary side water pressure during the 5 seconds steady state run does not affect

PACIFIC GAS AND ELECTRIC COMPANY
 GENERAL COMPUTATION SHEET

SHEET NO. 62 OF 174 SHEETS
 CALC NO. STA-042 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident

MADE BY HML DATE 10/1/96 CHECK BY _____ APPROVED BY _____

| | | | | | | | | | |
|---------|---------|--------------------|-------|-----|-----|-----|-----|----|--|
| 0010316 | 3.0 | 31 | | | | | | | |
| 0010317 | 0.5 | 33 | | | | | | | |
| 0010318 | 1.60435 | 35 | | | | | | | |
| 0010319 | 0.5 | 37 | | | | | | | |
| 0010320 | 1.60435 | 39 | | | | | | | |
| 0010321 | 0.5 | 41 | | | | | | | |
| 0010322 | 1.60435 | 43 | | | | | | | |
| 0010323 | 0.5 | 45 | | | | | | | |
| 0010324 | 1.60435 | 47 | | | | | | | |
| 0010325 | 0.5 | 49 | | | | | | | |
| 0010326 | 1.60435 | 51 | | | | | | | |
| 0010327 | 0.5 | 53 | | | | | | | |
| 0010328 | 1.60435 | 55 | | | | | | | |
| 0010329 | 0.5 | 57 | | | | | | | |
| 0010329 | 1.2553 | 59 | | | | | | | |
| 0010330 | 1.1667 | 60 | | | | | | | |
| 0010601 | 90.0 | 30 | | | | | | | |
| 0010602 | -90.0 | 60 | | | | | | | |
| 0010801 | 0.0 | 0.0642 | 60 | | | | | | |
| 0011001 | 00000 | 60 | | | | | | | |
| 0011101 | 000000 | 59 | | | | | | | |
| 0011201 | 3 | ² 250.0 | 547.0 | 0.0 | 0.0 | 0.0 | 0.0 | 60 | |
| 0011300 | 1 | | | | | | | | |

HML 10/1/96
 PC 10/2/96

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 61 OF 174 SHEETS
CALC NO. STA-002 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY HML/EE DATE 10/1/96 CHECK BY _____ APPROVED BY _____

junctions. As discussed in Section 4, a constant primary side mass flow rate of 9148.5 lb/sec is assumed. The initial mass flow rate of 9148.5 lb/sec is used for all the 59 junctions.

The following input are used for the Component ~~3~~.

1
HML 10/1/96
to 10/2/96

| | | |
|---------|---------|------|
| 0010000 | tubes | pipe |
| 0010001 | 60 | |
| 0010101 | 10.956 | 60 |
| 0010301 | 1.1667 | 1 |
| 0010302 | 1.2553 | 3 |
| 0010303 | 0.5 | 5 |
| 0010304 | 1.60435 | 7 |
| 0010305 | 0.5 | 9 |
| 0010306 | 1.60435 | 11 |
| 0010307 | 0.5 | 13 |
| 0010308 | 1.60435 | 15 |
| 0010309 | 0.5 | 17 |
| 0010310 | 1.60435 | 19 |
| 0010311 | 0.5 | 21 |
| 0010312 | 1.60435 | 23 |
| 0010313 | 0.5 | 25 |
| 0010314 | 1.60435 | 27 |
| 0010315 | 0.5 | 29 |

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 60 OF 174 SHEETS
CALC NO. STA-042 R. 0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY HM LEE DATE 10/1/96 CHECK BY _____ APPROVED BY _____

Volume 2-29. This small discrepancy does not have significant effect on the total heat transfer from the primary side to the secondary side and the effect on the loads on the TSPs is negligible.

The Volumes 1-01 to 1-30 are vertical upward volumes. The inclination angles are 90° and the elevation changes are same as the volume lengths. The Volumes 1-30 to 1-60 are vertical downward volumes. The inclination angles are -90° and the elevation changes are same as the volume lengths. The TRANFLO code specifies the hydraulic diameter of a control volume in the input for a connector. The hydraulic diameter of 0.0642 ft is specified for the Connectors 1 to 17 of the TRANFLO model. The same hydraulic diameter is used for the volumes 1-01 to 1-60. Since a constant flow rate is assumed for the primary side of the tubes during the entire transient, the friction loss in the primary side of the tubes is not important. A smooth wall is assumed for the Volumes 1-01 to 1-60. The initial pressure of 2250 psia and temperature of 547 °F are used for the Node 1 to 16 of the TRANFLO model, the same initial pressure and temperature are used for the Volumes 1-01 to 1-60.

There are 59 junctions, Junctions 1-01 to 1-59, used in the Component 1 to connect the 60 volumes of the Component 1. The junction flow area for the 59 junctions is same as the flow area for the volumes which is 10.956 ft². Since the tubes are smooth, no flow resistance is used for the

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 59 OF 176 SHEETS
CALC NO. STA-042 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY IFMLBE DATE 10/1/96 CHECK BY _____ APPROVED BY _____

The length of Volumes 1-10 and 1-51 equals to the length of Volume 2-09.
The length of Volumes 1-11 and 1-50 equals to the length of Volume 2-10.
The length of Volumes 1-12 and 1-49 equals to the length of Volume 2-11.
The length of Volumes 1-13 and 1-48 equals to the length of Volume 2-12.
The length of Volumes 1-14 and 1-47 equals to the length of Volume 2-13.
The length of Volumes 1-15 and 1-46 equals to the length of Volume 2-14.
The length of Volumes 1-16 and 1-45 equals to the length of Volume 2-15.
The length of Volumes 1-17 and 1-44 equals to the length of Volume 2-16.
The length of Volumes 1-18 and 1-43 equals to the length of Volume 2-17.
The length of Volumes 1-19 and 1-42 equals to the length of Volume 2-18.
The length of Volumes 1-20 and 1-41 equals to the length of Volume 2-19.
The length of Volumes 1-21 and 1-40 equals to the length of Volume 2-20.
The length of Volumes 1-22 and 1-39 equals to the length of Volume 2-21.
The length of Volumes 1-23 and 1-38 equals to the length of Volume 2-22.
The length of Volumes 1-24 and 1-37 equals to the length of Volume 2-23.
The length of Volumes 1-25 and 1-36 equals to the length of Volume 2-24.
The length of Volumes 1-26 and 1-35 equals to the length of Volume 2-25.
The length of Volumes 1-27 and 1-34 equals to the length of Volume 2-26.
The length of Volumes 1-28 and 1-33 equals to the length of Volume 2-27.
The length of Volumes 1-29 and 1-32 equals to the length of Volume 2-28.
The length of Volumes 1-30 and 1-31 equals to the length of Volume 2-29.
However, a volume length of 3.0 ft is input for the Volumes 1-30 and 1-31
which is slightly shorter than the volume length of 3.2075 ft for the

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO 50 OF 74 SHEETS
CALC NO. STA-642 R.O

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY HALGG DATE 10/1/96 CHECK BY _____ APPROVED BY _____

30 volumes (Volumes 30-01, 2-01 to 2-29). There is no heat transfer from primary side to secondary side is modeled for the Volume 2-30. Since the U-tubes are used in the Model 51 steam generator, 60 volumes (Volumes 1-01 to 1-60) are needed to model the primary side of the tubes which are included in the Component 1. To connect the 60 volumes, 59 junctions (Junction 1-01 to 1-59) are also included in the Component 1.

The flow area for the primary side of the tubes used in the TRANFLO model can be calculated as the volume size of Node 1 (46.11 ft³) divided by the flow length of Node 1 (50.5" or 4.2083 ft): $46.11/4.2083 = 10.956 \text{ ft}^2$. This flow area is used for all the volumes of the Component 1. To achieve correct heat transfer from the primary side to the secondary side, the volume lengths of Volumes 1-01 to 1-60 have to be same as the following volumes:

The length of Volumes 1-01 and 1-60 equals to the length of Volume 30-01.
The length of Volumes 1-02 and 1-59 equals to the length of Volume 2-01.
The length of Volumes 1-03 and 1-58 equals to the length of Volume 2-02.
The length of Volumes 1-04 and 1-57 equals to the length of Volume 2-03.
The length of Volumes 1-05 and 1-56 equals to the length of Volume 2-04.
The length of Volumes 1-06 and 1-55 equals to the length of Volume 2-05.
The length of Volumes 1-07 and 1-54 equals to the length of Volume 2-06.
The length of Volumes 1-08 and 1-53 equals to the length of Volume 2-07.
The length of Volumes 1-09 and 1-52 equals to the length of Volume 2-08.

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 57 OF 174 SHEETS
CALC NO. STA-042 R.0

SUBJECT . Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H.M. LEE DATE 12/1/96 CHECK BY _____ APPROVED BY _____

the high loads on the TSPs only last less than 1 second after the steam line break is initiated, the heat added to the secondary side is very small during that period which does not have significant effect on the analysis results. Therefore, accurate modeling of the primary loop is not required.

As discussed in Section 2, a constant mass flow through the primary side of the tubes during the entire transient is assumed. To achieve the constant mass flow in the primary loop, two time dependent junction, Components 500 and 501, are used to provide constant mass flow rate through the entire transient. The Component 100 is used as a mass source while the Component 101 is used a mass sink. The Component 1 is used to model the primary side of the tubes.

Component 1

The Component 1 is a Pipe with assigned name tubes which is used to model the region inside (primary side) the steam generator tubes. In the TRANFLO model, the primary side of the steam generator tubes is modeled by the Nodes 1 to 16 and the Connectors 2 to 16. In the RELAP5 model, To provide correct heat transfer from primary side to the secondary side, the lengths of the volumes modeling the primary side have to be same as the lengths of the volumes modeling the secondary side of the tube region. The secondary side of the steam generator tubes are modeled by

PACIFIC GAS AND ELECTRIC COMPANY
 GENERAL COMPUTATION SHEET

SHEET NO. 56 OF 174 SHEETS
 CALC NO. STA-002 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
 MADE BY HML DATE 10/1/96 CHECK BY _____ APPROVED BY _____

The following input are used for the Component 33.

*5 HML 10/1/96
 re 10/2/96*

*HML
 10/1/96
 re 10/2/96*

| | | | | | | | |
|----------------------|---------|---------|-------|-----|-----|-----|---|
| 0350000 | downc | pipe | | | | | |
| ³ 0350001 | 3 | | | | | | |
| 0350101 | 0.0 | 3 | | | | | |
| 0350201 | 7.096 | 2 | | | | | |
| 0350301 | 11.827 | 3 | | | | | |
| 0350401 | 122.4 | 3 | | | | | |
| 0350601 | -90.0 | 3 | | | | | |
| 0350801 | 0.00015 | 0.4275 | 3 | | | | |
| 0351001 | 00000 | 3 | | | | | |
| 0351101 | 000000 | 2 | | | | | |
| 0351201 | 3 | 1024.84 | 547.0 | 0.0 | 0.0 | 0.0 | 1 |
| 0351202 | 3 | 1028.64 | 547.0 | 0.0 | 0.0 | 0.0 | 2 |
| 0351203 | 3 | 1032.44 | 547.0 | 0.0 | 0.0 | 0.0 | 3 |
| 0351300 | 1 | | | | | | |
| 0351301 | 0.0 | 0.0 | 0.0 | 2 | | | |

Primary Loop

The primary loop includes the components 1, 100, 101, 500 and 501. A schematic of the secondary loop is shown in the Figure 5-3. The primary loop is only used to provide heat source to the secondary side. Since

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 55 OF 174 SHEETS
CALC NO. STA-042 R, 0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY HML DATE 10/1/96 CHECK BY _____ APPROVED BY _____

used for the Volumes 35-01, 35-02 and 35-03. The initial pressure in the Volumes 35-01, 35-02 and 35-03 can be calculated as:

The initial pressure at the center of the Volume 30-01 = 1034.15 psia

The elevation increase from the center of the Volume 30-01 to the center of the Volume 35-03 = $11.827/2 - 1.1667/2 = 5.3302$ ft.

As calculated for the Component 2, the water static pressure reduces $46.17/144 = 0.3206$ psi for every foot elevation increase. Then, the initial pressure at the center of the Volume 35-03 is $1034.15 - 0.3206 * 5.3302 = 1032.44$ psia.

The elevation increase from the center of the Volume 30-03 to 30-02 or from the center of The Volume 30-02 to 30-01 is 11.827 ft. Then, the initial pressure at the center of the Volume 30-02 is $1032.44 - 0.3206 * 11.827 = 1028.64$ psia and the initial pressure at the center of the Volume 30-01 is $1028.64 - 0.3206 * 11.827 = 1024.84$ psia.

The Junction 35-01 connects the Volume 35-01 to the Volume 35-02 and the Junction 35-02 connects the Volume 35-02 to the Volume 35-03. Since the majority portion of the downcomer has flow area of 7.096 ft², the flow area of the Junctions 35-01 and 35-02 is set to be 7.096 ft². There is no abrupt area change and flow element in the downcomer. Therefore, no flow resistance is specified for the Junctions 35-01 and 35-02. The smooth area change is also used for these junctions.

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 59 OF 174 SHEETS
CALC NO. STA-042 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY HMLGG DATE 10/1/96 CHECK BY _____ APPROVED BY _____

The reason is the flow area in the downcomer region is not constant and the flow area of 7.096 ft² only represents the majority portion of the downcomer. Since the propagation of the depressurization wave due to steam line break has significant effects on this analysis, the volume length has to be preserved. The initial water inventory in the steam generator also affects the analysis. Therefore, the downcomer length and volume are preserved in this analysis. The volume length for each of the three volumes can be calculated as $35.48/3 = 11.827$ ft. The volume size for each of the three volumes can be calculated as $367.2/3 = 122.4$ ft³.
The volume length and size are specified as input data while the flow area is not specified which will be calculated by the code using the volume length and size.

*HML
10/1/96
LC
10/2/96*

The Volumes 35-01, 35-02 and 35-03 are vertical downward volumes. The inclination angles are -90° and the elevation changes are same as the volume lengths. The TRANFLO code specifies the hydraulic diameter of a control volume in the input for a connector. The hydraulic diameter of 0.4275 ft is used for the segment 1 of the Connectors 30 and 31 and segment 2 of the Connectors 29 and 43 of the TRANFLO model. The same hydraulic diameter is used for the volumes 35-01, 35-02 and 35-03.

As given in Reference 1, the Nodes 35 and 37 of the TRANFLO model contain single phase water initially. The water temperature is 547 °F which is

PACIFIC GAS AND ELECTRIC COMPANY
 GENERAL COMPUTATION SHEET

SHEET NO 53 OF 174 SHEETS
 CALC NO. STA-042 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident

MADE BY HMLBB DATE 10/1/96 CHECK BY _____ APPROVED BY _____

The Junction 34-01 connects the outlet of Volume 34-01 to the inlet of Volume 35-01. Since the Nodes 35 and 37 of TRANFLO model are combined in the RELAP5 model, the Junction 34-01 is corresponding to the combination of the Connectors 29 and 43. The smaller of the two flow areas of Volumes 34-01 and 35-01 is 7.096 ft² which is used as the flow area for this junction. As given the Reference 1, no flow resistance is specified for the Connectors 29 and 43. However, an abrupt area change is specified for the Connectors 29 and 43. Therefore, the forward and reverse flow resistant coefficient of 0.0 is used for this junction and the control flag a is set to 1 to specify an abrupt area change at this junction.

The following input are used for the Component 34.

HML 10/1/96
LC 10/2/96

| | | | | | | | | | |
|---------|-----------|-----------|-------|-----|------|---------|---------|-----|-------|
| 0340000 | feedrg | branch | | | | | | | |
| 0340001 | 1 | 1 | | | | | | | |
| 0340101 | 92.1 | 3.1097 | 0.0 | 0. | -90. | -3.1097 | 0.00015 | 0.0 | 00000 |
| 0340200 | 3 | 1022.48 | 547.0 | | | | | | |
| 0341101 | 034010000 | 035000000 | 7.096 | 0.0 | 0.0 | | 000100 | | |
| 0341201 | 0.0 | 0.0 | 0.0 | | | | | | |

HML 10/1/96
LC 10/2/96
HML 10/1/96
LC 10/2/96

Component 35

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 52 OF 174 SHEETS
CALC NO. STA-042 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H.M. LEE DATE 10/1/96 CHECK BY _____ APPROVED BY _____

The Component 35 is a Pipe with assigned name downc which is used to model the downcomer region. In the TRANFLO model, the downcomer region is modeled by two Nodes, Node 35 for hot-leg downcomer and Node 37 for cold-leg downcomer. Since the feedwater is not included in the RELAP5 model and the heat transfer from primary side to the secondary side is insignificant for this analysis due to the short duration, the Nodes 35 and 37 of the TRANFLO model are combined in the RELAP5 model. However, due to the long length of the downcomer, the downcomer region is separated into three volumes with equal the volume lengths. There are 3 volumes (Volumes 35-01, 35-02 and 35-03) and 2 junctions (Junctions 35-01 and 35-02) included in the Component 35.

As given in the Reference 1, the combined flow area of the Nodes 35 and 37 of the TRANFLO model is $3.548 * 2 = 7.096 \text{ ft}^2$. The combined volume size of the Nodes 35 and 37 of the TRANFLO model is $183.6 * 2 = 367.2 \text{ ft}^3$. The segment 1 of the Connectors 30 and 31 and segment 2 of the Connectors 29 and 43 have the same segment length of 17.74 ft. This indicates that the half of the downcomer length (or the volume lengths for Nodes 35 and 37) is 17.74 ft and the downcomer length is $2 * 17.74 = 35.48 \text{ ft}$. However, a discrepancy is noticed. The volume size based on the combined flow area of 7.096 ft^2 for the Nodes 35 and 37 and volume length of 35.48 ft is $7.096 * 35.48 = 251.77 \text{ ft}^3$ which is smaller than the combined size of the Nodes 35 and 37 as given in the Reference 1.

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO 51 OF 176 SHEETS
CALC NO. STA-042 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H.M. LEE DATE 10/1/96 CHECK BY _____ APPROVED BY _____

0332201 0.0 0.0 0.0

Component 34

The Component 34 is a branch with assigned name feedrg which is used to model the region from feeding to top of the tube sheet downcomer, the region outside feeding and primary separator risers. This component consists of 1 volume (Volume 34-01) and 1 junction (Junctions 34-01). The Volume 34-01 is corresponding the Node 34 of the TRANFLO model given in Reference 1. As given in the Table 4.2.2 of Reference 1, the flow area and volume size for the Node 34 are 92.1 ft² and 286.4 ft³. The volume length of Node 36 is $286.4/92.1 = 3.1097$ ft. The flow area and volume length are specified as input data while the volume size is not specified which will be calculated by the code using the volume length and flow area.

The Volume 34-01 is a vertical downward volume. The inclination angle is -90° and the elevation change is same as the volume length. The hydraulic diameter of the volume is not specified also and the code will calculate it.

The initial water properties for the Node 34 of the TRANFLO model are single phase liquid at pressure of 1022.48 psia and temperature of 547 °F which are also used for the Volume 34-01.

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 50 OF 174 SHEETS
CALC NO. STA-042 R. 0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY HM LEE DATE 10/1/96 CHECK BY _____ APPROVED BY _____

Volume 33-01 which is corresponding to the Connector 28 of the TRANFLO model. The smaller of the two flow areas of Volumes 32-01 and 33-01 is 17.35 ft² which is used as the flow area for this junction. As given the Reference 1, no flow resistance is specified for the Connector 28. Therefore, the forward and reverse flow resistant coefficient of 0.0 is used for this junction.

The Junction 33-02 connects the outlet of Volume 33-01 to the inlet of Volume 34-01 which is corresponding to the Connector 23 of the TRANFLO model. As given in the Reference 1, the smallest flow area of the two segments of the Connector 23 is 79.288 ft² which is used as the flow area for this junction. As given the Reference 1, no flow resistance is specified for the Connector 23. Therefore, a forward and reverse flow resistant coefficient of 0.0 is used for this junction.

The following input are used for the Component 33.

| | | | | | | | | | | |
|---------|-----------|-----------|--------|-----|------|---------|---------|-----|-------|--|
| 0330000 | abovf1 | branch | | | | | | | | |
| 0330001 | 2 | 1 | | | | | | | | |
| 0330101 | 100.79 | 2.9225 | 0.0 | 0. | -90. | -2.9225 | 0.00015 | 0.0 | 00000 | |
| 0330200 | 2 | 1021.72 | 0.73 | | | | | | | |
| 0331101 | 032010000 | 033000000 | 17.35 | 0.0 | 0.0 | | 000000 | | | |
| 0332101 | 033010000 | 034000000 | 79.288 | 0.0 | 0.0 | | 000000 | | | |
| 0331201 | 0.0 | 0.0 | 0.0 | | | | | | | |

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 49 OF 174 SHEETS
CALC NO. STA-042 R, 0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY HMLGG DATE 10/1/96 CHECK BY _____ APPROVED BY _____

The Component 33 is a branch with assigned name abovf1 which is used to model the lower portion of the region below the mid-deck plate and above the feedring including the region outside the drain pipes, separator downcomer and separator riser. This component consists of 1 volume (Volume 33-01) and 2 junctions (Junctions 33-01 and 33-02). The Volume 33-01 is corresponding the lower part of Node 33 of the TRANFLO model given in Reference 1. The flow area of Volume 33-01 is 100.7 ft² which is same as the flow area for Volume 53 or the Node 33 of TRANFLO model. As discussed for the Component 53, the volume length of Volume 33-01 should be 2.9225 ft. The flow area and volume length are specified as input data while the volume size is not specified which will be calculated by the code using the volume length and flow area.

The Volume 33-01 is a vertical downward volume. The inclination angle is -90° and the elevation change is same as the volume length. The hydraulic diameter of the volume is not specified also and the code will calculate it.

The initial water properties for Volume 33-01 are same as those for the Volume 53-01 which are two-phase water at pressure of 1021.72 psia and quality of 0.73.

The Junction 33-01 connects the outlet of Volume 32-01 to the inlet of

PACIFIC GAS AND ELECTRIC COMPANY
 GENERAL COMPUTATION SHEET

SHEET NO. 48 OF 174 SHEETS
 CALC NO. STA-002 R, 0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
 MADE BY HML DATE 10/1/96 CHECK BY _____ APPROVED BY _____

model. The smaller of the two flow areas of Volumes 36-01 and 53-01 is 2.34 ft² which is used as the flow area for this junction. As given the Reference 1, a forward and reverse flow resistant coefficient of 0.5 associated with a flow area of 2.34 ft² for segment 1 of the Connector 22 which is also used for the Junction 53-01.

The Junction 53-02 connects the outlet of Volume 53-01 to the inlet of Volume 33-01. This junction is created due to splitting the Node 33 of TRANFLO model into two volumes in RELAP5 model. There is no connector in the TRANFLO model corresponding to this junction. The flow area of this junction is same as the flow area of the Volumes 53-01 and 33-01 (100.7 ft²) and no flow resistance is specified for this junction.

The following input are used for the Component 53.

```

0530000  abovfr2  branch
0530001  2      1
0530101  100.70 3.9156 0.0 0. -90. -3.9156 0.00015 0.0 00000
0530200  2      1021.72 0.73
0531101  036010000 053000000 2.34 0.5 0.5 000000
0532101  053010000 033000000 100.7 0.0 0.0 000000
0531201  0.0 0.0 0.0
0532201  0.0 0.0 0.0
  
```

Component 33

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 47 OF 174 SHEETS
CALC NO. STA- 042 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY HML EE DATE 10/1/96 CHECK BY APPROVED BY

$688.6/100.7 = 6.8381$ ft. The top 3.9156 portion of the volume length for Node 33 is used for the Volume 53-01. Then, the remaining 2.9225 ft of the volume length for Node 33 is used for the volume length of Volume 33-01. The flow area and volume length are specified as input data while the volume size is not specified which will be calculated by the code using the volume length and flow area.

The Volume 53-01 is a vertical downward volume. The inclination angle is -90° and the elevation change is same as the volume length. The hydraulic diameter of the volume is not specified also and the code will calculate it.

The initial water properties for Node 33 are given in Reference 1 as - pressure at 1021.72 psia, temperature at 547°F and void fraction of 0.73. For a two-phase water, the RELAP5 code does not allow to specify both the water pressure and temperature. The pressure of TRANFLO Node 33 is used for this component. As discussed for the Component 23, the void fraction of 0.73 is used in the RELAP5 analysis as quality for this volume. The initial water properties are specified as pressure at 1021.72 psia and the quality of 0.73.

The Junction 53-01 connects the outlet of Volume 36-01 to the inlet of Volume 53-01 which is corresponding to the Connector 22 of the TRANFLO

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 46 OF 174 SHEETS
CALC NO. STA-092 R. 0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY HML DATE 10/1/96 CHECK BY _____ APPROVED BY _____

Component 53

The Component 53 is a branch with assigned name abovfr2 which is used to model the upper portion of the region below the mid-deck plate and above the feedring including the region outside the drain pipes, separator downcomer and separator riser. This component consists of 1 volume (Volume 53-01) and 2 junctions (Junctions 53-01 and 53-02). The Volume 53-01 is corresponding the upper part of Node 33 of the TRANFLO model given in Reference 1. Since the RELAP5 code only allows the junctions located either at the inlet of the volume or the outlet of the volume, the Node 33 of TRANFLO model has to be separated to two volumes in the RELAP5 model, Volumes 53-01 and 33-01. Otherwise, the drain water from the primary separator (Component 22) can not be connected to the drain return at the correct elevation. As given in the Table 4.2.2 of Reference 1, the flow area and volume size for the Node 33 are 100.7 ft² and 688.6 ft³. The elevation of the drain water outlet junction from the primary separator (Junction 22-01) is at 39.7188 ft above the center of Volume 2-01 (as given in the output of the RELAP5 analysis) which is same as the elevation of the outlet of the Volume 32-01 (or Junction 33-01). The elevation at the outlet of the Volume 36 (Junction 53-01) is 43.6344 ft above the center of the Volume 2-01. Therefore, to make the elevation at the outlet of the Volume 53-01 (or Junction 53-02) at 39.7188 ft above the center of the Volume 2-01, the volume length for the Volume 53 has to be $43.6344 - 39.7188 = 3.9156$ ft. The volume length of Node 36 is

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 45 OF 174 SHEETS
CALC NO. STA-042 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY IM CEE DATE 1/1/96 CHECK BY _____ APPROVED BY _____

significant effects on the analysis. The flow area and volume length are specified as input data while the volume size is not specified which will be calculated by the code using the volume length and flow area input.

The Volume 36-01 is a vertical downward volume. The inclination angle is -90° and the elevation change is same as the volume length. The hydraulic diameter of the volume is not specified also and the code will calculate it.

The initial water properties for Node 36 are given in Reference 1 as - pressure at 1021.57 psia, temperature at 547°F and void fraction of 0.82. For a two-phase water, the RELAP5 code does not allow to specify both the water pressure and temperature. The pressure of TRANFLO Node 36 is used for this component. As discussed for the Component 23, the void fraction of 0.82 is used in the RELAP5 analysis as quality for this volume. The initial water properties are specified as pressure at 1021.57 psia and the quality of 0.82.

The following input are used for the Component 36.

```
0360000  spsteam  snglvol
0360101  2.34  9.7312  0.0  0.  -90.  -9.7312  0.00015  0.0  00000
0200200  2  1021.57  0.82
```

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 44 OF 174 SHEETS
CALC NO. STA-042 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY HM LEE DATE 12/1/96 CHECK BY _____ APPROVED BY _____

Since the steam flow through is break is chocked through the entire transient, the initial condition for the Volume 38-01 does not affect the analysis. Saturated steam at atmospherical pressure (14.7 psia) is assumed for the Volume 38-01.

The following input are used for the Component 38.

```
0380000  contnm  snglvol
0380101  10000.0  200.0  0.0  0.0  90.0  200.0  0.00015  0.0  00000
0380200  2  14.7  1.0
```

Component 36

The Component 36 is a single volume with assigned name dsdryer which is used to model the secondary separator drain pipes. This component consists of 1 volume (Volume 36-01). The Volume 36-01 is corresponding the Node 36 of the TRANFLO model given in Reference 1. As given in the Table 4.2.2 of Reference 1, the flow area and volume size for the Node 36 are 2.34 ft² and 22.83 ft³. The volume length of Node 36 is $22.83/2.34 = 9.7564$ ft. However, since the TRANFLO code does not require perfect elevation match for its Nodes, the use of the volume length of 9.7564 ft causes a small elevation discrepancy at the junction connects the Volume 36-01. Therefore, the volume length of 9.7312 ft is used ^{for} the Volume 36-01 (equivalent 0.059 ft³ volume reduction). The small volume length discrepancy on the water drain return from the dryer does not cause any

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 43 OF 74 SHEETS
CALC NO. STA-002 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY HM CEG DATE 10/1/96 CHECK BY _____ APPROVED BY _____

The following input are used for the Component 518.

| | | | | | | | |
|---------|-----------|-----------|--------|-----|-----|--------|--|
| 5180000 | break | valve | | | | | |
| 5180101 | 017010000 | 038000000 | 4.6 | 0.0 | 0.0 | 000100 | |
| 5180110 | 0.0 | 0.0 | 1.0 | 1.0 | | | |
| 5180201 | 1 | 0.0 | 0.0 | 0.0 | | | |
| 5180300 | mtrv1v | | | | | | |
| 5180301 | 502 | 503 | 1000.0 | 0.0 | | | |

Component 38

The Component 38 is a single volume with assigned name contnm which is used to provide a mass sink for steam blowdown after the break is initiated. This component consists of 1 volume (Volume 38-01). Since the steam flow through the break is choked through the entire transient, a arbitrary large flow area of 10000.0 ft² and volume length of 200.0 ft are used. The flow area and volume length are specified as input data while the volume size is not specified which will be calculated by the code using the volume length and flow area.

The Volume 38-01 is a vertical upward volume. The inclination angle is 90° and the elevation change is same as the volume length. The hydraulic diameter of the volume is not specified also and the code will calculate it.

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 42 OF 174 SHEETS
CALC NO. STA-042 R, 0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY HM LEE DATE 10/1/96 CHECK BY _____ APPROVED BY _____

The Component 518 is a valve junction with assigned name break which is used to simulate the steam line break. This component consists of 1 valve junction (Junction 518) which provides a flow control from the Volume 17-01 (Component 17) to the Volume 38-01 (Component 38). The Junction 518 is corresponding the Connector 18 of the TRANFLO model given in Reference 1.

For this case, the location of the steam line break is assumed at the steam nozzle which has an inside diameter of 29" (Ref. 7). The flow area of the Junction 518 can be calculated as $(29/24)^2 * 3.1416 = 4.6 \text{ ft}^2$. Since the flow through this junction is always choked during the entire transient, no flow resistance is assigned to this junction. However, an abrupt area change at this junction is used by setting the junction control flag a to 1. The RELAP5 motor valve is ^{used} ~~used~~ to simulate the initiation of the steam line break. The Trip 502 is set to open the motor valve (Initiate steam line break). The valve is initially closed and no steam is ^{blown} ~~blow~~ out from the steam generator until the Trip 502 is tripped. Since it is assumed the steam line breaks open at very high speed, a 0.001 second valve opening time (or a valve change rate of 1000 second⁻¹) is assumed. The Trip 503 is set to close the motor valve. Since the steam line break can not be terminated, an arbitrary long time is used for the Trip 503.

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 41 OF 76 SHEETS
CALC NO. STA-042 R, 0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY HM CEG DATE 10/1/96 CHECK BY _____ APPROVED BY _____

as input data while the volume size is not specified which will be calculated by the code using the volume length and flow area.

The Volume 17-01 is a vertical upward volume. The inclination angle is 90° and the elevation change is same as the volume length. The hydraulic diameter of the volume is not specified also and the code will calculate it.

The initial water properties for Node 17 are given in Reference 1 as - pressure at 1020.94 psia, temperature at 547°F and void fraction of 1.0 (pure steam). Since there is no superheated steam in the steam generator, the steam in volume 17-01 must be saturated steam. For saturated steam, the RELAP5 code does not allow to specify both the water pressure and temperature. The steam pressure of TRANFLO Node 17 is used for this component. The initial water properties are specified as pressure at 1020.94 psia and the quality of 1.0.

The following input are used for the Component 17.

```
0170000  sgdoom  snglvol
0170101  94.12  3.5497  0.0  0.0  90.0  3.5497  0.00015  0.0  00000
0170200  2  1020.94  1.0
```

Component 518

PACIFIC GAS AND ELECTRIC COMPANY
 GENERAL COMPUTATION SHEET

SHEET NO. 40 OF 174 SHEETS
 CALC NO. STA-042 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
 MADE BY HM LBB DATE 10/1/96 CHECK BY _____ APPROVED BY _____

is used to provide a flow junction from the Volume 18-01 (Component 18) to the Volume 17-01 (Component 17). This component consists of 1 junction (Junction 519). The Junction 519 is corresponding the Connector 19 of the TRANFLO model given in Reference 1.

The smaller of the two flow areas of Volumes 18-01 and 17-01 is 63.49 ft² which is used as the flow area for this junction. As given the Reference 1, no flow resistance coefficient is specified for the Connector 19. The forward and reverse flow resistant coefficient of 0.0 is used for this junction. The following input are used for the Component 519.

```
5190000  aboverfr  sngljun
5190101  018010000  017000000  63.49  0.0  0.0  000000
5190110  0.0  0.0  1.0  1.0
5190201  1  0.0  0.0  0.0
```

Component 17 ⁷ HM 10/1/96 LC 10/2/96

The Component 17 is a single volume with assigned name sgdoom which is used to model the region above the upper deck and below the steam nozzle. This component consists of 1 volume (Volume 17-01). The Volume 17-01 is corresponding the Node 17 of the TRANFLO model given in Reference 1. As given in the Table 4.2.2 of Reference 1, the flow are and volume size for the Node 17 are 94.12 ft² and 334.1 ft³. The volume length of Node 17 is $334.1/94.12 = 3.5497$ ft. The flow area and volume length are specified

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 39 OF 74 SHEETS
CALC NO. STA-042 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY HML/BB DATE 10/1/96 CHECK BY _____ APPROVED BY _____

while the volume length is not specified which will be calculated by the code using the volume size and flow area.

The Volume 18-01 is a horizontal volume. The inclination angle is 0.0° and there is no elevation change. The hydraulic diameter of the volume is not specified also and the code will calculate it.

The initial water properties for Node 18 are given in Reference 1 as - pressure at 1020.96 psia, temperature at 547°F and void fraction of 1.0 (pure steam). Since there is no superheated steam in the steam generator, the steam in volume 18-01 must be saturated steam. For saturated steam, the RELAP5 code does not allow to specify both the water pressure and temperature. The steam pressure of TRANFLO Node 18 is used for this component. The initial water properties are specified as pressure at 1020.96 psia and the quality of 1.0.

The following input are used for the Component 18.

```
0180000  spsteam  snglvol
0180101  63.49  0.0  473.0  0.  0.0  0.0  0.00015  0.0  00000
0180200  2  1020.96  1.0
```

Component 519

The Component 519 is a single junction with assigned name abovefr which

PACIFIC GAS AND ELECTRIC COMPANY
 GENERAL COMPUTATION SHEET

SHEET NO. 30 OF 174 SHEETS
 CALC NO. STA-042 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
 MADE BY HML 86 DATE 10/1/96 CHECK BY APPROVED BY

for this junction. As given the Reference 1, a forward and reverse flow resistant coefficient of 0.5 associated with a flow area of 70.75 ft² is specified for the segment ¹ of the Connector 24. *HML 10/1/96*
lc 10/2/96
 The following input are used for the Component 19.

| | | | | | | | | | |
|---------|-----------|-----------|-------|-------|----------------|--------|---------|-----|-------|
| 0190000 | dryer | separatr | | | | | | | |
| 0190001 | 3 | 1 | | | | | | | |
| 0190101 | 171.4 | 0.7083 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00015 | 0.0 | 00000 |
| 0190200 | 2 | 1020.96 | 1.0 | | | | | | |
| 0191101 | 019010000 | 018000000 | 63.49 | 5.502 | 5.502 | 000000 | | | |
| 0192101 | 019000000 | 036000000 | 2.34 | 0.5 | 0.5 | 000000 | | | |
| 0193101 | 020010000 | 019000000 | 70.75 | 0.5 | 0.5 | 000000 | | | |
| 0191201 | 0.0 | 0.0 | 0.0 | | | | | | |
| 0192201 | 0.0 | 0.0 | 0.0 | | | | | | |
| 0193201 | 0.0 | 0.0 | 0.0 | | | | | | |

Component 18

The Component 18 is a single volume with assigned name updryer which is used to model the region inside the secondary separator. This component consists of 1 volume (Volume 18-01). The Volume 18-01 is corresponding the Node 18 of the TRANFLO model given in Reference 1. As given in the Table 4.2.2 of Reference 1, the flow are and volume size for the Node 18 are 63.49 ft² and 473.0 ft³. The volume length of Node 18 is 473.0/63.49 = 7.45 ft. The volume size and flow area are specified as input data

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 37 OF 174 SHEETS
CALC NO. STA-042 R. 0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M LEE DATE 10/1/96 CHECK BY _____ APPROVED BY _____

model. As given in the Reference 1, the smallest flow area of the two segments of the Connector 20 is 63.49 ft² which is used as the flow area for this junction. As given the Reference 1, flow resistance is specified for the segments 1 and 2 of the Connector 20, a forward and reverse flow resistant coefficient of 40.0 associated with a flow area of 179.54 ft² for segment 1 and a forward and reverse flow resistant coefficient of 0.5 associated with a flow area of 63.49 ft² for segment 2. Therefore, for Junction 19-01, the flow resistant coefficient associated with the flow area of 63.49 ft² can be calculated as:

$$40.0 / (179.54 / 63.49)^2 + 0.5 = 5.002 + 0.5 = 5.502$$

The Junction 19-02 connects the inlet of Volume 19-01 to the inlet of Volume 36-01 which is corresponding to the Connector 21 of the TRANFLO model. As given in the Reference 1, the smallest flow area of the two segments of the Connector 21 is 2.34 ft² which is used as the flow area for this junction. As given the Reference 1, a forward and reverse flow resistant coefficient of 0.5 associated with a flow area of 2.34 ft² is specified for the segment 2 of the Connector 21.

The Junction 19-03 connects the outlet of Volume 20-01 to the inlet of Volume 19-01 which is corresponding to the Connector 24 of the TRANFLO model. As given in the Reference 1, the smallest flow area of the two segments of the Connector 24 is 70.75 ft² which is used as the flow area

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 36 OF 174 SHEETS
CALC NO. STA-042 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY HML DATE 10/1/96 CHECK BY _____ APPROVED BY _____

(Junctions 19-01, 19-02 and 19-03). The Volume 19-01 is corresponding the Node 19 of the TRANFLO model given in Reference 1. As given in the Table 4.2.2 of Reference 1, the flow area and volume size for the Node 19 are 171.4 ft² and 121.4 ft³. The volume length of Node 22 is 121.4/171.4 = 0.7083 ft. The flow area and volume length are specified as input data while the volume size is not specified which will be calculated by the code using the volume length and flow area.

The Volume 19-01 is a horizontal volume. The inclination angle is 0° and there is no elevation change. The hydraulic diameter of the volume is not specified also and the code will calculate it.

The initial water properties for Node 19 are given in Reference 1 as - pressure at 1020.96 psia, temperature at 547°F and void fraction of 1.0 (pure steam). Since there is no superheated steam in the steam generator, the steam in volume 19-01 must be saturated steam. For saturated steam, the RELAP5 code does not allow to specify both the water pressure and temperature. The steam pressure of TRANFLO Node 19 is used for this component. The initial water properties are specified as pressure at 1020.96 psia and the quality of 1.0.

The Junction 19-01 connects the outlet of Volume 19-01 to the inlet of Volume 18-01 which is corresponding to the Connector 20 of the TRANFLO

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 70 OF 174 SHEETS
CALC NO. STA-042 R, D

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

1-60 is 1.1667 ft and the heat transfer area to the left boundary volumes is $682.9 \times 1.1667 = 796.74 \text{ ft}^2$.

For Heat Slabs 2, 3, 58 and 59, the length of the left boundary Volumes 1-02, 1-03, 1-58 and 1-59 is 1.2553 ft and the heat transfer area to the left boundary volumes is $682.9 \times 1.2553 = 857.24 \text{ ft}^2$.

For Heat Slabs 4, 5, 8, 9, 12, 13, 16, 17, 20, 21, 24, 25, 28, 29, 32, 33, 36, 37, 40, 41, 44, 45, 48, 49, 52, 53, 56, and 57, the length of the left boundary Volumes 1-04, 1-05, 1-08, 1-09, 1-12, 1-13, 1-16, 1-17, 1-20, 1-21, 1-24, 1-25, 1-28, 1-29, 1-32, 1-33, 1-36, 1-37, 1-40, 1-41, 1-44, 1-45, 1-48, 1-49, 1-52, 1-53, 1-56, and 1-57 is 0.5 ft and the heat transfer area to the left boundary volumes is $682.9 \times 0.5 = 341.45 \text{ ft}^2$.

For Heat Slabs 6, 7, 10, 11, 14, 15, 18, 19, 22, 23, 26, 27, 34, 35, 38, 39, 42, 43, 46, 47, 50, 51, 54, and 55, the length of the left boundary Volumes 1-06, 1-07, 1-10, 1-11, 1-14, 1-15, 1-18, 1-19, 1-22, 1-23, 1-26, 1-27, 1-34, 1-35, 1-38, 1-39, 1-42, 1-43, 1-46, 1-47, 1-50, 1-51, 1-54, and 1-55 is 1.60435 ft and the heat transfer area to the left boundary volumes is $682.9 \times 1.60435 = 1095.61 \text{ ft}^2$. The length of 3.0 ft is used for Volumes 1-30 and 1-31. As described in the section for Component 1, the actual tube length modeled in the Volumes 1-30 and 1-31 is 3.2075 ft. Therefore, for the heat slabs 30 and 31, the heat transfer area to the left boundary Volumes 1-30 and 1-31 is $682.9 \times 3.2075 = 2190.4 \text{ ft}^2$.

For each heat slab, the right boundary volume has the same length as the

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 71 OF 174 SHEETS
CALC NO. STA-042 R.D

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

left boundary volume. Since the tubes have cylindrical shape, the ratio of the heat transfer areas for the right and left boundary volumes for all heat slabs equals to the ratio of the outside diameter and inside diameter of the tubes. The outside diameter of the tubes is the sum of the inside diameter of the tubes and twice of the tube wall thickness which can be calculated as $0.0642 + 2*0.00438 = 0.07296$ ft. The ratio of the heat transfer areas for the right and left boundary volumes for all heat slabs equals to $0.07296/0.0642 = 1.136449$. Then, the heat transfer area of the right boundary volume for each heat slab can be calculated as the heat transfer area of the left boundary volume for heat slab multiplied by 1.136449.

For Heat Slabs 1 and 60, the heat transfer area to the right boundary volumes is $1.136449*796.74 = 905.4541$ ft².

For Heat Slabs 2, 3, 58 and 59, the heat transfer area to the right boundary volumes is $1.136449*857.24 = 974.2092$ ft².

For Heat Slabs 4, 5, 8, 9, 12, 13, 16, 17, 20, 21, 24, 25, 28, 29, 32, 33, 36, 37, 40, 41, 44, 45, 48, 49, 52, 53, 56, and 57, the heat transfer area to the right boundary volumes is $1.136449*341.45 = 388.0404$ ft².

For Heat Slabs 6, 7, 10, 11, 14, 15, 18, 19, 22, 23, 26, 27, 34, 35, 38, 39, 42, 43, 46, 47, 50, 51, 54, and 55, the heat transfer area to the right boundary volumes is $1.136449*1095.61 = 1245.1044$ ft². For Heat Slabs 30 and 31, the heat transfer area to the right boundary volumes is

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 72 OF 74 SHEETS
CALC NO. STA-042 R0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

$$1.136449 * 2190.4 = 2489.277 \text{ ft}^2.$$

There is no heat source in all heat slabs. The initial source multiplier and the direct moderator heating multipliers for both left and right boundary volumes are set to be 0.0. The hydraulic diameters for all the left and right boundary volumes are used for the heat transfer hydraulic diameter. Since the heat transfer rate through the tubes is much lower than the CHF, arbitrary large values or default values are used for all the input related to CHF calculation for both the left and right boundary volumes.

The input data for the heat slabs are listed as follows.

| | | | | | | | |
|----------|-----------|-------|----|---|---------|---|--|
| 11201000 | 60 | 11 | 2 | 1 | 0.0321 | | |
| 11201100 | 0 | | 2 | | | | |
| 11201101 | 0.000438 | | 10 | | | | |
| 11201201 | 1 | | 10 | | | | |
| 11201301 | 0.0 | | 10 | | | | |
| 11201401 | 547.0 | | 11 | | | | |
| 11201501 | 001010000 | 0000 | 1 | 0 | 796.74 | 1 | |
| 11201502 | 001020000 | 10000 | 1 | 0 | 857.24 | 3 | |
| 11201503 | 001040000 | 10000 | 1 | 0 | 341.45 | 5 | |
| 11201504 | 001060000 | 10000 | 1 | 0 | 1095.61 | 7 | |
| 11201505 | 001080000 | 10000 | 1 | 0 | 341.45 | 9 | |

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 73 OF 174 SHEETS
CALC NO. STA-042 R.D

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

| | | | | | | |
|----------|-----------|-------|---|---|---------|----|
| 11201506 | 001100000 | 10000 | 1 | 0 | 1095.61 | 11 |
| 11201507 | 001120000 | 10000 | 1 | 0 | 341.45 | 13 |
| 11201508 | 001140000 | 10000 | 1 | 0 | 1095.61 | 15 |
| 11201509 | 001160000 | 10000 | 1 | 0 | 341.45 | 17 |
| 11201510 | 001180000 | 10000 | 1 | 0 | 1095.61 | 19 |
| 11201511 | 001200000 | 10000 | 1 | 0 | 341.45 | 21 |
| 11201512 | 001220000 | 10000 | 1 | 0 | 1095.61 | 23 |
| 11201513 | 001240000 | 10000 | 1 | 0 | 341.45 | 25 |
| 11201514 | 001260000 | 10000 | 1 | 0 | 1095.61 | 27 |
| 11201515 | 001280000 | 10000 | 1 | 0 | 341.45 | 29 |
| 11201516 | 001300000 | 10000 | 1 | 0 | 2190.4 | 31 |
| 11201517 | 001320000 | 10000 | 1 | 0 | 341.45 | 33 |
| 11201518 | 001340000 | 10000 | 1 | 0 | 1095.61 | 35 |
| 11201519 | 001360000 | 10000 | 1 | 0 | 341.45 | 37 |
| 11201520 | 001380000 | 10000 | 1 | 0 | 1095.61 | 39 |
| 11201521 | 001400000 | 10000 | 1 | 0 | 341.45 | 41 |
| 11201522 | 001420000 | 10000 | 1 | 0 | 1095.61 | 43 |
| 11201523 | 001440000 | 10000 | 1 | 0 | 341.45 | 45 |
| 11201524 | 001460000 | 10000 | 1 | 0 | 1095.61 | 47 |
| 11201525 | 001480000 | 10000 | 1 | 0 | 341.45 | 49 |
| 11201526 | 001500000 | 10000 | 1 | 0 | 1095.61 | 51 |
| 11201527 | 001520000 | 10000 | 1 | 0 | 341.45 | 53 |
| 11201528 | 001540000 | 10000 | 1 | 0 | 1095.61 | 55 |

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 78 OF 174 SHEETS
CALC NO. STA-042 RD

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

| | | | | | | |
|----------|-----------|--------|---|---|-----------|----|
| 11201529 | 001560000 | 10000 | 1 | 0 | 341.45 | 57 |
| 11201530 | 001580000 | 10000 | 1 | 0 | 857.24 | 59 |
| 11201531 | 001600000 | 0000 | 1 | 0 | 796.74 | 60 |
| 11201601 | 030010000 | 0000 | 1 | 0 | 905.4541 | 1 |
| 11201602 | 002010000 | 10000 | 1 | 0 | 974.2092 | 3 |
| 11201603 | 002030000 | 10000 | 1 | 0 | 388.0404 | 5 |
| 11201604 | 002050000 | 10000 | 1 | 0 | 1245.1044 | 7 |
| 11201605 | 002070000 | 10000 | 1 | 0 | 388.0404 | 9 |
| 11201606 | 002090000 | 10000 | 1 | 0 | 1245.1044 | 11 |
| 11201607 | 002110000 | 10000 | 1 | 0 | 388.0404 | 13 |
| 11201608 | 002130000 | 10000 | 1 | 0 | 1245.1044 | 15 |
| 11201609 | 002150000 | 10000 | 1 | 0 | 388.0404 | 17 |
| 11201610 | 002170000 | 10000 | 1 | 0 | 1245.1044 | 19 |
| 11201611 | 002190000 | 10000 | 1 | 0 | 388.0404 | 21 |
| 11201612 | 002210000 | 10000 | 1 | 0 | 1245.1044 | 23 |
| 11201613 | 002230000 | 10000 | 1 | 0 | 388.0404 | 25 |
| 11201614 | 002250000 | 10000 | 1 | 0 | 1245.1044 | 27 |
| 11201615 | 002270000 | 10000 | 1 | 0 | 388.0404 | 29 |
| 11201616 | 002290000 | 0000 | 1 | 0 | 2489.277 | 31 |
| 11201617 | 002280000 | -10000 | 1 | 0 | 388.0404 | 33 |
| 11201618 | 002260000 | -10000 | 1 | 0 | 1245.1044 | 35 |
| 11201619 | 002240000 | -10000 | 1 | 0 | 388.0404 | 37 |
| 11201620 | 002220000 | -10000 | 1 | 0 | 1245.1044 | 39 |

PACIFIC GAS AND ELECTRIC COMPANY
 GENERAL COMPUTATION SHEET

SHEET NO. 75 OF 174 SHEETS
 CALC NO. STA-042 R0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
 MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

| | | | | | | | | | |
|----------|-----------|--------|------|-----|------------|-----|-----|-----|----|
| 11201621 | 002200000 | -10000 | 1 | 0 | 388.0404 | 41 | | | |
| 11201622 | 002180000 | -10000 | 1 | 0 | 1245.1044 | 43 | | | |
| 11201623 | 002160000 | -10000 | 1 | 0 | 388.0404 | 45 | | | |
| 11201624 | 002140000 | -10000 | 1 | 0 | 1245.1044 | 47 | | | |
| 11201625 | 002120000 | -10000 | 1 | 0 | 388.0404 | 49 | | | |
| 11201626 | 002100000 | -10000 | 1 | 0 | 1245.1044 | 51 | | | |
| 11201627 | 002080000 | -10000 | 1 | 0 | 388.0404 | 53 | | | |
| 11201628 | 002060000 | -10000 | 1 | 0 | 1245.1044 | 55 | | | |
| 11201629 | 002040000 | -10000 | 1 | 0 | 388.0404 | 57 | | | |
| 11201630 | 002020000 | -10000 | 1 | 0 | 974.2092 | 59 | | | |
| 11201631 | 003010000 | 0000 | 1 | 0 | 905.4541 | 60 | | | |
| 11201701 | 0 | 0.0 | 0.0 | 0.0 | 60 | | | | |
| 11201801 | 0.0 | 15.0 | 15.0 | 1.5 | 1.5 | 0.0 | 0.0 | 1.0 | 60 |
| 11201901 | 0.0 | 15.0 | 15.0 | 1.5 | 1.5 | 0.0 | 0.0 | 1.0 | 60 |
| 20100100 | tbl/fctn | 1 | 1 | | | | | | |
| 20100101 | 70.0 | | | | 2.3843e-03 | | | | |
| 20100102 | 200.0 | | | | 2.5232e-03 | | | | |
| 20100103 | 400.0 | | | | 2.8009e-03 | | | | |
| 20100104 | 600.0 | | | | 3.0787e-03 | | | | |
| 20100105 | 800.0 | | | | 3.3565e-03 | | | | |
| 20100106 | 1000.0 | | | | 3.6574e-03 | | | | |
| 20100107 | 1200.0 | | | | 3.9815e-03 | | | | |

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 76 OF 174 SHEETS
CALC NO. STA-042 R.O

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

| | | |
|----------|--------|------------|
| 20100108 | 1400.0 | 4.3056e-03 |
| 20100151 | 70.0 | 55.6831 |
| 20100152 | 200.0 | 55.5227 |
| 20100153 | 400.0 | 55.2607 |
| 20100154 | 600.0 | 54.9895 |
| 20100155 | 800.0 | 54.7069 |
| 20100156 | 1000.0 | 54.3982 |
| 20100157 | 1200.0 | 54.0907 |
| 20100158 | 1400.0 | 53.7516 |

Control Variables

The purpose of this analysis is to determine the pressure difference across the TSPs. In this calculation, the pressure difference across the TSP is defined as the pressure at the center of the volume immediately above the TSP subtracting the pressure at the center of the volume immediately below the TSP. Since the length of the volume immediately above or below the TSP is 0.5 ft, this definition conservatively adds a 0.5 ft hydraulic head to the actual pressure difference across TSP. Control Variables 1 to 7 are used to calculate the differential pressures across TSPs 1 to 7.

Control Variable 1

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 77 OF 174 SHEETS
CALC NO. STA-042 RD

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

Control Variable 1 is named as deltp1 which is used to calculate the differential pressure across TSP 1. The deltp1 is the sum of the negative pressure of the Volume 2-04 and the pressure of the Volume 2-03. The RELAP5 code used pa for the pressure. As given in Reference 3, a pa equals to 1.45038e-4 psi. A conversion factor of 1.45038e-4 is used in the Control Variable 1. The following input is used for the Control Variable 1.

```
20500100 deltp1 sum 1.45038e-4 0.0 1
20500101 0.0 -1.0, p, 002040000 1.0, p, 002030000
```

Control Variable 2

Control Variable 2 is named as deltp2 which is used to calculate the differential pressure across TSP 2. The deltp2 is the sum of the negative pressure of the Volume 2-08 and the pressure of the Volume 2-07. A conversion factor of 1.45038e-4 is used in the Control Variable 2 to convert pa to psi. The following input is used for the Control Variable 2.

```
20500200 deltp2 sum 1.45038e-4 0.0 1
20500201 0.0 -1.0, p, 002080000 1.0, p, 002070000
```

Control Variable 3

Control Variable 3 is named as deltp3 which is used to calculate the differential pressure across TSP 3. The deltp3 is the sum of the

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 78 OF 74 SHEETS
CALC NO. STA-042 R.O

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

negative pressure of the Volume 2-12 and the pressure of the Volume 2-11. A conversion factor of $1.45038e-4$ is used in the Control Variable 3 to convert pa to psi. The following input is used for the Control Variable 3.

20500300 delptp3 sum $1.45038e-4$ 0.0 1
20500301 0.0 -1.0, p, 002120000 1.0, p, 002110000

Control Variable 4

Control Variable 4 is named as delptp4 which is used to calculate the differential pressure across TSP 4. The delptp4 is the sum of the negative pressure of the Volume 2-16 and the pressure of the Volume 2-15. A conversion factor of $1.45038e-4$ is used in the Control Variable 4 to convert pa to psi. The following input is used for the Control Variable 4.

20500400 delptp4 sum $1.45038e-4$ 0.0 1
20500401 0.0 -1.0, p, 002160000 1.0, p, 002150000

Control Variable 5

Control Variable 5 is named as delptp5 which is used to calculate the differential pressure across TSP 5. The delptp5 is the sum of the negative pressure of the Volume 2-20 and the pressure of the Volume 2-19. A conversion factor of $1.45038e-4$ is used in the Control Variable 5 to convert pa to psi. The following input is used for the Control Variable

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 79 OF 174 SHEETS
CALC NO. STA-042 R0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

5.

20500500 delptp5 sum 1.45038e-4 0.0 1

20500501 0.0 -1.0, p, 002200000 1.0, p, 002190000

Control Variable 6

Control Variable 6 is named as delptp6 which is used to calculate the differential pressure across TSP 6. The delptp6 is the sum of the negative pressure of the Volume 2-24 and the pressure of the Volume 2-23. A conversion factor of 1.45038e-4 is used in the Control Variable 6 to convert pa to psi. The following input is used for the Control Variable 6.

20500600 delptp6 sum 1.45038e-4 0.0 1

20500601 0.0 -1.0, p, 002240000 1.0, p, 002230000

Control Variable 7

Control Variable 7 is named as delptp7 which is used to calculate the differential pressure across TSP 7. The delptp7 is the sum of the negative pressure of the Volume 2-28 and the pressure of the Volume 2-27. A conversion factor of 1.45038e-4 is used in the Control Variable 7 to convert pa to psi. The following input is used for the Control Variable 7.

20500700 delptp7 sum 1.45038e-4 0.0 1

20500701 0.0 -1.0, p, 002280000 1.0, p, 002270000

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 80 OF 174 SHEETS
CALC NO. STA-042 R.D.

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

Time Step Control

A very small minimum time step of $1.0e^{-7}$ second is used for the entire run to insure that the time step can be reduced to the required size as determined by the RELAP5 time step control scheme. The steam line break is occurred at 5 seconds for this analysis. For the first 5 seconds, the steam generator is in steady state condition. The purpose for the first 5 seconds run is to self correct the slightly inconsistence in the input and a real steady state condition can be provided at the initiation of the break. For steady state run, larger time steps can be used. A maximum time step of 0.005 second is used for the first 5 seconds run.

After the initiation of the break, a very large steam flow is blown out from the steam generator which induces a very fast transient in the steam generator. In addition, a great portion of the water in the steam generator is in pure liquid phase at the initiation of the break. The depressurization wave travels at a very high speed in the liquid water. To correctly track the depressurization wave front and to limit the water property change in the components during each time step, a maximum time step of $1.0e^{-5}$ second is used immediately after the initiation of break. The depressurization wave travelling speed is substantially reduced when flashing occurs in the liquid region due to depressurization. Then, the maximum time step size can be increased. A maximum time step size of $2.5e^{-5}$ second is used starting at 0.3 second after the initiation of the

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 81 OF 174 SHEETS
CALC NO. STA-042 R.O

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

break (5.3 seconds into the run). The maximum time step size is further increased to $5e^{-5}$ second starting at 1.5 seconds after the initiation of the break (6.5 seconds into the run). The analysis is terminated at 3 seconds after the initiation of the break (8 seconds into the run). A maximum time step size of $1.0e^{-4}$ second is specified in the input after 8 seconds which is not used in the run.

During the entire run, the standard major edits are printed. The time step control options ss and d are set to 0. The time step control option tt is set to 3 which allows to use a mass error analysis to control the hydrodynamics advancement time step size in addition to standard time step control. The heat conduction/transfer time step is set to the same as the hydrodynamics time step. Since the maximum time step sizes allowed are very small, the maximum time step sizes are used during the entire run. Therefore, the time step control option has no effect on the analysis.

The minor edits are printed out every 0.1 seconds which is the frequency of the differential pressure used in the TSP structure analysis performed by Westinghouse. Due to 109000 time steps advanced during the run, the major edit frequency is set to be very small to reduce the output to a manageable size. The restart is not used. An arbitrary small restart frequency is used.

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 82 OF 77 SHEETS
CALC NO. STA-042 RD

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

The following input is used for the time step control.

| | | | | | | | |
|-----|--------|-------|----------|---|------|-------|--------|
| 201 | 5.0 | 1.d-7 | 0.005 | 3 | 2 | 200 | 10000 |
| 202 | 5.3 | 1.d-7 | 0.00001 | 3 | 1000 | 20000 | 100000 |
| 203 | 6.5 | 1.d-7 | 0.000025 | 3 | 400 | 8000 | 100000 |
| 204 | 8.0 | 1.d-7 | 0.00005 | 3 | 200 | 10000 | 100000 |
| 205 | 1000.0 | 1.d-7 | 0.0001 | 3 | 100 | 10000 | 100000 |

Trip Cards

Three trip cards are used in the input. The Trip Card 501 is used to terminate the analysis at 8 seconds. The Trip Card 502 is used to initiate the steam line break at 5 seconds. The Trip Card 503 is used to close the steam line break at an arbitrary large time of 200 seconds. For all the three Trip Cards, the latch indicator is set to 1 which makes all the three trips once set true remain true. The following input is used for the Trip Cards.

| | | | | | | | |
|-----|------|---|----|------|---|-------|---|
| 501 | time | 0 | ge | null | 0 | 8.0 | 1 |
| 502 | time | 0 | ge | null | 0 | 5.0 | 1 |
| 503 | time | 0 | ge | null | 0 | 200.0 | 1 |

Trip Stop Advancement Card

The Trip Card 501 is used to terminate the analysis. The following input is used for the trip stop advancement card.

600 501

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 83 OF 174 SHEETS
CALC NO. STA-042 R.O.

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

Miscellaneous Input

The following input is used to indicate the problem type is a new transient.

100 new transnt

The following input is used to select the british units for both input and out output.

102 british british

To tern off the CPU time check and diagnostic edit, empty Card 105 is input.

105

The following variables are listed in the minor edit.

- . The flow rates at TSPs (Junctions 2-03, 2-07, 2-11, 2-15, 2-19, 2-23 and 2-27) and the break (Junction 518).
- . The pressure at the volume upstream the break (Volume 17-01).
- . The differential pressures across the TSPs (Control Variables 1 to 7).

The following input is used to select the minor edit.

301 mflowj 518000000

302 mflowj 002030000

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 84 OF 174 SHEETS
CALC NO. STA-042 R0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

| | | |
|-----|----------|-----------|
| 303 | mflowj | 002070000 |
| 304 | mflowj | 002110000 |
| 305 | mflowj | 002150000 |
| 306 | mflowj | 002190000 |
| 307 | mflowj | 002230000 |
| 308 | mflowj | 002270000 |
| 309 | p | 017010000 |
| 319 | cntrlvar | 1 |
| 320 | cntrlvar | 2 |
| 321 | cntrlvar | 3 |
| 322 | cntrlvar | 4 |
| 323 | cntrlvar | 5 |
| 324 | cntrlvar | 6 |
| 326 | cntrlvar | 7 |

The title of the analysis is set as follows.

=SLB pressure difference across the SG tube support plates

The input file name is reidpl and the output file name is reodpl.

The complete list of the input is attached in the Appendix D.

RELAP5 Input for LB Case 2

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 85 OF 174 SHEETS
CALC NO. STA-042 R.O

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

The only difference between the LB Case 1 and LB Case 2 is the equilibrium model is used in LB Case 2 for the volumes modeling the shell side of the steam generator tubes. Therefore, the only input changes from LB Case 1 to LB Case 2 are the volume control flag e is set to 1 for Volumes 2-01 to 2-30. The following input changes are used for LB Case 2.

0021001 00101 29

0021002 00001 30

The remaining input are the same as those for the LB Case 1.

The input file name is reidp2 and the output file name is reodp2.

RELAP5 Input for LB Case 3

The only difference between the LB Case 1 and LB Case 3 is the initial steam generator water level and flow resistance of the TSPs. The initial water level used in LB Case 1 is 490.5" above the steam generator tube plate, while the initial water level used in LB Case 3 is 466.0" above the steam generator tube plate. The initial void fractions for the Volumes 23-01, 32-01, 33-01 and 36-01 are changed to 0.39, 1.0, 0.93 and 1.0 from those used for the LB Case 1, as shown in Appendix C for case 61. As discussed for LB Case 1 input, the void fractions are conservatively used as qualities for LB Case 3. The initial pressures at each of the Volumes are slightly reduced due to lower water level. However, since five seconds steady state run is performed before the

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 86 OF 74 SHEETS
CALC NO. STA-042 R.O

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

initiation of the break, the volume pressures will be self-corrected when the break is initiated. Therefore, it is not necessary to change the initial volume pressures for this case. The flow resistant coefficient of 0.78 is used for forward and reverse flow through the TSPs for LB Case 1. For LB Case 3, the flow resistant coefficient is increased to 0.99 for forward and reverse flow through the TSPs. The following input changes are used for LB Case 3.

| | | | |
|---------|------|---------|------|
| 0230200 | 2 | 1022.72 | 0.39 |
| 0320200 | 2 | 1021.26 | 1.0 |
| 0330200 | 2 | 1021.72 | 0.93 |
| 0360200 | 2 | 1021.57 | 0.82 |
| 0020902 | 0.99 | 0.99 | 3 |
| 0020904 | 0.99 | 0.99 | 7 |
| 0020906 | 0.99 | 0.99 | 11 |
| 0020908 | 0.99 | 0.99 | 15 |
| 0020910 | 0.99 | 0.99 | 19 |
| 0020912 | 0.99 | 0.99 | 23 |
| 0020914 | 0.99 | 0.99 | 27 |

The remaining input are the same as those for the LB Case 1.

The input file name is reidp5 and the output file name is reodp5.

RELAP5 Input for SB Case 1

The only difference between the LB Case 1 and SB Case 1 is the steam line

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 87 OF 174 SHEETS
CALC NO. STA-042 20

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

break size. For LB Case 1, the cross section area of the steam generator steam outlet nozzle is used for the break size. For SB Case 1, the cross section area of the steam pipe down stream the flow restrictor is used. As given in Reference 1, the break size of 1.388 ft² is used for the SB Case 1. Therefore, the only input change from LB Case 1 to SB Case 1 is that the flow area of Junction 518 is changed from 4.6 ft² to 1.388 ft². The following input change is used for SB Case 1

5180101 017010000 038000000 1.388 0.0 0.0 000100

The remaining input are the same as those for the LB Case 1.

The input file name is reidp3 and the output file name is reodp3.

RELAP5 Input for SB Case 2

The only difference between the SB Case 1 and SB Case 2 is the equilibrium model is used in SB Case 2 for the volumes modeling the shell side of the steam generator tubes. Therefore, the only input changes from SB Case 1 to SB Case 2 are the volume control flag e is set to 1 for Volumes 2-01 to 2-30. The following input changes are used for SB Case 2.

0021001 00101 29

0021002 00001 30

The remaining input are the same as those for the SB Case 1.

The input file name is reidp4 and the output file name is reodp4.

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 88 OF 174 SHEETS
CALC NO. STA-042 R₀

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

6. Results

The results of all RELAP5 runs are microfiched and attached to the calculation file as Appendix G.

Large Break Case 1

The time history of the differential pressures across TSPs 1 to 7 after the initiation of the break are plotted on Figures 6-1 to 6-7. The peak differential pressures across the TSPs 1 to 7 are 1.855 psi, 5.774 psi, 9.489 psi, 9.732 psi, 9.541 psi, 9.411 and 8.784 psi, respectively. All the peak pressures are occurred at 0.5 to 0.8 second after the initiation of the break. The duration of the high differential pressure across the TSP is very short for the TSP 1 which is located nearest to the bottom of the steam generator. The duration increases when the location of the TSP is further away from the bottom of the steam generator. Therefore, even the difference is very small between the peak differential pressures across the TSPs 3 to 7, the integrated force acting on the TSP increases with the elevation of the TSP.


Large Break Case 2

The time history of the differential pressures across TSPs 1 to 7 after the initiation of the break are plotted on Figures 6-8 to 6-14. The peak differential pressures across the TSPs 1 to 7 are 1.938 psi, 2.17

89/174
HML 10/1/96
STA-DW R.O

FIGURE 6-1

DP AT TSP 1 (LB CASE 1)



DP AT TSP 2 (LB CASE 1)





FIGURE 6-2

90/174
144 10/11/96
57A-042 R.D


91/174
144/10/196
STA-202 R+

FIGURE 6-3




26/1/22
14th 10/1/19
STA-082
R.O

FIGURE 6-4




93/174
HAC 10/1/96
STA-042
R.O

FIGURE 6-5




2/1/85
1400 10/1/86
STA-002 R.D

9-9 TIG WRT 6-6



3/17/55
ITMC 10/11/96
STA-002
R, 6

FIGURE 6-7



DP AT TSP 1 (LB CASE 2)




FIGURE 6-8

96/174
1704/19/196
STA-002 R.

DP AT TSP 2 (LB CASE 2)




FIGURE 8-9

97/174
144C 19/196
STA-042 R.O

DP AT TSP 3 (LB CASE 2)




FIGURE 6-10

98/170
MIL 10/1/96
STA-002
P.O

DP AT TSP 4 (LB CASE 2)




FIGURE 6-11

59/174
144 10/1/96
SAD-042
R.O

DP AT TSP 5 (LB CASE 2)





FIGURE 6-12

10/17/96
HMC 10/1/96
STA-002
E.O.


10/1/74
HAC 10/1/96
STA-042
R.C.

FIGURE 6-13



102/174
HWA 10/1/96
STA--042
R.0

FIGURE 6-14



DP AT TSP 7 (LB CASE 2)

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 103 OF 174 SHEETS
CALC NO. STA-042 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

psi, 3.534 psi, 4.751 psi, 6.418 psi, 8.376 and 9.769 psi, respectively. The peak pressure across the TSP increases substantially with the increase of the TSP elevation for LB Case 2 which is quite different from the LB Case 1. All the peak pressures are occurred at 0.3 to 0.5 second after the initiation of the break which is also much earlier than those for LB Case 1. In addition, more smooth time histories are noticed for the differential pressures acting on the TSPs for LB Case 2. Similar to LB Case 1, the duration of the high differential pressure across the TSP is very short for the TSP 1 which is located nearest to the bottom of the steam generator. The duration increases when the location of the TSP is further away from the bottom of the steam generator. Except for TSPs 1 and 7, the peak differential pressures at TSPs 2 to 6 for LB Case 2 are substantially lower than those for LB Case 1. However, in general, the duration of the high differential pressure acting on each TSP is longer for LB Case 2 than that for LB Case 1. Therefore, the difference between the integrated forces acting on the TSPs for LB Case 1 and LB Case 2 are not substantial.

As discussed above, the characteristic of the differential pressures across the TSPs for LB Case 2 is substantially different from that for LB Case 1 which is a result of changing the modeling scheme from non-equilibrium to equilibrium for the shell side of the tube region. Since this is a very fast transient, it is difficult to determine which case is

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 104 OF 174 SHEETS
CALC NO. STA-042 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

more accurate. Therefore, the results of both cases are transmitted to Westinghouse to perform structure analysis for the TSPs.


Large Break Case 3

The time history of the differential pressures across TSPs 1 to 7 after the initiation of the break are plotted on Figures 6-15 to 6-21. The peak differential pressures across the TSPs 1 to 7 are -4.915 psi, 12.93 psi, 12.93 psi, 11.24 psi, 10.98 psi, 11.57 and 12.84 psi, respectively. As shown in Figure 6-15 and 6-17, the peak differential pressure across TSPs 1 and 3 for LB Case 3 are spikes with very short duration which can not be explained physically. Excluding the spikes, the peak differential pressures across the TSPs 1 and 3 are 1.885 psi and 4.106 psi, respectively. All the peak pressures are occurred at 0.4 to 0.6 second after the initiation of the break which is earlier than those for LB Case 1. Similar the LB Case 1, the duration of the high differential pressure across the TSP is very short for the TSP 1 which is located nearest to the bottom of the steam generator. The duration increases when the location of the TSP is further away from the bottom of the steam generator. Therefore, even the difference is very small between the peak differential pressures across the TSPs 4 to 7, the integrated force acting on the TSP increases with the elevation of the TSP.

Comparison between the differential pressures across the TSPs for LB Case

105/174
HML 10/1/96
STA--042 K

FIGURE 6-15



DP AT TSP 2 (LB CASE 3)




FIGURE 6-16

106/174
HML 10/11/96
SAR-042
R.O

DP AT TSP 3 (LB CASE 3)




FIGURE 6-17

107/174
HHL 10/1/96
STA-042
R.O

DP AT TSP 4 (LB CASE 3)





FIGURE 6-18

103/174
HML 10/1/96
STA-042
R.O

109/174
HMC 10/1/96
STA-042
L.O

FIGURE 6-19



DP TA TSP 6 (LB CASE 3)





FIGURE 6-20

11/17/74
HMC 10/1/96
STA-0402
2.0

11/17/74
1700 10/1/96
STA-04
R.O

FIGURE 6-21



DP AT TSP 7 (LB CASE 3)

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 112 OF 176 SHEETS
CALC NO. STA-042 R. 0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

1 and LB Case 3 indicates that the lower initial water level and higher TSP flow resistance used in LB Case 3 result in similar or lower differential pressures at the TSPs 1 to 3 (excluding the spikes for LB Case 3). However, for the TSPs at higher elevations (TSPs 4 to 7), the lower initial water level and higher TSP flow resistance used in LB Case 3 result in higher differential pressure and a higher differential pressure increase is calculated for a TSP at higher elevation.

Small Break Case 1

The time history of the differential pressures across TSPs 1 to 7 after the initiation of the break are plotted on Figures 6-22 to 6-28. The peak differential pressures across the TSPs 1 to 7 are 2.032 psi, 0.866 psi, 0.982 psi, 8.390 psi, 3.336 psi, 4.059 and 3.031 psi, respectively. As shown in Figure 6-22, 6-25 and 6-27, the peak differential pressure across TSPs 1, 4 and 6 for LB Case 3 are spikes with very short duration which can not be explained physically. Excluding the spikes, the peak differential pressures across the TSPs 1, 4 and 6 are 0.939 psi, 1.29 and 3.4 psi (approximate), respectively. All the peak pressures are occurred at 0.5 to 1.3 seconds after the initiation of the break. Similar to the large break cases, the duration of the high differential pressure across the TSP is very short for the TSP 1 which is located nearest to the bottom of the steam generator. The duration increases when the location of the TSP is further away from the bottom of the steam

DP AT TSP 1 (SB CASE 1)




FIGURE 6-22

1/3/70
HNL 10/1/96
STA-OVER

DP AT TSP 2 (SB CASE 1)




FIGURE 6-23


11/17/96
HWL 10/1/96
STA-042
R.S.

115/70

14M 10/1/96

STA - 04
R.O

FIGURE 6-24



DP AT TSP 3 (SB CASE 1)

DP AT TSP 4 (SB CASE 1)




FIGURE 6-25

11/6/74
HML 10/1/96
STA-042
R.D

DP AT TSP 5 (SB CASE 1)




FIGURE G-26

STA - 0
R. 0

APR 10/1/96

117/70

DP AT TSP 6 (SB CASE 1)




FIGURE 6-27

11/8/70
HWL 10/1/76
STA-002
R. 0

DP AT TSP 7 (SB CASE 1)




FIGURE 6-28

11/9/79
HML 10/1/92
STA-002
R.O

120/174

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 120 OF 174 SHEETS
CALC NO. STA-042 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

generator. Therefore, even the difference is very small between the peak differential pressures across the TSPs 3 to 7, the integrated force acting on the TSP increases with the elevation of the TSP.

Small Break Case 2

The time history of the differential pressures across TSPs 1 to 7 after the initiation of the break are plotted on Figures 6-29 to 6-354. The peak differential pressures across the TSPs 1 to 7 are 1.264 psi, 1.414 psi, 1.386 psi, 1.500 psi, 1.697 psi, 2.278 and 2.405 psi, respectively. Similar to the LB Case 2, the peak pressure across the TSP increases with the increase of the TSP elevation for LB Case 2 which is different from the SB Case 1. All the peak pressures are occurred within 0.5 second after the initiation of the break which is also much earlier than those for SB Case 1. In addition, more smooth time histories are noticed for the differential pressures acting on the TSPs for SB Case 2. Similar to SB Case 1, the duration of the high differential pressure across the TSP is very short for the TSP 1 which is located nearest to the bottom of the steam generator. The duration increases when the location of the TSP is further away from the bottom of the steam generator.

As discussed above, the characteristic of the differential pressures across the TSPs for SB Case 2 is substantially different from that for SB Case 1 which is a result of changing the modeling scheme from non-

DP AT TSP 1 (SB CASE 2)




FIGURE 6-29

STA-002

APR 19/1/96

12/1/74

DP AT TSP 2 (SB CASE2)





FIGURE 6-30

STA-042
R.O.
HNL 10/1/96
1/22/174

DLI/321
HML 12/1/96
STA-042
R, D

FIGURE 6-31

Time (sec)
5.00E+00 5.50E+00 6.00E+00 6.50E+00 7.00E+00 7.50E+00 8.00E+00



DP (psi)
-2.00E-01
0.00E+00
2.00E-01
4.00E-01
6.00E-01
8.00E-01
1.00E+00
1.20E+00
1.40E+00
1.60E+00

DP AT TSP 3 (SB CASE 2)

DP AT TSP 4 (SB CASE 2)




FIGURE 6-32

57A-002
R.D.
APR 10/1/96
124/74

DP AT TSP 5 (SB CASE 2)




FIGURE 6-33

125/179
HAD 10/1/96
STA-002
L.D.

DP AT TSP 6 (SB CASE 2)





FIGURE 6-34

STA-002
R.O.
April 19/196
129174

12/7/74
HML 19/1/75
STA-002
R.0

FIGURE 6-35



128/174

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 128 OF 174 SHEETS
CALC NO. STA-042 R, v

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

equilibrium to equilibrium for the shell side of the tube region. It is difficult to determine which case is more accurate. Therefore, the results of both cases are transmitted to Westinghouse to perform structure analysis for the TSPs. However, since the extremely high differential pressures spikes calculated for some of the TSPs in SB Case 1 can not be explained physically, it may not be needed to consider these high spikes in the structure analysis.

DATA EXTRACTION FOR STP STRUCTURE ANALYSIS

The results of the RELAP5 analysis are transmitted to Westinghouse to perform structure analysis for the TSPs. In addition to the differential pressures across the TSPs, Westinghouse needs the pressure and density at the each TSP for their structure analysis . Therefore, the pressure and density at Volumes immediately above the TSPs are extracted from the RELAP5 output file with the differential pressures across the TSPs. The following input is used to extracting the data out from the RELAP5 output for each TSP.

TSP 1

The following STRIP run input is used to extract the time histories of the pressure, density and differential pressure which will be used in the structure analysis for the TSP 1.

```
=SLB pressure difference across the SG tube support plates  
0000100 strip fmtout
```

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 129 OF 174 SHEETS
CALC NO. STA-042 R.D

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

103 0
1001 p 002040000
1002 rho 002040000
1003 cntrlvar 1
.

TSP 2

The following STRIP run input is used to extract the time histories of the pressure, density and differential pressure which will be used in the structure analysis for the TSP 2.

=SLB pressure difference across the SG tube support plates

0000100 strip fmtout
103 0
1001 p 002080000
1002 rho 002080000
1003 cntrlvar 2
.

TSP 3

The following STRIP run input is used to extract the time histories of the pressure, density and differential pressure which will be used in the structure analysis for the TSP 3.

=SLB pressure difference across the SG tube support plates

0000100 strip fmtout

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 130 OF 174 SHEETS
CALC NO. STA-042 R. v

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

103 0
1001 p 002120000
1002 rho 002120000
1003 cntrlvar 3

TSP 4

The following STRIP run input is used to extract the time histories of the pressure, density and differential pressure which will be used in the structure analysis for the TSP 4.

=SLB pressure difference across the SG tube support plates

0000100 strip fmtout
103 0
1001 p 002160000
1002 rho 002160000
1003 cntrlvar 4

TSP 5

The following STRIP run input is used to extract the time histories of the pressure, density and differential pressure which will be used in the structure analysis for the TSP 5.

=SLB pressure difference across the SG tube support plates

0000100 strip fmtout

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 131 OF 174 SHEETS
CALC NO. STA-042 R.D

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

103 0
1001 p 002200000
1002 rho 002200000
1003 cntrlvar 5

TSP 6

The following STRIP run input is used to extract the time histories of the pressure, density and differential pressure which will be used in the structure analysis for the TSP 6.

=SLB pressure difference across the SG tube support plates

0000100 strip fmtout
103 0
1001 p 002240000
1002 rho 002240000
1003 cntrlvar 6

TSP 7

The following STRIP run input is used to extract the time histories of the pressure, density and differential pressure which will be used in the structure analysis for the TSP 7.

=SLB pressure difference across the SG tube support plates

0000100 strip fmtout

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 132 OF 174 SHEETS
CALC NO. STA-042 R0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

103 0
1001 p 002280000
1002 rho 002280000
1003 cntrlvar 7

Since the pressure and density data extracted from the RELAP5 output file are in the unit of pa and kg/m³. Microsoft Excel program is used to convert pa to psi by multiplying a factor of 1.45038e⁻⁴ to the pressure data and convert kg/m³ to lb/ft³ by dividing a factor of 16.0185 to the density data. The names for the Excel files transmitted to Westinghouse are SLBLBC1.XLS, SLBLBC2.XLS and SLBLBC3.XLS for LB Cases 1, 2 and 3 and SLBSBC1.XLS and SLBSBC2.XLS for SB Cases 1 and 2. All these files are stored in two flappy disks which is attached as Attachment 1.

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 133 OF 174 SHEETS
CALC NO. STA-042 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

7. References

1. Westinghouse Calculation TH-95-001, 'Model 51 Steam Generator TRANFLO Model Development', Dated 9/30/96.
2. Westinghouse Letter NCE-85-529, from NCD engineering to M. Oshinsky, " GENF Input for Models 44, 44F, 51, 51F and F Steam Generators", September 5, 1985. This letter is also attached to this calculation file as Appendix E.
3. ASME Steam Table.
4. RELAP5/Mod3 Code User's Manual.
5. WCAP-11206, Loss of Feed Flow, Steam Generator Tube Rupture and Steam Line Break Thermohydraulic Experiments.
6. Nuclear Heat Transport, Published by ANS.
7. Westinghouse Drawing 350794-B, "Steam Generator Nozzle to Elliptical Head". This Drawing is also attached to this calculation file as Appendix F.

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 134 OF 174 SHEETS
CALC NO. STA-042 R, D

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

Appendix A

Loss Coefficient of Tube Bundle Crossflow



135/174
 HML 10/1/96
 STA-002 R.

NSD-JLH-6070

From: Steam Generator Design & Analysis
WIN: 224-5992
Date: March 7, 1996
Subject: Loss Coefficient of Tube Bundle Crossflow for RELAP Modeling

To: M. J. Miller

cc: T. A. Pitterle
 G. P. Lilly
 W. J. Scherder

This is to respond to an action item generated during the March 6, 1996, reviewing meeting between Hsiung Lee and Westinghouse concerning the computer modeling of TRANFLO and RELAP for Model 51 steam generators. Please forward this to Hsiung Lee for his information and use.

The TRANFLO model for steam line break event considers a crossflow resistance across the tubesheet. The RELAP code may not have a built-in correlation for this crossflow resistance. It was agreed that Westinghouse should provide an equivalent crossflow loss coefficient for the use in the RELAP simulation.

The built-in correlation for the crossflow resistance in the TRANFLO code is as follows:

$$K = 192 Re_v^{-0.143} \left(\frac{P}{De} \right)^{0.6} N_L$$

where

- Re_v = Reynolds number
- P = tube pitch
- De = hydraulic diameter
- N_L = number of tube rows in crossflow

The Reynolds number is defined as below:

$$Re_v = \frac{\rho V_{max} De}{\mu}$$

136/174

HML 10/1/96

STA-042 R.O

where

- ρ = fluid density
- V_{max} = velocity through the tube gap
- μ = dynamic viscosity

The hydraulic diameter is defined as below:

$$De = 4(\pi / 4)[D_{iw}^2 - 2N_{UT}D_o^2] / [\pi(D_{iw} + 2N_{UT}D_o)]$$

where

- D_{iw} = inside diameter of wrapper
- N_{UT} = number of U-tubes
- D_o = outside diameter of U-tube


Now, for Model 51 steam generators, $D_{iw} = 123.50"$, $N_{UT} = 3388$, $D_o = 0.875"$, $P = 1.2812"$. The TRANFLO model considers $NL = 24$ for effective crossflow at the tubesheet. Therefore, it follows that $De = 1.6628"$. Finally, we obtain the following

$$K = 39.4 Re^{-0.4}$$

At a Reynolds number of 1.0×10^6 , $K = 5.32$, and at a Reynolds number of 2.0×10^6 , $K = 4.81$. Note that V_{max} for Reynolds number is based on a flow area of 4.43 ft^2 for the crossflow. Consider that $V_{max} = 10 \text{ ft/sec}$ of saturated water at 1000 psia, it follows that $Re = 46.32 \times 10 \times 1.6628 / (12 \times 0.00006293) = 1.02 \times 10^6$.

Considering the above discussion, we recommend, as an approximation, to use $K = 5.32$ in the RELAP calculation.

Approved:



M. H. Hu
SG Design and Analysis



J. L. Houtman, Manager
SG Design and Analysis

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 137 OF 174 SHEETS
CALC NO. STA-042 R, D

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

Appendix B

Sensitivity Study for Initial Steam Generator Water Level

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 138 OF 174 SHEETS
CALC NO. STA-042 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

As discussed in Section 5, void fraction used in the TRANFLO model is input into RELAP5 model as quality. A sensitivity study is performed in this Appendix to show that the RELAP5 model is conservative. The LB Case 2 is reanalyzed in LB Case 4 with changing the void fractions used for Volumes 23-01, 32-01, 33-01, 53-01 and 36-01 to water qualities. The equation 12-3a of Reference 6 gives the relation between void fraction and water quality as follows.

$$F = (X * Vg) / (Vf + X * Vfg)$$

where F = void fraction

X = water quality

Vf = specific volume for water

Vg = specific volume for steam

$$Vfg = Vg - Vf$$

The above equation can be rewritten as:

$$F * Vf + X * F * (Vg - Vf) = X * Vg$$

$$X * (Vg - F * Vg + F * Vf) = F * Vf$$

$$X = (F * Vf) / ((1-F) * Vg + F * Vf)$$

For Volume 23-01, the pressure is 1022.72 psia. The specific volumes for saturated water and steam at 1022.72 psia are 0.02167 ft³/lbm and 0.43491 ft³/lbm. Then, the water quality for void fraction 0.03 is 0.00154.

For Volume 32-01, the pressure is 1021.26 psia. The specific volumes for saturated water and steam at 1021.26 psia are 0.02167 ft³/lbm and 0.43560

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 139 OF 174 SHEETS
CALC NO. STA-042 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

ft³/lbm. Then, the water quality for void fraction 0.92 is 0.364.

For Volumes 33-01 and 53-01, the pressure is 1021.72 psia. The specific volumes for saturated water and steam at 1021.72 psia are 0.02167 ft³/lbm and 0.43539 ft³/lbm. Then, the water quality for void fraction 0.73 is 0.119.

For Volume 36-01, the pressure is 1021.57 psia. The specific volumes for saturated water and steam at 1021.57 psia are 0.02167 ft³/lbm and 0.43546 ft³/lbm. Then, the water quality for void fraction 0.83 is 0.195.

The following input change are used in the reanalysis.

| | | | |
|---------|---|---------|---------|
| 0230200 | 2 | 1022.72 | 0.00154 |
| 0320200 | 2 | 1021.26 | 0.364 |
| 0330200 | 2 | 1021.72 | 0.119 |
| 0530200 | 2 | 1021.72 | 0.119 |
| 0360200 | 2 | 1021.57 | 0.195 |

The remain input is the same as those used for LB Case 2. The input file name is reidp6 and the output file name is reodp6.

The results of the LB Case 4 are microfiched and attached in the Appendix G. The time history of the differential pressures across TSPs 1 to 7 after the initiation of the break are plotted on Figures B-1 to B-7. The peak differential pressures across the TSPs 1 to 7 are 1.814 psi, 2.116 psi, 2.559

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET


SHEET NO. 140 OF 174 SHEETS
CALC NO. STA-042 R0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

psi, 3.987 psi, 5.733 psi, 7.814 and 9.130 psi, respectively. The time history curves for the differential pressure across the TSPs for LB Case 4 are very similar to those for LB Case 2. The magnitude of the differential pressure across the TSPs for LB Case 4 are smaller than those for LB Case 2. Therefore, it can be conclude that the RELAP5 model used in this calculation is conservative.

141/174
HML 10/1/96
STA-0421

FIGURE B-1



DP AT TSP 2 (LB CASE 4)





FIGURE B-2

142/74
MAR 19/196
STA-002 R.

143/174
HNL 10/1/96
STA-042 E

FIGURE B-3



DP AT TSP 4 (LB CASE 4)




FIGURE B-4

148/174
148-191/96
570-042
P. 0

185/174
HML 19/1/96
STA-002
R.O

FIGURE B-5





FIGURE-6

146/174
HAM 10/1/96
STA-042
R.O




147/178

HAN 10/1/96

STA-042

R.O

FIGURE B-7



PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 168 OF 174 SHEETS
CALC NO. STA-042 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident

MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

Appendix C

Tranflo Input Changes for Case 61

149/174

Wiley-1 SLB BOT STD -Nominal Level (490°) - DER

| | | | | | | | |
|--------|--------|--------|-------|---------|-----|------|---|
| 11 | 0 | 244.3 | 38.57 | 1022.72 | 547 | 0.03 | 0 |
| | 0 | 86.73 | 42.97 | 1021.26 | 547 | 0.92 | 0 |
| 13 | 0 | 688.6 | 42.04 | 1021.72 | 547 | 0.73 | 0 |
| 16 | 0 | 22.83 | 43.52 | 1021.57 | 547 | 0.82 | 0 |
| 1.548 | 17.74 | .4275 | 0.5 | 0.5 | 3 | | |
| 1.548 | 17.74 | .4275 | 0.5 | 0.5 | 3 | | |
| 13.716 | 0.0625 | 0.0625 | 0.78 | 0.78 | 3 | | |
| 13.716 | 0.0625 | 0.0625 | 0.78 | 0.78 | 3 | | |
| 13.716 | 0.0625 | 0.0625 | 0.78 | 0.78 | 3 | | |
| 13.716 | 0.0625 | 0.0625 | 0.78 | 0.78 | 3 | | |
| 13.716 | 0.0625 | 0.0625 | 0.78 | 0.78 | 3 | | |
| 13.716 | 0.0625 | 0.0625 | 0.78 | 0.78 | 3 | | |
| 13.716 | 0.0625 | 0.0625 | 0.78 | 0.78 | 3 | | |

Nodes for Water level
HML 10/11/96
STA-042
R.V

Connectors 3 of 31, D.E. Resist.

Connectors 34-40 TSP loss coeff

Case 1 Cards to
be changed for
Case 61

JAN 25 '96 16:48

FROM OPL LICENSING

Wiley-1 SLB BOT STD -Worst case (case 61)

| | | | | | | | |
|--------|--------|--------|-------|---------|-----|------|---|
| 11 | 0 | 244.3 | 38.57 | 1022.17 | 547 | 0.39 | 0 |
| 12 | 0 | 86.73 | 42.97 | 1021.28 | 547 | 1 | 0 |
| 13 | 0 | 688.6 | 42.04 | 1021.28 | 547 | 0.93 | 0 |
| 16 | 0 | 22.83 | 43.52 | 1021.07 | 547 | 1 | 0 |
| 1.548 | 17.74 | .4275 | 0.0 | 0.0 | 3 | | |
| 1.548 | 17.74 | .4275 | 0.0 | 0.0 | 3 | | |
| 13.716 | 0.0625 | 0.0625 | 0.99 | 0.99 | 3 | | |
| 13.716 | 0.0625 | 0.0625 | 0.99 | 0.99 | 3 | | |
| 13.716 | 0.0625 | 0.0625 | 0.99 | 0.99 | 3 | | |
| 13.716 | 0.0625 | 0.0625 | 0.99 | 0.99 | 3 | | |
| 13.716 | 0.0625 | 0.0625 | 0.99 | 0.99 | 3 | | |
| 13.716 | 0.0625 | 0.0625 | 0.99 | 0.99 | 3 | | |
| 13.716 | 0.0625 | 0.0625 | 0.99 | 0.99 | 3 | | |

Case 61 cards
changed from
Case 1

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 150 OF 176 SHEETS
CALC NO.: STA-042 R.D

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

Appendix D

Input Listing for LB Case 1

151/174
HML 10/1/96
STA-042
R.O

=SLB pressure difference across the SG tube support plats
* hot standby nonequilibrium models
*
*
*
100 new transnt
*
*
102 british british
105
*

* time step cards
*
*
*
201 5. 1.d-7 0.005 3 2 200 10000
202 5.3 1.d-7 0.00001 3 1000 20000 100000
203 6.5 1.d-7 0.000025 3 400 8000 100000
204 8.0 1.d-7 0.00005 3 200 10000 100000
205 1000.0 1.d-7 0.00010 3 100 10000 100000

* minor edit variables
*
*
*
301 mflowj 518000000
302 mflowj 002030000
303 mflowj 002070000
304 mflowj 002110000
305 mflowj 002150000
306 mflowj 002190000
307 mflowj 002230000
308 mflowj 002270000
309 p 017010000
*310 p 018010000
*311 p 019010000
*312 p 020010000
*313 p 021010000
*314 p 022010000
*315 p 023010000
*316 p 033010000
*317 p 034010000
*318 p 036010000
319 cntrlvar 1
320 cntrlvar 2
321 cntrlvar 3
322 cntrlvar 4
323 cntrlvar 5
324 cntrlvar 6
325 cntrlvar 7
*
*
*
*
*
*
*
*
*
*

* trip input data
*
*
*
501 time 0 ge null 0 8.0 1

152/174

HML 10/1/96

STA - 042 R.O

```

502 time 0 ge null 0 5.0 1
503 time 0 ge null 0 200.0 1

```

600 501

```

*****
* hydrodynamic components
*

```

```

*****
* primary side model
* hot leg and cold leg represented by tdvs
*****

```

```

*
1000000 inplen tmdpvol
1000101 0.0 10.0 5000.0 0.0 0.0 0.0 0.0 0.0 0
1000200 3
1000201 0.0 2235.7 547.0
1000202 5.0 2250.0 547.0
1000203 15.0 800.0 491.0
*1000204 1.0e6 800.0 491.0

```

```

*
1010000 outplen tmdpvol
1010101 0.0 10.0 5000.0 0.0 0.0 0.0 0.0 0.0 0
1010200 3
1010201 0.0 2200.0 547.0
1010202 5.0 2200.0 547.0
1010203 15.0 700.0 491.0

```

```

*
0010000 tubes pipe
0010001 60
0010101 10.956 60
0010301 1.1667 1
0010302 1.2553 3
0010303 0.5 5
0010304 1.60435 7
0010305 0.5 9
0010306 1.60435 11
0010307 0.5 13
0010308 1.60435 15
0010309 0.5 17
0010310 1.60435 19
0010311 0.5 21
0010312 1.60435 23
0010313 0.5 25
0010314 1.60435 27
0010315 0.5 29
0010316 3.0 31
0010317 0.5 33
0010318 1.60435 35
0010319 0.5 37
0010320 1.60435 39
0010321 0.5 41
0010322 1.60435 43

```

153/174

HML 10/1/96

STA-042

| | | | | | | | |
|---------|----------|--------|-----|-----|-----|-----|----|
| 0010323 | 0.5 | 45 | | | | | |
| 0010324 | 1.60435 | 47 | | | | | |
| 0010325 | 0.5 | 49 | | | | | |
| 0010326 | 1.60435 | 51 | | | | | |
| 0010327 | 0.5 | 53 | | | | | |
| 0010328 | 1.60435 | 55 | | | | | |
| 0010329 | 0.5 | 57 | | | | | |
| 0010330 | 1.2553 | 59 | | | | | |
| 0010331 | 1.1667 | 60 | | | | | |
| 0010601 | 90.0 | 30 | | | | | |
| 0010602 | -90.0 | 60 | | | | | |
| 0010801 | 0.0 | 0.0642 | 60 | | | | |
| 0011001 | 00000 | 60 | | | | | |
| 0011101 | 000000 | 59 | | | | | |
| 0011201 | 3 2250.0 | 547.0 | 0.0 | 0.0 | 0.0 | 0.0 | 60 |
| 0011300 | 1 | | | | | | |
| 0011301 | 9148.5 | 0.0 | 0.0 | 59 | | | |

*
*

| | | | | | | | |
|---------|-----------|---------|--------|-----|--|--|--|
| 5000000 | prmin1 | tmdpjun | | | | | |
| 5000101 | 100000000 | 1000000 | 10.956 | | | | |
| 5000200 | 1 | | | | | | |
| 5000201 | 0.0 | 9148.5 | 0.0 | 0.0 | | | |
| 5000202 | 1.0e6 | 9148.5 | 0.0 | 0.0 | | | |

*
*

| | | | | | | | |
|---------|---------|-----------|--------|-----|--|--|--|
| 5010000 | prout | tmdpjun | | | | | |
| 5010101 | 1010000 | 101000000 | 10.956 | | | | |
| 5010200 | 1 | | | | | | |
| 5010201 | 0.0 | 9148.5 | 0.0 | 0.0 | | | |
| 5010202 | 1.0e6 | 9148.5 | 0.0 | 0.0 | | | |

*
*

| | | | | | | | |
|---------|---------|------|--|--|--|--|--|
| 0020000 | shell | pipe | | | | | |
| 0020001 | 30 | | | | | | |
| 0020101 | 54.22 | 27 | | | | | |
| 0020102 | 70.0 | 30 | | | | | |
| 0020201 | 54.22 | 2 | | | | | |
| 0020202 | 23.716 | 3 | | | | | |
| 0020203 | 54.22 | 6 | | | | | |
| 0020204 | 23.716 | 7 | | | | | |
| 0020205 | 54.22 | 10 | | | | | |
| 0020206 | 23.716 | 11 | | | | | |
| 0020207 | 54.22 | 14 | | | | | |
| 0020208 | 23.716 | 15 | | | | | |
| 0020209 | 54.22 | 18 | | | | | |
| 0020210 | 23.716 | 19 | | | | | |
| 0020211 | 54.22 | 22 | | | | | |
| 0020212 | 23.716 | 23 | | | | | |
| 0020213 | 54.22 | 26 | | | | | |
| 0020214 | 23.716 | 27 | | | | | |
| 0020215 | 70.0 | 29 | | | | | |
| 0020301 | 1.2553 | 1 | | | | | |
| 0020302 | 1.2553 | 2 | | | | | |
| 0020303 | 0.5 | 4 | | | | | |
| 0020304 | 1.60435 | 6 | | | | | |
| 0020305 | 0.5 | 8 | | | | | |
| 0020306 | 1.60435 | 10 | | | | | |
| 0020307 | 0.5 | 12 | | | | | |
| 0020308 | 1.60435 | 14 | | | | | |

154/174

HML 10/1/96

STA-042 R.D

| | | | | | | | |
|---------|-----------|-------|-----|-----|-----|----|--|
| 0020309 | 0.5 | 16 | | | | | |
| 0020310 | 1.60435 | 18 | | | | | |
| 0020311 | 0.5 | 20 | | | | | |
| 0020312 | 1.60435 | 22 | | | | | |
| 0020313 | 0.5 | 24 | | | | | |
| 0020314 | 1.60435 | 26 | | | | | |
| 0020315 | 0.5 | 28 | | | | | |
| 0020316 | 3.2075 | 29 | | | | | |
| 0020317 | 3.4338 | 30 | | | | | |
| 0020601 | 90.0 | 30 | | | | | |
| 0020801 | 0.00015 | 0.136 | 29 | | | | |
| 0020802 | 0.00015 | 0.0 | 30 | | | | |
| 0020901 | 0.0 | 0.0 | 2 | | | | |
| 0020902 | 0.78 | 0.78 | 3 | | | | |
| 0020903 | 0.0 | 0.0 | 6 | | | | |
| 0020904 | 0.78 | 0.78 | 7 | | | | |
| 0020905 | 0.0 | 0.0 | 10 | | | | |
| 0020906 | 0.78 | 0.78 | 11 | | | | |
| 0020907 | 0.0 | 0.0 | 14 | | | | |
| 0020908 | 0.78 | 0.78 | 15 | | | | |
| 0020909 | 0.0 | 0.0 | 18 | | | | |
| 0020910 | 0.78 | 0.78 | 19 | | | | |
| 0020911 | 0.0 | 0.0 | 22 | | | | |
| 0020912 | 0.78 | 0.78 | 23 | | | | |
| 0020913 | 0.0 | 0.0 | 26 | | | | |
| 0020914 | 0.78 | 0.78 | 27 | | | | |
| 0020915 | 0.0 | 0.0 | 29 | | | | |
| 0021001 | 00100 | 29 | | | | | |
| 0021002 | 00000 | 30 | | | | | |
| 0021101 | 000000 | 29 | | | | | |
| 0021201 | 3 1033.73 | 547.0 | 0.0 | 0.0 | 0.0 | 1 | |
| 0021202 | 3 1033.34 | 547.0 | 0.0 | 0.0 | 0.0 | 2 | |
| 0021203 | 3 1033.07 | 547.0 | 0.0 | 0.0 | 0.0 | 3 | |
| 0021204 | 3 1032.91 | 547.0 | 0.0 | 0.0 | 0.0 | 4 | |
| 0021205 | 3 1032.57 | 547.0 | 0.0 | 0.0 | 0.0 | 5 | |
| 0021206 | 3 1032.06 | 547.0 | 0.0 | 0.0 | 0.0 | 6 | |
| 0021207 | 3 1031.72 | 547.0 | 0.0 | 0.0 | 0.0 | 7 | |
| 0021208 | 3 1031.56 | 547.0 | 0.0 | 0.0 | 0.0 | 8 | |
| 0021209 | 3 1031.22 | 547.0 | 0.0 | 0.0 | 0.0 | 9 | |
| 0021210 | 3 1030.71 | 547.0 | 0.0 | 0.0 | 0.0 | 10 | |
| 0021211 | 3 1030.37 | 547.0 | 0.0 | 0.0 | 0.0 | 11 | |
| 0021212 | 3 1030.21 | 547.0 | 0.0 | 0.0 | 0.0 | 12 | |
| 0021213 | 3 1029.87 | 547.0 | 0.0 | 0.0 | 0.0 | 13 | |
| 0021214 | 3 1029.36 | 547.0 | 0.0 | 0.0 | 0.0 | 14 | |
| 0021215 | 3 1029.02 | 547.0 | 0.0 | 0.0 | 0.0 | 15 | |
| 0021216 | 3 1028.86 | 547.0 | 0.0 | 0.0 | 0.0 | 16 | |
| 0021217 | 3 1028.53 | 547.0 | 0.0 | 0.0 | 0.0 | 17 | |
| 0021218 | 3 1028.01 | 547.0 | 0.0 | 0.0 | 0.0 | 18 | |
| 0021219 | 3 1027.68 | 547.0 | 0.0 | 0.0 | 0.0 | 19 | |
| 0021220 | 3 1027.52 | 547.0 | 0.0 | 0.0 | 0.0 | 20 | |
| 0021221 | 3 1027.18 | 547.0 | 0.0 | 0.0 | 0.0 | 21 | |
| 0021222 | 3 1026.66 | 547.0 | 0.0 | 0.0 | 0.0 | 22 | |
| 0021223 | 3 1026.33 | 547.0 | 0.0 | 0.0 | 0.0 | 23 | |
| 0021224 | 3 1026.17 | 547.0 | 0.0 | 0.0 | 0.0 | 24 | |
| 0021225 | 3 1025.83 | 547.0 | 0.0 | 0.0 | 0.0 | 25 | |
| 0021226 | 3 1025.32 | 547.0 | 0.0 | 0.0 | 0.0 | 26 | |
| 0021227 | 3 1024.98 | 547.0 | 0.0 | 0.0 | 0.0 | 27 | |
| 0021228 | 3 1024.82 | 547.0 | 0.0 | 0.0 | 0.0 | 28 | |
| 0021229 | 3 1024.23 | 547.0 | 0.0 | 0.0 | 0.0 | 29 | |
| 0021230 | 3 1023.17 | 547.0 | 0.0 | 0.0 | 0.0 | 30 | |

155/174

HML 10/1/96

STA-042 k

0021300 1
 0021301 0.0 0.0 0.0 29
 0021401 0.0625 0.0 1.0 1.0 29

*
0350000 downc pipe

0350001 3
 0350101 0.0 3
 0350201 7.096 2
 0350301 11.827 3
 0350401 122.4 3
 0350601 -90.0 3
 0350801 0.00015 0.4275 3
 0351001 00000 3
 0351101 000000 2
 0351201 3 1024.84 547.0 0.0 0.0 0.0 1
 0351202 3 1028.64 547.0 0.0 0.0 0.0 2
 0351203 3 1032.44 547.0 0.0 0.0 0.0 3
 0351300 1
 0351301 0.0 0.0 0.0 2

*
0300000 tubesh branch

0300001 2 1
 0300101 54.22 1.1667 0. 0. 90. 1.1667 0.00015 0.136 00100
 0300200 3 1034.15 547.0
 0301101 035010000 030000000 7.096 0.5 0.5 000000
 0302101 030010000 002000000 4.43 5.32 5.32 000000
 0301201 0.0 0.0 0.0
 0302201 0.0 0.0 0.0

*
0340000 feedrg branch

0340001 1 1
 0340101 92.1 3.1097 0.0 0. -90. -3.1097 0.00015 0.0 00000
 0340200 3 1022.48 547.0
 0341101 034010000 035000000 7.096 0.0 0.0 000100
 0341201 0.0 0.0 0.0

*
0230000 abovetb snglvol

0230101 49.43 4.9423 0.0 0.0 90. 4.9423 0.00015 0.0 00000
 0230200 2 1022.72 0.03

*
5330000 abovetb sngljun

5330101 002010000 023000000 49.43 0.0 0.0 000100
 5330110 0.0 0.0 1.0 1.0
 5330201 1 0.0 0.0 0.0

*
0220000 speratr separatr

0220001 3 1
 0220101 41.73 3.9156 0.0 0. 90. 3.9156 0.00015 0.0 00000
 0220200 2 1021.14 1.0
 0221101 022010000 021000000 12.828 0.84 0.47 000000
 0222101 022000000 032000000 17.35 0.597 0.597 000000
 0223101 023010000 022000000 41.73 8.689 8.689 000000
 0221201 0.0 0.0 0.0
 0222201 0.0 0.0 0.0

156/17P

HML 10/1/96

STA-042
R.D

```

0223201 0.0 0.0 0.0
*
*
0300000 liqsept snglvol
0.01 17.35 0.0 86.75 0.0 0.0 0.0 0.00015 0.0 00000
030200 2 1021.26 0.92
*
*
0330000 abovf1 branch
0330001 2 1
0330101 100.7 2.9225 0.0 0.0 -90.0 -2.9225 0.00015 0.0 00000
0330200 2 1021.72 0.73
0331101 032010000 033000000 17.35 0.0 0.0 000000
0332101 033010000 034000000 79.288 0.0 0.0 000000
0331201 0.0 0.0 0.0
0332201 0.0 0.0 0.0
*
*
0530000 abovfr2 branch
0530001 2 1
0530101 100.7 3.9156 0.0 0.0 -90.0 -3.9156 0.00015 0.0 00000
0530200 2 1021.72 0.73
0531101 036010000 053000000 2.34 0.5 0.5 000000
0532101 053010000 033000000 100.7 0.0 0.0 000000
0531201 0.0 0.0 0.0
0532201 0.0 0.0 0.0
*
*
0210000 abovspr branch
0210001 2 1
0210101 152.19 2.281 0.0 0.0 90. 2.281 0.00015 0.0 00000
0210200 2 1021.12 1.0
0211101 021010000 020000000 70.75 0.0 0.0 000100
0212101 021000000 053000000 7.96 1.78 1.67 000000
0211201 0.0 0.0 0.0
0212201 0.0 0.0 0.0
*
*
0200000 spsteam snglvol
0200101 70.75 7.4502 0.0 0.0 90. 7.4502 0.00015 0.0 00000
0200200 2 1020.96 1.0
*
*
0190000 dryer separatr
0190001 3 1
0190101 171.4 0.7083 0.0 0. 0. 0. 0.00015 0.0 00000
0190200 2 1020.96 1.0
0191101 019010000 018000000 63.49 5.502 5.502 000000
0192101 019000000 036000000 2.34 0.5 0.5 000000
0193101 020010000 019000000 70.75 0.5 0.5 000000
0191201 0.0 0.0 0.0
0192201 0.0 0.0 0.0
0193201 0.0 0.0 0.0
*
*
0360000 dsdryer snglvol
0360101 2.34 9.7312 0.0 0.0 -90. -9.7312 0.00015 0.0 00000
0360200 2 1021.57 0.82
*
*

```

157/174

AML 19/1/96

STA-0021

```

0180000 updryer  snglvol
0180101 63.49  0.0  473.0  0.0  0.  0.0  0.00015  0.0  00000
0180200 2      1020.96  1.0

```

```

*
*
0170000 sgdoom  snglvol
0170101 94.12  3.5497  0.0  0.0  90.  3.5497  0.00015  0.0  00000
0170200 2      1020.94  1.0

```

```

*
0380000 contnm  snglvol
0380101 10000.0  200.0  0.0  0.0  90.  200.0  0.0  0.0  00000
0380200 2      14.7  1.0

```

```

*
5190000 abovefr  sngljun
5190101 018010000  017000000  63.49  0.0  0.0  000000
5190110 0.0  0.0  1.0  1.0
5190201 1  0.0  0.0  0.0

```

```

*
5180000 break  valve
5180101 017010000  038000000  4.6  0.0  0.0  000100
5180110 0.0  0.0  1.0  1.0
5180201 1  0.0  0.0  0.0
5180300 mtrvlv
5180301 502  503  1000.0  0.0

```

* heat structure input

```

*****
11201000 60 11 2 1 0.0321
11201100 0 2
11201101 0.000438 10
11201201 1 10
11201301 0.0 10
11201401 547.0 11
11201501 001010000 0000 1 0 796.74 1
11201502 001020000 10000 1 0 857.24 3
11201503 001040000 10000 1 0 341.45 5
11201504 001060000 10000 1 0 1095.61 7
11201505 001080000 10000 1 0 341.45 9
11201506 001100000 10000 1 0 1095.61 11
11201507 001120000 10000 1 0 341.45 13
11201508 001140000 10000 1 0 1095.61 15
11201509 001160000 10000 1 0 341.45 17
11201510 001180000 10000 1 0 1095.61 19
11201511 001200000 10000 1 0 341.45 21
11201512 001220000 10000 1 0 1095.61 23
11201513 001240000 10000 1 0 341.45 25
11201514 001260000 10000 1 0 1095.61 27
11201515 001280000 10000 1 0 341.45 29
11201516 001300000 10000 1 0 2190.4 31
11201517 001320000 10000 1 0 341.45 33
11201518 001340000 10000 1 0 1095.61 35
11201519 001360000 10000 1 0 341.45 37
11201520 001380000 10000 1 0 1095.61 39
11201521 001400000 10000 1 0 341.45 41

```

158/174

HML 10/1/96

STA-042
R.0

| | | | | | | | | |
|----------|-----------|--------|------|-----|-----------|-----|-----|--------|
| 11201522 | 001420000 | 10000 | 1 | 0 | 1095.61 | 43 | | |
| 11201523 | 001440000 | 10000 | 1 | 0 | 341.45 | 45 | | |
| 11201524 | 001460000 | 10000 | 1 | 0 | 1095.61 | 47 | | |
| 11201525 | 001480000 | 10000 | 1 | 0 | 341.45 | 49 | | |
| 11201526 | 001500000 | 10000 | 1 | 0 | 1095.61 | 51 | | |
| 11201527 | 001520000 | 10000 | 1 | 0 | 341.45 | 53 | | |
| 11201528 | 001540000 | 10000 | 1 | 0 | 1095.61 | 55 | | |
| 11201529 | 001560000 | 10000 | 1 | 0 | 341.45 | 57 | | |
| 11201530 | 001580000 | 10000 | 1 | 0 | 857.24 | 59 | | |
| 11201531 | 001600000 | 0000 | 1 | 0 | 796.74 | 60 | | |
| 11201601 | 030010000 | 0000 | 1 | 0 | 905.4541 | 1 | | |
| 11201602 | 002010000 | 10000 | 1 | 0 | 974.2092 | 3 | | |
| 11201603 | 002030000 | 10000 | 1 | 0 | 388.0404 | 5 | | |
| 11201604 | 002050000 | 10000 | 1 | 0 | 1245.1044 | 7 | | |
| 11201605 | 002070000 | 10000 | 1 | 0 | 388.0404 | 9 | | |
| 11201606 | 002090000 | 10000 | 1 | 0 | 1245.1044 | 11 | | |
| 11201607 | 002110000 | 10000 | 1 | 0 | 388.0404 | 13 | | |
| 11201608 | 002130000 | 10000 | 1 | 0 | 1245.1044 | 15 | | |
| 11201609 | 002150000 | 10000 | 1 | 0 | 388.0404 | 17 | | |
| 11201610 | 002170000 | 10000 | 1 | 0 | 1245.1044 | 19 | | |
| 11201611 | 002190000 | 10000 | 1 | 0 | 388.0404 | 21 | | |
| 11201612 | 002210000 | 10000 | 1 | 0 | 1245.1044 | 23 | | |
| 11201613 | 002230000 | 10000 | 1 | 0 | 388.0404 | 25 | | |
| 11201614 | 002250000 | 10000 | 1 | 0 | 1245.1044 | 27 | | |
| 11201615 | 002270000 | 10000 | 1 | 0 | 388.0404 | 29 | | |
| 11201616 | 002290000 | 0000 | 1 | 0 | 2489.277 | 31 | | |
| 11201617 | 002280000 | -10000 | 1 | 0 | 388.0404 | 33 | | |
| 11201618 | 002260000 | -10000 | 1 | 0 | 1245.1044 | 35 | | |
| 11201619 | 002240000 | -10000 | 1 | 0 | 388.0404 | 37 | | |
| 11201620 | 002220000 | -10000 | 1 | 0 | 1245.1044 | 39 | | |
| 11201621 | 002200000 | -10000 | 1 | 0 | 388.0404 | 41 | | |
| 11201622 | 002180000 | -10000 | 1 | 0 | 1245.1044 | 43 | | |
| 11201623 | 002160000 | -10000 | 1 | 0 | 388.0404 | 45 | | |
| 11201624 | 002140000 | -10000 | 1 | 0 | 1245.1044 | 47 | | |
| 11201625 | 002120000 | -10000 | 1 | 0 | 388.0404 | 49 | | |
| 11201626 | 002100000 | -10000 | 1 | 0 | 1245.1044 | 51 | | |
| 11201627 | 002080000 | -10000 | 1 | 0 | 388.0404 | 53 | | |
| 11201628 | 002060000 | -10000 | 1 | 0 | 1245.1044 | 55 | | |
| 11201629 | 002040000 | -10000 | 1 | 0 | 388.0404 | 57 | | |
| 11201630 | 002020000 | -10000 | 1 | 0 | 974.2092 | 59 | | |
| 11201631 | 030010000 | 0000 | 1 | 0 | 905.4541 | 60 | | |
| 11201701 | 0 | 0.0 | 0.0 | 0.0 | 60 | | | |
| 11201801 | 0.0 | 15.0 | 15.0 | 1.5 | 1.5 | 0.0 | 0.0 | 1.0 60 |
| 11201901 | 0.0 | 15.0 | 15.0 | 1.5 | 1.5 | 0.0 | 0.0 | 1.0 60 |

*
*
* composition type and data format
*

| | | | | |
|----------|----------|------------|---|-----------|
| 20100100 | tbl/fctn | 1 | 1 | * inconel |
| 20100101 | 70.0 | 2.3843e-03 | | |
| 20100102 | 200.0 | 2.5232e-03 | | |
| 20100103 | 400.0 | 2.8009e-03 | | |
| 20100104 | 600.0 | 3.0787e-03 | | |
| 20100105 | 800.0 | 3.3565e-03 | | |
| 20100106 | 1000.0 | 3.6574e-03 | | |
| 20100107 | 1200.0 | 3.9815e-03 | | |
| 20100108 | 1400.0 | 4.3056e-03 | | |
| 20100151 | 70.0 | 55.6831 | | |
| 20100152 | 200.0 | 55.5227 | | |

159/174
HML 1/1/96
STA-042 R.V

| | | |
|----------|--------|---------|
| 20100153 | 400.0 | 55.2607 |
| 20100154 | 600.0 | 54.9895 |
| 20100155 | 800.0 | 54.7069 |
| 2 0156 | 1000.0 | 54.3982 |
| 2 0157 | 1200.0 | 54.0907 |
| 20100158 | 1400.0 | 53.7516 |

*
* control component cards
*
* compute pressure difference
*

20500100 delptp1 sum 1.45038e-4 0.0 1
20500101 0.0 -1.0, p, 002040000 1.0, p, 002030000
20500200 delptp2 sum 1.45038e-4 0.0 1
20500201 0.0 -1.0, p, 002080000 1.0, p, 002070000
20500300 delptp3 sum 1.45038e-4 0.0 1
20500301 0.0 -1.0, p, 002120000 1.0, p, 002110000
20500400 delptp4 sum 1.45038e-4 0.0 1
20500401 0.0 -1.0, p, 002160000 1.0, p, 002150000
20500500 delptp5 sum 1.45038e-4 0.0 1
20500501 0.0 -1.0, p, 002200000 1.0, p, 002190000
20500600 delptp6 sum 1.45038e-4 0.0 1
20500601 0.0 -1.0, p, 002240000 1.0, p, 002230000
20500700 delptp7 sum 1.45038e-4 0.0 1
20500701 0.0 -1.0, p, 002280000 1.0, p, 002270000

*
* end of the input
*
* *****
*

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 160 OF 174 SHEETS
CALC NO. STA-042 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

Appendix E

Steam Generator Design Alternation
(Westinghouse Letter NCE-85-529)

7.

378
HML 10/1/196

51 SERIES STEAM GENERATORS

51A-012 R.0

Default Geometry: **CN-TA-90-167**

INPUT DATA BASED ON MODEL 51 STEAM GENERATOR DEFAULT GEOMETRY

| MODEL | 51 | MODE | 0 | IFINAL | 1 | |
|-------|--------|--------|----------|--------|---------|-------|
| IT | 1 | TUREND | 0 | IMPU | 0 | |
| DPI | 31.00 | DPO | 31.00 | ALI | 12.22 | |
| ALB | 12.22 | ALPHAI | 11.00 | ALPHAO | 11.00 | |
| DC | 125.12 | TTP | 21.28 | DIUS | 168.50 | |
| DIU | 123.00 | DILS | 14.32 | 9ICDP | 15.01 | |
| DSN | 20.00 | DSU | 5.05 | DPOD | 28.00 | |
| ANDP | 1 | DM | 20.00 | XOAR | 3. | |
| DT | 56.00 | ALPHA | 37.00 | MT | 33.64 | |
| M2 | 22.19 | DIUJ | 135.22 | MT8 | 417.03 | |
| CAPR | 8.43 | SL | 86.03 | XLATC | 21.50 | |
| MC | 34.38 | DIRC | 62.25 | XLA | 106.49 | |
| XLS | 3.21 | HD | 0.50 | ELFDR | 463.00 | |
| XLIUS | 232.16 | XLU | 300.81 | CKR | 10.000 | |
| MNO | 14.00 | XLBC | 12.74 | DIDCB | 65.61 | |
| XLIJW | 11.31 | XLSTC | 71.7 | MSNU | 4.587 | |
| XLIS | 359.99 | AMTS | 7 | USM | 0.34 | |
| XLIS | 41.45 | CK1 | 0.780 | USM | 45.38 | |
| ELSN | 721.00 | CKSN | 0.230 | TKRDP | 0.375 | |
| CKFCR | 9.420 | CKSEP2 | 92.000 | TKCDP | 0.250 | |
| CKDC | 0.000 | TKDCB | 0.313 | TT | 0.05250 | |
| XLDCB | 60.00 | USM | 5.36 | AO | 51500. | |
| UIM | 14.57 | USM | 1.22 | PS | 350.00 | |
| U4R | 3.50 | X5 | 0.70 | US | 0.00000 | |
| X4 | 0.50 | TKLDP | 0.375 | ADCO 1 | 0.200 | |
| TU | 0.375 | TKMSR | 0.250 | ADCO 2 | 0.200 | |
| TKLDP | 0.750 | TKTS | 0.750 | ADCO 3 | 0.200 | |
| TKUP | 0.258 | DO | 0.8750 | ADCO 4 | 0.200 | |
| STP | 7.00 | MN | 3381. | ADCO 5 | 0.200 | |
| PT | 1.2810 | ACJ | 0.87 | ADCO 6 | 0.200 | |
| ARBGT | 0.50 | RF | 0.000100 | ADCO 7 | 0.200 | |
| PCL | 100.00 | TAUG | 0.00 | | | |
| U80 | 0. | | | | | |
| 11-13 | ALTS 1 | 50.12 | AFTS 1 | 23.77 | ADCO 1 | 0.200 |
| | ALTS 2 | 99.87 | AFTS 2 | 23.77 | ADCO 2 | 0.200 |
| | ALTS 3 | 149.62 | AFTS 3 | 23.77 | ADCO 3 | 0.200 |
| | ALTS 4 | 199.37 | AFTS 4 | 23.77 | ADCO 4 | 0.200 |
| | ALTS 5 | 249.12 | AFTS 5 | 23.77 | ADCO 5 | 0.200 |
| | ALTS 6 | 298.87 | AFTS 6 | 23.77 | ADCO 6 | 0.200 |
| | ALTS 7 | 348.62 | AFTS 7 | 23.77 | ADCO 7 | 0.200 |

1.63/174

AML 10/1/96

STA-042 R.D

51 Series Steam Generators Standard Features:

- 0 3 56-inch primary separators
- 0 Steam nozzle with no flow limiting devices
- 0 Fillet type tube-to-tubesheet weld
- 0 Secondary separator with Westinghouse formed vanes and perforated plates
- 0 Downcomer resistance plate removed
- 0 0.5 orifice

Farley 1 (ALA)

Special features: None
List input update: RF = 0.00016, CKSEP2 = 125.0

Farley 2 (AFR)

Special features: 7 inch wrapper opening
List input update: HWO = 7.00, XLN = 385.81, RF = 0.00016,
CKSEP2 = 125.0

D. C. Cook 1 & 2 (AEP/AMP)

Special features: None
List input update: RF = 0.00020, CKSEP2 = 125.0

Zion 1 & 2 (CWE/COM)

Special features: 0.6 orifice
High downcomer resistance plate setting
List input update: DPOD = 33.50, CKDC = 16.9, CKSEP2 = 125.0

164/174
371
HML 10/1/96
STAN-ORL
R. O

CN-TA-90-167

Beaver Valley 1 (DLW)

Special features: None
List input update: RF = 0.00016, CKSEP2 = 125.0

TAKAHAMA 1 (TAK)

Special features: 0.6 orifice
Low downcomer resistance plate setting
List input update: DPOD = 33.50, CKDC = 7.26, CKSEP2 = 125.0

OHI 1 (OHI)

Special features: 0.6 orifice
Low downcomer resistance plate setting
List input update: DPOD = 33.50, CKDC = 7.26, RF = 0.00005,
CKSEP2 = 125.0

KORI 1 (KOR)

Special features: 7 inch wrapper opening
List input update: HWO = 7.00, XLW = 385.81, CKSEP2 = 125.0

Prairie Island 1 & 2 (NSP/NRP)

Special features: None
List input update: RF = 0.00018, CKSEP2 = 125.0

Diablo Canyon 1 (PGE)

Special features: None
List input update: RF = 0.00018, CKSEP2 = 125.0

XLW = 380.81

165/174

HML 10/1/96

STA-062 R.0

Diablo Canyon 2 (PEG)

Special features: None
List input update: RF = 0.00018, CKSEP2 = 125.0

Trojan (POR)

Special features: None
List input update: RF = 0.00005, CKSEP2 = 125.0

Salen 1 (PSE)

Special features: None
List input update: RF = 0.00018, CKSEP2 = 125.0

Sequoiah 1 (TVA)

Special features: None
List input update: RF = 0.00006, CKSEP2 = 125.0

Sequoiah 2 (TEN)

Special features: None
List input update: RF = 0.00006, CKSEP2 = 125.0

North Anna 1 (VRA)

Special features: None
List input update: RF = 0.00005, CKSEP2 = 125.0

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 166 OF 174 SHEETS
CALC NO. STA-042 R.D.

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident


MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

Appendix F

Westinghouse Drawing 350794-B
Steam Generator Nozzle to Elliptical Head
51 Series Steam Generator

| | |
|------|--------|
| S.O. | |
| D.S. | |
| ITEM | CHANGE |
| 1 | |

872C799001



| | |
|------------------|------------|
| LAST NUMBER USED | |
| ITEM | PARTS LIST |
| NONE | NONE |
| ISSUE DATE | |
| ENGRS | |
| RES | |
| APP | |
| WELD APP | |

Westinghouse Electric Corporation
TAMPA DIVISION TAMPA FLA.
APPARATUS 51 SERIES STM GEN.
TITLE STEAM OUTLET NOZZLE TO ELLIPTICAL HEAD

DTM T. O. 504
 CHD R. A. O
 DESIGN APP
 WELD APP

FORM NO. 1-A
 REVISIONS
 DRAWING NOT TO SCALE

350794-B
 SHEET NO 1 OF 1 SHEETS

THIS DOCUMENT IS THE PROPERTY OF AND CONTAINS PROPRIETARY INFORMATION OF WESTINGHOUSE ELECTRIC CORPORATION. THE TRANSMISSION OF THIS DOCUMENT TO ANY OTHER PERSON OR THE REPRODUCTION OF THIS DOCUMENT IN ANY MANNER WITHOUT THE EXPRESS WRITTEN PERMISSION OF WESTINGHOUSE ELECTRIC CORPORATION IS PROHIBITED. THIS DOCUMENT IS LOANED TO YOU ON THE UNDERSTANDING THAT YOU WILL NOT DISSEMINATE OR REPRODUCE IT IN ANY MANNER WITHOUT THE EXPRESS WRITTEN PERMISSION OF WESTINGHOUSE ELECTRIC CORPORATION.



167/174
 HNL 10/1/96 STA-002 R.D.

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 168 OF 174 SHEETS
CALC NO. STA-042 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____

Appendix G

Microfiches for the RELAP5 Runs

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 174 OF 174 SHEETS
CALC NO. STA-042 R.O

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____



REDDP 6

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 173 OF 174 SHEETS
CALC NO. STA-042 R. 0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____



REDDP 5

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 172 OF 174 SHEETS
CALC NO. STA-042 R.D

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____



RGODP 4

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 171 OF 174 SHEETS
CALC NO. STA-042 R. 0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident

MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____



RGDDP 3

IFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 170 OF 174 SHEETS
CALC NO. STA-042 R.0

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/196 CHECK BY L R Chang APPROVED BY _____



RGODP 2

PACIFIC GAS AND ELECTRIC COMPANY
GENERAL COMPUTATION SHEET

SHEET NO. 169 OF 174 SHEETS
CALC NO. STA-042 R.O.

SUBJECT Loads on the Steam Generator Support Plats During SLB Accident
MADE BY H M Lee DATE 10/1/96 CHECK BY L R Chang APPROVED BY _____



R50DP1

Hard Copy Listings of Input Decks for RELAP5

RELAP5 Input Deck reidp1

Large Break Case 1 - No flow restrictor, non-equilibrium

=SLB pressure difference across the SG tube support plats

* hot standby nonequilibrium models

*

*

*

100 new transnt

*

*

102 british british

105

*

* time step cards

*

*

201 5. 1.d-7 0.005 3 2 200 10000

202 5.3 1.d-7 0.00001 3 1000 20000 100000

203 6.5 1.d-7 0.000025 3 400 8000 100000

204 8.0 1.d-7 0.00005 3 200 10000 100000

205 1000.0 1.d-7 0.00010 3 100 10000 100000

* minor edit variables

*

*

301 mflowj 518000000

302 mflowj 002030000

303 mflowj 002070000

304 mflowj 002110000

305 mflowj 002150000

306 mflowj 002190000

307 mflowj 002230000

308 mflowj 002270000

309 p 017010000

*310 p 018010000

*311 p 019010000

*312 p 020010000

*313 p 021010000

*314 p 022010000

*315 p 023010000

*316 p 033010000

*317 p 034010000

*318 p 036010000

319 cntrlvar 1

320 cntrlvar 2

321 cntrlvar 3

322 cntrlvar 4

323 cntrlvar 5

324 cntrlvar 6

325 cntrlvar 7

*

*

*

RELAP5 Input Deck reidp1

Large Break Case 1 - No flow restrictor, non-equilibrium

```
*
*
*
*****
*   trip input data
*
*
501  time 0 ge null 0 8.0 |
502  time 0 ge null 0 5.0 |
503  time 0 ge null 0 200.0 |
*
*
*
*
*
*
600 501
*
*****
*   hydrodynamic components
*
*****
*   primary side model
*   hot leg and cold leg represented by tdvs
*****
*
1000000 inplen tmdpvol
1000101 0.0 10.0 5000.0 0.0 0.0 0.0 0.0 0.0 0
1000200 3
1000201 0.0 2235.7 547.0
1000202 5.0 2250.0 547.0
1000203 15.0 800.0 491.0
*1000204 1.0e6 800.0 491.0
*
*
1010000 outplen tmdpvol
1010101 0.0 10.0 5000.0 0.0 0.0 0.0 0.0 0.0 0
1010200 3
1010201 0.0 2200.0 547.0
1010202 5.0 2200.0 547.0
1010203 15.0 700.0 491.0
*
*
0010000 tubes pipe
0010001 60
0010101 10.956 60
0010301 1.1667 1
0010302 1.2553 3
0010303 0.5 5
0010304 1.60435 7
0010305 0.5 9
0010306 1.60435 11
```

RELAP5 Input Deck reidp1**Large Break Case 1 - No flow restrictor, non-equilibrium**

3 of 10

```
0010307 0.5 13
0010308 1.60435 15
0010309 0.5 17
0010310 1.60435 19
0010311 0.5 21
0010312 1.60435 23
0010313 0.5 25
0010314 1.60435 27
0010315 0.5 29
0010316 3.0 31
0010317 0.5 33
0010318 1.60435 35
0010319 0.5 37
0010320 1.60435 39
0010321 0.5 41
0010322 1.60435 43
0010323 0.5 45
0010324 1.60435 47
0010325 0.5 49
0010326 1.60435 51
0010327 0.5 53
0010328 1.60435 55
0010329 0.5 57
0010330 1.2553 59
0010331 1.1667 60
0010601 90.0 30
0010602 -90.0 60
0010801 0.0 0.0642 60
0011001 00000 60
0011101 000000 59
0011201 3 2250.0 547.0 0.0 0.0 0.0 60
0011300 1
0011301 9148.5 0.0 0.0 59
*
*
5000000 prmini tmdpjun
5000101 100000000 1000000 10.956
5000200 1
5000201 0.0 9148.5 0.0 0.0
5000202 1.0e6 9148.5 0.0 0.0
*
*
5010000 prmout tmdpjun
5010101 1010000 101000000 10.956
5010200 1
5010201 0.0 9148.5 0.0 0.0
5010202 1.0e6 9148.5 0.0 0.0
*
*
0020000 shell pipe
0020001 30
0020101 54.22 27
```

RELAP5 Input Deck reidp1**Large Break Case 1 - No flow restrictor, non-equilibrium**

4 of 10

0020102 70.0 30
0020201 54.22 2
0020202 23.716 3
0020203 54.22 6
0020204 23.716 7
0020205 54.22 10
0020206 23.716 11
0020207 54.22 14
0020208 23.716 15
0020209 54.22 18
0020210 23.716 19
0020211 54.22 22
0020212 23.716 23
0020213 54.22 26
0020214 23.716 27
0020215 70.0 29
0020301 1.2553 1
0020302 1.2553 2
0020303 0.5 4
0020304 1.60435 6
0020305 0.5 8
0020306 1.60435 10
0020307 0.5 12
0020308 1.60435 14
0020309 0.5 16
0020310 1.60435 18
0020311 0.5 20
0020312 1.60435 22
0020313 0.5 24
0020314 1.60435 26
0020315 0.5 28
0020316 3.2075 29
0020317 3.4338 30
0020601 90.0 30
0020801 0.00015 0.136 29
0020802 0.00015 0.0 30
0020901 0.0 0.0 2
0020902 0.78 0.78 3
0020903 0.0 0.0 6
0020904 0.78 0.78 7
0020905 0.0 0.0 10
0020906 0.78 0.78 11
0020907 0.0 0.0 14
0020908 0.78 0.78 15
0020909 0.0 0.0 18
0020910 0.78 0.78 19
0020911 0.0 0.0 22
0020912 0.78 0.78 23
0020913 0.0 0.0 26
0020914 0.78 0.78 27
0020915 0.0 0.0 29
0021001 00100 29

RELAP5 Input Deck reidp1

Large Break Case 1 - No flow restrictor, non-equilibrium

0021002 00000 30
0021101 000000 29
0021201 3 1033.73 547.0 0.0 0.0 0.0 1
0021202 3 1033.34 547.0 0.0 0.0 0.0 2
0021203 3 1033.07 547.0 0.0 0.0 0.0 3
0021204 3 1032.91 547.0 0.0 0.0 0.0 4
0021205 3 1032.57 547.0 0.0 0.0 0.0 5
0021206 3 1032.06 547.0 0.0 0.0 0.0 6
0021207 3 1031.72 547.0 0.0 0.0 0.0 7
0021208 3 1031.56 547.0 0.0 0.0 0.0 8
0021209 3 1031.22 547.0 0.0 0.0 0.0 9
0021210 3 1030.71 547.0 0.0 0.0 0.0 10
0021211 3 1030.37 547.0 0.0 0.0 0.0 11
0021212 3 1030.21 547.0 0.0 0.0 0.0 12
0021213 3 1029.87 547.0 0.0 0.0 0.0 13
0021214 3 1029.36 547.0 0.0 0.0 0.0 14
0021215 3 1029.02 547.0 0.0 0.0 0.0 15
0021216 3 1028.86 547.0 0.0 0.0 0.0 16
0021217 3 1028.53 547.0 0.0 0.0 0.0 17
0021218 3 1028.01 547.0 0.0 0.0 0.0 18
0021219 3 1027.68 547.0 0.0 0.0 0.0 19
0021220 3 1027.52 547.0 0.0 0.0 0.0 20
0021221 3 1027.18 547.0 0.0 0.0 0.0 21
0021222 3 1026.66 547.0 0.0 0.0 0.0 22
0021223 3 1026.33 547.0 0.0 0.0 0.0 23
0021224 3 1026.17 547.0 0.0 0.0 0.0 24
0021225 3 1025.83 547.0 0.0 0.0 0.0 25
0021226 3 1025.32 547.0 0.0 0.0 0.0 26
0021227 3 1024.98 547.0 0.0 0.0 0.0 27
0021228 3 1024.82 547.0 0.0 0.0 0.0 28
0021229 3 1024.23 547.0 0.0 0.0 0.0 29
0021230 3 1023.17 547.0 0.0 0.0 0.0 30
0021300 1
0021301 0.0 0.0 0.0 29
0021401 0.0625 0.0 1.0 1.0 29
*
*
0350000 downc pipe
0350001 3
0350101 0.0 3
0350201 7.096 2
0350301 11.827 3
0350401 122.4 3
0350601 -90.0 3
0350801 0.00015 0.4275 3
0351001 00000 3
0351101 000000 2
0351201 3 1024.84 547.0 0.0 0.0 0.0 1
0351202 3 1028.64 547.0 0.0 0.0 0.0 2
0351203 3 1032.44 547.0 0.0 0.0 0.0 3
0351300 1
0351301 0.0 0.0 0.0 2

RELAP5 Input Deck reidp1

Large Break Case 1 - No flow restrictor, non-equilibrium

```
*
*
0300000 tubesh branch
0300001 2 1
0300101 54.22 1.1667 0. 0. 90. 1.1667 0.00015 0.136 00100
0300200 3 1034.15 547.0
0301101 035010000 030000000 7.096 0.5 0.5 000000
0302101 030010000 002000000 4.43 5.32 5.32 000000
0301201 0.0 0.0 0.0
0302201 0.0 0.0 0.0
*
*
0340000 feedrg branch
0340001 1 1
0340101 92.1 3.1097 0.0 0. -90. -3.1097 0.00015 0.0 00000
0340200 3 1022.48 547.0
0341101 034010000 035000000 7.096 0.0 0.0 000100
0341201 0.0 0.0 0.0
*
*
0230000 abovetb snglvol
0230101 49.43 4.9423 0.0 0.0 90. 4.9423 0.00015 0.0 00000
0230200 2 1022.72 0.03
*
*
5330000 abovetb sngljun
5330101 002010000 023000000 49.43 0.0 0.0 000100
5330110 0.0 0.0 1.0 1.0
5330201 1 0.0 0.0 0.0
*
*
0220000 speratr separatr
0220001 3 1
0220101 41.73 3.9156 0.0 0. 90. 3.9156 0.00015 0.0 00000
0220200 2 1021.14 1.0
0221101 022010000 021000000 12.828 0.84 0.47 000000
0222101 022000000 032000000 17.35 0.597 0.597 000000
0223101 023010000 022000000 41.73 8.689 8.689 000000
0221201 0.0 0.0 0.0
0222201 0.0 0.0 0.0
0223201 0.0 0.0 0.0
*
*
0320000 liqsept snglvol
0320101 17.35 0.0 86.75 0.0 0. 0.0 0.00015 0.0 00000
0320200 2 1021.26 0.92
*
*
0330000 abovf1 branch
0330001 2 1
0330101 100.7 2.9225 0.0 0.0 -90.0 -2.9225 0.00015 0.0 00000
0330200 2 1021.72 0.73
```

RELAP5 Input Deck reidp1

Large Break Case 1 - No flow restrictor, non-equilibrium

```
0331101 032010000 033000000 17.35 0.0 0.0 000000
0332101 033010000 034000000 79.288 0.0 0.0 000000
0331201 0.0 0.0 0.0
0332201 0.0 0.0 0.0
*
*
0530000 abovfr2 branch
0530001 2 1
0530101 100.7 3.9156 0.0 0.0 -90.0 -3.9156 0.00015 0.0 00000
0530200 2 1021.72 0.73
0531101 036010000 053000000 2.34 0.5 0.5 000000
0532101 053010000 033000000 100.7 0.0 0.0 000000
0531201 0.0 0.0 0.0
0532201 0.0 0.0 0.0
*
*
0210000 abovspr branch
0210001 2 1
0210101 152.19 2.281 0.0 0.0 90. 2.281 0.00015 0.0 00000
0210200 2 1021.12 1.0
0211101 021010000 020000000 70.75 0.0 0.0 000100
0212101 021000000 053000000 7.96 1.78 1.67 000000
0211201 0.0 0.0 0.0
0212201 0.0 0.0 0.0
*
*
0200000 spsteam snglvol
0200101 70.75 7.4502 0.0 0.0 90. 7.4502 0.00015 0.0 00000
0200200 2 1020.96 1.0
*
*
0190000 dryer separatr
0190001 3 1
0190101 171.4 0.7083 0.0 0.0 0. 0.00015 0.0 00000
0190200 2 1020.96 1.0
0191101 019010000 018000000 63.49 5.502 5.502 000000
0192101 019000000 036000000 2.34 0.5 0.5 000000
0193101 020010000 019000000 70.75 0.5 0.5 000000
0191201 0.0 0.0 0.0
0192201 0.0 0.0 0.0
0193201 0.0 0.0 0.0
*
*
0360000 dsdryer snglvol
0360101 2.34 9.7312 0.0 0.0 -90. -9.7312 0.00015 0.0 00000
0360200 2 1021.57 0.82
*
*
0180000 updryer snglvol
0180101 63.49 0.0 473.0 0.0 0. 0.0 0.00015 0.0 00000
0180200 2 1020.96 1.0
*
```


RELAP5 Input Deck reidp1

Large Break Case 1 - No flow restrictor, non-equilibrium

```
*
*
0170000 sgdoom snglvol
0170101 94.12 3.5497 0.0 0.0 90. 3.5497 0.00015 0.0 00000
0170200 2 1020.94 1.0
*
*
0380000 contnm snglvol
0380101 10000.0 200.0 0.0 0.0 90. 200.0 0.0 0.0 00000
0380200 2 14.7 1.0
*
*
5190000 abovefr sngljun
5190101 018010000 017000000 63.49 0.0 0.0 000000
5190110 0.0 0.0 1.0 1.0
5190201 1 0.0 0.0 0.0
*
*
5180000 break valve
5180101 017010000 038000000 4.6 0.0 0.0 000100
5180110 0.0 0.0 1.0 1.0
5180201 1 0.0 0.0 0.0
5180300 mtrvlv
5180301 502 503 1000.0 0.0
*
*
* heat structure input
*
*****
11201000 60 11 2 1 0.0321
11201100 0 2
11201101 0.000438 10
11201201 1 10
11201301 0.0 10
11201401 547.0 11
11201501 001010000 0000 1 0 796.74 1
11201502 001020000 10000 1 0 857.24 3
11201503 001040000 10000 1 0 341.45 5
11201504 001060000 10000 1 0 1095.61 7
11201505 001080000 10000 1 0 341.45 9
11201506 001100000 10000 1 0 1095.61 11
11201507 001120000 10000 1 0 341.45 13
11201508 001140000 10000 1 0 1095.61 15
11201509 001160000 10000 1 0 341.45 17
11201510 001180000 10000 1 0 1095.61 19
11201511 001200000 10000 1 0 341.45 21
11201512 001220000 10000 1 0 1095.61 23
11201513 001240000 10000 1 0 341.45 25
11201514 001260000 10000 1 0 1095.61 27
11201515 001280000 10000 1 0 341.45 29
11201516 001300000 10000 1 0 2190.4 31
11201517 001320000 10000 1 0 341.45 33
```

RELAP5 Input Deck reidp1**Large Break Case 1 - No flow restrictor, non-equilibrium**

9 of 10

| | | | | | | |
|----------|-----------|--------|------|-----|-----------|----------------|
| 11201518 | 001340000 | 10000 | 1 | 0 | 1095.61 | 35 |
| 11201519 | 001360000 | 10000 | 1 | 0 | 341.45 | 37 |
| 11201520 | 001380000 | 10000 | 1 | 0 | 1095.61 | 39 |
| 11201521 | 001400000 | 10000 | 1 | 0 | 341.45 | 41 |
| 11201522 | 001420000 | 10000 | 1 | 0 | 1095.61 | 43 |
| 11201523 | 001440000 | 10000 | 1 | 0 | 341.45 | 45 |
| 11201524 | 001460000 | 10000 | 1 | 0 | 1095.61 | 47 |
| 11201525 | 001480000 | 10000 | 1 | 0 | 341.45 | 49 |
| 11201526 | 001500000 | 10000 | 1 | 0 | 1095.61 | 51 |
| 11201527 | 001520000 | 10000 | 1 | 0 | 341.45 | 53 |
| 11201528 | 001540000 | 10000 | 1 | 0 | 1095.61 | 55 |
| 11201529 | 001560000 | 10000 | 1 | 0 | 341.45 | 57 |
| 11201530 | 001580000 | 10000 | 1 | 0 | 857.24 | 59 |
| 11201531 | 001600000 | 0000 | 1 | 0 | 796.74 | 60 |
| 11201601 | 030010000 | 0000 | 1 | 0 | 905.4541 | 1 |
| 11201602 | 002010000 | 10000 | 1 | 0 | 974.2092 | 3 |
| 11201603 | 002030000 | 10000 | 1 | 0 | 388.0404 | 5 |
| 11201604 | 002050000 | 10000 | 1 | 0 | 1245.1044 | 7 |
| 11201605 | 002070000 | 10000 | 1 | 0 | 388.0404 | 9 |
| 11201606 | 002090000 | 10000 | 1 | 0 | 1245.1044 | 11 |
| 11201607 | 002110000 | 10000 | 1 | 0 | 388.0404 | 13 |
| 11201608 | 002130000 | 10000 | 1 | 0 | 1245.1044 | 15 |
| 11201609 | 002150000 | 10000 | 1 | 0 | 388.0404 | 17 |
| 11201610 | 002170000 | 10000 | 1 | 0 | 1245.1044 | 19 |
| 11201611 | 002190000 | 10000 | 1 | 0 | 388.0404 | 21 |
| 11201612 | 002210000 | 10000 | 1 | 0 | 1245.1044 | 23 |
| 11201613 | 002230000 | 10000 | 1 | 0 | 388.0404 | 25 |
| 11201614 | 002250000 | 10000 | 1 | 0 | 1245.1044 | 27 |
| 11201615 | 002270000 | 10000 | 1 | 0 | 388.0404 | 29 |
| 11201616 | 002290000 | 0000 | 1 | 0 | 2489.277 | 31 |
| 11201617 | 002280000 | -10000 | 1 | 0 | 388.0404 | 33 |
| 11201618 | 002260000 | -10000 | 1 | 0 | 1245.1044 | 35 |
| 11201619 | 002240000 | -10000 | 1 | 0 | 388.0404 | 37 |
| 11201620 | 002220000 | -10000 | 1 | 0 | 1245.1044 | 39 |
| 11201621 | 002200000 | -10000 | 1 | 0 | 388.0404 | 41 |
| 11201622 | 002180000 | -10000 | 1 | 0 | 1245.1044 | 43 |
| 11201623 | 002160000 | -10000 | 1 | 0 | 388.0404 | 45 |
| 11201624 | 002140000 | -10000 | 1 | 0 | 1245.1044 | 47 |
| 11201625 | 002120000 | -10000 | 1 | 0 | 388.0404 | 49 |
| 11201626 | 002100000 | -10000 | 1 | 0 | 1245.1044 | 51 |
| 11201627 | 002080000 | -10000 | 1 | 0 | 388.0404 | 53 |
| 11201628 | 002060000 | -10000 | 1 | 0 | 1245.1044 | 55 |
| 11201629 | 002040000 | -10000 | 1 | 0 | 388.0404 | 57 |
| 11201630 | 002020000 | -10000 | 1 | 0 | 974.2092 | 59 |
| 11201631 | 030010000 | 0000 | 1 | 0 | 905.4541 | 60 |
| 11201701 | 0 | 0.0 | 0.0 | 0.0 | 60 | |
| 11201801 | 0.0 | 15.0 | 15.0 | 1.5 | 1.5 | 0.0 0.0 1.0 60 |
| 11201901 | 0.0 | 15.0 | 15.0 | 1.5 | 1.5 | 0.0 0.0 1.0 60 |

*

*

* composition type and data format

*

RELAP5 Input Deck reidp1

Large Break Case 1 - No flow restrictor, non-equilibrium

| | | | | |
|----------|----------|------------|---|-----------|
| 20100100 | tbl/fctn | 1 | 1 | * inconel |
| 20100101 | 70.0 | 2.3843e-03 | | |
| 20100102 | 200.0 | 2.5232e-03 | | |
| 20100103 | 400.0 | 2.8009e-03 | | |
| 20100104 | 600.0 | 3.0787e-03 | | |
| 20100105 | 800.0 | 3.3565e-03 | | |
| 20100106 | 1000.0 | 3.6574e-03 | | |
| 20100107 | 1200.0 | 3.9815e-03 | | |
| 20100108 | 1400.0 | 4.3056e-03 | | |
| 20100151 | 70.0 | 55.6831 | | |
| 20100152 | 200.0 | 55.5227 | | |
| 20100153 | 400.0 | 55.2607 | | |
| 20100154 | 600.0 | 54.9895 | | |
| 20100155 | 800.0 | 54.7069 | | |
| 20100156 | 1000.0 | 54.3982 | | |
| 20100157 | 1200.0 | 54.0907 | | |
| 20100158 | 1400.0 | 53.7516 | | |

*

* control component cards

*

* compute pressure difference

*

| | | | | | |
|----------|---------|----------|------------|---------|-----------|
| 20500100 | delptp1 | sum | 1.45038e-4 | 0.0 | 1 |
| 20500101 | 0.0 | -1.0, p, | 002040000 | 1.0, p, | 002030000 |
| 20500200 | delptp2 | sum | 1.45038e-4 | 0.0 | 1 |
| 20500201 | 0.0 | -1.0, p, | 002080000 | 1.0, p, | 002070000 |
| 20500300 | delptp3 | sum | 1.45038e-4 | 0.0 | 1 |
| 20500301 | 0.0 | -1.0, p, | 002120000 | 1.0, p, | 002110000 |
| 20500400 | delptp4 | sum | 1.45038e-4 | 0.0 | 1 |
| 20500401 | 0.0 | -1.0, p, | 002160000 | 1.0, p, | 002150000 |
| 20500500 | delptp5 | sum | 1.45038e-4 | 0.0 | 1 |
| 20500501 | 0.0 | -1.0, p, | 002200000 | 1.0, p, | 002190000 |
| 20500600 | delptp6 | sum | 1.45038e-4 | 0.0 | 1 |
| 20500601 | 0.0 | -1.0, p, | 002240000 | 1.0, p, | 002230000 |
| 20500700 | delptp7 | sum | 1.45038e-4 | 0.0 | 1 |
| 20500701 | 0.0 | -1.0, p, | 002280000 | 1.0, p, | 002270000 |

*

* end of the input

*

RELAP5 Input Deck reidp2

Large Break Case 2 - No flow restrictor, equilibrium

=SLB pressure difference across the SG tube support plats

* hot standby nonequilibrium models

*

*

*

100 new transnt

*

*

102 british british

105

*

* time step cards

*

*

201 5. 1.d-7 0.005 3 2 200 10000

202 5.3 1.d-7 0.00001 3 1000 20000 100000

203 6.5 1.d-7 0.000025 3 400 8000 100000

204 8.0 1.d-7 0.00005 3 200 10000 100000

205 1000.0 1.d-7 0.00010 3 100 10000 100000

* minor edit variables

*

*

301 mflowj 518000000

302 mflowj 002030000

303 mflowj 002070000

304 mflowj 002110000

305 mflowj 002150000

306 mflowj 002190000

307 mflowj 002230000

308 mflowj 002270000

309 p 017010000

*310 p 018010000

*311 p 019010000

*312 p 020010000

*313 p 021010000

*314 p 022010000

*315 p 023010000

*316 p 033010000

*317 p 034010000

*318 p 036010000

319 cntrlvar 1

320 cntrlvar 2

321 cntrlvar 3

322 cntrlvar 4

323 cntrlvar 5

324 cntrlvar 6

325 cntrlvar 7

*

*

*

RELAP5 Input Deck reidp2
Large Break Case 2 - No flow restrictor, equilibrium

```
*
*
*
*****
*   trip input data
*
*
501  time 0 ge null 0 8.0 |
502  time 0 ge null 0 5.0 |
503  time 0 ge null 0 200.0 |
*
*
*
*
*
*
600  501
*
*****
*   hydrodynamic components
*
*****
*   primary side model
*   hot leg and cold leg represented by tdvs
*****
*
1000000 inplen tmdpvol
1000101 0.0 10.0 5000.0 0.0 0.0 0.0 0.0 0.0 0
1000200 3
1000201 0.0 2235.7 547.0
1000202 5.0 2250.0 547.0
1000203 15.0 800.0 491.0
*1000204 1.0e6 800.0 491.0
*
*
1010000 outplen tmdpvol
1010101 0.0 10.0 5000.0 0.0 0.0 0.0 0.0 0.0 0
1010200 3
1010201 0.0 2200.0 547.0
1010202 5.0 2200.0 547.0
1010203 15.0 700.0 491.0
*
*
0010000 tubes pipe
0010001 60
0010101 10.956 60
0010301 1.1667 1
0010302 1.2553 3
0010303 0.5 5
0010304 1.60435 7
0010305 0.5 9
0010306 1.60435 11
```

RELAP5 Input Deck reidp2

Large Break Case 2 - No flow restrictor, equilibrium

0010307 0.5 13
0010308 1.60435 15
0010309 0.5 17
0010310 1.60435 19
0010311 0.5 21
0010312 1.60435 23
0010313 0.5 25
0010314 1.60435 27
0010315 0.5 29
0010316 3.0 31
0010317 0.5 33
0010318 1.60435 35
0010319 0.5 37
0010320 1.60435 39
0010321 0.5 41
0010322 1.60435 43
0010323 0.5 45
0010324 1.60435 47
0010325 0.5 49
0010326 1.60435 51
0010327 0.5 53
0010328 1.60435 55
0010329 0.5 57
0010330 1.2553 59
0010331 1.1667 60
0010601 90.0 30
0010602 -90.0 60
0010801 0.0 0.0642 60
0011001 00000 60
0011101 000000 59
0011201 3 2250.0 547.0 0.0 0.0 0.0 60
0011300 1
0011301 9148.5 0.0 0.0 59
*
*
5000000 prmini tmdpjun
5000101 100000000 1000000 10.956
5000200 1
5000201 0.0 9148.5 0.0 0.0
5000202 1.0e6 9148.5 0.0 0.0
*
*
5010000 prmout tmdpjun
5010101 1010000 101000000 10.956
5010200 1
5010201 0.0 9148.5 0.0 0.0
5010202 1.0e6 9148.5 0.0 0.0
*
*
0020000 shell pipe
0020001 30
0020101 54.22 27

RELAP5 Input Deck reidp2**Large Break Case 2 - No flow restrictor, equilibrium**

4 of 10

| | | | | |
|---------|---------|-------|----|--|
| 0020102 | 70.0 | 30 | | |
| 0020201 | 54.22 | 2 | | |
| 0020202 | 23.716 | 3 | | |
| 0020203 | 54.22 | 6 | | |
| 0020204 | 23.716 | 7 | | |
| 0020205 | 54.22 | 10 | | |
| 0020206 | 23.716 | 11 | | |
| 0020207 | 54.22 | 14 | | |
| 0020208 | 23.716 | 15 | | |
| 0020209 | 54.22 | 18 | | |
| 0020210 | 23.716 | 19 | | |
| 0020211 | 54.22 | 22 | | |
| 0020212 | 23.716 | 23 | | |
| 0020213 | 54.22 | 26 | | |
| 0020214 | 23.716 | 27 | | |
| 0020215 | 70.0 | 29 | | |
| 0020301 | 1.2553 | 1 | | |
| 0020302 | 1.2553 | 2 | | |
| 0020303 | 0.5 | 4 | | |
| 0020304 | 1.60435 | 6 | | |
| 0020305 | 0.5 | 8 | | |
| 0020306 | 1.60435 | 10 | | |
| 0020307 | 0.5 | 12 | | |
| 0020308 | 1.60435 | 14 | | |
| 0020309 | 0.5 | 16 | | |
| 0020310 | 1.60435 | 18 | | |
| 0020311 | 0.5 | 20 | | |
| 0020312 | 1.60435 | 22 | | |
| 0020313 | 0.5 | 24 | | |
| 0020314 | 1.60435 | 26 | | |
| 0020315 | 0.5 | 28 | | |
| 0020316 | 3.2075 | 29 | | |
| 0020317 | 3.4338 | 30 | | |
| 0020601 | 90.0 | 30 | | |
| 0020801 | 0.00015 | 0.136 | 29 | |
| 0020802 | 0.00015 | 0.0 | 30 | |
| 0020901 | 0.0 | 0.0 | 2 | |
| 0020902 | 0.78 | 0.78 | 3 | |
| 0020903 | 0.0 | 0.0 | 6 | |
| 0020904 | 0.78 | 0.78 | 7 | |
| 0020905 | 0.0 | 0.0 | 10 | |
| 0020906 | 0.78 | 0.78 | 11 | |
| 0020907 | 0.0 | 0.0 | 14 | |
| 0020908 | 0.78 | 0.78 | 15 | |
| 0020909 | 0.0 | 0.0 | 18 | |
| 0020910 | 0.78 | 0.78 | 19 | |
| 0020911 | 0.0 | 0.0 | 22 | |
| 0020912 | 0.78 | 0.78 | 23 | |
| 0020913 | 0.0 | 0.0 | 26 | |
| 0020914 | 0.78 | 0.78 | 27 | |
| 0020915 | 0.0 | 0.0 | 29 | |
| 0021001 | 00101 | 29 | | |

RELAP5 Input Deck reidp2

Large Break Case 2 - No flow restrictor, equilibrium

0021002 00001 30
0021101 000000 29
0021201 3 1033.73 547.0 0.0 0.0 0.0 1
0021202 3 1033.34 547.0 0.0 0.0 0.0 2
0021203 3 1033.07 547.0 0.0 0.0 0.0 3
0021204 3 1032.91 547.0 0.0 0.0 0.0 4
0021205 3 1032.57 547.0 0.0 0.0 0.0 5
0021206 3 1032.06 547.0 0.0 0.0 0.0 6
0021207 3 1031.72 547.0 0.0 0.0 0.0 7
0021208 3 1031.56 547.0 0.0 0.0 0.0 8
0021209 3 1031.22 547.0 0.0 0.0 0.0 9
0021210 3 1030.71 547.0 0.0 0.0 0.0 10
0021211 3 1030.37 547.0 0.0 0.0 0.0 11
0021212 3 1030.21 547.0 0.0 0.0 0.0 12
0021213 3 1029.87 547.0 0.0 0.0 0.0 13
0021214 3 1029.36 547.0 0.0 0.0 0.0 14
0021215 3 1029.02 547.0 0.0 0.0 0.0 15
0021216 3 1028.86 547.0 0.0 0.0 0.0 16
0021217 3 1028.53 547.0 0.0 0.0 0.0 17
0021218 3 1028.01 547.0 0.0 0.0 0.0 18
0021219 3 1027.68 547.0 0.0 0.0 0.0 19
0021220 3 1027.52 547.0 0.0 0.0 0.0 20
0021221 3 1027.18 547.0 0.0 0.0 0.0 21
0021222 3 1026.66 547.0 0.0 0.0 0.0 22
0021223 3 1026.33 547.0 0.0 0.0 0.0 23
0021224 3 1026.17 547.0 0.0 0.0 0.0 24
0021225 3 1025.83 547.0 0.0 0.0 0.0 25
0021226 3 1025.32 547.0 0.0 0.0 0.0 26
0021227 3 1024.98 547.0 0.0 0.0 0.0 27
0021228 3 1024.82 547.0 0.0 0.0 0.0 28
0021229 3 1024.23 547.0 0.0 0.0 0.0 29
0021230 3 1023.17 547.0 0.0 0.0 0.0 30
0021300 1
0021301 0.0 0.0 0.0 29
0021401 0.0625 0.0 1.0 1.0 29

*

*

0350000 downc pipe
0350001 3
0350101 0.0 3
0350201 7.096 2
0350301 11.827 3
0350401 122.4 3
0350601 -90.0 3
0350801 0.00015 0.4275 3
0351001 00000 3
0351101 000000 2
0351201 3 1024.84 547.0 0.0 0.0 0.0 1
0351202 3 1028.64 547.0 0.0 0.0 0.0 2
0351203 3 1032.44 547.0 0.0 0.0 0.0 3
0351300 1
0351301 0.0 0.0 0.0 2

RELAP5 Input Deck reidp2

Large Break Case 2 - No flow restrictor, equilibrium

*

*

0300000 tubesh branch
0300001 2 1
0300101 54.22 1.1667 0. 0. 90. 1.1667 0.00015 0.136 00100
0300200 3 1034.15 547.0
0301101 035010000 030000000 7.096 0.5 0.5 000000
0302101 030010000 002000000 4.43 5.32 5.32 000000
0301201 0.0 0.0 0.0
0302201 0.0 0.0 0.0

*

*

0340000 feedrg branch
0340001 1 1
0340101 92.1 3.1097 0.0 0. -90. -3.1097 0.00015 0.0 00000
0340200 3 1022.48 547.0
0341101 034010000 035000000 7.096 0.0 0.0 000100
0341201 0.0 0.0 0.0

*

*

0230000 abovetb snglvol
0230101 49.43 4.9423 0.0 0.0 90. 4.9423 0.00015 0.0 00000
0230200 2 1022.72 0.03

*

*

5330000 abovetb sngljun
5330101 002010000 023000000 49.43 0.0 0.0 000100
5330110 0.0 0.0 1.0 1.0
5330201 1 0.0 0.0 0.0

*

*

0220000 speratr separatr
0220001 3 1
0220101 41.73 3.9156 0.0 0. 90. 3.9156 0.00015 0.0 00000
0220200 2 1021.14 1.0
0221101 022010000 021000000 12.828 0.84 0.47 000000
0222101 022000000 032000000 17.35 0.597 0.597 000000
0223101 023010000 022000000 41.73 8.689 8.689 000000
0221201 0.0 0.0 0.0
0222201 0.0 0.0 0.0
0223201 0.0 0.0 0.0

*

*

0320000 liqsept snglvol
0320101 17.35 0.0 86.75 0.0 0. 0.0 0.00015 0.0 00000
0320200 2 1021.26 0.92

*

*

0330000 abovf1 branch
0330001 2 1
0330101 100.7 2.9225 0.0 0.0 -90.0 -2.9225 0.00015 0.0 00000
0330200 2 1021.72 0.73

RELAP5 Input Deck reidp2

Large Break Case 2 - No flow restrictor, equilibrium

0331101 032010000 033000000 17.35 0.0 0.0 000000
0332101 033010000 034000000 79.288 0.0 0.0 000000
0331201 0.0 0.0 0.0
0332201 0.0 0.0 0.0
*
*
0530000 abovfr2 branch
0530001 2 1
0530101 100.7 3.9156 0.0 0.0 -90.0 -3.9156 0.00015 0.0 00000
0530200 2 1021.72 0.73
0531101 036010000 053000000 2.34 0.5 0.5 000000
0532101 053010000 033000000 100.7 0.0 0.0 000000
0531201 0.0 0.0 0.0
0532201 0.0 0.0 0.0
*
*
0210000 abovspr branch
0210001 2 1
0210101 152.19 2.281 0.0 0.0 90. 2.281 0.00015 0.0 00000
0210200 2 1021.12 1.0
0211101 021010000 020000000 70.75 0.0 0.0 000100
0212101 021000000 053000000 7.96 1.78 1.67 000000
0211201 0.0 0.0 0.0
0212201 0.0 0.0 0.0
*
*
0200000 spsteam snglvol
0200101 70.75 7.4502 0.0 0.0 90. 7.4502 0.00015 0.0 00000
0200200 2 1020.96 1.0
*
*
0190000 dryer separatr
0190001 3 1
0190101 171.4 0.7083 0.0 0.0 0. 0.00015 0.0 00000
0190200 2 1020.96 1.0
0191101 019010000 018000000 63.49 5.502 5.502 000000
0192101 019000000 036000000 2.34 0.5 0.5 000000
0193101 020010000 019000000 70.75 0.5 0.5 000000
0191201 0.0 0.0 0.0
0192201 0.0 0.0 0.0
0193201 0.0 0.0 0.0
*
*
0360000 dsdryer snglvol
0360101 2.34 9.7312 0.0 0.0 -90. -9.7312 0.00015 0.0 00000
0360200 2 1021.57 0.82
*
*
0180000 updryer snglvol
0180101 63.49 0.0 473.0 0.0 0. 0.0 0.00015 0.0 00000
0180200 2 1020.96 1.0
*

RELAP5 Input Deck reidp2

Large Break Case 2 - No flow restrictor, equilibrium

```
*
*
0170000 sgdoom snglvol
0170101 94.12 3.5497 0.0 0.0 90. 3.5497 0.00015 0.0 00000
0170200 2 1020.94 1.0
*
*
0380000 contnm snglvol
0380101 10000.0 200.0 0.0 0.0 90. 200.0 0.0 0.0 00000
0380200 2 14.7 1.0
*
*
5190000 abovefr sngljun
5190101 018010000 017000000 63.49 0.0 0.0 000000
5190110 0.0 0.0 1.0 1.0
5190201 1 0.0 0.0 0.0
*
*
5180000 break valve
5180101 017010000 038000000 4.6 0.0 0.0 000100
5180110 0.0 0.0 1.0 1.0
5180201 1 0.0 0.0 0.0
5180300 mtrvlv
5180301 502 503 1000.0 0.0
*
*
* heat structure input
*
*****
11201000 60 11 2 1 0.0321
11201100 0 2
11201101 0.000438 10
11201201 1 10
11201301 0.0 10
11201401 547.0 11
11201501 001010000 0000 1 0 796.74 1
11201502 001020000 10000 1 0 857.24 3
11201503 001040000 10000 1 0 341.45 5
11201504 001060000 10000 1 0 1095.61 7
11201505 001080000 10000 1 0 341.45 9
11201506 001100000 10000 1 0 1095.61 11
11201507 001120000 10000 1 0 341.45 13
11201508 001140000 10000 1 0 1095.61 15
11201509 001160000 10000 1 0 341.45 17
11201510 001180000 10000 1 0 1095.61 19
11201511 001200000 10000 1 0 341.45 21
11201512 001220000 10000 1 0 1095.61 23
11201513 001240000 10000 1 0 341.45 25
11201514 001260000 10000 1 0 1095.61 27
11201515 001280000 10000 1 0 341.45 29
11201516 001300000 10000 1 0 2190.4 31
11201517 001320000 10000 1 0 341.45 33
```

RELAP5 Input Deck reidp2

Large Break Case 2 - No flow restrictor, equilibrium

| | | | | | | |
|----------|-----------|--------|------|-----|-----------|----------------|
| 11201518 | 001340000 | 10000 | 1 | 0 | 1095.61 | 35 |
| 11201519 | 001360000 | 10000 | 1 | 0 | 341.45 | 37 |
| 11201520 | 001380000 | 10000 | 1 | 0 | 1095.61 | 39 |
| 11201521 | 001400000 | 10000 | 1 | 0 | 341.45 | 41 |
| 11201522 | 001420000 | 10000 | 1 | 0 | 1095.61 | 43 |
| 11201523 | 001440000 | 10000 | 1 | 0 | 341.45 | 45 |
| 11201524 | 001460000 | 10000 | 1 | 0 | 1095.61 | 47 |
| 11201525 | 001480000 | 10000 | 1 | 0 | 341.45 | 49 |
| 11201526 | 001500000 | 10000 | 1 | 0 | 1095.61 | 51 |
| 11201527 | 001520000 | 10000 | 1 | 0 | 341.45 | 53 |
| 11201528 | 001540000 | 10000 | 1 | 0 | 1095.61 | 55 |
| 11201529 | 001560000 | 10000 | 1 | 0 | 341.45 | 57 |
| 11201530 | 001580000 | 10000 | 1 | 0 | 857.24 | 59 |
| 11201531 | 001600000 | 0000 | 1 | 0 | 796.74 | 60 |
| 11201601 | 030010000 | 0000 | 1 | 0 | 905.4541 | 1 |
| 11201602 | 002010000 | 10000 | 1 | 0 | 974.2092 | 3 |
| 11201603 | 002030000 | 10000 | 1 | 0 | 388.0404 | 5 |
| 11201604 | 002050000 | 10000 | 1 | 0 | 1245.1044 | 7 |
| 11201605 | 002070000 | 10000 | 1 | 0 | 388.0404 | 9 |
| 11201606 | 002090000 | 10000 | 1 | 0 | 1245.1044 | 11 |
| 11201607 | 002110000 | 10000 | 1 | 0 | 388.0404 | 13 |
| 11201608 | 002130000 | 10000 | 1 | 0 | 1245.1044 | 15 |
| 11201609 | 002150000 | 10000 | 1 | 0 | 388.0404 | 17 |
| 11201610 | 002170000 | 10000 | 1 | 0 | 1245.1044 | 19 |
| 11201611 | 002190000 | 10000 | 1 | 0 | 388.0404 | 21 |
| 11201612 | 002210000 | 10000 | 1 | 0 | 1245.1044 | 23 |
| 11201613 | 002230000 | 10000 | 1 | 0 | 388.0404 | 25 |
| 11201614 | 002250000 | 10000 | 1 | 0 | 1245.1044 | 27 |
| 11201615 | 002270000 | 10000 | 1 | 0 | 388.0404 | 29 |
| 11201616 | 002290000 | 0000 | 1 | 0 | 2489.277 | 31 |
| 11201617 | 002280000 | -10000 | 1 | 0 | 388.0404 | 33 |
| 11201618 | 002260000 | -10000 | 1 | 0 | 1245.1044 | 35 |
| 11201619 | 002240000 | -10000 | 1 | 0 | 388.0404 | 37 |
| 11201620 | 002220000 | -10000 | 1 | 0 | 1245.1044 | 39 |
| 11201621 | 002200000 | -10000 | 1 | 0 | 388.0404 | 41 |
| 11201622 | 002180000 | -10000 | 1 | 0 | 1245.1044 | 43 |
| 11201623 | 002160000 | -10000 | 1 | 0 | 388.0404 | 45 |
| 11201624 | 002140000 | -10000 | 1 | 0 | 1245.1044 | 47 |
| 11201625 | 002120000 | -10000 | 1 | 0 | 388.0404 | 49 |
| 11201626 | 002100000 | -10000 | 1 | 0 | 1245.1044 | 51 |
| 11201627 | 002080000 | -10000 | 1 | 0 | 388.0404 | 53 |
| 11201628 | 002060000 | -10000 | 1 | 0 | 1245.1044 | 55 |
| 11201629 | 002040000 | -10000 | 1 | 0 | 388.0404 | 57 |
| 11201630 | 002020000 | -10000 | 1 | 0 | 974.2092 | 59 |
| 11201631 | 030010000 | 0000 | 1 | 0 | 905.4541 | 60 |
| 11201701 | 0 | 0.0 | 0.0 | 0.0 | 60 | |
| 11201801 | 0.0 | 15.0 | 15.0 | 1.5 | 1.5 | 0.0 0.0 1.0 60 |
| 11201901 | 0.0 | 15.0 | 15.0 | 1.5 | 1.5 | 0.0 0.0 1.0 60 |

*

*

* composition type and data format

*

RELAP5 Input Deck reidp2

Large Break Case 2 - No flow restrictor, equilibrium

20100100 tbl/fctn 1 1 * inconel
20100101 70.0 2.3843e-03
20100102 200.0 2.5232e-03
20100103 400.0 2.8009e-03
20100104 600.0 3.0787e-03
20100105 800.0 3.3565e-03
20100106 1000.0 3.6574e-03
20100107 1200.0 3.9815e-03
20100108 1400.0 4.3056e-03
20100151 70.0 55.6831
20100152 200.0 55.5227
20100153 400.0 55.2607
20100154 600.0 54.9895
20100155 800.0 54.7069
20100156 1000.0 54.3982
20100157 1200.0 54.0907
20100158 1400.0 53.7516

*
* control component cards
*
* compute pressure difference
*

20500100 delptp1 sum 1.45038e-4 0.0 1
20500101 0.0 -1.0, p, 002040000 1.0, p, 002030000
20500200 delptp2 sum 1.45038e-4 0.0 1
20500201 0.0 -1.0, p, 002080000 1.0, p, 002070000
20500300 delptp3 sum 1.45038e-4 0.0 1
20500301 0.0 -1.0, p, 002120000 1.0, p, 002110000
20500400 delptp4 sum 1.45038e-4 0.0 1
20500401 0.0 -1.0, p, 002160000 1.0, p, 002150000
20500500 delptp5 sum 1.45038e-4 0.0 1
20500501 0.0 -1.0, p, 002200000 1.0, p, 002190000
20500600 delptp6 sum 1.45038e-4 0.0 1
20500601 0.0 -1.0, p, 002240000 1.0, p, 002230000
20500700 delptp7 sum 1.45038e-4 0.0 1
20500701 0.0 -1.0, p, 002280000 1.0, p, 002270000

*
* end of the input
*

RELAP5 Input Deck reidp3

Small Break Case 1 - Flow restrictor, non-equilibrium

=SLB pressure difference across the SG tube support plats

* hot standby nonequilibrium models

*

*

*

100 new transnt

*

*

102 british british

105

*

* time step cards

*

*

201 5. 1.d-7 0.005 3 2 200 10000

202 5.3 1.d-7 0.00001 3 1000 20000 100000

203 6.5 1.d-7 0.000025 3 400 8000 100000

204 8.0 1.d-7 0.00005 3 200 10000 100000

205 1000.0 1.d-7 0.00010 3 100 10000 100000

* minor edit variables

*

*

301 mflowj 518000000

302 mflowj 002030000

303 mflowj 002070000

304 mflowj 002110000

305 mflowj 002150000

306 mflowj 002190000

307 mflowj 002230000

308 mflowj 002270000

309 p 017010000

*310 p 018010000

*311 p 019010000

*312 p 020010000

*313 p 021010000

*314 p 022010000

*315 p 023010000

*316 p 033010000

*317 p 034010000

*318 p 036010000

319 cntrlvar 1

320 cntrlvar 2

321 cntrlvar 3

322 cntrlvar 4

323 cntrlvar 5

324 cntrlvar 6

325 cntrlvar 7

*

*

*

RELAP5 Input Deck reidp3
Small Break Case 1 - Flow restrictor, non-equilibrium

```
*
*
*
*****
*   trip input data
*
*
501  time 0 ge null 0 8.0 |
502  time 0 ge null 0 5.0 |
503  time 0 ge null 0 200.0 |
*
*
*
*
*
*
600 501
*
*****
*   hydrodynamic components
*
*****
*   primary side model
*   hot leg and cold leg represented by tdvs
*****
*
1000000 inplen tmdpvol
1000101 0.0 10.0 5000.0 0.0 0.0 0.0 0.0 0.0 0
1000200 3
1000201 0.0 2235.7 547.0
1000202 5.0 2250.0 547.0
1000203 15.0 800.0 491.0
*1000204 1.0e6 800.0 491.0
*
*
1010000 outplen tmdpvol
1010101 0.0 10.0 5000.0 0.0 0.0 0.0 0.0 0.0 0
1010200 3
1010201 0.0 2200.0 547.0
1010202 5.0 2200.0 547.0
1010203 15.0 700.0 491.0
*
*
0010000 tubes pipe
0010001 60
0010101 10.956 60
0010301 1.1667 1
0010302 1.2553 3
0010303 0.5 5
0010304 1.60435 7
0010305 0.5 9
0010306 1.60435 11
```

RELAP5 Input Deck reidp3**Small Break Case 1 - Flow restrictor, non-equilibrium**

3 of 10

```
0010307 0.5 13
0010308 1.60435 15
0010309 0.5 17
0010310 1.60435 19
0010311 0.5 21
0010312 1.60435 23
0010313 0.5 25
0010314 1.60435 27
0010315 0.5 29
0010316 3.0 31
0010317 0.5 33
0010318 1.60435 35
0010319 0.5 37
0010320 1.60435 39
0010321 0.5 41
0010322 1.60435 43
0010323 0.5 45
0010324 1.60435 47
0010325 0.5 49
0010326 1.60435 51
0010327 0.5 53
0010328 1.60435 55
0010329 0.5 57
0010330 1.2553 59
0010331 1.1667 60
0010601 90.0 30
0010602 -90.0 60
0010801 0.0 0.0642 60
0011001 00000 60
0011101 000000 59
0011201 3 2250.0 547.0 0.0 0.0 0.0 60
0011300 1
0011301 9148.5 0.0 0.0 59
*
*
5000000 prminl tmdpjun
5000101 100000000 1000000 10.956
5000200 1
5000201 0.0 9148.5 0.0 0.0
5000202 1.0e6 9148.5 0.0 0.0
*
*
5010000 prmout tmdpjun
5010101 1010000 101000000 10.956
5010200 1
5010201 0.0 9148.5 0.0 0.0
5010202 1.0e6 9148.5 0.0 0.0
*
*
0020000 shell pipe
0020001 30
0020101 54.22 27
```


RELAP5 Input Deck reidp3**Small Break Case 1 - Flow restrictor, non-equilibrium**

4 of 10

| | | | | |
|---------|---------|-------|----|--|
| 0020102 | 70.0 | 30 | | |
| 0020201 | 54.22 | 2 | | |
| 0020202 | 23.716 | 3 | | |
| 0020203 | 54.22 | 6 | | |
| 0020204 | 23.716 | 7 | | |
| 0020205 | 54.22 | 10 | | |
| 0020206 | 23.716 | 11 | | |
| 0020207 | 54.22 | 14 | | |
| 0020208 | 23.716 | 15 | | |
| 0020209 | 54.22 | 18 | | |
| 0020210 | 23.716 | 19 | | |
| 0020211 | 54.22 | 22 | | |
| 0020212 | 23.716 | 23 | | |
| 0020213 | 54.22 | 26 | | |
| 0020214 | 23.716 | 27 | | |
| 0020215 | 70.0 | 29 | | |
| 0020301 | 1.2553 | 1 | | |
| 0020302 | 1.2553 | 2 | | |
| 0020303 | 0.5 | 4 | | |
| 0020304 | 1.60435 | 6 | | |
| 0020305 | 0.5 | 8 | | |
| 0020306 | 1.60435 | 10 | | |
| 0020307 | 0.5 | 12 | | |
| 0020308 | 1.60435 | 14 | | |
| 0020309 | 0.5 | 16 | | |
| 0020310 | 1.60435 | 18 | | |
| 0020311 | 0.5 | 20 | | |
| 0020312 | 1.60435 | 22 | | |
| 0020313 | 0.5 | 24 | | |
| 0020314 | 1.60435 | 26 | | |
| 0020315 | 0.5 | 28 | | |
| 0020316 | 3.2075 | 29 | | |
| 0020317 | 3.4338 | 30 | | |
| 0020601 | 90.0 | 30 | | |
| 0020801 | 0.00015 | 0.136 | 29 | |
| 0020802 | 0.00015 | 0.0 | 30 | |
| 0020901 | 0.0 | 0.0 | 2 | |
| 0020902 | 0.78 | 0.78 | 3 | |
| 0020903 | 0.0 | 0.0 | 6 | |
| 0020904 | 0.78 | 0.78 | 7 | |
| 0020905 | 0.0 | 0.0 | 10 | |
| 0020906 | 0.78 | 0.78 | 11 | |
| 0020907 | 0.0 | 0.0 | 14 | |
| 0020908 | 0.78 | 0.78 | 15 | |
| 0020909 | 0.0 | 0.0 | 18 | |
| 0020910 | 0.78 | 0.78 | 19 | |
| 0020911 | 0.0 | 0.0 | 22 | |
| 0020912 | 0.78 | 0.78 | 23 | |
| 0020913 | 0.0 | 0.0 | 26 | |
| 0020914 | 0.78 | 0.78 | 27 | |
| 0020915 | 0.0 | 0.0 | 29 | |
| 0021001 | 00100 | 29 | | |

RELAP5 Input Deck reidp3

Small Break Case 1 - Flow restrictor, non-equilibrium

0021002 00000 30
0021101 000000 29
0021201 3 1033.73 547.0 0.0 0.0 0.0 1
0021202 3 1033.34 547.0 0.0 0.0 0.0 2
0021203 3 1033.07 547.0 0.0 0.0 0.0 3
0021204 3 1032.91 547.0 0.0 0.0 0.0 4
0021205 3 1032.57 547.0 0.0 0.0 0.0 5
0021206 3 1032.06 547.0 0.0 0.0 0.0 6
0021207 3 1031.72 547.0 0.0 0.0 0.0 7
0021208 3 1031.56 547.0 0.0 0.0 0.0 8
0021209 3 1031.22 547.0 0.0 0.0 0.0 9
0021210 3 1030.71 547.0 0.0 0.0 0.0 10
0021211 3 1030.37 547.0 0.0 0.0 0.0 11
0021212 3 1030.21 547.0 0.0 0.0 0.0 12
0021213 3 1029.87 547.0 0.0 0.0 0.0 13
0021214 3 1029.36 547.0 0.0 0.0 0.0 14
0021215 3 1029.02 547.0 0.0 0.0 0.0 15
0021216 3 1028.86 547.0 0.0 0.0 0.0 16
0021217 3 1028.53 547.0 0.0 0.0 0.0 17
0021218 3 1028.01 547.0 0.0 0.0 0.0 18
0021219 3 1027.68 547.0 0.0 0.0 0.0 19
0021220 3 1027.52 547.0 0.0 0.0 0.0 20
0021221 3 1027.18 547.0 0.0 0.0 0.0 21
0021222 3 1026.66 547.0 0.0 0.0 0.0 22
0021223 3 1026.33 547.0 0.0 0.0 0.0 23
0021224 3 1026.17 547.0 0.0 0.0 0.0 24
0021225 3 1025.83 547.0 0.0 0.0 0.0 25
0021226 3 1025.32 547.0 0.0 0.0 0.0 26
0021227 3 1024.98 547.0 0.0 0.0 0.0 27
0021228 3 1024.82 547.0 0.0 0.0 0.0 28
0021229 3 1024.23 547.0 0.0 0.0 0.0 29
0021230 3 1023.17 547.0 0.0 0.0 0.0 30
0021300 1
0021301 0.0 0.0 0.0 29
0021401 0.0625 0.0 1.0 1.0 29
*
*
0350000 downc pipe
0350001 3
0350101 0.0 3
0350201 7.096 2
0350301 11.827 3
0350401 122.4 3
0350601 -90.0 3
0350801 0.00015 0.4275 3
0351001 00000 3
0351101 000000 2
0351201 3 1024.84 547.0 0.0 0.0 0.0 1
0351202 3 1028.64 547.0 0.0 0.0 0.0 2
0351203 3 1032.44 547.0 0.0 0.0 0.0 3
0351300 1
0351301 0.0 0.0 0.0 2

RELAP5 Input Deck reidp3

Small Break Case 1 - Flow restrictor, non-equilibrium

*

*

0300000 tubesh branch
0300001 2 1
0300101 54.22 1.1667 0. 0. 90. 1.1667 0.00015 0.136 00100
0300200 3 1034.15 547.0
0301101 035010000 030000000 7.096 0.5 0.5 000000
0302101 030010000 002000000 4.43 5.32 5.32 000000
0301201 0.0 0.0 0.0
0302201 0.0 0.0 0.0

*

*

0340000 feedrg branch
0340001 1 1
0340101 92.1 3.1097 0.0 0. -90. -3.1097 0.00015 0.0 00000
0340200 3 1022.48 547.0
0341101 034010000 035000000 7.096 0.0 0.0 000100
0341201 0.0 0.0 0.0

*

*

0230000 abovetb snglvol
0230101 49.43 4.9423 0.0 0.0 90. 4.9423 0.00015 0.0 00000
0230200 2 1022.72 0.03

*

*

5330000 abovetb sngljun
5330101 002010000 023000000 49.43 0.0 0.0 000100
5330110 0.0 0.0 1.0 1.0
5330201 1 0.0 0.0 0.0

*

*

0220000 speratr separatr
0220001 3 1
0220101 41.73 3.9156 0.0 0. 90. 3.9156 0.00015 0.0 00000
0220200 2 1021.14 1.0
0221101 022010000 021000000 12.828 0.84 0.47 000000
0222101 022000000 032000000 17.35 0.597 0.597 000000
0223101 023010000 022000000 41.73 8.689 8.689 000000
0221201 0.0 0.0 0.0
0222201 0.0 0.0 0.0
0223201 0.0 0.0 0.0

*

*

0320000 liqsept snglvol
0320101 17.35 0.0 86.75 0.0 0. 0.0 0.00015 0.0 00000
0320200 2 1021.26 0.92

*

*

0330000 abovf1 branch
0330001 2 1
0330101 100.7 2.9225 0.0 0.0 -90.0 -2.9225 0.00015 0.0 00000
0330200 2 1021.72 0.73

RELAP5 Input Deck reidp3**Small Break Case 1 - Flow restrictor, non-equilibrium**

7 of 10

```
0331101 032010000 033000000 17.35 0.0 0.0 000000
0332101 033010000 034000000 79.288 0.0 0.0 000000
0331201 0.0 0.0 0.0
0332201 0.0 0.0 0.0
*
*
0530000 abovfr2 branch
0530001 2 1
0530101 100.7 3.9156 0.0 0.0 -90.0 -3.9156 0.00015 0.0 00000
0530200 2 1021.72 0.73
0531101 036010000 053000000 2.34 0.5 0.5 000000
0532101 053010000 033000000 100.7 0.0 0.0 000000
0531201 0.0 0.0 0.0
0532201 0.0 0.0 0.0
*
*
0210000 abovspr branch
0210001 2 1
0210101 152.19 2.281 0.0 0.0 90. 2.281 0.00015 0.0 00000
0210200 2 1021.12 1.0
0211101 021010000 020000000 70.75 0.0 0.0 000100
0212101 021000000 053000000 7.96 1.78 1.67 000000
0211201 0.0 0.0 0.0
0212201 0.0 0.0 0.0
*
*
0200000 spsteam snglvol
0200101 70.75 7.4502 0.0 0.0 90. 7.4502 0.00015 0.0 00000
0200200 2 1020.96 1.0
*
*
0190000 dryer separatr
0190001 3 1
0190101 171.4 0.7083 0.0 0.0 0. 0. 0.00015 0.0 00000
0190200 2 1020.96 1.0
0191101 019010000 018000000 63.49 5.502 5.502 000000
0192101 019000000 036000000 2.34 0.5 0.5 000000
0193101 020010000 019000000 70.75 0.5 0.5 000000
0191201 0.0 0.0 0.0
0192201 0.0 0.0 0.0
0193201 0.0 0.0 0.0
*
*
0360000 dsdryer snglvol
0360101 2.34 9.7312 0.0 0.0 -90. -9.7312 0.00015 0.0 00000
0360200 2 1021.57 0.82
*
*
0180000 updryer snglvol
0180101 63.49 0.0 473.0 0.0 0. 0.0 0.00015 0.0 00000
0180200 2 1020.96 1.0
*
```

RELAP5 Input Deck reidp3

Small Break Case 1 - Flow restrictor, non-equilibrium

```
*
*
0170000 sgdoom snglvol
0170101 94.12 3.5497 0.0 0.0 90. 3.5497 0.00015 0.0 00000
0170200 2 1020.94 1.0
*
*
0380000 contnm snglvol
0380101 10000.0 200.0 0.0 0.0 90. 200.0 0.0 0.0 00000
0380200 2 14.7 1.0
*
*
5190000 abovefr sngljun
5190101 018010000 017000000 63.49 0.0 0.0 000000
5190110 0.0 0.0 1.0 1.0
5190201 1 0.0 0.0 0.0
*
*
5180000 break valve
5180101 017010000 038000000 1.388 0.0 0.0 000100
5180110 0.0 0.0 1.0 1.0
5180201 1 0.0 0.0 0.0
5180300 mtrvlv
5180301 502 503 1000.0 0.0
*
*
* heat structure input
*
*****
11201000 60 11 2 1 0.0321
11201100 0 2
11201101 0.000438 10
11201201 1 10
11201301 0.0 10
11201401 547.0 11
11201501 001010000 0000 1 0 796.74 1
11201502 001020000 10000 1 0 857.24 3
11201503 001040000 10000 1 0 341.45 5
11201504 001060000 10000 1 0 1095.61 7
11201505 001080000 10000 1 0 341.45 9
11201506 001100000 10000 1 0 1095.61 11
11201507 001120000 10000 1 0 341.45 13
11201508 001140000 10000 1 0 1095.61 15
11201509 001160000 10000 1 0 341.45 17
11201510 001180000 10000 1 0 1095.61 19
11201511 001200000 10000 1 0 341.45 21
11201512 001220000 10000 1 0 1095.61 23
11201513 001240000 10000 1 0 341.45 25
11201514 001260000 10000 1 0 1095.61 27
11201515 001280000 10000 1 0 341.45 29
11201516 001300000 10000 1 0 2190.4 31
11201517 001320000 10000 1 0 341.45 33
```

RELAP5 Input Deck reidp3**Small Break Case 1 - Flow restrictor, non-equilibrium**

9 of 10

| | | | | | | |
|----------|-----------|--------|------|-----|-----------|----------------|
| 11201518 | 001340000 | 10000 | 1 | 0 | 1095.61 | 35 |
| 11201519 | 001360000 | 10000 | 1 | 0 | 341.45 | 37 |
| 11201520 | 001380000 | 10000 | 1 | 0 | 1095.61 | 39 |
| 11201521 | 001400000 | 10000 | 1 | 0 | 341.45 | 41 |
| 11201522 | 001420000 | 10000 | 1 | 0 | 1095.61 | 43 |
| 11201523 | 001440000 | 10000 | 1 | 0 | 341.45 | 45 |
| 11201524 | 001460000 | 10000 | 1 | 0 | 1095.61 | 47 |
| 11201525 | 001480000 | 10000 | 1 | 0 | 341.45 | 49 |
| 11201526 | 001500000 | 10000 | 1 | 0 | 1095.61 | 51 |
| 11201527 | 001520000 | 10000 | 1 | 0 | 341.45 | 53 |
| 11201528 | 001540000 | 10000 | 1 | 0 | 1095.61 | 55 |
| 11201529 | 001560000 | 10000 | 1 | 0 | 341.45 | 57 |
| 11201530 | 001580000 | 10000 | 1 | 0 | 857.24 | 59 |
| 11201531 | 001600000 | 0000 | 1 | 0 | 796.74 | 60 |
| 11201601 | 030010000 | 0000 | 1 | 0 | 905.4541 | 1 |
| 11201602 | 002010000 | 10000 | 1 | 0 | 974.2092 | 3 |
| 11201603 | 002030000 | 10000 | 1 | 0 | 388.0404 | 5 |
| 11201604 | 002050000 | 10000 | 1 | 0 | 1245.1044 | 7 |
| 11201605 | 002070000 | 10000 | 1 | 0 | 388.0404 | 9 |
| 11201606 | 002090000 | 10000 | 1 | 0 | 1245.1044 | 11 |
| 11201607 | 002110000 | 10000 | 1 | 0 | 388.0404 | 13 |
| 11201608 | 002130000 | 10000 | 1 | 0 | 1245.1044 | 15 |
| 11201609 | 002150000 | 10000 | 1 | 0 | 388.0404 | 17 |
| 11201610 | 002170000 | 10000 | 1 | 0 | 1245.1044 | 19 |
| 11201611 | 002190000 | 10000 | 1 | 0 | 388.0404 | 21 |
| 11201612 | 002210000 | 10000 | 1 | 0 | 1245.1044 | 23 |
| 11201613 | 002230000 | 10000 | 1 | 0 | 388.0404 | 25 |
| 11201614 | 002250000 | 10000 | 1 | 0 | 1245.1044 | 27 |
| 11201615 | 002270000 | 10000 | 1 | 0 | 388.0404 | 29 |
| 11201616 | 002290000 | 0000 | 1 | 0 | 2489.277 | 31 |
| 11201617 | 002280000 | -10000 | 1 | 0 | 388.0404 | 33 |
| 11201618 | 002260000 | -10000 | 1 | 0 | 1245.1044 | 35 |
| 11201619 | 002240000 | -10000 | 1 | 0 | 388.0404 | 37 |
| 11201620 | 002220000 | -10000 | 1 | 0 | 1245.1044 | 39 |
| 11201621 | 002200000 | -10000 | 1 | 0 | 388.0404 | 41 |
| 11201622 | 002180000 | -10000 | 1 | 0 | 1245.1044 | 43 |
| 11201623 | 002160000 | -10000 | 1 | 0 | 388.0404 | 45 |
| 11201624 | 002140000 | -10000 | 1 | 0 | 1245.1044 | 47 |
| 11201625 | 002120000 | -10000 | 1 | 0 | 388.0404 | 49 |
| 11201626 | 002100000 | -10000 | 1 | 0 | 1245.1044 | 51 |
| 11201627 | 002080000 | -10000 | 1 | 0 | 388.0404 | 53 |
| 11201628 | 002060000 | -10000 | 1 | 0 | 1245.1044 | 55 |
| 11201629 | 002040000 | -10000 | 1 | 0 | 388.0404 | 57 |
| 11201630 | 002020000 | -10000 | 1 | 0 | 974.2092 | 59 |
| 11201631 | 030010000 | 0000 | 1 | 0 | 905.4541 | 60 |
| 11201701 | 0 | 0.0 | 0.0 | 0.0 | 60 | |
| 11201801 | 0.0 | 15.0 | 15.0 | 1.5 | 1.5 | 0.0 0.0 1.0 60 |
| 11201901 | 0.0 | 15.0 | 15.0 | 1.5 | 1.5 | 0.0 0.0 1.0 60 |

*

*

* composition type and data format

*

RELAP5 Input Deck reidp3
Small Break Case 1 - Flow restrictor, non-equilibrium

| | | | | |
|----------|----------|------------|---|-----------|
| 20100100 | tbl/fctn | 1 | 1 | * inconel |
| 20100101 | 70.0 | 2.3843e-03 | | |
| 20100102 | 200.0 | 2.5232e-03 | | |
| 20100103 | 400.0 | 2.8009e-03 | | |
| 20100104 | 600.0 | 3.0787e-03 | | |
| 20100105 | 800.0 | 3.3565e-03 | | |
| 20100106 | 1000.0 | 3.6574e-03 | | |
| 20100107 | 1200.0 | 3.9815e-03 | | |
| 20100108 | 1400.0 | 4.3056e-03 | | |
| 20100151 | 70.0 | 55.6831 | | |
| 20100152 | 200.0 | 55.5227 | | |
| 20100153 | 400.0 | 55.2607 | | |
| 20100154 | 600.0 | 54.9895 | | |
| 20100155 | 800.0 | 54.7069 | | |
| 20100156 | 1000.0 | 54.3982 | | |
| 20100157 | 1200.0 | 54.0907 | | |
| 20100158 | 1400.0 | 53.7516 | | |

*
* control component cards
*
* compute pressure difference
*

| | | | | | |
|----------|---------|----------|------------|---------|-----------|
| 20500100 | delptp1 | sum | 1.45038e-4 | 0.0 | 1 |
| 20500101 | 0.0 | -1.0, p, | 002040000 | 1.0, p, | 002030000 |
| 20500200 | delptp2 | sum | 1.45038e-4 | 0.0 | 1 |
| 20500201 | 0.0 | -1.0, p, | 002080000 | 1.0, p, | 002070000 |
| 20500300 | delptp3 | sum | 1.45038e-4 | 0.0 | 1 |
| 20500301 | 0.0 | -1.0, p, | 002120000 | 1.0, p, | 002110000 |
| 20500400 | delptp4 | sum | 1.45038e-4 | 0.0 | 1 |
| 20500401 | 0.0 | -1.0, p, | 002160000 | 1.0, p, | 002150000 |
| 20500500 | delptp5 | sum | 1.45038e-4 | 0.0 | 1 |
| 20500501 | 0.0 | -1.0, p, | 002200000 | 1.0, p, | 002190000 |
| 20500600 | delptp6 | sum | 1.45038e-4 | 0.0 | 1 |
| 20500601 | 0.0 | -1.0, p, | 002240000 | 1.0, p, | 002230000 |
| 20500700 | delptp7 | sum | 1.45038e-4 | 0.0 | 1 |
| 20500701 | 0.0 | -1.0, p, | 002280000 | 1.0, p, | 002270000 |

*
* end of the input
*

RELAP5 Input Deck reidp4

Small Break Case 2 - Flow restrictor, equilibrium

=SLB pressure difference across the SG tube support plats

* hot standby nonequilibrium models

*

*

*

100 new transnt

*

*

102 british british

105

*

* time step cards

*

*

201 5. 1.d-7 0.005 3 2 200 10000

202 5.3 1.d-7 0.00001 3 1000 20000 100000

203 6.5 1.d-7 0.000025 3 400 8000 100000

204 8.0 1.d-7 0.00005 3 200 10000 100000

205 1000.0 1.d-7 0.00010 3 100 10000 100000

* minor edit variables

*

*

301 mflowj 518000000

302 mflowj 002030000

303 mflowj 002070000

304 mflowj 002110000

305 mflowj 002150000

306 mflowj 002190000

307 mflowj 002230000

308 mflowj 002270000

309 p 017010000

*310 p 018010000

*311 p 019010000

*312 p 020010000

*313 p 021010000

*314 p 022010000

*315 p 023010000

*316 p 033010000

*317 p 034010000

*318 p 036010000

319 cntrlvar 1

320 cntrlvar 2

321 cntrlvar 3

322 cntrlvar 4

323 cntrlvar 5

324 cntrlvar 6

325 cntrlvar 7

*

*

*

RELAP5 Input Deck reidp4
Small Break Case 2 - Flow restrictor, equilibrium

```
*
*
*
*****
*   trip input data
*
*
501  time 0 ge null 0 8.0 |
502  time 0 ge null 0 5.0 |
503  time 0 ge null 0 200.0 |
*
*
*
*
*
*
600  501
*
*****
*   hydrodynamic components
*
*****
*   primary side model
*   hot leg and cold leg represented by tdvs
*****
*
1000000 inplen tmdpvol
1000101 0.0 10.0 5000.0 0.0 0.0 0.0 0.0 0.0 0
1000200 3
1000201 0.0 2235.7 547.0
1000202 5.0 2250.0 547.0
1000203 15.0 800.0 491.0
*1000204 1.0e6 800.0 491.0
*
*
1010000 outplen tmdpvol
1010101 0.0 10.0 5000.0 0.0 0.0 0.0 0.0 0.0 0
1010200 3
1010201 0.0 2200.0 547.0
1010202 5.0 2200.0 547.0
1010203 15.0 700.0 491.0
*
*
0010000 tubes pipe
0010001 60
0010101 10.956 60
0010301 1.1667 1
0010302 1.2553 3
0010303 0.5 5
0010304 1.60435 7
0010305 0.5 9
0010306 1.60435 11
```

RELAP5 Input Deck reidp4

Small Break Case 2 - Flow restrictor, equilibrium

0010307 0.5 13
0010308 1.60435 15
0010309 0.5 17
0010310 1.60435 19
0010311 0.5 21
0010312 1.60435 23
0010313 0.5 25
0010314 1.60435 27
0010315 0.5 29
0010316 3.0 31
0010317 0.5 33
0010318 1.60435 35
0010319 0.5 37
0010320 1.60435 39
0010321 0.5 41
0010322 1.60435 43
0010323 0.5 45
0010324 1.60435 47
0010325 0.5 49
0010326 1.60435 51
0010327 0.5 53
0010328 1.60435 55
0010329 0.5 57
0010330 1.2553 59
0010331 1.1667 60
0010601 90.0 30
0010602 -90.0 60
0010801 0.0 0.0642 60
0011001 00000 60
0011101 000000 59
0011201 3 2250.0 547.0 0.0 0.0 0.0 60
0011300 1
0011301 9148.5 0.0 0.0 59
*
*
5000000 prmini tmdpjun
5000101 100000000 1000000 10.956
5000200 1
5000201 0.0 9148.5 0.0 0.0
5000202 1.0e6 9148.5 0.0 0.0
*
*
5010000 prmout tmdpjun
5010101 1010000 101000000 10.956
5010200 1
5010201 0.0 9148.5 0.0 0.0
5010202 1.0e6 9148.5 0.0 0.0
*
*
0020000 shell pipe
0020001 30
0020101 54.22 27

RELAP5 Input Deck reidp4**Small Break Case 2 - Flow restrictor, equilibrium**

4 of 10

0020102 70.0 30
0020201 54.22 2
0020202 23.716 3
0020203 54.22 6
0020204 23.716 7
0020205 54.22 10
0020206 23.716 11
0020207 54.22 14
0020208 23.716 15
0020209 54.22 18
0020210 23.716 19
0020211 54.22 22
0020212 23.716 23
0020213 54.22 26
0020214 23.716 27
0020215 70.0 29
0020301 1.2553 1
0020302 1.2553 2
0020303 0.5 4
0020304 1.60435 6
0020305 0.5 8
0020306 1.60435 10
0020307 0.5 12
0020308 1.60435 14
0020309 0.5 16
0020310 1.60435 18
0020311 0.5 20
0020312 1.60435 22
0020313 0.5 24
0020314 1.60435 26
0020315 0.5 28
0020316 3.2075 29
0020317 3.4338 30
0020601 90.0 30
0020801 0.00015 0.136 29
0020802 0.00015 0.0 30
0020901 0.0 0.0 2
0020902 0.78 0.78 3
0020903 0.0 0.0 6
0020904 0.78 0.78 7
0020905 0.0 0.0 10
0020906 0.78 0.78 11
0020907 0.0 0.0 14
0020908 0.78 0.78 15
0020909 0.0 0.0 18
0020910 0.78 0.78 19
0020911 0.0 0.0 22
0020912 0.78 0.78 23
0020913 0.0 0.0 26
0020914 0.78 0.78 27
0020915 0.0 0.0 29
0021001 00101 29

RELAP5 Input Deck reidp4

Small Break Case 2 - Flow restrictor, equilibrium

0021002 00001 30
0021101 000000 29
0021201 3 1033.73 547.0 0.0 0.0 0.0 1
0021202 3 1033.34 547.0 0.0 0.0 0.0 2
0021203 3 1033.07 547.0 0.0 0.0 0.0 3
0021204 3 1032.91 547.0 0.0 0.0 0.0 4
0021205 3 1032.57 547.0 0.0 0.0 0.0 5
0021206 3 1032.06 547.0 0.0 0.0 0.0 6
0021207 3 1031.72 547.0 0.0 0.0 0.0 7
0021208 3 1031.56 547.0 0.0 0.0 0.0 8
0021209 3 1031.22 547.0 0.0 0.0 0.0 9
0021210 3 1030.71 547.0 0.0 0.0 0.0 10
0021211 3 1030.37 547.0 0.0 0.0 0.0 11
0021212 3 1030.21 547.0 0.0 0.0 0.0 12
0021213 3 1029.87 547.0 0.0 0.0 0.0 13
0021214 3 1029.36 547.0 0.0 0.0 0.0 14
0021215 3 1029.02 547.0 0.0 0.0 0.0 15
0021216 3 1028.86 547.0 0.0 0.0 0.0 16
0021217 3 1028.53 547.0 0.0 0.0 0.0 17
0021218 3 1028.01 547.0 0.0 0.0 0.0 18
0021219 3 1027.68 547.0 0.0 0.0 0.0 19
0021220 3 1027.52 547.0 0.0 0.0 0.0 20
0021221 3 1027.18 547.0 0.0 0.0 0.0 21
0021222 3 1026.66 547.0 0.0 0.0 0.0 22
0021223 3 1026.33 547.0 0.0 0.0 0.0 23
0021224 3 1026.17 547.0 0.0 0.0 0.0 24
0021225 3 1025.83 547.0 0.0 0.0 0.0 25
0021226 3 1025.32 547.0 0.0 0.0 0.0 26
0021227 3 1024.98 547.0 0.0 0.0 0.0 27
0021228 3 1024.82 547.0 0.0 0.0 0.0 28
0021229 3 1024.23 547.0 0.0 0.0 0.0 29
0021230 3 1023.17 547.0 0.0 0.0 0.0 30
0021300 1
0021301 0.0 0.0 0.0 29
0021401 0.0625 0.0 1.0 1.0 29
*
*
0350000 downc pipe
0350001 3
0350101 0.0 3
0350201 7.096 2
0350301 11.827 3
0350401 122.4 3
0350601 -90.0 3
0350801 0.00015 0.4275 3
0351001 00000 3
0351101 000000 2
0351201 3 1024.84 547.0 0.0 0.0 0.0 1
0351202 3 1028.64 547.0 0.0 0.0 0.0 2
0351203 3 1032.44 547.0 0.0 0.0 0.0 3
0351300 1
0351301 0.0 0.0 0.0 2

RELAP5 Input Deck reidp4
Small Break Case 2 - Flow restrictor, equilibrium

```
*
*
0300000 tubesh branch
0300001 2 1
0300101 54.22 1.1667 0. 0. 90. 1.1667 0.00015 0.136 00100
0300200 3 1034.15 547.0
0301101 035010000 030000000 7.096 0.5 0.5 000000
0302101 030010000 002000000 4.43 5.32 5.32 000000
0301201 0.0 0.0 0.0
0302201 0.0 0.0 0.0
*
*
0340000 feedrg branch
0340001 1 1
0340101 92.1 3.1097 0.0 0. -90. -3.1097 0.00015 0.0 00000
0340200 3 1022.48 547.0
0341101 034010000 035000000 7.096 0.0 0.0 000100
0341201 0.0 0.0 0.0
*
*
0230000 abovetb snglvol
0230101 49.43 4.9423 0.0 0.0 90. 4.9423 0.00015 0.0 00000
0230200 2 1022.72 0.03
*
*
5330000 abovetb sngljun
5330101 002010000 023000000 49.43 0.0 0.0 000100
5330110 0.0 0.0 1.0 1.0
5330201 1 0.0 0.0 0.0
*
*
0220000 speratr separatr
0220001 3 1
0220101 41.73 3.9156 0.0 0. 90. 3.9156 0.00015 0.0 00000
0220200 2 1021.14 1.0
0221101 022010000 021000000 12.828 0.84 0.47 000000
0222101 022000000 032000000 17.35 0.597 0.597 000000
0223101 023010000 022000000 41.73 8.689 8.689 000000
0221201 0.0 0.0 0.0
0222201 0.0 0.0 0.0
0223201 0.0 0.0 0.0
*
*
0320000 liqsept snglvol
0320101 17.35 0.0 86.75 0.0 0. 0.0 0.00015 0.0 00000
0320200 2 1021.26 0.92
*
*
0330000 abovf1 branch
0330001 2 1
0330101 100.7 2.9225 0.0 0.0 -90.0 -2.9225 0.00015 0.0 00000
0330200 2 1021.72 0.73
```

RELAP5 Input Deck reidp4

Small Break Case 2 - Flow restrictor, equilibrium

0331101 032010000 033000000 17.35 0.0 0.0 000000
0332101 033010000 034000000 79.288 0.0 0.0 000000
0331201 0.0 0.0 0.0
0332201 0.0 0.0 0.0
*
*
0530000 abovfr2 branch
0530001 2 1
0530101 100.7 3.9156 0.0 0.0 -90.0 -3.9156 0.00015 0.0 00000
0530200 2 1021.72 0.73
0531101 036010000 053000000 2.34 0.5 0.5 000000
0532101 053010000 033000000 100.7 0.0 0.0 000000
0531201 0.0 0.0 0.0
0532201 0.0 0.0 0.0
*
*
0210000 abovspr branch
0210001 2 1
0210101 152.19 2.281 0.0 0.0 90. 2.281 0.00015 0.0 00000
0210200 2 1021.12 1.0
0211101 021010000 020000000 70.75 0.0 0.0 000100
0212101 021000000 053000000 7.96 1.78 1.67 000000
0211201 0.0 0.0 0.0
0212201 0.0 0.0 0.0
*
*
0200000 spsteam snglvol
0200101 70.75 7.4502 0.0 0.0 90. 7.4502 0.00015 0.0 00000
0200200 2 1020.96 1.0
*
*
0190000 dryer separatr
0190001 3 1
0190101 171.4 0.7083 0.0 0.0 0. 0. 0.00015 0.0 00000
0190200 2 1020.96 1.0
0191101 019010000 018000000 63.49 5.502 5.502 000000
0192101 019000000 036000000 2.34 0.5 0.5 000000
0193101 020010000 019000000 70.75 0.5 0.5 000000
0191201 0.0 0.0 0.0
0192201 0.0 0.0 0.0
0193201 0.0 0.0 0.0
*
*
0360000 dsdryer snglvol
0360101 2.34 9.7312 0.0 0.0 -90. -9.7312 0.00015 0.0 00000
0360200 2 1021.57 0.82
*
*
0180000 updryer snglvol
0180101 63.49 0.0 473.0 0.0 0. 0.0 0.00015 0.0 00000
0180200 2 1020.96 1.0
*

RELAP5 Input Deck reidp4
Small Break Case 2 - Flow restrictor, equilibrium

```
*
*
0170000 sgdoom snglvol
0170101 94.12 3.5497 0.0 0.0 90. 3.5497 0.00015 0.0 00000
0170200 2 1020.94 1.0
*
*
0380000 contnm snglvol
0380101 10000.0 200.0 0.0 0.0 90. 200.0 0.0 0.0 00000
0380200 2 14.7 1.0
*
*
5190000 abovefr sngljun
5190101 018010000 017000000 63.49 0.0 0.0 000000
5190110 0.0 0.0 1.0 1.0
5190201 1 0.0 0.0 0.0
*
*
5180000 break valve
5180101 017010000 038000000 1.388 0.0 0.0 000100
5180110 0.0 0.0 1.0 1.0
5180201 1 0.0 0.0 0.0
5180300 mtrvlv
5180301 502 503 1000.0 0.0
*
*
* heat structure input
*
*****
11201000 60 11 2 1 0.0321
11201100 0 2
11201101 0.000438 10
11201201 1 10
11201301 0.0 10
11201401 547.0 11
11201501 001010000 0000 1 0 796.74 1
11201502 001020000 10000 1 0 857.24 3
11201503 001040000 10000 1 0 341.45 5
11201504 001060000 10000 1 0 1095.61 7
11201505 001080000 10000 1 0 341.45 9
11201506 001100000 10000 1 0 1095.61 11
11201507 001120000 10000 1 0 341.45 13
11201508 001140000 10000 1 0 1095.61 15
11201509 001160000 10000 1 0 341.45 17
11201510 001180000 10000 1 0 1095.61 19
11201511 001200000 10000 1 0 341.45 21
11201512 001220000 10000 1 0 1095.61 23
11201513 001240000 10000 1 0 341.45 25
11201514 001260000 10000 1 0 1095.61 27
11201515 001280000 10000 1 0 341.45 29
11201516 001300000 10000 1 0 2190.4 31
11201517 001320000 10000 1 0 341.45 33
```

RELAP5 Input Deck reidp4

Small Break Case 2 - Flow restrictor, equilibrium

| | | | | | | | | | |
|----------|-----------|--------|------|-----|-----------|-----|-----|-----|----|
| 11201518 | 001340000 | 10000 | 1 | 0 | 1095.61 | 35 | | | |
| 11201519 | 001360000 | 10000 | 1 | 0 | 341.45 | 37 | | | |
| 11201520 | 001380000 | 10000 | 1 | 0 | 1095.61 | 39 | | | |
| 11201521 | 001400000 | 10000 | 1 | 0 | 341.45 | 41 | | | |
| 11201522 | 001420000 | 10000 | 1 | 0 | 1095.61 | 43 | | | |
| 11201523 | 001440000 | 10000 | 1 | 0 | 341.45 | 45 | | | |
| 11201524 | 001460000 | 10000 | 1 | 0 | 1095.61 | 47 | | | |
| 11201525 | 001480000 | 10000 | 1 | 0 | 341.45 | 49 | | | |
| 11201526 | 001500000 | 10000 | 1 | 0 | 1095.61 | 51 | | | |
| 11201527 | 001520000 | 10000 | 1 | 0 | 341.45 | 53 | | | |
| 11201528 | 001540000 | 10000 | 1 | 0 | 1095.61 | 55 | | | |
| 11201529 | 001560000 | 10000 | 1 | 0 | 341.45 | 57 | | | |
| 11201530 | 001580000 | 10000 | 1 | 0 | 857.24 | 59 | | | |
| 11201531 | 001600000 | 0000 | 1 | 0 | 796.74 | 60 | | | |
| 11201601 | 030010000 | 0000 | 1 | 0 | 905.4541 | 1 | | | |
| 11201602 | 002010000 | 10000 | 1 | 0 | 974.2092 | 3 | | | |
| 11201603 | 002030000 | 10000 | 1 | 0 | 388.0404 | 5 | | | |
| 11201604 | 002050000 | 10000 | 1 | 0 | 1245.1044 | 7 | | | |
| 11201605 | 002070000 | 10000 | 1 | 0 | 388.0404 | 9 | | | |
| 11201606 | 002090000 | 10000 | 1 | 0 | 1245.1044 | 11 | | | |
| 11201607 | 002110000 | 10000 | 1 | 0 | 388.0404 | 13 | | | |
| 11201608 | 002130000 | 10000 | 1 | 0 | 1245.1044 | 15 | | | |
| 11201609 | 002150000 | 10000 | 1 | 0 | 388.0404 | 17 | | | |
| 11201610 | 002170000 | 10000 | 1 | 0 | 1245.1044 | 19 | | | |
| 11201611 | 002190000 | 10000 | 1 | 0 | 388.0404 | 21 | | | |
| 11201612 | 002210000 | 10000 | 1 | 0 | 1245.1044 | 23 | | | |
| 11201613 | 002230000 | 10000 | 1 | 0 | 388.0404 | 25 | | | |
| 11201614 | 002250000 | 10000 | 1 | 0 | 1245.1044 | 27 | | | |
| 11201615 | 002270000 | 10000 | 1 | 0 | 388.0404 | 29 | | | |
| 11201616 | 002290000 | 0000 | 1 | 0 | 2489.277 | 31 | | | |
| 11201617 | 002280000 | -10000 | 1 | 0 | 388.0404 | 33 | | | |
| 11201618 | 002260000 | -10000 | 1 | 0 | 1245.1044 | 35 | | | |
| 11201619 | 002240000 | -10000 | 1 | 0 | 388.0404 | 37 | | | |
| 11201620 | 002220000 | -10000 | 1 | 0 | 1245.1044 | 39 | | | |
| 11201621 | 002200000 | -10000 | 1 | 0 | 388.0404 | 41 | | | |
| 11201622 | 002180000 | -10000 | 1 | 0 | 1245.1044 | 43 | | | |
| 11201623 | 002160000 | -10000 | 1 | 0 | 388.0404 | 45 | | | |
| 11201624 | 002140000 | -10000 | 1 | 0 | 1245.1044 | 47 | | | |
| 11201625 | 002120000 | -10000 | 1 | 0 | 388.0404 | 49 | | | |
| 11201626 | 002100000 | -10000 | 1 | 0 | 1245.1044 | 51 | | | |
| 11201627 | 002080000 | -10000 | 1 | 0 | 388.0404 | 53 | | | |
| 11201628 | 002060000 | -10000 | 1 | 0 | 1245.1044 | 55 | | | |
| 11201629 | 002040000 | -10000 | 1 | 0 | 388.0404 | 57 | | | |
| 11201630 | 002020000 | -10000 | 1 | 0 | 974.2092 | 59 | | | |
| 11201631 | 030010000 | 0000 | 1 | 0 | 905.4541 | 60 | | | |
| 11201701 | 0 | 0.0 | 0.0 | 0.0 | 60 | | | | |
| 11201801 | 0.0 | 15.0 | 15.0 | 1.5 | 1.5 | 0.0 | 0.0 | 1.0 | 60 |
| 11201901 | 0.0 | 15.0 | 15.0 | 1.5 | 1.5 | 0.0 | 0.0 | 1.0 | 60 |

*

*

* composition type and data format

*

RELAP5 Input Deck reidp4

Small Break Case 2 - Flow restrictor, equilibrium

20100100 tbl/fctn 1 1 * inconel
20100101 70.0 2.3843e-03
20100102 200.0 2.5232e-03
20100103 400.0 2.8009e-03
20100104 600.0 3.0787e-03
20100105 800.0 3.3565e-03
20100106 1000.0 3.6574e-03
20100107 1200.0 3.9815e-03
20100108 1400.0 4.3056e-03
20100151 70.0 55.6831
20100152 200.0 55.5227
20100153 400.0 55.2607
20100154 600.0 54.9895
20100155 800.0 54.7069
20100156 1000.0 54.3982
20100157 1200.0 54.0907
20100158 1400.0 53.7516

*

* control component cards

*

* compute pressure difference

*

20500100 delptp1 sum 1.45038e-4 0.0 1
20500101 0.0 -1.0, p, 002040000 1.0, p, 002030000
20500200 delptp2 sum 1.45038e-4 0.0 1
20500201 0.0 -1.0, p, 002080000 1.0, p, 002070000
20500300 delptp3 sum 1.45038e-4 0.0 1
20500301 0.0 -1.0, p, 002120000 1.0, p, 002110000
20500400 delptp4 sum 1.45038e-4 0.0 1
20500401 0.0 -1.0, p, 002160000 1.0, p, 002150000
20500500 delptp5 sum 1.45038e-4 0.0 1
20500501 0.0 -1.0, p, 002200000 1.0, p, 002190000
20500600 delptp6 sum 1.45038e-4 0.0 1
20500601 0.0 -1.0, p, 002240000 1.0, p, 002230000
20500700 delptp7 sum 1.45038e-4 0.0 1
20500701 0.0 -1.0, p, 002280000 1.0, p, 002270000

*

* end of the input

*

.

Large Break Case 5 - No flow restrictor, non-equilibrium, reduced water level

=SLB pressure difference across the SG tube support plats

* hot standby nonequilibrium models

*

*

*

100 new transnt

*

*

102 british british

105

*

* time step cards

*

*

201 5. 1.d-7 0.005 3 2 200 10000

202 5.3 1.d-7 0.00001 3 1000 20000 100000

203 6.5 1.d-7 0.000025 3 400 8000 100000

204 8.0 1.d-7 0.00005 3 200 10000 100000

205 1000.0 1.d-7 0.00010 3 100 10000 100000

* minor edit variables

*

*

301 mflowj 518000000

302 mflowj 002030000

303 mflowj 002070000

304 mflowj 002110000

305 mflowj 002150000

306 mflowj 002190000

307 mflowj 002230000

308 mflowj 002270000

309 p 017010000

*310 p 018010000

*311 p 019010000

*312 p 020010000

*313 p 021010000

*314 p 022010000

*315 p 023010000

*316 p 033010000

*317 p 034010000

*318 p 036010000

319 cntrlvar 1

320 cntrlvar 2

321 cntrlvar 3

322 cntrlvar 4

323 cntrlvar 5

324 cntrlvar 6

325 cntrlvar 7

*

*

*

Large Break Case 5 - No flow restrictor, non-equilibrium, reduced water level

```
*
*
*
*****
*   trip input data
*
*
501  time 0  ge  null 0  8.0 |
502  time 0  ge  null 0  5.0 |
503  time 0  ge  null 0 200.0 |
*
*
*
*
*
*
600 501
*
*****
*   hydrodynamic components
*
*****
*   primary side model
*   hot leg and cold leg represented by tdvs
*****
*
1000000 inplen  tmdpvol
1000101 0.0 10.0 5000.0 0.0 0.0 0.0 0.0 0.0 0
1000200 3
1000201 0.0 2235.7 547.0
1000202 5.0 2250.0 547.0
1000203 15.0 800.0 491.0
*1000204 1.0e6 800.0 491.0
*
*
1010000 outplen  tmdpvol
1010101 0.0 10.0 5000.0 0.0 0.0 0.0 0.0 0.0 0
1010200 3
1010201 0.0 2200.0 547.0
1010202 5.0 2200.0 547.0
1010203 15.0 700.0 491.0
*
*
0010000 tubes  pipe
0010001 60
0010101 10.956 60
0010301 1.1667 1
0010302 1.2553 3
0010303 0.5 5
0010304 1.60435 7
0010305 0.5 9
0010306 1.60435 11
```

Large Break Case 5 - No flow restrictor, non-equilibrium, reduced water level

```
0010307 0.5 13
0010308 1.60435 15
0010309 0.5 17
0010310 1.60435 19
0010311 0.5 21
0010312 1.60435 23
0010313 0.5 25
0010314 1.60435 27
0010315 0.5 29
0010316 3.0 31
0010317 0.5 33
0010318 1.60435 35
0010319 0.5 37
0010320 1.60435 39
0010321 0.5 41
0010322 1.60435 43
0010323 0.5 45
0010324 1.60435 47
0010325 0.5 49
0010326 1.60435 51
0010327 0.5 53
0010328 1.60435 55
0010329 0.5 57
0010330 1.2553 59
0010331 1.1667 60
0010601 90.0 30
0010602 -90.0 60
0010801 0.0 0.0642 60
0011001 00000 60
0011101 000000 59
0011201 3 2250.0 547.0 0.0 0.0 0.0 60
0011300 1
0011301 9148.5 0.0 0.0 59
*
*
5000000 prminl tmdpjun
5000101 100000000 1000000 10.956
5000200 1
5000201 0.0 9148.5 0.0 0.0
5000202 1.0e6 9148.5 0.0 0.0
*
*
5010000 prmout tmdpjun
5010101 1010000 101000000 10.956
5010200 1
5010201 0.0 9148.5 0.0 0.0
5010202 1.0e6 9148.5 0.0 0.0
*
*
0020000 shell pipe
0020001 30
0020101 54.22 27
```

Large Break Case 5 - No flow restrictor, non-equilibrium, reduced water level

| | | | | |
|---------|---------|-------|----|--|
| 0020102 | 70.0 | 30 | | |
| 0020201 | 54.22 | 2 | | |
| 0020202 | 23.716 | 3 | | |
| 0020203 | 54.22 | 6 | | |
| 0020204 | 23.716 | 7 | | |
| 0020205 | 54.22 | 10 | | |
| 0020206 | 23.716 | 11 | | |
| 0020207 | 54.22 | 14 | | |
| 0020208 | 23.716 | 15 | | |
| 0020209 | 54.22 | 18 | | |
| 0020210 | 23.716 | 19 | | |
| 0020211 | 54.22 | 22 | | |
| 0020212 | 23.716 | 23 | | |
| 0020213 | 54.22 | 26 | | |
| 0020214 | 23.716 | 27 | | |
| 0020215 | 70.0 | 29 | | |
| 0020301 | 1.2553 | 1 | | |
| 0020302 | 1.2553 | 2 | | |
| 0020303 | 0.5 | 4 | | |
| 0020304 | 1.60435 | 6 | | |
| 0020305 | 0.5 | 8 | | |
| 0020306 | 1.60435 | 10 | | |
| 0020307 | 0.5 | 12 | | |
| 0020308 | 1.60435 | 14 | | |
| 0020309 | 0.5 | 16 | | |
| 0020310 | 1.60435 | 18 | | |
| 0020311 | 0.5 | 20 | | |
| 0020312 | 1.60435 | 22 | | |
| 0020313 | 0.5 | 24 | | |
| 0020314 | 1.60435 | 26 | | |
| 0020315 | 0.5 | 28 | | |
| 0020316 | 3.2075 | 29 | | |
| 0020317 | 3.4338 | 30 | | |
| 0020601 | 90.0 | 30 | | |
| 0020801 | 0.00015 | 0.136 | 29 | |
| 0020802 | 0.00015 | 0.0 | 30 | |
| 0020901 | 0.0 | 0.0 | 2 | |
| 0020902 | 0.99 | 0.99 | 3 | |
| 0020903 | 0.0 | 0.0 | 6 | |
| 0020904 | 0.99 | 0.99 | 7 | |
| 0020905 | 0.0 | 0.0 | 10 | |
| 0020906 | 0.99 | 0.99 | 11 | |
| 0020907 | 0.0 | 0.0 | 14 | |
| 0020908 | 0.99 | 0.99 | 15 | |
| 0020909 | 0.0 | 0.0 | 18 | |
| 0020910 | 0.99 | 0.99 | 19 | |
| 0020911 | 0.0 | 0.0 | 22 | |
| 0020912 | 0.99 | 0.99 | 23 | |
| 0020913 | 0.0 | 0.0 | 26 | |
| 0020914 | 0.99 | 0.99 | 27 | |
| 0020915 | 0.0 | 0.0 | 29 | |
| 0021001 | 00100 | 29 | | |

Large Break Case 5 - No flow restrictor, non-equilibrium, reduced water level

```

0021002 00000 30
0021101 000000 29
0021201 3 1033.73 547.0 0.0 0.0 0.0 1
0021202 3 1033.34 547.0 0.0 0.0 0.0 2
0021203 3 1033.07 547.0 0.0 0.0 0.0 3
0021204 3 1032.91 547.0 0.0 0.0 0.0 4
0021205 3 1032.57 547.0 0.0 0.0 0.0 5
0021206 3 1032.06 547.0 0.0 0.0 0.0 6
0021207 3 1031.72 547.0 0.0 0.0 0.0 7
0021208 3 1031.56 547.0 0.0 0.0 0.0 8
0021209 3 1031.22 547.0 0.0 0.0 0.0 9
0021210 3 1030.71 547.0 0.0 0.0 0.0 10
0021211 3 1030.37 547.0 0.0 0.0 0.0 11
0021212 3 1030.21 547.0 0.0 0.0 0.0 12
0021213 3 1029.87 547.0 0.0 0.0 0.0 13
0021214 3 1029.36 547.0 0.0 0.0 0.0 14
0021215 3 1029.02 547.0 0.0 0.0 0.0 15
0021216 3 1028.86 547.0 0.0 0.0 0.0 16
0021217 3 1028.53 547.0 0.0 0.0 0.0 17
0021218 3 1028.01 547.0 0.0 0.0 0.0 18
0021219 3 1027.68 547.0 0.0 0.0 0.0 19
0021220 3 1027.52 547.0 0.0 0.0 0.0 20
0021221 3 1027.18 547.0 0.0 0.0 0.0 21
0021222 3 1026.66 547.0 0.0 0.0 0.0 22
0021223 3 1026.33 547.0 0.0 0.0 0.0 23
0021224 3 1026.17 547.0 0.0 0.0 0.0 24
0021225 3 1025.83 547.0 0.0 0.0 0.0 25
0021226 3 1025.32 547.0 0.0 0.0 0.0 26
0021227 3 1024.98 547.0 0.0 0.0 0.0 27
0021228 3 1024.82 547.0 0.0 0.0 0.0 28
0021229 3 1024.23 547.0 0.0 0.0 0.0 29
0021230 3 1023.17 547.0 0.0 0.0 0.0 30
0021300 1
0021301 0.0 0.0 0.0 29
0021401 0.0625 0.0 1.0 1.0 29
*
*
0350000 downc pipe
0350001 3
0350101 0.0 3
0350201 7.096 2
0350301 11.827 3
0350401 122.4 3
0350601 -90.0 3
0350801 0.00015 0.4275 3
0351001 00000 3
0351101 000000 2
0351201 3 1024.84 547.0 0.0 0.0 0.0 1
0351202 3 1028.64 547.0 0.0 0.0 0.0 2
0351203 3 1032.44 547.0 0.0 0.0 0.0 3
0351300 1
0351301 0.0 0.0 0.0 2

```

Large Break Case 5 - No flow restrictor, non-equilibrium, reduced water level

*

*

0300000 tubesh branch

0300001 2 1

0300101 54.22 1.1667 0. 0. 90. 1.1667 0.00015 0.136 00100

0300200 3 1034.15 547.0

0301101 035010000 030000000 7.096 0.0 0.0 000000

0302101 030010000 002000000 4.43 5.32 5.32 000000

0301201 0.0 0.0 0.0

0302201 0.0 0.0 0.0

*

*

0340000 feedrg branch

0340001 1 1

0340101 92.1 3.1097 0.0 0. -90. -3.1097 0.00015 0.0 00000

0340200 3 1022.48 547.0

0341101 034010000 035000000 7.096 0.0 0.0 000100

0341201 0.0 0.0 0.0

*

*

0230000 abovetb snglvol

0230101 49.43 4.9423 0.0 0.0 90. 4.9423 0.00015 0.0 00000

0230200 2 1022.72 0.39

*

*

5330000 abovetb sngljun

5330101 002010000 023000000 49.43 0.0 0.0 000100

5330110 0.0 0.0 1.0 1.0

5330201 1 0.0 0.0 0.0

*

*

0220000 speratr separatr

0220001 3 1

0220101 41.73 3.9156 0.0 0. 90. 3.9156 0.00015 0.0 00000

0220200 2 1021.14 1.0

0221101 022010000 021000000 12.828 0.84 0.47 000000

0222101 022000000 032000000 17.35 0.597 0.597 000000

0223101 023010000 022000000 41.73 8.689 8.689 000000

0221201 0.0 0.0 0.0

0222201 0.0 0.0 0.0

0223201 0.0 0.0 0.0

*

*

0320000 liqsept snglvol

0320101 17.35 0.0 86.75 0.0 0. 0.0 0.00015 0.0 00000

0320200 2 1021.26 1.0

*

*

0330000 abovf1 branch

0330001 2 1

0330101 100.7 2.9225 0.0 0.0 -90.0 -2.9225 0.00015 0.0 00000

0330200 2 1021.72 0.93

Large Break Case 5 - No flow restrictor, non-equilibrium, reduced water level

```
0331101 032010000 033000000 17.35 0.0 0.0 000000
0332101 033010000 034000000 79.288 0.0 0.0 000000
0331201 0.0 0.0 0.0
0332201 0.0 0.0 0.0
*
*
0530000 abovfr2 branch
0530001 2 1
0530101 100.7 3.9156 0.0 0.0 -90.0 -3.9156 0.00015 0.0 00000
0530200 2 1021.72 0.93
0531101 036010000 053000000 2.34 0.5 0.5 000000
0532101 053010000 033000000 100.7 0.0 0.0 000000
0531201 0.0 0.0 0.0
0532201 0.0 0.0 0.0
*
*
0210000 abovspr branch
0210001 2 1
0210101 152.19 2.281 0.0 0.0 90. 2.281 0.00015 0.0 00000
0210200 2 1021.12 1.0
0211101 021010000 020000000 70.75 0.0 0.0 000100
0212101 021000000 053000000 7.96 1.78 1.67 000000
0211201 0.0 0.0 0.0
0212201 0.0 0.0 0.0
*
*
0200000 spsteam snglvol
0200101 70.75 7.4502 0.0 0.0 90. 7.4502 0.00015 0.0 00000
0200200 2 1020.96 1.0
*
*
0190000 dryer separatr
0190001 3 1
0190101 171.4 0.7083 0.0 0.0 0. 0. 0.00015 0.0 00000
0190200 2 1020.96 1.0
0191101 019010000 018000000 63.49 5.502 5.502 000000
0192101 019000000 036000000 2.34 0.5 0.5 000000
0193101 020010000 019000000 70.75 0.5 0.5 000000
0191201 0.0 0.0 0.0
0192201 0.0 0.0 0.0
0193201 0.0 0.0 0.0
*
*
0360000 dsdryer snglvol
0360101 2.34 9.7312 0.0 0.0 -90. -9.7312 0.00015 0.0 00000
0360200 2 1021.57 1.0
*
*
0180000 updryer snglvol
0180101 63.49 0.0 473.0 0.0 0. 0.0 0.00015 0.0 00000
0180200 2 1020.96 1.0
*
```


Large Break Case 5 - No flow restrictor, non-equilibrium, reduced water level

*

*

0170000 sgdoom snglvol

0170101 94.12 3.5497 0.0 0.0 90. 3.5497 0.00015 0.0 00000

0170200 2 1020.94 1.0

*

*

0380000 contnm snglvol

0380101 10000.0 200.0 0.0 0.0 90. 200.0 0.0 0.0 00000

0380200 2 14.7 1.0

*

*

5190000 abovefr sngljun

5190101 018010000 017000000 63.49 0.0 0.0 000000

5190110 0.0 0.0 1.0 1.0

5190201 1 0.0 0.0 0.0

*

*

5180000 break valve

5180101 017010000 038000000 4.6 0.0 0.0 000100

5180110 0.0 0.0 1.0 1.0

5180201 1 0.0 0.0 0.0

5180300 mtrvlv

5180301 502 503 1000.0 0.0

*

*

* heat structure input

*

11201000 60 11 2 1 0.0321

11201100 0 2

11201101 0.000438 10

11201201 1 10

11201301 0.0 10

11201401 547.0 11

11201501 001010000 0000 1 0 796.74 1

11201502 001020000 10000 1 0 857.24 3

11201503 001040000 10000 1 0 341.45 5

11201504 001060000 10000 1 0 1095.61 7

11201505 001080000 10000 1 0 341.45 9

11201506 001100000 10000 1 0 1095.61 11

11201507 001120000 10000 1 0 341.45 13

11201508 001140000 10000 1 0 1095.61 15

11201509 001160000 10000 1 0 341.45 17

11201510 001180000 10000 1 0 1095.61 19

11201511 001200000 10000 1 0 341.45 21

11201512 001220000 10000 1 0 1095.61 23

11201513 001240000 10000 1 0 341.45 25

11201514 001260000 10000 1 0 1095.61 27

11201515 001280000 10000 1 0 341.45 29

11201516 001300000 10000 1 0 2190.4 31

11201517 001320000 10000 1 0 341.45 33

Large Break Case 5 - No flow restrictor, non-equilibrium, reduced water level!

| | | | | | | | | | | |
|----------|-----------|--------|------|-----|-----------|-----|-----|-----|----|--|
| 11201518 | 001340000 | 10000 | 1 | 0 | 1095.61 | 35 | | | | |
| 11201519 | 001360000 | 10000 | 1 | 0 | 341.45 | 37 | | | | |
| 11201520 | 001380000 | 10000 | 1 | 0 | 1095.61 | 39 | | | | |
| 11201521 | 001400000 | 10000 | 1 | 0 | 341.45 | 41 | | | | |
| 11201522 | 001420000 | 10000 | 1 | 0 | 1095.61 | 43 | | | | |
| 11201523 | 001440000 | 10000 | 1 | 0 | 341.45 | 45 | | | | |
| 11201524 | 001460000 | 10000 | 1 | 0 | 1095.61 | 47 | | | | |
| 11201525 | 001480000 | 10000 | 1 | 0 | 341.45 | 49 | | | | |
| 11201526 | 001500000 | 10000 | 1 | 0 | 1095.61 | 51 | | | | |
| 11201527 | 001520000 | 10000 | 1 | 0 | 341.45 | 53 | | | | |
| 11201528 | 001540000 | 10000 | 1 | 0 | 1095.61 | 55 | | | | |
| 11201529 | 001560000 | 10000 | 1 | 0 | 341.45 | 57 | | | | |
| 11201530 | 001580000 | 10000 | 1 | 0 | 857.24 | 59 | | | | |
| 11201531 | 001600000 | 0000 | 1 | 0 | 796.74 | 60 | | | | |
| 11201601 | 030010000 | 0000 | 1 | 0 | 905.4541 | 1 | | | | |
| 11201602 | 002010000 | 10000 | 1 | 0 | 974.2092 | 3 | | | | |
| 11201603 | 002030000 | 10000 | 1 | 0 | 388.0404 | 5 | | | | |
| 11201604 | 002050000 | 10000 | 1 | 0 | 1245.1044 | 7 | | | | |
| 11201605 | 002070000 | 10000 | 1 | 0 | 388.0404 | 9 | | | | |
| 11201606 | 002090000 | 10000 | 1 | 0 | 1245.1044 | 11 | | | | |
| 11201607 | 002110000 | 10000 | 1 | 0 | 388.0404 | 13 | | | | |
| 11201608 | 002130000 | 10000 | 1 | 0 | 1245.1044 | 15 | | | | |
| 11201609 | 002150000 | 10000 | 1 | 0 | 388.0404 | 17 | | | | |
| 11201610 | 002170000 | 10000 | 1 | 0 | 1245.1044 | 19 | | | | |
| 11201611 | 002190000 | 10000 | 1 | 0 | 388.0404 | 21 | | | | |
| 11201612 | 002210000 | 10000 | 1 | 0 | 1245.1044 | 23 | | | | |
| 11201613 | 002230000 | 10000 | 1 | 0 | 388.0404 | 25 | | | | |
| 11201614 | 002250000 | 10000 | 1 | 0 | 1245.1044 | 27 | | | | |
| 11201615 | 002270000 | 10000 | 1 | 0 | 388.0404 | 29 | | | | |
| 11201616 | 002290000 | 0000 | 1 | 0 | 2489.277 | 31 | | | | |
| 11201617 | 002280000 | -10000 | 1 | 0 | 388.0404 | 33 | | | | |
| 11201618 | 002260000 | -10000 | 1 | 0 | 1245.1044 | 35 | | | | |
| 11201619 | 002240000 | -10000 | 1 | 0 | 388.0404 | 37 | | | | |
| 11201620 | 002220000 | -10000 | 1 | 0 | 1245.1044 | 39 | | | | |
| 11201621 | 002200000 | -10000 | 1 | 0 | 388.0404 | 41 | | | | |
| 11201622 | 002180000 | -10000 | 1 | 0 | 1245.1044 | 43 | | | | |
| 11201623 | 002160000 | -10000 | 1 | 0 | 388.0404 | 45 | | | | |
| 11201624 | 002140000 | -10000 | 1 | 0 | 1245.1044 | 47 | | | | |
| 11201625 | 002120000 | -10000 | 1 | 0 | 388.0404 | 49 | | | | |
| 11201626 | 002100000 | -10000 | 1 | 0 | 1245.1044 | 51 | | | | |
| 11201627 | 002080000 | -10000 | 1 | 0 | 388.0404 | 53 | | | | |
| 11201628 | 002060000 | -10000 | 1 | 0 | 1245.1044 | 55 | | | | |
| 11201629 | 002040000 | -10000 | 1 | 0 | 388.0404 | 57 | | | | |
| 11201630 | 002020000 | -10000 | 1 | 0 | 974.2092 | 59 | | | | |
| 11201631 | 030010000 | 0000 | 1 | 0 | 905.4541 | 60 | | | | |
| 11201701 | 0 | 0.0 | 0.0 | 0.0 | 60 | | | | | |
| 11201801 | 0.0 | 15.0 | 15.0 | 1.5 | 1.5 | 0.0 | 0.0 | 1.0 | 60 | |
| 11201901 | 0.0 | 15.0 | 15.0 | 1.5 | 1.5 | 0.0 | 0.0 | 1.0 | 60 | |

*

*

* composition type and data format

*

Large Break Case 5 - No flow restrictor, non-equilibrium, reduced water level

| | | | | |
|----------|----------|------------|---|-----------|
| 20100100 | tbl/fctn | 1 | 1 | * inconel |
| 20100101 | 70.0 | 2.3843e-03 | | |
| 20100102 | 200.0 | 2.5232e-03 | | |
| 20100103 | 400.0 | 2.8009e-03 | | |
| 20100104 | 600.0 | 3.0787e-03 | | |
| 20100105 | 800.0 | 3.3565e-03 | | |
| 20100106 | 1000.0 | 3.6574e-03 | | |
| 20100107 | 1200.0 | 3.9815e-03 | | |
| 20100108 | 1400.0 | 4.3056e-03 | | |
| 20100151 | 70.0 | 55.6831 | | |
| 20100152 | 200.0 | 55.5227 | | |
| 20100153 | 400.0 | 55.2607 | | |
| 20100154 | 600.0 | 54.9895 | | |
| 20100155 | 800.0 | 54.7069 | | |
| 20100156 | 1000.0 | 54.3982 | | |
| 20100157 | 1200.0 | 54.0907 | | |
| 20100158 | 1400.0 | 53.7516 | | |

*

* control component cards

*

* compute pressure difference

*

| | | | | | |
|----------|---------|----------|------------|---------|-----------|
| 20500100 | delptp1 | sum | 1.45038e-4 | 0.0 | 1 |
| 20500101 | 0.0 | -1.0, p, | 002040000 | 1.0, p, | 002030000 |
| 20500200 | delptp2 | sum | 1.45038e-4 | 0.0 | 1 |
| 20500201 | 0.0 | -1.0, p, | 002080000 | 1.0, p, | 002070000 |
| 20500300 | delptp3 | sum | 1.45038e-4 | 0.0 | 1 |
| 20500301 | 0.0 | -1.0, p, | 002120000 | 1.0, p, | 002110000 |
| 20500400 | delptp4 | sum | 1.45038e-4 | 0.0 | 1 |
| 20500401 | 0.0 | -1.0, p, | 002160000 | 1.0, p, | 002150000 |
| 20500500 | delptp5 | sum | 1.45038e-4 | 0.0 | 1 |
| 20500501 | 0.0 | -1.0, p, | 002200000 | 1.0, p, | 002190000 |
| 20500600 | delptp6 | sum | 1.45038e-4 | 0.0 | 1 |
| 20500601 | 0.0 | -1.0, p, | 002240000 | 1.0, p, | 002230000 |
| 20500700 | delptp7 | sum | 1.45038e-4 | 0.0 | 1 |
| 20500701 | 0.0 | -1.0, p, | 002280000 | 1.0, p, | 002270000 |

*

* end of the input

*

strippe.xls
stripvfyg.xls

strippe.xls
reidp5!
reidp4!
reidp3!
reidp2!
reidp1!