



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

February 28, 2000

Mr. L. W. Myers  
Senior Vice President  
Beaver Valley Power Station  
Post Office Box 4  
Shippingport, PA 15077

**SUBJECT: BEAVER VALLEY 1 AND 2 - ISSUANCE OF AMENDMENT RE: RELOCATION OF SEISMIC MONITORING INSTRUMENTATION REQUIREMENTS PER GUIDANCE OF GENERIC LETTER 95-10 (TAC NOS. MA5624 AND MA5625)**

Dear Mr. Myers:

The Commission has issued the enclosed Amendment No. 228 to Facility Operating License No. DPR-66 and Amendment No. 107 to Facility Operating License No. NPF-73 for the Beaver Valley Power Station, Unit Nos. 1 and 2 (BVPS-1 and 2). These amendments consist of changes to the Technical Specifications (TSs) in response to Duquesne Light Company's (DLC) application dated May 27, 1999, as the then licensee for BVPS-1 and 2, which submitted License Amendment Request Nos. 268 and 143.

On the date of the May 27, 1999, letter, DLC was the licensed operator for BVPS-1 and BVPS-2. On December 3, 1999, DLC's ownership interests in both BVPS-1 and BVPS-2 were transferred to the Pennsylvania Power Company, and DLC's operating authority for BVPS-1 and BVPS-2 was transferred to FirstEnergy Nuclear Operating Company (FENOC). By letter dated December 13, 1999, FENOC requested that the Nuclear Regulatory Commission continue to review and act upon all requests before the Commission which had been submitted by DLC.

These amendments relocate the seismic monitoring instrumentation requirements contained in Technical Specification (TS) 3/4.3.3.3 to the Licensing Requirements Manual (LRM) based on the guidance provided in Generic Letter 95-10, "Relocation of Selected Technical Specifications Requirements Related to Instrumentation." The Bases section for Specification 3/4.3.3.3 is also relocated to the LRM. The appropriate Index pages, Table Index page (Unit No. 1 only), TS pages and Bases pages are revised to reflect the removal of the seismic monitoring instrumentation specification from the TSs. An additional specification page is added to reflect that TS Number 3/4.3.3.4 is not used. This additional page also denotes the number of the following page. Finally, the Bases section is modified to denote that TS Number 3/4.3.3.4 is not used.

**NRC FILE CENTER COPY**


*DFoI*

L. W. Myers

-2-

A copy of our safety evaluation is also enclosed. The Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,



Daniel S. Collins, Project Manager, Section 1  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-334 and 50-412

Enclosures: 1. Amendment No.228 to DPR-66  
2. Amendment No.107 to NPF-73  
3. Safety Evaluation

cc w/encls: See next page

L. W. Myers

-2-

February 28, 2000

A copy of our safety evaluation is also enclosed. The Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

/RA/

Daniel S. Collins, Project Manager, Section 1  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-334 and 50-412

- Enclosures: 1. Amendment No.228 to DPR-66
- 2. Amendment No.107 to NPF-73
- 3. Safety Evaluation

cc w/encls: See next page

**DISTRIBUTION:**

~~File Center~~

PUBLIC  
PDI-1 Reading  
MGamberoni

MO'Brien  
DCollins  
OGC  
GHill (4)

ACRS  
WBeckner  
EMarinos  
EAdensam (E-Mail)  
MOprendek, RGN-I  
DSpaulding

DOCUMENT NAME: G:\PDI-1\Beaver1&2\Amda5625 version b.wpd

\* See previous concurrence

\*\* SE Input dated 1/2/00 was provided and no major technical changes were made.

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PDI-1/PM	E	PDI-2/LA	EEIB**	RTSB	OGC	PDI-1/ASC
NAME	DCollins		MO'Brien	SE dtd	WBeckner*	EMarinos	MGamberoni
DATE	2/11/00		2/11/00	01/20/00	02/08/00	2/22/00	2/29/00

Official Record Copy

Beaver Valley Power Station, Units 1 and 2

Jay E. Silberg, Esquire  
Shaw, Pittman, Potts & Trowbridge  
2300 N Street, NW.  
Washington, DC 20037

First Energy Nuclear Operating Company  
Licensing Section  
Mark S. Ackerman, Manager (2 Copies)  
Beaver Valley Power Station  
PO Box 4, BV-A  
Shippingport, PA 15077

Commissioner Roy M. Smith  
West Virginia Department of Labor  
Building 3, Room 319  
Capitol Complex  
Charleston, WV 25305

Director, Utilities Department  
Public Utilities Commission  
180 East Broad Street  
Columbus, OH 43266-0573

Director, Pennsylvania Emergency  
Management Agency  
Post Office Box 3321  
Harrisburg, PA 17105-3321

Ohio EPA-DERR  
ATTN: Zack A. Clayton  
Post Office Box 1049  
Columbus, OH 43266-0149

Dr. Judith Johnsrud  
National Energy Committee  
Sierra Club  
433 Orlando Avenue  
State College, PA 16803

First Energy Nuclear Operating Company  
Beaver Valley Power Station  
J. J. Maracek  
P. O. Box 4, BV-A  
Shippingport, PA 15077

First Energy Nuclear Operating Company  
Beaver Valley Power Station  
PO Box 4  
Shippingport, PA 15077  
ATTN: Kevin L. Ostrowski,  
Plant General Manager (BV-SOSB-7)

Bureau of Radiation Protection  
Pennsylvania Department of  
Environmental Protection  
ATTN: Larry Ryan  
Post Office Box 2063  
Harrisburg, PA 17120

Mayor of the Borough of  
Shippingport  
Post Office Box 3  
Shippingport, PA 15077

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Resident Inspector  
U.S. Nuclear Regulatory Commission  
Post Office Box 298  
Shippingport, PA 15077

First Energy Nuclear Operating Company  
Beaver Valley Power Station  
PO Box 4  
Shippingport, PA 15077  
ATTN: M. P. Pearson, Director Plant  
Services (BV-NCD-3)

Mr. J. A. Hultz, Manager  
Projects & Support Services  
First Energy  
76 South Main Street  
Akron, OH 44308



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

PENNSYLVANIA POWER COMPANY

OHIO EDISON COMPANY

FIRSTENERGY NUCLEAR OPERATING COMPANY

DOCKET NO. 50-334

BEAVER VALLEY POWER STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 228  
License No. DPR-66

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by FirstEnergy Nuclear Operating Company, et al. (the licensee) dated May 27, 1999, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-66 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 228 , are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance and shall be implemented within 60 days. Implementation of this amendment shall include the relocation of these Technical Specification requirements to the appropriate documents as described in the licensee's application dated May 27, 1999, and evaluated in the staff's safety evaluation attached to this amendment.

FOR THE NUCLEAR REGULATORY COMMISSION



Marsha Gamberoni, Acting Chief, Section 1  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical  
Specifications

Date of Issuance: February 28, 2000

ATTACHMENT TO LICENSE AMENDMENT NO. 228

FACILITY OPERATING LICENSE NO. DPR-66

DOCKET NO. 50-334

Replace the following pages of Appendix A Technical Specifications with the attached revised pages. The revised pages are identified by amendment number and contain marginal lines indicating the areas of change.

<u>Remove</u>	<u>Insert</u>
IV	IV
X	X
XVI	XVI
3/4 3-38	3/4 3-38
3/4 3-39	3/4 3-39
3/4 3-40	-----
B 3/4 3-2	B 3/4 3-2

INDEXLIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

<u>SECTION</u>		<u>PAGE</u>
3/4.1.3.3	Position Indication System - Shutdown ....	3/4 1-21
3/4.1.3.4	Rod Drop Time .....	3/4 1-22
3/4.1.3.5	Shutdown Rod Insertion Limit .....	3/4 1-23
3/4.1.3.6	Control Rod Insertion Limits .....	3/4 1-23a
<u>3/4.2 POWER DISTRIBUTION LIMITS</u>		
3/4.2.1	AXIAL FLUX DIFFERENCE .....	3/4 2-1
3/4.2.2	HEAT FLUX HOT CHANNEL FACTOR .....	3/4 2-5
3/4.2.3	NUCLEAR ENTHALPY HOT CHANNEL FACTOR .....	3/4 2-8
3/4.2.4	QUADRANT POWER TILT RATIO .....	3/4 2-10
3/4.2.5	DNB PARAMETERS .....	3/4 2-12
<u>3/4.3 INSTRUMENTATION</u>		
3/4.3.1	REACTOR TRIP SYSTEM INSTRUMENTATION .....	3/4 3-1
3/4.3.2	ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION .....	3/4 3-14
3/4.3.3	MONITORING INSTRUMENTATION	
3/4.3.3.1	Radiation Monitoring .....	3/4 3-33
3/4.3.3.2	Movable Incore Detectors .....	3/4 3-37
3/4.3.3.5	Remote Shutdown Instrumentation .....	3/4 3-44
3/4.3.3.7	Chlorine Detection System .....	3/4 3-49
3/4.3.3.8	Accident Monitoring Instrumentation .....	3/4 3-50
3/4.3.3.11	Explosive Gas Monitoring Instrumentation .	3/4 3-54



INDEXBASES

<u>SECTION</u>	<u>PAGE</u>
3/4.2.2 AND 3/4.2.3 HEAT FLUX AND NUCLEAR ENTHALPY HOT CHANNEL FACTORS .....	B 3/4 2-4
3/4.2.4 QUADRANT POWER TILT RATIO .....	B 3/4 2-5
3/4.2.5 DNB PARAMETERS .....	B 3/4 2-6
 <u>3/4.3 INSTRUMENTATION</u>	
3/4.3.1 AND 3/4.3.2 PROTECTIVE AND ENGINEERED SAFETY FEATURES (ESF) INSTRUMENTATION .....	B 3/4 3-1
3/4.3.3 MONITORING INSTRUMENTATION .....	B 3/4 3-2
3/4.3.3.1 Radiation Monitoring Instrumentation .....	B 3/4 3-2
3/4.3.3.2 Moveable Incore Detectors .....	B 3/4 3-2
3/4.3.3.5 Remote Shutdown Instrumentation .....	B 3/4 3-3
3/4.3.3.7 Chlorine Detection Systems .....	B 3/4 3-3
3/4.3.3.8 Accident Monitoring Instrumentation .....	B 3/4 3-3
3/4.3.3.11 Explosive Gas Monitoring Instrumentation .....	B 3/4 3-4
 <u>3/4.4 REACTOR COOLANT SYSTEM</u>	
3/4.4.1 REACTOR COOLANT LOOPS .....	B 3/4 4-1
3/4.4.2 AND 3/4.4.3 SAFETY VALVES .....	B 3/4 4-1a
3/4.4.4 PRESSURIZER .....	B 3/4 4-2
3/4.4.5 STEAM GENERATORS .....	B 3/4 4-2
3/4.4.6 REACTOR COOLANT SYSTEM LEAKAGE .....	B 3/4 4-3
3/4.4.6.1 Leakage Detection Instrumentation .....	B 3/4 4-3
3/4.4.6.2 Operational Leakage .....	B 3/4 4-3d
3/4.4.6.3 Pressure Isolation Valve Leakage .....	B 3/4 4-3j
3/4.4.7 CHEMISTRY .....	B 3/4 4-4

TABLE INDEX

<u>TABLE</u>	<u>TITLE</u>	<u>PAGE</u>
2.2-1	Reactor Trip System Instrumentation Trip Setpoints	2-6
3.1-1	Accident Analyses Requiring Reevaluation in the event of an Inoperable Full or Part Length Rod	3/4 1-19a
3.2-1	DNB Parameters	3/4 2-13
3.3-1	Reactor Trip System Instrumentation	3/4 3-2
4.3-1	Reactor Trip System Instrumentation Surveillance Requirements	3/4 3-11
3.3-3	Engineered Safety Features Actuation System Instrumentation	3/4 3-15
3.3-4	Engineered Safety Features Actuation System Instrumentation Trip Setpoints	3/4 3-22
4.3-2	Engineered Safety Feature Actuation System Instrumentation Surveillance Requirements	3/4 3-29
3.3-6	Radiation Monitoring Instrumentation	3/4 3-34
4.3-3	Radiation Monitoring Instrumentation Surveillance Requirements	3/4 3-36
3.3-9	Remote Shutdown Panel Monitoring Instrumentation	3/4 3-45
4.3-6	Remote Shutdown Monitoring Instrumentation Surveillance Requirements	3/4 3-46

DPR-66  
INSTRUMENTATION

3/4.3.3.3 (This Specification number is not used.)

DPR-66  
INSTRUMENTATION

3/4.3.3.4 (This Specification number is not used.)

BASES

---

---

3/4.3.3 MONITORING INSTRUMENTATION

3/4.3.3.1 RADIATION MONITORING INSTRUMENTATION

The OPERABILITY of the radiation monitoring channels ensures that: 1) the radiation levels are continually measured in the areas served by the individual channels; 2) the alarm or automatic action is initiated when the radiation level trip setpoint is exceeded; and 3) sufficient information is available on selected plant parameters to monitor and assess these variables following an accident. This capability is consistent with the recommendations of NUREG-0737, "Clarification of TMI Action Plan Requirements," October, 1980.

3/4.3.3.2 MOVABLE INCORE DETECTORS

The OPERABILITY of the movable incore detectors with the specified minimum complement of equipment ensures that the measurements obtained from use of this system accurately represent the spatial neutron flux distribution of the reactor core. The OPERABILITY of this system is demonstrated by irradiating each detector used and determining the acceptability of its voltage curve.

For the purpose of measuring  $F_0(Z)$  or  $F_{\Delta H}^N$ , a full incore flux map is used. Quarter-core flux maps, as defined in WCAP-8648, June 1976, may be used in recalibration of the excore neutron flux detection system, and full incore flux maps or symmetric incore thimbles may be used for monitoring the Quadrant Power Tilt Ratio when one Power Range Channel is inoperable.

3/4.3.3.3 (This Specification number is not used.)

3/4.3.3.4 (This Specification number is not used.)



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

PENNSYLVANIA POWER COMPANY

OHIO EDISON COMPANY

THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

THE TOLEDO EDISON COMPANY

FIRSTENERGY NUCLEAR OPERATING COMPANY

DOCKET NO. 50-412

BEAVER VALLEY POWER STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 107  
License No. NPF-73

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by FirstEnergy Nuclear Operating Company, et al. (the licensee) dated May 27, 1999, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-73 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 107 , and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto are hereby incorporated in the license. FENOC shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance and shall be implemented within 60 days. Implementation of this amendment shall include the relocation of these Technical Specification requirements to the appropriate documents as described in the licensee's application dated May 27, 1999, and evaluated in the staff's safety evaluation attached to this amendment.

FOR THE NUCLEAR REGULATORY COMMISSION



Marsha Gamberoni, Acting Chief, Section 1  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical  
Specifications

Date of Issuance: February 28, 2000

ATTACHMENT TO LICENSE AMENDMENT NO. 107

FACILITY OPERATING LICENSE NO. NPF-73

DOCKET NO. 50-412

Replace the following pages of Appendix A Technical Specifications with the attached revised pages. The revised pages are identified by amendment number and contain marginal lines indicating the areas of change.

<u>Remove</u>	<u>Insert</u>
IV	IV
X	X
3/4 3-46	3/4 3-46
3/4 3-47	3/4 3-47
3/4 3-48	-----
B 3/4 3-11	B 3/4 3-11



INDEXLIMITING CONDITION FOR OPERATION AND SURVEILLANCE REQUIREMENTS

<u>SECTION</u>		<u>PAGE</u>
3/4.1.2.9	Isolation of Unborated Water Sources - Shutdown .....	3/4 1-17
3/4.1.3	MOVABLE CONTROL ASSEMBLIES	
3/4.1.3.1	Group Height .....	3/4 1-18
3/4.1.3.2	Position Indication Systems - Operating .	3/4 1-21
3/4.1.3.3	Position Indication System - Shutdown ...	3/4 1-22
3/4.1.3.4	Rod Drop Time .....	3/4 1-23
3/4.1.3.5	Shutdown Rod Insertion Limit .....	3/4 1-24
3/4.1.3.6	Control Rod Insertion Limits .....	3/4 1-25
 <u>3/4.2 POWER DISTRIBUTION LIMITS</u>		
3/4.2.1	AXIAL FLUX DIFFERENCE (AFD) .....	3/4 2-1
3/4.2.2	HEAT FLUX HOT CHANNEL FACTOR - $F_Q(Z)$ ....	3/4 2-4
3/4.2.3	NUCLEAR ENTHALPY HOT CHANNEL FACTOR - $F_{\Delta H}^N$ .....	3/4 2-7
3/4.2.4	QUADRANT POWER TILT RATIO .....	3/4 2-9
3/4.2.5	DNB PARAMETERS .....	3/4 2-11
 <u>3/4.3 INSTRUMENTATION</u>		
3/4.3.1	REACTOR TRIP SYSTEM INSTRUMENTATION .....	3/4 3-1
3/4.3.2	ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION .....	3/4 3-14
3/4.3.3	MONITORING INSTRUMENTATION	
3/4.3.3.1	Radiation Monitoring .....	3/4 3-39
3/4.3.3.2	Movable Incore Detectors .....	3/4 3-45

INDEXBASES

<u>SECTION</u>	<u>PAGE</u>
<u>3/4.2 POWER DISTRIBUTION LIMITS</u>	
3/4.2.1	AXIAL FLUX DIFFERENCE (AFD) ..... B 3/4 2-1
3/4.2.2 AND 3/4.2.3	HEAT FLUX AND NUCLEAR ENTHALPY HOT CHANNEL FACTORS $F_Q(Z)$ AND $F_{\Delta H}^N$ ..... B 3/4 2-2
3/4.2.4	QUADRANT POWER TILT RATIO ..... B 3/4 2-5
3/4.2.5	DNB PARAMETERS ..... B 3/4 2-5
<u>3/4.3 INSTRUMENTATION</u>	
3/4.3.1	REACTOR TRIP SYSTEM INSTRUMENTATION ..... B 3/4 3-1
3/4.3.2	ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION ..... B 3/4 3-1
3/4.3.3	MONITORING INSTRUMENTATION
3/4.3.3.1	Radiation Monitoring Instrumentation ..... B 3/4 3-10
3/4.3.3.2	Movable Incore Detectors ..... B 3/4 3-10
3/4.3.3.5	Remote Shutdown Instrumentation ..... B 3/4 3-11
3/4.3.3.7	Chlorine Detection Systems ..... B 3/4 3-11
3/4.3.3.8	Accident Monitoring Instrumentation ..... B 3/4 3-12
3/4.3.3.11	Explosive Gas Monitoring Instrumentation ..... B 3/4 3-12
3/4.3.4	TURBINE OVERSPEED PROTECTION ..... B 3/4 3-12
<u>3/4.4 REACTOR COOLANT SYSTEM</u>	
3/4.4.1	REACTOR COOLANT LOOPS AND COOLANT CIRCULATION ..... B 3/4 4-1
3/4.4.2 AND 3/4.4.3	SAFETY VALVES ..... B 3/4 4-2
3/4.4.4	PRESSURIZER ..... B 3/4 4-2

NPF-73  
INSTRUMENTATION

3/4.3.3.3 (This Specification number is not used.)

NPF-73  
INSTRUMENTATION

3/4.3.3.4 (This Specification number is not used.)

BASES

---

3/4.3.3.3 (This Specification number is not used.)

3/4.3.3.4 (This Specification number is not used.)

3/4.3.3.5 REMOTE SHUTDOWN INSTRUMENTATION

The OPERABILITY of the remote shutdown instrumentation ensures that sufficient capability is available to permit shutdown and maintenance of HOT STANDBY of the facility from locations outside of the control room. This capability is required in the event control room habitability is lost and is consistent with General Design Criteria 19 of 10 CFR 50.

3/4.3.3.6 (This Specification number is not used).

3/4.3.3.7 CHLORINE DETECTION SYSTEMS

The OPERABILITY of the chlorine detection systems ensures that sufficient capability is available to promptly detect and initiate protective action in the event of an accidental chlorine release. This capability is required to protect control room personnel and is consistent with the recommendations of Regulatory Guide 1.95, "Protection of Nuclear Power Plant Control Room Operators Against an Accidental Chlorine Release," January 1977.



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION  
RELATED TO AMENDMENT NOS. 228 AND 107 TO FACILITY OPERATING  
LICENSE NOS. DPR-66 AND NPF-73  
PENNSYLVANIA POWER COMPANY  
OHIO EDISON COMPANY  
THE CLEVELAND ELECTRIC ILLUMINATING COMPANY  
THE TOLEDO EDISON COMPANY  
FIRSTENERGY NUCLEAR OPERATING COMPANY  
BEAVER VALLEY POWER STATION, UNIT NOS. 1 AND 2  
DOCKET NOS. 50-334 AND 50-412

1.0 INTRODUCTION

By letter dated May 27, 1999, the Duquesne Light Company (DLC) submitted a request for changes to the Beaver Valley Power Station, Unit Nos. 1 and 2 (BVPS-1 and 2), Technical Specifications (TSs). The requested changes would relocate the seismic monitoring instrumentation requirements contained in TS 3/4.3.3.3 to the Licensing Requirements Manual (LRM) based on the guidance provided in Generic Letter (GL) 95-10, "Relocation of Selected Technical Specifications Requirements Related to Instrumentation." The Bases section for Specification 3/4.3.3.3 will also be relocated to the LRM. The appropriate Index pages, Table Index page (Unit No. 1 only), TS pages and Bases pages will be revised to reflect the removal of the seismic monitoring instrumentation specification from the TSs. An additional specification page will be added to reflect that TS Number 3/4.3.3.4 is not used. This additional page will also denote the number of the following page. The Bases section will also be modified to denote that TS Number 3/4.3.3.4 is not used.

On the date of the May 27, 1999, letter, DLC was the licensed operator for BVPS-1 and BVPS-2. On December 3, 1999, DLC's ownership interests in both BVPS-1 and BVPS-2 were transferred to the Pennsylvania Power Company, and DLC's operating authority for BVPS-1 and BVPS-2 was transferred to FirstEnergy Nuclear Operating Company (FENOC). By letter dated December 13, 1999, FENOC requested that the Nuclear Regulatory Commission (NRC) continue to review and act upon all requests before the Commission which had been submitted by DLC.

## 2.0 BACKGROUND

Per GL 95-10, licensees were allowed to request a license amendment to relocate selected instrumentation requirements from their TSs. Licensees that decided to follow GL 95-10 were asked to submit license amendment requests to relocate the affected TSs.

GL 95-10 addresses the relocation of selected TS requirements related to instrumentation as a result of applying the 10 CFR 50.36 criteria (specifies criteria that TS sections should address). The NRC staff determined that, in accordance with the 10 CFR 50.36 criteria, several specifications did not warrant inclusion in the TSs. The staff also concluded that the instrumentation addressed by these specifications is not related to dominant contributors to plant risk. The TS for seismic monitoring instrumentation represented one of several entities which were recommended for relocation to licensee-controlled documents.

## 3.0 EVALUATION

The relocation of the seismic requirements to the LRM may be viewed as a two-fold process which calls for: (1) the deletion of the information as found in said seismic TSs from the plant TSs, and (2) the addition of said information to the LRM. In order to carry out the relocation of the seismic requirements, the licensee submitted proposed revisions to the plant TSs.

- 3.1. The licensee proposes that: (1) the Seismic Monitoring Instrumentation requirements, TS 3/4.3.3.3, for BVPS-1 and 2, and (2) the Bases section for TS 3/4.3.3.3, for BVPS-1 and 2, be relocated from the plant TSs to the LRM.

### Unit 1

The licensee proposes that TS 3/4.3.3.3 (located on page 3/4 3-38) and its associated tables, Table 3.3-7 (located on page 3/4 3-39), "Seismic Monitoring Instrumentation," and Table 4.3-4 (located on page 3/4 3-40), "Seismic Monitoring Instrumentation Surveillance Requirements," be relocated from the TSs to the LRM.

The licensee proposes that the Bases section (located on page B3/4 3-2) which corresponds to TS 3/4.3.3.3 be relocated from the TSs to the LRM.

### Unit 2

The licensee proposes that TS 3/4.3.3.3 (located on page 3/4 3-46) and its associated tables, Table 3.3-7 (located on page 3/4 3-37), "Seismic Monitoring Instrumentation," and Table 4.3-4 (located on page 3/4 3-48), "Seismic Monitoring Instrumentation Surveillance Requirements," be relocated from the TSs to the LRM.

The licensee proposes that the Bases section (located on page B3/4 3-11) which corresponds to TS 3/4.3.3.3 be relocated from the TSs to the LRM.

Seismic monitoring instrumentation is not used to detect degradation of the reactor coolant pressure boundary; it is not a process variable, design feature, or operating restriction that is an initial condition of a design basis accident or transient analysis; it performs no protective functions assumed in a safety analysis to mitigate a design basis accident or transient; and there is no operating experience or probabilistic risk assessment which shows it to be significant to public health and safety. Therefore, seismic monitoring instrumentation does not meet any of the four criteria specified in 10 CFR 50.36(c)(2)(ii) regarding items for which a limiting condition for operation must be established. Hence, it is acceptable to relocate these TS requirements to the LRM. Such a relocation of these requirements is consistent with the guidance of GL 95-10.

- 3.2 The following revisions proposed by the licensee are editorial in nature and correspond to the proposed relocation of the seismic monitoring instrumentation requirements from the TSs to the LRM.
- 3.2.1 The licensee requests that the appropriate Index pages, TS pages, and Bases pages, for BVPS-1 and 2, be revised to reflect the removal of the seismic monitoring instrumentation requirements from the TSs.

#### Unit 1

##### Index Pages

Index pages IV, X, and XVI are revised to delete references to TS 3/4.3.3.3 and the associated Tables 3.3-7 and 4.3-4.

##### Technical Specification Pages

TS page 3/4 3-38 is revised to state, "3.4.3.3.3 This Specification number is not used."

TS page 3/4 3-39 is revised not only to remove Table 3.3-7 but also to state that TS number 3/4.3.3.4 is not used, and to indicate that the next page is 3/4 3-44.

TS page 3/4 3-40 is deleted.

##### Bases Pages

Bases page B 3/4 3-2 is revised to state: "3.4.3.3.3 This Specification number is not used."

#### Unit 2

##### Index Pages

Index pages IV and X are revised to delete references to TS 3/4.3.3.3



#### Technical Specification Pages

TS page 3/4 3-46 is revised to state: "3.4.3.3.3 This Specification number is not used."

TS page 3/4 3-47 is revised not only to remove Table 3.3-7 but also to state that TS number 3/4.3.3.4 is not used, and to indicate that the next page is 3/4 3-52.

TS page 3/4 3-48 is deleted.

#### Bases Pages

Bases page B 3/4 3-11 is revised to state: "3.4.3.3.3 This Specification number is not used."

The licensee's proposed TS modifications which will relocate the seismic monitoring instrumentation requirements to the LRM as well as the corresponding editorial changes, as detailed above, have been found acceptable by the NRC staff.

#### 4.0 SUMMARY

The NRC staff reviewed the licensee's submittal which addresses relocation of the seismic monitoring instrumentation requirements contained in TS 3/4.3.3.3, and editorial changes, per GL 95-10. The staff also reviewed the request pertaining to TS 3/4.3.3.4. Based on its review, the NRC staff finds the proposed TS changes acceptable.

#### 5.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Pennsylvania State official was notified of the proposed issuance of the amendments. The State official had no comments.

#### 6.0 ENVIRONMENTAL CONSIDERATION

The amendments change requirements with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20 and change surveillance requirements. The NRC staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendments involve no significant hazards consideration, and there has been no public comment on such finding (64 FR 35203). Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

## 7.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributors: D. Spaulding  
D. Collins

Date: February 28, 2000