



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

March 1, 2000

Mr. Robin DeLaBarre
Non-proliferation/Nuclear Energy Affairs (NP/NEA)
U.S. Department of State
Washington, DC 20520

Dear Mr. DeLaBarre:

Enclosed is an application for a license (XCOM1135) recently received by the Nuclear Regulatory Commission, for the export of two pusher type furnaces for sintering of UO₂ pellets, plus spare and replacement parts, for use in a fuel fabrication facility in China.

Before taking action on this request, we would appreciate your views, in accordance with established procedures and from the overall perspective of the Executive Branch, as to whether the requested export meets the applicable criteria in the Atomic Energy Act of 1954, as amended.


Sincerely,

Ronald D. Hauber, Deputy Director
Office of International Programs

Enclosure: Appl. dtd. 2/24/00
(XCOM1135-China)

cc w/enclosure: M. Krupa, DOE
A. Welichozkiy, DOE
W. Witter, DOD
S. Clagett, DOC

DFO3

NRC FORM 7 (3-94) 10 CFR 110		U.S. NUCLEAR REGULATORY COMMISSION			APPROVED BY OMB: NO. 3150-0027 EXPIRES: 3-31-97									
APPLICATION FOR LICENSE TO EXPORT NUCLEAR MATERIAL AND EQUIPMENT <i>(See Instructions on Reverse)</i>							ESTIMATED BURDEN PER RESPONSE TO COMPLY WITH THIS INFORMATION COLLECTION REQUEST: 1.7 HOURS. THIS MANDATORY SUBMITTAL IS REVIEWED TO ENSURE THAT THE APPLICABLE STATUTORY, REGULATORY, AND POLICY CONSIDERATIONS ARE SATISFIED. FORWARD COMMENTS REGARDING BURDEN ESTIMATE TO THE INFORMATION AND RECORDS MANAGEMENT BRANCH (T-8F33), U.S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, DC 20555-0001, AND TO THE PAPERWORK REDUCTION PROJECT (3150-0027), OFFICE OF MANAGEMENT AND BUDGET, WASHINGTON, DC 20503.							
1. APPLICANT'S USE		a. DATE OF APPLICATION		b. APPLICANT'S REFERENCE			2. NRC USE		a. DOCKET NUMBER		b. LICENSE NUMBER			
		Feb. 24, 2000							11005192		XCOM1135			
3. APPLICANT'S NAME AND ADDRESS							4. SUPPLIER'S NAME AND ADDRESS							
a. NAME Harper International Corporation							(Complete if applicant is not supplier of material)							
b. STREET ADDRESS (Facility Site)							a. NAME							
West Drullard Ave.														
c. CITY			d. STATE		e. ZIP CODE		b. STREET ADDRESS							
Lancaster			NY		14086-1698									
f. TELEPHONE NUMBER (Area Code - Number - Extension)							c. CITY			d. STATE		e. ZIP CODE		
716-684-7400 Ext. 179														
5. FIRST SHIPMENT SCHEDULED		6. FINAL SHIPMENT SCHEDULED		7. APPLICANT'S CONTRACTUAL DELIVERY DATE			8. PROPOSED LICENSE EXPIRATION DATE		9. U.S. DEPARTMENT OF ENERGY CONTRACT NO. (If known)					
Aug 1, 2000		Feb 1, 2001		August 1, 2000			Sept 1, 2005		N/A					
10. ULTIMATE FOREIGN CONSIGNEE							11. ULTIMATE END USE					USE CODE		
a. NAME Boston Nuclear Element Plant China Nuclear Energy Industry Corp.							(include plant or facility name) Fuel fabrication facility							
b. STREET ADDRESS (Facility Site)							11a. DATE REQUIRED							
P.O. Box 456							Aug 1, 2000							
c. CITY			d. COUNTRY				13. INTERMEDIATE END USE					USE CODE		
Boston, Inner Mongolia			Rep. of China											
12. INTERMEDIATE FOREIGN CONSIGNEE							13a. DATE REQUIRED							
a. NAME														
N/A														
b. STREET ADDRESS							15. INTERMEDIATE END USE					USE CODE		
c. CITY			d. COUNTRY				15a. DATE REQUIRED							
14. INTERMEDIATE FOREIGN CONSIGNEE							15. INTERMEDIATE END USE					USE CODE		
a. NAME														
N/A														
b. STREET ADDRESS (Facility Site)							16a. DATE REQUIRED							
c. CITY			d. COUNTRY											
18. COM CODE		17. DESCRIPTION					18. MAX. ELEMENT WEIGHT		19. MAX. WT. %		20. MAX. ISOTOPE WEIGHT		21. UNIT	
		(Include chemical and physical form of nuclear material; give dollar value of nuclear equipment and components)					N/A		N/A		N/A		N/A	
		Two (2) pusher type furnaces for sintering of UO ₂ pellets plus spare and replacement parts. Approximate dollar value of equipment \$1,320,000.00												
22. COUNTRY OF ORIGIN - SOURCE MATERIAL			23. COUNTRY OF ORIGIN - ENRICHED OR PRODUCED			24. COUNTRIES WHICH ATTACH SAFEGUARDS (If known)								
N/A			N/A			95% U ²³⁵ 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 00								
25. ADDITIONAL INFORMATION ON CONSIGNEES, END USES, AND PRODUCT DESCRIPTION (Use separate sheet if necessary)													RECEIVED OIP	
See attached sheet.														
26. The applicant certifies that this application is prepared in conformity with Title 10, Code of Federal Regulations, and that all information in this application is correct to the best of his/her knowledge.														
27. AUTHORIZED OFFICIAL			a. SIGNATURE						b. TITLE					
									Vice President					

**SUPPLEMENTAL INFORMATION FOR NRC FORM 7
APPLICATION FOR LICENSE TO EXPORT
NUCLEAR MATERIAL AND EQUIPMENT
BY
HARPER INTERNATIONAL CORPORATION**

Item 10.

Baotou Nuclear Element Plant
China Nuclear Energy Industry Corporation
P.O. Box 456
Baotou, Inner Mongolia
People's Republic of China

Item 11.

Sintering of UO₂ pellets at the China Nuclear Energy Industry Corporation,
Baotou Nuclear Material Plant.

Item 11a.

August 1, 2000

Item 17.

Quantity of two (2) pusher type furnaces for sintering of UO₂ pellets. Pellets for subsequent use in civilian nuclear power plant. Approximate dollar value of equipment is \$13,20,000.

Item 25.

Refer to attached process and production parameters and summary of equipment specifications attached and Importer Statement on End-User and End-Use verified by Department of Science and Technology of Ministry, MOFTEC, People's Republic of China.

JAECKLE FLEISCHMANN & MUGEL, LLP
ATTORNEYS AT LAW

FLEET BANK BUILDING TWELVE FOUNTAIN PLAZA BUFFALO, NEW YORK 14202-2292
TEL (716) 856-0600 FAX (716) 856-0432

PETER G. KLEIN
Partner

Direct Dial: (716) 843-3857

February 24, 2000

VIA FEDEX

United States Nuclear Regulatory Commission
Office of International Programs
Mail Stop 04E9
11555 Rockville Pike
Rockville, MD 20852-2738

Re: Submission of NRC Form 7

Dear Sir or Madam:

I enclose the Application for License to Export Nuclear Material and Equipment on NRC Form 7 made by Harper International Corporation, for the export of nuclear equipment comprising pusher type furnaces for sintering of UO₂ pellets to the People's Republic of China. In conversations with Ms. Betty Wright of the NRC Division of Non-Proliferation, Exports and Multilateral Relations, I was informed that this application required Executive review and hence the filing fee would be \$5,600 under Category K.2. on the Schedule to 10 CFR 170.21. Accordingly, I enclose a check for that amount payable to "U.S. Nuclear Regulatory Commission".

However, it appears that the instant application more properly should be considered under 10 CFR 110.42(b) as this equipment is not for a production or utilization facility but rather is of the type stated in 10 CFR 110.8(e). This would mean that Executive review would not be required and that the appropriate filing fee would be either \$1,700 or \$1,100 under Category K.3. or K.4. under the Schedule to 10 CFR 170.21. If you concur, kindly issue an appropriate refund in the name of Harper International Corporation which should be sent to my attention.

2000 FEB 28 AM 7:56

RECEIVED OIP

United States Nuclear Regulatory Commission
Office of International Programs
February 24, 2000


Page 2

Please contact the undersigned should you require anything further.

Very truly yours,

JAECKLE FLEISCHMANN & MUGEL, LLP

By


Peter G. Klein

PGK/rad

Enclosures


cc: Mr. Charles W. Miller, Jr.
Mr. Thomas Haggerty

December 9, 1999

Harper Confidential Information

Contract Specifications
for
Baotou Nuclear Fuel Plant
P.R. China

HARPER



INTERNATIONAL

HARPER Tunnel Kiln Thermal System

Model No. MG-12677-PTKA-20-PR-EDD

HARPER Reference No. 961010-3

December 9, 1999

HARPER INTERNATIONAL CORPORATION

West Drullard Avenue

Lancaster, New York 14086
USA



12/9/99

December 9, 1999

*Harper Confidential Information***TABLE OF CONTENTS**

1.0	<u>INTRODUCTION</u>	1
	HARPER's Background, Facilities and Capabilities	1
2.0	<u>CODES AND STANDARDS</u>	2
	2.1 Basic Design and Fabrication Codes	2
	2.2 General	2
3.0	<u>HARPER SERVICES</u>	3
	3.1 Inspection by Purchaser's Representative	3
	3.2 Training of Purchaser's Personnel	3
	3.3 Supervision, Installation and/or Startup	3
	3.4 Turnkey Installation	4
	3.5 Spare & Replacement Parts	4
4.0	<u>PROCESS AND PRODUCTION PARAMETERS</u>	
	4.1 Process Description	5
	4.2 Process Material	5
	4.3 Process Containers, Fixtures, Furniture, Etc.	5
	4.4 Load or Charge Description	5
	4.5 Process Requirements	6
	4.6 Production Requirements	6
	4.7 NOTE	6
5.0	<u>SCOPE OF SUPPLY</u>	
	As proposed by HARPER INTERNATIONAL CORPORATION	7
	5.1 HARPER Tunnel Kiln Thermal System	7
	5.2 Additional Options Quoted	7
	5.3 Documentation	7
	5.4 Purchaser's Responsibilities	8
6.0	<u>SUMMARY OF EQUIPMENT SPECIFICATIONS</u>	9

2


 A handwritten signature and the date 12/9/99.

December 9, 1999

Harper Confidential Information

6.1	HARPER Model MG-12677-PTKA-20-PR-EDD	9
6.2	Power System, Proportional	9
6.3	Temperature Control System	14
6.4	Additional Options Quoted	15
6.5	Services and Utilities Required.....	15
7.0	<u>GENERAL SPECIFICATIONS FOR HARPER EQUIPMENT</u>	17
7.1	Manufacturing	17
7.2	Painting	17
7.3	Piping	17
7.4	Wiring	18
7.5	Quality Assurance	18
7.6	Shipping Preparations	18
7.7	Shipment Policy	18
8.0	<u>INVESTMENT</u>	19
8.1	<u>HARPER Model MG-12677-PTKA-20-PR-EDD</u>	19
8.2	<u>Power Systems Proportional</u>	19
8.3	<u>PC Temperature Control Systems</u>	19
8.4	<u>Additional Items Included</u>	19
8.5	<u>Spare Parts List</u>	19
8.6	<u>Training at Harper</u>	19
8.7	<u>Start-up Supervision</u>	19
8.8	<u>CIF Tianjin Shipment</u>	19
8.9	<u>Portable Oxygen Monitor</u>	19
9.0	<u>SCHEDULES</u>	20
9.1	Shipment Schedule	20
9.2	Proposal Validity	20
9.3	Terms of Payment	20
9.4	Export Fees and Charges	20
10.0	<u>TERMS AND CONDITIONS OF SALE</u>	Attached
11.0	<u>PURCHASER'S DATA SHEETS</u>	Attached

2


 A handwritten signature and the date 12/9/99 are located in the bottom right corner of the page.

BaoTao Nuclear Fuel Plant
P.R. China

Page

HARPER Reference No. 961010-3

December 9, 1999

Harper Confidential Information

4.0 PROCESS AND PRODUCTION PARAMETERS

- 4.1 Process Description Sintering
- 4.2 Process Material Uranium Oxide Fuel Pellets for
Candu style fuel
- 4.3 Process Containers, Fixtures, Furniture, Etc.

All of the listed data below was used in our assumption for sizing.

- 4.3.1 Container Molybdenum bent sheets (i.e
separators)
- Material Molybdenum
- Dimensions
- | | | |
|-----------------|--------|-------------|
| Width | 280 mm | 11 inches |
| Length | 133 mm | 5.25 inches |
| Thickness | 1 mm | .040 inches |
- 4.3.2 Fixtures and/or Furniture Molybdenum bent sheets
- 4.3.3 Pusher Plate Per HARPER Recommendation
- Material Molybdenum
- Dimensions
- | | | |
|-----------------|--------|-----------|
| Width | 305 mm | 12 inches |
| Length | 305 mm | 12 inches |
| Thickness | 16 mm | .625 inch |

4.4 Load or Charge Description

The following is a description of the individual load or charge being processed.

4.4.1 Dimensions, Overall

Width	305 mm	12 inches
Length	305 mm	12 inches
Height	153 mm	6.0 inches

2

12/9/99

BaoTao Nuclear Fuel Plant
P.R. China

Page

HARPER Reference No. 961010-3

December 9, 1999

Harper Confidential Information

4.4.2 Loading per Pusher Plate

Separators are placed on the pusher slab, 2 per layer, and stacked to a maximum 8 layers high. This gives a maximum boat capacity of 1344 pellets.

4.5 Process Requirements

- 4.5.1 Atmosphere Hydrogen
- 4.5.1.1 Dewpoint - 20.6°C - 5°F
- Temperatures Per sample below

4.5.2.1 Zone Profiles


The following are the design operating profiles, as measured by the zone thermocouples, for normal operation. The actual product temperature in each zone will be a function of furnace operating techniques. Based on experience and sound design practice, Harper International expects the product to achieve and be at the temperatures stated through most of the zone lengths.

Zone 1	750 °C to 900 C
Zone 2	750 °C to 900 C
Zone 3	1650 °C to 1750 C
Zone 4	1650 °C to 1750 C
Zone 5	1650 °C to 1750 C

4.6 Production Requirements

Hourly 20 to 24 kg/hr

4.7 NOTE: The proposed HARPER Thermal System is based upon the above information. Further customer discussion will be required to verify that this information and the requirements specified are correct.

December 9, 1999

*Harper Confidential Information***6.0 SUMMARY OF EQUIPMENT SPECIFICATIONS**

The proposed HARPER Thermal System shall have the following overall specifications.

6.1 HARPER Model MG-12677-PTKA-20-PR-EDD Tunnel Kiln

The proposed heating equipment shall be designed and fabricated to process material and carriers of the size, weight and configuration described in Section 4.

The proposed tunnel kiln shall consist of the following major sections and assemblies:

6.1.1 General Configuration

The kiln shall consist an entrance purge chamber, pre-heat section, high heat section, insulated cooling section, water-jacketed cooling section, exit chamber, exit purge chamber, and a material handling system. The latter does not include a return conveyor.

The kiln shall be designed and fabricated for operation under a controlled atmosphere at temperatures up to a maximum of 1800°C.

6.1.2 Entrance Purge Chamber

Material of Construction	Carbon steel
Door Locations	
Entrance Door	Right-hand side of chamber
Door Operation	Pneumatic
Flame Seal system.....	Included

6.1.3 Preheat Chamber (Zones 1 and 2)

The preheat section will incorporate a high temperature alloy muffle to effectively handle the burn-off of binders from the product. A high temperature bellows is employed to accommodate thermal expansion of the muffle assembly.

6.1.3.1 Thermal Control Zones

Number Of Individual Control Zones	Two (2)
Nominal Length of Zones(ea)	762 mm 30 inches
Nominal Length Total.....	1524 mm 60 in
Temperature Rating	900°C Maximum

6.1.3.1.1 Heat Sources

Type	NiCr resistance elements
Number of Elements	To be determined at final design

6.1.3.1.2 Thermal Insulation

December 9, 1999

Harper Confidential Information

Type Insulating Fire Brick

6.1.3.1.3 Thermocouples There shall be provisions for a dual-type thermocouple through the approximate center of the sidewall in the control zone

6.1.4 Heating Chamber (Zones 3 through 5)

In order to achieve optimum temperature uniformity within the process load space, the heating chamber shall be designed with sufficient room over, under and on both sides of the load for excellent cross-radiation and reflection of heat.

6.1.4.1 Thermal Control Zones

Number Of Individual Control Zones	Three (3)	
Length Zone -3	762.0 1117 mm	30 inches
Length Zone -4	546.1 775 mm	21.5 inches
Length Zone -5	546.1 775 mm	21.5 inches
Baffles	76 mm / 3 inches thick between each control zone for good temperature control	

2 *12/9/99*

Temperature Rating 1800°C Maximum

6.1.4.1.1 Heat Sources

Type Molybdenum resistance elements
Location of Elements Side walls

6.1.4.1.2 Thermal Insulation

Type 99.8% alumina hot face brick
Insulation Thickness, Nominal 368 mm 14.5 inches

High alumina insulation shall be used for the inner "hot" lining of the heating chambers to resist the effects of the reduction of silica from the use of a hydrogen atmosphere at elevated chamber temperatures.

6.1.4.1.3 Load Supporting Hearths Alumina, high purity

6.1.4.1.4 Thermocouples There shall be provisions for a single thermocouple through the approximate center of the roof in each control zone

2

12/9/99

BaoTao Nuclear Fuel Plant
P.R. China

Page

HARPER Reference No. 981010-3

December 9, 1999

*Harper Confidential Information***6.1.5 Insulated Cooling Section**

The insulated cooling section shall be provided with 2-stage insulation to achieve a gradually increasing level of product cooling in order to minimize thermal shock.

6.1.5.1 1st Stage Insulated Cooling

Thermal Insulation, 1st Stage high alumina hot face

6.1.5.2 2nd Stage Insulated Cooling

Thermal Insulation, 2nd Stage high alumina hot face

6.1.5.3 Insulated Cooling Section Length

Length of 1 st Stage	406 mm	16 inches
Length of 2 nd Stage	457 mm	18 inches
Total Length of Insulated Cooling Section	864 mm	34 inches

6.1.6 Water-Jacketed Cooling Section

The final cooling stage shall be water-jacketed to reduce the product temperature to a satisfactory level before discharge into the room environment.

Material of Construction	Carbon steel
Refractory Hearth	Included
Material	Alumina, high purity
Total Length of Water-Jacketed Cooling Section	1803 mm 71 inches

6.1.7 Exit Chamber

Material of Construction Carbon steel

6.1.8 Exit Purge Chamber

Material of Construction	Carbon steel
Door Locations	
Exit Door	Right-hand side parallel to the centerline of the kiln tunnel
Door Operation	Pneumatic
Flame Seal system.....	Included

6.1.9 Material Handling

The pusher plates with their process material shall be automatically loaded into the entrance chamber, pushed through the kiln at a preset speed, and finally discharged from the exit chamber. Operation of the entrance and exit doors shall also be controlled automatically. The Purchaser shall be responsible for providing the mechanisms required to feed the raw

BaoTao Nuclear Fuel Plant
P.R. China

Page

HARPER Reference No. 961010-3

December 9, 1999

Harper Confidential Information

product into position to be loaded into the kiln, and to remove the fired process material from the exit end discharge position.

6.1.9.1	Entrance Loading Pusher	
	Type of Pusher Mechanism	Mechanical, roller chain and sprocket, fixed speed
6.1.9.2	Main Pusher	
	Type of Pusher Mechanism	Heavy duty ball screw with parallel ball bushing guides rods
	Operation	Adjustable, variable-speed pusher. High-speed approach & retract. SCR controlled DC drive motor and speed reducer combination
	Speed, Nominal Effective Mid-range	Nominal 12"/hr
	Pusher Safety Overload Device	Approx. Range 2"/hr to 20"/hr. Included
6.1.9.3	Exit Cross Pusher	
	Type of Pusher Mechanism	Mechanical, roller chain and sprocket, fixed speed
6.1.9.4	Exit Discharge Pusher	
	Type of Pusher Mechanism	Mechanical, roller chain and sprocket, fixed speed
6.1.9.5	Automation Control	
6.1.9.5.1	Graphic Status Display	Designed to provide a visual indication of electro-mechanical pusher devices within the Windows PC based system
6.1.9.5.2	Process Logic Controller (PLC)	Texas Instruments 545 Series (or equal)
6.1.9.5.3	Location	Temperature control cubicle See Section 6.3 below
6.1.10	<u>Cooling Water System</u>	

The kiln shall be equipped with a complete cooling water distribution and drain system with individual flow control valves for each cooling circuit. The drain shall consist of one or more open, gravity receptacles. The latter provide unrestricted release of any steam pressure re-

December 9, 1999

Harper Confidential Information

suiting from a water supply failure. Open drains receptacles also facilitate the measurement of effluent water flow rates and temperatures.

6.1.11 Atmosphere System

The kiln shall be equipped with a complete atmosphere distribution system. Inclusive with the package are individual flowmeters for each atmosphere inlet into the kiln. The system shall also include appropriate pressure regulators and gauges for both gases.

The system shall include a safety shut-off valve in the hydrogen input line together with a provision to replace the hydrogen flow with nitrogen in the event of a hydrogen supply failure, loss of electrical service, or a loss of adequate hydrogen supply pressure.

A humidifier is included to humidify the process gas delivered to the main tunnel inlet.

The atmosphere system shall be mounted, piped and wired on a separate, free-standing, open backed panel.

6.1.12 Tunnel Kiln Dimensions, Overall Approximate

Width	2400 mm	8 ft	
Height	2100 mm	7 ft	
Length	Approximately	13m	(To be confirmed)

Refer to General Arrangement Drawing #S-961010-03

6.2 Power System, Proportional

The power system shall be mounted and wired by HARPER in the base of the tunnel kiln, complete with all interconnecting wiring to the heating element terminals. The system shall include all circuit breakers, switches, ammeters, fusing, etc., necessary for a safe, reliable and responsive system.

6.2.1 Power System Configuration

Zone 1 & 2(Preheat two zones)	SCR/Transformer
Zones 3 through 5 (High Heat).....	SCR/Transformer

6.2.2 Power System Rating

Zone 1 & 2	12 kVA (to be confirmed upon final design)
Zones 3 through 5	35 kVA (to be confirmed upon final design)
Total Connected Load	130 kVA (to be confirmed upon final design)

BaoTao Nuclear Fuel Plant
P.R. China

Page

HARPER Reference No. 961010-3

December 9, 1999

Harper Confidential Information

6.3 PC Based Temperature Control System

Complete kiln control, monitoring, and temperature data acquisition is provided to the customer. This system will be mounted and wired by HARPER within a separate, free-standing enclosure together with all required relays, switches, status lights, alarms, etc. Thermocouples and leadwire shall also be provided as a part of the system.

- 6.3.1 Control Cubicle Nema 12, free-standing with cubicle power disconnect switch
- 6.3.2.1 PC: Human Machine Interface Pentium based PC with Windows operating system, 17" Color Monitor and large capacity hard drive.

6.3.2.2 Harper's Total Thermal Processing System

The following capabilities are enabled through the PC:

- Temperature Control Set Points
- Atmosphere System Display
- Materials Handling Display
- Display temperatures, target and measured values
- Supervisory Control
- Complete Data Acquisition, Trending and display
- Alarm Display and Record

6.3.3 Thermocouples and Leadwire

6.3.3.1 Thermocouples

- Zone 1 & 2 One (1) Type "K", dual element thermocouple with alloy protection tube per each zone
- Zones 3 through 5 One (1) Type C thermocouple per zone for temperature control. One (1) Type "C" thermocouple with molybdenum protection tube per zone for overtemperature protection.

6.3.3.2

Leadwire

15 meters 49.2 ft
per each thermocouple element.

BaoTao Nuclear Fuel Plant
P.R. China

Page

HARPER Reference No. 961010-3

December 9, 1999

Harper Confidential Information

6.4 Additional Items Included

6.4.1 Spare Parts

Although HARPER makes every effort to maintain a stock of the most commonly requested spares, the diversity of components used in our equipment does not allow us to stock replacements for all components. Therefore, in order to minimize the likelihood of start-up delays or subsequent extended production stoppages, we recommend that you maintain an on-site stock of selected spares for your HARPER EQUIPMENT. The following preliminary list represents parts that will be supplied with the equipment. A complete list with pricing will be supplied on completion of the final design of the equipment.

The following quantities of components will be supplied with the contract:

- One(1) Preheat nickel-chromium heating elements
- Two (2) Firing molybdenum heating elements
- One (1) Preheat SCR
- One (1) Firing SCR
- Two (2) Dual Type "K" T/C
- Two (2) Single Type "C" T/C
- One (1) Preheat Temp Controller
- Two (2) Firing Temp Controller
- Two (2) Hearth Tiles
- One (1) Miscellaneous Fuse Kit
- One (1) High Temperature Gasket Kit

6.4.2 Customer Training at Harper International

HARPER shall train client's personnel in general maintenance and operation of the kiln system. The package includes all travel to and from Beijing and living expenses for four (4) persons of the client's selection for two (2) weeks at Harper International's Lancaster, New York plant site.

6.4.3 Start-Up Supervision

The HARPER Technician shall test all equipment systems and "fine tune" them to ensure that they are functioning smoothly and properly. Our Supervisor shall also oversee the purging (when required) and the dryout of the heating equipment. Purging involves the removal of all residual air from the interior of the heating equipment and its thermal insulation. Dryout is the process of slowly removing residual moisture from the thermal insulation. Purging (when required) and dryout are essential for successful long-term operation of the equipment. While some of these operations must be performed sequentially, others may be performed simultaneously. Our quoted price includes two (2) trips each for two (2) weeks to accomplish above. The client is responsible to provide transportation to and from the work site as well as ~~living accommodations~~ during the work.

6.5 Service and Utilities Required

2

12/9/99

BaoTao Nuclear Fuel Plant
P.R. China

Page

HARPER Reference No. 961010-3

December 9, 1999

Harper Confidential Information

The following services and utilities are required for the proper operation of the proposed HARPER Thermal System:

6.5.1 Electric Power Requirements

Primary Power Supply	380 volts, 50 hz, 3 phase
Connected Load, Total	To be confirmed upon final Design
.....	

6.5.2 Atmosphere Requirements

Type of Atmosphere	H ₂	
Quality, Dew Point	-20.6°C	- 5°F
Supply Pressure at Equipment Site	0.35 kg/cm ²	5 psi
Flow Capacity, Combined Maximum	28.3 cmh	1000 scfh
Purge Gas	N ₂	
Quality, Oxygen and water vapor	< 5 ppm	
Supply Pressure at Equipment Site	0.35 kg/cm ²	5 psi
Flow Capacity, Combined Maximum	56.6 cmh	2000 scfh

6.5.3 Compressed Air Requirements

Supply Pressure	5.0 kg/cm ²	<i>12/9/99</i>
Usage	7.03 kg/cm² 100 psi	
	Nominal	

6.5.4 Cooling Water

Quality	Filtered	
Supply Pressure	2.81 kg/cm ²	40 psi
Flow Capacity Recommended, Minimum	7.6 lpm	2 gpm

Note: The cooling water flow rate specified above is based upon operation at maximum rated temperatures and production levels. It is further based upon a nominal 22°C (40°F) water temperature rise together with ideal theoretical heat transfer. Water discharge temperature should not exceed 54°C (130°F) in any water-cooled circuit.

Note:

The details and dimensions specified above are subject to minor revisions upon completion of the final design.

TO: Chuck Miller

JACK Feb. 17/2000. 最终用户和最终用途说明 N° 0003210 B


IMPORTER STATEMENT ON END-USER AND END-USE

序号 Serial No.	000097	出口国别 Country of Exporter	United States
合同类别 Title of Contract	Purchase Contract		
合同号 Contract No.	99CMAE/JF48202US	签字日期 Date of Sign.	Dec. 9, 1999
进口商名称 Name of Importer	China Nuclear Energy Industry Corporation		
出口商名称 Name of Exporter	Harper International Corporation		
最终用户 End-user	Baotou Nuclear Fuel Element Plant		
最终用途 End-Use	Sintering CANDU Fuel Pellet for the use of Nuclear Power Plant		
说明 Statement	<p>下列商品用于中华人民共和国，不向第三国转口 The commodities listed below is for use in the People's Republic of China and not for re-export to the third country</p> <p style="text-align: right;">进口商签字盖章 Signature and Seal by the Importer 日期 Date 2000.01.25</p>		
序号 No.	商品名称 Commodities and Descriptions	数量 Quantity	金额 Value
1	Harper Tunnel Kiln Thermal System MG-12677-PTKA-20-PR-EDD	2	USD.1,220,000.
		总金额 Total	USD.1,220,000.

上述最终用户最终用途说明业经对外贸易经济合作部科技发展和技术进出口司核实无误，特此证明。
This statement has been verified of the truthfulness of the enduser and enduse by Department of Science and Technology of Ministry of Foreign Trade and Economic Cooperation of the P. R. C.

盖

最终用户说明专用章



签字

刘海生

科技发展和技术进出口司
司长(副司长)

签署日期

000128