

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

February 22, 2000

United States Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D. C. 20555

Serial No. 00-090
NAPS/JHL
Docket Nos. 50-338
50-339
License Nos. NPF-4
NPF-7

Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY
NORTH ANNA POWER STATION UNIT NOS. 1 AND 2
ANNUAL SPECIFIC ACTIVITY REPORT

The results of specific activity analysis in which the primary coolant exceeded the limits of Technical Specification 3.4.8 are to be submitted on an annual basis pursuant to Technical Specification 6.9.1.5.c. There were no instances where the primary coolant exceeded 1.0 $\mu\text{Ci}/\text{gram}$ Dose Equivalent Iodine-131 or 100/E-bar $\mu\text{Ci}/\text{gram}$ during 1999.

If you have any questions or require additional information, please contact us.

Very truly yours,



W. R. Matthews
Site Vice President

cc: U. S. Nuclear Regulatory Commission
Region II
Atlanta Federal Center
61 Forsyth Street, SW, Suite 23T85
Atlanta, Georgia 30303

Mr. M. J. Morgan
NRC Senior Resident Inspector
North Anna Power Station

A001