

1. ALL EQUIPMENT AND INSTRUMENT NUMBERS ARE TO BE PRECEDED BY MPL D11, UNLESS OTHERWISE NOTED
2. DELETED
3. * FURNISHED WITH ASSOCIATED EQUIPMENT
4. ●●●● DENOTES ELECTRICAL HEAT TRACING.
5. THIS LINE TO BE ELECTRICALLY HEAT TRACED AND INSULATED WITH 1" FIBERGLASS INSULATION TO MAINTAIN A TEMP. OF 110° F.

REFERENCES

| TITLE | MPL NO | DWG NO |
|---|-----------|---------|
| 1. SCHEMATIC DIAGRAM POST ACCIDENT REACTOR COOLANT AND CONTAINMENT ATMOSPHERE SAMPLING SYSTEM | 2P33-1010 | H-26384 |
| 2. FISSION PRODUCTS MONITORING SYSTEM P.&I.D., SHEET NO. 2 | D11-1010 | H-16274 |
| 3. DELETED | | |
| 4. SAMPLE LINE ROUTING REACTOR & RADWASTE BLDG. BELOW EL. 130'-0" | | H-16553 |
| 5. SAMPLE LINE ROUTING REACTOR & RADWASTE BLDG. EL. 130'-0" | | H-16554 |
| 6. SAMPLE LINE ROUTING REACTOR & RADWASTE BLDG. EL. 158'-0" | | H-16556 |
| 7. DIGITAL INPUT SIGNALS TO THE ERF COMPUTER SYSTEM I.E.D. SHEET 2 OF 15 | X75-1010 | H-16404 |
| 8. PROCESS RADIATION MONITORING SYSTEM P.&I.D. SHEET 4. | | H-16566 |
| 9. PRIMARY CONTAINMENT ATMOSPHERE H'2 | | H-16276 |

LICENSE RENEWAL DOCUMENT

MPL NO. D11-1020 ACAD14 HL16173



LICENSE RENEWAL SCREENING FOR INFORMATION ONLY

EDWIN I. HATCH NUCLEAR PLANT UNIT No. 1 FISSION PRODUCTS MONITORING SYSTEM P&I.D. SHEET No. 1

Revisions: A Date: 1-5-2000 APPROVED, ISSUED PER LICENSE RENEWAL DOCUMENTS. DRAWING CREATED FROM H-16173, REV.11; BY TDM.

| DATE | BY | DESCRIPTION |
|--------|------|-------------|
| 10-502 | None | None |

BOUNDARY DIAGRAM NO.:1T23-B01-014
 FUNCTION(S) NO.: 1T23-01
 PREPARED BY: FAROOK CHANDIWALA
 DATE: 10/20/98
 REVIEWED BY: LARRY ORR
 DATE: 12/8/98

BOUNDARY DIAGRAM NO.:1P33-B01-03
 FUNCTION(S) NO.: 1P33-01
 PREPARED BY: ALEX MORRISON
 DATE: 3/9/98
 REVIEWED BY: ED DAVIDSON
 DATE: 5/27/98

