

1. ALL EQUIPMENT AND INSTRUMENT NUMBERS ON THIS DRAWING ARE PRECEDED BY MPL P52 UNLESS OTHERWISE NOTED. EXAMPLE: P52-F500.
2. ALL CHECK VALVES ARE SPRING LOADED LIFT CHECKS WITH HARD SEAT & SOFT DISC INSERT, WITH 1/2 LB. CRACKING PRESSURE.
3. ANNUNCIATORS FOR HIGH FLOW ALARMS & LOW PRESSURE ALARMS ARE LOCATED IN THE MAIN CONTROL ROOM.
4. IF AIR IS NOT AVAILABLE FROM THE COMPRESSORS, THE AIR RECEIVERS WILL SUPPLY AIR TO EVOLVE THE NON-INTERRUPTIBLE SERVICE VALVES TO MAKE UP VALVE AIR-OPERATOR LEAKAGE, & PROVIDE A MOTIVE AIR SOURCE.
5. LOW POINT DRAINS TO BE ADDED AS DETERMINED BY PHYSICAL ROUTING OF THE SYSTEM.
6. ALL INTERRUPTIBLE SERVICE VALVES ARE CONNECTED TO THE ASSOCIATED MAIN AS SHOWN IN DETAIL NO. 3.
7. PIPE OR TUBE DOWNSTREAM OF THE SPEC. CHANGE SHALL CONFORM TO SHEET 604 OF DWG. # A-11000 WHERE NOTED.
8. ALL LETTERS (A,B,C & D) & A.R. NUMBERS TO BE FOUND ON TABLE DWG. H-16251.
9. ITEM REFERRING TO THIS NOTE SHALL BE CONNECTED TO THE ADJACENT INTERRUPTIBLE AIR HEADER BY DETAIL NO. 3 OR 24 ON THIS PAID.
10. WHERE GV NO.'S ARE SHOWN, THE VALVES ARE TAGGED WITH THESE NO.'S, WHERE GV NO.'S ARE NOT SHOWN, THE VALVES ARE TAGGED WITH THE MPL NO.
11. MOTOR OPERATED VALVES ON NITROGEN BACK-UP SUPPLY LINES OPEN ON NON-INTERRUPTIBLE INST. AIR HEADER LOW PRESSURE.
12. FOR DETAILED INSTRUMENT AIR ROUTING SEE DWG. H-11867.
13. LOCATIONS & NUMBER OF UNITS VARY, SEE AS BUILT (ISOMETRIC) DWGS. FOR DETAILS.
14. ALTHOUGH NOT A DESIGN REQUIREMENT, THESE VALVES ARE CONNECTED TO AND SUPPLIED BY A NON-INTERRUPTIBLE AIR SUPPLY.

REFERENCES

REFERENCE	MPL NO.	S.S. NO.
1. REACTOR BLDG. INSTRUMENT AIR SYSTEM TABLES	P52-1020	H-16251 (SH. 1) H-11867 (SH. 2)
2. PIPING & INSTRUMENT SYMBOLS	A41-1010	S-15051
3. PLANT INSTRUMENT AIR SYSTEM DIAGRAM	P52-1010	H-11028
4. REACTOR BLDG. FLOOR & EQUIP. DRAINAGE DIAGRAM	T45-1020	H-16018
5. NITROGEN INERTING SYS.	T48-1010	H-16000
6. DRYWELL PNEUMATIC SYS.	P70-1010	H-16286
7. INSTRUMENT INSTALLATION DETAILS	A-16237	
8. PRIMARY CONTAINMENT ATMOSPHERE H ₂ & O ₂ ANALYZER SYSTEM P.&I.D.	P33-1010	H-16280
9. MISC. AIR INSTRUMENT SERVICE SYSTEM P51 AND P52 ELEMENTARY DIAGRAM		H-17092
10. TORUS DRAINAGE AND PURIFICATION SYSTEM P.&I.D. AND P.F.D.	G51-1010 G51-1020	H-16135
11. CONTROL ROD DRIVE SYSTEM P&I SHEET 2	C11-1010	H-16065

WORK THIS DRAWING WITH H-16251 AND H-11667.

LICENSE RENEWAL DOCUMENT

MPL NO. P52-1020 ACAD14 HL16239

SOUTHERN COMPANY

LICENSE RENEWAL SCREENING FOR INFORMATION ONLY

EDWIN H. HATCH NUCLEAR PLANT UNIT No. 1
REACTOR BUILDING INSTRUMENT AIR SYSTEM P.&I.D.

FORM	ISSUED	ISSUES	REVISIONS	DATE
TRM	TRM	TRM	TRM	TRM
TRM	TRM	TRM	TRM	TRM

10-502 HL-16239 A

Revisions: A [Date: 12-29-99]

APPROVED, ISSUED PER LICENSE RENEWAL BOUNDARY PACKAGES. DRAWING CREATED FROM H-16239, REV.32, BY JRM.

BOUNDARY DIAGRAM NO.:1T48-B01-04
FUNCTION(S) NO.: 1T48-01
 PREPARED BY: ED DAVIDSON
 DATE: 4/6/98
 REVIEWED BY: ALEX MORRISON
 DATE: 4/27/98

