

NOTES

- 2U43112W01 - ALL EQUIPMENT & INSTRUMENTS ARE PREFIXED WITH 2U43 UNLESS OTHERWISE NOTED.
- 2Z43112W13 - ALL EQUIPMENT & INSTRUMENTS ARE PREFIXED WITH 2Z43 UNLESS OTHERWISE NOTED.

LEGEND:

- PLUGGED CONNECTION
- 1/2" SPRINKLER HEAD (GRINNELL 1/2" SSU-3 DURASPEED 212°F)
- BREAK GLASS STATION
- SIDE OUTLET GLOBE VALVE
- BALL DRIFT VALVE
- ADDRESSABLE INTERFACE MODULE
- RESTRICTION CHECK VALVE
- ALARM VALVE
- RETARD CHAMBER
- PILOT HEAD (175°F)
- SPRAY NOZZLE
- DRY PILOT ACTUATOR
- REGULATOR
- FLOODING VALVE (GRINNELL MODULE B)
- PLUG VALVE N.O.
- PLUG VALVE N.C.
- MONITOR SWITCH
- BELL
- GLOBE VALVE - (CLOSED)

REFERENCES:

TITLE	MPL. NO.	DWG. NO.
1. TURBINE BUILDING - FIRE PROTECTION SYSTEM	2U43-1010	H-21016
2. TURBINE BUILDING - FIRE PROTECTION SYSTEM	2Z43-1010	H-21199
SHT. 2 OF 5		
3. FIRE PROTECTION - FCD - 2U43112W01	2U43	B-24630
4. BILL OF MATERIAL		NONE
5. WEST CABLEWAY (VENDOR)		SX-24976
6. INST. MANUAL		SX-29668
7. HEADER DETAILS		SX-26300
8. SPRINKLER DETAILS		H-26371
9. TURBINE BUILDING - FIRE PROTECTION SYSTEM - PLAN	2U43	H-21176
10. FIRE PROTECTION - FCD	2Z43	B-24689
	2Z43	B-24689

LICENSE RENEWAL DOCUMENT

MPL. NO. 2U43-1010 / 2Z43-1010 ACAD14 HL21198



LICENSE RENEWAL SCREENING FOR INFORMATION ONLY

EDWIN I. HATCH NUCLEAR PLANT UNIT No.2
TURBINE BUILDING
FIRE PROTECTION SYSTEM P&ID. SHT. 1 OF 5

Revision: A Date: 12-22-99
APPROVED, ISSUED PER LICENSE RENEWAL BOUNDARY PACKAGES. DRAWING CREATED FROM H-21198, REV. 10; ECB

BY	CHK'D	APP'D	DATE	SCALE	LOCATION	DOCUMENT NUMBER	REVISION
ECB	MDS	ASK		None	10-502	HL-21198	A

BOUNDARY DIAGRAM NO.: 2X43-B01-07
FUNCTION(S) NO.: 2X43-04, 2X43-06
 PREPARED BY: M. D. STEPHENS
 DATE: 02-06-98
 REVIEWED BY: ALEX MORRISON
 DATE: 07-13-98

2U43112W01
WEST CABLEWAY
FLR. EL. 112'-0"

SYSTEM NO 2Z43112W13
CONTROL BUILDING &
LUBE OIL STORAGE TANKS
FLR. EL. 112'-0"

