



SYSTEM NO. 2Z43130W23
 MAIN TURBINE LUBE OIL RESERVOIR
 OIL CONDITIONER & HYDRAULIC
 FLUID POWER UNIT AREA
 FLR. EL. 130'-0"

NOTES
 1. 2Z43130W23 EQUIPMENT & INSTRUMENTS ARE PREFIXED WITH 2Z43 UNLESS OTHERWISE NOTED.

LEGEND

	1/2" SPRINKLER HEAD (GRINNELL D-3 PROTECTOSPRAY NOZZLE)
	BREAK GLASS STATION
	MULTIPORT GAGE TEST VALVE
	BALL DRIP VALVE
	MULTIMATIC VALVE
	RESTRICTION CHECK VALVE
	ALARM VALVE
	RETARD CHAMBER
	PILOT HEAD (175°F)
	SPRAY NOZZLE
	DRY PILOT ACTUATOR
	REGULATOR
	ADDRESSABLE INTERFACE MODULE
	MONITOR SWITCH
	BELL
	HORN

REFERENCES

TITLE	MPL. NO	DWG. NO.
1. TURBINE BLDG. FIRE PROTECTION SYSTEM P&ID.	2U43-1010	H-21016
2. TURBINE BLDG. FIRE PROTECTION SYS. P&ID SHT. 1 OF 5.	2U43-1010	H-21198
3. FIRE PROTECTION FCD.	2Z43130W23	B-24701
4.		
5. FIRE PROT-PIPING LUBE OIL RSVR-EL. 130' & OIL STORAGE TANKS.	2Z43-1010	H-26371
6. TURBINE BLDG. FIRE PROT. SYS PLAN.	2U43-1010	H-21176
7. VALVE HEADER DETAILS		SX-26300

BOUNDARY DIAGRAM NO.: 2X43-B01-08
 FUNCTION(S) NO.: 2X43-04
 2X43-06
 PREPARED BY: M D STEPHENS
 DATE: 2/6/98
 REVIEWED BY: ALEX MORRISON
 DATE: 7/13/98

BOUNDARY DIAGRAM NO.: 2X43-B06-03
 FUNCTION(S) NO.: 2X43-06
 PREPARED BY: M D STEPHENS
 DATE: 3/19/98
 REVIEWED BY: ALEX MORRISON
 DATE: 7/15/98

LICENSE RENEWAL DOCUMENT

MPL No. 2Z43-1010 ACAD14 HL21199



LICENSE RENEWAL SCREENING FOR INFORMATION ONLY

EDWIN I. HATCH NUCLEAR PLANT UNIT No.2
 TURBINE BUILDING
 FIRE PROTECTION SYSTEM P&ID

Revision: A Date: 12-22-99
 APPROVED, ISSUED PER LICENSE RENEWAL BOUNDARY PACKAGES. DRAWING CREATED FROM H-21199, REV.8; BY TRM.

BY	CHK'D	APPR.	DATE	DESIGNED	LOCATION	DOCUMENT NUMBER	REVISION
TRM	LCF						
TRM	MDS	ASK					

10-502 HL-21199 A